

# DRAFT Facilities Operations PM Analysis from 6/1/2015 through 6/30/2015

Requested Finished Open WND							% Finished
<b>Engineering</b>		<b>587</b>	<b>330</b>	<b>257</b>	<b>0</b>		<b>56%</b>
<b>E - Auxiliary</b>		<b>30</b>	<b>15</b>	<b>15</b>	<b>0</b>		<b>50%</b>
FO-317581	Created By PM Schedule	034-AIR-001	6/1/2015		False	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317582	Created By PM Schedule	034-AIR-002	6/1/2015		False	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317590	Created By PM Schedule	134-AHU-001	6/1/2015		False	0.00 PM - Air Handling Unit	
FO-317591	Created By PM Schedule	134-AHU-002	6/1/2015		False	PM - Air Handling Unit	
FO-317592	Created By PM Schedule	127-MAU-005	6/1/2015		False	PM - Fan Coil/HV/AC Unit	
FO-317593	Created By PM Schedule	501-ACU-001	6/1/2015		False	PM - Water/Air Cooled Condenser	
FO-317594	Finished	992-ES-001*	6/1/2015	6/5/2015	False	PM - Emergency Shower/Eyewash Station	
FO-317596	Finished	134-ACU-001	6/1/2015	6/15/2015	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-317606	Finished	507-ACU-001	6/1/2015	6/15/2015	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-317611	Created By PM Schedule	134-FP-001	6/1/2015		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-317612	Created By PM Schedule	127-FP-001	6/1/2015		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-317613	Created By PM Schedule	115-FP-001	6/1/2015		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-317614	Created By PM Schedule	104-FP-001	6/1/2015		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-317615	Created By PM Schedule	507-FP-001	6/1/2015		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-317627	Created By PM Schedule	136-BSG-004	6/1/2015		False	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~	
FO-317628	Created By PM Schedule	136-BSG-003	6/1/2015		False	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~	
FO-317629	Created By PM Schedule	136-BSG-002	6/1/2015		False	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~	
FO-317630	Created By PM Schedule	136-BSG-001	6/1/2015		False	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~	
FO-317981	Finished	501-GEN-001	6/9/2015	6/10/2015	False	Generator Maintenance, Monthly	
FO-317983	Finished	992-ES-001*	6/8/2015	6/12/2015	False	PM - Emergency Shower/Eyewash Station	
FO-318495	Finished	507-GEN-001	6/10/2015	6/11/2015	False	Generator Maintenance, Monthly	
FO-318499	Finished	992-ES-001*	6/15/2015	6/19/2015	False	PM - Emergency Shower/Eyewash Station	
FO-319074	Finished	104-GEN-001	6/23/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319076	Finished	127-GEN-001	6/23/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319078	Finished	127-GEN-002	6/23/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319080	Finished	127-GEN-003	6/23/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319082	Finished	127-GEN-004	6/23/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319086	Finished	536-GEN-001	6/17/2015	6/24/2015	False	Generator Maintenance, Monthly	
FO-319230	Finished	992-ES-001*	6/22/2015	6/26/2015	False	PM - Emergency Shower/Eyewash Station	
FO-319766	Finished	992-ES-001*	6/29/2015	6/30/2015	False	PM - Emergency Shower/Eyewash Station	
<b>E - MedPharm</b>		<b>44</b>	<b>17</b>	<b>27</b>	<b>0</b>		<b>39%</b>
FO-317435	Created By PM Schedule	603-HEX-001	6/1/2015		False	PM - Heat Exchanger and Economizer	
FO-317436	Created By PM Schedule	603-HEX-002	6/1/2015		False	PM - Heat Exchanger and Economizer	
FO-317437	Created By PM Schedule	603-HEX-003*	6/1/2015		False	PM - Heat Exchanger and Economizer	
FO-317439	Created By PM Schedule	603-SP-001*	6/1/2015		False	PM - Sump Pump	
FO-317440	Created By PM Schedule	603-SP-002*	6/1/2015		False	PM - Sump Pump	

**Requested Finished Open WND**

**% Finished**

FO-317441	Finished	609-ECO-001	6/1/2015	6/18/2015	False		PM - Heat Exchanger and Economizer
done							
FO-317442	Created By PM Schedule	611-AIR-001C**	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317443	Created By PM Schedule	611-HVU-001**	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-317444	Created By PM Schedule	611-HVU-004**	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-317445	Created By PM Schedule	629-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317446	Finished	629-ROS-001	6/1/2015	6/16/2015	False	2.00	PM - Reverse Osmosis Water Softener System
FO-317447	Created By PM Schedule	612-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317448	Finished	612-AIR-002	6/1/2015	6/25/2015	False	0.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317449	Finished	612-AIR-003	6/1/2015	6/25/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317450	Finished	612-SP-001	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-317451	Finished	612-SP-002	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-317452	Finished	612-SP-003	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-317453	Created By PM Schedule	603-HEX-004*	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317454	Created By PM Schedule	611-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317455	Finished	629-WSS-001	6/1/2015	6/16/2015	False	2.00	PM - Water Softener
FO-317456	Finished	629-GFP-001	6/1/2015	6/30/2015	False	0.10	PM - Centrifugal Pump, over 1 H.P.
FO-317457	Finished	629-GFP-002	6/1/2015	6/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-317458	Finished	612-ACU-002	6/1/2015	6/19/2015	False	8.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317459	Created By PM Schedule	612-ACU-001	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317460	Created By PM Schedule	611-ACU-002**	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317461	Created By PM Schedule	611-ACU-001**	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317462	Finished	608-ACU-001	6/1/2015	6/5/2015	False	4.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317463	Created By PM Schedule	603-ACU-002	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317464	Created By PM Schedule	603-ACU-001	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317465	Finished	608-ACU-002	6/1/2015	6/5/2015	False	4.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317466	Finished	629-BSG-003	6/1/2015	6/24/2015	False	7.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317467	Created By PM Schedule	629-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317468	Created By PM Schedule	629-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317469	Created By PM Schedule	603-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317470	Created By PM Schedule	620-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317471	Created By PM Schedule	620-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317472	Finished	608-BSG-002	6/1/2015	6/30/2015	False	8.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317473	Finished	608-BSG-001	6/1/2015	6/30/2015	False	8.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317474	Created By PM Schedule	629-EOS-001	6/1/2015		False		Replace PRE-filters
FO-317960	Created By PM Schedule	603-CRP-001	6/6/2015		False		PM - Condensate Return Pump
FO-317961	Created By PM Schedule	603-CRP-002	6/6/2015		False		PM - Condensate Return Pump

## Requested Finished Open WND

% Finished

FO-318458	Finished	609-GEN-001	6/16/2015	6/18/2015	False		Generator Maintenance, Monthly checked fluids and battery
FO-319070	Created By PM Schedule	611-GEN-001	6/26/2015		False		Generator Maintenance, Monthly
FO-319072	Created By PM Schedule	629-GEN-001	6/26/2015		False		Generator Maintenance, Monthly
<b>E - North</b>			<b>38</b>	<b>26</b>	<b>12</b>	<b>0</b>	<b>68%</b>
FO-317475	Created By PM Schedule	140-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317476	Finished	140-AIR-002	6/1/2015	6/24/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317477	Finished	050-AIR-001	6/1/2015	6/29/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317478	Finished	050-AIR-002	6/1/2015	6/29/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317479	Finished	049-DWBP-001	6/1/2015	6/19/2015	False	0.50	PM - Water Booster Pump
FO-317480	Finished	049-DWBP-002	6/1/2015	6/19/2015	False	0.50	PM - Water Booster Pump
FO-317481	Created By PM Schedule	048-HEX-001	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317482	Finished	048-HEX-002	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317483	Finished	027-HEX-001	6/1/2015	6/2/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-317484	Finished	027-HEX-002	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317485	Finished	027-HEX-003	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317486	Finished	027-HEX-004	6/1/2015	6/2/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-317487	Finished	036-HEX-001	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317488	Finished	036-HEX-002	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317489	Finished	048-DHW-001	6/1/2015	6/15/2015	False	0.40	PM - Domestic Water Heater, Steam
FO-317490	Created By PM Schedule	130-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317491	Finished	046-HEX-001	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317492	Created By PM Schedule	046-HEX-002	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317493	Finished	046-HEX-003	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317494	Finished	046-HEX-004	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317495	Created By PM Schedule	046-HEX-005	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317496	Finished	048-HEX-003	6/1/2015	6/15/2015	False	0.40	PM - Heat Exchanger and Economizer
FO-317497	Finished	048-DWBP-001	6/1/2015	6/15/2015	False	0.40	PM - Water Booster Pump
FO-317498	Finished	048-DWBP-002	6/1/2015	6/2/2015	False	0.40	PM - Water Booster Pump
FO-317499	Finished	049-HWP-001	6/1/2015	6/19/2015	False	0.45	PM - Water Booster Pump
FO-317500	Created By PM Schedule	062-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317501	Finished	026-HEX-002	6/1/2015	6/10/2015	False	1.00	PM - Heat Exchanger and Economizer
FO-317502	Finished	026-ACU-004	6/1/2015	5/26/2015	False	1.00	PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317503	Created By PM Schedule	048-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317504	Created By PM Schedule	048-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317505	Created By PM Schedule	038-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317506	Finished	038-BSG-001	6/1/2015	6/23/2015	False	4.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
Boiler #1 inspected by state and DJ Connely. Proceeding to close and put back on line.							
FO-317507	Created By PM Schedule	026-BSG-002	6/1/2015		False	0.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317508	Created By PM Schedule	026-BSG-001	6/1/2015		False	0.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

**Requested Finished Open WND**

**% Finished**

FO-318459	Created By PM Schedule	043-AHU-INT	6/15/2015		False		PM - Outside/Fresh Air Intake Screens
FO-318460	Finished	048-GEN-001	6/12/2015	6/12/2015	False	0.65	Generator Maintenance, Monthly
FO-319084	Finished	130-GEN-001	6/24/2015	6/25/2015	False	1.00	Generator Maintenance, Monthly
FO-319213	Finished	048-EW-001	6/18/2015	6/18/2015	False	0.25	PM - Emergency Shower/Eyewash Station - Annual Flow Test
<b>E - Northeast</b>			<b>26</b>	<b>12</b>	<b>14</b>	<b>0</b>	<b>46%</b>
FO-317509	Created By PM Schedule	193-HEX-001	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317510	Created By PM Schedule	193-HEX-002	6/1/2015		False		PM - Heat Exchanger and Economizer
FO-317511	Created By PM Schedule	067-ACU-109	6/1/2015		False	0.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317512	Finished	065-ACU-001	6/1/2015	6/18/2015	False		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317513	Created By PM Schedule	067-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317514	Created By PM Schedule	067-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317515	Created By PM Schedule	193-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317516	Created By PM Schedule	193-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317517	Finished	064-BSG-002	6/1/2015	6/22/2015	False	2.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317518	Finished	064-BSG-001	6/1/2015	6/22/2015	False	2.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317519	Finished	217-BSG-001	6/1/2015	6/9/2015	False	2.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
worked with Detroit boiler tech. inspection report in boiler room							
FO-317963	Finished	193-GEN-001	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317964	Finished	193-GEN-002	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317965	Finished	193-GEN-003	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317966	Finished	193-GEN-004	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-318461	Created By PM Schedule	203-GEN-001	6/16/2015		False		Generator Maintenance, Monthly
FO-318462	Created By PM Schedule	062-DHW-006	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-318463	Created By PM Schedule	062-DHW-005	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-318464	Created By PM Schedule	062-DHW-004	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-318465	Created By PM Schedule	062-DHW-003	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-318466	Created By PM Schedule	062-DHW-002	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-318467	Created By PM Schedule	062-DHW-001	6/12/2015		False		PM - Domestic Water Heater, Gas
FO-319067	Finished	066-GEN-001	6/24/2015	6/22/2015	False	1.00	Generator Maintenance, Monthly
generator checked. coolant was low. distilled water added to prevent damage if unit is run. hose connections leak and look corroded. oil leak from gasket on North side of unit as well.							
FO-319088	Finished	527-GEN-001	6/18/2015	6/18/2015	False	1.50	Generator Maintenance, Monthly
completed test							
FO-319094	Finished	060-GEN-001A	6/25/2015	6/18/2015	False		Generator Maintenance, Monthly
no access. new unit. under warranty. I have not received a key yet.							
FO-319096	Finished	060-GEN-001B	6/25/2015	6/18/2015	False		Generator Maintenance, Monthly
no access. new unit. under warranty. I have not received a key yet.							
<b>E - Preventative Maintenance</b>			<b>264</b>	<b>147</b>	<b>117</b>	<b>0</b>	<b>56%</b>
FO-316179	Finished	005-EXF-013	6/1/2015	6/27/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

**Requested Finished Open WND**

**% Finished**

FO-316180	Finished	005-EXF-014	6/1/2015	6/27/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316181	Finished	050-RAF-001	6/1/2015	5/27/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316182	Created By PM Schedule	01-FCU-002HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316183	Created By PM Schedule	01-FCU-003HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316184	Created By PM Schedule	01-FCU-003LOB	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316185	Created By PM Schedule	01-FCU-004HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316186	Created By PM Schedule	01-FCU-005HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316187	Created By PM Schedule	01-FCU-006HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316188	Created By PM Schedule	01-FCU-007HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316189	Created By PM Schedule	01-FCU-008HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316190	Created By PM Schedule	01-FCU-009HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316191	Created By PM Schedule	01-FCU-010HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316192	Created By PM Schedule	01-FCU-011HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316193	Created By PM Schedule	01-FCU-012HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316194	Created By PM Schedule	01-FCU-013HCF	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316195	Created By PM Schedule	001-FCU-3121	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316196	Created By PM Schedule	001-FCU-3129	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316197	Created By PM Schedule	001-FCU-3133-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316198	Created By PM Schedule	001-FCU-3133-2	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316199	Created By PM Schedule	001-FCU-3133-3	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316200	Created By PM Schedule	001-FCU-3133-4	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316201	Created By PM Schedule	001-FCU-3133-5	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316202	Created By PM Schedule	001-FCU-3134-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316203	Created By PM Schedule	001-FCU-3134-2	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316204	Created By PM Schedule	001-FCU-3134-3	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316205	Created By PM Schedule	001-FCU-3134-4	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316206	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316207	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316208	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316209	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316210	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316211	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316212	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316213	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316214	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316215	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316216	Created By PM Schedule	001-FCU-3141-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316217	Created By PM Schedule	001-FCU-3141-2	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316218	Created By PM Schedule	001-FCU-3141-3	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316219	Created By PM Schedule	001-FCU-3141-4	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316220	Created By PM Schedule	001-FCU-3141-5	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316221	Created By PM Schedule	001-FCU-3141-6	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316222	Created By PM Schedule	001-FCU-3141-7	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316223	Created By PM Schedule	001-FCU-3141-8	6/1/2015		False		PM - Fan Coil/HV/AC Unit

**Requested Finished Open WND**

**% Finished**

FO-316224	Created By PM Schedule	001-FCU-3141-9	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316225	Created By PM Schedule	001-FCU-3202	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316226	Created By PM Schedule	001-FCU-3203	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316227	Created By PM Schedule	001-FCU-3204	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316228	Created By PM Schedule	001-FCU-3207-1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316229	Created By PM Schedule	001-FCU-3207.2	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316230	Created By PM Schedule	039-EXF-001	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316231	Created By PM Schedule	039-EXF-004	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316232	Created By PM Schedule	039-EXF-005	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316233	Finished	040-EXF-002	6/1/2015	5/16/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316234	Finished	040-EXF-003	6/1/2015	5/28/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316235	Finished	040-EXF-005	6/1/2015	5/16/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316236	Finished	040-EXF-006	6/1/2015	5/28/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316237	Finished	040-EXF-007	6/1/2015	5/19/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316238	Finished	040-EXF-008	6/1/2015	5/25/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316239	Finished	040-EXF-009	6/1/2015	5/19/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316240	Finished	040-EXF-010	6/1/2015	5/25/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316241	Finished	040-EXF-011	6/1/2015	5/20/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316242	Finished	040-EXF-012	6/1/2015	5/25/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316243	Created By PM Schedule	042-EXF-001	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316244	Created By PM Schedule	043-EXF-001	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316245	Created By PM Schedule	043-EXF-002	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316246	Created By PM Schedule	043-EXF-003	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316247	Created By PM Schedule	043-EXF-004	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316248	Created By PM Schedule	043-EXF-005	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316249	Finished	005-EXF-003	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316250	Finished	005-EXF-005	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316251	Finished	005-EXF-006	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316252	Finished	005-EXF-007	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316253	Finished	005-EXF-009	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316254	Finished	005-EXF-016	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316255	Finished	005-EXF-017	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316256	Finished	005-EXF-018	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316257	Finished	005-EXF-022	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316258	Finished	005-EXF-023	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316259	Finished	005-EXF-034	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316260	Finished	005-EXF-037	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316261	Finished	005-EXF-038	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316262	Finished	005-EXF-039	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316263	Finished	005-EXF-040	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316264	Finished	005-EXF-041	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316265	Finished	005-EXF-042	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316266	Finished	005-EXF-043	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316267	Finished	006-EXF-001	6/1/2015	6/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

**Requested Finished Open WND**

**% Finished**

FO-316268	Finished	006-EXF-002	6/1/2015	6/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316269	Finished	006-EXF-003	6/1/2015	6/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316270	Finished	006-EXF-004	6/1/2015	6/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316271	Created By PM Schedule	065-EXF-001A	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316272	Created By PM Schedule	065-EXF-001B	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316273	Created By PM Schedule	065-EXF-001C	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316274	Created By PM Schedule	065-EXF-002	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316275	Created By PM Schedule	065-EXF-003	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316276	Created By PM Schedule	067-EXF-001	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316277	Created By PM Schedule	067-EXF-002	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316278	Created By PM Schedule	067-EXF-003	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316279	Created By PM Schedule	067-EXF-004	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316280	Finished	008-EXF-001	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316281	Finished	008-EXF-002	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316282	Created By PM Schedule	001-FCU-3125	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316283	Created By PM Schedule	001-FCU-3125.1	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316284	Created By PM Schedule	001-FCU-3125.2	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316285	Created By PM Schedule	001-FCU-3125.3	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316286	Created By PM Schedule	001-FCU-3207.3	6/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-316287	Finished	005-EXF-030	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316288	Finished	005-EXF-031	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316289	Finished	005-EXF-032	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316290	Finished	005-EXF-033	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316291	Finished	005-EXF-035	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316292	Finished	005-EXF-036	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316293	Finished	005-EXF-004	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316294	Finished	005-EXF-008	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316295	Finished	005-EXF-015	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316296	Finished	005-EXF-020	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316297	Finished	005-EXF-025	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316298	Finished	005-EXF-026	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316299	Finished	005-EXF-027	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316300	Finished	005-EXF-028	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316301	Finished	005-EXF-029	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316302	Finished	603-EXF-005	6/7/2015	7/1/2015	False	0.50	Animal Lab Filter Changes for Applelebaum
FO-316303	Finished	046-FAP-001	6/1/2015	6/24/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316304	Finished	048-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316305	Finished	049-FAP-001	6/1/2015	6/24/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316306	Finished	156-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316307	Finished	499-FAP-001	6/1/2015	6/16/2015	False	6.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316308	Finished	620-FAP-001	6/1/2015	6/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316309	Finished	036-FP-001	6/1/2015	6/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316310	Finished	025-FP-001	6/1/2015	6/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316311	Finished	007-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

**Requested Finished Open WND**

**% Finished**

FO-316312	Finished	001-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316313	Finished	005-FAP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316314	Finished	040-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316315	Finished	038-FAP-001	6/1/2015	6/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316316	Finished	028-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316317	Finished	026-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316318	Finished	022-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316319	Finished	017-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316320	Finished	016-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316321	Finished	003-FAP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316322	Finished	006-FP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316323	Finished	050-FAP-001	6/1/2015	6/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316324	Finished	043-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316325	Finished	042-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316326	Finished	062-FP-001	6/1/2015	6/6/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316327	Finished	065-FP-001	6/1/2015	6/24/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316328	Finished	068-FAP-001	6/1/2015	6/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316329	Finished	067-FP-001	6/1/2015	6/22/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316330	Finished	089-FP-001	6/1/2015	6/29/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316331	Finished	082-FP-001	6/1/2015	6/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316332	Finished	080-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316333	Finished	090-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316334	Finished	155-FP-001	6/1/2015	6/12/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316335	Finished	150-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316336	Finished	167-FAP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316337	Finished	166-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316338	Finished	140-FAP-001	6/1/2015	6/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316339	Finished	130-FP-001	6/1/2015	6/6/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316340	Finished	193-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316341	Finished	189-FP-001	6/1/2015	6/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316342	Finished	510-FAP-001	6/1/2015	6/4/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316343	Finished	509-FAP-001	6/1/2015	6/4/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316344	Finished	504-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316345	Finished	629-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316346	Finished	612-FP-001	6/1/2015	6/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316347	Finished	611-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316348	Finished	609-FP-001	6/1/2015	6/19/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316349	Finished	603-FP-001	6/1/2015	6/19/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316350	Finished	608-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316351	Finished	603-AHU-009	6/1/2015	6/25/2015	False	6.00	Replace PRE-filters
FO-316352	Finished	603-AHU-008	6/1/2015	7/1/2015	False	3.00	Replace PRE-filters
FO-316353	Finished	603-AHU-007	6/1/2015	7/1/2015	False	3.00	Replace PRE-filters
FO-316354	Finished	603-AHU-006	6/1/2015	6/25/2015	False	6.00	Replace PRE-filters
FO-316366	Finished	637-AHU-004	6/1/2015	6/15/2015	False	3.00	Replace PRE-filters



**Requested Finished Open WND**

**% Finished**

FO-316367	Finished	637-AHU-003	6/1/2015	6/12/2015	False	3.00	Replace PRE-filters
FO-316368	Created By PM Schedule	637-AHU-002	6/1/2015		False		Replace PRE-filters
FO-316369	Created By PM Schedule	637-AHU-001A	6/1/2015		False		Replace PRE-filters
FO-316370	Created By PM Schedule	637-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316371	Finished	074-FAP-001	6/1/2015	6/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316372	Finished	005-AHU-003	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316373	Finished	005-AHU-002	6/1/2015	6/17/2015	False	2.50	Replace PRE-filters
FO-316374	Finished	005-AHU-001	6/1/2015	6/17/2015	False	2.50	Replace PRE-filters
FO-316375	Finished	089-AHU-006	6/1/2015	6/11/2015	False	1.00	Replace PRE-filters
FO-316376	Finished	089-AHU-005	6/1/2015	6/11/2015	False	2.00	Replace PRE-filters
FO-316377	Finished	089-AHU-004	6/1/2015	6/11/2015	False	1.00	Replace PRE-filters
FO-316378	Finished	089-AHU-003	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316379	Finished	089-AHU-002	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316380	Finished	089-AHU-001	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316381	Finished	008-AHU-005	6/1/2015	6/8/2015	False	1.50	Replace PRE-filters
FO-316382	Finished	008-AHU-004	6/1/2015	6/8/2015	False	2.00	Replace PRE-filters
FO-316383	Finished	008-AHU-002	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316384	Finished	008-AHU-001	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316385	Finished	006-AHU-005	6/1/2015	6/24/2015	False	1.00	Replace PRE-filters
FO-316386	Finished	006-AHU-004	6/1/2015	6/15/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316387	Finished	006-AHU-003	6/1/2015	6/15/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316388	Finished	006-AHU-002	6/1/2015	6/18/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316389	Finished	006-AHU-001	6/1/2015	6/18/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-316390	Finished	008-EXF-005	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316391	Finished	008-EXF-004	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316392	Finished	008-EXF-003	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316393	Created By PM Schedule	140-AHU-004	6/1/2015		False		Replace PRE-filters
FO-316394	Created By PM Schedule	140-AHU-003	6/1/2015		False		Replace PRE-filters
FO-316395	Created By PM Schedule	140-AHU-002	6/1/2015		False		Replace PRE-filters
FO-316396	Created By PM Schedule	140-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316397	Created By PM Schedule	189-AHU-002	6/1/2015		False		Replace PRE-filters
FO-316398	Created By PM Schedule	189-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316399	Created By PM Schedule	042-SAF-013	6/1/2015		False		Replace PRE-filters
FO-316400	Created By PM Schedule	042-SAF-012	6/1/2015		False		Replace PRE-filters
FO-316401	Created By PM Schedule	042-SAF-001	6/1/2015		False		Replace PRE-filters
FO-316402	Created By PM Schedule	042-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316403	Created By PM Schedule	040-SAF-004	6/1/2015		False		Replace PRE-filters
FO-316404	Finished	040-SAF-003	6/1/2015	5/21/2015	False	1.50	Replace PRE-filters
FO-316405	Finished	040-SAF-002	6/1/2015	5/19/2015	False	1.00	Replace PRE-filters
FO-316406	Created By PM Schedule	039-SAF-009	6/1/2015		False		Replace PRE-filters
FO-316407	Created By PM Schedule	039-SAF-008	6/1/2015		False		Replace PRE-filters
FO-316408	Created By PM Schedule	039-SAF-007	6/1/2015		False		Replace PRE-filters
FO-316409	Created By PM Schedule	039-SAF-006	6/1/2015		False		Replace PRE-filters
FO-316410	Finished	039-SAF-005	6/1/2015	5/21/2015	False	1.00	Replace PRE-filters

## Requested Finished Open WND

% Finished

FO-316411	Created By PM Schedule	039-SAF-004	6/1/2015		False		Replace PRE-filters
FO-316412	Created By PM Schedule	039-SAF-003	6/1/2015		False		Replace PRE-filters
FO-316413	Created By PM Schedule	039-SAF-002	6/1/2015		False		Replace PRE-filters
FO-316414	Finished	039-SAF-001	6/1/2015	5/21/2015	False	2.00	Replace PRE-filters
FO-316415	Created By PM Schedule	038-SAF-004	6/1/2015		False		Replace PRE-filters
FO-316416	Created By PM Schedule	038-SAF-003	6/1/2015		False		Replace PRE-filters
FO-316417	Created By PM Schedule	038-SAF-002	6/1/2015		False		Replace PRE-filters
FO-316418	Created By PM Schedule	038-SAF-001	6/1/2015		False		Replace PRE-filters
FO-316419	Created By PM Schedule	189-HVU-001	6/1/2015		False		Replace PRE-filters
FO-316420	Created By PM Schedule	189-HVU-002	6/1/2015		False		Replace PRE-filters
FO-316421	Created By PM Schedule	043-HVU-001	6/1/2015		False		Replace PRE-filters
FO-316422	Created By PM Schedule	043-AHU-003	6/1/2015		False		Replace PRE-filters
FO-316423	Created By PM Schedule	043-AHU-002	6/1/2015		False		Replace PRE-filters
FO-316424	Created By PM Schedule	043-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316427	Finished	096-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316428	Created By PM Schedule	085-ACU-001	6/1/2015		False		Replace PRE-filters
FO-316429	Finished	050-AHU-001	6/1/2015	6/29/2015	False	3.00	Replace PRE-filters
FO-316430	Created By PM Schedule	065-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316431	Created By PM Schedule	067-AHU-003	6/1/2015		False		Replace PRE-filters
FO-316432	Created By PM Schedule	067-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316433	Finished	609-AHU-005	6/1/2015	6/18/2015	False	3.00	Replace PRE-filters
FO-316434	Finished	609-AHU-004	6/1/2015	6/18/2015	False	3.00	Replace PRE-filters
FO-316435	Finished	609-AHU-003B	6/1/2015	6/19/2015	False	3.00	Replace PRE-filters
FO-316436	Finished	609-AHU-003A	6/1/2015	6/19/2015	False	3.00	Replace PRE-filters
FO-316437	Finished	609-AHU-002	6/1/2015	6/23/2015	False	3.00	Replace PRE-filters
FO-316438	Finished	609-AHU-001	6/1/2015	6/24/2015	False	3.00	Replace PRE-filters
FO-316439	Created By PM Schedule	067-EXF-005	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316440	Created By PM Schedule	067-EXF-006	6/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316441	Created By PM Schedule	001-AHU-004O	6/1/2015		False		Replace PRE-filters
FO-316442	Created By PM Schedule	001-AHU-003O	6/1/2015		False		Replace PRE-filters
FO-316443	Created By PM Schedule	001-AHU-003ML	6/1/2015		False		Replace PRE-filters
FO-316444	Created By PM Schedule	001-AHU-002O	6/1/2015		False		Replace PRE-filters
FO-316445	Created By PM Schedule	001-AHU-002ML	6/1/2015		False		Replace PRE-filters
FO-316446	Created By PM Schedule	001-AHU-002	6/1/2015		False		Replace PRE-filters
FO-316447	Created By PM Schedule	001-AHU-001O	6/1/2015		False		Replace PRE-filters
FO-316448	Created By PM Schedule	001-AHU-001ML	6/1/2015		False		Replace PRE-filters
FO-316449	Created By PM Schedule	001-AHU-001	6/1/2015		False		Replace PRE-filters
FO-316450	Finished	169-FAP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316451	Finished	608-AHU-004	6/1/2015	6/10/2015	False	3.00	Replace PRE-filters
FO-316452	Finished	608-AHU-003	6/1/2015	6/10/2015	False	2.00	Replace PRE-filters
FO-316453	Finished	608-AHU-002	6/1/2015	6/9/2015	False	2.00	Replace PRE-filters
FO-316454	Finished	608-AHU-001	6/1/2015	6/9/2015	False	3.00	Replace PRE-filters
FO-316459	Finished	008-AHU-003	6/1/2015	6/9/2015	False	2.50	Replace PRE-filters
<b>E - South</b>			<b>49</b>	<b>38</b>	<b>11</b>	<b>0</b>	<b>78%</b>

**Requested Finished Open WND**

**% Finished**

FO-316465	Finished	007-AHU-007	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316466	Finished	007-AHU-006	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316467	Finished	007-AHU-005	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316468	Finished	007-AHU-004	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316469	Finished	007-AHU-003	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316470	Finished	007-EXF-002	6/13/2015	6/13/2015	False	2.00	Replace PRE-filters
FO-316471	Finished	007-EXF-001	6/13/2015	6/13/2015	False	2.00	Replace PRE-filters
FO-316472	Finished	007-AHU-002	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316473	Finished	007-AHU-001	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316474	Created By PM Schedule	007-BSG-004	6/1/2015		False	0.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316475	Finished	007-BSG-003	6/1/2015	6/3/2015	False	0.50	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316476	Finished	007-BSG-002	6/1/2015	6/3/2015	False	0.50	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316477	Created By PM Schedule	007-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317520	Finished	022-AIR-001	6/1/2015	6/2/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.  Checked operation of the unit, checked for any unusual noise and vibration. Checked the belts and sheaves. Drained the main tank. checked the air filter and it was clean. Did not change oil this time, ( it was clear and was changed on last service. Checked operation of the air dryer and cleaned it's coils. checked the moisture and oil trap. Cleaned the equipment.
FO-317568	Finished	096-DWBP-001	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317569	Finished	096-DWBP-002	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317570	Finished	096-DHW-001	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317571	Finished	096-DHW-003	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317572	Finished	096-DHW-004	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317573	Finished	096-DWBP-002	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317578	Created By PM Schedule	028-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317595	Finished	090-WSS-001	6/1/2015	6/1/2015	False	1.00	PM - Water Softener
FO-317597	Finished	090-ACU-403	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317598	Finished	090-ACU-402	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317599	Finished	090-ACU-401	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317600	Created By PM Schedule	022-ACU-001	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317601	Finished	007-ACU-002	6/1/2015	6/24/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317602	Finished	007-ACU-001	6/1/2015	6/24/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317610	Finished	096-ACU-001	6/1/2015	6/1/2015	False	10.00	PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317631	Created By PM Schedule	090-BSG-004	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317632	Created By PM Schedule	090-BSG-003	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317633	Created By PM Schedule	090-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317634	Created By PM Schedule	090-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317635	Created By PM Schedule	016-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

**Requested Finished Open WND**

**% Finished**

FO-317636	Created By PM Schedule	016-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317652	Created By PM Schedule	028-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317974	Finished	096-DWBP-003	6/6/2015	6/18/2015	False	1.00	PM - Clayton Valves for Booster Pumps (UGL)
FO-317975	Finished	096-SP-001	6/6/2015	6/18/2015	False	1.00	PM - Sump Pump
FO-317976	Finished	096-DWBP-003	6/6/2015	6/23/2015	False	1.00	PM - Clayton Valves for Booster Pumps (UGL)
FO-317977	Finished	090-ACU-CR2	6/8/2015	6/16/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-317978	Finished	090-ACU-CR1	6/8/2015	6/19/2015	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-317987	Finished	005-EW-001	6/4/2015	6/16/2015	False	1.00	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-318468	Finished	096-CFP-003	6/13/2015	6/18/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-318482	Finished	007-GEN-001	6/11/2015	6/11/2015	False	0.50	Generator Maintenance, Monthly
FO-318484	Finished	007-GEN-002	6/11/2015	6/11/2015	False	0.50	Generator Maintenance, Monthly
FO-318486	Finished	090-GEN-001	6/16/2015	6/16/2015	False	1.00	Generator Maintenance, Monthly
FO-318498	Finished	090-GEN-002	6/11/2015	6/11/2015	False	1.00	Generator Maintenance, Monthly
FO-319065	Finished	089-GEN-001	6/17/2015	6/23/2015	False	1.00	Generator Maintenance, Monthly
FO-319090	Finished	006-GEN-001	6/18/2015	6/18/2015	False	0.60	Generator Maintenance, Monthly

**E - Southeast**

**113**

**69**

**44**

**0**

**61%**

FO-317521	Finished	001-HEX-001SW	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM, CLEAN AREA.							
FO-317522	Finished	001-HEX-001WM	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM, CLEAN AREA.							
FO-317523	Finished	001-HEX-002SW	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM , CLEAN AREA.							
FO-317524	Finished	001-HEX-002WM	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM , CLEAN AREA.							
FO-317526	Finished	071-ACU-003	6/1/2015	5/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-317527	Finished	071-ACU-006	6/1/2015	5/25/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-317528	Finished	071-HWP-005	6/1/2015	5/26/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317529	Finished	071-HWP-006	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317530	Finished	071-HWP-007	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317531	Finished	071-HWP-008	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317532	Finished	071-HWP-009	6/1/2015	5/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317533	Finished	071-HWP-010	6/1/2015	5/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317534	Finished	071-HWP-011	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317535	Finished	071-HWP-012	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317536	Finished	071-HWP-013	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317537	Finished	071-HWP-014	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317538	Finished	071-HWP-015	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317539	Finished	071-HWP-016	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317540	Finished	071-HWP-017	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317541	Finished	071-HWP-018	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317542	Finished	071-HWP-019	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317543	Finished	071-HWP-020	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317544	Finished	071-HWP-021	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)

**Requested Finished Open WND**

**% Finished**

FO-317545	Finished	071-HWP-022	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317546	Finished	071-HWP-023	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317547	Finished	071-HWP-187	6/1/2015	5/11/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317548	Finished	071-HWP-188	6/1/2015	5/11/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317549	Finished	071-HWP-189	6/1/2015	5/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317550	Finished	071-HWP-190	6/1/2015	5/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317551	Finished	071-HWP-191	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317552	Finished	071-HWP-192	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317553	Finished	071-HWP-193	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317554	Finished	071-HWP-194	6/1/2015	5/14/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317555	Finished	071-HWP-195	6/1/2015	5/14/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317556	Finished	071-HWP-196	6/1/2015	5/15/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317557	Finished	071-HWP-197	6/1/2015	5/15/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317558	Finished	071-HWP-198	6/1/2015	5/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317559	Finished	071-HWP-199	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317560	Finished	071-HWP-200	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317561	Finished	071-HWP-201	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317562	Finished	071-HWP-202	6/1/2015	5/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317563	Finished	071-HWP-203	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317564	Finished	071-HWP-204	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317565	Finished	071-HWP-205	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317566	Finished	071-HWP-215	6/1/2015	5/28/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317567	Finished	071-HWP-216	6/1/2015	5/28/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317574	Finished	016-SP-003	6/1/2015	6/17/2015	False	1.00	PM - Sump Pump

Checked the operation of the unit. Checked float switch for proper operation. Lubricated motor bearings.  
checked oil level in pump seal cavity and bearing. Checked motor and pump for proper alignment and possible vibration. cleaned the unit.

FO-317575	Finished	016-SP-004	6/1/2015	6/17/2015	False	1.00	PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	------	----------------

Checked the operation of the unit. Checked float switch for proper operation. Lubricated motor bearings.  
checked oil level in pump seal cavity and bearing. Checked motor and pump for proper alignment and possible vibration. cleaned the unit.

FO-317576	Finished	023-SP-001	6/1/2015	6/22/2015	False		PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	--	----------------

Checked operation of the unit, checked it's float switch operation. Lubricated motor bearings, checked pump bearing and seal oil level. checked the motor and pump for alignment . Cleaned the unit.

FO-317577	Finished	023-SP-002	6/1/2015	6/22/2015	False		PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	--	----------------

Checked operation of the unit, checked it's float switch operation. Lubricated motor bearings, checked pump bearing and seal oil level. checked the motor and pump for alignment . Cleaned the unit.

FO-317579	Created By PM Schedule	189-HEX-001	6/1/2015		False		PM - Heat Exchanger and Economizer
-----------	------------------------	-------------	----------	--	-------	--	------------------------------------

FO-317584	Finished	071-HWP-222	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317585	Finished	071-HWP-223	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317586	Finished	071-HWP-224	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317587	Finished	071-HWP-225	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317588	Finished	071-HWP-226	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317589	Finished	071-HWP-227	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317603	Created By PM Schedule	001-ACU-003	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
-----------	------------------------	-------------	----------	--	-------	--	--

FO-317604	Created By PM Schedule	001-ACU-002	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
-----------	------------------------	-------------	----------	--	-------	--	--

**Requested Finished Open WND**

**% Finished**

FO-317605	Created By PM Schedule	001-ACU-001	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317607	Created By PM Schedule	189-ACU-003	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317608	Created By PM Schedule	609-ACU-002	6/1/2015		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317609	Created By PM Schedule	609-ACU-001	6/1/2015		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317616	Created By PM Schedule	637-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317617	Created By PM Schedule	637-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317618	Created By PM Schedule	609-BSG-003	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317619	Created By PM Schedule	609-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317620	Created By PM Schedule	609-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317637	Created By PM Schedule	001-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317638	Created By PM Schedule	001-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317639	Created By PM Schedule	189-BSG-003	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317640	Created By PM Schedule	189-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317641	Created By PM Schedule	189-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317642	Finished	071-BSG-002	6/1/2015	6/23/2015	False	8.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317643	Finished	071-BSG-001	6/1/2015	6/11/2015	False	8.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317644	Created By PM Schedule	070-BSG-001*	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317647	Created By PM Schedule	504-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317648	Created By PM Schedule	085-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317649	Created By PM Schedule	085-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317651	Created By PM Schedule	068-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317967	Finished	001-CRP-001	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
FO-317968	Finished	001-CRP-002	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
FO-317969	Finished	001-CRP-003	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
FO-317970	Finished	001-CRP-004	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
FO-317972	Created By PM Schedule	070-CRS-001*	6/5/2015		False		PM - Condensate Return Pump
FO-317973	Created By PM Schedule	070-CRS-002*	6/5/2015		False		PM - Condensate Return Pump



**Requested Finished Open WND**

**% Finished**

FO-317624	Finished	166-BSG-001	6/1/2015	6/15/2015	False	8.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
Prepared boiler for inspection by removing all plugs and low water cutouts an removing fire side doors and burner to expose and inspect burner and combustion chamber.							
FO-317625	Created By PM Schedule	155-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317626	Created By PM Schedule	155-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317645	Created By PM Schedule	003-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317646	Created By PM Schedule	003-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317650	Created By PM Schedule	078-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317971	Finished	167-DHW-001	6/8/2015	6/10/2015	False	2.00	PM - Domestic Water Heater, Gas
Inspected water heater, checked for leaks and wiped tank down. Used lase temp probe to check for accuracy of tank sensor. Tank 2F off of laser probe.							
FO-317988	Finished	001 SPARE from	6/9/2015	6/11/2015	False		Generator Maintenance, Monthly
FO-318469	Finished	169-AHU-001	6/15/2015	6/30/2015	False		PM - Water/Air Cooled Condenser
FO-318470	Created By PM Schedule	169-AHU-002	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318471	Created By PM Schedule	169-AHU-003	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318472	Created By PM Schedule	169-AHU-004	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318473	Created By PM Schedule	169-AHU-005	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318474	Created By PM Schedule	169-AHU-006	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318475	Created By PM Schedule	169-AHU-007	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-318476	Created By PM Schedule	169-AHU-008	6/15/2015		False		PM - Water/Air Cooled Condenser
FO-319092	Finished	169-GEN-001	6/25/2015	6/29/2015	False		Generator Maintenance, Monthly

Trades		43	38	5	0	88%	
T - Electrician		38	34	4	0	89%	
FO-317962	Created By PM Schedule	608-GEN-001	6/5/2015		False		Generator Maintenance, Monthly
FO-317979	Finished	193-GEN-001	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317980	Finished	501-GEN-001	6/9/2015	6/9/2015	False	4.00	Generator Test Tuesday 6/9/2015 @ 1PM.
FO-317982	Finished	608-GEN-001	6/5/2015	6/2/2015	False	4.00	Generator Test Tuesday 6/2/2015 @ 7:15AM.
FO-317989	Finished	193-GEN-002	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317990	Finished	193-GEN-003	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317991	Finished	193-GEN-004	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-318456	Created By PM Schedule	612-GEN-001	6/12/2015		False		Generator Maintenance, Monthly
FO-318457	Created By PM Schedule	612-GEN-002	6/12/2015		False		Generator Maintenance, Monthly
FO-318481	Finished	609-GEN-001	6/16/2015	6/16/2015	False	4.00	Generator Test Tuesday 6/16/2015 @ 7:15AM.
FO-318483	Finished	007-GEN-001	6/11/2015	6/11/2015	False	2.00	Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318485	Finished	007-GEN-002	6/11/2015	6/11/2015	False	2.00	Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318487	Finished	090-GEN-001	6/16/2015	6/16/2015	False	4.00	Generator Test Tuesday 6/16/2015 @ 9:30AM.
FO-318488	Finished	637-GEN-001	6/16/2015	6/16/2015	False		Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318490	Finished	637-GEN-002	6/16/2015	6/16/2015	False	2.00	Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318492	Finished	612-GEN-001	6/12/2015	6/9/2015	False	2.00	Generator Test Tuesday 6/9/2015 @ 7:15 AM.



