

# Facilities Operations Work Orders Received 04/01/2013 through 04/30/2013

WO	Received	Finished	Total	Request
<b>Maint. Work Order (MWRP)</b>			<b>1912</b>	
<b>Custodial</b>			<b>248</b>	
<b>Emergency</b>			<b>1</b>	
<b>C-Repair</b>			<b>1</b>	
FO-247756	4/12/2013	4/12/2013		EQUIPMENT TRANSFER:
<b>High</b>			<b>1</b>	
<b>C-Projects</b>			<b>1</b>	
FO-248477	4/22/2013	4/22/2013		Water / chemicals leaking down from boiler room above. Need water clean up from floor and c
<b>Medium</b>			<b>4</b>	
<b>C-Director</b>			<b>3</b>	
FO-248064	4/17/2013			Custodial to provide support for the Admissions Preview Day. the following Buildings will be pr
FO-248340	4/19/2013	4/22/2013		Custodial to clean, seal, and wax the floors in rooms 101, 103, and 105.
FO-249059	4/28/2013			A lot of lights are out in the tunnel leading from Fitness center to Purdy Kresge library
<b>C-Repair</b>			<b>1</b>	
FO-247567	4/10/2013			convetimatic need squezgie repaired 24 inch machine. Located in basement of Scott Hall
<b>Low</b>			<b>229</b>	
<b>C-Director</b>			<b>10</b>	
FO-246872	4/3/2013			2 trash receptacles for Provost Office
FO-247018	4/5/2013	4/18/2013		Requesting special cleaning(Custodial Services) of St.Andrews Hall at the conclusion of the re
FO-247668	4/11/2013	4/15/2013		Replace broken toilet paper holder and soap dispenser in the 3rd floor ladies room of Student
FO-247782	4/13/2013			Light in men's restroom in the basement is out.
FO-248071	4/17/2013			Custodial to provide support for the Admissions Preview Day to Student Center Building Satur
FO-248112	4/17/2013			Request for two wall mounted hand sanitizer holders and sanitizer. Charge to account 227149.
FO-248257	4/19/2013			3rd floor stairwell, west side, light needs to be changed.
FO-248378	4/19/2013	4/19/2013		Allied Eagle
FO-248820	4/24/2013			Allied Eagle Supply
FO-249057	4/27/2013			Basement janitor's closet (across from elevators) need light change.
<b>C-Lighting</b>			<b>79</b>	
FO-246451	4/1/2013	4/2/2013		Hallway outside restroom 237: burned out lightbulb. Please replace.
FO-246476	4/1/2013	4/1/2013		URGENT
FO-246829	4/3/2013	4/3/2013		Replaced 2 bulbs in unisex restroom.
FO-246924	4/4/2013	4/8/2013		completed task, installed 18 bulbs in room.
FO-246927	4/4/2013	4/5/2013		Room 3354 - Jaffar Lecture hall projection booth - lights burnt out - Please replace.
FO-246934	4/4/2013	4/4/2013		Light out above desk in office
FO-246941	4/4/2013	4/9/2013		Our overhead lobby light fixtures,by the elevators, on the third floor of 5057 Woodward Ave. h
FO-246943	4/4/2013	4/8/2013		completed task, installed 12 bulbs.
FO-246966	4/4/2013	4/11/2013		Installed 4 bulbs
FO-247019	4/5/2013	4/19/2013		ok to close. all light bulbs are installed.
FO-247013	4/5/2013	4/9/2013		Real room number is 125.2. One of the light bulb sets in this office is making a ticking/hissing
FO-247135	4/8/2013	4/10/2013		Replaced 18 bulbs in room 3033, replaced12 bulbs in room 3009, replaced 8 bulbs in 3010, a
FO-247168	4/8/2013	4/8/2013		Light bulbs are out in Dr. Cacace lab room 045 and room 045.1 (045.1 is inside room 045).
FO-247182	4/8/2013	4/11/2013		Installed 12 bulbs
FO-247184	4/8/2013	4/12/2013		Lande Rm 474 - flickering light
FO-247185	4/8/2013	4/18/2013		installed 2 bulbs near rear of room.
FO-247202	4/8/2013	4/9/2013		Room 3113 - Several lights burnt out, please fix.
FO-247203	4/8/2013	4/9/2013		Room 3363 - Several lights burnt out, please fix.

WO	Recieved	Finished	Total	Request
FO-247245	4/9/2013	4/9/2013		Real room number is 125. One set of lights by Vicki's desk are intermittently blinking badly (lik
FO-247348	4/9/2013	4/16/2013		The lights are on a timer in this area, per the bldg. engineer, please see the bldg. coordinator
FO-247381	4/9/2013	4/10/2013		Please change blown out light.
FO-247386	4/9/2013	4/10/2013		Lights on middle tier of spiral stairwell leading to basement (pit area) are flickering.
FO-247678	4/11/2013	4/12/2013		1st floor Unisex restroom light flickering then it goes out, near sink. Please replace.
FO-247680	4/11/2013	4/12/2013		5057 Woodward Rm 6203
FO-247689	4/11/2013	4/17/2013		installed 54 bilbs in room 1343, and 6 bulbs in baasement cooridor, near mens restroom.
FO-247694	4/11/2013	4/15/2013		ceiling flood lights to the left of 1281 need to
FO-247698	4/11/2013	4/17/2013		replaced 6 bulbs per customer request. ok to close.
FO-247728	4/12/2013	4/12/2013		5057 Woodward
FO-247744	4/12/2013	4/15/2013		Replaced bulb in entrance way of restroom.. ok to close out.
FO-247884	4/15/2013	4/15/2013		Lights out in Simons 1st flr Ladies Restroom & Rm 127
FO-247913	4/15/2013	4/16/2013		Restroom 220.01: lightbulb burned out above toilet.
FO-247927	4/15/2013	4/16/2013		Hallway near room 234: lightbulb burned out, please replace.
FO-248079	4/17/2013	4/18/2013		Light out, under cabinet light, in Scott Hall Rm 1102
FO-248120	4/17/2013	4/18/2013		sconces by theater doors
FO-248242	4/18/2013	4/19/2013		installed 40 bulbs in 2 rooms. close out.
FO-248258	4/19/2013	4/19/2013		Installed 15 bulbs in class room..ok to close out.
FO-248305	4/19/2013	4/19/2013		Need a 60 watt bulb in Beecher House Rm 109
FO-248331	4/19/2013	4/19/2013		Hilberry
FO-248348	4/19/2013	4/22/2013		replaced 4 bulbs in cooridor. ok to close.
FO-248366	4/19/2013	4/22/2013		Lights flickering and out in Rm 219
FO-248368	4/19/2013	4/22/2013		Lights are flickering and out in Rm 283.
FO-248380	4/19/2013	4/22/2013		Rm 1309 (mail room) light is flickering. Stop in FSS office (rm#1102) to sign out mail room ke
FO-248385	4/19/2013	4/22/2013		Bulbs out in reception area, administrative area, and rm 136
FO-248487	4/22/2013	4/22/2013		Room 1215 has 6 bulbs out.
FO-248490	4/22/2013	4/22/2013		Lights out in FAB Rm 2047
FO-248531	4/22/2013	4/24/2013		West and East Stairwell, several lights out
FO-248564	4/22/2013	4/23/2013		Rm 5250 has multiple lights out
FO-248579	4/23/2013	4/23/2013		3rd Floor hallway outside lecture halls - Several light burnt out throughout hallway, please fix.
FO-248604	4/23/2013	4/23/2013		Light bulb burned out just inside main entrance, above bench.
FO-248641	4/23/2013	4/24/2013		ok to close out..Replaced bulb in overhead Binder Bin.
FO-248821	4/24/2013	4/25/2013		Room 4254 lights are out.
FO-248822	4/24/2013	4/25/2013		Room 4254 lights are out. There are 3 burned out in the 4254 ante-room, 9 in the main 4254 r
FO-248854	4/25/2013	4/26/2013		installed 12 bulbs in classroom. ok to close.
FO-248855	4/25/2013	4/26/2013		installed 12 bulbs in classroom. ok to close.
FO-248856	4/25/2013	4/26/2013		installed 10 bulbs in classroom. ok to close.
FO-248857	4/25/2013	4/26/2013		installed 4 bulbs in classroom. ok to close.
FO-248858	4/25/2013	4/26/2013		installed 7 bulbs in classroom. ok to close.
FO-248860	4/25/2013	4/25/2013		installed 8 bulbs in classroom. ok to close
FO-248861	4/25/2013	4/25/2013		installed 13 bulbs in classroom. ok to close.
FO-248862	4/25/2013	4/25/2013		installed 9 bulbs in classroom. ok to close.
FO-248863	4/25/2013	4/25/2013		installed 12 bulbs in classroom. ok to close.
FO-248864	4/25/2013	4/26/2013		installed 12 bulbs in classroom. ok to close.
FO-248867	4/25/2013	4/25/2013		installed 9 bulbs in classroom. ok to close.
FO-248868	4/25/2013	4/25/2013		installed 9 bulbs in classroom. ok to close.
FO-248869	4/25/2013	4/26/2013		installed 7 bulbs in classroom. ok to close.

WO	Recieved	Finished	Total	Request
FO-248870	4/25/2013	4/25/2013		installed 7 bulbs in classroom. ok to close.
FO-248871	4/25/2013	4/25/2013		installed 12 bulbs in classroom. ok to classroom.
FO-248872	4/25/2013	4/26/2013		installed 7 bulbs in classroom. ok to close.
FO-248874	4/25/2013	4/26/2013		installed 10 bulbs in classroom. ok to close.
FO-248875	4/25/2013	4/26/2013		installed 15 bulbs in classroom. ok to close.
FO-248891	4/25/2013	4/25/2013		Hallway across from room 115.
FO-248943	4/25/2013	4/30/2013		BASEMENT WOMEN'S RESTROOM ONE OF THE TUBE LIGHTS OUT.
FO-248992	4/26/2013	4/26/2013		Hallway by room 2116 and 2118 have lights out. Thanks.
FO-249002	4/26/2013			First Floor relamping needed in the following areas. Areas listed by floor, room number, room
FO-249004	4/26/2013			Second Floor relamping needed in the following areas. Areas listed by room number, room de
FO-249006	4/26/2013			Third Floor areas requiring relamping. Areas listed below by room number, room description a
FO-249007	4/26/2013			Fourth Floor areas requiring relamping. Areas listed by room number, room description, and n
FO-249035	4/26/2013			WOMEN'S RESTROOM #108 LIGHT OUT.
FO-249037	4/26/2013			MEN'S RESTROOM #218 LIGHT OUT OVER TOILET.
<b>C-Materials</b>			<b>13</b>	
FO-247518	4/10/2013	4/11/2013		Recycling Pick Up Rm 3103 Engineering
FO-247730	4/12/2013	4/12/2013		Deliver large recycling bin to Scott Hall Rm 2309.
FO-248059	4/17/2013	4/18/2013		Pick Up Recycling
FO-248163	4/18/2013	4/18/2013		3 Recycling Bins Pick Up, empties returned
FO-248236	4/18/2013	4/19/2013		Recycling Pick Up
FO-248237	4/18/2013	4/19/2013		Recycling Pick Up
FO-248329	4/19/2013	4/19/2013		Elliman Rm 3104
FO-248621	4/23/2013	4/23/2013		Recycling Pick Up
FO-248852	4/25/2013			Room 263 clock not working.
FO-248933	4/25/2013	4/26/2013		2309 Scott Hall - Recycling Pick (does NOT need empty back)
FO-248952	4/25/2013	4/26/2013		Recycling Pick Up
FO-248966	4/26/2013	4/26/2013		EQUIPMENT TRANSFER:
FO-249186	4/29/2013	4/29/2013		Recycling Pick Up
<b>C-Projects</b>			<b>13</b>	
FO-246968	4/4/2013			Room 3248 - Please strip and wax lab floor. Please contact Jill Todt at 577-9636 to schedule
FO-247612	4/11/2013	4/15/2013		Mens restroom of FP&M custodial building (5743 woodward)needs entire restroom extensively
FO-247958	4/15/2013			Office 2133 (Sean Wu) Is requesting that his office gets a through cleaning and sahmoothing
FO-248167	4/18/2013			Sub-basement - Room 0014, Art Collection.
FO-248170	4/18/2013			Scrub carpet and wipe down flat surfaces in vacant faculty office. (1107.3 Elliman) Contact C
FO-248808	4/18/2013			contact: Valeria Cook
FO-248226	4/18/2013	4/23/2013		I am requesting evening carpet cleaning for the entire office suite (1600) and each office locat
FO-248524	4/22/2013			Rooms 2246, 2248, and hallway leading to 2221 needs carpet shampooed week of April 22, 2
FO-248753	4/23/2013			Clean & wax hallway floors, north of elevators on the 4th floor. Contact Tracy Schuck in DLA
FO-248953	4/25/2013	4/30/2013		Carpet cleaning--schedule for the week of April 29th. Room is vacant can be done during the
FO-249005	4/26/2013			Floors in the Education Building need to be
FO-249050	4/26/2013	4/30/2013		Steam clean carpet in room 284 on the mezzanine. Please inform me before work is to begin
FO-249188	4/29/2013			Division of Engineering Technology would like to request floors to be clean and waxed for the f
<b>C-Repair</b>			<b>46</b>	
FO-246462	4/1/2013			Women's restroom #3126 (Cass side) paper towel dispenser broken. Please repair or replace.
FO-246893	4/4/2013			AUTO SCRUBBER IN CLOSET #021 NEEDS SERVICING. CAP MISSING ON HOSE AND S
FO-246917	4/4/2013			Ladies restroom on 3rd floor has a broken soap dispensor. Please replace.
FO-247052	4/5/2013			Soap dispenser off the wall. Mens restroom 5th floor. Science Engineering library
FO-247120	4/8/2013			Install airfreshner system in men and women's restroom @ 5743 Woodward building

WO	Recieved	Finished	Total	Request
FO-247133	4/8/2013			EQUIPMENT TRANSFER: BY (E. HILL) A REQUEST TO USE A FLOOR AIR MOVER TO D
FO-247134	4/8/2013			A REQUEST FOR SERVICE REPAIRS ON (SANITAIRE / M#887-B / SER.#1219003926) TH
FO-247272	4/9/2013			Roll towel dispenser 3rd Flr - Malfunctioning.
FO-247290	4/9/2013			mens room paper towel despencer is broken. needs replacing.6th floor
FO-247357	4/9/2013	4/23/2013		please r/r soap dispenser in mech room 51
FO-247393	4/10/2013			Have a high speed buffer on the first floor of welcome center. Needs to be checked, and need
FO-247566	4/10/2013			Please repair sm-18 Sanitaire vacuum cleaner, from Beecher House. Rhoda Lloyd turned it in
FO-247642	4/11/2013			3rd floor E-Wing Women's restroom #3405 paper towel dispenser broken. Please replace or r
FO-247646	4/11/2013			NEED SOME VACUUMS CLEANER PARTS TO DO SOME SERVICE REPAIRS ON VAC. IN
FO-247771	4/12/2013			Purdy 2nd Floor, Handicap restroom next to Room 235. This is the only handicap restroom on
FO-247873	4/15/2013			R/R RM 138/WOMENS RM 2ND SOAP DISPENSER BTWN 2ND & 3RD SINKS IS BROKEN
FO-247907	4/15/2013			Bio Sci Bldg - Soap Dispenser on the 4th Flr Men's Restroom is broken
FO-247989	4/16/2013			paper towel dispenser is broke/ 3rd floor unsex restroom located inside of the dressing room
FO-247990	4/16/2013			REPAIR PAPPER TOWEL DESPENSER IN ROOM 056.
FO-248039	4/16/2013			Please repair or replace handle on Noble Scout24 electric sweeper and replace filter.
FO-248095	4/17/2013			2nd floor Men's restroom paper towel dispenser broken, hanging off wall. This is on the Danto
FO-248104	4/17/2013	4/19/2013		Women's restroom #170 paper towel dispenser broken. Please repair or replace.
FO-248176	4/18/2013	4/19/2013		NEED SOME PARTS (VAC.) MOTERS FOR (3) WET/DRY VACUUM MACHINE (NOBLBES/
FO-248205	4/18/2013	4/18/2013		Front and read entrance out of hand sanitizer at Matthaei
FO-248252	4/18/2013			Clarke Focus Boost 2 floor machine need the jets cleaned. Boost machine from Scott Hall an
FO-248262	4/19/2013	4/22/2013		Please make or issue a key for boost machine on W/O FO-248252.
FO-248313	4/19/2013			R/R 1ST FLR STAFF/UNISEX Restroom paper towel dispenser
FO-248387	4/20/2013			Vacuum cleaner is very loud and does not have good suction. Serial#: 0829003692/ model:sc
FO-248493	4/22/2013			NEED SOME PARTS FOR A (Tennant/7100) BIG RIDER SCRUBBER AT THE (ATHLETIC M
FO-248495	4/22/2013			NEED SERVICE REPAIRS FOR (2), TWO OLD BROKEN VACUUMS CLEANER.
FO-248809	4/22/2013			Install paper towel dispensers near sink in the following rooms on the 2nd floor: 2223, 2225, 2
FO-248626	4/23/2013			TENNANT / RIDER SCRUBBER NEED SOME SERVICE REPAIRS.
FO-248631	4/23/2013			Broken roll towel dispenser in Men's restroom 1st. floor.
FO-248771	4/24/2013			Sanitaire with dust cup upright vacuum/not picking up - used on the 4th floor AAB building
FO-248807	4/24/2013			REPAIR GANDOLA(TRASH DUMPTER)NEEDS 4 NEW WHEELS. PLEASE REPAIR AS SO
FO-249010	4/25/2013			Replace broken hand towel holder plus add an additional one inside lower level ladies room in
FO-248915	4/25/2013	4/25/2013		NEW EQUIPMENT: MAIN OFFICE/STOCKROOM
FO-248969	4/26/2013			NEW EQUIPMENT: Needs Assembling
FO-248994	4/26/2013			Need paper towel and soap dispenser installed at sink area.
FO-249013	4/26/2013			NEW EQUIPMENT: Needs Assembling
FO-249017	4/26/2013			NEW EQUIPMENT: Needs Assembling
FO-249054	4/27/2013			the chemical dispenser in closet 2128 does not work. May need to be replaced.
FO-249153	4/29/2013			soap dispenser in 1st floor women's room is broken
FO-249157	4/29/2013			Please replace or repair soap dispenser in men restroom on the 3rd floor outside of Labor Rel
FO-249175	4/29/2013			sANITAIRE VACUUM CLEANER NEEDS BEATER BAR SERIAL # 0825003487, model # SC
FO-249177	4/29/2013			Sanitaire vacuum #1207001293 model SC887 clogged. Please repair. Vacuum behind bathro
<b>C-Sector 01</b>			<b>2</b>	
FO-247569	4/10/2013	4/12/2013		Admitted Student Day Friday April 12th room 25 Prentis--please schedule cleaning for this roo
FO-247749	4/12/2013	4/11/2013		Men's restroom on first floor of Life Sci is a mess. Please send someone to clean.
<b>C-Sector 02</b>			<b>14</b>	
FO-246579	4/2/2013	4/8/2013		Room 6119 - Please scrub equipment room floor - Please contact Krista Mitchell at 577-9028
FO-246581	4/2/2013	4/9/2013		Rooms 6111, 6312 and 6320 - Please strip and wax lab floors. Please contact Dr. Kingsley O
FO-247167	4/8/2013	4/19/2013		Room 7327 - Please strip and wax lab floors. Please contact Robin Roberts at 577-1747 to sc

WO	Recieved	Finished	Total	Request
FO-247226	4/9/2013	4/9/2013		Scrub and Wax lab floors in rm.9244 an 9227
FO-247618	4/10/2013	4/16/2013		Room 5350 - Floor needs to be mopped and waxed. For access, please contact Daisy Wright
FO-247699	4/11/2013	4/17/2013		Room 6321 - Please strip and wax lab floors. Please contact Dr. Mattingly at 577-6022 to sch
FO-247734	4/12/2013			Rooms 2309 & 2309.1 Scott Hall, Schedule carpet cleaning. Rooms are currently unoccupied
FO-248089	4/17/2013	4/17/2013		scrub and wax room 8203.
FO-248519	4/22/2013	4/25/2013		Room 3135 needs to have carpet shampooed week of April 22nd if possible. Thanks!
FO-248616	4/23/2013	4/23/2013		scrub and waxed floors in labs 8252
FO-249190	4/29/2013	4/29/2013		6 cases of dial soap
FO-249191	4/29/2013	4/29/2013		4 cases of dial soap
FO-249192	4/29/2013	4/29/2013		4 cases of dial soap
FO-249193	4/29/2013	4/30/2013		3 cases of dial soap
<b>C-Sector 04</b>			<b>9</b>	
FO-246630	4/2/2013	3/29/2013		2 cases of dial soap
FO-247059	4/5/2013	4/11/2013		to pick up ext cord for vac cleaner and key tags
FO-247143	4/8/2013	4/10/2013		There is an event on Wednesday, April 10th from 6-8pm. Will need custodial service to clean
FO-247273	4/9/2013	4/10/2013		Please forward to evening custodian: There is an event on Wednesday, April 10th from 6-8pm
FO-248034	4/16/2013	4/17/2013		Room 1213: All tables need to be wiped down for Board of Visitors lunch on 4/17/13 by 10am
FO-248228	4/18/2013	4/19/2013		1 case of dial soap
FO-248229	4/18/2013	4/20/2013		1 case of dial soap
FO-248230	4/18/2013	4/20/2013		1 case of dial soap
FO-248344	4/19/2013	4/20/2013		Detroit Hardware
<b>C-Sector 05</b>			<b>7</b>	
FO-248586	4/23/2013			1 box of rags
FO-248587	4/23/2013			1 box of rags
FO-248588	4/23/2013			1 box of rags
FO-248589	4/23/2013			1 box of rags
FO-248590	4/23/2013			1 box of rags
FO-248591	4/23/2013			2 boxes of rags
FO-248592	4/23/2013			2 boxes of rags
<b>C-Sector 06</b>			<b>3</b>	
FO-248347	4/19/2013			High Profile Donor Event on May 1st. Scrub and detail clean restrooms, cleaning conference r
FO-248496	4/22/2013			Strip, scrub and wax floor in office 138.
FO-248504	4/22/2013			Please clean the carpet in the Dean's Office and Dean's Office conference room (rooms 3327,
<b>C-Sector 07</b>			<b>10</b>	
FO-246902	4/4/2013	4/11/2013		6th floor kitchen--scrub/wax on Friday, April 12 6am-9am.
FO-247241	4/9/2013	4/10/2013		4th floor corridor scrubbed including Men's restroom off corridor.
FO-247894	4/15/2013	4/15/2013		1 case of dial soap
FO-247895	4/15/2013	4/15/2013		1 case of dial soap
FO-247896	4/15/2013	4/15/2013		1 case of dial soap
FO-247897	4/15/2013	4/15/2013		2 cases of dial soap
FO-247898	4/15/2013	4/15/2013		2 cases of dial soap
FO-247899	4/15/2013	4/15/2013		2 cases of dial soap
FO-247900	4/15/2013	4/15/2013		3 cases of dial soap
FO-248119	4/17/2013	4/26/2013		Please clean both levels of the Elaine L. Jacob Gallery with the mop machine on Friday, (04/2
<b>C-Sector 08</b>			<b>8</b>	
FO-247248	4/9/2013	4/9/2013		1 case of dial soap
FO-248181	4/18/2013			wash and wax room 37 subbasement knapp building
FO-248593	4/23/2013	4/24/2013		2 boxes of rags

WO	Recieved	Finished	Total	Request
FO-248594	4/23/2013	4/24/2013		2 boxes of rags
FO-248595	4/23/2013	4/24/2013		2 boxes of rags
FO-248596	4/23/2013	4/24/2013		2 boxes of rags
FO-248598	4/23/2013	4/24/2013		2 boxes of rags
FO-248599	4/23/2013	4/24/2013		1 box of rags
<b>C-Sector 09</b>			<b>15</b>	
FO-246994	4/4/2013	4/5/2013	4/15/2013	Purdy Library 1st Floor Check Out Desk (Staff) area
FO-247383	4/9/2013		4/10/2013	Extract carpet in Dean's Suite room 226. Pipefitter's were changing pipes.
FO-247701	4/11/2013	4/11/2013		Mop all the floors including the main entrance
FO-247752	4/12/2013			Hallways need to be mopped and waxed on west, south, and east side of building in the lab ar
FO-247887	4/15/2013	4/15/2013		2 cases of dial soap
FO-247888	4/15/2013	4/13/2013		2 cases of dial soap
FO-247889	4/15/2013	4/13/2013		2 cases of dial soap
FO-247890	4/15/2013	4/13/2013		2 cases of dial soap
FO-247891	4/15/2013	4/13/2013		2 cases of dial soap
FO-247892	4/15/2013	4/13/2013		2 cases of dial soap
FO-248213	4/18/2013	4/18/2013		Allied Eagle
FO-248615	4/23/2013			This customer wants his floors done in the afternoons room 5344 & 5324 scrub and waxed. Pl
FO-248766	4/24/2013	4/26/2013		Please strip and wax cafeteria floors. Must be done during evening hours. Per conversations
FO-248924	4/25/2013			Room 5324/5344 - Please strip and wax lab floor. Please note, this room has two door adress
FO-249238	4/29/2013	4/30/2013		Carpet cleaning request: Carpet stains in carpet on bridge leading from Scott Hall to Mazurek
<b>Routine</b>			<b>13</b>	
<b>C-Director</b>			<b>11</b>	
FO-248168	4/18/2013			FY2013 FO for Boomer Construction Materials
FO-248169	4/18/2013			FY2013 FO for HP Products
FO-248171	4/18/2013			FY2013 FO for Shemin Nurseries
FO-248172	4/18/2013			FY2013 FO for Contractors Fence & Gate Services
FO-248174	4/18/2013			FY2013 FO for Fraza Forklifts
FO-248177	4/18/2013			FY2013 FO for Landscape Services Inc
FO-248180	4/18/2013			FY2013 for Rizzo Services
FO-249224	4/29/2013			From Heat Engineering purchase the following:
FO-249225	4/29/2013			From Granger Co.to purchase the following:
FO-249226	4/29/2013			Grounds Dept.stock withdrawal:
FO-249230	4/29/2013			FO for Pioneer Mfg FY2013
<b>C-Materials</b>			<b>2</b>	
FO-247149	4/8/2013	4/8/2013		Transferred a wet & dry vacuum and industrial fan from main custodial stockroom to FP&M se
FO-247151	4/8/2013	4/8/2013		Transferred a Nobles Scout 24 sweeper sn# 8000020014 - model# 614213 - #053 WSU to Ma
<b>Engineering</b>			<b>672</b>	
<b>Emergency</b>			<b>12</b>	
<b>E - Afternoon Engineer</b>			<b>3</b>	
FO-247370	4/9/2013	4/10/2013		KEY STUCK IN DOOR LOCK. ROOM 401.
FO-247696	4/11/2013	4/12/2013		MALL AREA BTWN SCB, UGL, FITNESS CTR & PURDY LIB EAST OF FLAG POLE SINK H
FO-248950	4/25/2013	4/26/2013		EMERGENCY OUTSIDE FROM THE GRND LEVEL ABOVE RM 0033/LETCHAL CHAMBER
<b>E - Area 1 Engineer</b>			<b>3</b>	
FO-247512	4/10/2013	4/10/2013		BLDG FRONT AREA NAT GAS SMELL
FO-248309	4/19/2013			AHU #2 HAS WATER LEAKING OUT OF IT
FO-248946	4/25/2013			EMERGENCY R/R OUTSIDE FROM THE GRND LEVEL ABOVE RM 0033/LETCHAL CHAM

WO	Recieved	Finished	Total	Request
<b>E - Area 2 Engineer</b>			<b>4</b>	
FO-247117	4/8/2013	4/8/2013		Carpet is soaked. Service Center room 138. See Serena.
FO-248627	4/23/2013	4/23/2013		RM 2242 HAS WATER POURING IN @ TOP OF WALL
FO-248981	4/26/2013	4/26/2013		FAP IS IN ALARM
FO-249199	4/29/2013	4/29/2013		4TH FLR NEAR RM 455 SMOKE IS COMING FROM SOMEWHERE
<b>E - Area 3 Auxiliary Eng</b>			<b>2</b>	
FO-246899	4/4/2013	4/5/2013		NO POWER IN ROOM 679.
FO-247576	4/10/2013	4/10/2013		CALLED SCHINDLER ELEV CO FOR ENTRAPMENT #1 ELEV STUCK ON 8TH FLR
<b>High</b>			<b>177</b>	
<b>E - Afternoon Engineer</b>			<b>46</b>	
FO-246501	4/1/2013	4/2/2013		4TH FL FIRE ALARM SOUNDING
FO-246502	4/1/2013	4/2/2013		RM 6353 LOW TEMP ALARM
FO-246641	4/3/2013	4/2/2013		Replace bad 4amp fuse on #2 boiler.
FO-246883	4/3/2013	4/4/2013		LAB 10 OUTLETS NOT WORKING
FO-246972	4/4/2013	4/4/2013		CEILING LEAK IN LOBBY COMING FROM 2ND FL RADIATOR
FO-246975	4/4/2013	4/5/2013		4TH FL NEAR LADIES RM HALLWAY BURNING SMELL
FO-246976	4/4/2013	4/5/2013		MAIN LOUNGE AREA TOO WARM, EVENT TAKING PLACE
FO-246977	4/4/2013	4/5/2013		MAIN LOBBY BURNING SMELL
FO-246978	4/4/2013	4/4/2013		SIDE DOOR LOCK BROKEN OFF, SECURITY ISSUE
FO-246981	4/4/2013	4/5/2013		RM 260 FUME HOOD LEAKING
FO-246986	4/5/2013	4/5/2013		PS reported ceiling leak in room 411. Engineer please trouble shoot.
FO-247067	4/5/2013	4/6/2013		PS called stating that the NW door was not securing.
FO-247193	4/8/2013	4/9/2013		RM 1245 UNISEX RESTROOM TOILET CLOGGED
FO-247195	4/8/2013	4/9/2013		3RD FL MENS RM FLOODING, BELIEVES WATER IS COMING FROM TOILET
FO-247197	4/8/2013	4/9/2013		RM 0229 LOW TEMP
FO-247206	4/8/2013	4/8/2013		HOT WATER NOT WORKING ON FLOORS ENDING IN 06
FO-247214	4/9/2013	4/9/2013		PS call - Postitive pressure issue causing doors to stay open.
FO-247215	4/9/2013	4/9/2013		PS call - Door 155-05E not closing and securing.
FO-247217	4/9/2013	4/9/2013		PS reported high temp alarm ahu 3.
FO-247219	4/9/2013	4/9/2013		ON BAS found alarms on #1 and #4 generators.
FO-247221	4/9/2013	4/9/2013		Replace leaking vents inside ahu-9
FO-247369	4/9/2013	4/11/2013		Eyeglass fell in an exhaust pipe. Can see glasses from hole needs to retrieve. Contact numbe
FO-247768	4/12/2013	4/13/2013		NORTHWEST DOOR WON'T CLOSE.
FO-247781	4/13/2013	4/13/2013		AHU 2 not running on BAS
FO-247934	4/15/2013	4/15/2013		RM 4330 HIGH TEMP ALARM
FO-247942	4/15/2013	4/16/2013		BRADY SIDE FRONT ENTRANCE DOORS ARE NOT CLOSING AND NOT LOCKING.
FO-247944	4/15/2013	4/16/2013		RM 1131 DOOR LATCH BROKEN DEANS OFFICE, SECURITY ISSUE
FO-247945	4/15/2013	4/16/2013		CEILING LEAK OVER HANDICAP STALL. 5TH FLOOR MEN'S RESTROOM.
FO-247953	4/15/2013	4/16/2013		SUPPLY FAN # 1 ALARMING
FO-248025	4/16/2013	4/17/2013		S.W. CORNER 1ST FLR AN ALARM IS SNDNG
FO-248028	4/16/2013	4/17/2013		LOUD BUZZING SOUND 1ST FL
FO-248107	4/17/2013	4/18/2013		rm 160 a heavy piece of wood fell away from the hvac unit along the wall @ window
FO-248238	4/18/2013	4/19/2013		FIRE TROUBLE ALARM SNDNG AGAIN
FO-248240	4/18/2013	4/19/2013		RM 2537 EDC SERVER RM AIR NOT WORKING RM TOO HOT
FO-248247	4/18/2013	4/19/2013		ALL LAB'S IN BLDG TOO HOT
FO-248251	4/18/2013	4/19/2013		PS called about a roof leak and some burned out lights for show.
FO-248254	4/19/2013	4/19/2013		PS call for fire alarm
FO-248255	4/19/2013	4/19/2013		PS call for fire trouble alarm.

WO	Recieved	Finished	Total	Request
FO-248266	4/19/2013	4/19/2013		FIRE TROUBLE ALARM SNDNG AGAIN (also 4/19/13)
FO-248383	4/19/2013			FIRE TROUBLE ALARM SOUNDING CALLED IN YESTERDAY STILL IN ALARM
FO-248545	4/22/2013	4/23/2013		1ST FL MENS RM TOILET CONTINUOUSLY FLUSHING
FO-248639	4/23/2013	4/24/2013		RM 4328/WALK IN COLD RM BOX IS TOO HOT-ALARM DID NOT SOUND
FO-248840	4/24/2013	4/25/2013		RM 3351 WATER LEAKING INTO RM FROM INSIDE WALLS
FO-248843	4/24/2013	4/25/2013		5TH FL HALLWAY CEILING IS BUCKLING DUE TO LEAK LOOKS LIKE IT WELL BURST S
FO-249231	4/29/2013	4/29/2013		3rd flr has a sewage smell
FO-249232	4/29/2013	4/29/2013		rm 3293 has a terrible smell like rotten eggs
<b>E - Area 1 Engineer</b>			<b>60</b>	
FO-246437	4/1/2013	4/1/2013		LOW TEMP. ALARM. ROOM 6353.
FO-246438	4/1/2013	4/1/2013		LOW HUMIDITY IN ROOMS 411, 416, 414, 200.08, 200.06, 200.11 & 200.12
FO-246449	4/1/2013	4/1/2013		SUPPLY FAN #1 ALARM
FO-246466	4/1/2013	4/1/2013		LOW TEMP. ALARM. ROOM 5341.
FO-246470	4/1/2013	4/1/2013		RM 4374 NO HEAT
FO-246480	4/1/2013	4/1/2013		RETURN FAN #1 ALARM.
FO-246496	4/1/2013	4/1/2013		LOW TEMP. ALARM. ROOM 6353.
FO-246513	4/2/2013	4/2/2013		LOW TEMP. ALARM. ROOM 6353.
FO-246526	4/2/2013	4/2/2013		LOW TEMP. ALARM.
FO-246569	4/2/2013	4/2/2013		411,412,414,417,419 LOW HUMIDITY
FO-246570	4/2/2013	4/2/2013		200.01,200.06,200.07,200.08,200.11,200.12 LOW HUMIDITY
FO-246574	4/2/2013	4/2/2013		RM 5451 TOO WARM
FO-246593	4/2/2013	4/2/2013		RM 6353 LOW TEMP ALARM
FO-246847	4/3/2013	4/4/2013		LOW HUMIDITIES IN ROOMS 200.07, 200.08, 200.12, 200.11, 200.06, 200.01,412, 413, 416
FO-246859	4/3/2013	4/3/2013		AF22 LOW HUMIDITY
FO-246900	4/4/2013	4/4/2013		LOW HUMIDITY. ROOMS 468, 470, 469, 471, 474 AND 472.
FO-246907	4/4/2013			Room 5550 is Negative to hallway needs to be Positive.
FO-246935	4/4/2013	4/5/2013		RM 7116 CEILING LEAKING GREEN FLUID NEAR AIR VENTS TOWARD THE BACK OF R
FO-246937	4/4/2013	4/4/2013		LOW HUMIDITY IN ROOMS 412, 416, 419, 200.01, & 200.12.
FO-247027	4/5/2013			RM 7119 LOW HUMIDITY
FO-247186	4/8/2013	4/9/2013		LOW TEMP. ALARM. ROOM 0229.
FO-247247	4/9/2013	4/9/2013		RM 2220 & 2225 NO VENTILATION
FO-247655	4/11/2013	4/13/2013		Fan in ceiling outside this room is very loud. Auditory testing just down the hall, may influence
FO-247656	4/11/2013			LOW TEMP. ROOM 0502.
FO-247875	4/15/2013	4/15/2013		DOOR NOT CLOSING. (MAYBE DUE TO AIR PRESSURE) ROOM 5463.
FO-247908	4/15/2013			RM 419 HAS LOW HUMDITY
FO-247909	4/15/2013	4/15/2013		RM 7119 HAS LOW HUMDITY
FO-247921	4/15/2013			AHU-3 HIGH TEMP ALARM
FO-247987	4/16/2013	4/16/2013		FIRE TROUBLE ALARM
FO-248070	4/17/2013			RM 5451 HIGH TEMP
FO-248162	4/18/2013			AHU-3 HIGH TEMP ALARM
FO-248182	4/18/2013			ALL ANIMAL RM'S ARE TOO HOT
FO-248186	4/18/2013	4/18/2013		LOW FLOW ALARMS SOUNDING ON FUME HOODS RM#'s 2336,2342,2348
FO-248192	4/18/2013			Lab way too hot, cannot work. temp at 85
FO-248211	4/18/2013			RM 6312 WALK IN COLD RM BOX HI TEMP ALARM
FO-248273	4/19/2013			RM 461 HAS HI TEMP
FO-248275	4/19/2013			RM 463 HAS HI TEMP
FO-248276	4/19/2013			RM 469 HAS HI TEMP



WO	Recieved	Finished	Total	Request
FO-248277	4/19/2013			RM 472 HAS HI TEMP
FO-248319	4/19/2013			RM 4312 ENCUBATER IS IN ALARM
FO-248320	4/19/2013			RM 5150 IS TOO COLD
FO-248324	4/19/2013			RM 5565 LOW TEMP ALARM
FO-248359	4/19/2013			RMS 422, 424 HAVE CLNG LEAKS FROM ROOFTOP UNITS BEING TURNED ON
FO-248394	4/21/2013	4/21/2013		Low Temp
FO-248395	4/21/2013	4/21/2013		Low Temp
FO-248396	4/21/2013	4/21/2013		Low Temp 0503 0508 0509
FO-248486	4/22/2013			RM 4321 ALARM SOUNDING (POSSIBLY TEMP ALARM)
FO-248538	4/22/2013	4/23/2013		AHU #3 DISCHARGE HI TEMP ALARM
FO-248575	4/23/2013	4/23/2013		EDC AUDITORIUM TOO HOT, MEETING @ 10am RM IS 90 DEGREES
FO-248624	4/23/2013			AHU #3 DISCHARGE HI TEMP ALARM
FO-248758	4/24/2013			5TH FLR MENS RR ACROSS FROM 5114 LAST STALL CLNG HAS BEEN LEAKING OVER
FO-248773	4/24/2013			HIGH TEMPS IN ANIMAL RM'S 0237,0239,0243,0247
FO-248774	4/24/2013			COLD RM 4328 TOO HOT, TEMP 16 DEGREES SHOULD BE 4 DEGREES
FO-248780	4/24/2013			RM 414 ANIMAL QUARTERS TOO HOT
FO-248819	4/24/2013			ENTIRE BSMT ANIMAL QUARTERS HAVE NO HOT WTR COMING FROM TAPS
FO-249014	4/26/2013	4/26/2013		RM 6312 WALK IN COLD RM BOX HI TEMP ALARM
FO-249207	4/29/2013			AHU #3 D/C HI TEMP ALARM
FO-249209	4/29/2013			RM 412 HAS HI TEMP
FO-249211	4/29/2013			RM 7119 HAS HI TEMP
FO-249213	4/29/2013			RM 7119 HAS HI HUMIDITY
<b>E - Area 2 Engineer</b>			<b>16</b>	
FO-246431	4/1/2013	4/1/2013		NO WATER ON THE 4TH FLOOR. (WATER MAIN BREAK)
FO-246846	4/3/2013	4/3/2013		12th FL DOOR ALARM
FO-246854	4/3/2013	4/3/2013		EARLY CHILDHOOD DEV PLAYGROUND PILLAR PLASTIC COVERING HAS BROKEN OF
FO-247128	4/8/2013	4/8/2013		THERMOSTAT IS MAKING LOUD NOISE. ROOM 154.
FO-247577	4/10/2013	4/10/2013		13TH FLR EAST STWL BY ELEVS' DOOR ALARM SNDNG
FO-247652	4/11/2013	4/11/2013		RM 241.1 TAMPER ALARM
FO-247723	4/12/2013	4/12/2013		DOOR ALARMS SOUNDING. 4TH FLOOR - RICK NORK'S OFFICE. (ROOM 4900)
FO-247903	4/15/2013	4/15/2013		BASEMENT DOOR ALARM. HANCOCK SIDE.
FO-247916	4/15/2013	4/15/2013		LOW BATT ALARM (RM 11) 1ST FL SOUTH END FIBER RM
FO-247999	4/16/2013	4/16/2013		S.W. CORNER 1ST FLR AN ALARM IS SNDNG
FO-248142	4/18/2013	4/18/2013		RM 330 HAS A CLNG LEAK NEED SOMETHING TO CATCH WATER
FO-248145	4/18/2013	4/18/2013		RM 226 TOO HOT, HEAT AFFECTING FOOD IN VENDING MACHINES
FO-248206	4/18/2013	4/18/2013		BSMT BLR ALARM SNDNG AGAIN
FO-248301	4/19/2013	4/19/2013		W LOBBY AREA ALARM SOUNDING
FO-248536	4/22/2013			2ND FLR MENS RM WATER LEFT ON GOING INTO 1ST FLR LOBBY
FO-248894	4/25/2013	4/25/2013		Install replacement window AC unit, which is scheduled to arrive on 4/26/13. The AC unit for t
<b>E - Area 3 Auxiliary Eng</b>			<b>44</b>	
H-37230	4/2/2013		4/3/2013	Fix heat vent. The heat has went out.
H-37246	4/3/2013		4/3/2013	Lights in living room and bedroom are not working. -RUSH
H-37250	4/3/2013		4/4/2013	Shower is leaking. Maintenance can not complete their work in shower until leak has been fixe
H-37256	4/4/2013		4/9/2013	Radiator in TV room is leaking and is soaking the carpet creating a moldy smell. Leak in radiat
H-37271	4/5/2013		4/8/2013	Hello, we have an issue with the apartment's first bathroom. There is a water leakage from the
H-37285	4/5/2013		4/8/2013	Garbage disposal is out of order.
H-37283	4/6/2013		4/8/2013	Radiator is leaking in living room.
H-37286	4/7/2013		4/8/2013	Garbage disposal is not working

WO	Recieved	Finished	Total	Request
H-37288	4/7/2013		4/8/2013	Garbage disposal not working correctly and water not going down drain in kitchen sink.
H-37311	4/8/2013	4/10/2013	4/10/2013	Ring is stuck in the sink, and the toilet is clogged with the toilet paper holder.
H-37317	4/8/2013			shower head popped off while resident was taking a shower - 541 Ghafari
H-37329	4/8/2013		4/9/2013	The right side pipes of my kitchen sink are leaking. I would like someone to please come look
H-37350	4/9/2013		4/10/2013	Replace Ballast above room 1213
H-37351	4/9/2013		4/10/2013	Replace Ballast above room 1218
H-37376	4/11/2013		4/18/2013	Water is leaking through the living room and large bedroom windows from the rain; repair is ne
H-37373	4/11/2013		4/11/2013	HEALTH CLINIC IN DEROY...
H-37375	4/11/2013		4/12/2013	There seems to be some type of coolant leaking from the base of the toilet...
H-37377	4/11/2013		4/17/2013	Window Leaking
FO-247681	4/11/2013	4/11/2013		BLR ALARM SNDNG
H-37390	4/11/2013		4/12/2013	Radiator in the living room is leaking. Someone came and tightened it, however it is still leakin
FO-247746	4/12/2013	4/12/2013		FIRE TROUBLE ALARM
H-37402	4/12/2013		4/15/2013	1. Sink trap in the kitchen is leaking
H-37432	4/16/2013		4/17/2013	The fuse blew in the kitchen where the refrigerator is connected.
H-37462	4/16/2013		4/19/2013	the problem is in my bathroom especially in the toilet. I used it this morning. The water did not
H-37459	4/17/2013		4/17/2013	Main sink is leaking in kitchen and needs immediate fix
H-37468	4/17/2013		4/17/2013	power is out in kitchen
H-37473	4/17/2013		4/17/2013	Please remove and replace exit signs, emergency lights and smoke detectors on 3rd floor of
H-37488	4/18/2013			Bathroom sink faucet is leaking.
H-37501	4/18/2013		4/18/2013	Ceiling is leaking in the middle of the living room.
H-37526	4/19/2013		4/22/2013	No hot water coming from sink. Garbage Disposal broken.
FO-248391	4/21/2013	4/21/2013		OBR needs access to roof
FO-248392	4/21/2013	4/21/2013		Occupant hears gas leak
FO-248393	4/21/2013	4/21/2013		NE Interior Panic Bar broke
FO-248394	4/21/2013	4/21/2013		Low Temp
H-37529	4/21/2013		4/22/2013	The kitchen sink pipes leak beneath the sink into the cabinet when it is in use. Needs to be fix
H-37530	4/21/2013		4/22/2013	Constant leak from ceiling in living room.
H-37531	4/21/2013		4/24/2013	Nozzle for the shower fell off.
H-37537	4/22/2013	4/23/2013	4/22/2013	Light switches do not work in the entire apartment. Plugs do work however.
FO-248480	4/22/2013	4/22/2013		FIRE PUMP IS RUNNING
H-37599	4/23/2013		4/26/2013	There was a leakage from the bathroom ceiling and the repair guy made a hole to see where t
H-37617	4/24/2013			kitchen sink tap water is coming out with a green tint
H-37629	4/25/2013			Garbage disposal is making a certain sound which could mean something may be stuck.
H-37638	4/26/2013			leak water from the roof in kitchen
H-37637	4/26/2013			showerhead is broken - 227 Ghafari
<b>E - Controls Engineer</b>			<b>11</b>	
FO-246488	4/1/2013	4/8/2013		refer. crew troubleshoot & calibrate ahu-2 humidifier for lack humidity in 400 suite, priority high.
FO-247171	4/8/2013	4/8/2013		Hook up data logger with electricians.
FO-247365	4/9/2013	4/29/2013		Trade: Controls/Boilers Priority: High
FO-247959	4/15/2013			Room 2537 in EDC (Server Room). The temperature is 85 degrees and the air conditioner is
FO-248191	4/18/2013			Investigate high discharge temps off AHU. Give DX unit a good looking at.
FO-248193	4/18/2013	4/18/2013		Investigate high discharge temps off AHU. Give DX unit a good looking at. Record Starts and
FO-248195	4/18/2013	4/18/2013		Investigate high discharge temps off AHU. Give DX unit a good looking at. Record Starts and
FO-248207	4/18/2013			Investigate Phase Reversal on AHU. Give DX unit a good looking at.
FO-248756	4/24/2013	4/24/2013		Replace broken gauge glass connection on boiler
FO-248913	4/25/2013			ROOFER

WO	Recieved	Finished	Total	Request
FO-248914	4/25/2013			Roofers. High priority. Work due from FO-248843.
<b>Medium</b>			<b>311</b>	
<b>E - Afternoon Engineer</b>			<b>45</b>	
FO-246503	4/1/2013	4/2/2013		SE STAIRWELL TOO WARM
FO-246635	4/2/2013	4/3/2013		8TH FL WEST WING TOO COLD
FO-246637	4/2/2013	4/3/2013		RM 342.1 TOO WARM
FO-246882	4/3/2013	4/4/2013		RM 3255 TOO HOT
FO-246980	4/4/2013	4/5/2013		Very warm about 85 degrees.
FO-247054	4/5/2013	4/6/2013		RM 13201.6 COLD AIR BLOWING FROM VENT
FO-247056	4/5/2013	4/9/2013		Lab 230, fume hoods 3, 5, 10, 11, 12 and 13 failed OEHS inspection. The airflow needs to be
FO-247055	4/5/2013	4/6/2013		PLEASE TURN HEAT DOWN BLDG IS NEAR 100 DEGREES FRONT DOOR(CASS) IS ON
FO-247057	4/5/2013	4/6/2013		LAB 40 TOO HOT
FO-247191	4/8/2013	4/9/2013		RM 4100 TOO HOT
FO-247194	4/8/2013	4/9/2013		RM 7341 EYEWASH NEEDS TO BE REPAIRED ONE SIDE BLOCKED
FO-247378	4/9/2013	4/10/2013		LAB 40 TOO HOT
FO-247379	4/9/2013	4/9/2013		RM 609 TOILET NOT WORKING
FO-247595	4/10/2013	4/11/2013		RM 110 COLD AIR IS BLOWING OUT OF AIR VENTS
FO-247617	4/11/2013	4/16/2013		Having some problems with alignment of sheaves. We found later that the motor base is out o
FO-247778	4/12/2013	4/13/2013		RM 408 PROBLEM WITH HVAC
FO-247936	4/15/2013	4/16/2013		RM 217 TOO HOT
FO-247941	4/15/2013	4/16/2013		RM 3505 & 3354.1 TOO HOT
FO-247950	4/15/2013			RM 1159 IS TOO HOT
FO-248030	4/16/2013	4/17/2013		Room is about 80 degrees - way too hot. Thermostats still do not work.
FO-248031	4/16/2013	4/17/2013		The ceiling vent goes on and off and blows air that smells of gas. It is very uncomfortable for
FO-248023	4/16/2013	4/17/2013		SHUT-OFF EXH FAN #3 @ PANEL causing doors hard to maneuver
FO-248115	4/17/2013	4/18/2013		1ST FL JANITORS CLOSET DRAIN BACKING UP
FO-248118	4/17/2013	4/18/2013		Room too cold
FO-248231	4/18/2013	4/19/2013		Thermostat not working; room very hot.
FO-248232	4/18/2013	4/19/2013		1ST FL EXTREMELY HOT ESPECIALLY DR.KNIGHTS OFF 139, 135, 141
FO-248234	4/18/2013	4/19/2013		3RD FLR EAST HALLWAY BTWN RMS 3014, 3015, & 3016
FO-248241	4/18/2013	4/19/2013		RM 318 WOULD LIKE ENG TO CHECK AND SEE IF ITEMS IN RM ARE COVERED WITH P
FO-248244	4/18/2013	4/19/2013		RM 1502 LEAK
FO-248245	4/18/2013	4/18/2013		RM 11 TOO HOT NEEDS TO ADJUST TEMP
FO-248248	4/18/2013	4/19/2013		Room is too cold.
FO-248250	4/18/2013	4/19/2013		Room is too cold
FO-248376	4/19/2013	4/20/2013		BLDG IS TOO COLD/SHOW TONITE
FO-248542	4/22/2013	4/23/2013		Inside cashiers office on the second floor office #217 has blown a fuse.
FO-248642	4/23/2013			Per Tim Herr, Maintenance Team Leader. Please check air handlers (ac unit) for water, possib
FO-248643	4/23/2013	4/24/2013		CONTRACTOR NEEDS BLDG ENG TO ASSIST WITH OPENING ELEV TO MOVE SUPPLIE
FO-248645	4/23/2013	4/24/2013		RM 2177 TOO HOT
FO-248845	4/24/2013	4/25/2013		BURNING RUBBER SMELL COMING FROM GENERATOR OUTSIDE OF BLDG
FO-248849	4/24/2013	4/25/2013		RM 330 & 430 AUTOCLAVE NOT GETTING ENOUGH STEAM PRESSURE
FO-248954	4/25/2013	4/26/2013		Fans are extremely loud, creating a cold draft,
FO-249048	4/26/2013	4/26/2013		RM 103 IS TOO HOT
FO-249049	4/26/2013	4/26/2013		RM 133 IS TOO HOT
FO-249228	4/29/2013	4/29/2013		RM 395 IS TOO HOT
FO-249236	4/29/2013	4/30/2013		BLDG IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-249237	4/29/2013	4/30/2013		RM 2177 IS TOO HOT
<b>E - Area 1 Engineer</b>			<b>76</b>	
FO-246445	4/1/2013	4/1/2013		TOO COLD. ROOM 5449.
FO-246576	4/2/2013	4/2/2013		RM 101 TOO COLD
FO-246580	4/2/2013	4/2/2013		TOO HOT. ROOM 40.
FO-246589	4/2/2013	4/2/2013		GREEN LECTURE HALL IS TOO COLD
FO-246833	4/3/2013	4/3/2013		RM 373 IS TOO COLD
FO-246836	4/3/2013	4/3/2013		2nd FL Locker 280, door is jammed and wont open.
FO-246901	4/4/2013	4/4/2013		LOUD WHISTLING NOISE. ROOMS 463 & 471.
FO-246903	4/4/2013	4/4/2013		Office 1163 is too cold. Employee is feeling the vcold air coming down from the ceiling fans.
FO-246904	4/4/2013	4/4/2013		Building Engineer manually adjusted thermostat to make it hotter in Dean's Suite. It is now to
FO-246929	4/4/2013	4/4/2013		RM 454 HAS A CLNG LEAK
FO-246931	4/4/2013	4/4/2013		RM 456 HAS A CLNG LEAK
FO-246932	4/4/2013	4/4/2013		RM 458 HAS A CLNG LEAK
FO-247008	4/5/2013	4/5/2013		RM 5449 TOO COLD
FO-247051	4/5/2013	4/5/2013		RM 6133 IS TOO HOT
FO-247138	4/8/2013	4/8/2013		RM 1128 DR MATTISONS AREA TOO HOT
FO-247147	4/8/2013	4/8/2013		ESS TECHNICIAN NEED ACCESS TO ROOM 5561.
FO-247153	4/8/2013	4/8/2013		Fume Hood in 3310 ir running very noisy. Can you please have the Building Engineer look at.
FO-247154	4/8/2013	4/9/2013		RM 354 FRONT AREA(MARY& HEATHER)DESK COLD AIR BLOWING DOWN
FO-247180	4/8/2013	4/9/2013		TOO HOT. ROOMS 3124 AND 3126.
FO-247225	4/8/2013	4/9/2013		Office too warm. Have fan on and just moving hot air around office. Back section of second fl
FO-247234	4/9/2013	4/10/2013		TOO HOT. ROOM 1313.
FO-247239	4/9/2013	4/12/2013		TOO HOT. ROOM 1104.
FO-247310	4/9/2013	4/9/2013		RM 0249 TOO HOT
FO-247519	4/10/2013	4/10/2013		RM 030 IS TOO HOT
FO-247560	4/10/2013	4/12/2013		Thermostat set at 65 degrees and the current temperature is 80 degrees.
FO-247568	4/10/2013	4/10/2013		TOO COLD. ROOM 5449.
FO-247570	4/10/2013	4/10/2013		3RD FL TOO COLD
FO-247578	4/10/2013	4/10/2013		BLDG IS TOO COLD
FO-247660	4/11/2013	4/12/2013		TOO COLD. ROOMS 2601, 2603, 2605 AND 2612.
FO-247733	4/12/2013			TOO HOT. ROOM 1104. CALL SHERYL MACGILLIS 7-1446.
FO-247741	4/12/2013	4/15/2013		RM 5463 IS TOO HOT
FO-247886	4/15/2013			RM 3317 HAS NO AIR FLOW/WARM/STUFFY
FO-247902	4/15/2013			TOO WARM. ROOM 103.
FO-247930	4/15/2013			RM 4112 IS TOO HOT
FO-247931	4/15/2013			RM 4114 IS TOO HOT
FO-247968	4/16/2013			BLDG IS TOO HOT
FO-247979	4/16/2013			Office is to warm, currently 81.
FO-247980	4/16/2013	4/16/2013		Temp is @ 79 degrees - Too Hot
FO-248013	4/16/2013	4/16/2013		ENTIRE BLDG IS TOO HOT
FO-248065	4/17/2013			RM 1328 IS TOO HOT
FO-248154	4/18/2013			LAB 103 TOO WARM
FO-248190	4/18/2013	4/18/2013		Too warm
FO-248208	4/18/2013			RM 5455/DLAR STILL HAS HI TEMP
FO-248209	4/18/2013			RM 3125 IS TOO HOT
FO-248212	4/18/2013			RM 034 IS EXTREMELY HOT

WO	Recieved	Finished	Total	Request
FO-248215	4/18/2013			ENTIRE 3RD FLR IS TOO HOT
FO-248214	4/18/2013			RM 1540 IS TOO HOT
FO-248222	4/18/2013	4/18/2013		Office is 80 degrees and climbing. Way too hot.
FO-248217	4/18/2013			RM 5275 ONLY FUMEHOOD NO AIR FLOW
FO-248225	4/18/2013			RM 3127 TOO HOT
FO-248335	4/19/2013			RM 34 WATER LEAKING FROM CEILING IN BSMNT
FO-248337	4/19/2013			4TH & 5TH FL W CORRIDOR TOO COLD
FO-248338	4/19/2013			rm 5617 is too cold
FO-248341	4/19/2013			RM 5447/DLAR IS TOO COLD
FO-248342	4/19/2013			RM 5449/DLAR IS TOO COLD
FO-248343	4/19/2013			RM 5451/DLAR IS TOO COLD
FO-248345	4/19/2013			RM 5455/DLAR IS TOO COLD
FO-248346	4/19/2013			RM 5565/DLAR IS TOO COLD
FO-248352	4/19/2013	4/19/2013		RM 030/BSMT TOO HOT
FO-248503	4/22/2013			3136 Room is extremely cold
FO-248520	4/22/2013			Adjust damper for office. Air is blowing out vents in room.
FO-248521	4/22/2013	4/22/2013		It is 79-80 degrees fahrenheit in our office. The air coming out of the vents is 80 degrees.
FO-248523	4/22/2013			RM 034 IS EXTREMELY HOT (OVER 80degrees)
FO-248625	4/23/2013			RM 0034/STILL TOO HOT It is 79-80 degrees fahrenheit in our office. The air coming out of t
FO-248770	4/24/2013			Lab is to warm, current temperature is 80
FO-248789	4/24/2013			RM 231 TOO COLD
FO-248790	4/24/2013			GREEN LECT HALL IS TOO COLD
FO-248797	4/24/2013	4/24/2013		RM 0309/SURGERY RM IS TOO COLD (surgery in progress)
FO-248893	4/25/2013	4/25/2013		RM 1128 TOO HOT
FO-248920	4/25/2013			Room is too hot - 80 degrees and climbing. We have been reporting the same problem every
FO-248949	4/25/2013	4/26/2013		RM 034 IS STILL TOO HOT NOT ABLE TO CONTROL TEMP
FO-249163	4/29/2013			BSMT IS TOO HOT
FO-249164	4/29/2013			BSMT IS TOO HOT
FO-249170	4/29/2013			RM 1128 IS TOO HOT
FO-249183	4/29/2013			RM 103 IS TOO HOT
FO-249198	4/29/2013			RM 3016 IS TOO HOT
<b>E - Area 2 Engineer</b>			<b>99</b>	
FO-246439	4/1/2013	4/1/2013		TOO COLD. BASEMENT, 1ST & 2ND FLOORS. ALSO CIRCULATION AND REFENCE DE
FO-246464	4/1/2013	4/1/2013		TOO HOT. BUILDING.
FO-246497	4/1/2013	4/1/2013		TOO COLD. ROOM 8307.3.
FO-246577	4/2/2013	4/2/2013		BSMT STORAGE AREA NEAR ELEV TOO COLD
FO-246584	4/2/2013	4/2/2013		ENTIRE LIBRARY TOO COLD BSMNT -2ND FL
FO-246837	4/3/2013	4/3/2013		TOO WARM. ROOM 1120.
FO-246839	4/3/2013	4/3/2013		TOO COLD. ROOM 8307.2
FO-246850	4/3/2013	4/3/2013		RM 250 TOO COLD
FO-246905	4/4/2013	4/4/2013		ENTIRE 1ST FLR IS EXTREMELY COLD
FO-246913	4/4/2013	4/4/2013		TOO HOT. ROOMS 328, 358, 368 & 308.
FO-246945	4/4/2013	4/4/2013		Engineer - Investigate why AHU1 is discharging 71 when setpoint is 65. Make certain no point
FO-246949	4/4/2013	4/5/2013		RM 226 IS TOO HOT/T-STAT NOT WRKNG
FO-246955	4/4/2013	4/5/2013		THERMOSTAT COVER IS BROKEN. ROOM 9 (BASEMENT)
FO-246957	4/4/2013	4/4/2013		RM 398 COLD AIR IS BLOWING OUT AIR VENTS
FO-247002	4/5/2013	4/5/2013		2ND FLR STE 294 (Dirs' flr) IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-247003	4/5/2013	4/5/2013		Office 222 has very high temperatures that do not match the temperature of the rest of the buil
FO-247150	4/8/2013	4/8/2013		TOO HOT. ROOM 400.
FO-247165	4/8/2013	4/8/2013		Offices on the 3rd floor are hot (85 degrees and higher). Please turn down the heat a little (act
FO-247224	4/8/2013	4/9/2013		Office is too warm - back section of second floor too hot.
FO-247228	4/9/2013	4/9/2013		TOO HOT. ROOM 441.
FO-247240	4/9/2013	4/9/2013		RM 4100 TOO HOT
FO-247366	4/9/2013	4/24/2013		Check and repair shaft seal on boiler feedwater pump.
FO-247367	4/9/2013	4/9/2013		TOO HOT. BUILDING. (TURN HEAT OFF)
FO-247515	4/10/2013			TOO WARM. ROOM 1155.
FO-247542	4/10/2013	4/10/2013		NEED KEY TO 3RD FLOOR.
FO-247553	4/10/2013	4/10/2013		VERY COLD. SERVICE CENTER.
FO-247556	4/10/2013	4/10/2013		ENTIRE BLDG IS TOO COLD
FO-247557	4/10/2013	4/11/2013		RM 3305 IS TOO COLD
FO-247635	4/11/2013	4/11/2013		R/R RM 421 CLNG IS LKNG
FO-247641	4/11/2013	4/11/2013		RM/STE 226 IS TOO COLD
FO-247640	4/11/2013	4/11/2013		3RD FL FIRE DOORS NEED TO BE OPEN
FO-247664	4/11/2013	4/11/2013		RM 110 &112 TOO COLD. COLD AIR BLOWING FROM VENTS
FO-247666	4/11/2013	4/11/2013		ALARM SOUNDING. 2ND FLOOR STAIRWELL.
FO-247673	4/11/2013	4/11/2013		MAIN LOUNGE IS TOO HOT
FO-247675	4/11/2013	4/11/2013		TOO HOT. ROOM 1515.
FO-247682	4/11/2013	4/11/2013		RM 427 RED LITE IS ON NO HEAT/TOO COLD
FO-247715	4/12/2013	4/12/2013		GALLERY AREA IS TOO HOT
FO-247719	4/12/2013	4/12/2013		RM 140/AUDITORIUM AREA IS TOO HOT
FO-247727	4/12/2013	4/12/2013		TOO COLD. ROOM 4100.
FO-247761	4/12/2013	4/12/2013		2ND FLR OUTSIDE OF STE 249 CLNG IS LKNG
FO-247915	4/15/2013	4/15/2013		TOO HOT. ROOMS 247 AND 249.
FO-247917	4/15/2013	4/15/2013		TOO HOT. ROOM 421.
FO-247928	4/15/2013	4/15/2013		BLDG IS TOO HOT
FO-247967	4/16/2013	4/16/2013		RM 100 IS TOO COLD
FO-247981	4/16/2013	4/17/2013		RM 218 TOO HOT
FO-248001	4/16/2013	4/16/2013		6TH FL TOO HOT
FO-248004	4/16/2013	4/16/2013		RM 1147 AIR CONDITIONER BLOWING TOO COLD
FO-248045	4/17/2013			Bldg. Engineer (T. Mitchell) Med Priority
FO-248052	4/17/2013	4/17/2013		RM 239 IS EXTREMELY COLD
FO-248053	4/17/2013	4/17/2013		ENTIRE 2ND FLR EXTREMELY COLD
FO-248069	4/17/2013	4/17/2013		RM 250 IS TOO COLD
FO-248072	4/17/2013	4/17/2013		STE 13201.3 IS TOO COLD
FO-248074	4/17/2013	4/17/2013		STE 13201.4 IS TOO COLD
FO-248075	4/17/2013	4/17/2013		STE 13201.5 IS TOO COLD
FO-248077	4/17/2013	4/17/2013		STE 13201.6 IS TOO COLD
FO-248080	4/17/2013	4/17/2013		RM 247 IS EXTREMELY HOT
FO-248081	4/17/2013	4/17/2013		RM 249 IS EXTREMELY HOT
FO-248152	4/18/2013	4/19/2013		Radiator is making a lot of noise. Considering how warm it is outside, the boiler should not ev
FO-248144	4/18/2013	4/19/2013		RM 217 TOO HOT
FO-248150	4/18/2013	4/18/2013		DISPATCH IS TOO WARM, HAVING A PROBLEM WITH MAIN HVAC NOT WORKING. PLE
FO-248166	4/18/2013	4/18/2013		BLDG TOO WARM
FO-248185	4/18/2013	4/18/2013		RM 7906.5 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-248196	4/18/2013	4/18/2013		RM 441.3 TOO HOT
FO-248210	4/18/2013	4/18/2013		RM 7908 IS TOO COLD
FO-248216	4/18/2013	4/18/2013		BLDG IS EXTREMELY HOT
FO-248221	4/18/2013	4/18/2013		THEATRE/WAREHOUSE AREA DUCTWORK IS LKNG
FO-248281	4/19/2013			Radiator valves in rooms 229 and 231 are either frozen open or frozen shut. Please make ope
FO-248287	4/19/2013	4/19/2013		BUZZING NOISE COMING FROM BOILER RM
FO-248292	4/19/2013	4/19/2013		RM 6203 TOO HOT
FO-248318	4/19/2013	4/19/2013		BLDG TOO COLD
FO-248323	4/19/2013	4/19/2013		RM 441.3 IS TOO COLD
FO-248328	4/19/2013	4/19/2013		RM 4231 TOO COLD
FO-248483	4/22/2013	4/22/2013		RM 7904.2 TOO COLD
FO-248489	4/22/2013	4/22/2013		2ND FL LOCK SHOP SW CORNER TOO HOT
FO-248497	4/22/2013	4/22/2013		STE 3638 TOO COLD
FO-248508	4/22/2013	4/22/2013		STE 3300 IS TOO COLD
FO-248509	4/22/2013	4/22/2013		STE 3600 IS TOO COLD
FO-248511	4/22/2013	4/22/2013		STE 3638 IS TOO COLD
FO-248572	4/23/2013	4/23/2013		RM 7904.2 TOO COLD
FO-248580	4/23/2013	4/23/2013		RM 7906.2 TOO COLD
FO-248608	4/23/2013			MAIN LOBBY/LNG RM 026 IS TOO HOT
FO-248628	4/23/2013	4/23/2013		POOL KEEPS FILLING HOWEVER WATER LEVEL DECREASES
FO-248629	4/23/2013	4/23/2013		AFTER FAP TESTING S.F. IN BSMT STOPPED WRKNG
FO-248635	4/23/2013			RM 109 IS TOO HOT
FO-248778	4/24/2013	4/24/2013		RM 2103 TOO HOT, VENTILATION SYSTEM NEEDS TO BE CHECKED
FO-248783	4/24/2013	4/24/2013		POOL LEVEL DROPPING RAPIDLY
FO-248791	4/24/2013			RM 50 AIR VENTILATION HOODS NOT WORKING PROPERLY
FO-248805	4/24/2013			Furnace#5 not working.
FO-248799	4/24/2013	4/24/2013		2ND FLR LOCK SHOP IS STILL TOO HOT
FO-248810	4/24/2013	4/24/2013		RM 4249 IS TOO COLD
FO-248811	4/24/2013	4/24/2013		BLDG IS TOO COLD
FO-248898	4/25/2013	4/25/2013		Office 14110.2   There is no air circulation.
FO-248975	4/26/2013			ENTIRE 1ST FLR IS TOO HOT
FO-248983	4/26/2013			RM 6201/CONF RM A IS TOO HOT
FO-248987	4/26/2013			RM 3660 IS TO COLD
FO-249003	4/26/2013			BACKSTAGE GREEN RM IS TOO HOT
FO-249173	4/29/2013	4/29/2013		RM 3104 IS TOO HOT
FO-249179	4/29/2013	4/29/2013		2ND FLR IS TOO HOT
FO-249206	4/29/2013	4/30/2013		INSIDE STE 219 RM 219.1 COLD AIR BLOWING
<b>E - Area 3 Auxiliary Eng</b>			<b>84</b>	
H-37200	4/1/2013		4/1/2013	The water faucets in the shower aren't working properly. When the knob is pulled on the lower
H-37225	4/1/2013		4/2/2013	The LAN port in the first living room is not working.
H-37224	4/2/2013		4/4/2013	First floor bathroom, handicap stall toilet does not flush.
H-37236	4/2/2013		4/3/2013	Handle of toilet is broken in 1st bathroom.
H-37231	4/3/2013	4/8/2013	4/8/2013	Thermostat will not move from 75 and 76 degrees even when it is set to a lower temperature.
H-37239	4/3/2013		4/3/2013	Install "EXIT" sign on 2nd floor by rooms 210/211.
H-37247	4/3/2013		4/4/2013	Kitchen sink blocked and the garbage disposal doesn't work. Needs repair. Thank you.
H-37263	4/4/2013		4/5/2013	The heat vent went out again. Needs to be fixed.
H-37269	4/4/2013		4/8/2013	The Insink erator is not working and due to this we are facing difficulties in using the kitchen.

WO	Recieved	Finished	Total	Request
H-37336	4/6/2013		4/10/2013	Kitchen sink aerator not functional
H-37337	4/6/2013		4/16/2013	there is no warm water in the apartment. Even at the max for warm, the water is mild.
H-37338	4/7/2013		4/18/2013	Hot water is not coming in the bathrooms
H-37340	4/7/2013		4/10/2013	Engineers left a note for other engineers to check the rooms that have no hot water. These ro
H-37341	4/8/2013		4/9/2013	First bathroom - toilet tank constantly dripping, and no hot water from sink or shower.
H-37342	4/8/2013		4/10/2013	NO HOT water in bathroom!
H-37343	4/8/2013		4/10/2013	the bathrooms have no hot water from time to time
H-37302	4/8/2013		4/8/2013	Garbage disposal is not working and sink is clogged.
H-37304	4/8/2013		4/9/2013	Exit Light is out
H-37344	4/8/2013		4/10/2013	We don't have hot water in the bathrooms. Actually, it is super cold.
H-37320	4/8/2013		4/8/2013	The garbage disposal in the sink does not seem to be functioning.
H-37345	4/8/2013		4/16/2013	We are not getting any hot water. I tried it once in the morning and once again in the afternoon
H-37346	4/9/2013		4/11/2013	5th floor hallway, between apartments 504 and 506 light needs a new balice. Light is not work
H-37352	4/9/2013		4/9/2013	The sink erator in the kitchen is not working properly. Taking long time to drain the water.
H-37360	4/10/2013			In the kitchen Area the garbage disposal is the problem. The Issue is that after cleaning the di
H-37374	4/11/2013		4/11/2013	Our kitchen sink is clogged and water appears to build-up and not drain adequately along with
H-37368	4/11/2013			heat isn't blowing out of the vent. Cool air isauthenticated user: Jasmine Unavailable - ez8
H-37421	4/11/2013		4/17/2013	University Tower Apt. Engineer do the following on Friday morning (tomorrow):
H-37384	4/11/2013		4/16/2013	Heat not working
H-37381	4/12/2013		4/12/2013	The ceiling in the kitchen and in the hallway by the front door leaks when it rains outside. The r
H-37383	4/12/2013		4/16/2013	The larger bedroom ceiling is leaking about 6 inches from the window. Needs to be looked at
H-37404	4/12/2013			Heat will not blow warm air when engaged.authenticated user: Samantha Arzola - ee8936r
H-37407	4/15/2013		4/16/2013	The shower head continues to drip after it is not in use any longer. Could someone possibly st
H-37422	4/15/2013		4/16/2013	URGENT - We have already requested for the Garbage disposal not working. We have a smal
H-37423	4/15/2013		4/16/2013	My room is not getting any hot water from the sink or the tub. Please fix this as soon as possib
H-37425	4/15/2013		4/16/2013	Hi, the hot water supply in the apartment 911 seems to be completely dysfunctional. Regardle
H-37426	4/15/2013		4/16/2013	No hot water
H-37435	4/16/2013			Ac vent grill screw brokenauthenticated user: Gurbinder Singh Dhaliwal - dz4639requester
H-37436	4/16/2013		4/17/2013	Need to change the lan cable socket.It has come out
H-37442	4/16/2013		4/16/2013	The airconditioning unit in our apartment is not working so it is difficult to lower the temperatur
H-37430	4/16/2013		4/16/2013	Garbage Disposal went out and needs to be repaired.
H-37445	4/16/2013		4/17/2013	The toilet right besides the large bedroom doesn't seem to flush properly. Could you come an
H-37456	4/16/2013		4/17/2013	ATTN: Engineer. 3rd Floor Trash room, light is out. Needs a ballast.
H-37458	4/16/2013		4/17/2013	Our shower head hose needs to be fixed. The part that goes to the back of the wall is off the w
H-37474	4/17/2013		4/18/2013	Dining room electrical outlet cover is broken.
H-37475	4/17/2013		4/18/2013	2nd bathroom: The faucet in the bathtub does not seal during a shower and the drain doesn't
H-37480	4/17/2013			Shower started Drippingauthenticated user: Carmen Parsons - fa7692requester ip address:
H-37494	4/17/2013		4/19/2013	Per Jack Evans:
H-37486	4/18/2013		4/17/2013	reset garbage disposal
H-37498	4/18/2013		4/25/2013	Leak on handle lever, adult toilet near front desk.
H-37503	4/19/2013		4/19/2013	The AC is not working well.
H-37519	4/19/2013			bathroom closest to kitchen not flushing/clogged, just fills up with water. requesting to get it fix
H-37510	4/19/2013			Two of the outlets in my room are not working any longer. authenticated user: Rico Fierros -
H-37541	4/19/2013		4/22/2013	Bathroom closest to the door: light is permanently on. Only way we keep it off is to tape down
H-37542	4/20/2013		4/22/2013	The ventilator in the living room needs to be fixed.
H-37543	4/20/2013		4/23/2013	Kitchen sink pipes seem to be clogged. It might be the garbage disposal or the pipes. Water
H-37544	4/20/2013		4/22/2013	Our garbage disposer is not working, the garbage stuck there begins to rot and it is stinky



WO	Recieved	Finished	Total	Request
H-37546	4/20/2013		4/23/2013	The toilet is not functioning again. Please fix it.
H-37549	4/22/2013		4/22/2013	Kitchen zinc Grinding system is not working, and it smells foul. Need immediate service
H-37550	4/22/2013		4/22/2013	Kitchen sink grinding system not working, need immediate service, smells foul
H-37551	4/22/2013		4/22/2013	Toilet flush not working properly, getting stuck.
H-37554	4/22/2013		4/23/2013	The electric outlet behind the futon in the bedroom fell out including plastic cover. The cover is
H-37571	4/23/2013		4/23/2013	The toilet of the first bathroom is having a problem with the flush again. It was taken care of thi
H-37587	4/23/2013			Outlet next to fridge and underneath cabinets needs fixingauthenticated user: Nancy Varghe
H-37588	4/23/2013		4/26/2013	End bathroom keeps running after flushing toilet needs to be fixed
H-37590	4/23/2013		4/24/2013	Per Phyllis, main trash room on 1st floor is leaking.
H-37611	4/24/2013			Cool air blows out when thermostat is set to heat. authenticated user: Jessyka Faison - eq99
H-37618	4/24/2013			Garbage disposal doesn't work and both the kitchen sinks are blocked. Thank you!
H-37619	4/24/2013			I saw the note left in our apt. However, did you check the 4oC rather than the -20oC? It is still
H-37621	4/24/2013			please fix the toilet in the second bathroom
H-37626	4/25/2013		4/25/2013	Water supply line to toilet tank blocked by something. Tried turning off and on valve to unblock
H-37634	4/26/2013			water pressure in shower is very low - 642 Ghafari
H-37648	4/26/2013			after flushing the toilet the tank fills up very slowly
H-37656	4/26/2013			Vacant - Eng. Check
H-37671	4/26/2013			Vacant - Eng. Check
H-37672	4/26/2013			Vacant - Eng. Check
H-37673	4/26/2013			Vacant - Eng. Check
H-37674	4/26/2013			Vacant - Eng. Check
H-37675	4/26/2013			Vacant - Eng. Check
H-37687	4/26/2013			Faulty Kitchen drainage system
H-37695	4/27/2013			change A/C filter
H-37645	4/27/2013			Something is caught in the garbage disposal in the sink, causing it to not work.
H-37696	4/28/2013			Toilet Tank Damaged of washroom with tub
H-37719	4/29/2013			THIS IS NOT A REPEATED REQUESTToilet doesn't work. NEITHER of our toilets work.
H-37720	4/29/2013			G/D broken/leakingauthenticated user: - requester ip address: 141.217.220.164
<b>E - Controls Engineer</b>			<b>7</b>	
FO-232482	4/1/2013			REFRIG CREW:
FO-246832	4/3/2013	4/4/2013		Please do the burner adjustment so the boiler can be returned to service.
FO-247125	4/8/2013			Boilers & controls- basement room 008 the stat is not operating properly .no air to stat & the c
FO-247179	4/8/2013			Controls Med.
FO-247269	4/9/2013			Refg. Crew/Honeywell:
FO-247977	4/16/2013			Controls, please repair air leak for contol valve below cooling tower #1.
FO-248755	4/24/2013			OUTSIDE RM 1023 CEILING LEAKING.SCHREIBER ROOFING WAS OUT ON 4-23-13. REP
<b>Low</b>			<b>158</b>	
<b>E - Afternoon Engineer</b>			<b>5</b>	
FO-247775	4/12/2013			Temperture in lab in not maintain properly. They are saying inefficient heating. Can call Sahil
FO-247943	4/15/2013	4/15/2013		RM 117/MECH RM NEED ACCESS TO RM FOR SECURITY CAMERA INFO
FO-248547	4/22/2013	4/23/2013		This pertains to Work Order # FO-248521, which has a status of "Finished." The temperature
FO-249051	4/26/2013	4/27/2013		Restrooms 322.09 and 322.10: inadequate ventilation, smells waft to nearby offices.
FO-249234	4/29/2013			Since chiller is not running for our building yet we need to have the auxiliary cooling unit runni
<b>E - Area 1 Engineer</b>			<b>43</b>	
FO-246575	4/2/2013	4/22/2013		Room Lab 3430 - Ventilation is not adequate. Please check ceiling vents; fume hood seems t
FO-246587	4/2/2013	4/2/2013		Dean Business Office and Suite is exceptionally cold. Can you please have buidling engineer
FO-246954	4/4/2013	4/4/2013		RM 125 ONLY WINDOW LOOKS AS IF SOMEONE COULD HAVE BEEN TAMPERING W/IT
FO-247552	4/4/2013	4/10/2013		The door from the stairs to the basement hallway became physically shut. Could not be open

WO	Recieved	Finished	Total	Request
FO-246999	4/5/2013	4/5/2013		ELEV AS YOU FACE THEM ON YOUR LEFT STUCK ON 1ST FLR DOORS OPEN?
FO-247547	4/10/2013			Air conditioning blowing strongly over head, please adjust blower strength.
FO-247562	4/10/2013			Thermostat set at 65 degrees and the current temperature is 80 degrees.
FO-247579	4/10/2013			2ND FLR HALLWAY OUTSIDE OF RM 2301 HAS A CLNG LEAK
FO-247581	4/10/2013			AF - 5 CLNG LEAK
FO-247624	4/11/2013			Whistleing sound started at 7:40
FO-247625	4/11/2013			Whistleing sound started at 7:40
FO-247626	4/11/2013			Whistleing sound started at 7:40am
FO-247632	4/11/2013	4/11/2013		Alarm is going off when you enter the Engineering Buidling. Right next to the Hall of Fame Co
FO-247882	4/15/2013	4/15/2013		Room 1301: Weighing tank that is full of water needs to be emptied. Please contact building
FO-247885	4/15/2013	4/15/2013		RM 169 TOO HOT
FO-247957	4/15/2013			The chemical fume hoods in Elliman 1145
FO-247976	4/16/2013			FREIGHT ELEV DOORS WILL NOT OPEN ON DESIGNATED FLRS
FO-247991	4/16/2013			lab is to warm, currently 83.
FO-247995	4/16/2013			lab is to warm, currently 84.
FO-247994	4/16/2013			lab is to warm, currently 80.
FO-247998	4/16/2013			lab is to warm, currently 82.
FO-248017	4/16/2013			5TH FLR/DLAR AIR PRESSURE MAIN ENT DOOR BY FREIGHT ELEV SECURITY DOOR I
FO-248149	4/18/2013			bearing assembly for hot water circ pump in PH mechanical room
FO-248178	4/18/2013	4/18/2013		Water leaking from under mechanical room door.
FO-248175	4/18/2013			Fume hood in 3012 is making a very loud noise that is bothering the people in the room below
FO-248219	4/18/2013			MSIS way too hot
FO-248369	4/19/2013			Room 2603 now has a leak in it. I think the leak in the room next to it, 2601, has spread to 26
FO-248512	4/22/2013			RM 0225/CAGE WASH RM NO WATER IS GOING TO CAGEWASH
FO-248605	4/23/2013	4/30/2013		CALLED SCHINDLER ELEV CO FOR Elevator near Margherio Conference Center: hand-rail i
FO-248754	4/24/2013			Ac/Refrig. High priority. Work due to FO248639. Repair/replace AC for cooler #4330-refrig line
FO-248813	4/24/2013			Room is too cold please adjust.
FO-248814	4/24/2013			Replace bearing
FO-248938	4/25/2013			RM 4328 WALK-IN COLD RM BOX HAS SHUTDOWN (refer FO248639).
FO-248960	4/25/2013	4/30/2013		Sinks in labs 0331, 0331.1 and 0331.22 do not have hot water available. Even when water ru
FO-248961	4/25/2013	4/25/2013		Restrooms on the first and 2nd floors in the Engineering Buidling (Old Buidling) Women's bath
FO-248999	4/26/2013			JCI replace sensor OEM part # 623-00240
FO-249022	4/26/2013			Inconsistant humidity levels recently. Humidity seems to drop down to 19% at night and rise a
FO-249025	4/26/2013			There is no hot water THROUGHOUT the ENTIRE animal quarters.
FO-249180	4/29/2013	4/29/2013		Turn heat off in entire building.
FO-249182	4/29/2013	4/29/2013		1st floor of the Engineering Technology Bldg. is very warm. This includes all faculty and staff
FO-249210	4/29/2013			Room 5108 is too hot
FO-249212	4/29/2013			service line thermostat is buzzing loudly
FO-249233	4/29/2013			Replace dirty air filter and adjust air pressure. It is very noisy in room.
<b>E - Area 2 Engineer</b>			<b>25</b>	
FO-246817	4/3/2013	4/3/2013		RM 250 HAS NO HEAT/TOO COLD
FO-246834	4/3/2013	4/4/2013		AC unit is very loud and can be heard in room 314 when running. Compressor did not come o
FO-247619	4/10/2013	4/10/2013		It has been reported that there is water on the floor of the Men's bathroom that is between the
FO-247683	4/11/2013	4/11/2013		DELIVERY MAN NEED ACCESS THRU GATE FOR CHEMICAL DELIVERY
FO-247760	4/12/2013	4/12/2013		NEED ACCESS TO BSMT FROM POOL AREA SO THEY CAN VIEW POOL FROM AREA
FO-247869	4/15/2013	4/23/2013		Siemens/DDC/Controls...High Priority.
FO-247974	4/16/2013	4/16/2013		RM 0014/ART COLLECTION AREA HAD A CLNG LEAK 4/15/13 WOULD LIKE TO KNOW T

WO	Recieved	Finished	Total	Request
FO-247986	4/16/2013	4/16/2013		Window won't stay open when lifted
FO-248073	4/17/2013			REplace gasket for chiller
FO-248078	4/17/2013			REplace gasket for chiller
FO-248140	4/18/2013	4/18/2013		13TH FLR EAST STRWL DOOR ALARM IS SNDNG
FO-248265	4/18/2013	4/19/2013		Room 322A, pipes protruding from the side of the kitchen countertop. Can we please have the
FO-248269	4/18/2013	4/19/2013		Room 422A, pipes protruding from the side of the kitchen countertop. Can we please have the
FO-248278	4/19/2013			RM 257 INVESTIGATE A LEAK FROM YESTERDAY EVEN/4-18-13 & CALL MARIE W/STAT
FO-248481	4/22/2013	4/22/2013		PEDERSON GLASS NEED ACCESS TO ROOF TO REPLACE SKYLITE GLASS
FO-248568	4/23/2013	4/23/2013		CK BLDG AIR PRESSURE CAUSING DOORS NOT TO CLOSE WHICH SETS SEC DR ALA
FO-248610	4/23/2013			RM 103 CK SCRATCHED WINDOW
FO-248634	4/23/2013	4/23/2013		In classroom 2255, the projector was found to be unresponsive approximately two months ago
FO-248895	4/25/2013	4/25/2013		Install replacement window AC unit scheduled to be delivered to WSU on 4/26/13.
FO-248897	4/25/2013	4/25/2013		Install replacement window AC unit to be delivered to WSU on 4/26/13.
FO-248903	4/25/2013	4/25/2013		Install replacement window AC unit to be delivered to WSU on 4/26/13.
FO-248973	4/26/2013	4/26/2013		ELEV AS YOU FACE THEM TO YOUR FAR RIGHT IS STUCK ON 1ST FLR DOORS CLOSE
FO-248985	4/26/2013	4/26/2013		HANDICAP DOORS ARE PARTIALLY OPENNING BOTH SETS INTERIOR/EXTERIOR DRS
FO-249171	4/29/2013			Extremely warm in the TRC. Thermostats are flashing. May have had a power bump over the
FO-249178	4/29/2013			N.E. ELEV NOT RESPONDNG TO ANY CALLS
<b>E - Area 3 Auxiliary Eng</b>			<b>27</b>	
H-37177	4/1/2013		4/2/2013	Air conditioning not going below 72 degrees. We turned it all of the way down to 65 degrees a
H-37197	4/1/2013		4/3/2013	Sink problem in Kitchen, Sink problem in washroom 1
H-37190	4/1/2013		4/2/2013	Shortage in light over kitchen sink; keeps turning off.
H-37203	4/1/2013			Light out in hallway near apt. 505
H-37204	4/1/2013		4/8/2013	7th floor center stairwell light is out.
H-37249	4/3/2013	4/3/2013	4/3/2013	our bathroom light went out and would like it to be changed please.
H-37262	4/4/2013	4/5/2013	4/5/2013	the air/heat does not work
H-37279	4/5/2013	4/8/2013	4/8/2013	Garbage disposal out of order--Engineering
H-37280	4/5/2013	4/8/2013	4/8/2013	Lounge--Garbage disposal out of order--Engineering
H-37281	4/5/2013	4/8/2013	4/8/2013	Lounge--Thermostat missing
H-37290	4/5/2013			Drain in the middle of bathroom(not shower) is emitting a foul order. Resident thinks it may be
H-37278	4/7/2013		4/8/2013	Shower head is broken
H-37420	4/8/2013		4/16/2013	Heat and air conditioning not working,
H-37328	4/9/2013		4/9/2013	The kitchen light above the sink is not working. The resident said he tried replacing the bulb, b
H-37448	4/10/2013		4/17/2013	My thermometer is broke.
H-37365	4/10/2013	4/11/2013	4/11/2013	Lounge near back elevator garbage disposal is broken
FO-247584	4/10/2013	4/11/2013		RM 4114 HAS A CLNG LEAK
H-37410	4/11/2013		4/15/2013	first bathroom toilet clogged
FO-247688	4/11/2013	4/11/2013		Leak above Studio 127 (MCR) needs to be fixed to prevent damage to radio equipment.
H-37388	4/12/2013			The vent opening is broken.authenticated user: Aaron Sabal - ei9400requester ip address:
H-37411	4/14/2013		4/17/2013	Kitchen sink is blocked. water is stagnating and smells bad. Please unclog it as soon as possi
H-37447	4/15/2013		4/17/2013	Heat was recently fixed on Friday but continues to blow out cold air.
H-37534	4/21/2013		4/22/2013	Resident is requesting the engineer to turn off the radiator in apartment. The valve on radiator
H-37574	4/22/2013			Air conditioning is broken authenticated user: Delonte Gardner - ec5741requester ip addre
H-37595	4/23/2013			938 Towers Room Clight switch was "broken".Please, come in my room.....authenticate
H-37596	4/23/2013			Inspect ACauthenticated user: Kristen Thompson - er3952requester ip address: 141.217.2
FO-248817	4/24/2013	4/24/2013		Check and secure leak in water line
<b>E - Controls Engineer</b>			<b>56</b>	
FO-246487	4/1/2013	4/5/2013		refrigeration crew please calibrate ahu-1 humidifier&troubleshoot the lack of humidty to 200 su

WO	Recieved	Finished	Total	Request
FO-241939	4/1/2013			Refrigeration Crew; low
FO-246511	4/2/2013	4/8/2013		AC/Controls. Medium priority. Work due to FO-246502. Inspect and adjust alarm setting for thi
FO-246515	4/2/2013	4/23/2013		Zone 1 Engineer
FO-246516	4/2/2013	4/4/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246517	4/2/2013	4/4/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246518	4/2/2013	4/2/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246519	4/2/2013	4/2/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246520	4/2/2013	4/4/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246521	4/2/2013	4/8/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246522	4/2/2013	4/4/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246523	4/2/2013	4/8/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246524	4/2/2013	4/2/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246525	4/2/2013	4/2/2013		Room is pressurized, needs to be slightly negative, Titus boxes
FO-246585	4/2/2013	4/3/2013		Refg Crew:
FO-246609	4/2/2013			Boiler & controls-
FO-246610	4/2/2013			Trade: Refer/Vendor Johnson Controls
FO-246612	4/2/2013			boiler & controls-
FO-246615	4/2/2013	4/3/2013		refrigeration crew/aubery waller R/R RM PH/MECH RM please repair humidifier on ahu-9,priori
FO-246807	4/2/2013	4/8/2013		REF CREW:
FO-246809	4/3/2013			Trade: Controls/Siemens Priority: Low
FO-246811	4/3/2013	4/3/2013		Refill OX/Acetylene
FO-246835	4/3/2013			REF CREW/MED
FO-246911	4/4/2013			refrig crew-
FO-246922	4/4/2013	4/9/2013		Refg. Crew:
FO-247229	4/9/2013	4/25/2013		return fan is out of order and needs to be checked asap. I tried to reset panel but unit still wont
FO-247231	4/9/2013	4/24/2013		Control Engineer; Low
FO-247510	4/10/2013			Refrig.Crew
FO-247653	4/10/2013	4/22/2013		Repair/Replace AC unit air compressor inside Pizza Hut at Student Center. Compressor shut
FO-247623	4/10/2013			REFRIG CREW-
FO-247711	4/12/2013			REFRIG CREW,
FO-247735	4/12/2013			boiler/refrig:please repair #1 boiler,lts down on low gas press. PRIORITY:reg.
FO-247759	4/12/2013	4/18/2013		Trade: Controls/Siemens Priority: Medium
FO-247870	4/15/2013	4/23/2013		Siemens/DDC/Controls...High Priority.
FO-231487	4/15/2013	4/23/2013		CONTROLS CREW,
FO-248016	4/16/2013	4/25/2013		Trade: Refrig/controls/Contractor
FO-248067	4/17/2013			R/R RMS 2918 & 4900 Please repair or replace the following stat's. Room 2918 stat will not r
FO-248076	4/17/2013			Refg. Crew/Honeywell:
FO-248139	4/18/2013			Trade: Controls/Siemens Priority: Medium
FO-248492	4/22/2013	4/29/2013		Trade: Boiler group Priority: Medium
FO-248498	4/22/2013	4/24/2013		REFER CREW:
FO-248502	4/22/2013	4/25/2013		Refrigeration
FO-248584	4/23/2013			Trade: Controls/Siemens Priority: Medium
FO-248829	4/24/2013			Trade: Controls/Boilers Priority: Medium
FO-248830	4/24/2013	4/29/2013		Refridge crew please
FO-248832	4/24/2013			Refridge crew please
FO-248928	4/25/2013			Siemens...Med Priority
FO-248964	4/26/2013			Refrig Crew

WO	Recieved	Finished	Total	Request
FO-248978	4/26/2013			Honeywell:
FO-248980	4/26/2013			Honeywell:
FO-248995	4/26/2013			Trade: Controls Priority: Low
FO-249012	4/26/2013			AC Shop:
FO-249021	4/26/2013			room 470 thermostat and humidistat have no display
FO-249028	4/26/2013	4/29/2013		humidity valve does not respond properly
FO-249029	4/26/2013	4/29/2013		steam control valve does not respond properly
FO-249160	4/28/2013			REFRIDGERATION GROUP (HIGH)
<b>E - Director</b>			<b>2</b>	
FO-246606	4/2/2013			Trade: Refer/Management Priority: High
FO-246607	4/2/2013			Trade: Refer/Management Priority: High
<b>Routine</b>			<b>14</b>	
<b>E - Afternoon Engineer</b>			<b>9</b>	
FO-246983	4/4/2013	4/5/2013		Take Filter Engineering contractor around through Computer Center,AAB, 5959 Woodward, 5
FO-246984	4/4/2013	4/5/2013		Take Filter Engineering contractor around through Cohn, Law School, Law Library, Law Classr
FO-246985	4/4/2013	4/9/2013		Grainger tool order for afternoons. 4 Ton Ram and some hand tools to help to do bearing and
FO-247380	4/9/2013	4/16/2013		belt order
FO-247614	4/11/2013	4/11/2013		reset 7123 cooler
FO-247615	4/11/2013	4/11/2013		Reset alarm 3901 Chrysler
FO-247774	4/12/2013			Clean incinerator
FO-247955	4/16/2013	4/16/2013		Take Filter Engineering to visit buildings.
FO-248560	4/23/2013			tools for bearing and sheave changes
<b>E - Area 3 Auxiliary Eng</b>			<b>4</b>	
H-37309	4/8/2013		4/9/2013	Mechanical Check for 1009
H-37313	4/8/2013		4/9/2013	Mechanical Check for 1215
H-37307	4/8/2013			heat is not working properly in room - 438 Ghafari
H-37575	4/23/2013		4/23/2013	Mechanical Check.
<b>E - Controls Engineer</b>			<b>1</b>	
FO-248533	4/23/2013			Boiler - Open Clean and Close 78 inch Boilers
<b>Grounds</b>			<b>11</b>	
<b>High</b>			<b>1</b>	
<b>G - Physical Grounds</b>			<b>1</b>	
FO-248165	4/18/2013	4/19/2013		Stock purchase"
<b>Low</b>			<b>8</b>	
<b>G - Moving/Storage</b>			<b>4</b>	
FO-248804	4/2/2013	4/29/2013		contact: Anita Knight
FO-247025	4/5/2013	4/8/2013		Please have Grounds department pick up pallets from FP&M Stockroom .
FO-248806	4/9/2013	4/29/2013		Remove refrigerator and tables
FO-247780	4/12/2013			Turned over to D. Wrench on 4/16/2013. 7-1831
<b>G - Physical Grounds</b>			<b>4</b>	
FO-248183	4/18/2013			RFP is currently under bid will have vendor 5/1/13, per Mr. Wrench.
FO-248353	4/19/2013			Pond Dedication on May 1, 2013
FO-248513	4/22/2013	4/25/2013		To purchase lawn mower gas cap from Weingartz.
FO-248848	4/24/2013	4/25/2013		Please have Grounds crew remove wooden pallets from front of the FP&M stockroom entranc
<b>Routine</b>			<b>2</b>	
<b>G - Physical Grounds</b>			<b>2</b>	
FO-247706	4/12/2013	4/25/2013	4/25/2013	Concrete contract not approved/cancelled 04/25/13 per R. Lindenmuth 7-4324

WO	Recieved	Finished	Total	Request
FO-248082	4/17/2013	4/18/2013		Inventory withdrawal for Grounds Dept.
<b>Trades</b>			<b>981</b>	
<b>Emergency</b>			<b>72</b>	
<b>T - Carpenter</b>			<b>20</b>	
FO-246845	4/3/2013	4/3/2013		RM 5315 PROFESSOR LOCKED OUT,UNABLE TO UNLOCK WITH KEY LOCK KEEPS SPI
FO-246856	4/3/2013	4/3/2013		Please secure Plumbers gang box where someone had tried to break into it. Basement mech
FO-246938	4/4/2013	4/4/2013		DOOR WILL NOT CLOSE. ROOM 410. Finished 4/5/13 LT
FO-247007	4/5/2013	4/5/2013		EAST /WEST DOORS LOCKS BROKEN OFF SECURITY ISSUE Finished 4/8/13 LT
FO-247213	4/9/2013	4/9/2013		Cut opening in drywall 72" high x 32" wide.
FO-247227	4/9/2013	4/9/2013		PROJECTION SCREEN IS HANGING FROM WALL. ROOM 329. Finished 4/10/13 LT
FO-247669	4/11/2013	4/11/2013		DOOR WON'T LOCK. FOOTBALL STADIUM AT THE TOP OF THE BLEACHERS IN THE P
FO-247738	4/12/2013	4/12/2013		KEYS TURN IN DOOR LOCK. DOOR WON'T OPEN. ROOM 22. BASEMENT. Finished 4/1
FO-247740	4/12/2013	4/12/2013		DOOR WON'T LOCK SOUNDING DOOR ALARMS SOUNDING. 4TH FLOOR - RICK NORK'
FO-247975	4/16/2013	4/16/2013		RM 3205 KEY UNABLE TO LOCK DOOR, SECURITY ISSUE FACULTY NEEDS TO LEAVE
FO-248138	4/18/2013	4/18/2013		EMERGENCY R/R ENT HANDICAP DOOR #609 05N ADJUST DOOR CLOSURE DOOR IS
FO-248285	4/19/2013	4/19/2013		STE 4900 KEY STUCK IN LOCK UNABLE TO ENTER Finished 4/19/2013LT
FO-248350	4/19/2013	4/19/2013		EMERGENCY R/R ENTRANCE DOOR #062 03W DOOR CLOSURE LEAKING HYDRAULIC
FO-248614	4/23/2013	4/23/2013		R/R FRONT ENTRANCE DEAD BOLT LOCK KEYS AREN'T WORKING INSIDE/OUTSIDE Fi
FO-248772	4/24/2013	4/24/2013		Door 023 01E lock broke/door on the far right side facing the Prentis building Finished 4/25/13
FO-248786	4/24/2013	4/24/2013		DOCK DELIVERY DOORS STUCK OPEN, SECURITY ISSUE Finished 4/25/13 LT
FO-248815	4/24/2013	4/25/2013		EMERGENCY R/R RM 0501/DLAR CANNOT UNLOCK DOOR LOCK W/ANY KEY - KEYS A
FO-248900	4/25/2013	4/25/2013		RM# 04E DOOR HINGE BROKEN Finished 4/26/13LT
FO-248982	4/26/2013	4/26/2013		EMERGENCY R/R 2ND FLR EAST HALLWAY DOUBLE DOORS AREN'T LOCKING
FO-249001	4/26/2013	4/29/2013		R/R ENTRANCE HANDICAP DOOR #096 04E INTERIOR/EXTERIOR DOOS ARE OPENNIN
<b>T - Electrician</b>			<b>27</b>	
FO-246441	4/1/2013	4/1/2013		BLOWN CIRCUIT. SUITE 416. Finished 4/2/2013LT
FO-246583	4/2/2013	4/2/2013		FIRE TROUBLE ALARM Finished 4/3/13 LT
FO-246852	4/3/2013			Office 2101 (Dr. Singh) in Mechanical Engineering. The power outlet on the right outside from
FO-246920	4/4/2013	4/4/2013		NO POWER IN WALL OUTLETS. ROOM 3326. Finished 4/5/13LT
FO-246930	4/4/2013	4/4/2013		FIRE TROUBLE ALARM. BASEMENT ROOM 16. Finished 4/5/13LT
FO-246991	4/5/2013	4/4/2013		Fire panel won't go out of alarm. Finished 4/5/13LT
FO-247280	4/9/2013	4/9/2013		FIRE TROUBLE ALARM Finished 4/10/13 LT
FO-247530	4/10/2013	4/10/2013		WALL OUTLETS ARE NOT WORKING. 4TH FLOOR HALLWAY NORTHWEST SIDE. Finish
FO-247555	4/10/2013	4/10/2013		NO POWER TO #2 BOILER Finished 4/11/13 LT
FO-247580	4/10/2013	4/10/2013		Check and replace fuses as needed. Check circuit and repair as needed. Finished 4/11/13 LT
FO-247620	4/11/2013	4/11/2013		FIRE TROUBLE ALARM. PANEL IS IN ROOM 1209. Finished 4/12/13LT
FO-247622	4/11/2013	4/11/2013		FIRE TROUBLE ALARM. Finished 4/12/13LT
FO-247893	4/15/2013	4/15/2013		This is an emergency work order to repair the short in a solenoid in the mechanical room that i
FO-247964	4/16/2013	4/16/2013		EMERGENCY R/R RM 100 TROUBLESHOOT EMERGENCY FIRE PUMP ISOLATING/TRAN
FO-247983	4/16/2013	4/16/2013		Check and replace fuses as needed. Check circuit and repair as needed. Finished 4/11/13 LT
FO-248007	4/16/2013	4/16/2013		FIRE TROUBLE ALARM Finished 4/16/13LT
FO-248146	4/18/2013	4/18/2013		STE 100 NO LIGHTS NEED BREAKER RESET Finished 4/19/2013LT
FO-248200	4/18/2013	4/18/2013		LAW SCHOOL EDC FIRE TROUBLE ALARM Finished 4/19/2013LT
FO-248267	4/19/2013	4/19/2013		EMERGENCY R/R RM 1131 FIRE PROTECTION PANELS ARE IN ALARM LOSS COMMUNI
FO-248354	4/19/2013	4/19/2013		R/R FIRE ALARM PANEL (ESS contractor not able to repair per Pub Safe) Finished 4/19/201
FO-248361	4/19/2013	4/19/2013		COVER EQUIPMENT AND STOCK IN ROOM 411 AND 413 TO PREVENT WATER DAMAG
FO-248372	4/19/2013	4/19/2013		Please disconnect / Reconnect domestic recirculation pump in penthouse . See Ron Clark for

WO	Recieved	Finished	Total	Request
FO-248473	4/22/2013	4/22/2013		EMERGENCY: R/R 3RD FLR PH/MECH RM CIRCUIT BREAKER FOR 3RD FLR CLEAN RE
FO-248514	4/22/2013	4/22/2013		RM 1107 CIRCUIT BREAKERS NOT WORKING Finished 4/23/2013LT
FO-248896	4/25/2013	4/25/2013		STE 1100 CIRCUIT BREAKER NEEDS TO BE RESET Finished 4/26/13LT
FO-248984	4/26/2013	4/26/2013		Check power and cycling issues on condensate reciever in room 33 . See Jim Hill for info Fini
FO-249167	4/29/2013	4/29/2013		EMERGENCY R/R BLDG FAP IS IN ALARM Finished 4/30/13 LT
<b>T - Pipefitter</b>			<b>7</b>	
FO-246851	4/3/2013	4/3/2013		AIR HANDLER #1 HUMIDIFIER HAS A LEAKY UNION. ROOM 100. SEE ENGINEER.....
FO-248326	4/19/2013	4/19/2013		steam coil leak ,,,,,,,,,,ME/4-19-13 ,,,,,,,,,,DUE 4-20-13 Finished 4/19/2013LT
FO-248327	4/19/2013	4/19/2013		leak in drip leg of steam piping,,,,,,,,,ME/4-19-13 ,,,,,,,,,,DUE 4-20-13 Finished 4/19/2013
FO-248505	4/22/2013	4/22/2013		BOILER RM DOMESTIC HOTWATER TANK HAS A HOLE, NO HOT WATER IN BLDG PLEA
FO-248529	4/22/2013	4/22/2013		EMERGENCY R/R PENTHOUSE REPAIR COIL LEAK ON AHU #1,,,,,,,,,JH/RC 4-22-13 ,,
FO-248583	4/23/2013	4/23/2013		PIPEFIITER:
FO-249031	4/26/2013	4/26/2013		PIPEFITTER:
<b>T - Plumber</b>			<b>17</b>	
FO-246461	4/1/2013	4/1/2013		Entire room found flooded. No sign of a visible leak,,,,,,,,,MM/4-1-13,,,,,,,,,DUE 4-2-13
FO-246828	4/3/2013	4/3/2013		EMERGENCY R/R 4TH FLR ONLY WOMENS RM ALL 4 SINKS & FLR DRAIN HAVE RAW S
FO-246842	4/3/2013	4/3/2013		CHECK WATER PRESSURE FOR THE BUILDING, WHEN TOILETS FLUSHED WATER SP
FO-246849	4/3/2013	4/4/2013		NO WATER PRESSURE. 13TH FLOOR,,,,,,,,,MP/DB 4-3-13 ,,,,,,,,,,DUE 4-4-13 Finished
FO-246962	4/4/2013	4/4/2013		R/R temporary sump pump for boiler room trench ,,,,,,,,,, MP/DB 4-4-13 ,,,,,,,,,,DUE 4-5-13
FO-247564	4/10/2013	4/10/2013		CEILING LEAK (WATER) 2ND FLOOR HALLWAY NEAR ROOM 207. Finished 4-10-13 JWT
FO-247634	4/11/2013	4/11/2013		EMERGENCY R/R RM 440/MENS RM 1ST & 2ND STALLS TOILETS ARE PLUGGED & OV
FO-247663	4/11/2013	4/11/2013		RM 416 WATER LEAKING FROM SPRINKLER SYSTEM / Finished 4-11-13 JWT / Being con
FO-247720	4/12/2013	4/11/2013		Hook up domestic hot water tanks and turn water on to press box ,,,,,,,,,,RJC/4-11-13 ,,,,,,,,,,
FO-247932	4/15/2013	4/15/2013		EMERGENCY R/R 4TH FLR ONLY MENS RR/ONLY TOILET IS PLUGGED & OVERFLOWIN
FO-248057	4/17/2013	4/17/2013		R/R 7TH FL WOMENS RESTROOM WEST END NEAR RM 7802 WHEN TOILETS ARE FLU
FO-248087	4/17/2013	4/17/2013		EMERGENCY R/R RM 398/MEND RR - 3RD SINK WTR FAUCET WILL NOT SHUT OFF RU
FO-248128	4/18/2013	4/17/2013		Please service temporary boiler room floor pumps ,,,,,,,,,, MP/DB 4-17-13 ,,,,,,,,,,DUE 4-18
FO-248566	4/18/2013	4/18/2013		Flooding on west side of building / area drain suspect ,,,,,,,,,,MP/DB 4-18-13,,,,,,,,,DUE 4-
FO-248197	4/18/2013	4/19/2013		2ND FL WATER FOUNTAIN NEEDS TO BE TURNED OFF, DRAIN ON FOUNTAIN IS PLUG
FO-248501	4/22/2013	4/22/2013		BOILER RM DOMESTIC HOTWATER TANK HAS A HOLE, NO HOT WATER IN BLDG PLEA
FO-248551	4/22/2013	4/22/2013		Get irrigation water shut down to baseball feild ,,,,,,,,,,RJC/4-22-13 ,,,,,,,,,,DUE 4-23-13 Fi
<b>T - Sheetmetal</b>			<b>1</b>	
FO-248160	4/18/2013			R/R BLRG There is a window pane in the skylight of the
<b>High</b>			<b>183</b>	
<b>T - Carpenter</b>			<b>46</b>	
FO-246460	4/1/2013	4/1/2013		R&R Door in Mario Sanchez's office Finished 4/2/2013LT
FO-246506	4/1/2013	4/2/2013		RM 122 DOOR UNABLE TO UNLOCK WITH KEY Finished 4/3/13 LT
FO-246603	4/2/2013	4/3/2013		Main Lobby outside rm. 130, reinstate brass brackets to light fixture Finished 4/4/13LT
FO-246830	4/3/2013	4/4/2013		Carpenters,
FO-247014	4/5/2013	4/5/2013		CARPENTER TO SECURE ALL THE EXTERIOR DOORS MUSIC ANNEX Finished 4/8/13 LT
FO-247028	4/5/2013	4/8/2013		RM 301 COLLAPSIBLE WALL BROKEN PLEASE CALL PHIL FOR FURTHER DETAILS 7-10
FO-247058	4/5/2013	4/5/2013		EMERGENCY CALL-IN - A door leading to the suite of offices in the Provost's office, which no
FO-247148	4/8/2013	4/9/2013		DOOR HARD TO OPEN. ROOM 4164. Finished 4/10/13 LT
FO-247156	4/8/2013	4/10/2013		Please cut piece of wood / 1ea : 3/4" x 16" x 87" for Jim in the Pipe Shop Finished 4/12/13LT
FO-247183	4/8/2013	4/9/2013		Door 203-03N intermittently won't latch. Finished 4/10/13 LT
FO-247196	4/8/2013	4/17/2013		Insulate gap / crack between basement mechanical room wall and ceiling in room 022. Sound
FO-247204	4/8/2013	4/9/2013		STAIRWELL A DOOR A HANDLES OFF. PLEASE SEE CAROL FOR HANDLES Finished 4/1
FO-247216	4/9/2013	4/9/2013		Door 155-05E closer broken. parts on engineers desk in penthouse. Finished 4/10/13 LT

WO	Recieved	Finished	Total	Request
FO-247242	4/9/2013	4/10/2013		3RD FLOOR SOUTH STAIRWELL DOOR IS MISSING THE PUSH BAR AND PARTS ARE H
FO-247267	4/9/2013	4/23/2013		Remove small square ceiling tiles and cinder block on the wall for access for Plumbers 5th flo
FO-247554	4/10/2013	4/11/2013		R/R BSMT W. STRWL (Old Wing) INSIDE DOUBLE DOORS PUSH BAR OFF BROKEN/LAT
FO-247599	4/10/2013	4/11/2013		R&R Core for door next to ELEVATOR. (SOUTH OF ELEVATOR). EXISTING CORE IS 12RG
FO-247603	4/10/2013			Remove ceiling in first floor womens room . See Mike Pummill for location
FO-247631	4/11/2013	4/17/2013		R/R RM 231/JANITOR'S CLOSET INSIDE DOOR KNOB CAME OFF WILL NOT STAY ON FI
FO-247737	4/12/2013	4/15/2013		OUTSIDE AND INSIDE HANDICAP DOOR BUTTON IS NOT WORKING. NORTH SIDE (NE
FO-247742	4/12/2013	4/19/2013		R/R 1ST FLR LOBBY N.W. HALLWAY DOOR LEADING INTO OLD CASHIERS' OFC CORRI
FO-247789	4/13/2013	4/18/2013		Remove section of ceiling in garage for Plumbers to access . See Mike McAlinden for location
FO-247793	4/15/2013	4/15/2013		Investigate and correct cause of door 090 02W not consistantly latching securely. Finished 4/1
FO-247912	4/15/2013	4/23/2013		HOLES IN CEMENT - ENTRANCE TO DOORS 3-WEST AND 1-WEST. Finished 4/24/13LT
FO-247920	4/15/2013	4/18/2013		Remove broken key tip from office door in lower level of Student Centr. Office is located next t
FO-247948	4/15/2013	4/16/2013		R/R 1ST FLR NORTH DOOR CORRIDOR DOOR LEADING INTO STE OF OFCS' (Card Rea
FO-247956	4/16/2013	4/17/2013		RM 1131 DOOR LATCH BROKEN DEANS OFFICE, SECURITY ISSUE Finished 4/19/2013LT
FO-248010	4/16/2013	4/17/2013		carpenters/locksmith please remove broken key in lock rm.-1326 janitor closet. priority high Fi
FO-248092	4/17/2013	4/18/2013		2ND FL MENS RM 2438 DOOR OFF HINGES Finished 4/19/2013LT
FO-248100	4/17/2013	4/17/2013		RUSH PRESIDENT"S OFFICE.
FO-248194	4/18/2013	4/18/2013		Room AT-306 - Repair main door entry lockset Resident
FO-248263	4/19/2013	4/19/2013		Investigate and correct cause of front, NW, inner door not properly closing. Finished 4/19/201
FO-248311	4/19/2013	4/22/2013		RM 3110 DATA CLOSET WONT LOCK Finished 4/23/2013LT
FO-248333	4/19/2013	4/22/2013		DOOR # 096-04E HANDICAP DOOR NOT OPENING PROPERLY Finished 4/23/2013LT
FO-248351	4/19/2013	4/22/2013		R/R ENTRANCE DOOR #090 02W DOOR IS SCRAPING @ TOP CAUSING DOOR NOT TO
FO-248474	4/19/2013			***HIGH PRIORITY***
FO-248478	4/22/2013	4/22/2013		CARPENTERS R/R PLACE REPLACE INSIDE STRWL BROKEN DOOR HANDLE GRD. FL.
FO-248482	4/22/2013	4/22/2013		CARPENTERS REPLACE 4 CEILING TILES IN PRESSBOX Finished 4/23/2013LT
FO-248484	4/22/2013	4/22/2013		R/R RM 278 INSIDE DOOR KNOB IS VERY LOOSE Finished 4/23/2013LT
FO-248522	4/22/2013	4/23/2013		Remove ceiling tile and cross bracing on 3rd floor office wing at end of south east corridor . Se
FO-248574	4/23/2013	4/23/2013		RM 324.1 LOOSE HANDLE ON DOOR Finished 4/24/13LT
FO-248611	4/23/2013	4/24/2013		RM 9227 LATCH STUCK IN, CORE STUCK HALF WAY Finished 4/25/13 LT
FO-248638	4/23/2013	4/24/2013		Please provide access in wall on 4th floor next to janitors closet for Plumbers . See Mike Pum
FO-248649	4/23/2013			Please provide another ceiling access panel in garage ceiling . See Mike McAlinden for locatio
FO-248801	4/24/2013			Remove upper cabinets in Japeneese kitchen **ASAP Please. See Mike Pummill for locatio
FO-248959	4/25/2013			R/R GENERATOR/ELECTRICAL AREA The Door on the Generator handle fell off , please re
<b>T - Electrician</b>			<b>46</b>	
FO-246468	4/1/2013	4/1/2013		Repair Fixture above Mechanics work bench, mechanics area very dark. Finished 4/2/2013LT
FO-246490	4/1/2013	4/1/2013		power outage in Karen Krisher's office #404. Could be a blown fuse. Finished 4/2/2013LT
FO-246878	4/3/2013	4/4/2013		Please R&R exit sign at south side entrance door from courtyard leading to the building engin
FO-246887	4/3/2013			Disconnect condasate pump #2 in basement . See Ron Clark for location
FO-246916	4/4/2013	4/4/2013		Manoogian Hall.
FO-246925	4/4/2013	4/4/2013		Circuit making frying noise, and lights went out, check Breakers. Finished 4/5/13LT
FO-247132	4/8/2013	4/9/2013		The sensor for the lights in room 5141 are very sensitive. The lights turn off every 5-10 minute
FO-247129	4/8/2013	4/9/2013		please deliver pallet of parts for Scott Hall Johnson Controls project Finished 4/10/13 LT
FO-247144	4/8/2013	4/8/2013		URGENT: Room 3530 has a UV light in the fume hood that needs to be replaced ASAP. Imp
FO-247170	4/8/2013			Install Data Monitor on the A main, in sub 49.
FO-247222	4/9/2013			took fan down for belt change and fan won't come back on. Disconnect won't close in.
FO-247271	4/9/2013	4/9/2013		First floor womens restroom, light switch is broken, light stays on. Finished 4/11/13 LT
FO-247283	4/9/2013	4/9/2013		DOOR # 080-15N 080-16N , DOOR ALARMS BEEPING Finished 4/10/13 LT



WO	Recieved	Finished	Total	Request
FO-247396	4/10/2013	4/11/2013		R/R Bottle filler 4th floor . See John in Pipe Shop first Finished 4/12/13LT
FO-247536	4/10/2013	4/11/2013		Problem Solved - No EP
FO-247596	4/10/2013	4/11/2013		RE-COVER ELECTRICAL WIRES WHERE LIGHT POLE IS MISSING. SOUTH OF STATE H
FO-247685	4/11/2013	4/12/2013		R/R RM 226.3 HAS NO POWER IN WALL OUTLETS Finished 4/12/13LT
FO-247718	4/12/2013	4/12/2013		Remove light fixture 2ed floor mechanical room . See Corey for location. ** Needs to be down
FO-247792	4/13/2013	4/17/2013		Remove non-asbestos insulation on cooling tower make up storage tank located in basement
FO-247879	4/15/2013	4/15/2013		R/R RM 105 NEED BREAKER RESET FOR NORTH WALL - WALL OUTLETS LOST POWE
FO-247914	4/15/2013	4/16/2013		Repair power to exhaust fan inside Met Grill located on 1st floor of Student Center. This is an
FO-247905	4/15/2013	4/15/2013		FIRE TROUBLE ALARM. BASEMENT. Finished 4/16/13LT
FO-247929	4/15/2013	4/18/2013		R/R 1ST FLR NEAR EMERGENCY EXIT (ONLY EMER/EXIT DOOR) LITE PANEL IS MAKIN
FO-247963	4/16/2013			R/R SUB BSMT the fire panel willn't reset ,due to a bad smoke dector, the panel in the chiller
FO-247984	4/16/2013			Maintenance Laborer
FO-247962	4/16/2013			4 fixture in room
FO-248026	4/16/2013	4/17/2013		electrican
FO-248043	4/17/2013	4/17/2013		R/R FAP FIRE TROUBLE ALARM SNDNG Finished 4/18/2013
FO-248148	4/18/2013	4/18/2013		SOUTH STAIRWELL 4TH FL EMERGENCY LIGHT ON Finished 4/19/2013LT
FO-248161	4/18/2013			R/R RM 4108 2 fixtures relamped
FO-248271	4/19/2013	4/19/2013		No Power in Pipe Shop office Finished 4/19/2013LT
FO-248349	4/19/2013	4/19/2013		R/R RM 1147 BOTH WALL OUTLETS LOST POWER NEED BREAKER RESET Finished 4/1
FO-248485	4/22/2013	4/22/2013		Replace LED fixture at Ferry Door. Finished 4/23/2013LT
FO-248561	4/23/2013	4/22/2013		Assist Healy Fire Technicians with testing of fire system. Finished 4/23/2013LT
FO-248571	4/23/2013	4/23/2013		ELECTRICAL DEPT/LABORER-PLEASE
FO-248760	4/24/2013	4/24/2013		R/R RM 2255 ELECTRICAL CONDUIT IN CLNG IS LKNG AN OILY SUBSTANCE ABOVE P
FO-248779	4/24/2013			Electricians:
FO-248942	4/25/2013	4/25/2013		R/R RM 010/SB47 TROUBLESHOOT DEDICATED ELEC/LINE SUPPLYING ELECTRICAL P
FO-249158	4/27/2013			Electrician:
FO-249161	4/28/2013			R/R RM 0114/MECH RM Please repair or replace smoke detector in room 0114. Alarm panel
FO-249154	4/29/2013	4/29/2013		Repair the Manoogian fire panel trouble alarm Finished 4/30/13 LT
FO-249155	4/29/2013			repair the Security gate across the
FO-249166	4/29/2013	4/29/2013		Electricians:
FO-249185	4/29/2013	4/29/2013		R/R RM 1147 NEED BREAKER RESET Finished 4/30/13 LT
FO-249200	4/29/2013			Having new furniture installed in room and need hard wired electrical service on existing furnit
FO-249201	4/29/2013	4/29/2013		R/R 4TH HALWWAY BTWN RMS461 & 462 LIGHT BALLAST STARTED SMOKING/SPARKI
<b>T - Locksmith</b>			<b>10</b>	
FO-246601	4/2/2013	4/12/2013		74228 DEROY APT. ROOM 714 2-CORES 4-KEYS Finished 4/15/13LT
FO-246974	4/4/2013	4/12/2013		73721 2-keys Finished 4/15/13LT
FO-247651	4/11/2013	4/11/2013		#74239 1 Key Room 505 Finished 4/12/13LT
FO-247676	4/11/2013	4/12/2013		74234 Request #74234 10-keys for New Hire Terry Dunn Finished 4/15/13LT
FO-247965	4/16/2013	4/16/2013		Cut 2 keys for the controller at Student center Finished 4/16/13LT
FO-248102	4/17/2013	4/18/2013		REQ # 74156 1 CORE & 9 KEYS ROOM # 165 Finished 4/19/2013LT
FO-248153	4/18/2013	4/19/2013		#74243 2 Keys Finished 4/19/2013LT
FO-248282	4/19/2013			#74244 25 Keys and 4 Cores Rooms 5107,5107.1,5107.2,5151
FO-248800	4/24/2013	4/25/2013		#72507 3Keys Finished 4/26/13LT
FO-248892	4/25/2013	4/25/2013		74345 1-KEY Finished 4/26/13LT
<b>T - Pipefitter</b>			<b>24</b>	
FO-246508	4/1/2013			Control Valve Gaskets / Shop Stock ,,,,,,,,,,CB/4-1-13,,,,,,,,,,,,,DUE 4-3-13
FO-246633	4/2/2013	4/3/2013		Build Pipe brackets for rack near 3rd floor storage cage ,,,,,,,,,,JH/RC 4-2-13 ,,,,,,,,,,DUE 4-4-1
FO-246915	4/4/2013			Need the pump piping removed to facilitate chiller rebuild by the Trane CO. Please see Trane

WO	Recieved	Finished	Total	Request
FO-246973	4/4/2013	4/9/2013		Transfer oxy / sed bottles from shop to storage area ,,,,,,,,,,EA/4-4-13 ,,,,,,,,,,DUE 4-6-13 Fi
FO-246987	4/5/2013	4/5/2013		Preheat coil inside #5 ahu leaking bad. Causing ceiling leaks in room 411.
FO-247032	4/5/2013	4/9/2013		CEILING LEAKS. 4TH FLOOR ROOMS 469 AND 471,,,,,,,,,JH/RC 4-5-13 ,,,,,,,,,,DUE 4-8
FO-247118	4/8/2013	4/8/2013		Repair leaking steam trap near
FO-247190	4/8/2013	4/10/2013		This situtation is for every sink in the locker rooms and the bathrooms. There is only scalding
FO-247192	4/8/2013	4/8/2013		Assist Dennis in moving steel plate from Life Sci. to University Towers loading dock ,,,,,,,,,,
FO-247514	4/9/2013	4/16/2013		R/R leaking union room 341,,,,,,,,,ME/4-10-13 ,,,,,,,,,,DUE 4-11-13 Finished 4/19/2013LT
FO-247347	4/9/2013	4/10/2013		fitters- Bell & gossett heating pump# 2 needs seal replaced badly, also heating pump#1 is star
FO-247395	4/10/2013	4/9/2013		Pipe fitters: please repair hot water heat pipe leak in room 105.1. ,,,,,,,,,,CB/4-9-13 ,,,,,,,,,,D
FO-247588	4/10/2013			CEILING LEAK (WATER) 2ND FLOOR HALLWAY NEAR ROOM 207. ,,,,,,,,,,CB/4-10-13 ,,
FO-247731	4/12/2013	4/13/2013		R/R 2 steam coils air handler #1 ,,,,,,,,,,CB/4-12-13 ,,,,,,,,,,DUE 4-15-13 Finished 4/15/13L
FO-247784	4/12/2013	4/12/2013		Evaluate 24" chill water butterfly valve acuators ,,,,,,,,,,CB/ME 4-12-13 ,,,,,,,,,,DUE 4-14-1
FO-248133	4/17/2013	4/17/2013		R/R condensate line for wing coil in basement mechanical room ,,,,,,,,,,JH/RC 4-16-13 ,,,,,,,,,,
FO-248476	4/22/2013	4/23/2013		Fitters-
FO-248550	4/22/2013	4/22/2013		Repair leaking HHW pumps in crib area ,,,,,,,,,,ME/4-22-13 ,,,,,,,,,,DUE 4-24-13 Finished 4/
FO-248775	4/24/2013	4/25/2013		FITTERS (HIGH)
FO-248890	4/25/2013	4/26/2013		RM 2314 STEAM PIPE BEHIND DISHWASHER IS LEAKING ,,,,,,,,,,ME/4-25-13,,,,,,,,,,DU
FO-248916	4/25/2013	4/25/2013		R/R chill water ball valve in basement ,,,,,,,,,,CB/4-25-13 ,,,,,,,,,,DUE 4-27-13 Finished 4/29
FO-248968	4/26/2013			plumbers please replace busted "2" in ball valve, on cooling tower fill line. priority HIGH !,,,,,,,,,,
FO-249218	4/29/2013			Fitters,
FO-249221	4/29/2013			Fitters,
<b>T - Plumber</b>			<b>50</b>	
FO-246475	4/1/2013	4/1/2013		R/R garbage disposal 1st floor kitchen ,,,,,,,,,,DJP/4-1-13 ,,,,,,,,,,DUE 4-3-13 Finished 4/2/2
FO-246602	4/2/2013			R/R 4th floor ladies restroom ADA stall HAS NO WATER IN IT ALSO NOT FLUSHING, PLUG
FO-246814	4/3/2013	4/5/2013		CEILING LEAKS. 4TH FLOOR ROOMS 469 AND 471,,,,,,,,,MM/4-3-13 ,,,,,,,,,,DUE 4-5-1
FO-246879	4/3/2013	4/3/2013		Purdy Library 4th Floor Women's Restroom (the only Women's Restroom on the 4th Floor),,,,,,
FO-246918	4/4/2013	4/8/2013		CEILING PIPE LEAK OVER CABINETS. COORIDOR 103. SEE LEE FOR DETAILS.,,,,,,,,,,
FO-247140	4/8/2013	4/8/2013		RM 6100.2 UNISEX RESTROOM TOILET OVERFLOWING ,,,,,,,,,,MP/DB 4-8-13 ,,,,,,,,,,D
FO-247146	4/8/2013	4/8/2013		HANDICAP RESTROOM (OLD) 1ST FL TOILET CLOGGED ,,,,,,,,,,MP/DB 4-8-13 ,,,,,,,,,,
FO-247163	4/8/2013	4/10/2013		3RD FL MENS RM SENSORS NOT WORKING 1ST 3 STALLS TOILET NOT FLUSHING.,,,,,,,
FO-247178	4/8/2013	4/9/2013		1st floor-Women's restroom-sink plugged up; water on floor.,,,,,,,,,,RJC/4-9-13 ,,,,,,,,,,DU
FO-247189	4/8/2013	4/9/2013		This situtation is for every sink in the locker rooms and the bathrooms. There is only scalding
FO-247246	4/9/2013	4/10/2013		Plugged toilet in men's bathroom in hallway by the custodian's closet in hallway that runs from
FO-247261	4/9/2013	4/11/2013		RM 2005 PIPE DRIPPING NEAR MAIN ENTRANCE ,,,,,,,,,,RJC/4-10-13 ,,,,,,,,,,DUE 4-11
FO-247279	4/9/2013	4/9/2013		Drain cap loose in mens room near back door of Shiffman . See Johnny May Ph.# 577-4118 f
FO-247282	4/9/2013	4/12/2013		1ST FL UNISEX RESTROOM TOILET NOT FLUSHING, ALSO WATER CONTINUOUSLY R
FO-247587	4/10/2013			CEILING LEAK (WATER) 2ND FLOOR HALLWAY NEAR ROOM 207. ,,,,,,,,,,CB/4-10-13 ,,
FO-247586	4/10/2013	4/11/2013		R/R RM 1378/WOMENS RM BOTH TOILET STALLS HAVE SIGNS NOT WORKING ,,,,,,,,,,
FO-247590	4/10/2013	4/11/2013		EMERGENCY R/R RM 176.1 INSIDE WOMENS LOCKER RM WOMENS RM ONLY SINK H
FO-247648	4/11/2013	4/18/2013		Plumbers, repair sill cock north side of bldg. west end. Must be repaired befor Mat 1, 2013 Pri
FO-247690	4/11/2013	4/13/2013		CEILING LEAK. ROOM 3141.2 (INSIDE ROOM 3141) ,,,,,,,,,,RJC/4-12-13 ,,,,,,,,,,DUE 4
FO-247729	4/12/2013			leak in ceiling. Someone was out earlier this week because there was a stain on the ceiling.
FO-247769	4/12/2013	4/15/2013		Sink is plugged. Thank you.,,,,,,,,,,MP/DB 4-15-13 ,,,,,,,,,,DUE 4-15-13 Finished 4/16/13L
FO-247925	4/15/2013	4/16/2013		R/R RM 5111/WOMENS RR - 5TH/HANDICAP STALL TOILET IS PLUGGED & OVERFLOW
FO-247952	4/15/2013	4/18/2013		Sink in kitchen backs up when dishwasher is emptying water.,,,,,,,,,,DJP/4-15-13 ,,,,,,,,,,D
FO-248003	4/16/2013	4/16/2013		Roof drain backed up. Auditorium roof section South East. Large pond of water on roof. ,,,,,,,,,,
FO-248091	4/17/2013	4/19/2013		2ND FL MENS RM IN STACKS AREA(2238) URINAL PLUGGED ,,,,,,,,,,DJP/4-18-13 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-248093	4/17/2013	4/19/2013		3RD FL MENS RM URINAL BACKED UP STALL IS BAGGED ,,,,,,,,,,,,,, DJP/4-18-13 ,,,,,,,,,,
FO-248097	4/17/2013	4/18/2013		Toilet is reported to continue to run.,,,,,,,,,,,,,, RJC/4-18-13 ,,,,,,,,,,,,,,DUE 4-19-13 Finished 4/19/
FO-248117	4/17/2013	4/18/2013		3RD FL MENS RM PLUMBERS REPLACED BATTERY NOW WATTER COMES ON AND OF
FO-248127	4/17/2013	4/18/2013		unplug mens 2ed floor toilet ,,,,,,,,,,,,,,RJC/4-13-13 ,,,,,,,,,,,,,,DUE 4-19-13 Finished 4/19/2013LT
FO-248132	4/18/2013	4/17/2013		Evaluate and repair any needed plumbing issues . *** Note all repairs made on this work order
FO-248203	4/18/2013	4/22/2013		Walk through and Evaluate any needed plumbing repairs . Logg all areas and repairs on this
FO-248246	4/18/2013			Water leak behind coffee machine in cafeteria (WATER COMING FROM WATER COOLER) ,
FO-248325	4/19/2013	4/22/2013		8TH FL W.END MENS RM URINAL HAS NO WATER SOUNDS LIKE AIR COMING FROM U
FO-248370	4/19/2013	4/23/2013		6TH FL MENS RM TOILET LEAKING ,,,,,,,,,,,,,,MM/4-22-13 ,,,,,,,,,,,,,,DUE ASAP Finished 4/24/
FO-248510	4/22/2013	4/23/2013		1ST FL MENS RM TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,,,,,,RJC/4-23-13 ,,,,,,,,,,,,,,DUE 4-
FO-248546	4/22/2013	4/24/2013		Room 0301 - Men's Showers - Shower heads at each end are not working - Please fix.,,,,,,,,,,,,,,
FO-248612	4/23/2013	4/29/2013		Both sinks plugged up 3rd floor mens (sinks are bagged) room-no room number- next to janitor
FO-248648	4/23/2013	4/24/2013		Install eyewash station in room 226 . See Bob Akins for location ,,,,,,,,,,,,,,MM/4-24-13 Finished
FO-248757	4/24/2013	4/24/2013		R/R RM 5111/WOMENS RR - 3RD STALL TOILET SPRAYS EVERYWHERE WHEN FLUSH
FO-248759	4/24/2013	4/24/2013		R/R 4TH FLR WOMENS RM ACROSS FROM RM 4114 3RD STALL HAS LOW WATER PRE
FO-248767	4/24/2013			RM 530 WATER POURING THROUGH CEILING LIGHT ,,,,,,,,,,,,,,MP/DB 4-24-13,,,,,,,,,,,,, DUE
FO-248769	4/24/2013	4/25/2013		5TH FL WOMENS RM LEAK FROM WALL WHEN TOILET IS FLUSHED ,,,,,,,,,,,,,,MM/4-24-13
FO-248776	4/24/2013	4/26/2013		RM 5540 PIPE UNDER SINK IS LEAKING ,,,,,,,,,,,,,,MM/4-24-13 ,,,,,,,,,,,,,,DUE 4-26-13 Finished
FO-248777	4/24/2013	4/25/2013		RM 5453 FAUCET LEAKING,,,,,,,,,,,,,MM/4-24-13 ,,,,,,,,,,,,,,DUE 4-26-13 Finished 4/29/2013 L
FO-248784	4/24/2013	4/25/2013		1ST FL KITCHEN SINK DRAINING SLOWLY ,,,,,,,,,,,,,,RJC/4-24-13 ,,,,,,,,,,,,,,DUE 4-26-13 Fini
FO-248793	4/24/2013			Drain pipe in room 280 is leaking and rusted. ,,,,,,,,,,,,,,DJP/4-24-13 ,,,,,,,,,,,,,,DUE 4-26-13
FO-248818	4/24/2013	4/25/2013		Plumbers, repair sill cock north side of bldg. west end. Must be repaired befor Mat 1, 2013 Pri
FO-248948	4/25/2013	4/26/2013		plumbers please replace busted "2" in ball valve, on cooling tower fill line. priority HIGH ! ,,,,,,,,,,
FO-248957	4/25/2013	4/29/2013		We are located at 5057 Woodward Avenue, Third Floor, Suite 3101. Our kitchen sink faucet (c
FO-249008	4/26/2013	4/26/2013		R/R BSMT UNISEX RR ONLY TOILET IS CON'T FLUSHING VERY HARD & FILLING UP W
<b>T - Roofing</b>			<b>6</b>	
FO-247633	4/11/2013	4/18/2013		ROOF/CEILING LEAK. ROOM 270 MEZZANINE PART.SCHREIBER ROOFING WAS OUT 4
FO-247783	4/13/2013	4/15/2013		CEILING LEAK. ROOM 3141.2 (INSIDE ROOM 3141) / This is a roof leak see Roy Caloia for
FO-248137	4/18/2013			Roofers
FO-248823	4/24/2013	4/25/2013		ROOFER
FO-248879	4/25/2013	4/25/2013		Roofers. High priority. Work due from FO-248843.
FO-248880	4/25/2013			Roofers. High priority. Work due to FO-248840.
<b>T - Sheetmetal</b>			<b>1</b>	
FO-249159	4/28/2013			Sheetmetals:
<b>Medium</b>			<b>204</b>	
<b>T - Carpenter</b>			<b>39</b>	
FO-246463	4/1/2013	4/2/2013		RM 219 WINDOW HARD TO LIFT AND LET DOWN Finished 4/3/13 LT
FO-246604	4/2/2013	4/3/2013		R/R ENT DOOR #499 01N IS SCRAPING THRESHOLD PERIODICALLY CAUSING DOOR N
FO-246619	4/2/2013	4/23/2013		First floor in Purdy the lens keep falling from the ceiling, the panels are not wide enough, and
FO-246831	4/3/2013	4/4/2013		2nd FL Locker 280, door is jammed and wont open. Finished 4/5/13 LT
FO-246857	4/3/2013	4/4/2013		CARPENTERS,
FO-246906	4/4/2013	4/5/2013		Room A, ( which I believe to be room 120) inside of door handle damaged and loose.Screws
FO-246928	4/4/2013	4/5/2013		Room 1226 - Please adjust door closer - Door is not closing and latching properly. Finished 4/
FO-247004	4/5/2013	4/8/2013		R/R RM 305/MECH-BLR RM lock smith please replace key core on cabinets medium priority
FO-247005	4/5/2013	4/8/2013		CARPENTERS: Please replace multipule damaged ceiling tiles do to DLAR water leak in roo
FO-247033	4/5/2013	4/24/2013		Install counter top in Mario's office . See John for location
FO-247061	4/5/2013	4/8/2013		Kick stop to Custodial Stockroom needs replacing. Screws are stripped. Finished 4/9/2013 LT
FO-247230	4/9/2013	4/24/2013		Carpenter; Medium

WO	Recieved	Finished	Total	Request
FO-247233	4/9/2013	4/10/2013		WINDOW BLINDS ARE HANGING FROM WALL. ROOM 329. Finished 4/12/13LT
FO-247284	4/9/2013	4/11/2013		DOOR # 189-08E DOOR NOT CLOSING PROPERLY NEEDS ADJUSTING Finished 4/12/13
FO-247350	4/9/2013	4/10/2013		Office door casing is coming undone, needs to be fixed. Finished 4/12/13LT
FO-247522	4/10/2013	4/11/2013		Carpenters, door lock on room H will not lock see Lydia. priority medium Finished 4/12/13LT
FO-247523	4/10/2013	4/11/2013		Carpenters, repair door lock room I door will not stay locked. see Lydia. priority medium Finish
FO-247524	4/10/2013	4/11/2013		carpenter, repair door lock Rm. I door won't stay locked. see Lydia priority medium Finished 4/
FO-247559	4/10/2013	4/15/2013		South side of the carriage house east/west downspouts face south. Need to change the elbow
FO-247609	4/10/2013	4/17/2013		Mount 2 grease boards in Pipe Shop .See John for Location Finished 4/19/2013LT
FO-247739	4/12/2013	4/15/2013		3RD FLOOR UNISEX RESTROOM ENTRANCE DOOR WON'T UNLOCK. Finished 4/16/13L
FO-247946	4/15/2013	4/16/2013		FRONT ENTRANCE DOOR OFF HINGES CONTACT LEONARD FOR QUESTIONS 313-872
FO-247993	4/16/2013			Please have carpenters seal the wall and edge
FO-248027	4/16/2013	4/22/2013		RM 3121 WINDOW NEEDS TO BE CAULKED LEAKS WHEN RAINING Finished 4/23/2013L
FO-248111	4/17/2013	4/23/2013		Plastic handle at bottom of window (to open or close window) is broke. It will need to be replac
FO-248114	4/17/2013	4/19/2013		RM 14109 MISSING CEILING TILE IN VESTIBULE AREA Finished 4/19/2013LT
FO-248158	4/18/2013	4/19/2013		Please repair carpet. It is coming up between the hallway and the door of office 3330. Finishe
FO-248239	4/18/2013	4/19/2013		Broken upper hinge on the new door leading from the Studio theatre lobby to the restroom are
FO-248379	4/19/2013	4/22/2013		Carpentry:
FO-248530	4/22/2013	4/23/2013		R/R 1ST FLR @ ELEVATORS TO YOUR LEFT LAMINATED WALL NEEDS TO RE-GLUED
FO-248553	4/22/2013	4/25/2013		Men's shower (226 on floor plan) needs grout added to entire corner. Original grout fell out. S
FO-248565	4/23/2013			Please support ceiling 1st floor near elevator . See Eric Adams for location .
FO-248606	4/23/2013	4/24/2013		Carpenters: please repair east entrance door # 023 01 E, it sticks to door jamb and hard to op
FO-248787	4/24/2013			Please repair the screen so that the window can be open without letting in bugs.
FO-248785	4/24/2013			RM 1339 LEAK AROUND WINDOW SEAL NEEDS TO BE SEALED
FO-248835	4/24/2013	4/25/2013		2ND FL STAIRWELL J DOOR HANDLE STICKING Finished 4/26/13LT
FO-248837	4/24/2013	4/25/2013		R/R RM 4109 KEYS ARE STICKING IN DOOR LOCK Finished 4/26/13LT
FO-248889	4/25/2013	4/26/2013		Door hold open device is loose and missing a screw. Finished 4/29/13 LT
FO-248899	4/25/2013	4/26/2013		STAIRWELL C 2ND FL DOOR HANDLE STICKING Finished 4/29/13 LT
<b>T - Electrician</b>			<b>50</b>	
FO-246447	4/1/2013	4/5/2013		Meet Michigan Mechanical to repair whip on RAF 14, it have to be longer.
FO-246594	4/2/2013	4/8/2013		Maintenance Labor to clean electrical room 049. Dispose of bird nest, dispose of boxes, other
FO-246595	4/2/2013	4/8/2013		North Electrical Room. Maintenance Labor to clean out / vacuum room. Haul out pallets of bric
FO-246597	4/2/2013	4/5/2013		Room 49 electrical room. Install cover of electrical breaker panel. Panel cover on floor in room
FO-246898	4/4/2013	4/8/2013		Electricians
FO-246895	4/4/2013	4/4/2013		Time for Safety Meeting for month April, 2013. Finished 4/5/13LT
FO-247064	4/5/2013			Move the Good Year Belts and Sheaves received supplied by Applied Industrial Technologies
FO-247071	4/6/2013	4/17/2013		Move trailer from roof to Pipe Shop for repairs . See John Finished 4/18/2013
FO-247074	4/7/2013	4/27/2013		Relocate electrical plug/associated wiring to accomodate new water chemical controller in boil
FO-247121	4/8/2013	4/9/2013		CLOCK IS NOT WORKING. 3RD FLOOR HALLWAY - CASS SIDE. Finished 4/10/13 LT
FO-247130	4/8/2013	4/9/2013		Electrical- need ballasts replaced in fire pump room in basement.one to the left as you come i
FO-247353	4/9/2013	4/10/2013		Trade: Electrician Priority: Medium
FO-247355	4/9/2013	4/25/2013		ELECTRICIANS: Please repair light sensor in room 5141 MED. Finished 4/26/13LT
FO-247345	4/9/2013	4/10/2013		PLEASE CLEAN UP CONSTRUCTION DUST FROM WEST STAIRWAY BETWEEN FIRST
FO-247509	4/9/2013	4/10/2013		Room 205, lights are dimming. May be an electrical problem? Finished 4/11/13 LT
FO-247528	4/10/2013	4/12/2013		elect. replace duplex GFI in hot kitchen for warmer see Matt plug keeps falling out. priority me
FO-247535	4/10/2013	4/11/2013		electrical dept-please check #4boiler chemical pump motor-motor won't run- Finished 4/12/13
FO-247563	4/10/2013	4/10/2013		Electricians:
FO-247565	4/10/2013	4/22/2013		Electricians: Please check and repair/replace emergency exit signs.

WO	Recieved	Finished	Total	Request
FO-247597	4/10/2013	4/25/2013		CEILING LIGHT IS OUT AFTER CEILING LEAK LAST WEEK. ROOM 411. Finished 4/26/13
FO-247610	4/10/2013	4/17/2013		Lights out in Pipe Shop office Finished 4/18/2013
FO-247658	4/11/2013	4/13/2013		Kresge 1st Floor - Near Emergency Exit
FO-247667	4/11/2013	4/17/2013		FIRE ALARM CONTROL PANEL WILL NOT SILENCE. MECHANICAL ROOM 3.
FO-247674	4/11/2013	4/19/2013		please remove insulation on flashtank in mechanical room 100..see John Towle for exact locat
FO-247747	4/12/2013	4/15/2013		ELECTRICAL DEPT/LABORER-NEED THE FOLLOWING CHEMICALS DELIVERED-AS PE
FO-247748	4/12/2013	4/15/2013		Electrician; Medium
FO-247750	4/12/2013			The Carpenter was cutting an access for the Plumbers, and cut a circuit in the ceiling. Have E
FO-247785	4/13/2013	4/23/2013		Pick up piping debris in 2ed floor mechanical room . See Ron Clark for location
FO-247933	4/15/2013	4/17/2013		R/R RM 245 SOME COVERS ARE LOOSE AND LOOKED TO BE READY TO FALL & SOME
FO-247992	4/16/2013	4/18/2013		Hallway out side of room 2125 - North face of dual faced Simplex clock not keeping proper tim
FO-248006	4/16/2013	4/17/2013		FIRE TROUBLE ALARM
FO-248032	4/16/2013	4/18/2013		Laborer- Please remove old fan sheaves from boilerroom (They are piled by the door and mark
FO-248143	4/18/2013	4/22/2013		1ST FL MAIN ENTRANCE CLOCK NOT WORKING Finished 4/23/2013LT
FO-248332	4/19/2013	4/23/2013		Move a Good year Belt and Sheaves timing belt from Stock Room to Mechanical room in Scot
FO-248384	4/19/2013	4/22/2013		please have FP&M electricians check out the ColorTran light board which controls all the lighti
FO-248555	4/22/2013			Relocate 2 cabinets that are in the way to remove sewage ejector pump . See Mike Pummill
FO-248647	4/23/2013			Please move PVC pipe in stockroom to 3rd floor .... See John for location
FO-248652	4/24/2013	4/26/2013		Replace broken lense on outside light on north side of the building. It is the closest to Woodw
FO-248816	4/24/2013			Change out both motors on Domestic Water Booster pumps in basement mehanical room. ***
FO-248826	4/24/2013	4/25/2013		Electricians please investigate alarm in hallway outside room 18. Alarm is connected to a pan
FO-248828	4/24/2013	4/25/2013		R/R RM 260 1/2 OF WALL OUTLETS AREN'T WRKNG Finished 4/26/13LT
FO-248838	4/24/2013			Please remove miscellaneous items from Pipe Shop 3rd floor cage .
FO-248847	4/24/2013			Laborer- "low priority" - please remove and dispose of large motor by tool cabinet just inside th
FO-248917	4/25/2013	4/25/2013		Disconnect condensate reciever in basement. See Jim Hill for location Finished 4/26/13LT
FO-248925	4/25/2013	4/26/2013		Electrician Med. Priority
FO-248947	4/25/2013			LABORER TO REMOVE THE PLASTER TEAR OUT DEBRIS ASAP JAPANESE ROOM KIT
FO-248965	4/26/2013			Move coils from stock room to basement of Science hall . Eric Adams can give you a hand mo
FO-248967	4/26/2013			Move drinkinking fountains from stock room to Holden lock up . See Mike Pummill for help
FO-248996	4/26/2013			Trade: Electrician Priority: Medium
FO-249058	4/27/2013			Perform Generator Full Load test, Al Kotel has some issues he need to verify. Last test some
<b>T - Laborer</b>			<b>2</b>	
FO-248908	4/25/2013	4/26/2013		Friday 4/26 make this the first job. Go to 275 W. Milwaukee to LTK's office, and pick up lens f
FO-249176	4/29/2013			Remove debris from underground return shaft located in McGregor basement. This is the area
<b>T - Locksmith</b>			<b>2</b>	
FO-246605	4/2/2013	4/9/2013		74229 6-KEYS Finished 4/10/13 LT
FO-248355	4/19/2013	4/25/2013		#72569 7 Keys Finished 4/26/13LT
<b>T - Pipefitter</b>			<b>38</b>	
FO-246484	4/1/2013	4/2/2013		R/R condasate line in Pipe Shop,,,,,,,,,,,,,RC/4-1-13,,,,,,,,,,,,,DUE 4-15-13 Finished 4/3/13 L
FO-246824	4/3/2013	4/4/2013		FITTERS: Please repair/replace BALL VALVE on BOILER#3 lower blow down line, ground lev
FO-246825	4/3/2013	4/3/2013		FITTERS Please repair/replace sample cooler above sink in boiler room MED,,,,,,Finished 4-3
FO-246826	4/3/2013	4/4/2013		FITTERS Please repair/replace sample cooler above sink in boiler room MED,,,,,,,,,,,,,JH/RC
FO-246890	4/3/2013	4/3/2013		Electricians - medium. RE: FO-239552. Please replace the "lag" pressure switch on the air co
FO-247006	4/5/2013	4/5/2013		replace blown trap on main dirtleg/dripleg in chiller mechanical room,,,,,,,,,,,,,CB/4-5-13,,,,,,,,,,,,
FO-247009	4/5/2013	4/10/2013		fitters- please repair boiler room sulfite discharge leaking pipe on sulfite chemical line.cup und
FO-247012	4/5/2013	4/9/2013		Pipe Fitters: please replace leaking hot water reheat control valve for the unit in lobby of the d
FO-247126	4/8/2013			STEAM PIPE LEAK. BASEMENT / This is a recirculating pump leak / Lowering priority to allo
FO-247174	4/8/2013	4/9/2013		please replace boiler drain valve for domestic hot water boiler,,,,,,,,,,,,,CB/4-8-13,,,,,,,,,,,,,DUE 4-

WO	Recieved	Finished	Total	Request
FO-247548	4/10/2013			pipefitter please r/r water booster pump
FO-247572	4/10/2013			R/R RM 134/MECH RM Solenoid valve for no.2 lab Vacuum pump not energizing preventing p
FO-247592	4/10/2013	4/10/2013		Fitters, please repair leaking flange in reducing station behind exhaust fan 10 in upper PH. ,,,,,
FO-247593	4/10/2013	4/15/2013		PF Med. Priority Replace 3 drain valves on chilled and hot water suction line screens. See
FO-247629	4/11/2013	4/12/2013		Trade: Pipefitter Priority: Medium
FO-247705	4/11/2013	4/12/2013		R/R leak on heat recovery system near elevavor ,,,,,,,,,,ME/4-12-13 ,,,,,,,,,,DUE 4-26-13
FO-247725	4/12/2013	4/25/2013		FITTERS: Please repair/replace leaking hot water heat valve in room 2601 MED. ,,,,,,,,,,JH/
FO-247743	4/12/2013	4/24/2013		Trade: Pipefitter Priority: Medium
FO-247791	4/13/2013	4/19/2013		Assist Dennis ( Laborer ) in stripping non asbestos cooling tower make up tank located in mec
FO-247978	4/16/2013			Fitters, please re-configure discharge piping from boiler feed pump so that it feeds chemicals t
FO-248009	4/16/2013			Trade: Pipefitter Priority: Medium
FO-248044	4/17/2013	4/22/2013		PF Med Priority
FO-248047	4/17/2013			FITTERS: Please repair blowing steam trap in Mech. room 0130. Same trap called in the past.
FO-248054	4/17/2013			Pipe fitters: please repair or replace leaking reheat control valve for room 218. The valve is lea
FO-248056	4/17/2013	4/18/2013		Pipe fitters: please repair or replace leaking control valve on reheat coil for room 328.4, the val
FO-248063	4/17/2013	4/26/2013		Pipefitters:
FO-248083	4/17/2013			Fitters:
FO-248125	4/17/2013	4/18/2013		R/R Steam / Condensate valves for AHU#2 ,,,,,,,,,,ME/4-17-13 ,,,,,,,,,,DUE 5-1-13 Finished
FO-248558	4/22/2013	4/24/2013		RM 1372 CEILING LEAK, RM IS ALARMED PLEASE SEE LEE IN RM 1321 FOR ACCESS,,,,
FO-248796	4/24/2013			R/R chill water coil AH#4 ,,,,,,,,,,JH/RC 4-24-13 ,,,,,,,,,,DUE 5-8-13
FO-249034	4/24/2013			Remove condensate reciever in basement ,,,,,,,,,,JH/RC 4-24-13 ,,,,,,,,,,DUE 5-8-13
FO-248825	4/24/2013	4/25/2013		Fitters, please replace leaking gasket on economizer in basement mechanical room.,,,,,,,,,,
FO-248887	4/25/2013			FITTERS: Please place pressure gauges on condensate return line(2) in 4th floor pipe chase
FO-248921	4/25/2013	4/29/2013		Repair staem leak on water collum on boiler #1 ,,,,,,,,,, CB/4-25-13 ,,,,,,,,,,DUE 5-9-13 Fini
FO-248945	4/25/2013			R/R OUTSIDE FROM THE GRND LEVEL ABOVE RM 0033/LETCHAL CHAMBER CLNG PIP
FO-248986	4/26/2013	4/26/2013		Fabricate stands to remove cooling tower motors.,,,,,,,,,, ME/4-26-13 ,,,,,,,,,,DUE 5-10-13 Fi
FO-249016	4/26/2013	4/26/2013		R/R RM 2314 STM PIPE LKNG BEHIND DISHWASHER ,,,,,,,,,,Finished 4-26-13 JWT / RT
FO-249214	4/29/2013			R/R RM 2548 HAS A CLNG PIPE LEAK ABOVE WORK DESK (basket under leak).,,,,,,,,,,
<b>T - Plasterer</b>			<b>1</b>	
FO-248243	4/18/2013			Paint and plaster is falling from the ceiling near the stage, just above the the lower balcony an
<b>T - Plumber</b>			<b>60</b>	
FO-246436	4/1/2013	4/2/2013		PIPE LEAK UNDERNEATH SINK. 5TH FLOOR LADIES RESROOM 5204.,,,,,,,,,,MM/4-1-13
FO-246444	4/1/2013			Drinking Fountain does not work at south end of the third floor, opposite the south stairway.,,,,,,
FO-246443	4/1/2013	4/2/2013		LEAKY FAUCET. ROOM 0413.,,,,,,,,,, MM/4-1-13 ,,,,,,,,,,DUE 4-15-13 Finished 4/3/13 L
FO-246486	4/1/2013	4/16/2013		Room 2601: Please replace molded ceiling tile AFTER checking for leaks in pipes. Thanks! ,
FO-246504	4/1/2013	4/8/2013		Purdy 1st Floor Water Fountain Across from Stair 1
FO-246498	4/1/2013	4/4/2013		3RD FL LADIES RM SINK WATER TO COLD.,,,,,,,,,,MM/4-3-13.,,,,,,,,,,DUE 4-15-13 Finish
FO-246500	4/1/2013	4/4/2013		3RD FL NEAR ELEV CEILING LEAK STAIN ON CEILING TILE ,,,,,,,,,,MM/4-3-13 ,,,,,,,,,,D
FO-246816	4/2/2013	4/19/2013		R/R 3rd floor water cooler ,,,,,,,,,,DJP/4-3-13 ,,,,,,,,,,DUE 4-17-13 Finished 4/19/2013LT
FO-246613	4/2/2013	4/5/2013		3rd floor, Mens Restroom. Low water pressure. Water for sinks, slow flowing.
FO-246596	4/2/2013	4/4/2013		R/R RM 6344 REPAIR LEAKING DRAIN B TRAP ON ONLY SINK FROM UNDERNEATH (pai
FO-246998	4/3/2013	4/4/2013		R/R flush valve for body storage room 325 ,,,,,,,,,,MM/4-3-13 ,,,,,,,,,,DUE 4-17-13 / Finished
FO-246823	4/3/2013	4/3/2013		PM urinals throughout Building for month of April ,,,,,,,,,,MP/DB 4-3-13 ,,,,,,,,,,DUE 4-17-1
FO-246912	4/4/2013	4/16/2013		RM 1372 CEILING LEAK, RM IS ALARMED PLEASE SEE LEE IN RM 1321 FOR ACCESS,,,,
FO-246946	4/4/2013			Ray Lindenmuth was informed by Mitchell, to forward this Work Order to Plumbers on 4/3/13.
FO-246963	4/4/2013			Pump out lower level basement from water main break ,,,,,,,,,,MP/DB 4-4-13 ,,,,,,,,,,DUE 4-
FO-247022	4/5/2013	4/9/2013		1ST FL WATER FOUNTAIN NOT DRAINING ,,,,,,,,,, RJC/4-5-13 ,,,,,,,,,,DUE 4-17-13 Finish
FO-247053	4/5/2013	4/10/2013		R/R 4TH FLR WOMENS RM NEXT TO JANITOR'S CLOSET 4506 THE FIRST SINK DRAIN I

WO	Recieved	Finished	Total	Request
FO-247207	4/8/2013	4/10/2013		Clear floor drain in front of slop sink in basement ,,,,,,,,,,,,,,DJP/4-9-13 ,,,,,,,,,,,,,,DUE 4-22-13 Fi
FO-247361	4/9/2013	4/10/2013		PLUMBERS: Please repair leaking trap under sink. First sink near door. room 0111. MED.,,,,,,
FO-247368	4/9/2013	4/22/2013		PLUMBERS please fabricate a better drain line for eyewash station. It drains to the floor right
FO-247508	4/10/2013	4/11/2013		the chemistry boiler room is flooding
FO-247539	4/10/2013	4/10/2013		R/R RM 134/MECH RM Solenoid valve for no.2 lab Vacuum pump not energizing preventing p
FO-247549	4/10/2013			plumber please r/r backflow preventer on chill loop leaking
FO-247551	4/10/2013	4/11/2013		RUSTY WATER 2ND FLOOR LADIES RESTROOM.,,,,,,,,,,,,,, MP/DB 4-10-13 ,,,,,,,,,,,,,,DUE
FO-247606	4/10/2013	4/12/2013		First floor men's room sink is not draining properly.,,,,,,,,,,,,,,RJC/ 4-11-13 ,,,,,,,,,,,,,,DUE 4-
FO-247616	4/11/2013	4/17/2013		First floor woman's restroom (#1234)toilet leaks from the handle area. Considered a safety ha
FO-247628	4/11/2013	4/11/2013		Trade: Plumber Priority: Medium
FO-247630	4/11/2013			Trade: Plumber Priority: Medium
FO-247627	4/11/2013	4/12/2013		FAUCET LEAK. ROOM AF4. ,,,,,,,,,,,,,,MM/4-12-13 ,,,,,,,,,,,,,,DUE 4-26-13 Finished 4/15/13LT
FO-247677	4/11/2013	4/12/2013		1ST URINAL IS PLUGGED (NOT DRAINING). MEN'S RESTROOM. ROOM 9101. ,,,,,,,,,,,,,,
FO-247691	4/11/2013	4/24/2013		R/R RM 5125/DLAR ONLY SINK - FAUCET LKNG (DRIP/DRIP) @ SPOUT ,,,,,,,,,,,,,,MM/4-12-
FO-247753	4/12/2013	4/15/2013		URNIAL NOT FLUSHING. 3RD FLOOR MEN'S RESTRTOOM.,,,,,,,,,,,,,,MM/4-15-13 ,,,,,,,,,,,,,,
FO-247766	4/12/2013	4/18/2013		Plumbers: please unplug 3 right hand side urinals in mens room 029, they overflow when they
FO-247772	4/12/2013	4/18/2013		The urinal on the second floor in the old section of the men's room is out of order. Thank you.
FO-247788	4/13/2013	4/16/2013		Cold water supply needs to be located for bathroom in room 2324 / ** This needs to be treate
FO-247790	4/13/2013	4/16/2013		P.M. drinking fountain water filters through out building ,,,,,,,,,,,,,,RJC/4-15-13 ,,,,,,,,,,,,,,DUE 4-26-
FO-247883	4/15/2013			PLUMBERS please r/r leaking hot water line badly corroded in basement ceiling in front of wo
FO-247904	4/15/2013			plumbers-5425Woodward has no building hot water. circulation pumps & motors 4 & 5 needs t
FO-247906	4/15/2013	4/17/2013		Rmm 300 R/R faucet and leaking toilet ,,,,,,,,,,,,,,RJC/4-15-13 ,,,,,,,,,,,,,,DUE 4-29-13 Finished 4/
FO-247938	4/15/2013	4/19/2013		R/R 2ND FLR NORTH SIDE OF STACK AREA DRINK FOUNT IS DRAINING VERY SLOWL
FO-248126	4/17/2013	4/17/2013		Rehang Drinking fountain in south east corner 1st floor ,,,,,,,,,,,,,,RJC/4-17-13 ,,,,,,,,,,,,,,DUE 5-1-
FO-248157	4/18/2013	4/29/2013		Please repair faucet in staff lounge. It drips when in the off position.,,,,,,,,,,,,,, RJC/4-18-13 ,,,,,,
FO-248202	4/18/2013	4/19/2013		R/R 1ST FLR MENS RM (ONLY 1 MENS RR ON 1ST FLR) TOILET CON'T FLUSHING ,,,,,,,,,,,,,,
FO-248218	4/18/2013	4/19/2013		plumbers-please repair sloan valve in mens rest room by lab 125-only mens toilet on floor ,,,,,,
FO-248306	4/19/2013	4/23/2013		1ST FL JANITORS CLOSET SINK PLUGGED ,,,,,,,,,,,,,,RJC/4-19-13 ,,,,,,,,,,,,,,DUE 5-3-13 Fini
FO-248322	4/19/2013	4/22/2013		Men's shower (226 on floor plan) needs grout added to entire corner. Original grout fell out. S
FO-248360	4/19/2013	4/29/2013		Plumbers-please remove protruding piping & cap off. next to counter tops in rooms 322 & 422
FO-248386	4/19/2013	4/22/2013		Plumber:Ceiling leak at Mens restroom above handi cap stall from trap.
FO-248507	4/22/2013			R/R RM 0072/WOMENS RM 1ST STALL TOILET WAS RIPPED OFF NEED REPLACING.,,,,,,
FO-248557	4/22/2013			5th Floor mens room / install 2 auto flush retro fit kits ,,,,,,,,,,,,,,MP/DB 4-23-13 ,,,,,,,,,,,,,,DUE 5-6
FO-248607	4/23/2013			Plumbers:
FO-248617	4/23/2013			plumbers-please install pressure gauges on domestic water line for sprinkler system & check
FO-248632	4/23/2013	4/24/2013		RM 008/MENS RR 2ND STALL TOILET FLUSH HANDLE IS BROKEN & NEEDS REPAIR (pl
FO-248640	4/23/2013	4/24/2013		R/R 1ST FL MENS RR/UNISEX RESTROOM TOILET NOT FLUSHING, WTR TK TO TOILET
FO-248901	4/25/2013	4/29/2013		1ST FL WOMENS RM TOILET SEATS NEED TO BE TIGHTENED ,,,,,,,,,,,,,, MP/DB 4-25-13 ,,
FO-248906	4/25/2013	4/25/2013		R/R RM 356/LAB SINK ACROSS FROM FH #6 IS LKNG @ FAUCET FROM TOP STEADILY
FO-248907	4/25/2013	4/29/2013		R/R RM 356/LAB SINK FH #4 IS LKNG @ FAUCET FROM TOP ,,,,,,,,,,,,,,MP/DB 4-25-13.,,,,,,
FO-249030	4/26/2013	4/26/2013		R/R toilets in mens locker room basement ,,,,,,,,,,,,,, MM/4-26-13 ,,,,,,,,,,,,,,DUE 5-10-13 Finishe
FO-249038	4/26/2013	4/26/2013		Basement unisex rest room toilet not flushing.,,,,,,,,,,,,,,Finished 4-26-13 JWT / Refer to FO#24
FO-249249	4/29/2013	4/29/2013		Check Backflow for Chill Water make up . See Tom for location ,,,,,,,,,,,,,,DJP/4-29-13.,,,,,,,,,,,D
<b>T - Roofing</b>			<b>12</b>	
FO-247637	4/11/2013	4/17/2013		R/R RM 421 REPAIR ROOF/CLNG IS LKNG
FO-247649	4/11/2013	4/22/2013		Trade: Sheetmetal Priority: Medium
FO-247659	4/11/2013			RM 330 BAD LEAK APPEARS TO BE FROM THE ROOF CARPET VERY WET IN RM AND

WO	Recieved	Finished	Total	Request
FO-247693	4/11/2013	4/18/2013		Ceiling leaks in this room and 4050.
FO-248227	4/18/2013	4/22/2013		ROOFER
FO-248249	4/18/2013	4/23/2013		Roofers:Please repair leaks showing up at the south end of 3rd floor hallway in the "E" section
FO-248290	4/19/2013			ROOFR
FO-248291	4/19/2013			ROOFR
FO-248303	4/19/2013	4/23/2013		RM 2020 CEILING LEAKING. SCHREIBER ROOFING WAS OUT ON 4-23-13. REPAIRS WE
FO-248304	4/19/2013	4/23/2013		OUTSIDE RM 1023 CEILING LEAKING.SCHREIBER ROOFING WAS OUT ON 4-23-13. REP
FO-248336	4/19/2013			OUTSIDE RM 249 AT END OF HALL,CEILING LEAKING PANEL FALLING
FO-248827	4/24/2013			There is a roof leak when raining in our general reading
<b>Low</b>			<b>521</b>	
<b>T - Carpenter</b>			<b>87</b>	
FO-246448	4/1/2013			TEAM LEADER TIME ( APRIL 2013 )
FO-246493	4/1/2013	4/4/2013		At Zipcar location in front of loading dock, the
FO-246598	4/2/2013	4/18/2013		R/R CAMPUS/VARIOUS Reuther Mall between Anthony Wayne Drive and Gullen Mall, repair/
FO-246592	4/2/2013	4/3/2013		Please have Carpenters remove items from Storeroom wall. Also remove door. See Larry Coo
FO-246614	4/2/2013	4/4/2013		Carpenters-room-231 the room entrance door is hard to close due to the door being out of line
FO-246618	4/2/2013	4/3/2013		R/R RM 220 REPLACED WATER DAMAGED CLNG TILES Finished 4/4/13LT
FO-246843	4/3/2013	4/9/2013		#70476 20 Keys Finished 4/10/13 LT
FO-246869	4/3/2013	4/10/2013		There is a broken door handle on the fourth
FO-246870	4/3/2013	4/8/2013		There are three broken metal gate arm that
FO-246873	4/3/2013	4/10/2013		R/R ENT HANDICAP DOOR #026 01S ADJUST DOOR CLOSURE SO DOOR DOESN'T SCR
FO-246914	4/4/2013			R/R 1ST FLR WOMENS RM REPLACE SIGN FOR First floor ladies room rm. 166 the sign is
FO-246926	4/4/2013	4/13/2013		R/R Bridge between Mazurek and Margherio: piece of molding became detached from the sou
FO-246942	4/4/2013	4/8/2013		4th floor - Cove Base to the right of the door to NW stairwell is loose and coming off the wall.
FO-246970	4/4/2013	4/4/2013		CARPENTER TO ATTEND SAFETY MEETING ( APRIL 2013 ) Finished 4/5/13 LT
FO-246995	4/5/2013	4/16/2013		Carpenters
FO-247000	4/5/2013			R/R BTWN 1ST/2ND FLRS SOUTH STRWL The hand rail in the stairwell going up to the
FO-247010	4/5/2013	4/8/2013		CARPENTERS: Please repair door to Mens Room 0111 in basement. Hinge problem. LOW Fi
FO-247011	4/5/2013	4/8/2013		CARPENTERS: Please repair door to Mens Room 0111 in basement. Hinge problem. LOW Fi
FO-247063	4/5/2013	4/15/2013		Room 9217 Scott Hall Install locking hardware on door and reference key request 71873 for c
FO-247072	4/6/2013			Build shelve in Pipe Shop office . Have Steve/Jeff see John for location
FO-247173	4/8/2013			please replace ceiling tile in hallway outside room 202 before the double doors....
FO-247223	4/9/2013	4/15/2013		CARPENTERS TO RE-INSTALL ROOM # 200 SIGN Finished 4/16/13LT
FO-247385	4/9/2013	4/16/2013		Room 329 projection screen is hanging off wall by one bracket. Finished 4/16/13LT
FO-247521	4/10/2013	4/16/2013		This request is for Tim Herr to paint a cabinet. Its in Grounds at present, but will be taken to t
FO-247544	4/10/2013	4/15/2013		CARPENTERS,
FO-247585	4/10/2013	4/15/2013		Carpenters:
FO-247604	4/10/2013			Install new ceiling tiles in room 105
FO-247608	4/10/2013	4/17/2013		R/R DOOR SWEEP ON DOOR 007-13W Finished 4/19/2013LT
FO-247661	4/11/2013	4/10/2013		CARPENTERS TO CHECK & COUNT ATTIC STOCK SUB BASEMENT TIM DEROO WOUL
FO-247700	4/11/2013	4/26/2013		To cover the cost to adjust closure of mech. room 430, 412, 408. (Closure does not latch on it
FO-247708	4/12/2013	4/26/2013		CARPENTERS,
FO-247726	4/12/2013	4/22/2013		R/R 4th Floor in Office 446, SEAL Window is leaking. Window facing Woodward. Finished 4/2
FO-247732	4/12/2013	4/17/2013		Repair wire mesh in sub-basement rm 049, due to squirrel entry. Please close off opening. Fin
FO-247758	4/12/2013	4/15/2013		R/R WDET ENTRANCE DOOR TO WDET AFTER ENTERING @ ENT 507 11N POSSIBLE T
FO-247874	4/15/2013			Carpenters:
FO-247940	4/15/2013	4/22/2013		CHANGE WATER DAMAGED CEILING TILES IN ROOM 323.5 Finished 4/23/2013LT



WO	Recieved	Finished	Total	Request
FO-247951	4/15/2013	4/18/2013		R/R RM 146 Interior East doors in the TRC slam closed. Closer needs to be adjusted or repla
FO-247966	4/16/2013			Ceramic Tile loose/broken in front of #1200. Please repair or replace.
FO-247972	4/16/2013	4/17/2013		CARPENTERS,
FO-248005	4/16/2013			CARPENTERS,
FO-248037	4/16/2013			Room #237 broken tiles in flooring. Possible trip hazzard.
FO-248038	4/16/2013	4/19/2013		Room # 207 Teachers desk has broken leg. Finished 4/19/2013LT
FO-248058	4/17/2013			The fire door (north side) leading into the main stairwell from the first floor (by the office suite)
FO-248098	4/17/2013	4/18/2013		On the first floor A piece of wood molding broke off the inside window, above entrance/exit 2 d
FO-248105	4/17/2013	4/22/2013		WOMEN'S RESTROOM BASEMENT #011.1 SCREWS COMING OUT OF DOOR HINGES. P
FO-248110	4/17/2013	4/19/2013		R/R INSIDE RM 262 ADJUST DOOR CLOSURE TO Conference Room 2A, Room #262 has
FO-248136	4/17/2013	4/19/2013		R/R RM 2310/CLASS RM REPAIR BROKEN lock of the inner door between 2310 and 2316 is
FO-248299	4/18/2013	4/18/2013		Child Care Center main entry door (North
FO-248220	4/18/2013			Carpenters: please replace a missing floor tile in front of the door to class room 212. Priority: I
FO-248479	4/18/2013	4/26/2013		Need to meet with Bruce/Locksmith to make lock code changes on rooms where three/four lo
FO-248264	4/19/2013			R/R RM 138/SVC CTR PLS REPAIR ABOVE STORAGE FILE CABINET DOOR ON CUBICL
FO-248310	4/19/2013	4/22/2013		R/R 1ST FLR STAFF/UNISEX Restroom lock is not locking properly. Finished 4/23/2013LT
FO-248375	4/19/2013	4/22/2013		R/R RM 3204 Door handle has come off.
FO-248475	4/19/2013	4/23/2013		**Transferred to Carpenters for lens placement work -D.Glenn
FO-248500	4/22/2013			R/R RN 318 ONLY WINDOW IN OFC NEED TO BE SEALED AROUND WINDOW FRAME (L
FO-248518	4/22/2013			CARPENTERS,
FO-248540	4/22/2013	4/23/2013		Door closer came off double doors between Scott Hall and Mazurek. Please Repair. Finished
FO-248569	4/23/2013	4/24/2013		R/R RM 6203 MAIN ENTRY DOOR PART OF DOOR FRAME CAME OFF & ALSO STRIKER
FO-248609	4/23/2013	4/29/2013		Install Air Conditioner in window, in Electric shop, next to Stewarts seat. Finished 4/30/13 LT
FO-248636	4/23/2013	4/24/2013		R/R ENT/EXT DOOR #042 03E LOCK CYLINDER IS BINDING UP UNABLE TO LOCK DOO
FO-248768	4/24/2013	4/25/2013		Carpenters: Please replace a missing and a stained ceiling tiles in computer room 318. Priorit
FO-248859	4/25/2013	4/25/2013		Room 201 base board molding needs to be re-attached to wall. Finished 4/26/13LT
FO-248865	4/25/2013	4/25/2013		Outside room 221 the baseboard molding needs to be re-attached to wall. Finished 4/26/13LT
FO-248866	4/25/2013	4/25/2013		Outside room 205 the baseboard molding needs to be re-attached to the wall. Finished 4/26/1
FO-248873	4/25/2013	4/26/2013		the door of room 253 will not close. Finished 4/29/13 LT
FO-248878	4/25/2013	4/26/2013		2ND FLOOR UNISEX RESTROOM THE DOOR HARDWARE AT THE TOP IS BROKEN. PLE
FO-248881	4/25/2013	4/25/2013		CARPENTERS TO DRY WALL THE ACCESS HOLE PROVIDED TO LOOK FOR THE ROOF
FO-248909	4/25/2013	4/26/2013		Install replacement window AC unit, which is scheduled to arrive on 4/26/13. The AC unit for t
FO-248910	4/25/2013			Install replacement window AC unit scheduled to be delivered to WSU on 4/26/13.
FO-248911	4/25/2013			Install replacement window AC unit to be delivered to WSU on 4/26/13.
FO-248912	4/25/2013			Install replacement window AC unit to be delivered to WSU on 4/26/13.
FO-248923	4/25/2013	4/30/2013		Carpenters:
FO-248931	4/25/2013	4/29/2013		R/R RM 3225.07 RE-GLUE Carpet transition strip from hallway to office has come up. Needs
FO-248935	4/25/2013	4/26/2013		R/R 6TH FLR HALLWAY DOOR LEADING TO STE STRIKER PLATE CAME OFF AGAIN Fini
FO-248936	4/25/2013	4/26/2013		R/R 6TH FLR MENS RR/6213 NEAR STE 6203 ENTRY DOOR KNOB KEEPS TURNNING/T
FO-248940	4/25/2013	4/26/2013		repair holes in roof. REPAIRS WERE MADE BY CHRISTIAN DETROIT ROOFING.4-22-13. T
FO-248977	4/26/2013			Carpenters,
FO-248993	4/26/2013	4/26/2013		R/R Rm 2309, Repair rubber threshold in doorway that has come up and is a trip hazzard. Fini
FO-249026	4/26/2013	4/29/2013		R/R Room 0330: Door to Learning Resource Center is not closing; it catches as it closes. Fini
FO-249052	4/26/2013	4/29/2013		R/R Room 0330 Five STUDY tables are leaning and ARE WABLY NEED TO BE EVEN OUT
FO-249036	4/26/2013	4/29/2013		R/R 1ST FLR Lobby door on the south side of building has a broken closure....door will not clo
FO-249156	4/29/2013	4/29/2013		CARPENTER TO REPAIR MAIN ENTRANCE CASS AVE EXIT DEVICE HITTING ROOLER
FO-249165	4/29/2013			CARPENTER TO REPAIR THE LEGS OF INSTRUCTORS DESK ROOM # 205

WO	Recieved	Finished	Total	Request
FO-249181	4/29/2013	4/29/2013		Steve and Jeff to remove and replace moldy carpet in Lisa's office. Finished 4/30/13 LT
FO-249204	4/29/2013			Rubber tip for Custodial Stockroom door stopper
FO-249222	4/29/2013			Carpenters:
FO-249219	4/29/2013			CARPENTERS TO REPLACE WATER DAMAGED CEILING TILES ROOM #418
<b>T - Electrician</b>			<b>160</b>	
FO-246440	4/1/2013			Time for team leader for month of April, 2013.
FO-246467	4/1/2013	4/2/2013		Karmanos Cancer Center - Fire Trouble Alarm.
FO-246471	4/1/2013			The light at the bottom of the main stair has both bulbs flickering making the bottom of the sta
FO-246489	4/1/2013	4/2/2013		electrical dept/laborer please deliver as per FO-199429-boiler chemicals (6)Quest250s contain
FO-246491	4/1/2013	4/2/2013		1 fixture out
FO-249284	4/1/2013			Change existing 250V 50amp electric outlet to 250V 30amp.
FO-246564	4/2/2013	4/5/2013		Purdy 3rd Floor Room 350
FO-246571	4/2/2013	4/19/2013		Please have Electricians repair/replace light fixture , FP&M Stockroom . See Larry Cook for de
FO-246578	4/2/2013	4/22/2013		Replace/Repair blinking ceiling lamp/light fixture. 2 electrical problems. Finished 4/23/2013LT
FO-246616	4/2/2013	4/29/2013		Electrician repair/replace motor for bathroom exhaust fan on roof.
FO-246599	4/2/2013	4/2/2013		Meet Simplex at Old Main to repair clock in tower. Finished 4/3/13 LT
FO-246628	4/2/2013	4/8/2013		2 fixtures out
FO-246631	4/2/2013	4/12/2013		Build scaffold in room 1545, and it has to done first thing in the morning, due to classes. Finis
FO-246810	4/3/2013			Please check all EBU's in building. Repair if needed.
FO-246812	4/3/2013	4/4/2013		Please R&R 12 eps in room 100. Finished 4/5/13LT
FO-246813	4/3/2013	4/3/2013		Please check West side clock out of sync. Finished 4/4/13LT
FO-246815	4/3/2013	4/3/2013		Please change Tower lights to blue for Autism Awareness month. Finished 4/4/13LT
FO-246841	4/3/2013			Please R&R tagged fixtures in basement over book storage area. There are many fixtures not
FO-246880	4/3/2013			Applebaum Rm 364
FO-246881	4/3/2013	4/26/2013		1 fixture out
FO-246909	4/4/2013			There are 3-EP in room #130, please not that 2 of the EP are very old. one of the EP is dated
FO-246919	4/4/2013			Electricians:
FO-246923	4/4/2013	4/9/2013		Electricians:
FO-246958	4/4/2013	4/29/2013		1 fixture out
FO-246959	4/4/2013	4/5/2013		1 fixture out
FO-246960	4/4/2013	4/5/2013		1 fixture out
FO-247021	4/4/2013	4/13/2013		contact: Juanitta Hill
FO-246992	4/5/2013	4/5/2013		Please investigate why tamper switches go to alarm? Also the flow is on that circuit, could that
FO-247034	4/5/2013	4/9/2013		Go to each building with a UPS in the switchgear, and record type, and status, and date batter
FO-247026	4/5/2013	4/8/2013		Cold Room - Room 5222 - Several burnt out light bulbs, please fix. 2 electrical problem. Finish
FO-247068	4/6/2013			Time for work on clocks for the month of March.
FO-247069	4/6/2013			Time for Fire alarm for the month of March.
FO-247070	4/6/2013	4/9/2013		Move steel plate from Life Sci. to University Towers . See John for location. Finished 4/10/13
FO-247119	4/8/2013	4/9/2013		Relocate file cabinets from my office to front office 263.1
FO-247136	4/8/2013	4/9/2013		1 fixture out
FO-247137	4/8/2013	4/9/2013		1 fixture out
FO-247139	4/8/2013	4/9/2013		Light switch to the loading dock is loose, basement Finished 4/11/13 LT
FO-247278	4/8/2013	4/11/2013		We would like to have a new thermometer in
FO-247164	4/8/2013	4/9/2013		Outlet by desk has one receptacle which is partially blocked. We cannot get plugs in complet
FO-247160	4/8/2013	4/9/2013		R&R wall clock near room 115. Finished 4/11/13 LT
FO-247161	4/8/2013	4/9/2013		R&R wall clock near room 121 Finished 4/10/13 LT
FO-247162	4/8/2013	4/9/2013		R&R wall clock near room 20.2 Finished 4/10/13 LT

WO	Recieved	Finished	Total	Request
FO-247181	4/8/2013	4/9/2013		Trade: Sheetmetal Priority: Low
FO-247249	4/9/2013	4/9/2013		Inspect and repair electrical AC unit located inside Pizza Hut of Student Center. Store is extre
FO-247250	4/9/2013	4/10/2013		Repair clock outside room 61 Finished 4/11/13 LT
FO-247251	4/9/2013	4/10/2013		Repair clock outside room 63 Finished 4/11/13 LT
FO-247252	4/9/2013	4/11/2013		Repair clock outside room 77 Finished 4/12/13LT
FO-247253	4/9/2013	4/11/2013		Repair clock outside room 70 Finished 4/11/13 LT
FO-247254	4/9/2013	4/18/2013		Repair clock outside room 479 Finished 4/19/2013LT
FO-247255	4/9/2013	4/18/2013		Repair clock outside room 481 Finished 4/19/2013LT
FO-247256	4/9/2013	4/18/2013		Repair clock outside room 461 Finished 4/19/2013LT
FO-247257	4/9/2013	4/12/2013		Repair clock outside room 421 Finished 4/19/2013LT
FO-247258	4/9/2013	4/18/2013		Repair clock outside room 383 Finished 4/19/2013LT
FO-247259	4/9/2013	4/12/2013		Repair clock outside room 379 Finished 4/15/13LT
FO-247260	4/9/2013	4/11/2013		Repair clock outside room 277 Finished 4/12/13LT
FO-247262	4/9/2013	4/11/2013		Repair clock outside room 237 Finished 4/12/13LT
FO-247263	4/9/2013			Repair clock outside room 236
FO-247264	4/9/2013	4/11/2013		Repair clock outside room 221 Finished 4/12/13LT
FO-247265	4/9/2013	4/11/2013		Repair clock outside room 223 Finished 4/12/13LT
FO-247266	4/9/2013	4/10/2013		Repair clock outside room 165 Finished 4/11/13 LT
FO-247274	4/9/2013	4/18/2013		Chem #130 - 3 fixtures out
FO-247276	4/9/2013	4/10/2013		1 fixture out
FO-247277	4/9/2013	4/10/2013		1 fixture out
FO-247371	4/9/2013	4/29/2013		Locate motor for Karmanos Cooling Tower #1 purchased earlier, existing motor have seized.
FO-247373	4/9/2013	4/9/2013		Meet Scott Brown to check out power on the 6th, and 8th fllo.
FO-247387	4/9/2013			2 lights of the lower level stairwell are out. Electrical problem since 4-2-13. See FO-246471.
FO-247511	4/10/2013			Please move electric lift to fish bowl area . See Jim Hill for location
FO-247543	4/10/2013	4/16/2013		Elect.
FO-247537	4/10/2013			1 fixture out
FO-247538	4/10/2013	4/11/2013		1 fixture out
FO-247594	4/10/2013	4/18/2013		Room 100 has several lights out. Also the conference room has lights out. 1 electrical problem
FO-247611	4/10/2013	4/22/2013		Disconnect #2 hot water heating pump . See Ron Clark for location
FO-247638	4/11/2013	4/18/2013		Electricians-
FO-247639	4/11/2013			Repair light on 1st floorIn the common area 10 Eps. Circulation desk 1 EP. and 1 Ep in servi
FO-247686	4/11/2013	4/23/2013		2 fixtures out
FO-247692	4/11/2013	4/18/2013		R/R 1ST FLR Hallway outside room 1310 - East face of dual faced simplex clock has stopped
FO-247703	4/11/2013	4/15/2013		Deliver gondola to penthouse by AH#11 . See Corey for location
FO-247736	4/12/2013	4/12/2013		A light grate has fallen off its frame near the "A" section of the journals, and needs to be reinst
FO-247713	4/12/2013	4/16/2013		ELECTRICIAN,
FO-247716	4/12/2013	4/16/2013		ELECTRICIANS,
FO-247762	4/12/2013			Electricians:
FO-247764	4/12/2013	4/15/2013		Electrical:
FO-247767	4/12/2013	4/12/2013		Please Pick up material for Pipe Shop . See John Finished 4/15/13LT
FO-247872	4/15/2013			This an an EP. Please escalate to Eugene Owens.
FO-247901	4/15/2013	4/16/2013		1 fixture out
FO-247922	4/15/2013	4/17/2013		URGENT
FO-247935	4/15/2013			A light is out in the elevator 008-01.
FO-247947	4/15/2013	4/24/2013		1 fixture out
FO-247949	4/15/2013	4/24/2013		1 fixture out

WO	Recieved	Finished	Total	Request
FO-248002	4/16/2013			R/R 1ST FLR Please repair broken light fixture in telephone cubicle in hallway next to room 1
FO-248018	4/16/2013	4/18/2013		Fixture in 125.4 has an EP
FO-248035	4/16/2013	4/17/2013		Laborer- please remove pile of old fan sheaves by fan number 2 in the penthouse. Low priority
FO-248036	4/16/2013	4/17/2013		Laborer- Please remove old fan sheaves on floor by fan number 1. Low priority. Work order du
FO-248033	4/16/2013	4/17/2013		Trade: Laborer
FO-248042	4/17/2013	4/19/2013		pls remove the attic stock from the sub
FO-248051	4/17/2013	4/23/2013		DENNIS/LABOR:
FO-248055	4/17/2013	4/17/2013		Go to Sub 49, and get measurements on switchgear, and transformers. Finished 4/18/2013
FO-248066	4/17/2013	4/17/2013		Repair extension cord for electric cars for painters. Finished 4/18/2013
FO-248129	4/18/2013	4/18/2013		Please disconnect sewage ejector in sub basement see Mike Pummill for location Finished 4/
FO-248130	4/18/2013			Remove more piping debris from basement mechanical room . See John Towle for Location
FO-248147	4/18/2013	4/18/2013		Purchase replacement tools worn out by electricians, and tools for clock shop. They need sm
FO-248179	4/18/2013			R/R RM 0033.30/LETHAL CHAMBER 2 lamps are out in Flammable Storage room. Electrici
FO-248173	4/18/2013	4/26/2013		This is an EP
FO-248188	4/18/2013			Electrician repair several ceiling lights in basement mechanical room. priority low
FO-248189	4/18/2013			Electrician repair several ceiling lights in 4th sloor mechanical room. Priority low
FO-248198	4/18/2013	4/23/2013		Room 1358 - Simplex clock located on east end of room off by 1 hour - please fix. Finished 4/
FO-248199	4/18/2013			Please pick up cherry picker in penthouse and deliver to basement mechanical room #27 at P
FO-248223	4/18/2013			The light lens outside of the gym won't stay up inside of he fixture. The lens cover is in rm 102
FO-248224	4/18/2013	4/24/2013		1 fixture out
FO-248253	4/19/2013	4/19/2013		Electricians-Repair fire alarm panel. Won't go out of alarm.
FO-248272	4/19/2013	4/22/2013		Electrical
FO-248314	4/19/2013			R/R BLDG Test and repair the emergency battery unit lights throughout building. Many of the
FO-248315	4/19/2013			R/R BLDG Test and repair as needed the emergency battery unit lights throughout building, b
FO-248316	4/19/2013			R/R BLDG Test and repair as needed the emergency battery unit lights throughout building, b
FO-248317	4/19/2013	4/22/2013		The person in room 407 complains his lights have been out for 6 months.
FO-248371	4/19/2013	4/22/2013		2 fixtures out
FO-248373	4/19/2013			Rm 161
FO-248374	4/19/2013			Rm 1343
FO-248488	4/22/2013	4/25/2013		Flickering light in 3305. 1 electrical problem. Finished 4/26/13LT
FO-248491	4/22/2013	4/23/2013		Meet Dave, and the contractors to put fire panel in by pass. at 5057 Woodward, UGL, and en
FO-248515	4/22/2013	4/23/2013		Manoogian Rm 201
FO-248532	4/22/2013			Relamp Mall Lights
FO-248562	4/23/2013	4/22/2013		Please disconnect / Reconnect domestic recirculation pump in penthouse . See Ron Clark for
FO-248597	4/23/2013	4/29/2013		FIRE TROUBLE ALARM
FO-248600	4/23/2013	4/24/2013		1 fixture out
FO-248601	4/23/2013	4/26/2013		Retest Generator Friday 4/26/13, to test for breaker tripping at Chiller. Pm Technologies will b
FO-248622	4/23/2013	4/26/2013		Scott Hall Rm 322.9
FO-248623	4/23/2013	4/23/2013		Time for PM Technologies to perform the PM work on all 4 generators. Finished 4/24/13LT
FO-248637	4/23/2013	4/24/2013		BioSci just South of Rm 1002
FO-248644	4/23/2013			Range 122 has 2 lights out. Please replace. 1 electrical problem. Range 122 is located on the
FO-248646	4/23/2013			4 fixtures out - 1 EP, lights in 3 fixtures changed and 1 EP marked (D. Glenn)
FO-248752	4/24/2013			Appears breaker is tripped, replaced 3 standard bulbs. -M. Brunson
FO-248802	4/24/2013	4/24/2013		R/R RM 010/SB47 TROUBLESHOOT DEDICATED ELEC/LINE SUPPLYING ELECTRICAL P
FO-248841	4/24/2013	4/29/2013		1 fixture out
FO-248842	4/24/2013			2 fixtures out
FO-248850	4/24/2013			1 EP outside of lab 20, in front of clock.

WO	Recieved	Finished	Total	Request
FO-248853	4/25/2013	4/25/2013		Room 266 a row of lights out. Finished 4/26/13LT
FO-248876	4/25/2013	4/25/2013		Take down lighting on 5th floor in Japanesse room for Plumbers . See Mike Pummill for locati
FO-248888	4/25/2013			Re-lamp flickering light fixture,west corridor, first floor. 1 electrical problem. The e.p is across f
FO-249011	4/25/2013	4/27/2013		Parking Structure #6, Parking Office - Relocate thermostat and light switch. This work is in pr
FO-248927	4/25/2013			Electrician repair motor on chemical injection pump in boiler room.Priority low
FO-248956	4/25/2013			please R&R domestic water pump motor #2 sub basement mechanical room. See John Towle
FO-248962	4/26/2013			8th floor women's restroom eastside of bldg. light out in entrance. Please replace. 1 electrical
FO-248988	4/26/2013			Electricians:
FO-248976	4/26/2013	4/26/2013		This is for time to go to Mac & Mac for training on VFD, class from 2: to 3:30. Finished 4/29/13
FO-249000	4/26/2013			Lights out in room 239 Education - 1 bulb out. Electrical problem.
FO-249009	4/26/2013			Areas of entire building with Electrical Problems (EP). Areas listed by room number, room de
FO-249174	4/29/2013			Hallway light out is an EP. -M.Brunson
FO-249187	4/29/2013			R/R RM 101, Front Desk/Elevator (vapor light fixture missing), 1
FO-249184	4/29/2013			ELECTRICIANS TO MAKE TEST BOARD FOR THE ADA 12/24 VOLTAGE TEST
FO-249189	4/29/2013			R/R RM 119, Light switch (intermittently not working), 1
FO-249195	4/29/2013			R/R RM 301, Reuther 3rd floor hallway (vapor lights out), 2
FO-249196	4/29/2013			R/R (1) RM 320, Reuther Stacks, 3S-G/H row light louver/diffuser missing, 1
FO-249197	4/29/2013			R/R BLDG, Reuther North Stairwell (light marked as EP), 1
FO-249215	4/29/2013			Electricians:
FO-249202	4/29/2013			R/R RM 402, Staff Lounge vapor light (light marked as EP), 1
FO-249203	4/29/2013			R/R RM 420, Reuther Stacks, 4N-C/D row light louver/diffuser missing, 1
FO-249205	4/29/2013			R/R RM 431, 4N Proc Area (light marked as EP), 2
FO-249235	4/29/2013			Electrical work needed for the hot water tank in the back room of
FO-249246	4/29/2013			We have a bunch of burnt out lights. We would like them replaced. 1 electrical problem.
<b>T - Laborer</b>			<b>6</b>	
FO-246499	4/1/2013			Time for laborer to clean shops of trades for the month of April, 2013.
FO-247573	4/10/2013	4/10/2013		Go to Caniff Electric, and pick up 1" pipe. Finished 4/11/13 LT
FO-248041	4/17/2013			pls remove the 12" pipe fittings in the sub bsmt near SF 5 south west corner
FO-248289	4/19/2013			PLEASE INSTALL INSULATION ON SANITARY DRAIN LINE. SEE ENGINEER for location (
FO-248563	4/23/2013			Build Scaffold in the F stairwell, between the 2nd, and third floor.
FO-248951	4/25/2013	4/25/2013		Move motor over to Lande from electric shop. Finished 4/26/13LT
<b>T - Locksmith</b>			<b>89</b>	
FO-246446	4/1/2013			KEYS & CORES ( APRIL 2013 )
FO-246450	4/1/2013	4/1/2013		#74155 4 Keys Room 475 Finished 4/2/2013LT
FO-246452	4/1/2013	4/1/2013		#74154 3 Keys Room 330 Finished 4/2/2013LT
FO-246456	4/1/2013	4/1/2013		#74153 4 Keys Room 122 Finished 4/2/2013LT
FO-246477	4/1/2013	4/12/2013		#70829 4 Keys and 1 Core Room 2286 Finished 4/15/13LT
FO-246494	4/1/2013	4/10/2013		#74226 6 Keys and 2 Cores Room 216 Finished 4/12/13LT
FO-246495	4/1/2013	4/10/2013		#74227 4 Keys and 2 Cores Room 208 Finished 4/12/13LT
FO-246527	4/2/2013			#73998 73 Keys and 16 Cores
FO-246528	4/2/2013	4/12/2013		#73999 3 Keys and 1 Core room 38176 Finished 4/15/13LT
FO-246818	4/3/2013	4/15/2013		#71409 5 Keys Room 9200 Finished 4/16/13LT
FO-246819	4/3/2013	4/10/2013		#73665 8 Keys Room 018 Finished 4/12/13LT
FO-246820	4/3/2013	4/12/2013		#71410 31 Keys Room 9207 Finished 4/15/13LT
FO-246821	4/3/2013	4/15/2013		#71871 5 Keys Room 9207 Finished 4/16/13LT
FO-246844	4/3/2013	4/10/2013		#72433 1 Key Room 3218 Finished 4/12/13LT
FO-246948	4/4/2013			Request # 68395 14 Keys & 5 cores rooms #Corridor, 2103 2311 2312,2316,2320,2321 & 232
FO-246997	4/5/2013	4/15/2013		Please provide Janitor closet master key for Pipe Shop Plumbers . Finished 4/16/13LT

WO	Recieved	Finished	Total	Request
FO-247035	4/5/2013	4/16/2013		#74077 1 Key Room 160 Finished 4/16/13LT
FO-247037	4/5/2013	4/16/2013		#74075 1 key room 156 Finished 4/16/13LT
FO-247039	4/5/2013	4/16/2013		#74076 1 key room 157 Finished 4/16/13LT
FO-247040	4/5/2013	4/16/2013		#74074 4 keys room 140 Finished 4/16/13LT
FO-247042	4/5/2013	4/16/2013		#74073 1 key room 123 Finished 4/16/13LT
FO-247043	4/5/2013	4/16/2013		#74085 1 key room 327 Finished 4/16/13LT
FO-247044	4/5/2013	4/16/2013		#74084 1 key room 326 Finished 4/16/13LT
FO-247045	4/5/2013	4/16/2013		#74083 1 key room 325 Finished 4/16/13LT
FO-247046	4/5/2013	4/16/2013		#74082 1 key room 320/321 Finished 4/16/13LT
FO-247047	4/5/2013	4/18/2013		#74081 2 keys room 249 Finished 4/19/2013LT
FO-247048	4/5/2013	4/18/2013		#74080 1 key room 225 Finished 4/19/2013LT
FO-247049	4/5/2013	4/18/2013		#74079 2 keys room 234 Finished 4/19/2013LT
FO-247050	4/5/2013	4/16/2013		#74078 1 key room 161 Finished 4/16/13LT
FO-247124	4/8/2013	4/23/2013		#73720 6 Cores 15 Keys Finished 4/23/2013LT
FO-247141	4/8/2013	4/9/2013		#74233 1 Keys and 1 Core Room 145 Finished 4/10/13 LT
FO-247142	4/8/2013	4/10/2013		#74232 1 Key Room 139 Finished 4/12/13LT
FO-247527	4/10/2013	4/15/2013		#73406 13 Keys Finished 4/16/13LT
FO-247529	4/10/2013	4/15/2013		#73405 13 Keys Finished 4/16/13LT
FO-247531	4/10/2013			#71873 3 Keys and 1 Core Room 9217
FO-247532	4/10/2013	4/15/2013		#71872 4 Keys Room 9244 Finished 4/16/13LT
FO-247533	4/10/2013	4/16/2013		#65503 5 Keys and 1 Core Room 6259 Finished 4/16/13LT
FO-247534	4/10/2013	4/15/2013		#73597 1 Key Finished 4/16/13LT
FO-247600	4/10/2013			Provide four Padlocks with best cores keyed to Engineering for use with chains to padlock rec
FO-247644	4/11/2013	4/29/2013		#74180 2 Keys and 1 Core Room 3700 Finished 4/30/13 LT
FO-247754	4/12/2013	4/12/2013		Supply Fan Purdy Library
FO-247877	4/15/2013	4/18/2013		#60874 3 Keys Finished 4/19/2013LT
FO-247878	4/15/2013			#73723 3 Keys and 1 Core
FO-247924	4/15/2013	4/18/2013		#73369 7 Keys Room 409 Finished 4/19/2013LT
FO-247926	4/15/2013	4/22/2013		#73704 20 Keys Finished 4/23/2013LT
FO-247937	4/15/2013	4/18/2013		PLEASE MAKE FOUR PAD LOCKS FOR THE PAINT SHOP. Finished 4/19/2013LT
FO-247970	4/16/2013	4/19/2013		#71710 3 Keys Finished 4/19/2013LT
FO-247971	4/16/2013	4/19/2013		#74240 8 Keys Room 52 Finished 4/19/2013LT
FO-247973	4/16/2013	4/24/2013		#74241 3 Keys and 2 Cores Room 441 Finished 4/25/13 LT
FO-248048	4/17/2013	4/18/2013		#74156 9 Keys and 1 Core Room 165 Finished 4/19/2013LT
FO-248049	4/17/2013	4/26/2013		#73724 2 Cores Finished 4/29/13 LT
FO-248050	4/17/2013	4/24/2013		#74242 3 Keys and 2 Cores Room 215 Finished 4/25/13 LT
FO-248155	4/18/2013	4/26/2013		#74283 4 Keys Room 8239 Finished 4/29/13 LT
FO-248156	4/18/2013	4/26/2013		#72411 1 Key Finished 4/29/13 LT
FO-248159	4/18/2013	4/26/2013		#60012 1 Key Finished 4/29/13 LT
FO-248284	4/19/2013	4/25/2013		#74245 2 Keys Room 2123 Finished 4/26/13LT
FO-248286	4/19/2013	4/26/2013		#74045 2 Keys Finished 4/29/13 LT
FO-248288	4/19/2013			#73641 3 Keys and 6 Cores
FO-248294	4/19/2013	4/25/2013		#73632 3 Keys Room 1353 Finished 4/26/13LT
FO-248295	4/19/2013	4/25/2013		#73633 3 Keys Room 1200 Finished 4/26/13LT
FO-248296	4/19/2013	4/24/2013		#73637 4 Keys Room 2348 Finished 4/25/13 LT
FO-248297	4/19/2013			#73523 3 Keys Room 1151
FO-248298	4/19/2013			#73634 1 Key Room 5211

WO	Recieved	Finished	Total	Request
FO-248356	4/19/2013	4/23/2013		#74107 2 Keys Finished 4/24/13LT
FO-248357	4/19/2013	4/23/2013		#74046 2 Keys Finished 4/24/13LT
FO-248358	4/19/2013	4/23/2013		#74039 2 Keys Finished 4/24/13LT
FO-248362	4/19/2013	4/23/2013		#74038 1 Key Room 412 Finished 4/24/13LT
FO-248363	4/19/2013	4/24/2013		#73725 16 Keys Finished 4/25/13 LT
FO-248367	4/19/2013	4/23/2013		#74017 3 Keys and 2 Cores Finished 4/24/13LT
FO-248506	4/22/2013	4/23/2013		#73407 2 Keys Finished 4/24/13LT
FO-248525	4/22/2013			#72208 10 Keys and 3 Cores
FO-248526	4/22/2013	4/23/2013		#73325 2 Keys and 1 Core Room 1107 Finished 4/24/13LT
FO-248527	4/22/2013	4/23/2013		#71874 4 Keys Room 9227 Finished 4/24/13LT
FO-248528	4/22/2013	4/23/2013		#74105 1 Keys Room 1206 Finished 4/24/13LT
FO-248576	4/23/2013	4/23/2013		#71243 5 Keys Room 35 Finished 4/24/13LT6
FO-248577	4/23/2013	4/25/2013		#74044 3 Keys and 1 Core Room 2309 Finished 4/26/13LT
FO-248630	4/23/2013			Make 3 keys for the Fire Crew. Key ANT1
FO-248762	4/24/2013			#76386 19 Keys
FO-248763	4/24/2013			#73643 3 Keys
FO-248764	4/24/2013	4/29/2013		#73642 7 Keys Finished 4/30/13 LT
FO-248765	4/24/2013	4/29/2013		#73763 1 Key and 1 Core Finished 4/30/13 LT
FO-248798	4/24/2013	4/25/2013		#72510 4 Keys Finished 4/26/13LT
FO-248882	4/25/2013			REPLACE CORE ON EAST DOOR OF ROOM 2663. DOES NOT WORK WITH BUILDING M
FO-248884	4/25/2013	4/25/2013		#70478 3 Keys Finished 4/26/13LT
FO-248885	4/25/2013	4/29/2013		#73966 15 Keys Finished 4/30/13 LT
FO-248970	4/26/2013	4/29/2013		#74344 1 Key Room1509 Finished 4/30/13 LT
FO-248971	4/26/2013	4/29/2013		#73643 3 Keys Finished 4/30/13 LT
FO-249033	4/26/2013	4/26/2013		51265 28-KEYS Finished 4/29/13 LT
FO-249172	4/29/2013	4/29/2013		#73125 4 Keys Finished 4/30/13 LT
<b>T - Painter</b>			<b>35</b>	
FO-246572	4/2/2013	4/10/2013		Please have Painters patch/paint small room in the rear of the FP&M Stockroom . See Larry C
FO-246600	4/2/2013	4/9/2013		ADDING PAINTER: CURB APPEAL R/R CAMPUS/VARIOUS Reuther Mall between Anthony
FO-246876	4/3/2013	4/17/2013		Please repair and paint wall next to the entrance to room 2100 behind vending machines. The
FO-247175	4/8/2013	4/8/2013		NEW EMPLOYEE ORDINATION. Finished 4/9/2013 LT
FO-247176	4/8/2013	4/8/2013		REPAIR THE PLASTER AROUND THE ACCESS PANNEL Finished 4/9/2013 LT
FO-247177	4/8/2013	4/9/2013		PAINTERS:
FO-247516	4/10/2013	4/24/2013		JANITOR CLOSET #2211 NEEDS WALL PATCH AND THE CLOSET PAINTED. Finished 4/
FO-247636	4/11/2013	4/10/2013		Carpenter repair ceiling at room 2303. Priority low. Finished 4/10/13 LT
FO-247662	4/11/2013	4/25/2013		Please have Painters paint small room in the rear of the FP&M Stockroom . See Larry Cook fo
FO-247671	4/11/2013	4/16/2013		PAINT THE FOURTH FLOOR HALLWAY @ OFFICE SERVICES AREA. Finished 4/16/13LT
FO-247714	4/12/2013			HANDYMAN TIME.
FO-247717	4/12/2013			MTL TIME.
FO-247721	4/12/2013	4/18/2013		Repair the plaster in main lobby. Finished 4/19/2013LT
FO-247757	4/12/2013	4/29/2013		NEED A PAINTER TO DO SOME DRYWALL WORK IN ROOM # O108 (DLAR/LOUNGE) AR
FO-247867	4/15/2013	4/15/2013		PAINT THE UNDER SIDE AND HANDRAILS TO THE CHEMICAL PLATFORM FOR THE PO
FO-247868	4/15/2013	4/15/2013		FINISH MARIO'S DOOR Finished 4/18/2013
FO-247939	4/15/2013	4/16/2013		PLEASE EMPTY DRIP PANS IN ROOM 323.5 Finished 4/16/13LT
FO-247969	4/16/2013			Paint inside of main elevator-- engineering main building.
FO-248021	4/16/2013	4/19/2013		PAINT THE NORTH WEST AND THE SOUTH EAST ENTRANCE ON THE FOURTH FLOOR
FO-248084	4/17/2013	4/24/2013		TAPE, PATCH AND PAINT LUNCH ROOM IN THE PIPE SHOP. Finished 4/25/13 LT

WO	Recieved	Finished	Total	Request
FO-248086	4/17/2013	4/24/2013		PAINT DAMAGED CEILING TILES. 323.5 Finished 4/25/13 LT
FO-248099	4/17/2013	4/18/2013		RUSH PRESIDENT"S OFFICE.
FO-248106	4/17/2013	4/18/2013		Roofers Priority Med
FO-248131	4/18/2013			PAINT THE FLOOR IN PIPE SHOP LUNCH ROOM.
FO-248141	4/18/2013	4/18/2013		Caulk top of press box Finished 4/18/2013
FO-248365	4/19/2013	4/25/2013		REPAIR THE PLASTER IN THE GREEN ROOM CORNER. Finished 4/29/13 LT
FO-248517	4/22/2013	4/24/2013		Repair the plaster in main lobby. Finished 4/19/2013LT OPEN TO THE PAINTERS TO PAINT
FO-248543	4/22/2013	4/24/2013		PAINT THE THIRD FLOOR HALLWAY BETWEEN ROOM 3300 AND 3330. Finished 4/25/13
FO-248620	4/23/2013			Clean off or paint over graffiti on campus for the Month of April.
FO-248792	4/24/2013			PAINT THE SECOND FLOOR HALLWAY. DJK
FO-248794	4/24/2013	4/29/2013		PAINT THE THIRD FLOOR HALLWAY @ 3400 MARKETING AND COMMUNICATIONS. Fini
FO-248795	4/24/2013	4/29/2013		REPAIR THE PLASTER IN MAIN LOBBY WEST SIDE. DUE TO ROOF LEAK. Finished 4/29/
FO-248944	4/25/2013			WOMEN'S RESTROOM 1ST FLOOR GRAFFITI ON WALLS. PLEASE PAINT.
FO-249040	4/26/2013			REPAIR THE PLASTER IN MENS DRESSING ROOM. BASEMENT.
FO-249041	4/26/2013			REPAIR THE PLASTER IN FRONT OF THE ELEVATORS ON THE FIRST FLOOR.
<b>T - Pipefitter</b>			<b>37</b>	
FO-246453	4/1/2013	4/26/2013		Pipefitters:
FO-246478	4/1/2013			Asbestos / Insulation Processing for month of April ,,,,,,,,,,CB/4-1-13 ,,,,,,,,,, DUE 4-30-13
FO-246479	4/1/2013			Building Utility Interruption / Communication / Processing Time ,,,,,,,,,,CB/4-1-13 ,,,,,,,,,, D
FO-246611	4/2/2013			Fitter replace both sight glass on D.A. tank in boiler room. Priority low.,,,,,,,,,,ME/4-3-13 ,,,,,,
FO-246629	4/2/2013	4/8/2013		replace gasket on west end heat exchanger along with both supply butterfly valves for water a
FO-246634	4/2/2013	4/4/2013		Relocate PVC pipe to 3rd floor ,,,,,,,,,,ME/4-2-13,,,,,,,,,DUE 4-2-13 Finished 4/5/13 LT
FO-246840	4/3/2013			PF Med Priority
FO-247075	4/3/2013			Fabricate tank stand to accomodate new chemical feed system in boiler room.,,,,,,,,,,JH/
FO-246867	4/3/2013	4/3/2013		attend lock-out tag-out meeting in conference room #4 ,,,,,,,,,,CB/4-3-13 ,,,,,,,,,,DUE 5-3-1
FO-246888	4/3/2013	4/9/2013		fitters-please replace check valve & 5-pound safety valve for D.A.steam line in front D.A. tank
FO-246908	4/4/2013	4/5/2013		REPAIR HOLE IN GRATTING BY BIG PIPE SOUTH OF THE STAIRS. FRONT OF ENTRAN
FO-247166	4/4/2013	4/9/2013		Check new condensate reciever for correct operations ,,,,,,,,,,JH/RC 4-4-13 ,,,,,,,,,,DUE 5-8-
FO-246951	4/4/2013	4/25/2013		Fitter
FO-246967	4/4/2013	4/4/2013		please fab up hanger for air hose for electricians smoke alarm station,,,,,,,,,CB/4-4-13 ,,,,,,,,,,
FO-246969	4/4/2013	4/4/2013		please attend safety meeting for month of April,,,,,,,,,CB/4-4-13 ,,,,,,,,,,DUE 5-4-13 Finished
FO-246993	4/5/2013	4/9/2013		please remove piping from pipe rack, move to upstairs cage, and move rack to Scott Hall,,,,,,,,,
FO-247029	4/5/2013	4/19/2013		R/R Domestic hot water recirc pump on HWH penthouse ,,,,,,,,,,RC/4-5-13 ,,,,,,,,,,DUE 5-5-
FO-247041	4/5/2013	4/9/2013		Need material list to re-surface lay out table for Pipe Shop ,,,,,,,,,,JH/RC 4-5-13 ,,,,,,,,,, Fini
FO-247513	4/10/2013			Replace or unplug supply and return pipes to reheat coil for room 270. The reheat in located in
FO-247520	4/10/2013	4/29/2013		please repair/replace chilled water circuit setter on chiller #1,,,,,,,,,CB/4-10-13,,,,,,,,,DUE
FO-247525	4/10/2013	4/12/2013		fitters repair or replace boiler No. 2 chem pump. priority high ,,,,,,,,,, RC/4-10-13 ,,,,,,,,,, D
FO-247582	4/10/2013	4/11/2013		Fitter
FO-247591	4/10/2013	4/11/2013		FITTERS,
FO-247601	4/10/2013	4/29/2013		R/R 1 1/4" Steam Trap on heat exchanger . See Jim Hill for location ,,,,,,,,,, ME/4-11-13 ,,,,,
FO-247709	4/12/2013	4/13/2013		FITTERS,
FO-247710	4/12/2013	4/13/2013		FITTERS,
FO-247712	4/12/2013	4/13/2013		FITTERS,
FO-247786	4/13/2013			Update Pump trailer to accomadate all pump supplys ,,,,,,,,,,JH/RC 4-15-13 ,,,,,,,,,,DUE 5-1
FO-247787	4/13/2013			This is to start fabricating pipe mains and branchs for hydronic heating system in DLAR hallwa
FO-248549	4/22/2013			R/R leaking 4" chemical piping near tool crib rm 100 ,,,,,,,,,,ME/4-22-13 ,,,,,,,,,,DUE 5-22-13
FO-248556	4/22/2013	4/23/2013		R/R 2 1/2" flange gasket leaking on AH#4 ,,,,,,,,,,JH/RC 4-23-13,,,,,,,,,DUE 5-22-13 Finis



WO	Recieved	Finished	Total	Request
FO-248559	4/22/2013			replace leaking seals on condensate pump #1 on vacume pump unit #2 located in sub-basem
FO-248567	4/23/2013			R/R 24" butterfly valve acuators on roof . See Corey for location .....CB/4-23-13 .....
FO-248812	4/24/2013	4/25/2013		R/R RM 128 MENS RR RADIATOR IS LKNG .....JH/RC 4-25-13 .....DUE 5-24-13 Fini
FO-249217	4/29/2013			fitters-
FO-249216	4/29/2013			Fitters,
FO-249220	4/29/2013			Fitters,
<b>T - Plumber</b>			<b>98</b>	
FO-246442	4/1/2013	4/2/2013		R&R DRINKING FOUNTAIN IN LOCKER ROOM. DOES NOT WORK ..... MP/DB 4-1-13
FO-246472	4/1/2013	4/5/2013		The wall urinal next to showers does not flush.....MP/DB 4-3-13 Finished 4/8/13 LT
FO-246481	4/1/2013			Team Leader Adiministriative Time for month of April
FO-246482	4/1/2013			Plumber / Pipefitter Shop Time for month of April
FO-246485	4/1/2013	4/17/2013		PM all toilets as needed throughout all floors .....MM/4-1-13 .....DUE 5-1-13 Finished
FO-246617	4/1/2013	4/4/2013		R/R 3/4" gate valve on drip leg in basement mechanical room .....ME/4-2-13.....DUE 5
FO-246573	4/2/2013			R/R freight elevator sump pump in sub basement .....MP/DB 4-2-13 .....DUE 5-2-13
FO-246620	4/2/2013	4/5/2013		R/R RM 232 Womens restroom, 2nd floor. Low water pressure, not much water flowing in the
FO-246608	4/2/2013	4/8/2013		R/R 0410/DLAR HAS A LEAKING/DRIPPING PIPE LEADING TO BOTTLE WASHER .....
FO-246636	4/2/2013			Parking Structure #6 Office - Install retro-fit water bottle cooler. ....MP/DB 4-3-13 .....
FO-246627	4/2/2013			Evaluate material needed for backflow in room 100 .....MP/DB 4-2-13 .....DUE 5-2-13
FO-246639	4/2/2013	4/5/2013		In the Men's Locker Room the toilet in the stall closest to the shower does not have water.....
FO-246804	4/3/2013	4/26/2013		PM urinals for month of April .....MM/4-3-13 .....DUE 5-3-13 Finished 4/29/13 LT
FO-246806	4/3/2013	4/3/2013		R/R dishwasher leak / and vacuume breaker in kitchen .....RJC/4-3-13 .....DUE 5-
FO-246884	4/3/2013	4/4/2013		( Work is Done ). Check on plumbing drainage issue, Kitchen Area within retail space, Macca
FO-246871	4/3/2013	4/10/2013		CEILING LEAK. ROOM 330..... DJP/1-31-13 ..... MP/DB/DJP 4-4-13 .....DUE
FO-246889	4/3/2013			Install RPZ and piping for cooling tower .....DJP/4-4-13 .....DUE 5-3-13
FO-246897	4/3/2013	4/10/2013		Plumber:Men's Restroom
FO-246894	4/4/2013	4/8/2013		6TH FLOOR WEST MEN'S RESTROOM IN THE 2ND STALL BEHIND TOILET ON WALL ME
FO-246936	4/4/2013	4/8/2013		R/R 2ND FLR (DRINK FOUNT BY RESTROOMS)UNPLUG Two (out of four) water fountains
FO-246965	4/4/2013			Run Drain line 2ed floor / See John for location .....MP/DB 4-4-13 .....DUE 5-4-13
FO-246971	4/4/2013			R/R 5th floor floor drain from penthouse located in mens room .....MP/DB 4-4-13 .....
FO-246996	4/5/2013			Plumbers
FO-247017	4/5/2013	4/15/2013		R/R 2ed floor womens toilet room faucets.....MP/DB 4-5-13.....DUE 5-5-13 Finished
FO-247030	4/5/2013			Repair hole in domestic hot water feed line on HWH penthouse . See Jim Hill for location .....
FO-247036	4/5/2013	4/19/2013		Please install auto flush e-z retro fit kits in all mens toilet rooms 6 urinals old wing ..... MP/
FO-247073	4/6/2013	4/6/2013		R/R domestic water booster pump 21 in room 100 ..... MP/DB 5-6-13 ..... Finished 5-
FO-247275	4/8/2013			The hot water tank in the back room of
FO-247169	4/8/2013	4/10/2013		plumber: please clear drain next to slop sink.priority:reg.....DJP/4-9-13 .....DUE 5-8-
FO-247198	4/8/2013			PLEASE R&R BRADLY GAVE HAND SINK .....MP/DB 4-9-13 .....DUE 5-8-13
FO-247199	4/8/2013			The basement Janitor Closet sink needs new faucet so we can put a hose on it..... MP/
FO-247205	4/8/2013			Evaluate material for booster pumps in room 100 .....MP/DB 4-9-13 .....DUE 5-8-1
FO-247208	4/8/2013			PLUMBERS: Please repair leaking backflow preventer in penthouse near chillers. MED.
FO-247210	4/8/2013			Trade: Plumber Priority: Medium
FO-247211	4/8/2013			Evaluate material for repairing roof conductor .....MP/DB 4-9-13 .....DUE 5-8-13
FO-247218	4/9/2013	4/10/2013		Basement mens restroom (close to elevators)first sink has a leaking pipe.....MM/4-10-1
FO-247220	4/9/2013	4/10/2013		Basement women(close to elevators)restroom fourth sink has a leak.....MM/4-10-13 .....
FO-247384	4/9/2013	4/11/2013		1st floor Janitors closet located between men's room(132) and woman's room (130) slop sink
FO-247388	4/9/2013			Lower level men's restroom urinal running and wont stop.
FO-247389	4/9/2013			Lower level woman's toilet across from broken sink in need of repair.

WO	Recieved	Finished	Total	Request
FO-247390	4/9/2013			Lower level woman's restroom faucet is broken and sitting in the sink.
FO-247391	4/9/2013			2nd floor men's restroom faucet is broken. Custodial staff covered it with a WSU bag.
FO-247394	4/10/2013			Basement of Old main, room 0143, pipe leaking from the ceiling, near the window.
FO-247526	4/10/2013			Plumbers. repair leaking sill cock. in tunnel. priority medium ,,,,,,,,,,,,,,RJC/4-10-13 ,,,,,,,,,,,,,,DU
FO-247571	4/10/2013			Plumber; low
FO-247583	4/10/2013	4/19/2013		Plumber
FO-247602	4/10/2013			R/R 2ND FLR SOUTHEND DRINK FOUNT IS HANGING OFF WALL PLS SHUT OFF WTR
FO-247605	4/10/2013			please r&r faucet room 9232,,,,,,,,,,,,,MM /4-11-13 ,,,,,,,,,,,,,,DUE 5-10-13
FO-247607	4/10/2013			R/R 1ST FLR Please replace toilet in Women's Restroom (by the lunchroom) with a toilet with
FO-247647	4/11/2013	4/18/2013		Trade: Plumber Priority: Low
FO-247657	4/11/2013			plumber: please r or r badly leaking seals on both dom water booster pumps.PRIORITY:HIGH
FO-247704	4/11/2013	4/22/2013		R/R mens / womens room 1st,2ed,3rd floor ,,,,,,,,,,,,,,MP/DB 4-12-13 ,,,,,,,,,,,,,,DUE 5-11-13 Fini
FO-247763	4/12/2013	4/18/2013		R/R RM 101 Please repair kitchen faucet in kitchen area at the football stadium...See Bob OST
FO-247881	4/15/2013			R/R Room 2614: facet is leaking from base when turned on ,,,,,,,,,,,,,,MM/4-15-13 ,,,,,,,,,,,,,,D
FO-247910	4/15/2013	4/17/2013		R/R RM 412 HAS FAUCET IS LKNG ,,,,,,,,,,,,,,MM/4-15-13 ,,,,,,,,,,,,,,DUE 5-15-13 Finished 4/19
FO-247961	4/16/2013	4/16/2013		PLEASE ASSIST ENGINEER IN LOCATING ISOLATION VALVES TO THE SECOND FLOO
FO-247997	4/16/2013			Parking Structure #1 West Elevator Mechanical Room please check sump pumps to ensure th
FO-247996	4/16/2013			Please turn water on for Parking Structures #1, 2, 3, 4, 5, 6, and 8. If external water spigots ar
FO-248008	4/16/2013			Seat replacement in Women's Restroom at Custodial/Ground 5743 Woodward ,,,,,,,,,,,,,,RJC
FO-248011	4/16/2013	4/17/2013		PLUMBERS,
FO-248014	4/16/2013	4/19/2013		MEN'S RESTROOM ON 5TH FLOOR ACROSS FROM 5315--WHEN URINAL IS FLUSHED T
FO-248094	4/17/2013	4/18/2013		Urinal stopped up - basement mens room(the stopped up urinal is baged),,,,,,,,,,,,,,MP/DB 4-18
FO-248283	4/17/2013	4/19/2013		Need to replace toilet at parking structure #2 office. Toilet runs continually, (wasting water). T
FO-248134	4/18/2013	4/19/2013		PLEASE INSTALL INSULATION ON SANITARY DRAIN LINE. SEE ENGINEER for location (
FO-248135	4/18/2013			R/R TP valve on HWH #3 ,,,,,,,,,,,,,,MM/4-17-13,,,,,,,,,,,,,DUE 5-17-13
FO-248164	4/18/2013			Replace toilet seat in men's room ,,,,,,,,,,,,,,RJC/4-18-13 ,,,,,,,,,,,,,,DUE 5-18-13
FO-248256	4/19/2013	4/22/2013		Men's room 1303: Urinal leaks ,,,,,,,,,,,,,,MM/4-19-13 ,,,,,,,,,,,,,,DUE 5-18-13 Finished 4/23/201
FO-248259	4/19/2013			1st floor men's restroom (#108) 2nd stall leaks in seam between flush pipe and toilet. ,,,,,,,,,,,,,,
FO-248260	4/19/2013			Basement woman's restroom (#072)toilet seat is off toilet. ,,,,,,,,,,,,,,RJC/4-19-13 ,,,,,,,,,,,,,,DU
FO-248261	4/19/2013			1st floor womans restroom (#170)toilet has WSU bag over it due to being inoperable.,,,,,,,,,,,,,,
FO-248300	4/19/2013			R/R 3RD FLR HALLWAY OUTSIDE OF RM 355 DRINK FOUNT IN SLOWLY DRAINNING (cu
FO-248312	4/19/2013			R/R 1ST FLR STAFF/UNISEX Restroom handicap shower head in locker room shower.,,,,,,,,,,,,,,
FO-248330	4/19/2013			RM 130 SINK ACROSS FROM FUME HOOD 14 IS LEAKING BADLY ,,,,,,,,,,,,,,MP/DB 4-19-
FO-248388	4/20/2013	4/23/2013		WDET men's rest room, has a leaking faucet.,,,,,,,,,,,,,,MP/DB 4-22-13 ,,,,,,,,,,,,,,DUE 5-19-1
FO-248389	4/20/2013	4/25/2013		Men's restroom urinal squirts water from inside the top and leaks water from the bottom when
FO-248534	4/22/2013	4/22/2013		1st floor mens room toilet/water running ,,,,,,,,,,,,,,Finished 4-22-13 JWT / Refer to FO#248510
FO-248535	4/22/2013			Water fountain on/off switch sticking - in the basement near janitors closet ,,,,,,,,,,,,,,RJC/4-23-
FO-248537	4/22/2013	4/24/2013		toilet seat broke/ mens roon 3rd floor no room number near stairs, UGL ,,,,,,,,,,,,,,DJP/4-23-13 ,
FO-248539	4/22/2013	4/29/2013		R/R BSMT Water fountain in basement outside of the Mens and Womens restroom is leaking.
FO-248554	4/22/2013			Old Wing 2ed floor mens . Please install auto flush valve on urinal,,,,,,,,,,,,,MP/DB 4-23-13 ,,,,,,
FO-248650	4/23/2013			R/R cracked sink / Interceptor room 162 ,,,,,,,,,,,,,,RJC/4-24-13 ,,,,,,,,,,,,,,DUE 5-23-13
FO-248761	4/24/2013			Plumbers:
FO-248824	4/24/2013			Trade: Plumber Priority: Low
FO-248831	4/24/2013			PLUMBERS,
FO-248877	4/25/2013			Plumbers: Please repair broken handle on control valve for gang shower. Men's locker room c
FO-248922	4/25/2013			Plumber repair ceiling leak in garage coming from DLAR cage washer. Priority low.,,,,,,,,,,,,,,M
FO-248934	4/25/2013			Trade: Plumber Priority: Low

WO	Recieved	Finished	Total	Request
FO-248989	4/26/2013			Plunbers:
FO-249018	4/26/2013	4/29/2013		R/R BLDG Multiple water problems: Sink is clogged and
FO-249020	4/26/2013	4/26/2013		R/R RM 008/MENS RR 3RD SINK FAUCET SENSOR ISN'T WRKNG .....Finished 4-26
FO-249023	4/26/2013			R/R 3RD FLR/MENS RR (ONLY MENS RM) 3RD SINK FAUCET SENSOR ISN'T WRKNG ....
FO-249024	4/26/2013	4/29/2013		R/R 1ST FLR/WOMENS RR (ONLY WOMENS RM) HANDICAP STALL TOILET IS BAGGED
FO-249027	4/26/2013	4/29/2013		3rd floor Mens room 3438 toilet not flushing UGL building .....DJP/4-26-13 .....DUE 5-2
FO-249060	4/29/2013			R/R RM 1249 Handle on eyewash station in lab 1249 sticks in open position..... MM/4-2
FO-249169	4/29/2013	4/29/2013		MEN'S RESTROOM #107 FIRST STALL THE TOILET CONTINUES TO FLUSH. ....Finis
FO-249194	4/29/2013	4/29/2013		R/R RM 107/MENS RR Kresge 1st Floor Men's Rest Room
FO-249223	4/29/2013	4/30/2013		R/R 1ST FLR MENS RR Men's bathroom first floor. Toliet will not stop flushing.....Finish
FO-249229	4/29/2013			R/R RM 3016 Tap for distilled water is broken. Please fix.....MP/DB 4-30-13 .....D
<b>T - Roofing</b>			<b>5</b>	
FO-247684	4/11/2013	4/22/2013		R/R RM 318 REPAIR ROOF LEAKING OVER OFC EQUIP
FO-247876	4/15/2013			Roofer:
FO-248015	4/16/2013	4/23/2013		R/R 4TH FLR HALLWAY OUTSIDE/NEAR ELEV ROOF LEAK. IT WAS A AIR HANDLER LE
FO-248096	4/17/2013	4/23/2013		ROOFER: Please repair continous leak near freight elevator (rain leak) LOW. WORK WAS P
FO-248201	4/18/2013	4/23/2013		R/R 1ST FLR EAST OF SIDE OF AUDITORIUM RM 101 REPAIR ROOF LEAK. SCHREIBER
<b>T - Sheetmetal</b>			<b>4</b>	
FO-248046	4/17/2013			SHEETMTAL:
FO-248280	4/19/2013			Please exchange vav 9 and vav 10 with each other. These vav's were removed during DJ Kiet
FO-248905	4/25/2013			In ceiling of 1st floor lobby - Please replace fusible link in ductwork - An access hatch may hav
FO-248930	4/25/2013			Sheetmetal: Please repair or replace broken bracket for fan bearing. Fan F7-2 for Room 3141.
<b>Routine</b>			<b>1</b>	
<b>T - Electrician</b>			<b>1</b>	
FO-246566	4/2/2013	4/2/2013		Lights for the building.

**Scheduled Maint. (PM) 749**

**Engineering 716**

**High 2**

**E - Afternoon Engineer 2**

FO-246989 4/5/2013 4/5/2013 Check broken window as reported by PS.

FO-246990 4/5/2013 4/5/2013 PS reported that they needed an engineer to take them to Engineering building and Bio-Scien

**Low 1**

**E - Area 2 Engineer 1**

FO-248321 4/19/2013 FO Number for Year-Long Chemicals to treat boiler. FY 2013.

**Routine 713**

**E - Afternoon Engineer 289**

FO-243937 4/1/2013 4/17/2013 PM - Air Handling Unit

FO-243938 4/1/2013 3/21/2013 PM - Fan Coil/HV/AC Unit

FO-243939 4/1/2013 3/21/2013 PM - Fan Coil/HV/AC Unit

FO-243940 4/1/2013 3/21/2013 PM - Fan Coil/HV/AC Unit

FO-243941 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243942 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243943 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243944 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243945 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243946 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

FO-243947 4/1/2013 3/23/2013 PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-243948	4/1/2013	3/23/2013		PM - Fan Coil/HV/AC Unit
FO-243949	4/1/2013	3/23/2013		PM - Fan Coil/HV/AC Unit
FO-243955	4/1/2013	4/19/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243956	4/1/2013	4/5/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243957	4/1/2013	4/19/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243960	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243961	4/1/2013		3/19/2013	PM - Monthly Fire Alarm/Fire Protection System Test
FO-243962	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243963	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243964	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243965	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243966	4/1/2013	4/30/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243967	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243968	4/1/2013	4/30/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243969	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243970	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243971	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243972	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243973	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243974	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243975	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243976	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243977	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243978	4/1/2013	4/5/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243979	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243980	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243981	4/1/2013	4/5/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243982	4/1/2013	4/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243983	4/1/2013	4/17/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243984	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243985	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243986	4/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-243987	4/1/2013	4/30/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243988	4/1/2013	4/30/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243989	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243990	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243991	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243992	4/1/2013	5/1/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243993	4/1/2013	5/1/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243994	4/1/2013	4/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243995	4/1/2013	4/5/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243996	4/1/2013	4/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243997	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243998	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243999	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244000	4/1/2013	4/22/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244001	4/1/2013	4/18/2013		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-244002	4/1/2013	4/17/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244003	4/1/2013	4/17/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244004	4/1/2013	4/18/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244005	4/1/2013	4/18/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244887	4/1/2013	3/25/2011		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243950	4/3/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243951	4/3/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243952	4/3/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246891	4/4/2013	4/4/2013		Replace bag and pre - filters on ahu 6.
FO-243864	4/4/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243865	4/4/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243866	4/4/2013	4/2/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243867	4/4/2013	4/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243868	4/4/2013	4/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243869	4/4/2013	4/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243870	4/4/2013	4/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243871	4/4/2013	4/19/2013		PM - Air Handling Unit
FO-243872	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243873	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243874	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243875	4/4/2013	4/24/2013		PM - Air Handling Unit
FO-243880	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243881	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243882	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243883	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243884	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243885	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243886	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243887	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243888	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243889	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243890	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243891	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243892	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243893	4/4/2013	3/15/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243894	4/4/2013	3/15/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243895	4/4/2013	3/15/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243896	4/4/2013	3/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243897	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243898	4/4/2013	3/14/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243899	4/4/2013	3/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243905	4/4/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-243906	4/4/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-243907	4/4/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-243926	4/4/2013	4/16/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243927	4/4/2013	4/13/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243928	4/4/2013	4/13/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-243929	4/4/2013	4/13/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-243930	4/4/2013	4/19/2013		PM - Air Handling Unit
FO-243931	4/4/2013	4/19/2013		PM - Air Handling Unit
FO-243932	4/4/2013	4/18/2013		PM - Air Handling Unit
FO-243933	4/4/2013	4/18/2013		PM - Air Handling Unit
FO-246988	4/5/2013	4/5/2013		Change filters bags and pre filters.
FO-247062	4/5/2013	4/6/2013		Change filters both bags and pre-filters on ahu 4
FO-244520	4/6/2013	4/12/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244521	4/6/2013	4/11/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244522	4/6/2013	4/13/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244523	4/6/2013	4/11/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244524	4/6/2013	4/20/2013		PM - Air Handling Unit
FO-244531	4/6/2013			PM - Air Handling Unit
FO-244532	4/6/2013			PM - Air Handling Unit
FO-244533	4/6/2013	5/1/2013		PM - Air Handling Unit
FO-244534	4/6/2013	5/1/2013		PM - Air Handling Unit
FO-244540	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244541	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244542	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244543	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244544	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244545	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244546	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244547	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244548	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244549	4/8/2013	4/4/2013		PM - Fan Coil/HV/AC Unit
FO-244550	4/8/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-244551	4/8/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-244552	4/8/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-244553	4/8/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-247209	4/8/2013	4/9/2013		Change Filters
FO-244557	4/9/2013			Replace filters
FO-244558	4/9/2013			Replace filters
FO-244559	4/9/2013			Replace filters
FO-247382	4/9/2013	4/10/2013		Replace filters ahu 13.
FO-244519	4/10/2013			PM - Air Handling Unit
FO-244554	4/10/2013	4/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244555	4/10/2013	4/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244556	4/10/2013	4/23/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247613	4/11/2013	4/11/2013		Change filters on ahu 12
FO-244510	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244511	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244512	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244513	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244514	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244515	4/11/2013	4/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-244516	4/11/2013			PM - Air Handling Unit

WO	Recieved	Finished	Total	Request
FO-244517	4/11/2013			PM - Air Handling Unit
FO-244518	4/11/2013			PM - Air Handling Unit
FO-244525	4/11/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-244526	4/11/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-244527	4/11/2013	4/17/2013		PM - Fan Coil/HV/AC Unit
FO-244528	4/11/2013			PM - Air Handling Unit
FO-244535	4/11/2013	4/19/2013		PM - Air Handling Unit
FO-244536	4/11/2013	4/19/2013		PM - Air Handling Unit
FO-244537	4/11/2013	4/3/2013		PM - Air Handling Unit
FO-244538	4/11/2013	4/19/2013		PM - Air Handling Unit
FO-244539	4/11/2013	4/19/2013		PM - Air Handling Unit
FO-247702	4/11/2013	4/12/2013		Replace filters ahu 11
FO-244529	4/12/2013			PM - Air Handling Unit
FO-244530	4/12/2013			PM - Air Handling Unit
FO-247773	4/12/2013	4/13/2013		Change filters on ahu 10
FO-245132	4/13/2013	4/25/2013		PM - Air Handling Unit
FO-245140	4/13/2013			PM - Air Handling Unit
FO-245141	4/13/2013			PM - Air Handling Unit
FO-245142	4/13/2013			PM - Air Handling Unit
FO-245179	4/13/2013			PM - Air Handling Unit
FO-245123	4/14/2013	4/20/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245133	4/14/2013	4/24/2013		PM - Air Handling Unit
FO-245134	4/15/2013	4/24/2013		PM - Air Handling Unit
FO-245143	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245144	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245145	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245146	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245147	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245148	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245149	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245150	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245151	4/15/2013	4/6/2013		PM - Fan Coil/HV/AC Unit
FO-245135	4/16/2013	4/23/2013		PM - Air Handling Unit
FO-245171	4/16/2013			PM - Air Handling Unit
FO-245172	4/16/2013			PM - Air Handling Unit
FO-245173	4/16/2013			PM - Air Handling Unit
FO-245174	4/16/2013			PM - Air Handling Unit
FO-245175	4/16/2013			PM - Air Handling Unit
FO-245176	4/16/2013			PM - Air Handling Unit
FO-245177	4/16/2013			PM - Air Handling Unit
FO-245178	4/16/2013			PM - Air Handling Unit
FO-248040	4/16/2013	4/17/2013		perform PM on exhaust fan #11A
FO-245130	4/17/2013			PM - Air Handling Unit
FO-245131	4/17/2013			PM - Air Handling Unit
FO-245152	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245153	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245154	4/17/2013			PM - Fan Motor Box (Old Main)

WO	Recieved	Finished	Total	Request
FO-245155	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245156	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245157	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245158	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245159	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245160	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245161	4/17/2013	4/12/2013		PM - Fan Motor Box (Old Main)
FO-245168	4/17/2013	4/23/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245169	4/17/2013	4/25/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245170	4/17/2013	4/23/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-248121	4/17/2013	4/27/2013		PM for ahu 1A.
FO-248122	4/17/2013	4/26/2013		PM for ahu 2.
FO-248123	4/17/2013	4/26/2013		PM for ahu 3.
FO-248124	4/17/2013	4/27/2013		PM for ahu 4.
FO-245124	4/18/2013			PM - Air Handling Unit
FO-245125	4/18/2013			PM - Air Handling Unit
FO-245126	4/18/2013			PM - Air Handling Unit
FO-245127	4/18/2013			PM - Air Handling Unit
FO-245128	4/18/2013			PM - Air Handling Unit
FO-245129	4/18/2013			PM - Air Handling Unit
FO-245137	4/18/2013			PM - Fan Coil/HV/AC Unit
FO-245138	4/18/2013			PM - Fan Coil/HV/AC Unit
FO-245139	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245180	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245136	4/19/2013	4/25/2013		PM - Air Handling Unit
FO-245162	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245163	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245164	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245165	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245166	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245167	4/19/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245860	4/20/2013	4/20/2013		PM - Unit/Space Heater
FO-245873	4/20/2013	4/25/2013		PM - Air Handling Unit
FO-245875	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245876	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245877	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245878	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245879	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245880	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245881	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245882	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245883	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245884	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245885	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245886	4/22/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-245887	4/22/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-245888	4/22/2013	4/26/2013		PM - Fan Coil/HV/AC Unit



WO	Recieved	Finished	Total	Request
FO-248548	4/22/2013	4/23/2013		Change hepa filters on PEF #5.
FO-245861	4/24/2013	4/20/2013		PM - Air Handling Unit
FO-245862	4/24/2013	4/13/2013		PM - Air Handling Unit
FO-245863	4/24/2013	4/19/2013		PM - Air Handling Unit
FO-245864	4/24/2013	4/20/2013		PM - Air Handling Unit
FO-245865	4/24/2013	4/13/2013		PM - Air Handling Unit
FO-245866	4/24/2013	4/19/2013		PM - Air Handling Unit
FO-245867	4/24/2013	4/13/2013		PM - Air Handling Unit
FO-245868	4/24/2013	4/18/2013		PM - Air Handling Unit
FO-245869	4/24/2013	4/18/2013		PM - Air Handling Unit
FO-245896	4/24/2013	4/25/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245897	4/24/2013	4/26/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245898	4/24/2013	4/25/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245870	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245871	4/25/2013			PM - Air Handling Unit
FO-245872	4/25/2013			PM - Air Handling Unit
FO-245874	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245889	4/25/2013			PM - Air Handling Unit
FO-245890	4/25/2013			PM - Air Handling Unit
FO-245891	4/25/2013			PM - Air Handling Unit
FO-245892	4/25/2013			PM - Air Handling Unit
FO-245893	4/25/2013			PM - Air Handling Unit
FO-245894	4/25/2013	5/1/2013		PM - Air Handling Unit
FO-245895	4/25/2013			PM - Air Handling Unit
FO-245899	4/25/2013			PM - Air Handling Unit
FO-249053	4/26/2013	4/27/2013		Perform PM on ahu 1
FO-246646	4/27/2013			PM - Air Handling Unit
FO-246647	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246648	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246649	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246650	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246651	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246652	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246653	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246654	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246655	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246656	4/29/2013	4/26/2013		PM - Fan Coil/HV/AC Unit
FO-246657	4/29/2013	4/27/2013		PM - Fan Coil/HV/AC Unit
FO-246658	4/29/2013	4/27/2013		PM - Fan Coil/HV/AC Unit
FO-246659	4/29/2013	4/27/2013		PM - Fan Coil/HV/AC Unit
FO-246660	4/29/2013	4/27/2013		PM - Fan Coil/HV/AC Unit
FO-246723	4/29/2013			PM AHU - Belts & Lubrication
FO-246724	4/29/2013			PM AHU - Belts & Lubrication
<b>E - Area 1 Engineer</b>			<b>104</b>	
FO-244804	4/1/2013	4/11/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244805	4/1/2013	4/11/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244806	4/1/2013	4/11/2013		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-244807	4/1/2013	4/11/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244810	4/1/2013			PM - Emergency Shower/Eyewash Station
FO-244811	4/1/2013			PM - Emergency Shower/Eyewash Station
FO-244812	4/1/2013			PM - Emergency Shower/Eyewash Station
FO-244813	4/1/2013			PM - Emergency Shower/Eyewash Station
FO-244814	4/1/2013			PM - Emergency Shower/Eyewash Station
FO-244825	4/1/2013			PM - Water/Air Cooled Condenser
FO-244826	4/1/2013			PM - Water/Air Cooled Condenser
FO-244835	4/1/2013	4/10/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244836	4/1/2013	4/10/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244837	4/1/2013	4/10/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244838	4/1/2013	4/10/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244839	4/1/2013	4/18/2013		PM - Centrifugal Pump, over 1 H.P.
FO-245567	4/2/2013			PM INSPECT AND CLEAN COIL
FO-245568	4/2/2013			PM INSPECT AND CLEAN COIL
FO-245569	4/2/2013			PM INSPECT AND CLEAN COIL
FO-245541	4/4/2013			PM - Sump Pump
FO-245542	4/4/2013			PM - Sump Pump
FO-245558	4/4/2013	4/7/2013		PM - Water Softener
FO-245559	4/5/2013			PM - Heat Exchanger and Economizer
FO-245564	4/5/2013			Generator Maintenance, Monthly
FO-247001	4/5/2013			PM - Punch Tubes - Chiller/Absorber
FO-245543	4/8/2013			PM - Emergency Shower/Eyewash Station
FO-245544	4/8/2013			PM - Emergency Shower/Eyewash Station
FO-245545	4/8/2013			PM - Emergency Shower/Eyewash Station
FO-245546	4/8/2013			PM - Emergency Shower/Eyewash Station
FO-245547	4/8/2013			PM - Emergency Shower/Eyewash Station
FO-245560	4/8/2013	4/16/2013		Monthly AHU Inspection Clean Room Unit 2
FO-245561	4/8/2013			PM - Annual Inspection of Air Handling Unit
FO-245562	4/8/2013	4/16/2013		PM - Monthly AHU Inspection Clean Room Unit 1
FO-246309	4/11/2013			Generator Maintenance, Monthly
FO-246311	4/11/2013	4/11/2013		Generator Maintenance, Monthly
FO-246318	4/11/2013	4/11/2013		Generator Maintenance, Monthly
FO-246314	4/12/2013			Generator Maintenance, Monthly
FO-246316	4/12/2013			Generator Maintenance, Monthly
FO-246289	4/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246290	4/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246291	4/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246292	4/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246293	4/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246329	4/13/2013			PM - Punch Tubes - Chiller/Absorber
FO-246272	4/15/2013			PM - Emergency Shower/Eyewash Station
FO-246273	4/15/2013			PM - Emergency Shower/Eyewash Station
FO-246274	4/15/2013			PM - Emergency Shower/Eyewash Station
FO-246275	4/15/2013			PM - Emergency Shower/Eyewash Station
FO-246276	4/15/2013			PM - Emergency Shower/Eyewash Station
FO-246277	4/15/2013	4/16/2013		PM - Heat Exchanger and Economizer

WO	Recieved	Finished	Total	Request
FO-246278	4/15/2013	4/17/2013		PM - Heat Exchanger and Economizer
FO-246279	4/15/2013	4/17/2013		PM - Heat Exchanger and Economizer
FO-246294	4/15/2013			PM - Water/Air Cooled Condenser
FO-246295	4/15/2013			PM - Clean MEB AC unit Condenser
FO-246296	4/15/2013			PM - Clean MEB AC unit Condenser
FO-246297	4/15/2013			PM - Water/Air Cooled Condenser
FO-246298	4/15/2013			PM - Water/Air Cooled Condenser
FO-246299	4/15/2013			PM - Water/Air Cooled Condenser
FO-246300	4/15/2013			PM - Water/Air Cooled Condenser
FO-246301	4/15/2013			PM - Water/Air Cooled Condenser
FO-246302	4/15/2013			PM - Water/Air Cooled Condenser
FO-246303	4/15/2013			PM - Water/Air Cooled Condenser
FO-246304	4/15/2013			PM - Water/Air Cooled Condenser
FO-246305	4/15/2013			PM - Water/Air Cooled Condenser
FO-246306	4/15/2013			PM - Water/Air Cooled Condenser
FO-246307	4/15/2013			PM - Clean MEB AC unit Condenser
FO-246308	4/15/2013			PM - Clean MEB AC unit Condenser
FO-246319	4/15/2013	4/17/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246320	4/15/2013	4/18/2013		PM - Chemical Feed/Metering Pump/Controller
FO-246321	4/15/2013	4/18/2013		PM - Chemical Feed/Metering Pump/Controller
FO-246322	4/15/2013	4/18/2013		PM - Chemical Feed/Metering Pump/Controller
FO-246323	4/15/2013	4/18/2013		PM - Chemical Feed/Metering Pump/Controller
FO-246324	4/15/2013	4/19/2013		PM - Water Booster Pump
FO-246325	4/15/2013	4/19/2013		PM - Water Booster Pump
FO-246326	4/15/2013	4/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246327	4/15/2013	4/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246328	4/15/2013	4/22/2013		PM - Harmsco Side Stream Filter
FO-246530	4/16/2013	4/16/2013		Generator Maintenance, Monthly
FO-246551	4/16/2013			Generator Maintenance, Monthly
FO-246553	4/16/2013			Generator Maintenance, Monthly
FO-246562	4/16/2013			Generator Maintenance, Monthly
FO-246532	4/17/2013	4/17/2013		Generator Maintenance, Monthly
FO-247076	4/18/2013			PM - Domestic Water Heater, Steam
FO-247077	4/18/2013			PM - Domestic Water Heater, Steam
FO-247095	4/20/2013			PM - Water Softener
FO-247078	4/21/2013			PM - Domestic Water Heater, Steam
FO-247079	4/21/2013			PM - Domestic Water Heater, Steam
FO-247096	4/21/2013			PM - Domestic Water Heater, Steam
FO-247080	4/22/2013			PM - Emergency Shower/Eyewash Station
FO-247081	4/22/2013			PM - Emergency Shower/Eyewash Station
FO-247082	4/22/2013			PM - Emergency Shower/Eyewash Station
FO-247083	4/22/2013			PM - Emergency Shower/Eyewash Station
FO-247084	4/22/2013			PM - Emergency Shower/Eyewash Station
FO-247799	4/25/2013			PM - Condensate Return Pump
FO-247800	4/25/2013			PM - Condensate Return Pump
FO-247801	4/25/2013			PM - Condensate Return Pump
FO-246537	4/26/2013			Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-246539	4/26/2013			Generator Maintenance, Monthly
FO-247794	4/29/2013			PM - Emergency Shower/Eyewash Station
FO-247795	4/29/2013			PM - Emergency Shower/Eyewash Station
FO-247796	4/29/2013			PM - Emergency Shower/Eyewash Station
FO-247797	4/29/2013			PM - Emergency Shower/Eyewash Station
FO-247798	4/29/2013			PM - Emergency Shower/Eyewash Station
FO-247809	4/29/2013			Inspection of Air Handling Unit
<b>E - Area 2 Engineer</b>			<b>235</b>	
FO-244848	4/1/2013			PM - Water/Air Cooled Condenser
FO-244849	4/1/2013			PM - Water/Air Cooled Condenser
FO-244850	4/1/2013	4/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244851	4/1/2013	4/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244852	4/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-244853	4/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-244854	4/1/2013	4/24/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244855	4/1/2013	4/19/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244856	4/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-244857	4/1/2013	4/9/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244858	4/1/2013	4/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244859	4/1/2013	4/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244860	4/1/2013	4/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244861	4/1/2013	4/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244862	4/1/2013	4/19/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244863	4/1/2013	4/19/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244870	4/1/2013	4/22/2013		PM - Water/Air Cooled Condenser
FO-244871	4/1/2013	4/22/2013		PM - Water/Air Cooled Condenser
FO-244872	4/1/2013	4/22/2013		PM - Water/Air Cooled Condenser
FO-244873	4/1/2013	4/22/2013		PM - Water/Air Cooled Condenser
FO-244874	4/1/2013	4/22/2013		PM - Water/Air Cooled Condenser
FO-244875	4/1/2013			PM - Water/Air Cooled Condenser
FO-244876	4/1/2013	3/25/2013		PM - Water/Air Cooled Condenser
FO-244877	4/1/2013	3/25/2013		PM - Water/Air Cooled Condenser
FO-244878	4/1/2013			PM - Water/Air Cooled Condenser
FO-244879	4/1/2013			PM - Water/Air Cooled Condenser
FO-244880	4/1/2013			PM - Water/Air Cooled Condenser
FO-244881	4/1/2013			PM - Water/Air Cooled Condenser
FO-244882	4/1/2013			PM - Water/Air Cooled Condenser
FO-244883	4/1/2013			PM - Water/Air Cooled Condenser
FO-244884	4/1/2013			PM - Water/Air Cooled Condenser
FO-244885	4/1/2013			PM - Water/Air Cooled Condenser
FO-244886	4/1/2013	4/11/2013		PM - Cooling Tower Start-up
FO-245590	4/2/2013			PM - Cooling Tower, 500 - 1000 Tons
FO-245591	4/2/2013			PM - Cooling Tower, 500 - 1000 Tons
FO-245592	4/2/2013			PM - Cooling Tower, 500 - 1000 Tons
FO-245593	4/2/2013			PM - Cooling Tower, 500 - 1000 Tons
FO-245603	4/2/2013			PM - Heat Exchanger and Economizer
FO-245604	4/2/2013			PM - Heat Exchanger and Economizer

WO	Recieved	Finished	Total	Request
FO-245605	4/2/2013			PM - Heat Exchanger and Economizer
FO-245606	4/2/2013			PM - Heat Exchanger and Economizer
FO-245607	4/2/2013			PM - Heat Exchanger and Economizer
FO-245579	4/3/2013	4/4/2013		PM - Heat Pumps (5057 Woodward)
FO-245580	4/3/2013	4/4/2013		PM - Heat Pumps (5057 Woodward)
FO-245581	4/3/2013	4/4/2013		PM - Heat Pumps (5057 Woodward)
FO-245582	4/3/2013	4/4/2013		PM - Heat Pumps (5057 Woodward)
FO-245583	4/3/2013	4/5/2013		PM - Heat Pumps (5057 Woodward)
FO-245584	4/3/2013	4/5/2013		PM - Heat Pumps (5057 Woodward)
FO-245585	4/3/2013	4/5/2013		PM - Heat Pumps (5057 Woodward)
FO-245586	4/3/2013	4/5/2013		PM - Heat Pumps (5057 Woodward)
FO-245587	4/3/2013	4/8/2013		PM - Heat Pumps (5057 Woodward)
FO-245588	4/3/2013	4/8/2013		PM - Heat Pumps (5057 Woodward)
FO-245589	4/3/2013	4/8/2013		PM - Heat Pumps (5057 Woodward)
FO-245595	4/3/2013			PM - Forced Air Furnace (Jacob House) - Summer
FO-245596	4/3/2013			PM - Forced Air Furnace (Jacob House) - Summer
FO-245597	4/3/2013			PM - Forced Air Furnace (Jacob House) - Summer
FO-245598	4/3/2013			PM - Domestic Water Heater, Electric
FO-245599	4/3/2013			PM - Domestic Water Heater, Electric
FO-245614	4/3/2013			PM - Domestic Water Heater, Gas
FO-245570	4/4/2013			PM - Unspecified
FO-245571	4/4/2013			PM - Unspecified
FO-245572	4/4/2013	4/25/2013		PM - Chemical Feed/Metering Pump/Controller
FO-245573	4/4/2013	4/25/2013		PM - Chemical Feed/Metering Pump/Controller
FO-245574	4/4/2013	4/25/2013		PM - Chemical Feed/Metering Pump/Controller
FO-245575	4/4/2013	4/25/2013		PM - Chemical Feed/Metering Pump/Controller
FO-245576	4/4/2013	4/8/2013		PM - Fan Coil/HV/AC Unit
FO-245577	4/4/2013	4/8/2013		PM - Fan Coil/HV/AC Unit
FO-245578	4/4/2013	4/22/2013		PM - Fan Coil/HV/AC Unit
FO-245600	4/4/2013			PM - Harmsco Side Stream Filter
FO-245601	4/4/2013			PM - Harmsco Side Stream Filter
FO-245611	4/5/2013			Generator Maintenance, Monthly
FO-246423	4/9/2013	4/15/2013		Generator Maintenance, Monthly
FO-246360	4/10/2013	4/3/2013		PM - Heat Exchanger and Economizer
FO-246361	4/10/2013	4/9/2013		PM - Heat Exchanger and Economizer
FO-246362	4/10/2013	4/2/2013		PM - Heat Pumps (5057 Woodward)
FO-246363	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246364	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246365	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246366	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246367	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246368	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246369	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246370	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246371	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246372	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246373	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-246374	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246375	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246376	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246377	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246378	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246379	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246380	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246381	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246382	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246383	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246384	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246385	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246386	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246387	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246388	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246389	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246390	4/10/2013	4/10/2013		PM - Heat Pumps (5057 Woodward)
FO-246391	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246392	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246393	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246394	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246395	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246396	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246397	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246398	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246399	4/10/2013	4/11/2013		PM - Heat Pumps (5057 Woodward)
FO-246401	4/10/2013	4/18/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246402	4/10/2013	4/29/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246403	4/10/2013	4/22/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246404	4/10/2013	4/18/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246405	4/10/2013	4/29/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246406	4/10/2013	4/22/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246407	4/10/2013	4/29/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246408	4/10/2013	4/22/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246409	4/10/2013	4/22/2013		PM - Chilled Water Coils - Refill (Old Main)
FO-246410	4/10/2013			PM - Domestic Water Heater, Electric
FO-246411	4/10/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246412	4/10/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246331	4/11/2013			PM - Air Handling Unit
FO-246333	4/11/2013			PM - Air Handling Unit
FO-246344	4/11/2013	4/10/2013		PM - Fan Coil/HV/AC Unit
FO-246345	4/11/2013	4/16/2013		PM - Fan Coil/HV/AC Unit
FO-246346	4/11/2013	4/24/2013		PM - Fan Coil/HV/AC Unit
FO-246347	4/11/2013	4/25/2013		PM - Fan Coil/HV/AC Unit
FO-246348	4/11/2013			PM - Sump Pump
FO-246349	4/11/2013			PM - Sump Pump
FO-246350	4/11/2013			PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-246351	4/11/2013			PM - Sump Pump
FO-246352	4/11/2013			PM - Sump Pump
FO-246353	4/11/2013			PM - Sump Pump
FO-246354	4/11/2013			PM - Sump Pump
FO-246355	4/11/2013			PM - Sump Pump
FO-246356	4/11/2013			PM - Sump Pump
FO-246357	4/11/2013			PM - Sump Pump
FO-246358	4/11/2013			PM - Sump Pump
FO-246359	4/11/2013			PM - Sump Pump
FO-246417	4/12/2013			Generator Maintenance, Monthly
FO-246332	4/15/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246334	4/15/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246335	4/15/2013			PM - Centrifugal Pump, over 1 H.P.
FO-246336	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246337	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246338	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246339	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246340	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246341	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246342	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246343	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246400	4/15/2013			PM - Outside/Fresh Air Intake Screens
FO-246413	4/15/2013			PM - Condensate Return Pump
FO-246414	4/15/2013			PM - Condensate Return Pump
FO-246415	4/15/2013			PM - Chemical Feed/Metering Pump/Controller
FO-246418	4/15/2013			PM - Fan Coil/HV/AC Unit
FO-246419	4/15/2013			PM - Fan Coil/HV/AC Unit
FO-246420	4/15/2013			PM - Fan Coil/HV/AC Unit
FO-246421	4/15/2013			PM - Fan Coil/HV/AC Unit
FO-246557	4/16/2013			Generator Maintenance, Monthly
FO-247104	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247105	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247106	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247107	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247108	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247109	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247110	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247111	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247112	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247113	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-247114	4/17/2013			PM - Heat Pumps (5057 Woodward)
FO-246561	4/18/2013			Generator Maintenance, Monthly
FO-247097	4/18/2013			PM - Condensate Return Pump
FO-247098	4/18/2013			PM - Condensate Return Pump
FO-247099	4/18/2013			PM - Air Handling Unit
FO-247100	4/18/2013			PM - Unspecified
FO-247101	4/18/2013			PM - Unspecified

WO	Recieved	Finished	Total	Request
FO-247102	4/18/2013			PM - Fan Coil/HV/AC Unit
FO-247103	4/18/2013			PM - Fan Coil/HV/AC Unit
FO-247115	4/22/2013			PM - Domestic Water Heater, Gas
FO-247812	4/23/2013			PM - Heat Exchanger and Economizer
FO-247813	4/23/2013			PM - Heat Exchanger and Economizer
FO-247855	4/23/2013			PM - Domestic Water Heater, Electric
FO-247856	4/23/2013			Gas Fired Furnace
FO-247857	4/23/2013			PM - Humidifier
FO-247859	4/23/2013			Gas Fired Furnace
FO-247860	4/23/2013			Gas Fired Furnace
FO-247861	4/23/2013			Gas Fired Furnace
FO-246534	4/24/2013			Generator Maintenance, Monthly
FO-246555	4/24/2013			Generator Maintenance, Monthly
FO-247817	4/24/2013			PM - Air Handling Unit
FO-247818	4/24/2013			PM - Air Handling Unit
FO-247819	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247820	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247821	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247822	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247823	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247824	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247825	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247826	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247827	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247828	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247829	4/24/2013			PM - Heat Pumps (5057 Woodward)
FO-247832	4/24/2013	4/26/2013		PM - Domestic Water Heater, Gas
FO-247833	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247834	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247835	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247836	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247837	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247838	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247839	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247840	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247841	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247842	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247843	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247844	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247845	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247846	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247847	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247848	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247849	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247850	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-247851	4/24/2013	4/29/2013		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-247852	4/24/2013	4/29/2013		PM - Steam Valves to PreHeat Coils - Close (Old Main)



WO	Recieved	Finished	Total	Request
FO-247853	4/24/2013	4/29/2013		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-247854	4/24/2013	4/29/2013		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-247810	4/25/2013			PM - Sump Pump
FO-247811	4/25/2013			PM - Sump Pump
FO-247814	4/25/2013			PM - Fan Coil/HV/AC Unit
FO-247815	4/25/2013			PM - Fan Coil/HV/AC Unit
FO-247816	4/25/2013			PM - Fan Coil/HV/AC Unit
FO-247858	4/27/2013			PM - Centrifugal Pump, over 1 H.P.
<b>E - Area 3 Auxiliary Eng</b>			<b>39</b>	
FO-243958	4/1/2013	4/16/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-243959	4/1/2013	4/23/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244840	4/1/2013		4/29/2013	PM - Monthly Fire Alarm/Fire Protection System Test
FO-244890	4/1/2013	4/19/2013		PM - Air Handling Unit
FO-244891	4/1/2013	4/18/2013		PM - Air Handling Unit
FO-244892	4/1/2013	4/18/2013		PM - Air Handling Unit
FO-244893	4/1/2013	4/17/2013		PM - Air Handling Unit
FO-244894	4/1/2013	4/17/2013		PM - Air Handling Unit
FO-244895	4/1/2013	4/11/2013		PM - Cooling Tower, 500 - 1000 Tons
FO-244896	4/1/2013	4/11/2013		PM - Cooling Tower, 500 - 1000 Tons
FO-244897	4/1/2013	4/23/2013		PM - Cooling Tower, 500 - 1000 Tons
FO-244898	4/1/2013	4/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244899	4/1/2013	4/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244900	4/1/2013	4/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-244901	4/1/2013	4/2/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-244902	4/1/2013	4/26/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-245612	4/2/2013	4/15/2013		PM - Air Handling Unit
FO-245613	4/2/2013	4/15/2013		PM - Air Handling Unit
FO-246425	4/9/2013	4/9/2013		Generator Maintenance, Monthly
FO-246427	4/10/2013	4/10/2013		Generator Maintenance, Monthly
FO-246428	4/13/2013	4/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246429	4/13/2013	4/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246430	4/13/2013	4/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-246559	4/17/2013	4/17/2013		Generator Maintenance, Monthly
FO-246541	4/23/2013	4/23/2013		Generator Maintenance, Monthly
FO-246543	4/23/2013	4/23/2013		Generator Maintenance, Monthly
FO-246545	4/23/2013	4/23/2013		Generator Maintenance, Monthly
FO-246547	4/23/2013	4/23/2013		Generator Maintenance, Monthly
FO-246549	4/23/2013	4/23/2013		Generator Maintenance, Monthly
FO-247864	4/24/2013			PM - Roof Sumps - Zone 2, Area 3
FO-243007	4/29/2013			PM Replace Exhaust Air Filters
FO-243552	4/29/2013			PM Replace Exhaust Air Filters
FO-243553	4/29/2013			PM Replace Exhaust Air Filters
FO-243554	4/29/2013			PM Replace Exhaust Air Filters
FO-243557	4/29/2013			PM Replace Exhaust Air Filters
FO-243558	4/29/2013			PM Replace Exhaust Air Filters
FO-247862	4/29/2013			PM - Air Handling Unit
FO-247863	4/29/2013			PM - Air Handling Unit

WO	Recieved	Finished	Total	Request
FO-247865	4/29/2013			PM - Air Handling Unit
<b>E - Controls Engineer</b>			<b>8</b>	
FO-245566	4/2/2013			Boiler - Open Clean and Close 78 inch Boilers
FO-245608	4/2/2013			Boiler - Open Clean and Close 48 inch Boilers
FO-245609	4/2/2013			Boiler - Open Clean and Close 60 inch Boilers
FO-245610	4/2/2013			Boiler Rear Refractory Inspection - 60 " Boiler
FO-245594	4/5/2013	4/10/2013		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-247830	4/26/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-247831	4/26/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-247866	4/26/2013			Boiler - Open Clean and Close 78 inch Boilers
<b>E - Director</b>			<b>1</b>	
FO-247116	4/16/2013			Vendor or Contractor Work
<b>E - Midnight Engineer</b>			<b>36</b>	
FO-245548	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245549	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245550	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245551	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245552	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245553	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245554	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245555	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245556	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-245557	4/4/2013	4/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246280	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246281	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246282	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246283	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246284	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246285	4/11/2013	4/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246286	4/11/2013	4/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246287	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-246288	4/11/2013	4/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247085	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247086	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247087	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247088	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247089	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247090	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247091	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247092	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247093	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247094	4/18/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247802	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247803	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247804	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247805	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247806	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-247807	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-247808	4/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
<b>E - Midnight Swing Shift</b>			<b>1</b>	
FO-244841	4/1/2013	4/27/2013		PM - Monthly Fire Alarm/Fire Protection System Test
<b>Grounds</b>			<b>4</b>	
<b>Medium</b>			<b>2</b>	
<b>G - Moving/Storage</b>			<b>2</b>	
FO-246622	4/8/2013	4/9/2013	4/9/2013	Grounds - Roll Infield & Outfield
FO-246624	4/8/2013	4/8/2013	4/8/2013	Grounds - Roll Infield & Outfield
<b>Routine</b>			<b>2</b>	
<b>G - Moving/Storage</b>			<b>2</b>	
FO-246625	4/22/2013			Grounds - Roll Infield & Outfield
FO-246626	4/22/2013			Grounds - Roll Infield & Outfield
<b>Trades</b>			<b>29</b>	
<b>Routine</b>			<b>29</b>	
<b>T - Electrician</b>			<b>28</b>	
FO-245563	4/5/2013	4/5/2013		Generator Test Finished 4/8/13 LT
FO-245602	4/5/2013	4/5/2013		Generator Test Finished 4/8/13 LT
FO-246424	4/9/2013	4/9/2013		Generator Test Finished 4/11/13 LT
FO-246426	4/10/2013	4/10/2013		Generator Test Finished 4/11/13 LT
FO-246310	4/11/2013	4/4/2013		Generator Test Finished 4/5/13LT
FO-246312	4/11/2013	4/4/2013		Generator Test Finished 4/5/13LT
FO-246317	4/11/2013	4/11/2013		Generator Test Finished 4/12/13LT
FO-246313	4/12/2013	4/12/2013		Generator Test Finished 4/15/13LT
FO-246315	4/12/2013	4/12/2013		Generator Test Finished 4/15/13LT
FO-246416	4/12/2013	4/12/2013		Generator Test Finished 4/15/13LT
FO-246422	4/12/2013	4/2/2013		Generator Test Finished 4/3/13 LT
FO-246529	4/16/2013	4/16/2013		Generator Test Finished 4/16/13LT
FO-246531	4/16/2013	4/16/2013		Generator Test Finished 4/16/13LT
FO-246550	4/16/2013	4/16/2013		Generator Test Finished 4/16/13LT
FO-246552	4/16/2013	4/16/2013		Generator Test Finished 4/16/13LT
FO-246556	4/16/2013	4/16/2013		Generator Test Finished 4/16/13LT
FO-246533	4/17/2013	4/17/2013		Generator Test Finished 4/18/2013
FO-246558	4/17/2013	4/17/2013		Generator Test Finished 4/18/2013
FO-246560	4/18/2013	4/18/2013		Generator Test Finished 4/19/2013LT
FO-246540	4/23/2013	4/23/2013		Generator Test Finished 4/24/13LT
FO-246542	4/23/2013	4/23/2013		Generator Test Finished 4/24/13LT
FO-246544	4/23/2013	4/23/2013		Generator Test Finished 4/24/13LT
FO-246546	4/23/2013	4/23/2013		Generator Test Finished 4/24/13LT
FO-246548	4/23/2013	4/23/2013		Generator Test Finished 4/24/13LT
FO-246535	4/24/2013			Generator Test
FO-246554	4/24/2013	4/24/2013		Generator Test Finished 4/25/13 LT
FO-246536	4/26/2013	4/19/2013		Generator Test Finished 4/19/2013LT
FO-246538	4/26/2013	4/19/2013		Generator Test Finished 4/19/2013LT
<b>T - Roofing</b>			<b>1</b>	
FO-246330	4/1/2013	4/11/2013		Check Roof-Chemistry North Substation (Flat-Roof). CLEANED OFF ROOF, REPLACED CH

---

**Total: 2661**