

Facilities Operations Work Orders Received 12/01/2013 through 12/31/2013

WO	Received	Finished	Total	Request
Maint. Work Order (MWRf)			1704	
Custodial			166	
Emergency			3	
C-Repair			3	
FO-269080	12/5/2013	12/6/2013		Repair broken soap dispenser- Men's Restroom 1st floor. Also refill all 3 hand sanitizing units.
FO-271174	12/20/2013	12/20/2013		THEY SIDE THE VACUUM CLEANER NEED TO BE REPAIR NOT WORKING.
FO-271179	12/20/2013	12/20/2013		VACUUM CLEANER NEED SERVICE REPAIRS.
Medium			6	
C-Director			1	
FO-269000	12/4/2013	12/9/2013	12/9/2013	custodial to provide support for Noel night (December 7, 2013). The following buildings: Com
C-Repair			2	
FO-268785	12/3/2013	12/17/2013		The Advance auto scrubber needs a new squeegee.
FO-269012	12/4/2013	12/4/2013		VACUUM CLEANER (sanitaire) NEED SERVICE REPAIRS ON POWER CORD HANDLE AR
C-Sector 02			2	
FO-270883	12/9/2013	12/13/2013		Gross Lab scrub floor room 330, 340
FO-269658	12/11/2013	12/11/2013		Scrub gross lab s floors room 310 an 320
C-Sector 05			1	
FO-270140	12/16/2013			Office 281, carpet needs to be vacuumed.
Low			149	
C-Director			4	
FO-268711	12/2/2013			Clean and wax the hallway floors on 2nd, 6th and 7th floors of Student Center. Charge to acco
FO-269346	12/9/2013			Custodial Overtime for 12/14/2013, Graduation day. There will be 3 ceremonies: 10am, 2pm,
FO-271055	12/18/2013			I would like the following work done in office 6409.5:
FO-271121	12/19/2013			Custodial to seal and wax first floor of Shaver Music Bldg. including rooms 110, 112, 114.
C-Lighting			64	
FO-268656	12/2/2013	12/3/2013		Hallway near 237: burned out lightbulb, please replace.
FO-268672	12/2/2013	12/3/2013		R/R 1ST FLR Handicap unisex bathroom in area nearest to Student Disabilities Office, Room
FO-268671	12/2/2013	12/3/2013		R/R 1ST FLR Recessed ceiling light outside Ladies Rest Room behind the Circulation Desk,
FO-268692	12/2/2013	12/3/2013		CANDLE OPERA LIGHTS ARE OUT. 1ST FLOOR LOBBY.
FO-268798	12/3/2013	12/4/2013		LIGHT IS FLICKERING. ROOM 4200. SEE JOAN.
FO-268807	12/3/2013	12/3/2013		Light burnt out inside 5300, needs replacement.
FO-269016	12/4/2013	12/4/2013		Several ceiling light fixtures do not work and
FO-269026	12/4/2013	12/6/2013		The lamps are out at the doorway that leads from Science Hall into the Chemistry tunnel. It is
FO-269065	12/4/2013	12/5/2013		3 light bulbs out in room# 2014
FO-269068	12/4/2013	12/5/2013		4 lights out in room# 2112
FO-269069	12/4/2013	12/5/2013		light out in room 2085
FO-269070	12/4/2013	12/4/2013		lights to be adjusted in the Museum of Anthropology, room# 1227.
FO-269133	12/5/2013	12/5/2013		light bulb out in the ladies restroom, nest to janitors closet, 4th floor - 2 panels (4 light bulbs)
FO-269134	12/5/2013	12/5/2013		Lights are going on and off in room# 3161
FO-269146	12/5/2013	12/6/2013		Room 3126 has a light out that needs replacing. Thank you.
FO-269220	12/6/2013	12/6/2013		Hilberry theatre box office, 6 lights are out. Request for electrician has been made concerning
FO-269222	12/6/2013	12/10/2013		Development Office - Room 1151 has a florescent light that is out and needs to be replaced.
FO-269334	12/9/2013	12/10/2013		1 light flickering in room# 25.
FO-269339	12/9/2013	12/10/2013		1 light bulb out in room 147. The bulbs have been replaced no problems.
FO-269411	12/10/2013	12/10/2013		couple of lights out in room 100. The bulbs have been replaced no problems.
FO-269456	12/10/2013	12/13/2013		Men's restroom: burned out lightbulb above urinals. Please replace.

WO	Recieved	Finished	Total	Request
FO-269500	12/10/2013	12/10/2013		Light bulb replacements needed at the landing between the 3rd and 4th floors in the NW stair
FO-269582	12/11/2013	12/13/2013		LIGHTS OUT. STORAGE ROOM. ROOM 1154.
FO-269598	12/11/2013	12/12/2013		2 lights out in room #403. Job Done.No problems.
FO-269604	12/11/2013	12/13/2013		Please replace the burned out 220v halogen wall mounted work light in the southeast corner o
FO-269608	12/11/2013	12/16/2013		Please replace burned out light bulbs in the ceiling fixtures underneath the balcony, bulbs in th
FO-269638	12/11/2013	12/11/2013		In room #3315 Need 10 bulbs from overhead lights removed, and 1 flickering bulb to be replac
FO-269669	12/11/2013	12/11/2013		rm 4154 3 lites out
FO-269673	12/11/2013	12/20/2013		rm 335 3 out of 4 lites out
FO-269684	12/11/2013	12/13/2013		Light out in rm.# 9108
FO-269742	12/12/2013	12/12/2013		Purdy Library 3rd Floor
FO-269778	12/12/2013	12/13/2013		Room 2620 lights are out.
FO-269781	12/12/2013	12/14/2013		Lights are out in room 2601.
FO-269782	12/12/2013	12/12/2013		Track light at the entrance to room 2620 is out.
FO-269799	12/12/2013	12/13/2013		Hallway outside room 145: burned out lightbulb. Please replace.
FO-269803	12/12/2013	12/16/2013		Hallway outside 306: burned out spotlight on side of wall pointing at bridge. Please replace.
FO-269811	12/12/2013	12/13/2013		rm 460 2 out go to 585 and get key
FO-269835	12/12/2013	12/20/2013		Room 3135 (Professor Leyi Wang) needs a light bulb replaced in the room. Thank you.
FO-269909	12/13/2013	12/24/2013		LIGHT COVER HAS FALLEN OFF. ROOM 133.
FO-269947	12/13/2013			Please repalce burned out lights in lab 2217.
FO-269948	12/13/2013			Please repalce burned out lights in lab 2222.
FO-269955	12/13/2013			Please repalce burned out lights in the East passenger elevator.
FO-270073	12/16/2013	12/23/2013		Light crew: please replace burned out light bulbs in west vestibule and the stairways, priority: l
FO-270093	12/16/2013	12/17/2013		Room 4144 has lights out.
FO-270132	12/16/2013	12/19/2013		All the lights are out in the room. This room requires 8 ft. florescent tubes.
FO-270141	12/16/2013	12/18/2013		Light bulb replacements needed in offices 477 and 479. Thanks!
FO-270882	12/17/2013	12/23/2013		Womensrest room 006 light are out and need replacing.
FO-270925	12/17/2013	12/17/2013		2nd floor lounge off the basketball courts.
FO-270959	12/17/2013	12/18/2013		Flickering and burned out bulbs as follows: 385 (JLC) - 2-3 bulbs; 385 store room - 2 bulbs ou
FO-270984	12/18/2013	12/18/2013		rm 451/dlar Broken light cover. also lights need plastic sleeve put on until cover is fixed
FO-271010	12/18/2013	12/23/2013		Relamp fixture in room 297.
FO-271005	12/18/2013			2 big lights out in room #256
FO-271024	12/18/2013	12/18/2013		Room 2625 has lights that are out.
FO-271032	12/18/2013	12/19/2013		Overhead lights are out above main Receiving
FO-271084	12/19/2013	12/24/2013		Hallway outside 212.10: burned out lightbulb, please replace.
FO-271085	12/19/2013	12/24/2013		Broken light cover. Plastic sleeve must be put on for protection until light cover is fixed.
FO-271094	12/19/2013	12/19/2013		lights out in 4148 President's office
FO-271117	12/19/2013	12/23/2013		Real room number is 006 - Women's Restroom. The lights are out in here and can barely see.
FO-271134	12/20/2013	12/24/2013		Several lights out in corridor on 3rd floor. Bulbs near Public elevators and the back west corrid
FO-271163	12/20/2013			several lights are out in the class room #421.
FO-271196	12/20/2013	12/23/2013		Lights Out. Request for electrician has been made. Two electrical problems found.One in rm 1
FO-271358	12/20/2013			Please replace burned out lights (second request)
FO-271359	12/20/2013			Please replace burned out lights (second request)
FO-271228	12/23/2013	12/24/2013		Need repair or replacement of recessed ceiling light outside Ladies Room, 2234.
C-Materials			16	
FO-269031	12/4/2013	12/6/2013		would like to borrow the stock room carpet extractor for Bonstelle Theater on Thursday mornin
FO-269071	12/4/2013	12/5/2013		in room 259, 2 empty recycle bins need to be dropped off
FO-269072	12/4/2013	12/6/2013		large recycle bin to be picked up in room 4100

WO	Recieved	Finished	Total	Request
FO-269135	12/5/2013	12/5/2013		request for 2 Grey recycle bin's pickup at Law library, room# 3361
FO-269199	12/6/2013	12/6/2013		Recycle bin Pickup from the Printer room next to room# 707, 7th floor
FO-269341	12/9/2013	12/9/2013		recycle bin pick up and exchange grey bin, 1st floor near mail closet
FO-269436	12/10/2013	12/23/2013		Gondola and recycle bin for pick up near room 3361
FO-269602	12/11/2013	12/11/2013		1 recycle bin to 3rd floor of 5050 Anthony Wayne Drive
FO-269753	12/12/2013	12/23/2013		Recycle bin pick up and drop off room #2100
FO-270001	12/14/2013	12/14/2013		Sector 9 request the Purchase of (1) convertible hand truck,(3)18in microfiber finishing pads,
FO-271057	12/18/2013	12/20/2013		2 large recycle bins need to be picked up near room 4602
FO-271111	12/19/2013	12/20/2013		recycle bin pick-up in 2100 Engineering
FO-271158	12/20/2013			Request 3 cases of white rags for Closure.
FO-271180	12/20/2013			Closure: Items to be delivered by E. Hill on 12/24/13
FO-271205	12/23/2013			EQUIPMENT TRANSFER:
FO-271357	12/24/2013			Transfer new Equipment to Sector 5 to the Physics Building:
C-Projects			6	
FO-268707	12/2/2013			Old Main- Clean computer lab carpet and the carpet in the Recital Hall Green Room (0428). B
FO-269291	12/9/2013			I need to have my office rug vacuumed and shampooed over Break. Old Main 3129. I will ne
FO-269735	12/12/2013			Please sweep and wax the floor. If it's possible,
FO-270065	12/16/2013			Carpeting for several feet around radiator is saturated and has been since Friday. Carpeting n
FO-271062	12/18/2013			Please have custodians strip and wax floor in
FO-271083	12/19/2013			Strip, scrub and wax floor.
C-Repair			22	
FO-268781	12/3/2013	12/6/2013		Staff mens restroom on the first floor(Located near rear parking garage inside building), needs
FO-268782	12/3/2013	12/9/2013		First floor student center, Mens restroom paper towel dispenser broken (facing the urinal side
FO-268855	12/3/2013	12/17/2013		In the office/lab room 121 a soap dispenser is needed to be placed near the sink.
FO-269017	12/4/2013	12/9/2013		WOMEN'S RESTROOM IN BASEMENT ON THE NORTHEAST SIDE OF THE HANDICAP R
FO-269100	12/5/2013	12/9/2013		A REQUEST FOR SERVICE REPAIRS ON A BROKEN VACUUM CLEANER(SANITAIRE)alp
FO-269128	12/5/2013	12/20/2013		NOBLES SWEEPER MODEL #614213, SERIAL #16757-80000 THE BRUSHES STOPPED T
FO-269184	12/6/2013	12/17/2013		3rd floor men's restroom paper towel dispenser off wall needs new 1.Restroom by the frieght e
FO-269248	12/7/2013	12/17/2013		MEN'S ROOM #1346 1- SOAP DISPENSER BROKEN AND 4 TOILET PAPER DISPENSERS
FO-269252	12/7/2013	12/12/2013		2ND FLOOR LAB WING MEN'S ROOM. PAPER TOWEL DISPENSER DOESN'T WORK.
FO-269254	12/7/2013	12/17/2013		3RD FLOOR MEN'S ROOM LAB WING SIDE. PAPER TOWEL DISPENSER NOT WORKING
FO-269255	12/7/2013	12/17/2013		3RD FLOOR LADIES ROOM LAB WING SIDE. PAPER TOWEL DISPENSER NOT WORKIN
FO-269319	12/9/2013	12/18/2013		Affix name plate on Supervisor office door/room 207 state hall
FO-269385	12/9/2013	12/17/2013		The vacuum for the Reuther Library is not picking up. The vacuum is placed in the storage are
FO-269479	12/10/2013	12/20/2013		ADVANCE VACUUM, SERIAL #1615890, NEEDS SCREW IN HANDLE. PLEASE REPAIR.
FO-269532	12/11/2013	12/18/2013		The auto-scrubber for the Education Building has a leaking hose. The vacuum hose is leaking
FO-269814	12/12/2013	12/17/2013		A REQUEST FROM (A.D./S. LLOYD) ONE HAND, SANITIZER DISPENSER STAND TO BE
FO-270056	12/16/2013	12/18/2013		Room #133 unisex bathroom paper towel dispenser is broken
FO-270974	12/18/2013	12/18/2013		The covert-matic is not picking up water needs too check it out.
FO-271101	12/19/2013	12/20/2013		State Hall 1st Floor men's room 109 paper towel dispenser broke/the one next to the urinals
FO-271137	12/20/2013	12/23/2013		ADVANCE VACUUM serial #1693631, needs new cord the cord caught on fire. VACUUM IN 2
FO-271370	12/24/2013	12/24/2013		NEW EQUIPMENT: AND TRANSFER TO (STEVEN JOHNSON), SECTOR #5 (SANITAIRE)
FO-271386	12/24/2013	12/24/2013		NEW EQUIPMENT: AND TRANSFER TO (STEVEN JOHNSON), SECTOR #5 (SANITAIRE)
C-Sector 01			1	
FO-270915	12/17/2013			Please clean, shampoo rug and vacuum 326
C-Sector 02			2	
FO-269410	12/10/2013	12/18/2013		Spill on carpet outside classrooms 301/302. Please spot clean.
FO-271255	12/23/2013	12/23/2013		Scrub and wax floors in lab 5106

WO	Recieved	Finished	Total	Request
C-Sector 03			18	
FO-269293	12/9/2013	12/9/2013		2 cases of Dial Soap
FO-269297	12/9/2013	12/9/2013		2 cases of dial soap
FO-269299	12/9/2013	12/9/2013		2 cases of Dial Soap
FO-269300	12/9/2013	12/9/2013		2 cases of Dial Soap
FO-269301	12/9/2013	12/9/2013		1 case of dial soap
FO-269305	12/9/2013	12/9/2013		1 case of dial soap
FO-269308	12/9/2013	12/9/2013		1 case of dial soap
FO-269312	12/9/2013	12/9/2013		2 cases of dial soap
FO-269315	12/9/2013	12/9/2013		1 case of dial soap
FO-269317	12/9/2013	12/9/2013		1 case of dial soap
FO-269322	12/9/2013	12/9/2013		1 case of dial soap
FO-269323	12/9/2013	12/9/2013		1 case of dial soap
FO-269325	12/9/2013	12/9/2013		1 case of dial soap
FO-269697	12/11/2013	12/17/2013		Kresge Library 1st Floor, room 110
FO-270950	12/17/2013	12/17/2013		2 cases of dial soap
FO-270951	12/17/2013	12/17/2013		2 cases of dial soap
FO-270953	12/17/2013	12/17/2013		2 cases of dial soap
FO-270954	12/17/2013	12/17/2013		2 cases of dial soap
C-Sector 04			4	
FO-269092	12/5/2013			2cases of Dial Soap
FO-269095	12/5/2013			2cases of Dial Soap
FO-269097	12/5/2013			2cases of Dial Soap
FO-271378	12/24/2013			Trash has not been picked up since Monday in Old Main room 1321
C-Sector 05			8	
FO-269640	12/11/2013	12/17/2013		Room 531 carpet needs to be done will take care of this 12/16/13.
FO-269698	12/11/2013	12/17/2013		ALL of 2151 and inside side rooms - floors need washing and waxing. Particular bad area in fr
FO-269734	12/12/2013	12/5/2013		Rooms 456,460 needs to be shower srcub and wax both rooms
FO-269937	12/13/2013			4 cases of dial soap
FO-269938	12/13/2013			3 cases of dial soap
FO-270919	12/17/2013			Please clean, shampoo and vacuum 226
FO-270920	12/17/2013	12/23/2013		Please clean and wax 518 Manoogian. Pick up
FO-271184	12/20/2013			Closure Assignments & Projects: Full clean these Open Buildings: Chemistry, Mott Center, Sc
C-Sector 06			2	
FO-268694	12/2/2013			Music Shaver Floors need to be washed and waxed in rooms 101 and 105 Shaver
FO-270949	12/17/2013			2 cases of dial soap
C-Sector 08			1	
FO-270096	12/16/2013			Clean carpeting in this office and room 307. New employee starting 1/2/14. This is a "just do
C-Sector 09			1	
FO-271124	12/19/2013	12/20/2013		carpet brush scrub & extract entire lobby area carpeting and all entrance mats.
Routine			8	
C-Director			8	
FO-269038	12/4/2013	12/4/2013		FY 2014 FO for Grounds Department.
FO-269040	12/4/2013	11/8/2013		FY 2014 FO for Grounds Department.
FO-269044	12/4/2013	11/13/2013		FY 2014 FO for Grounds Department.
FO-269045	12/4/2013	11/13/2013		FY 2014 FO for Grounds Department.
FO-269046	12/4/2013	11/13/2013		FY 2014 FO for Grounds Department.
FO-269047	12/4/2013	11/13/2013		FY 2014 FO for Grounds Department.

WO	Recieved	Finished	Total	Request
FO-269048	12/4/2013	11/13/2013		FY 2014 FO for Grounds Department.
FO-271049	12/18/2013			pick up 1 recycle bin and drop off 2
Engineering			651	
Emergency			37	
E - Auxiliary			6	
FO-268625	12/2/2013	12/2/2013		FIRE TROUBLE ALARM.
FO-269295	12/9/2013	12/9/2013		FIRE ALARM SNDNG
FO-269622	12/11/2013	12/12/2013		FIRE ALARM.
FO-269789	12/12/2013	12/12/2013		FIRE ALARM.
H-43017	12/17/2013		12/17/2013	replace showerhead in romo 545 Ghafari Hall. showerhead broken off, water all over the place
FO-271003	12/18/2013	12/18/2013		BLDG FAP ACTIVE
E - Command Center			3	
FO-268629	12/2/2013	12/13/2013		Trade; Controls
FO-269190	12/6/2013	12/7/2013		BOILER #3 LOCKED OUT ON STANDBY. SEE RICK MASSA.
FO-269595	12/11/2013	12/13/2013		Boiler running with a high water condition - mechanical room full of steam.
E - MedPharm			2	
FO-269601	12/11/2013	12/11/2013		GAS SMELL ON THE 6TH FLOOR NEAR ELEVATORS.
FO-271168	12/20/2013	12/20/2013		RM 7244/AUTOCLAVE RM HAS A FLOOD COMING FROM SOMEWHERE
E - North			2	
FO-269402	12/10/2013	12/10/2013		GAS SMELL - 1ST FLOOR INCLUDING LOADING DOCK AREA.
FO-269419	12/10/2013	12/10/2013		GAS SMELL - 1ST FLOOR.
E - Northeast			1	
FO-271167	12/20/2013	12/20/2013		RM 057/MECH RM HAS A FLOOD COMING FROM THE MECH RM
E - Preventative Maintenance			13	
FO-268706	12/2/2013	12/2/2013		EMERGENCY EXIT DOOR #089 10W DOOR ALARM SNDNG
FO-268708	12/2/2013	12/3/2013		LIGHT FIXTURE IS HANGING. ROOM 4100.
FO-268710	12/2/2013	12/3/2013		EMERGENCY/CARP LOCKSMITH
FO-269685	12/11/2013	12/11/2013		SMOKY SMELL FROM BASEMENT FLOOR THOUGHTOUT THE BUILDING.
FO-269686	12/11/2013	12/11/2013		BLDG 3RD FLR SMELL SMOKE
FO-269688	12/11/2013	12/12/2013		BLDG SMELL OF SMOKE
FO-269689	12/11/2013	12/11/2013		BLDG SMELL OF SMOKE
FO-269690	12/11/2013	12/12/2013		FIRE TROUBLE ALARM
FO-269691	12/11/2013	12/11/2013		BLDG/5TH FLR SMELL OF SMOKE
FO-269692	12/11/2013	12/12/2013		BLDG SMELL OF SMOKE
FO-269693	12/11/2013	12/11/2013		BLDG SMELL OF SMOKE
FO-269881	12/12/2013	12/12/2013		NO POWER IN WALL OUTLETS. ROOM 318.
FO-269982	12/13/2013	12/14/2013		DWSD SHUT WATER DOWN PLS INVESTIGATE INFORM ROSE OF STATUS
E - South			1	
FO-269276	12/9/2013	12/9/2013		BACK AREA OF BLDG NEAR STUDENT LNG/SHIPPING & RECEIVING STRONG SMELL O
E - West			9	
FO-270944	12/17/2013	12/18/2013		BLDG/POOL? APPR 2:20 THEY HAD A POWER BUMP CK POOL PER RICK
FO-270994	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-270996	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-270997	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-270998	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-270999	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-271000	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58

WO	Recieved	Finished	Total	Request
FO-271001	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
FO-271002	12/18/2013	12/18/2013		PLD POWER BUMP APPR 9:58
High			162	
E - Auxiliary			50	
H-42713	12/2/2013		12/5/2013	Heat is not working!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
H-42715	12/3/2013		12/3/2013	we cannot get the heat to work and it is really cold in here. please come fix it.
FO-268800	12/3/2013	12/3/2013		EMERGENCY EXIT DOOR ALARM.
FO-268846	12/3/2013	12/3/2013		EMERGENCY EXIT DOOR ALARM.
H-42718	12/3/2013		12/4/2013	sink in pot room needs a plumber. Joe tried to unclog it but he was unsuccessful.
H-42739	12/4/2013	12/4/2013	12/5/2013	Shower head in second bathroom needs to be replaced.
H-42740	12/4/2013	12/4/2013	12/5/2013	Hood is broken over the stove.
H-42743	12/4/2013			check and replace seats and washers in kitchen sink faucet.
H-42809	12/5/2013		12/9/2013	The heater is blowing out cold air and will not heat the room.
H-42810	12/5/2013		12/6/2013	Heating unit does not work.
H-42774	12/5/2013	12/6/2013	12/23/2013	Toilet not flushing properly.
H-42777	12/5/2013			Mechanical check
H-42807	12/6/2013			Maintenance replaced bulbs in bathroom light fixture. Still no light. suspect Ballast.
H-42817	12/6/2013		12/10/2013	heat is broken... again, light is broken is 748 A, toilet seat is broken in bathroom.
H-42842	12/9/2013		12/10/2013	it seems as if my heat in my bedroom doesn't heat up my room but it heats up everywhere els
H-42846	12/9/2013		12/10/2013	every time the toilet is flushed, water leaks from the seal of the tank.
H-42866	12/9/2013		12/9/2013	Water leaking from ceiling in lobby.
H-42868	12/9/2013		12/10/2013	water in bathroom sink is a white-ish color. needs to be looked at.
H-42878	12/10/2013		12/11/2013	Heat went out again. Someone came last week to fix it and said that something is wrong with
H-42889	12/10/2013			The garbage disposal is not disposing this is my second request. It was never fixed and now t
H-42875	12/10/2013		12/11/2013	Please fix the HVAC unit
H-42876	12/10/2013	12/10/2013	12/18/2013	Kitchen faucet is leaking, and Tanzil could not get the water shut off.
H-42877	12/10/2013			Garbage disposal is not working-PLEASE RUSH
H-42883	12/11/2013			The heat is not working in our room. Only blows cold hair. Towers Room 411.authenticated u
H-42892	12/11/2013	12/11/2013		Please check the oven - when I turned it on at around 10-something this morning (12/11/13), it
H-42906	12/11/2013			Heating system not working. We have had it on heat at 80 and the temperature has been decr
H-42907	12/12/2013			Toilet Hood is overflowing when she tried flushing the toilet.
H-42909	12/12/2013			Ceiling has been leaking in bedroom, happens numerous times.
FO-269791	12/12/2013	12/12/2013		EMERGENCY DOOR ALARM SOUNDING. (NEAR CLINIC)
H-42912	12/12/2013			Heat is not working very well, apartment is cold.
H-42913	12/12/2013		12/16/2013	Hole in kitchen wall made by engineer last night due to leak. Leak in living room ceiling. Leak
H-42928	12/12/2013			When toilet flushes, water comes out from the top.
H-42917	12/12/2013		12/13/2013	The heating system is not working in the room. I don't know if it's a simple problem with the th
H-42918	12/13/2013		12/13/2013	Walls leaking slightly
H-42930	12/13/2013			Hot water from bathroom sink has a whitish color to it. It has been going on like this for the pa
H-42946	12/13/2013		12/16/2013	No heat and room is occupied. -RUSH
H-42936	12/13/2013		12/17/2013	Plumber needed for leak under dishwasher in towers kitchen.
H-42967	12/15/2013	12/15/2013		Please turn up the heat in my apartment, since it's still cold inside even when the radiator is o
H-42989	12/16/2013		12/16/2013	Hole was made in kitchen ceiling to investigate leak several days ago. There is now a leak in li
H-42992	12/16/2013			The ceiling is leaking in this suite. Joe Hutting took a look and we need a roofer. It's dripping o
H-43000	12/17/2013			The heat is no longer working.
H-43039	12/18/2013	12/18/2013	12/23/2013	Fuse is blown out at WDET
FO-271056	12/18/2013	12/18/2013		BOILER ALARM SNDNG

WO	Recieved	Finished	Total	Request
H-43056	12/19/2013	12/20/2013		Remove old and replace with owner supplied bathroom faucet. supply line needs 1/2" to 3/8" a
H-43105	12/20/2013	12/21/2013		Mechanical check
H-43106	12/20/2013			Maintenance check (RA unit)
H-43135	12/23/2013			Mechanical check
H-43145	12/24/2013	12/26/2013		No hot wateer. JuST RECENTLY WENT OUT AND ONLY HAS COLD WATER
H-43156	12/25/2013			The garbage disposal is not working properly and the sinks are getting clogged.
FO-271468	12/28/2013			Check status of pump and pump proof - Siemens shows it is in alarm when the boiler is runnin
E - Command Center			32	
FO-268607	12/1/2013			controls- Lounge room 125 is over heating badly on the first floor, also over heating the first flo
FO-268608	12/1/2013	12/3/2013		controls-Boiler#2Igniter is not sparking. the boiler is out of service due to this problem.
FO-268812	12/3/2013	12/4/2013		TOO HOT. VAV NOT WORKING. ROOM 1200.
FO-269207	12/6/2013	12/9/2013		Investigate and correct cause of 'wet floor' and 'dirt/mold' on horizon surfaces in cold room 63
FO-269217	12/6/2013	12/9/2013		Conference room 456 that opens into lab 460 is to warm. Box and valve were checked for ob
FO-269269	12/8/2013	12/9/2013		CONTROL CREW: Please repair/replace the pressure controller for the domestic water boost
FO-269409	12/10/2013			REPAIR CONTROLS FOR HEATING - TOO COLD. ROOM 231.2.
FO-269578	12/11/2013	12/17/2013		Trade: Controls/Boilers Priority: High
FO-269833	12/12/2013			Trade: Controls
FO-269898	12/13/2013	12/20/2013		Engineer found MEC boiler #2 tripped on flame failure. Unable to fire boiler. Engineer found s
FO-269968	12/13/2013	12/19/2013		CONTROL ACTUATOR BAD. (LOW HUMIDITY ROOMS 023 THRU 026.22)
FO-270125	12/16/2013	12/17/2013		Replace copper rings on ALWCO. Leaking steam
FO-270035	12/16/2013	12/16/2013		Boiler not running - Shows Float Check Failure
FO-270070	12/16/2013			PLEASE REPAIR STATIC PRESSURE CONTROLS S. EXHAUST FAN'S
FO-270079	12/16/2013			Trade: Controls
FO-270081	12/16/2013	12/20/2013		RED LIGHTS ON HEATERS. (ROOMS 410 AND 427) LOW ON REFRIGERANT.
FO-270106	12/16/2013			control group please troubleshoot controls for high pressure lab pumps #20&21,suspect bad p
FO-270107	12/16/2013	12/17/2013		control group please troubleshoot controls for high pressure lab pumps #20&21,suspect bad p
FO-270112	12/16/2013			control group please troubleshoot control on hi,pres.lab hot water heater.priority high.
FO-270886	12/17/2013	12/17/2013		BOILER #2 WILL NOT START. ROOM 4195.
FO-270916	12/17/2013	12/17/2013		BOILER #1 WILL NOT START.
FO-270975	12/18/2013			Trade: Controls
FO-271080	12/19/2013	12/20/2013		Trade: Controls/Siemens Priority: High
FO-271125	12/20/2013			please check refrigerant level of Cold Rm 6353 AC Unit.
FO-271141	12/20/2013			Trade: Conntrols
FO-271172	12/20/2013			Refrigeration Crew/High Priority
FO-271181	12/20/2013			Refrigeration Crew, High Priority Attn.(Lloyd
FO-271188	12/20/2013			Refrigeration Crew/High Priority
FO-271203	12/22/2013			Repair control air compressor.
FO-271451	12/26/2013			Investigate whole building too hot during closure.
FO-271445	12/26/2013	12/26/2013		Boiler will not start
FO-238308	12/27/2013	12/28/2012		Flue Gas Analysis
E - MedPharm			34	
FO-268611	12/2/2013	12/3/2013		LOW TEMP. ALARM. ROOM 8337.
FO-268650	12/2/2013	12/16/2013		Room 3210: This cold room blows thick dust around. Please contact building engineer. Than
FO-268682	12/2/2013	12/9/2013		RM 2156 PLS INVESTIGATE CLNG IS STILL LEAKING
FO-268683	12/2/2013	12/3/2013		RM 8337 WALK IN COLD RM BOX HAS LOW TEMP ALARM
FO-268690	12/2/2013	12/2/2013		BOILER ALARM. PENTHOUSE MECHANICAL ROOM.
FO-268705	12/2/2013			RM 8337 PLS DOUBLE CK WALK IN COLD RM BOX HAS LOW TEMP ALARM
FO-269051	12/4/2013	12/5/2013		Rms 2125 & 2205 report very high humidity.

WO	Recieved	Finished	Total	Request
FO-269083	12/5/2013	12/5/2013		RM 6130 HIGH TEMP ALARM
FO-269127	12/5/2013	12/5/2013		RM 8337 WALK IN COLD RM BOX LOW TEMP ALARM
FO-269144	12/5/2013	12/5/2013		RAF #3 DISCHARGE HI TEMP ALARM W/RESET
FO-269188	12/6/2013	12/6/2013		LOW TEMP. ALARM. ROOM 8337.
FO-269232	12/6/2013	12/6/2013		RM 6312 HIGH TEMP ALARM
FO-269338	12/9/2013	12/9/2013		RM 5451 HAS HI HUMIDITY (accumulating causing clng to leak)
FO-269405	12/10/2013	12/10/2013		RM 220 HAD A LOW TEMP ALARM W/RESET
FO-269407	12/10/2013	12/13/2013		Rooms 205,216 are positive to the hallway need to be negative . Room 200 is negative it need
FO-269454	12/10/2013	12/11/2013		CONDENSATION ON WINDOW (BY FUME HOOD)AND TOO COLD. ROOM 2105.
FO-269485	12/10/2013	12/11/2013		1ST FLR RMS 1107.4 & 1133 CONDENSATION ON WINDOWS & HUMIDITY IS EXTREMEL
FO-269486	12/10/2013	12/11/2013		2ND FLR RMS 2109, 2205, 2209 CONDENSATION ON WINDOWS & HUMIDITY IS EXTRE
FO-269589	12/11/2013	12/11/2013		LOW HUMIDITY IN ALL 2ND FLOOR ANIMAL ROOMS INCLUDING ROOMS 215, 219, 216
FO-269609	12/11/2013	12/11/2013		LOW HUMIDITY IN ENTIRE 400 SUITE.
FO-269612	12/11/2013	12/11/2013		AIR HANDLER UNIT #3 DISCHARGE HIGH TEMP.
FO-269630	12/11/2013			The temperature is too high. It should be O' degree but, it's 4 or 5 degrees. Need immediate
FO-269970	12/13/2013	12/13/2013		HIGH TEMP ALARM. AIR HANDLER UNIT #3 DISCHARGE.
FO-270037	12/16/2013	12/16/2013		BOILER ALARM. PENTHOUSE MECHANICAL ROOM.
FO-270913	12/17/2013			AHU#3 Discharge ALARM
FO-270982	12/18/2013	12/18/2013		Room pressure negative. Needs to be positive.
FO-270983	12/18/2013			air pressure is negative. Needs to be positve
FO-271073	12/19/2013			AIR PRESSURE IS POSITIVE AND SUPPOSE TO BE NEGATIVE. ROOMS 200.15, 200.13
FO-271077	12/19/2013	12/18/2013		High temp
FO-271107	12/19/2013			HIGH TEMP. ALARM. ROOM 6353.
FO-271130	12/20/2013	12/20/2013		HIGH TEMP. ALARM. ROOM 6353.
FO-271154	12/20/2013	12/20/2013		HIGH TEMP. ALARM. ROOM 8337.
FO-271161	12/20/2013	12/20/2013		HIGH TEMP. ALARM. ROOM 8215.
FO-271166	12/20/2013	12/20/2013		RM 6353 TOO HOT
E - North			1	
FO-269943	12/13/2013	12/13/2013		ENTIRE BLDG HAS NO HOT WTR
E - Northeast			6	
FO-268987	12/4/2013	12/4/2013		FURNANCE MAKING NOISE BENEATH FLOOR. EARLY CHILD CARE CENTER.
FO-269415	12/10/2013	12/28/2013		Deb Brazen's office (old copier room) is too cold.
FO-269465	12/10/2013	12/10/2013		TOO COLD. EARLY CHILD CARE CENTER.
FO-269666	12/11/2013	12/11/2013		BOILER ALARM.
FO-269755	12/12/2013	12/12/2013		VERY COLD. EARLY CHILD CARE.
FO-271252	12/23/2013	12/23/2013		LOCK SHOP HAS A BURNING SMELL
E - Preventative Maintenance			22	
FO-268862	12/3/2013	12/4/2013		RM 1070 UNABLE TO GET INTO RM KEY WONT UNLOCK DOOR
FO-268866	12/3/2013	12/3/2013		RM 8337 LOW TEMP ALARM
FO-269064	12/4/2013	12/5/2013		AHU# 3 HIGH TEMP ALARM
FO-269154	12/5/2013			CEILING LEAK. ROOM 1111.
FO-269177	12/5/2013	12/6/2013		FIRE TROUBLE ALARM. ROOM NEXT TO 1ST FLOOR PHONE ROOM.
FO-269179	12/5/2013	12/6/2013		DOORS WON'T OPEN OR LOCK WITH KEY. DOORS 074-01-N AND 074-03-S.
FO-269180	12/5/2013	12/6/2013		LOW TEMP. ALARM. ROOM 8337.
FO-269233	12/6/2013	12/7/2013		FAN ALARM SUPPLY FAN #1 & #2
FO-269238	12/6/2013	12/7/2013		CHECK BLDG PRESSURE,UNABLE TO OPEN DOORS YOU CAN FEEL THE AIR BLOWIN
FO-269242	12/6/2013	12/7/2013		BSMNT RM 60 BLK SMOKE COMING FROM KLM MACHINE
FO-269497	12/10/2013	12/11/2013		RM 4240 NEED BREAKRER RESET BLOWN FUSE

WO	Recieved	Finished	Total	Request
FO-269499	12/10/2013			1ST FL DRINKING FOUNTAIN LEAKING BADLY, WO SENT TO PLUMBERS AS WELL PLE
FO-269504	12/11/2013			5057 Woodward - Rm 6304
FO-269857	12/12/2013	12/12/2013		CARPET IS WET. POSSIBLE LEAK. NEAR WINDOW. ROOM 4347.
FO-269976	12/13/2013	12/13/2013		R/R INSIDE STE 100 OFC LOST POWER IN WALL OUTLET
FO-269994	12/13/2013	12/14/2013		Dedicated exhaust fan not working in necropsy room. Requires high priority to repair due to us
FO-270137	12/16/2013	12/17/2013		BOILER ALARM SOUNDING
FO-270961	12/17/2013	12/19/2013		RM 3226 OUTLETS NOT WORKING
FO-271061	12/18/2013	12/19/2013		13TH FLR W. STRWL DOOR ALARM IS SNNG
FO-271122	12/19/2013	12/20/2013		ATRIUM AREA RM 303&304 LOUD BUZZING NOISE COMING FROM THE PENTHOUSE
FO-271272	12/23/2013	12/23/2013		E. FRONT DOOR NOT LATCHING
FO-271273	12/23/2013	12/23/2013		RM 3129 CEILING LEAK
E - South			11	
FO-268638	12/2/2013	12/2/2013		HOT WATER COMING OUT OF TAP IN FUME HOODS. (ROOMS 220 AND 222)
FO-268786	12/3/2013	12/3/2013		CAGE WASHER HAVE LOTS OF STEAM WHEN RUNNING LOAD. BASEMENT ROOM 239
FO-269050	12/4/2013	12/5/2013		UNKNOWN ALARM SOUNDING. ROOM 350.
FO-269129	12/5/2013	12/10/2013		RM 019/DLAR HI TEMP
FO-269387	12/9/2013	12/10/2013		LOW HUMIDITY IN ROOMS 023 THRU 026.22.
FO-269741	12/12/2013	12/12/2013		RM 27.5/DLAR HAS A HI TEMP ALARM
FO-269754	12/12/2013	12/12/2013		BURNING PLASTIC SMELL. STRANGE NOISE COMING FROM VENT. ROOMS 477 AND
FO-269793	12/12/2013	12/12/2013		Building under strong negative pressure. Handicap student couldn't get in since the automatic
FO-270046	12/16/2013	12/16/2013		FUME HOODS ALARMING. ROOMS 470 AND 476.
FO-270062	12/16/2013	12/16/2013		FUME HOOD ALARMING. ROOM 320.
FO-271164	12/20/2013	12/20/2013		LAB 40 TOO HOT
E - Southeast			2	
FO-271100	12/19/2013			RM 6202 LOW BATT ALARM
FO-271140	12/20/2013			2317 TOO HOT
E - West			4	
FO-269321	12/9/2013	12/13/2013		RM 333 INVESTIGAT WHY CEILING TILES ARE FALLING
FO-270995	12/18/2013	12/19/2013		POWER BUMP PLEASE CHECK EQUIPMENT. ALSO CHECK POOL. POOL IS COOL. SE
FO-271066	12/19/2013	12/20/2013		POOL TEMPERATURE HAS DROPPED TO 76 DEGREES.
FO-271230	12/23/2013	12/24/2013		NO POWER IN BLDG
Medium			269	
E - Auxiliary			36	
H-42682	12/2/2013		12/3/2013	Heat isn't getting hot. We have the heat on 80 degrees but I won't rise aboce 69 degrees.
H-42683	12/2/2013		12/3/2013	Heat is not working
H-42684	12/2/2013		12/2/2013	Clogged toilet. Won't flush.
H-42702	12/2/2013		12/4/2013	My thermostat isn't working properly. It stays at one temperature and will not change when we
H-42704	12/3/2013		12/3/2013	my heater is spitting out cold air instead of hot, i think the heat is broken. the A/C works, but
H-42716	12/3/2013		12/10/2013	Our Air conditioner is broken and our room is becoming very hot.
H-42736	12/4/2013	12/6/2013	12/23/2013	Please perform and engineering check of this vacant apartment.
H-42811	12/5/2013		12/2/2013	The left sink (sink closest to the paper towel dispenser) has no hot water.
FO-269212	12/6/2013	12/7/2013		WATER PRESSURE ON 6TH RISER IS LOW
H-42812	12/6/2013		12/9/2013	The heat and cooling has been broken for a week and they would like their room fixed.
H-42880	12/10/2013		12/12/2013	Our heater has not been working. We put it in a higher temperature and instead for warm air t
H-42901	12/11/2013		12/13/2013	Thermostat is broken.
H-42904	12/11/2013		12/12/2013	Subway heating system is down.
H-42902	12/11/2013		12/24/2013	Hot water knob turns completely around. No pressure for hot water. Faucet drips when water i
H-42916	12/13/2013			The heat, A/C, and fan are not working in the room.

WO	Recieved	Finished	Total	Request
H-42919	12/13/2013		12/13/2013	Yo the shower head is leaking dawg!
FO-269952	12/13/2013	12/13/2013		APT 603 WATER IS DISCOLORED
H-42959	12/14/2013		12/16/2013	EMERGENCY!! Heat has been in and out for the past three weeks. The filter was changed a c
H-42960	12/15/2013		12/17/2013	Fuse is out in out light over foyer sink. Not the light bulb itself, the fuse. (thats what the other
H-42977	12/15/2013		12/16/2013	The electrical outlet in the bathroom does not work. Neither sockets work.
H-42999	12/16/2013		12/17/2013	Starbucks hot water handle is out of order.
H-42995	12/16/2013	12/17/2013	12/23/2013	Toilet needs a new flapper
H-43048	12/18/2013	12/20/2013	12/20/2013	heater needs to be repaired
H-43058	12/19/2013	12/21/2013		Mechanical Check
H-43061	12/19/2013	12/21/2013		Mechanical check
FO-271096	12/19/2013	12/20/2013		NORTH SIDE OF BLDG TOO COLD
H-43065	12/19/2013			Mechanical check-Room A only
H-43068	12/19/2013	12/21/2013		Mechanical check
H-43071	12/19/2013	12/21/2013		Mechanical check
H-43077	12/19/2013	12/29/2013		the ballast in the C room is going bad. please change or fix if you can.
H-43085	12/20/2013			room 208 - Atchison Hall shower leaking constantly
H-43086	12/20/2013			room 423 - Atchison Hall, sink faucet leaks when pulled up
H-43113	12/22/2013	12/23/2013		The faucet in the bathroom sink is not working. When I turn on the facet on, water sprays all o
H-43119	12/23/2013			Mechanical check
FO-271377	12/24/2013	12/24/2013		NO HOT WATER IN BLDG
H-43158	12/25/2013	12/26/2013		Hot water and heat is not working in unit
E - Command Center			18	
FO-268620	12/2/2013	12/3/2013		Repair burner on #2 boiler. Boiler will not light off.
FO-268636	12/2/2013	12/23/2013		Repair or replace freeze stat for AC-8. Stat tripping frequently; even when OAT above set poin
FO-268875	12/4/2013	12/6/2013		ATTN; A. Waller, Complete work necessary on #2 boiler to close/fill.
FO-269032	12/6/2013	12/13/2013		POOL CONTROL @ small pneumatic panel for steam control possibly IS OUT OF CALIBRAT
FO-269262	12/8/2013			Repair faulty freeze stat(s). The bottom two freeze stats were jumped out on Sunday Decemb
FO-269330	12/9/2013	12/9/2013		Repair LWCO on Boiler #1. Contiunes to trip the boiler.
FO-269333	12/9/2013	12/19/2013		Boiler # 1 has repeated feed water trips.
FO-269347	12/9/2013	12/13/2013		Trade: Controls/Siemens Priority: Medium
FO-269399	12/10/2013			Trade: Controls/Siemens Priority: Medium
FO-269424	12/10/2013			REPLACE NOISY DAMPER ACTUATOR ON EXHAUST VAV. ROOM 2550.
FO-269577	12/11/2013			pls repair the large fan coil heating unit in the boiler room near the fresh
FO-269816	12/12/2013	12/16/2013		Please repair/calibrate t-stat in kitchen area of President's apt.
FO-269900	12/13/2013			Please verify proper operation of control signal to MA dampers for SF #2.
FO-270888	12/17/2013	12/17/2013		REFRIGERATION SHOP
FO-270971	12/18/2013			Please investigate virtual OAT point for Life Sciences AHU-4.
FO-271035	12/18/2013	12/19/2013		#2 boiler won't start. Keeps tripping on Low Gas Pressure switch.
FO-271145	12/20/2013			trouble shoot issues with hot water loop temperature
FO-271474	12/30/2013			Repair feed water mod motor is not calling for water even though the boiler level is at low warn
E - MedPharm			48	
FO-268804	12/3/2013	12/4/2013		RM 1328 TOO HOT
FO-268814	12/3/2013			Repair leaking hydronic pump
FO-268820	12/3/2013	12/4/2013		RM 1261 TOO COLD
FO-269108	12/5/2013	12/5/2013		Room 8314 - Very loud noise coming from the air vents - Please investigate.
FO-269111	12/5/2013			Repair/replace pump 20 coupling.
FO-269208	12/6/2013	12/6/2013		TOO COLD. ROOM 5150.
FO-269384	12/9/2013			Chemical Fume Hood not working.

WO	Recieved	Finished	Total	Request
FO-269427	12/10/2013	12/11/2013		RM 363 TOO COLD RM WAS ALSO VERY COLD YESTERDAY. PLEASE ADJUST TEMP N
FO-269447	12/10/2013	12/10/2013		RM 200.07/DLAR HAS LOW TEMP
FO-269450	12/10/2013	12/17/2013		TOO COLD. ROOM 1116.
FO-269460	12/10/2013	12/11/2013		RM 268 TOO COLD
FO-269611	12/11/2013	12/11/2013		CONDENSATION ON WINDOWS. ROOM 2105.
FO-269616	12/11/2013	12/11/2013		RM 363 IS STILL TOO COLD
FO-269617	12/11/2013			RM 2258/CLASS RM IS EXTREMELY COLD
FO-269620	12/11/2013	12/11/2013		RM 1116 IS TOO HOT
FO-269627	12/11/2013	12/11/2013		RM 354 IS EXTREMELY COLD
FO-269641	12/11/2013			RM 4117 IS TOO COLD
FO-269662	12/11/2013	12/31/2013		Laborer Med. Priority
FO-269659	12/11/2013			RM 1328 IS TOO HOT
FO-269667	12/11/2013	12/11/2013		TOO COLD. ROOM 5150.
FO-269677	12/11/2013			TOO COLD. ROOM 1241.
FO-269772	12/12/2013			RM 6364 IS TOO COLD
FO-269774	12/12/2013			COLD ROOM IS TOO WARM. ROOM 6312.
FO-269784	12/12/2013			HEATER ON 1ST FLOOR ENTRANCE IS NOT WORKING.
FO-269785	12/12/2013			TOO COLD. ROOMS 5374 AND 5364.
FO-269790	12/12/2013	12/12/2013		TOO COLD. ROOM 361.
FO-269798	12/12/2013	12/12/2013		TOO COLD. ROOM 103.
FO-269800	12/12/2013	12/12/2013		TOO COLD. ROOM 111.
FO-269819	12/12/2013			RM 1102 TOO HOT
FO-269820	12/12/2013	12/17/2013		RM 1241 IS STILL TOO COLD
FO-269950	12/13/2013	12/13/2013		RM 116 TOO HOT
FO-269956	12/13/2013			RM 2105 SEE DR STIMMER
FO-270041	12/16/2013			Room 322.08: office is cold.
FO-270042	12/16/2013			Offices are cold.
FO-270074	12/16/2013			RM 3329 TOO HOT
FO-270076	12/16/2013			TOO COLD. ROMOS 301 AND 307.
FO-270918	12/17/2013			RM 1328 TOO HOT
FO-270986	12/18/2013			RM 1200 TOO HOT
FO-271086	12/18/2013			Room 3565 needs cardboard to be replaced with permanent vent in ceiling.
FO-271026	12/18/2013			TOO COLD. ROOM 3509.
FO-271027	12/18/2013			TOO WARM. ROOM 3520.
FO-271034	12/18/2013			Offices are cold.
FO-271095	12/19/2013			RM 3530 TOO HOT
FO-271223	12/23/2013			Low Humidity
FO-271237	12/23/2013			5324 TOO COLD
FO-271238	12/23/2013			5324 TOO HOT
FO-271241	12/23/2013			GREEN LECTURE HALL TOO COLD
FO-271250	12/23/2013			Room 301: room is cold, thermostat reads 66.
E - North			34	
FO-268687	12/2/2013	12/2/2013		TOO HOT. ROOM 3305.
FO-268799	12/3/2013	12/3/2013		RM 1550 TOO WARM
FO-269021	12/4/2013	12/4/2013		3RD FL TOO HOT
FO-269094	12/5/2013	12/6/2013		Again with the temperature. The original building
FO-269105	12/5/2013	12/5/2013		RM 1550 TOO HOT,ENTIRE BLDG IS HOT

WO	Recieved	Finished	Total	Request
FO-269125	12/5/2013	12/5/2013		NO COMPRESSED AIR. ROOM 250.
FO-269213	12/6/2013	12/6/2013		TOO HOT. ROOM 134.
FO-269219	12/6/2013	12/6/2013		RM 3315 & 3387 TOO COLD
FO-269289	12/9/2013	12/9/2013		Purdy Library 1st Floor, Room 134
FO-269345	12/9/2013	12/9/2013		TOO COLD. BUILDING
FO-269349	12/9/2013	12/9/2013		RM 2215 WITHIN STE 2226 TOO COLD
FO-269348	12/9/2013	12/9/2013		Purdy Library 2nd Floor, Room 231
FO-269360	12/9/2013	12/9/2013		RM 3315 DEANS OFFICE TOO COLD
FO-269413	12/10/2013	12/10/2013		TOO COLD. BUILDING.
FO-269416	12/10/2013	12/10/2013		ENTIRE 1ST FLR IS TOO COLD
FO-269437	12/10/2013	12/11/2013		RM 2347 IS TOO COLD
FO-269463	12/10/2013	12/10/2013		TOO COLD. ROOM 146.
FO-269614	12/11/2013	12/11/2013		Kresge Library, 2nd Floor
FO-269637	12/11/2013	12/11/2013		TOO HOT. 3RD FLOOR.
FO-269639	12/11/2013	12/11/2013		RM 362 IS TOO COLD
FO-269736	12/12/2013	12/12/2013		VERY COLD. BUILDING.
FO-269756	12/12/2013	12/12/2013		The main stacks are too warm, especially the 3rd
FO-269762	12/12/2013	12/12/2013		RM 2228 IS EXTREMELY COLD
FO-269764	12/12/2013	12/12/2013		RM 2242 IS EXTREMELY COLD
FO-269945	12/13/2013	12/16/2013		RM 1347 TOO COLD
FO-270072	12/16/2013	12/16/2013		Purdy Library, 2nd Floor
FO-270896	12/17/2013	12/17/2013		TOO COLD. CIRCULATION DESK ROOM 140.
FO-270921	12/17/2013	12/18/2013		RM 134 TOO HOT
FO-271021	12/18/2013	12/19/2013		Wind is whistling through window disturbing faculty member.
FO-271072	12/19/2013	12/19/2013		Office 154 and 156 need to have their temperature adjusted. It is very cold in these offices.
FO-271133	12/20/2013	12/20/2013		From too hot yesterday to too cold today. The
FO-271135	12/20/2013	12/20/2013		CHECK AIR PRESSURE OUTSIDE DOORS STANDING OPEN ON NORTH SIDE
FO-271151	12/20/2013	12/20/2013		Purdy Library First Floor, Office Suite 134
FO-271240	12/23/2013	12/23/2013		RM 052 METAL SHOP, NO VENTILATION
E - Northeast			33	
FO-268669	12/2/2013	12/2/2013		TOO COLD. SERVICE CENTER
FO-268801	12/3/2013	12/3/2013		Radiator by back door is leaking - the pan on the floor under it is full of water and more is drip
FO-268836	12/3/2013	12/3/2013		SUB BSMNT RM 008 TOO COLD
FO-269104	12/5/2013	12/5/2013	12/5/2013	1ST FL ACROSS FROM ENG CLOSET LEADING TO SUITES IS LOCKED, PLEASE UNLOC
FO-269121	12/5/2013	12/5/2013		TOO COLD. SERVICE CENTER.
FO-269216	12/6/2013	12/6/2013	12/6/2013	TOO COLD. ROOM 103.
FO-269328	12/9/2013	12/9/2013		VERY COLD. SERVICE CENTER
FO-269354	12/9/2013	12/9/2013		TOO COLD. ROOM 224 (AND AREA) BACK OF OFFICE.
FO-269374	12/9/2013	12/28/2013		2ND FLR CONF/MULTIPURPOSE RM IS TOO COLD
FO-269390	12/9/2013	12/28/2013		Office is cold. Radiator valve is open all the way. Pipe to radiator is hot, radiator is cold.
FO-269446	12/10/2013	12/10/2013		ENTIRE BLDG IS EXTREMELY COLD
FO-269452	12/10/2013	12/10/2013		RM 129 TOO COLD
FO-269453	12/10/2013	12/10/2013	12/10/2013	STE 4100 NEW FILTERS NEED TO BE REMOVED
FO-269464	12/10/2013	12/10/2013		TOO COLD. 2ND FLOOR LIBRARY. ROOM 223.
FO-269483	12/10/2013	12/10/2013	12/10/2013	RM 2622 IS TOO COLD/T-STAT NOT WRKNG
FO-269587	12/11/2013	12/11/2013		VERY CHILLY. ROOM 223 (LIBRARY)
FO-269606	12/11/2013	12/11/2013		TOO COLD. SUITE 100 (FRONT OFFICES)

WO	Recieved	Finished	Total	Request
FO-269618	12/11/2013	12/11/2013		Faculty offices are extremely cold. Please give us heat.
FO-269619	12/11/2013	12/11/2013		1ST FLR EARLY CHILDHOOD CTR IS TOO COLD
FO-269633	12/11/2013	12/11/2013	12/11/2013	TOO COLD. ROOM 3900.
FO-269651	12/11/2013	12/11/2013	12/11/2013	RM 150 IS TOO COLD
FO-269757	12/12/2013	12/12/2013		Karen Krisher's office is very cold room# 404. She is finding it hard to work.
FO-269767	12/12/2013	12/12/2013		SURPLUS AREA NEAR GRNDS DEPT CAGE AREA IS EXTREMELY COLD
FO-269807	12/12/2013	12/13/2013		RM 255 IS TOO COLD
FO-269808	12/12/2013	12/13/2013		RM 257 IS TOO COLD
FO-269818	12/12/2013	12/12/2013		RM 363 IS TOO COLD
FO-269935	12/13/2013	12/28/2013		RM 150 IS TOO COLD
FO-269936	12/13/2013	12/28/2013		RM 160 IS TOO COLD
FO-269975	12/13/2013	12/28/2013		RM 2236 IS TOO COLD
FO-270048	12/16/2013	12/28/2013		TOO COLD. ROOM 104.
FO-270979	12/18/2013	12/16/2013	12/16/2013	RM 2236 IS TOO COLD
FO-271081	12/19/2013	12/19/2013		MULTI PURPOSE RM TOO HOT, HOLIDAY PARTY TODAY PLEASE COME ASAP
FO-271153	12/20/2013	12/28/2013		RM 164 TOO COLD
E - Preventative Maintenance			31	
FO-268857	12/3/2013	12/3/2013		Room 5330: reduce the temp in the lab to 68-69 degrees in the small room area in my lab. Als
FO-268856	12/3/2013	12/3/2013		2156 TOO COLD
FO-268869	12/3/2013	12/4/2013		PUBLIC SAFETY REQUESTING ASSISTANCE TO ENTER RM 335
FO-269061	12/4/2013	12/5/2013		TOO HOT. ROOM 250.
FO-269063	12/4/2013	12/5/2013		TOO HOT. ROOM 0320.
FO-269066	12/4/2013	12/5/2013		RM 427 TOO COLD
FO-269073	12/4/2013	12/5/2013		STE 3900 AND LADIES RM HAVE NO HOT WATER
FO-269153	12/5/2013	12/6/2013		HIGH BAY AREA, NEED AIR FLOW CUT OFF TO PREVENT THE NOISE DURING EVENT.
FO-269172	12/5/2013	12/6/2013		There is an air conditioning problem in lab 0320.2 located in the basement. The heat is on ins
FO-269240	12/6/2013	12/7/2013		RM 8307.2 TOO COLD
FO-269395	12/9/2013	12/10/2013		LAUNDRY RM, WASHING MACHINES OVERFLOWING
FO-269396	12/9/2013	12/10/2013		RM 7001.1 TOO COLD
FO-269695	12/11/2013	12/11/2013		RM 3315 IS TOO COLD
FO-269700	12/11/2013			RM 340 IS TOO HOT
FO-269837	12/12/2013			Lab 2550 in the EDC still has the noise problem. They looked at it last week but the noise has
FO-269854	12/12/2013	12/12/2013		Office area is not warm enough.
FO-269855	12/12/2013	12/13/2013		TOO WARM. (HEATER CONTINUOUSLY RUNNING) ROOM 136.
FO-269996	12/13/2013			RM 9310 TOO COLD
FO-269997	12/13/2013	12/14/2013		RM 205 NO HEAT
FO-269998	12/13/2013	12/14/2013		ENTIRE 2ND FL TOO COLD
FO-270136	12/16/2013	12/17/2013		Rooms 2220 and 2232 are extremely cold.
FO-270130	12/16/2013	12/17/2013		4TH FL SE SIDE NO LIGHTS
FO-270134	12/16/2013	12/17/2013		rm 6353 TOO HOT
FO-270135	12/16/2013	12/17/2013		LECTURE HALL 102 TOO HOT
FO-270138	12/16/2013	12/16/2013		DISPATCH AREA 133 TOO HOT
FO-270139	12/16/2013	12/17/2013		6304.1, 6306.1, 6306.2 BLOWN FUSE NEEDS TO BE RESET AFFECTING THESE RM'S
FO-270963	12/17/2013			LOUD KNOCKING PIPES NEAR WOMENS RM AND C&IT. POSSIBLE BAD STEAM TRAP
FO-270965	12/17/2013			Rooms 2245/2246 are cold. Please have building engineer check heating system and progra
FO-271110	12/19/2013	12/20/2013		RM 1313 TOO HOT
FO-271192	12/20/2013			RM 5344 TOO HOT

WO	Recieved	Finished	Total	Request
FO-271195	12/20/2013	12/21/2013		LEAK WITHIN SUITE 300 CARPET IN BATHROOM VERY WET
E - South			34	
FO-268635	12/2/2013	12/2/2013		TOO HOT. ROOM 0034.
FO-268645	12/2/2013	12/2/2013		RM 260 IS TOO HOT
FO-268648	12/2/2013	12/2/2013		RM 160 IS TOO HOT
FO-268649	12/2/2013	12/11/2013		RM 155 IS TOO HOT
FO-268684	12/2/2013	12/6/2013		"Very cold" in this office.
FO-268789	12/3/2013	12/3/2013		Room 3149 thermostat is not working. The temperture is 62 and the heat is 70. Thank you.
FO-268853	12/3/2013	12/3/2013		TOO HOT. ROOM 105. MEZZANINE LEVEL.
FO-269007	12/4/2013	12/11/2013		RM 460 & 456 TOO HOT
FO-269041	12/4/2013	12/11/2013		Trade: Engineer - South
FO-269042	12/4/2013			Trade: Engineer - South
FO-269351	12/9/2013	12/9/2013		3RD FL LADIES RM TOO COLD
FO-269414	12/10/2013	12/11/2013		RM 231 IS TOO COLD.
FO-269417	12/10/2013	12/10/2013	12/10/2013	TOO COLD. 2ND FLOOR MULTI-PURPOSE ROOM.
FO-269421	12/10/2013	12/13/2013		Heat in the walkway/hallway between Science Hall, Life Science and Chemistry is very cold.
FO-269473	12/10/2013	12/12/2013		RM 101 IS TOO COLD
FO-269615	12/11/2013	12/11/2013		TOO COLD. ROOMS 2105, 2107 & 2109.
FO-269743	12/12/2013	12/13/2013		RM 430 IS STILL TOO HOT
FO-269750	12/12/2013	12/12/2013		TOO COLD. ROOMS 2111 AND 2113.
FO-269771	12/12/2013	12/12/2013		TOO COLD. ROOM 1100.
FO-269902	12/12/2013	12/13/2013		Heating problem in lab 1350. Heater is working but there is a source of cold air coming in the
FO-269904	12/12/2013	12/13/2013		Office 2137 goes back and forth from being very cold. Can contact Chin-An Tan at 7-3888. T
FO-269905	12/12/2013	12/13/2013		Lab 2534 EDC has little or no heat. The temperature is about 50F which is too cold and exper
FO-270033	12/16/2013	12/16/2013		RM 255 TOO HOT
FO-270039	12/16/2013	12/16/2013		RM 0034 TOO HOT
FO-270075	12/16/2013	12/16/2013		replace seal on feed water pump.
FO-270083	12/16/2013	12/17/2013		TOO COLD. ROOM 29.
FO-270119	12/16/2013			TOO HOT. SOUTHEAST STAIRWELL.
FO-270120	12/16/2013			TOO COLD. SOUTHWEST STAIRWELL.
FO-270892	12/17/2013	12/17/2013		TOO COLD. ROOM 200.
FO-271099	12/19/2013	12/28/2013		RM 0243 HIGH TEMP ALARM
FO-271136	12/20/2013	12/20/2013		TOO HOT. ROOM 0034.
FO-271138	12/20/2013	12/20/2013		RM 1360 TOO HOT
FO-271143	12/20/2013	12/20/2013		TOO HOT. ROOMS 4111 AND FRONT AREA OF ROOM 1360.
FO-271374	12/24/2013	12/24/2013		BSMNT NEAR AUDITORIUM VENT
E - Southeast			19	
FO-268651	12/2/2013	12/2/2013		TOO COLD. ROOM 13203.4.
FO-268809	12/3/2013	12/3/2013		RM 5019 TOO COLD
FO-269215	12/6/2013			4th floor, cubicles are directly below an air vent and cold air seems to be coming out of it. #44
FO-269221	12/6/2013	12/6/2013		ENTIRE BLDG IS TOO HOT
FO-269273	12/9/2013			3rd and 4th floors are too warm, temperature reading near 87 degrees, please adjust!
FO-269313	12/9/2013	12/9/2013		TOO COLD. SUITE 3010 ESPECIALLY ROOM 3010.2.
FO-269584	12/11/2013	12/11/2013		TOO COLD. ROOM 6304.2.
FO-269657	12/11/2013	12/11/2013		TOO COLD. ROOM 3225.6.
FO-269806	12/12/2013	12/12/2013		RM 7904.2 IS TOO COLD
FO-269974	12/13/2013	12/13/2013		TOO COLD. ROOM 8201.
FO-270012	12/14/2013	12/17/2013		office has mildew smell; please check for source

WO	Recieved	Finished	Total	Request
FO-270032	12/16/2013			NO HEAT. ROOM 140.
FO-270043	12/16/2013	12/16/2013		heat register not working, press buttons and nothing happens, no air blowing out
FO-270067	12/16/2013			RED LIGHT ON HEATER. ROOM 212.
FO-270900	12/17/2013			TOO HOT. ROOM 102.2.
FO-270911	12/17/2013	12/17/2013		RM 3226 TOO COLD, KEEP BLOWING FUSES USING SPACE HEATERS
FO-271217	12/23/2013			RM 13001.2 TOO COLD AIR BLOWING
FO-271221	12/23/2013			STE 4200 W. WING TOO COLD
FO-271232	12/23/2013			13203.4 TOO COLD
E - West			16	
FO-268673	12/2/2013	12/2/2013		TOO COLD. ROOM 455.
FO-268790	12/3/2013			TOO WARM. BUILDING.
FO-268825	12/3/2013	12/18/2013		Room 240: Chemical fume hood is not working, second request to have hood inspected/repair
FO-268989	12/4/2013			SOUTH SIDE OF BLDG TOO HOT PLEASE CALL OR SEE DEE 7-6187
FO-269110	12/5/2013			TOO HOT. ROOMS 388 AND 371.
FO-269114	12/5/2013	12/6/2013		HIGH BAY AREA TEMP NEEDS TO BE TURNED UP FOR EVENT PLEASE SEE RITA
FO-269327	12/9/2013	12/10/2013		TOO COLD. 1ST FLOOR NORTH SIDE OF BUILDING.
FO-269378	12/9/2013	12/12/2013		RM 2033 IS TOO COLD
FO-269451	12/10/2013	12/13/2013		TOO COLD. 2ND FLOOR.
FO-269628	12/11/2013	12/13/2013		TOO COLD. 2ND FLOOR SOUTH SIDE ROOMS 2011, 2015, 2017, 2033, 2037 & 2043.
FO-269749	12/12/2013	12/17/2013		TOO COLD. BUILDING.
FO-270047	12/16/2013			It smells like gas in this office. No one occupies this office.
FO-270061	12/16/2013			RM 1159 TOO COLD
FO-270121	12/16/2013			TOO COLD. ROOMS 2220 AND 2232.
FO-270935	12/17/2013	12/19/2013		TOO COLD. ROOM 101.
FO-271089	12/19/2013	12/20/2013		Basement rooms are very hot @ 80 degrees and climbing.
Low			178	
E - Auxiliary			92	
H-42672	12/1/2013	12/2/2013	12/5/2013	Bathroom sink does not drain correctly.
H-42689	12/1/2013		12/2/2013	Thermostat does not work.
H-42724	12/2/2013		12/4/2013	The silver part of the toilet that goes into the
H-42699	12/2/2013	12/2/2013	12/5/2013	URGENT : The bathroom with the tub has its commode chocked up with all water coming out.
H-42707	12/2/2013			please help me fix the bath at the main bathroom as soon as possible. thanks.authenticated
H-42709	12/3/2013	12/3/2013	12/5/2013	The toilet at the end of the hall continious to flush water for a long time after I push down on th
H-42706	12/3/2013			my thermostat does not work and I can not turn on the heat.authenticated user: Jawun Gam
H-42720	12/3/2013			Trap under the sink has a hole and is leaking.
H-42729	12/3/2013	12/6/2013	12/23/2013	The Kitchen sink needs to be replaced.
H-42730	12/3/2013	12/16/2013	12/23/2013	Broken Shower Head Holder/Attachment
H-42731	12/3/2013	12/5/2013	12/5/2013	The disposal in the kitchen sink is not functioning. When switched on it does not even initiate
H-42722	12/3/2013			Needs the air conditioning ducts cleaned authenticated user: Aja Pettiford - fi6887
H-42725	12/3/2013		12/2/2013	Sink behind the espresso bar is leaking.
H-42734	12/3/2013	12/4/2013	12/5/2013	URGENT! The garbage disposal in our kitchen sink is not working. Also, there has been a lea
H-42726	12/4/2013			Heating is no longer working.authenticated user: Noah Hall - fm7849requester ip address:
H-42738	12/4/2013			Rehang exit sign on the sixth floor.
H-42745	12/4/2013			The garbage disposal is out of order
H-42772	12/5/2013			Resident can only take a shower. The water does not come out of the faucet to fill the tub.
H-42779	12/5/2013	12/7/2013	12/23/2013	The bathroom no #2 flush is not working and need to be repaired, as we press the flush ...wat
H-42780	12/5/2013	12/5/2013	12/23/2013	Water is dripping from the left hand side of the pipe feeding into the toilet! (First bathroom on t
H-42789	12/6/2013			Apartment is extremely hot. Adjusting the thermostat doesn't seem to do anything.

WO	Recieved	Finished	Total	Request
H-42790	12/6/2013			HEAT DOESNT BLOW INTO THE BEDROOMS ITS FREEZING
H-42798	12/6/2013			Needs Mechanical Check.
H-42801	12/6/2013			Needs Mechanical Check.
H-42804	12/6/2013			Needs Mechanical Check.
H-42854	12/6/2013	12/10/2013	12/23/2013	shrink drain is not working.overflowing.please send anyone immediately
H-42856	12/7/2013	12/10/2013	12/18/2013	In the room farthest from the door, the vents gives off a terrible burning smell when we turn on
H-42826	12/8/2013			The showerhead constantly leaks. At first it was just dripping, but now a steady stream flows o
H-42829	12/8/2013		12/24/2013	The faucet in the laundry room is dripping continuously even though it is shut off.
H-42831	12/9/2013		12/9/2013	There is something wrong with the shower. The shower head is leaking badly. Before it was a
H-42814	12/9/2013	12/9/2013	12/23/2013	Please change light bulb
H-42847	12/9/2013			The water pressure in the resident's room has been quite high, making noise and spraying ba
H-42859	12/9/2013	12/12/2013	12/18/2013	the air conditioner does not work and the biggest fire is still not working.
H-42839	12/9/2013		12/9/2013	Womens bathroom toilets keep running on the first floor in the lobby.
H-42841	12/9/2013		12/10/2013	Toilet will not stop running.
H-42843	12/9/2013		12/10/2013	The shower handle is loose, when water is tuned on, water drips from the handle.
H-42861	12/9/2013	12/10/2013	12/18/2013	electric outlet malfunction in kitchen
H-42850	12/9/2013			Shower leak.authenticated user: Taylor Hall - eq7319requester ip address: 141.217.230.10
H-42864	12/9/2013	12/10/2013	12/18/2013	Heating system is broken in 901, please fix! thanks
H-42851	12/10/2013		12/10/2013	Thermostat is broken.
H-42887	12/11/2013			Dear! think the Fire alarm does not work! because I got food burned with too much smoke :)
H-42894	12/11/2013			water dripping continuously from the tap at bathroom sink.
H-42920	12/12/2013	12/13/2013	12/18/2013	Toilet keeps making constant noise after flush.
H-42910	12/12/2013			check ballast - sconce light near room 652 Atchison
H-42911	12/12/2013	12/12/2013	12/18/2013	The air conditioner in my room only blows cold air. I hope it can be fixed ASAP.
H-42921	12/12/2013	12/13/2013	12/18/2013	First bathroom on the right - toilet won't flush. Roommates are confused since this happened
H-42926	12/12/2013			Mechanical Check
H-42914	12/12/2013			Light is out in the foyer in the day care at UT. Maintenance cannot fix it.
H-42933	12/13/2013			please do an engineering check of room 434 - Ghafari Hall
H-42934	12/13/2013			please replace HVAC unit in room 323 - Ghafari Hall
H-42947	12/13/2013		12/16/2013	Garbage Disposal is not working property.
H-42937	12/13/2013			please do an engineering check of room 232 - Ghafari Hall, room is empty
H-42952	12/14/2013	12/16/2013	12/23/2013	Bathroom in apartment 923 will not flush. Only toilet in bathroom. Has flooded and requires m
H-42953	12/14/2013	12/16/2013	12/23/2013	URGENT! Our garbage disposal was replaced a couple weeks ago and it's malfunctioning aga
H-42964	12/15/2013			Electrical problems near kitchen sink, bathroom, and hallway. Attempted to reset her power an
H-42954	12/15/2013	12/16/2013	12/23/2013	Bathroom #2 tub nozzle needs to be tightened.
H-42955	12/16/2013	12/16/2013	12/23/2013	electric outlet malfunction in kitchen
H-42972	12/16/2013	12/16/2013	12/18/2013	Toilet in bathroom #2 is clogged and was leaking water. Water was cleaned and water was tur
H-42973	12/16/2013		12/13/2013	garbage disposal not working in lounge 635 Ghafari Hall
H-43012	12/17/2013	12/17/2013		There's no power in the rooms. It seems fuse has gone.
H-42997	12/17/2013	12/17/2013	12/23/2013	1st bathroom is chocked...
H-43013	12/17/2013			The tap of the sink in the kitchen is loosened up and water is leaking out of joints when ever it
H-43027	12/17/2013	12/18/2013	12/23/2013	In 330 the handle of the toilet in the first bathroom is broken, please fix.
H-43016	12/17/2013	12/17/2013	12/23/2013	Garbage disposal is not working.
H-43018	12/17/2013	12/17/2013	12/23/2013	Plug in the kitchen is not working.
H-43022	12/17/2013	12/18/2013		Sink is clogged due to broken garbage disposal, please repair garbage disposal.
H-43051	12/19/2013	12/19/2013	12/23/2013	the insinkerator in the kitchen is not working.
H-43078	12/19/2013	12/20/2013	12/23/2013	Hi, our Garburator seems like get stuck. Could you please help us to fix it? Thank you very m

WO	Recieved	Finished	Total	Request
H-43082	12/20/2013	12/20/2013		The toilet porcelain has cracked creating a leak. It appears that it has actually broken the entire
H-43109	12/20/2013			Exhaust in the kitchen and bug treatmentauthenticated user: Uday Bhaskar Krishnamurthy -
H-43120	12/21/2013			The garbage disposal in the kitchen does not work properly. It makes a really loud grinding noi
H-43115	12/22/2013	12/23/2013		The garbage disposal is not working.
H-43122	12/23/2013			There is a leak in the bathtub (main bathroom).authenticated user: Laura Moreno Cubillos -
H-43121	12/23/2013			The garbage disposal is really smelly and has stopped working. authenticated user: Hannah
H-43126	12/23/2013			Please do an engineering check of this vacant apartment.
H-43128	12/23/2013			There is an outlet out in 1121 by the stove in the kitchen
H-43129	12/23/2013			There is an outlet out in the hallway near 1125.
H-43131	12/23/2013			near lounge 619 Atchison Hall check ballast. new bulb put in but still does not work.
H-43144	12/24/2013	12/26/2013		Hot water in bath doesn't work.
H-43159	12/24/2013	12/26/2013		Hot water is not working in the bathroom. -RUSH (issue reported on 12/24/13, may have been
H-43157	12/25/2013	12/27/2013		Toilet keeps making noise in the tank. But it is still usable
H-43160	12/26/2013	12/26/2013		Prentis: Please adjust supply vents for all three rooms.
H-43185	12/27/2013			The kitchen ceiling is leaking.authenticated user: Sha-Tai Mcconico - eq7686requester ip a
H-43177	12/27/2013			Kitchen InSinkErator is not working.authenticated user: Chandni Patel - eh4413requester i
H-43186	12/27/2013			Ceiling is leaking rapidly, yellow stress marks by leak. Requesting urgent immediate assistanc
H-43178	12/27/2013			sink disposer is not workingauthenticated user: Arjun Singh - fi8442requester ip address: 1
H-43181	12/28/2013			The bathtub drain isn't working. The lever to pull to drain the water fell off and now the water w
H-43188	12/28/2013	12/31/2013		Faucet in bathroom sink is leaking.
H-43189	12/28/2013	12/31/2013		The faucet in the tub is dripping heavily when the shower is turned off. The water that is drippi
H-43191	12/29/2013	12/30/2013		Water sink disposer in the kitchen stopped working.
H-43184	12/30/2013			The toilet is running constantly since the power shutdown the other nightauthenticated user:
H-43195	12/30/2013			Maintenance repair in the bathroom.authenticated user: Sha-Tai Mcconico - eq7686reques
E - Command Center			49	
FO-268657	12/2/2013	12/6/2013		ATTN; Lloyd Brombach; R/R mod motor on #2? boiler.
FO-268674	12/2/2013	12/11/2013		Control Engineer; Medium
FO-268676	12/2/2013	12/20/2013		Trade: Controls/Boilers Priority: Medium
FO-268787	12/2/2013	12/17/2013		Refrg/Control
FO-268788	12/2/2013	12/17/2013		REFRIG./CONTROLS
FO-268851	12/3/2013			CONTROLS CREW,
FO-268858	12/3/2013	12/10/2013		Please repair controls in lab 260. Area is overheating (+80 deg). Air leaks have been repaire
FO-269022	12/4/2013			REPLACE FAULTY DAMPER MOTOR ON EXHAUST DUCT. (RM 2550 LOUD RUBBING N
FO-269027	12/4/2013	12/9/2013		Investigate/Calibrate pneumatic controls in mechanical rm basement @ Law bldg. Specifically
FO-269103	12/5/2013	12/12/2013		Controls High Priority
FO-269290	12/9/2013	12/9/2013		CONTROLS (HIGH)
FO-269296	12/9/2013	12/9/2013		CONTROLS GROUP-PLEASE INVESTIGATE PROBLEM WITH LOW WATER CUTOUT #1
FO-269470	12/10/2013	12/20/2013		Trade: Controls
FO-269469	12/10/2013	12/20/2013		Trade: Controls
FO-269471	12/10/2013			Trade: Controls
FO-269531	12/11/2013			In the General Lectures building after 10:00pm there is a foul smell that is most apparent near
FO-269600	12/11/2013	12/13/2013		Trade: Controls Engineering
FO-269623	12/11/2013			Refrig/ controlsR/R RM 0003.30/MECH RM repair or replace the steam valve and actuator to
FO-269652	12/11/2013			Please perform post flue gas analysis on #2 boiler @ 5057. Inform Bill Willard when complete.
FO-269737	12/11/2013			CONTROL SR/R RM 107 please resolve problem with cold offices in 100 suites. no/ very low
FO-269920	12/12/2013			Investigate/Calibrate pneumatic controls in mechanical rm basement @ Law bldg. & supply-si
FO-269775	12/12/2013	12/16/2013		Trade: ControlsPriority: HighR/R RM 0000.62/MECH-BLR RM Please repair ALWCO on b

WO	Recieved	Finished	Total	Request
FO-269776	12/12/2013	12/20/2013		Trade: Controls
FO-269777	12/12/2013			Controls Med. priority R/R RM 187.01 Make necessar repairs to # 2 unit heater controls on
FO-269817	12/12/2013	12/19/2013		Control Engineer; Medium
FO-269826	12/12/2013			CONTROLS please repair vav control for office 404 in MORT SCI. found discharge temp 99 d
FO-269836	12/12/2013	12/16/2013		controls -boiler #2 will not start,it is calling for heat but will not come on line at this time,pushe
FO-269915	12/13/2013			REFER SHOP: R/R RM 5420.8 Please replace Humidity Valve in room 5420.8 (Surgery Roo
FO-269916	12/13/2013			REFER SHOP:
FO-269924	12/13/2013			AC Shop - Lloyd - Medium. R/R RM 0100/MECH RM Please replace hydraulic pressure swit
FO-269925	12/13/2013			Trade: Controls
FO-269961	12/13/2013	12/13/2013		Replace Levelmaster with McDonnel Millers
FO-270114	12/16/2013			Control Engineer; High
FO-270926	12/17/2013			This will be a standing work order for Lloyd Brombach as he continues to work on the Scott Ha
FO-270940	12/17/2013			Trade: Contols/Siemens Priority: Medium
FO-271102	12/19/2013	12/20/2013		Boilers & controls-Please check out boiler #2 ,combustion motor will not start.
FO-271115	12/19/2013			Trade: Controls
FO-271113	12/20/2013			Replace bad contactor on Air Handling Unit.
FO-271162	12/20/2013			Refg. Crew:
FO-271183	12/20/2013			There is a defective transducer for Mixed air dampers on AHU-1. Have refrigeration dept. repa
FO-271185	12/20/2013			A/C shop
FO-271194	12/20/2013	12/23/2013		Trade: Controls
FO-271242	12/23/2013			ATTN; Aubrey:[Closure Project] Reclaim refrigerant from approx (20)units stored @ Music Nor
FO-271243	12/23/2013			ATTN; Tony A: Perform PM's on Beecher House A/C units- assistance will be required. Log P
FO-271244	12/23/2013			ATTN; Tony A./Rich H.; Perform Inventory of siemens parts located within cabinets @ Music
FO-271266	12/23/2013			Trade Controls priority medium
FO-271405	12/24/2013			R/R WEST STRWL WALL UNIT HEATER CONVECTOR not working (North Stairwell A)
FO-271407	12/24/2013			Trade: ControlsPriority: Highr/r rm 003.20/REC RM AHU #3's freeze stat keeps tripping the
FO-271408	12/24/2013			Trade: Controls
E - MedPharm			9	
FO-268654	12/2/2013	12/2/2013		Low humidity.
FO-269380	12/9/2013	12/9/2013		RM 415 CK CLNG LEAK
FO-269418	12/10/2013			Many animal rooms are nuetral to the hallway must be negative.
FO-269444	12/10/2013	12/11/2013		R/R UPPER PENTHOUSRE Please unsolder a piece of the line so we can remove debris fro
FO-269590	12/11/2013			Aquire data logger to record temperature and humidity
FO-269671	12/11/2013	12/11/2013		TOO COLD. ROOM 111.
FO-270898	12/17/2013	12/17/2013		7TH/8TH FLRS INVESTIGATE NO HOT WATER
FO-271033	12/18/2013			Room 322.07: office is cold.
FO-271165	12/20/2013			Repair a humidifer for/in the DLAR area.
E - North			7	
FO-268646	12/2/2013	12/2/2013		Our temps are off again. It's in the upper 70s
FO-268784	12/3/2013	12/20/2013		Day shift engineer: Please check Fan #3 unit operation (HW coil & Discharge Air Temp; also
FO-269096	12/5/2013	12/16/2013		Again with the temperature. The original building
FO-269331	12/9/2013	12/9/2013		Room 1550 is too hot. This problem has been
FO-269809	12/12/2013	12/17/2013		The employee lounge has been very cold for
FO-271078	12/19/2013	12/19/2013		The temps are high again in staff offices and in
FO-271201	12/21/2013			Atlas Oil Purchase Order # P0649717
E - Northeast			6	
FO-269579	12/10/2013			Install sensors in 3 mechanical closets that have HVAC units
FO-269738	12/12/2013	12/28/2013		RM 125/KITCHEN AREA IN BUS SVC AREA HAS NO HOT WTR IN BOTH SLOP/COUNTER

WO	Recieved	Finished	Total	Request
FO-269810	12/12/2013	12/12/2013		Entire building is very cold.
FO-270052	12/16/2013	12/16/2013		Radiators in Lunchroom and Larry Fodor's office is barely functioning. Please investigate and r
FO-270885	12/17/2013	12/17/2013		FYI: We have several puddles of water in the receiving garage (room 112). They are located
FO-271360	12/20/2013	12/24/2013		Karen Krisher's office extreme cold. 4th floor CLS offices. The temperature regulation problem
E - Preventative Maintenance			9	
FO-268703	12/2/2013	12/3/2013		RM 3554 Heat was at 61 now it is 74 and hard to concentrate. Is there a way we could have
FO-268873	12/4/2013			Replace Belts
FO-269394	12/9/2013	12/10/2013		RM 315 Power went out at 3 desks. (Computers and lights are not working)
FO-269501	12/10/2013			heating unit blows out cold air, and making noises
FO-269682	12/11/2013	12/12/2013		Fix outside air dampers, clean heating coil and rebalance supply fan no. 3.
FO-269696	12/11/2013	12/12/2013		Purdy Library 2nd Floor, Stair #1
FO-269699	12/11/2013	12/11/2013		Man -door on west-facing wall needs to be adjusted to close fully. Currently, if not pulled shut,
FO-269703	12/12/2013			Supply Fan #8
FO-270957	12/17/2013	12/18/2013		RM 2318 CK WALL OUTLET/COPY MACH FOR POWER RESET BREAKER IF NECESSAR
E - South			1	
FO-269294	12/9/2013	12/9/2013		SIEMEN'S CONTRACTORS NEED ACCESS TO 4TH FLOOR.
E - Southeast			1	
FO-268816	12/3/2013	12/4/2013		HVAC and ceiling filters need changing/cleaning
E - West			4	
FO-268647	12/2/2013			R/R RM 017/MECH RM please replace leaking chlorine line and re pipe where needed.
FO-269804	12/12/2013	12/17/2013		Office is extremely cold.
FO-269932	12/13/2013	12/18/2013		Fume hood in room 240 is not functioning properly.
FO-271023	12/18/2013	12/20/2013		Need fuse AMP-TRAP AJT\$, 600 volts
Routine			5	
E - Command Center			1	
FO-267547	12/2/2013	12/12/2013		pls repair t stat circuit out of order
E - Preventative Maintenance			4	
FO-270966	12/2/2013	12/18/2013		Replace PRE-filters
FO-270967	12/18/2013	12/18/2013		Replace PRE-filters
FO-270968	12/18/2013	12/18/2013		Replace PRE-filters
FO-270969	12/18/2013	12/17/2013		Replace PRE-filters
Grounds			4	
Low			3	
G - Moving/Storage			2	
FO-269687	12/6/2013	12/19/2013		Request to move surplus and obsolete items.
FO-271053	12/18/2013			I would like the following work done in office 6409.5:
G - Physical Grounds			1	
FO-269389	12/9/2013	12/10/2013		GROUNDS please salt in front of boiler room door at 5425 WOODWARD. Walk outside boiler
Routine			1	
G - Moving/Storage			1	
FO-269694	12/11/2013	12/18/2013		Move furniture selected (and tagged) from Property warehouse to office space at 4009 FAB.
Trades			883	
Emergency			108	
T - Carpenter			12	
FO-268709	12/2/2013	12/2/2013		EMERGENCY/CARP LOCKSMITH
FO-268818	12/3/2013	12/3/2013		Emergency Request. Repair/Replace lock to front door of Housing Office Room-598 in Studen
FO-269148	12/5/2013	12/5/2013		Emergency. Office 557 inside the CAPS office suite cannot be secured. This is a high security

WO	Recieved	Finished	Total	Request
FO-269335	12/9/2013	12/9/2013		NEED DOOR OPENED DUE TO WATER LEAK. ROOM 119. (NO KEY) Finished 12/10/2013
FO-269585	12/11/2013	12/11/2013		DOOR KNOB HAS FALLEN OFF. ROOM 474Finished 12/16/2013LT
FO-269654	12/11/2013	12/11/2013		EMERGENCY
FO-269656	12/11/2013	12/11/2013		EMERGENCY
FO-269783	12/12/2013	12/12/2013		EMERGENCY/CARP
FO-269940	12/13/2013	12/13/2013		NEED CARPET TAPPED DOWN - ENTRANCE TO ROOM. ROOM 106. (CALL JACKIE 1-2
FO-270127	12/16/2013	12/16/2013		005-12W HANDICAP EXIT DOOR STAYS OPEN VERY DIFFICULT TO CLOSE. Finished 12/
FO-270899	12/17/2013	12/18/2013		WHOLE IN CONCRETE BETWEEN THE MACABEES BUILDING AND PARKING STRUCTU
FO-271362	12/22/2013	12/24/2013		CARPENTERS:
T - Electrician			70	
FO-268613	12/2/2013	12/2/2013		CPU/MONITOR IS DOWN. 1ST FLOOR GUARD'S DESK. Finished 12/3/2013LT
FO-268639	12/2/2013	12/2/2013		WALL OUTLETS ARE NOT WORKING. ROOMS 4630 AND 4632. Finished 12/3/2013LT
FO-268658	12/2/2013	12/2/2013		FIRE TROUBLE ALARM. Finished 12/3/2013LT
FO-268660	12/2/2013	12/2/2013		EMERGENCY
FO-268668	12/2/2013	12/3/2013		LIGHT FIXTURE IS HANGING. ROOM 4100. Finished 12/4/2013LT
FO-268693	12/2/2013	12/4/2013		There is a light bulb broken in one of the light fixtures. Finished 12/6/2013 LT
FO-268805	12/3/2013	12/3/2013		FIRE TROUBLE ALARM. Finished 12/4/2013LT
FO-268810	12/3/2013	12/3/2013		RM 420 TRIPPED CIRCUIT Finished 12/4/2013LT
FO-268848	12/3/2013	12/3/2013		BLOWN FUSE. WALL OUTLETS ARE NOT WORKING. ROOM 126. Finished 12/4/2013LT
FO-268976	12/4/2013	12/4/2013		FIRE TROUBLE ALARM. Finished 12/6/2013 LT
FO-268980	12/4/2013	12/4/2013		WALL OUTLETS ARE NOT WORKING. ROOM 4630. Finished 12/6/2013 LT
FO-268991	12/4/2013	12/4/2013		FIRE PANEL IN ALARM Finished 12/6/2013 LT
FO-269001	12/4/2013	12/4/2013		Please chk to see if elements in hot water tank are working..tank is located 2nd floor southeas
FO-269055	12/4/2013	12/5/2013		ALL LIGHTS ARE OUT. ROOM 3139. Finished 12/6/2013LT
FO-269067	12/4/2013	12/6/2013		All the lights are out in mens and women's restroom, 3rd floor. Both switches are not working.
FO-269093	12/5/2013	12/6/2013		Move Scissor lift from Applebaum, to the corner of Warren, and Anthony Wayne Drv. at the Ki
FO-269136	12/5/2013	12/5/2013		POWER DISTRIUBUTION PUMP FOR SEWAGE AND AIR COMPRESOR IS NOT WORKIN
FO-269145	12/5/2013	12/5/2013		RM 1169 OUTLET NOT WORKING Finished 12/6/2013LT
FO-269186	12/6/2013	12/6/2013		SEWAGE PUMP IS NOT COMING ON. ROOM 23. Finished 12/10/2013LT
FO-269314	12/9/2013	12/9/2013		R/R RM 6203 ENTIRE STE EXCEPT 2 RMS LOST POWER IN WALL OUTLETS Finished 12/
FO-269329	12/9/2013	12/9/2013		NO POWER IN WALL OUTLETS. BASKETBALL OFFICE. ROOM 106.1 Finished 12/10/201
FO-269353	12/9/2013	12/9/2013		LIGHT FIXTURE IS HANGING. ROOM 133. Finished 12/10/2013LT
FO-269366	12/9/2013	12/10/2013		FIRE TROUBLE ALARM Finished 12/11/2013LT
FO-269381	12/9/2013	12/10/2013		R/R First floor women's room. Hand dryer has a burning smell when it's turned on. It also ma
FO-269382	12/9/2013	12/9/2013		R/R FAP FIRE TROUBLE ALARM Finished 12/10/2013LT
FO-269438	12/10/2013	12/10/2013		DANCE STUDIO NEAR RM 3317 2 OUTLETS NOT WORKING Finished 12/11/2013LT
FO-269459	12/10/2013	12/11/2013		FIRE TROUBLE ALARM Finished 12/12/2013LT
FO-269472	12/10/2013	12/11/2013		FIRE TROUBLE ALARM. Finished 12/12/2013LT
FO-269588	12/11/2013	12/11/2013		FIRE TROUBLE ALARM. Finished 12/12/2013LT
FO-269751	12/12/2013	12/12/2013		#2 BOILER FORCE DRAFT FAN MOTOR TRIPPED, WILL NOT RESET.
FO-269752	12/12/2013	12/12/2013		AIR HANDLER UNIT #2 IS NOT COMING ON. ROOM 3131. Finished 12/13/2013LT
FO-269780	12/12/2013	12/12/2013		WALL OUTLETS ARE NOT WORKING. ROOMS 351 AND 355. Finished 12/13/2013LT
FO-269786	12/12/2013	12/12/2013		No pressure at Booster pump, check motor, and contactor to make sure all is working properly
FO-269795	12/12/2013	12/12/2013		FIRE TROUBLE ALARM. Finished 12/13/2013LT
FO-269825	12/12/2013	12/13/2013		NO POWER IN WALL OUTLETS. ROOM 318. SEE RESULTS. Finished 12/16/2013LT
FO-269918	12/13/2013	12/13/2013		LIGHTS WILL NOT COME ON. 4TH FLOOR.. Finished 12/16/2013LT
FO-269934	12/13/2013	12/13/2013		ALARM SOUNDING. 2ND FLOOR ROOM NEXT TO CUSTODIAL CLOSET.. Finished 12/16/

WO	Recieved	Finished	Total	Request
FO-269941	12/13/2013	12/13/2013		EMERGENCY:ELEC
FO-270014	12/16/2013	12/16/2013		FIRE TROUBLE ALARM. Finished 12/17/2013LT
FO-270023	12/16/2013			Adding Electrician: Check to see if floats for sewage ejectors are working properly room 22 fan
FO-270024	12/16/2013	12/16/2013		4TH FL SOUTH END NO LIGHTS Finished 12/17/2013LT
FO-270036	12/16/2013	12/16/2013		AIR HANDLER UNIT #1 IS DOWN AND WILL NOT RESET. MOTOR CUTTING OFF ON OV
FO-270055	12/16/2013	12/18/2013		BSMNT PLANATARIUM FAN COIL UNIT HAS BLOWN FUSE RESULTING IN NO HEAT. Fini
FO-270063	12/16/2013	12/16/2013		Fuse blown LPS-RK-175SP on fume hood exhaust #1. Others not running. Finished 12/17/201
FO-270069	12/16/2013			PLEASE REPAIR SOUTH EXHAUST FAN #1
FO-270077	12/16/2013	12/16/2013		RM 2420 CIRCUITS NOT WORKING Finished 12/17/2013LT
FO-270078	12/16/2013	12/16/2013		NO POWER IN WALL OUTLETS. ROOM 2418. Finished 12/17/2013LT
FO-270129	12/16/2013	12/17/2013		FIRE TROUBLE ALARM. Finished 12/18/2013LT
FO-270906	12/17/2013	12/17/2013		BLOWN CIRCUIT. ROOM 225. Finished 12/18/2013LT
FO-270945	12/17/2013	12/17/2013		FIRE PANEL IS BEEPING. 1ST FLOOR. Finished 12/18/2013LT
FO-270947	12/17/2013	12/19/2013		FIRE TROUBLE ALARM. Finished 12/19/2013LT
FO-270976	12/18/2013	12/18/2013		MAIN SUPPLY FAN MOTOR IS MAKING LOUD NOISE AND KNOCKING AND VERY HOT..
FO-270989	12/18/2013	12/19/2013		NO HOT WATER - 3RD THROUGH 9TH FLOORS. SEE RESULTS. Finished 12/19/2013LT
FO-271006	12/18/2013	12/18/2013		FIRE ALARM PANEL IS BUZZING.. Finished 12/19/2013LT
FO-271018	12/18/2013	12/18/2013		ELECTRICAL BURNING SMELL AND SOOT IS COMING FROM WALL OUTLET. ROOM 35
FO-271031	12/18/2013	12/18/2013		1ST FL OFFICE OUTLET NOT WORKING, PLEASE GO TO RECEPTION DESK FOR LOCA
FO-271037	12/18/2013	12/18/2013		FIRE TROUBLE ALARM. Finished 12/19/2013LT
FO-271039	12/18/2013	12/18/2013		BLOWN FUSE. ROOM 13001. Finished 12/19/2013LT
FO-271043	12/18/2013	12/19/2013		ELEC:
FO-271091	12/19/2013	12/19/2013		Emergency Request. Electrical Power outage in Testing Evaluation Department Room-679 th
FO-271126	12/20/2013	12/26/2013		Adding Electrician: Please check float switch operation on sump . See Mike McAlinden
FO-271129	12/20/2013	12/20/2013		FIRE TROUBLE ALARM. Finished 12/23/2013LT
FO-271202	12/21/2013	12/20/2013		Emergency assistance with determining source of power outage at Community Arts Bldg & co
FO-271216	12/23/2013	12/23/2013		Building has no Power, restore Power to building. Finished 12/26/2013LT
FO-271222	12/23/2013	12/23/2013		AHU's not workin, no air movement in building. Finished 12/26/2013LT
FO-271258	12/23/2013	12/27/2013		Women's restroom along side of room 1515. EP in the light switches. The room completely da
FO-271375	12/24/2013	12/24/2013		FIRE TROUBLE ALARM Finished 12/26/2013LT
FO-271376	12/24/2013	12/24/2013		HALLWAY OF 1300 SMOKE ALARM TRIPPED Finished 12/26/2013LT
FO-271469	12/28/2013	12/28/2013		Investigate and correct cause of AHU-2 not running. Finished 12/28/2013LT
FO-271470	12/28/2013	12/28/2013		Motor appears to be burned up. Please replace or repair. Finished 12/28/2013LT
T - Laborer			1	
FO-270102	12/16/2013	12/17/2013		Adding Laborer:Please set up barricade around yellow barrel until city can replace manhole lid
T - Locksmith			1	
FO-271271	12/23/2013	12/20/2013		CALL-IN TO OPEN THE PRESIDENTS GARAGE DOOR @ 11:30 pm Finished 12/23/2013LT
T - Pipefitter			7	
FO-268791	12/3/2013	12/3/2013		please repair condensate pipe leak located in basement plenum....Ea/RC...12-3-13 Finished 1
FO-269355	12/9/2013	12/10/2013		R/R coil leak AC#1. See Delgado for location ,,,,,,,,,,,,,, ME/12-9-13 ,,,,,,,,,,,,,, DUE ASAP
FO-269423	12/10/2013	12/10/2013		REPAIR WATER LEAK FROM HOT WATER HEATING LINE. BASEMENT HALLWAY CEILI
FO-270034	12/16/2013	12/17/2013		MAIN CONDENSATE IS DOWN. ROOM 22,,,,,,,,,,,,, RC/12-16-13 ,,,,,,,,,,,,,, DUE ASAP
FO-270050	12/16/2013	12/16/2013		Radiator valve in room 317 is leaking. Carpeting around radiator is saturated and there is wat
FO-271028	12/18/2013	12/18/2013		AIR HANDLER #11 REPLACE VENT ON STEAM COIL. PENTHOUSE ,,,,,,,,,,,,,, JH/12-18-
FO-271048	12/18/2013	12/18/2013		PIPEFITTERS
T - Plumber			17	
FO-268829	12/3/2013	12/5/2013		ALL RESTROOMS IN THE FRONT OF BLDG MENS AND WOMENS NO HOT WATER, 2ND
FO-269211	12/6/2013	12/6/2013		The #1 sewage lift pump is jammed. Please have the plumbers repair it. This is urgent,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-269376	12/9/2013	12/9/2013		EMERGENCY/PLUMBERS
FO-269430	12/10/2013	12/13/2013		RM 2432 WOMENS RM FLUSH VALVE LEAKING WATER ,,,,,,, RJC/RB 12-10-13,,,,,
FO-269613	12/11/2013	12/11/2013		MOTION SINK FAUCET CONTINUOUSLY RUNNING AND WON'T TURN OFF. 1ST FLOOR L
FO-269773	12/12/2013	12/12/2013		EMERGENCY/PLUMBERS
FO-269828	12/12/2013	12/12/2013		NO WATER IN BUILDING.,,,,,,, Finished 12-12-13 JWT ** Duplicat Work Order / Refe
FO-269927	12/13/2013	12/13/2013		PLUGGED TOILET. 2ND FLOOR LADIES RESTROOM.,,,,,,, Finished 12-13-13 / Dupl
FO-269965	12/13/2013	12/13/2013		please unplug plugged sink in room 131 ladies restroom.....MP/DB...12-13-13 ,,,,,,, DU
FO-269967	12/13/2013			EMERGENCY/PLUMB
FO-270013	12/16/2013	12/16/2013		WATER COMING UP FROM FLOOR DRAIN. BASEMENT ROOM 28.,,,,,,, MP/DB 12
FO-270020	12/16/2013	12/16/2013		Manhole cover missing, on the North Side of the General Lectures building in crosswalk with y
FO-270066	12/16/2013	12/17/2013		NO HOT WATER. 3RD FLOOR.,,,,,,, MM/12-16-13 ,,,,,,, DUE ASAP Finished 1
FO-270116	12/16/2013	12/17/2013		TOILET NOT FLUSHING. LOW WATER PRESSURE. 12TH FLOOR LADIES RESTROOM.,,,
FO-270126	12/16/2013	12/17/2013		NO HOT WATER. ROOM 7244.,,,,,,, MM/12-16-13 ,,,,,,, DUE ASAP Finished 12-1
FO-271038	12/18/2013	12/18/2013		NO HOT WATER. 13TH FLOOR. ,,,,,,, Finished 12-18-13 JWT Other repair in building e
FO-271253	12/22/2013			Charge acct. entered per G. Tilson 12/23/13 MS
High			221	
T - Carpenter			46	
FO-268615	12/2/2013	12/2/2013		Door 005-07S stays ajar per officer checking building Finished 12/3/2013LT
FO-268616	12/2/2013	12/26/2013		Door 005-05E stays ajar per officer checking building Finished 12/27/2013LT
FO-268617	12/2/2013	12/3/2013		Door 005-14N stays ajar per officer checking building Finished 12/4/2013LT
FO-268644	12/2/2013	12/2/2013		LOCKSMITH,
FO-268663	12/2/2013	12/2/2013		METAL PANEL IS HANGING FROM CEILING. HALLWAY OUTSIDE OF ROOM 3009. (CAN
FO-268666	12/2/2013	12/3/2013		DOOR WON'T UNLOCK WITH KEY. HALLWAY DOOR OUTSIDE OF ROOM 5625. Finished
FO-268872	12/2/2013	12/4/2013		Must have Mullion (pole between back doors) removed for delivery of cans from Gleaners food
FO-268680	12/2/2013	12/3/2013		R/R RM 228/CLASS RM TOWARDS THE FRONT OF CLASS NEAR BLACKBOARD WINDO
FO-268688	12/2/2013	12/3/2013		please replace missing ceiling tiles in room 2156...Thanks Finished 12/4/2013LT
FO-268819	12/3/2013	12/9/2013		please replace ceiling tiles in hallway of 3rd floor office wing near conference room 3145.. Fini
FO-268847	12/3/2013	12/4/2013		UPPER DOOR HINGE IS LOOSE. DOOR 13-WEST. Finished 12/6/2013 LT
FO-268861	12/3/2013	12/6/2013		Perimeter door #17 (in stairwell F) - Door frame is corroded/rusted at floor level making door di
FO-268865	12/3/2013	12/5/2013		Perimeter door #5 (in stairwell D) - Door slams closed very quickly/hard. Please adjust. Finish
FO-268993	12/4/2013	12/4/2013		RM 2110 LOCK IS STRIPPED
FO-269036	12/4/2013	12/6/2013		please cut access hole in ceiling of garage near roll up door, pipe isa leaking and plumber nee
FO-269076	12/4/2013	12/5/2013		RM 378 DOOR HANDLE AND LOCK BROKEN, IF DOOR IS CLOSED SOMEONE COULD B
FO-269205	12/6/2013	12/9/2013		RM 127 BLINDS FALLEN OFF TRACK Finished 12/10/2013LT
FO-269229	12/6/2013	12/9/2013		Door handle from inner kitchen door fell out as well as door handle to basement is not working
FO-269285	12/9/2013	12/11/2013		R/R INVESTIGATE DOOR LOCK FOR ENTRANCE DOOR IN MAIN BLDG FROM THE LOA
FO-269310	12/9/2013	12/10/2013		Purdy Library 1st Floor, Room 134
FO-269332	12/9/2013	12/10/2013		The 2N door to the stacks was repaired, but now
FO-269364	12/9/2013	12/10/2013		RM 7001.1 LOCK JUST SPINNINGFinished 12/16/2013LT
FO-269442	12/10/2013	12/13/2013		Ceiling tiles in room 333 are falling down.Finished 12/16/2013LT
FO-269701	12/11/2013	12/13/2013		1011 E. Ferry
FO-269702	12/12/2013	12/13/2013		Please repair interior overhead door in EDC Weld Shop area. Dor is not working.Finished 12/
FO-269792	12/12/2013	12/13/2013		Handicap door button does not turn on automatic opener door N13 across from elevator.Finish
FO-269832	12/12/2013	12/13/2013		CARPENTERS TO REPAIR CEILING TILES MAIN ENTRANCE @ LIGHTED FIRE EXIT ARE
FO-269903	12/12/2013	12/13/2013		The lock is not working properly in 2140. It is very difficult to open and the close the door with
FO-269897	12/13/2013	12/13/2013		Door #023-05W
FO-269971	12/13/2013	12/16/2013		Carpenter, please build wooden structure to block off cold deck in AHU-1. Priority: highFinishe

WO	Recieved	Finished	Total	Request
FO-269972	12/13/2013	12/16/2013		Carpenter, please build wooden structure to block off cold deck in AHU-2. Priority: high Finis
FO-270060	12/16/2013	1/16/2014		Front door to building #074 01 N does not latch.Finished 12/17/2013LT
FO-270097	12/16/2013	12/17/2013		Carpenters: please repair or replace loose floor tiles in hall way in front of rooms 425 and 421.
FO-270108	12/16/2013	12/18/2013		There are floor tiles lifting up outside of the room 1010 where the old drinking fountain used to
FO-270113	12/16/2013	12/17/2013		Carpenters, please cover dampers in room 31 with plywood. Dampers do not close. Priority hi
FO-270118	12/16/2013	12/17/2013		KEY STICKS IN DOOR LOCK. ROOM 100.. Finished 12/23/2013LT
FO-270131	12/16/2013	12/17/2013		Two broken tiles in the instrument room in 249 Life Sciences need to be replaced - trip hazard
FO-270884	12/17/2013	12/18/2013		Adding Carpenters: provide access in wall for plumbing repair and repair when plumbers are d
FO-270941	12/17/2013	12/18/2013		R/R RM 0501/DLAR INSIDE DOOR KNOB FELL OFF UNABLE TO EXIT ROOM Finished 12/
FO-270987	12/18/2013	12/18/2013		R/R ENT DOOR #005-17N Officer performing building check at night states that door 005-17N
FO-271019	12/18/2013	12/20/2013		DOOR BROKEN AT TOP. HINGE IS COMING LOOSE. BASEMENT ENTRANCE DOOR TO
FO-271065	12/19/2013	12/23/2013		Please repair loading dock door.
FO-271106	12/19/2013	12/20/2013		Carpenter repair open windows in both womens rest rooms on first floor. Priority high, security
FO-271413	12/24/2013	12/26/2013		R/R BSMT STORAGE RM DOOR LOCK NOT LOCKING/LATCHING Finished 12/27/2013LT
FO-271436	12/26/2013	12/26/2013		CARPENTERS TO REMOVE 2ND FLOOR BATHROOM PARTITIONS FOR DAVID KUFFNE
FO-271443	12/26/2013	12/30/2013		Adding Carpenter: Please put more screws in backing board for new drinking fountain near roo
T - Electrician			71	
FO-268603	12/1/2013	12/2/2013		Repair fault in fire alarm system. Panel reads, "Signal circuit operated open".
FO-268640	12/2/2013	12/2/2013		BLDG ENTRANCES ELECTRONICS AREN'T RELEASING DOORS TO BE UNLOCKED Fini
FO-268659	12/2/2013	12/2/2013		R/R RM 2348 TROUBLESHOOT/RESET BREAKER (PLS NOTE IF FRIDGE IS BLOWING O
FO-268808	12/3/2013	12/10/2013		Please disconnect domestic hot water pump #2 and re-connect #1. mech room 1414...see Ro
FO-268815	12/3/2013	12/6/2013		Emergency - Please replace 4 lights in gym 111 that have suposedly burned-out...A lift will be
FO-268864	12/3/2013	12/6/2013		Perimeter door #6 (in stairwell K) - Light in emergency exit sign not lit. Please fix. Finished 12/
FO-268975	12/4/2013	12/4/2013		Put electric cord at window for the Christmas tree lights, Wednesday morning. Finished 12/6/2
FO-269084	12/5/2013	12/10/2013		STE 400 LIGHT FIXTURE IN HALL WAS REMOVED TO FIX LEAK, LEAK HAS BEEN FIXED
FO-269189	12/6/2013	12/6/2013		R/R BLDG FAP FIRE TROUBLE ALARM ACTIVATED Finished 12/10/2013LT
FO-269191	12/6/2013	12/6/2013		Sewage lift pump #1 does not work. When engaged it hums then trips circuit breaker. Please
FO-269267	12/6/2013			R/R RM 2310/CLASS RM CHEM FUMEHOOD FAN MOTOR TRIPPING.
FO-269258	12/7/2013			Repair faulty duct smoke detector located on Supply Fan #1.
FO-269324	12/9/2013	12/10/2013		In Engineer's office. Circuit to the computer trips when used. Need access asap. Finished 12
FO-269356	12/9/2013	12/10/2013		STE LIGHT FIXTURE HANGING Finished 12/11/2013LT
FO-269363	12/9/2013			Adding Electrician: Disconnect power to domestic water pump on left. motor will be removed fro
FO-269393	12/9/2013	12/10/2013		Check and supply fuses for control circuit to pumps. Finished 12/11/2013LT
FO-269420	12/10/2013	12/10/2013		R/R 3RD FLR RMS 326-330 LOST POWER IN OUTLETS (CUBICLE AREA) Finished 12/11/2
FO-269425	12/10/2013	12/10/2013		R/R BLDG FAP FIRE TROUBLE ALARM Finished 12/11/2013LT
FO-269462	12/10/2013	12/10/2013		Outlets to (south) back wall is not working.
FO-269475	12/10/2013	1/11/2014		R/R RM 6203 IN BACK AREA NEAR THE SHREDDING MACHINE 1/2 THE POWER WENT
FO-269492	12/10/2013	12/11/2013		BASKETBALL NET WILL NOT GO UP. GYM 109. MIDDLE BASKETBALL. Finished 12/12/2
FO-269586	12/11/2013	12/17/2013		pls repair heating fan motor as nesc
FO-269603	12/11/2013	12/11/2013		R/R 1ST FLR CIRC DESK AREA APPR 3 BREAKERS NEED TO BE RESET Finished 12/12/
FO-269607	12/11/2013	12/11/2013		R/R 3RD FLR RMS 326-330 LOST POWER AGAIN IN OUTLETS (CUBICLE AREA) Finished
FO-269621	12/11/2013	12/11/2013		ELECTRICAL DEPT-(DWBPS #1 & #2)
FO-269661	12/11/2013			Adding Electrician: Test and replace elements in electric hot water heater on 3rd floor womens
FO-269739	12/12/2013	12/12/2013		R/R BLDG/FAP FIRE TROUBLE ALARM Finished 12/13/2013LT
FO-269745	12/12/2013	12/12/2013		R/R BLDG/FAP FIRE TROUBLE ALARM Finished 12/13/2013LT
FO-269747	12/12/2013	12/12/2013		Repair wall fixtures in the parking lot, on back of building. Finished 12/13/2013LT
FO-269815	12/12/2013	12/13/2013		Replace front of EXIT sign outside of Gym 111.. Finished 12/16/2013LT

WO	Recieved	Finished	Total	Request
FO-269834	12/12/2013	12/13/2013		Electrical strip is pulled up behind seat #19.
FO-269912	12/13/2013			Trade: Electricians
FO-269942	12/13/2013	12/13/2013		In the north hallway, the custodial room has a smoke detector in it, and it's beeping. Please r
FO-269953	12/13/2013	12/27/2013		Adding Electrician: Disconnect condensate pump #1. See Ron Clark for location if needed
FO-269957	12/13/2013			There are 3 EPs in gym #109 & 2 fixtures out in Gym #111. There is 1 additional EP in front of
FO-270002	12/14/2013	12/16/2013		During the afternoon shift on Friday, 12-13-13, Public Safety reported a fire trouble alarm. En
FO-270021	12/16/2013	12/26/2013		LABORER TO PICKUP 150 CHAIRS @ STUDENT CENTER & BRING DOWN 15 TABLES F
FO-270054	12/16/2013	12/16/2013		Elect. High Priority
FO-270111	12/16/2013	12/26/2013		electrician amp. out #20 pump controls & probe in water column,pump not coming on priority h
FO-270122	12/16/2013	12/17/2013		electrician troubleshoot #35 circulating pump motor & mcc control panel.priority high. Finished
FO-270123	12/16/2013	12/26/2013		electrician troubleshoot #35 circulating pump motor & mcc control panel.priority high. pump ke
FO-270902	12/17/2013	12/17/2013		R/R RM 277 HAS NO POWER IN WALL OUTLETS Finished 12/18/2013LT
FO-270904	12/17/2013	12/17/2013		R/R RM 3226.3 LOST POWER IN BOTH CLNG LITES & WALL OUTLETS Finished 12/18/20
FO-270905	12/17/2013	12/17/2013		R/R RM 3226.4 LOST POWER IN BOTH CLNG LITES & WALL OUTLETS Finished 12/18/20
FO-270924	12/17/2013			Adding Electrician: please replace elements in domestic hot water tank located in 3rd floor jani
FO-270930	12/17/2013	12/17/2013		Time for PM Technologies to repair Generator for Dantos. Finished 12/18/2013LT
FO-270956	12/17/2013	12/17/2013		Meet PM Technologies Mechanic at the switchgear room to let them in, and give him access t
FO-271017	12/18/2013			Relamp beeping fixture in room 160, Northeast corner.
FO-271076	12/19/2013	12/19/2013		Install 70Amp breaker in generator for block heater.. Finished 12/19/2013LT
FO-271090	12/19/2013	12/20/2013		HEAT PUMP WIRES ARE EXPOSED. BACK OF BUILDING. Finished 12/23/2013LT
FO-271105	12/19/2013			There is a supervisory trouble alarm on the fire panel. Please have electricians correct.
FO-271144	12/20/2013	12/27/2013		Adding Electrician: replace motor for condensate pump #1 . Motor Info givin to Eugene 12-20-
FO-271169	12/20/2013	12/27/2013		please disconnect clear water pump farthest from wall in fan room 2.....see Mike or Don... Fini
FO-271364	12/23/2013			R/R RM 0025/MECH RM SAF #1 need to be checked for burn up motor and contact. This fan
FO-271372	12/23/2013			R/R RM 00025/MECH RM The condensate pump No.1 motor burn up during this power outa
FO-271371	12/23/2013			R/R RM 0032/MECH RM the exhaust fan(in the President area) will not run ,due to the power
FO-271373	12/23/2013			R/R RM 00025/MECH RM The condensate pumps are not working ,due to the power outage p
FO-271229	12/23/2013	12/23/2013		WDET RADIO STATION BREAKER OUT Finished 12/26/2013LT
FO-271365	12/24/2013	12/24/2013		R/R RM 0025/MECH RM SAF #3 beed to be checked for burn up motor and contact.. This fa
FO-271366	12/24/2013	12/24/2013		R/R RM 0025/MECH RM SAF #5 need to be checked for burn up motor and contact. This fan
FO-271367	12/24/2013	12/26/2013		R/R RM 0025/MECH RM SAF #6 need to be checked for burn up motor and contact. This fan
FO-271368	12/24/2013	12/26/2013		R/R RM 0025/MECH RM SAF #7 need to be checked for burn up motor and contact. Fan will
FO-271369	12/24/2013	12/26/2013		R/R RM 0025/MECH RM SAF #8 need to be checked for burn up motor and contact. Fan will
FO-271414	12/24/2013	12/26/2013		ELECTRICIANS,
FO-271433	12/26/2013			Adding Electrician: Please check operation of sewage ejectors mechanical room 23 . See Ray
FO-271437	12/26/2013	12/26/2013		Assist in receiving delivery from FedEx and moving item(s) to penthouse. Expect delivery 12/2
FO-271440	12/26/2013			ELECTRICIANS TO SUPPLY LOW VOLTAGE LINE TO THE MAIN ENTRANCE ADA DOOR
FO-271458	12/27/2013	12/27/2013		Fire Pump in alarm, please reset to normal. Finished 12/28/2013LT
FO-271463	12/27/2013	12/27/2013		Install Knack panel on fire system, and check to insure all is working properly. Finished 12/28/
FO-271466	12/27/2013	12/27/2013		Repair electrical problem preventing fan from starting. Finished 12/28/2013LT
FO-271477	12/30/2013	12/30/2013		Repair Fire Alarm Panel causing erratic fan operation - unable to reset.Finished 12/31/2013LT
T - Laborer			3	
FO-269636	12/11/2013	12/13/2013		Adding Laborer: Transport Rostabout lift from Chemistry subasement to room 100 at Scott hal
FO-271114	12/19/2013	12/23/2013		Adding Laborer: Please pick up material for Pipe Shop on Friday 12-20-13. See John Towle fo
FO-271149	12/20/2013			Adding Laborer: Relocate pump frame from Pipe Shop to sub basement of Chemistry. See Mi
T - Locksmith			9	
FO-268839	12/3/2013	12/3/2013		#75120 8 Keys Finished 12/4/2013LT
FO-269678	12/11/2013	12/11/2013		#75140 1 Key Room 8133Finished 12/16/2013LT

WO	Recieved	Finished	Total	Request
FO-269794	12/12/2013			2-KEYS REQUEST 75142
FO-269796	12/12/2013	12/13/2013		REQUEST 75143 2-KEYSFinished 12/16/2013LT
FO-270040	12/16/2013	12/17/2013		75088 2-KEYS Finished 12/23/2013LT
FO-271040	12/18/2013	12/23/2013		#75148 1 Key Finished 12/26/2013LT
FO-271118	12/19/2013	12/26/2013		75151 1-core 6-keys split existing core and provide 6- keys Finished 12/27/2013LT
FO-271119	12/19/2013	12/30/2013		75112 1-KEYFinished 12/31/2013LT
FO-271147	12/20/2013	12/23/2013		Safe in Pipe Shop will not open . See John Finished 12/26/2013LT
T - Pipefitter			26	
FO-268837	12/3/2013	12/5/2013		OFFICE NEXT TO RM 4144 CEILING LEAK.....JH...12-3-13 Finished 12/10/2013LT
FO-269060	12/4/2013	12/16/2013		Pipefitters/High Please replace leaking relief valve on Boiler. (Faulty Valve) 3/4" x 1" 1,391
FO-269062	12/4/2013			RM 010 CEILING LEAK, NEAR COMPUTER AND EXIT SIGN ,,,,,,,,,,,,,, ME/12-6-13 ,,,,,,,,,,,,,,
FO-269271	12/9/2013	12/10/2013		FITTERS: Please repair Boiler gas line piping on Boiler in Penthouse. (gas leak) HIGH....ME/1
FO-269302	12/9/2013			(**)STEAMFITTERS-
FO-269371	12/9/2013	12/10/2013		Trade: Pipefitter
FO-269383	12/9/2013	12/11/2013		Fitters, please repair leak in steam coil on AHU-2. Priority: High,,,,,,,,,,,,,,,,, ME/12-10-13,,,,,,,,,,,,,
FO-269386	12/9/2013	12/10/2013		Pipefitters/High Please repair leaking condensate piping near condensate reciever ,,,,,,,,,,,,,, J
FO-269458	12/10/2013	12/10/2013		R/R domestic water pump seals pump #2 room 1502 ,,,,,,,,,,,,,,,,,, RC/ 12-10-13 ,,,,,,,,,,,,,,,,,, DU
FO-269583	12/11/2013	12/11/2013		CEILING LEAK. HALLWAY OUTSIDE OF ROOM 5450.01....., ME/12-11-13 ,,,,,,,,,,,,,,,,,,
FO-269632	12/11/2013	12/12/2013		Adding Pipefitter:Fabricate a base for winch . See Attachment ,,,,,,,,,,,,,, JH/12-11-13,,,,,,,,,,,,,,,,,
FO-269928	12/13/2013			Trade: Pipefitter
FO-269930	12/13/2013			Trade: Pipefitter
FO-270049	12/16/2013	12/16/2013		Fitters, please repair steam coil leak on AHU-1 in PH. Priority: High,,,,,,,,,,,,,,,,, JH/12-16-13 ,,,,
FO-270051	12/16/2013	12/17/2013		Fitters, please repair steam coil leak on AHU-2 in PH. Priority: High,,,,,,,,,,,,,,,,, JH/12-16-13 ,,
FO-270090	12/16/2013			PIPEFITTERS please install heating unit for engineers office. room 36 degrees today. hydroni
FO-271060	12/18/2013	12/19/2013		Trade: Pipefitter
FO-271156	12/20/2013			HALLWAY OUTSIDE 5450.01 CEILING LEAK,,,,,,,,,,,,,,,,, EA/RC 12-23-13 ,,,,,,,,,,,,,,,,,, DUE A
FO-271182	12/20/2013	12/23/2013		heating coil on ac-1 leaking on to floor used a vacuum cleaner to pickup water so it doesn't lea
FO-271363	12/22/2013			FITTERS:R/R PENTHOUSE Please repair the coil leaks in ACU #1 in the penthouse mecha
FO-271227	12/23/2013	12/30/2013		PF High Priority
FO-271233	12/23/2013	12/24/2013		Pipe at ceiling is leaking. Over the weekend it leaked enough to fill up two trashcans with wat
FO-271247	12/23/2013	12/24/2013		Ceiling leak in Dr. Frade's office #330. Per Dr. Frade - As noted by the soaked rippled carpet
FO-271267	12/23/2013	12/30/2013		steam fitter please repair leaking 2"cap & nipple on preheat steam supply to 3rd coil in ac-12,a
FO-271400	12/24/2013			please repair steam leak in pipe chase
FO-271402	12/24/2013	12/27/2013		please repair steam leak in pipe chase
T - Plumber			65	
FO-268619	12/2/2013			(**)Plumber please replace broken faucet attachment in custodial closet rm. 21. Priority: high..
FO-268626	12/2/2013			(**)Trade: Plumber
FO-268677	12/2/2013	12/3/2013		R/R RM 151.2/UNISEX RR ONLY TOILET AUTO SENSOR ISN'T WORKING & ALSO THE T
FO-268849	12/3/2013	12/5/2013		Purdy Library 2nd Floor
FO-269009	12/4/2013	12/9/2013		Plumber repair broken drain pipe in garage ceiling. Priority high.....MM...12-4-13 Finished 12/
FO-269018	12/4/2013	12/9/2013		Clogged toilet in women's restroom. 1st Floor, Room 1378.....MM...12-4-13 Finished 12/11/2
FO-269074	12/4/2013	12/17/2013		Room 1378 - Ladies Rest Room - Toilet in last stall will not flush. Please fix,,,,,,,,,,,,,,,,, RJC/
FO-269075	12/4/2013	12/9/2013		Women's restroom: second stall, toilet sprays water upward from valve when flushed. Bagged
FO-269087	12/5/2013	12/9/2013		Emergency shower is leaking and making a puddle on the floor. Classes are in session.....,
FO-269099	12/5/2013	12/5/2013		R/R RM 249 The eye wash station that leaked has left a puddle. Please send a custodian to c
FO-269102	12/5/2013	12/9/2013		R/R 1ST FLR MENS RR OFF OF ATRIUM BOTH TOILETS ARE PLUGGED & NEED TO BE
FO-269106	12/5/2013	12/9/2013		BOTH TOILET WILL NOT FLUSH. 1ST FLOOR MEN'S RESTROOM. (FRONT OF BUILDIN
FO-269122	12/5/2013	12/24/2013		the 3900 and 4900 suite have no hot water the toilets have low psi and do not flush properly SI

WO	Recieved	Finished	Total	Request
FO-269137	12/5/2013	12/30/2013		TOILET LEAKING AT BOTTOM. 1ST FLOOR WOMEN'S RESTROOM..... RJC/RB 1
FO-269139	12/5/2013	12/19/2013		2 SINK SENSORS ARE NOT WORKING. 2ND FLOOR MEN'S RESTROOM. ROOM 208.....
FO-269200	12/6/2013	12/6/2013		R/R RM 220 SINK ACROSS FROM FUMEHOOD #11 FAUCET WILL NOT SHUT OFF
FO-269201	12/6/2013	12/6/2013		R/R RM 220 SINK ACROSS FROM FUMEHOOD #11 FAUCET WILL NOT SHUT OFF
FO-269202	12/6/2013	12/6/2013		R/R RM 350 ALL 3 SINK FAUCETS WILL NOT SHUT OFF MP/DB 12-6-13
FO-269206	12/6/2013	12/9/2013		2ND FL MENS RM NEAR STAIRS, SINK PLUGGED RJC/RB 12-6-13
FO-269270	12/9/2013	12/16/2013		Mens rest room in back of the first floor has a toilet stopped up.
FO-269288	12/9/2013	12/27/2013		Purdy Library 1st Floor, Room 140: Women's Restroom
FO-269306	12/9/2013	12/12/2013		TOILET IS NOT FLUSHING. LADIES RESTROOM. ROOM 2216..... MM/12-9-13 ,...
FO-269309	12/9/2013	12/10/2013		LOW WATER PRESSURE IN WATER FAUCETS. 7TH AND 8TH FLOORS.....MM/9-12-13 ,
FO-269311	12/9/2013	12/10/2013		toilet backed up 2nd floor mens room 2238....MP/DB 12-9-13..... DUE 12-11-13 Finish
FO-269318	12/9/2013			PLUMBERS (HIGH)
FO-269350	12/9/2013	12/10/2013		FUME HOOD #3 WATER LEAKS WHEN WATER IN TURNED ON. ROOM 130.
FO-269358	12/9/2013	12/10/2013		Trade: Plumbers
FO-269373	12/9/2013	12/11/2013		Plumbers,
FO-269408	12/10/2013	12/11/2013		No hot water in sink in room 205..... MM/12-10-13 DUE 12-12-13 Finished 1
FO-269461	12/10/2013	12/17/2013		1ST FL WOMENS RM TOILET CONTINUOUSLY RUNNING RJC/RB 12-16-13 ,...
FO-269592	12/11/2013	12/12/2013		SINK LEAKING UNDERNEATH. ROOM 200.04..... MM/12-11-13 DUE 12-1
FO-269610	12/11/2013			(**)R/R 2ND FLR ONLY WOMENS RR ONLY TOILET IS CON'T FLUSHING CAUSING FLOO
FO-269625	12/11/2013	12/12/2013		PLUGGED SINK. 7TH FLOOR LADIES RESTROOM OFF MAIN LOBBY..... MP/DB 1
FO-269644	12/11/2013	12/17/2013		PLUMBERS
FO-269668	12/11/2013			The drinking fountain (near the nFab lab) on the 3rd floor has a water leak. It has water drippi
FO-269744	12/12/2013	12/23/2013		TOILET IS FLUSHING VERY HARD AND WATER IS SPILLING OUT ONTO FLOOR. 4TH F
FO-269770	12/12/2013	1/13/2014		SEWAR GAS SMELL COMING OUT OF FLOOR DRAIN. CUSTODIAL CLOSET. 1ST FLOO
FO-269801	12/12/2013	12/16/2013		PLUGGED TOILET - 1ST FLOOR MEN'S RESTROOM - ROOM 1238..... RJC/RB 12-1
FO-269921	12/13/2013	12/16/2013		Leaking at base of pipes that flush toilets
FO-269923	12/13/2013	12/13/2013		second floor ladies room (no room number) sink next to trash can water draining very slow. - c
FO-269951	12/13/2013	12/16/2013		BSMNT MENS RM, RIGHT FAUCET IS NOT WORKING MP/DB 12-16-13
FO-269969	12/13/2013	12/17/2013		SINK DRAINS SLOWLY. ROOM 464..... MM/12-16-13 DUE 12-15-13 Fi
FO-270044	12/16/2013	12/19/2013		Bathroom stall in the women's restroom in the west wing corridor on the 2nd floor is stopped u
FO-270059	12/16/2013	12/17/2013		TOILET CONTINUOUSLY FLUSHING. 1ST FLOOR UNISEX RESTROOM..... RJC/RB
FO-270086	12/16/2013			UNISEX RESTROOM ACROSS FROM 142 SEWAGE SMELL RJC/RB 12-16-13,,
FO-270087	12/16/2013	12/17/2013		BSMNT MENS RM EDC TOILET AND URINAL BACKED UP..... MP/DB 12-16-13 ,...
FO-270091	12/16/2013	12/16/2013		4TH FL LADIES RM CONT FLUSHING..... MP/DB 12-16-13 DUE 12-18-13
FO-270115	12/16/2013	12/18/2013		FAUCET LEAKING AT TOP. ROOM 2229..... MM/12-17-13 DUE 12-18-1
FO-270895	12/17/2013	12/19/2013		LAB 130 SINK IN FRONT OF FH 5 LEAKING MP/DB 12-19-13 DUE 12
FO-270943	12/17/2013			(**)ELECTRICIANS please r/r control for domestic water booster pumps at Mort Sci. control s
FO-270958	12/17/2013	12/30/2013		please repair hot and cold water faucet handles....spinning and wont turn on or off...See kevin
FO-270960	12/17/2013	12/19/2013		RM 2229 FAUCET LEAKING MM/12-19-13 DUE 12-19-13 Finished 12/2
FO-270988	12/18/2013			Plumbers, repair leak in discharge pipe from sanitary #1 pump. priority high RJC/
FO-270993	12/18/2013	12/19/2013		Trade: Plumber
FO-271041	12/18/2013	12/20/2013		RM 5565 FAUCET FROM WALL IS LEAKING..... MM/12-18-132 DUE 12-2
FO-271127	12/20/2013	12/20/2013		Replace domestic hot water tank 3rd floor janitors Tank is now leaking closet MM/1
FO-271139	12/20/2013	12/23/2013		MENS RM WITHIN STE 2317 URINAL CONTINUOUSLY RUNNING MP/DB 12-20
FO-271142	12/20/2013	12/20/2013		CEILING LEAK. HALLWAY OUTSIDE OF ROOM 5463. MM/12-20-13
FO-271187	12/20/2013			PLUMBERS please replace flange gaskets on pool filter isolation valves leaking bad. also the
FO-271218	12/23/2013	12/23/2013		3RD FL WOMENS RM SINK PLUGGED MP/DB 12-13-13 DUE 12-25-1

WO	Recieved	Finished	Total	Request
FO-271268	12/23/2013	12/26/2013		Sewage lift pump #2 continues to jam and trip breakers. Very hi priority have plumbers repair
FO-271438	12/26/2013			Re-Pack domestic water booster pumps room 100 ,,,,,,,,,,,,,, MM/12-16-13 ,,,,,,,,,,,,,, DUE
FO-271448	12/26/2013	12/27/2013		R/R self priming drain trap 2ed floor womens shower ,,,,,,,,,,,,,, MM/12-26-13 ,,,,,,,,,,,,,, DUE 1
FO-271449	12/26/2013	12/27/2013		R/R failed domestic hot water galvanized pipe near hot water tanks room 110 ,,,,,,,,,,,,,, MM/
FO-271460	12/27/2013			Check operations of Pit Bull pump in old acid sump located in basement mechanical room ,,,,,
T - Roofing			1	
FO-271152	12/20/2013			CEILING LEAK. ROOM 4228.
Medium			155	
T - Carpenter			34	
FO-268850	12/3/2013	12/6/2013		please replace ceiling tiles in room 9248...Plumbes have completed there work. Finished 12/1
FO-268863	12/3/2013	12/5/2013		Perimeter door #9 (in stairwell H) - Door is not closing and latching on its own. Please correct.
FO-268981	12/4/2013	12/9/2013		Officers state their locker room door (223A) has to be pushed closed. Finished 12/10/2013LT
FO-269019	12/4/2013	12/5/2013		The door that leads to the racquetball & squash courts on the southwest side of the building h
FO-269023	12/4/2013	12/6/2013		Door knob on Room 306 is loose. Missing one screw and one screw is stripped. Finished 12/1
FO-269149	12/5/2013	12/6/2013		R/R RM 236 (entrance dr to student lng w/# on it) YOU ARE UNABLE TO INSERT KEY IN D
FO-269147	12/5/2013	12/6/2013		609-04N DOOR CLOSER NEEDS ADJUSTING,DOOR NOTCLOSING PROPERLY Finished
FO-269152	12/5/2013	12/9/2013		Please hang white board that recently fell off the wall. Finished 12/10/2013LT
FO-269195	12/6/2013	12/9/2013		INSIDE DOOR LOCK STICKS. LADIES RESTROOM. ROOM 1212. Finished 12/10/2013LT
FO-269197	12/6/2013	12/9/2013		1ST FL KITCHENETTE BETWEEN RM A&B WINDOW SHADE NEEDS TO BE FIXED
FO-269198	12/6/2013	12/9/2013		2ND FL RM J WINDOW SHADE NEEDS TO BE FIXED Finished 12/10/2013LT
FO-269239	12/6/2013			Clean gutters on Freer House before they
FO-269266	12/6/2013			Repair or replace rotten window sills and
FO-269361	12/9/2013	12/13/2013		please re-install ceiling tiles in hallway outside room 9211, Plumber has completed his work...s
FO-269398	12/9/2013	12/11/2013		Adding Carpenter: Install cover box where old drinking fountain was . 1st floor next to womens
FO-269448	12/10/2013	12/11/2013		Door knob mechanism is coming loose (the
FO-269455	12/10/2013			door closure arm on main entrance door to gallery is broken.
FO-269978	12/13/2013	12/16/2013		Male officers' locker room door is still staying ajar.Finished 12/17/2013LT
FO-270064	12/16/2013			Carpenters, please place weather stripping around 1st floor east entrance doors
FO-270894	12/17/2013	12/19/2013		Carpenter; Medium
FO-270964	12/17/2013	12/18/2013		Please add a door closure to this office door (office 6005). Also, the glass in this door is loose
FO-271016	12/18/2013	12/24/2013		There are three rooms that actually have blinds down. One of them is 114. The other two are
FO-271052	12/18/2013			Carpenters to replace popped up tiles in Bio-Sciences Lab room 2151.
FO-271063	12/18/2013			Adding Carpenters: Please remove cinder block to access plumbing repair. See Mike McAlind
FO-271064	12/18/2013	12/19/2013		Staff having a hard time getting into her office using her key and we think it's possibly a key co
FO-271070	12/19/2013	12/26/2013		Adding Carpenters: Replace ceiling tile next to projector room in auditorim 2009 Finished 12/2
FO-271071	12/19/2013	12/20/2013		Adding Carpenters: Repair cracked/broken window frame in office 3009.3. See Debra Zabari f
FO-271087	12/19/2013	12/23/2013		Carpenters:
FO-271186	12/20/2013	12/23/2013		Have Joe repair handicap door operation on #609 05 N. SEE ALLEN KOTAL FOR DETAILS.
FO-271226	12/23/2013	12/24/2013		Room 2240 door to this electrical closet does not close automatically. Finished 12/26/2013LT
FO-271236	12/23/2013	12/24/2013		CARPENTERS: Please repair door closers near doors 603 11 & 12 North. slamming due to wi
FO-271249	12/23/2013	12/24/2013		Carpenters-please remove ceiling grid so heat pump can be removed from cieling. Hallway in f
FO-271265	12/23/2013			Metal molding above main entrance doors has come loose. Molding is visible from second floo
FO-271439	12/26/2013			Adding Carpenter: Please add hinges to counter for pluming access in room 6126 located insi
T - Electrician			33	
FO-268664	12/2/2013	12/3/2013		R/R RM 0123.02 ON ONE SIDE WALL OUTLETS LOST POWER Finished 12/4/2013LT
FO-268678	12/2/2013	12/3/2013		Trade: Electrician Priority: Medium
FO-268802	12/3/2013			Electrician; Medium
FO-268803	12/3/2013	12/5/2013		Time for Safety Meeting Thursday December 5, 2013. Finished 12/6/2013LT

WO	Recieved	Finished	Total	Request
FO-268806	12/3/2013	12/11/2013		repair or replace boiler feed pump #2
FO-268841	12/3/2013	12/9/2013		Please move roust a bout crane from fp&m stockroom to room 100 at scott hall...any question
FO-268843	12/3/2013	12/26/2013		please build scaffle in mech room 0024 near 6 inch styeam shut off valve...see Jim Hill in pipe
FO-268979	12/4/2013	12/9/2013		Please relocate pallet of junk next to pump#1 sewage injector pumps located in sub basement
FO-268988	12/4/2013	12/6/2013		Trade: Laborer
FO-269025	12/4/2013	12/6/2013		On the first floor Warren entrance there is a lamp is out in stairwell D - lamp next to it is also fli
FO-269082	12/5/2013			Please investigate exterior lighting on Cust Grounds bldg [North wall, gravel lot]. (2) exterior lig
FO-269109	12/5/2013	12/6/2013		Electrician
FO-269141	12/5/2013	12/9/2013		Laborer; Medium
FO-269150	12/5/2013	12/9/2013		Correct wiring in basement, see photo attached. Finished 12/10/2013LT
FO-269218	12/6/2013	12/10/2013		Replace motor to exhaust fan for the restrooms on the 3rd floor. Finished 12/11/2013LT
FO-269259	12/8/2013	12/9/2013		Repair faulty recepticles located on wall in Hot Kitchen. One recepticle has burnt up, and two
FO-269260	12/8/2013	12/9/2013		Repair light switch controlling ceiling lights in Hot Kitchen. Finished 12/10/2013LT
FO-269647	12/11/2013	12/19/2013		Electrician; Medium
FO-269769	12/12/2013	12/13/2013		R/R 1ST FLR LOBBY AREA (@ATM MACHINE) WALL OUTLET NEEDS RESETTNG. Finish
FO-269996	12/13/2013			RM 9310 TOO COLD
FO-270110	12/16/2013	12/17/2013		ELECTRICIAN OUTSIDE LIGHTS NOT WORKING ON NORTH SIDE
FO-271082	12/19/2013	12/20/2013		Install light over domestic water booster pump room 0346. See Mike Pummill for location Finis
FO-271190	12/20/2013			Please pick up old coil in mechanical room 32 and put in holden lock up. Corey Blair can assi
FO-271418	12/23/2013	12/27/2013		University Electricians to move 20A, 240V
FO-271224	12/23/2013	12/23/2013		1 of 2 re: Electrical Closets
FO-271225	12/23/2013	12/23/2013		2 of 2 re Electrical Closets
FO-271248	12/23/2013	12/27/2013		Electricians-please remove light fixture so heat pump un it can be removed from cieling. Hallw
FO-271261	12/23/2013			Adding Electrician: Please provide 2 new motors. Ron Clark will be installing new seals/bearin
FO-271270	12/23/2013			The exhaust fans on the 3rd flr which serve entire building will not start. Switch in rm 45 bsmt
FO-271396	12/24/2013	12/27/2013		Men's Room 2438 ... hand blower needs attention ... it doesn't work Finished 12/28/2013LT
FO-271395	12/24/2013			Four clocks in UGL need attention, either to reactivate, repair or replace. Two on Third Floor
FO-271552	12/30/2013	12/30/2013		Re-term pump motor, and remove lock from disconnect.Finished 12/31/2013LT
FO-271472	12/30/2013			Adding Electrician: Please disconnect / reconnect sump pump. See Mike McAlinden for locatio
T - Laborer			3	
FO-269098	12/5/2013			Adding Laborer: Relocate 2 pumps in the basement of Mattaei to Science Hall mechanical roo
FO-269359	12/9/2013	12/30/2013		Adding Laborer: Transport sink from basement of 5425 Woodward to Paint Shop. See Ray / R
FO-271246	12/23/2013			Adding Laborer: Transport pump frame from Pipe Shop to sub-basement of Chemistry . See
T - Locksmith			7	
FO-268624	12/2/2013	12/9/2013		62436 7-CORES 20 KEYS Finished 12/10/2013LT
FO-268631	12/2/2013	12/2/2013		#74803 24 Keys Finished 12/3/2013LT
FO-268686	12/2/2013	12/4/2013		75089 3-KEYS Finished 12/6/2013 LT
FO-269155	12/5/2013	12/6/2013		75131 5-KEYS Finished 12/10/2013LT
FO-269337	12/9/2013	12/9/2013		75133 6-KEYS Finished 12/10/2013LT
FO-270890	12/17/2013	12/23/2013		Please replace block key 27A 89806 issue #093 Finished 12/26/2013LT
FO-271120	12/19/2013	12/24/2013		REQUEST 75150 2-CORES 3-KEYS Finished 12/26/2013LT
T - Painter			2	
FO-270084	12/16/2013			WDET hallway painting request:
FO-271444	12/26/2013			Adding Painter: Please finish new backing board repairs and paint wall so Plumber can re-han
T - Pipefitter			27	
FO-268691	12/2/2013	12/23/2013		please chk float on surge tank in basement, valve is bleeding by, cant get a possotive shut-off.
FO-268859	12/3/2013	12/4/2013		PIPEFITTERS please r/r drip from steam pipe above "sterling" heating unit in boiler room at B
FO-268860	12/3/2013	12/5/2013		PIPEFITTERS please repair drip from steam line directly next to the back door (from the insid

WO	Recieved	Finished	Total	Request
FO-268983	12/4/2013			Trade: Pipefitter Priority Medium
FO-269015	12/4/2013	12/9/2013		FITTERS: Please repair/replace bad steam trap in room 130 lower level mech room. ATTN. JI
FO-269059	12/4/2013	12/6/2013		FITTERS,
FO-269193	12/6/2013	12/6/2013		Heat Exhchanger #2 is leaking by. We are getting hardness in our boilers due to this problem.
FO-269263	12/8/2013	12/13/2013		Repair flange leak on 6 inch main hp steam supply. Located in basement mechanical room. L
FO-269326	12/9/2013			FITTERS:
FO-269493	12/10/2013	12/16/2013		STEAMFITTERS-PLEASE REPAIR LEAKING B&G CIRCULATING PUMP#5 IN FURNACE R
FO-269594	12/11/2013	12/13/2013		Fitters - Medium. Please install check valve in discharge piping off each of the three control ai
FO-269626	12/11/2013	12/13/2013		FITTERS: Please repair steam coil leak (pinhole) in AHU#6. This leaks when steam valve is o
FO-269665	12/11/2013	12/16/2013		Steam Fitters Med Priority
FO-269670	12/11/2013	12/17/2013		Brace motor frame on supply fan #1. See Mario for info ,,,,,,,,,, JH/12-11-13 ,,,,,,,,,, DU
FO-269939	12/12/2013	12/12/2013		R/R ball valve on tempering line. Room 100 ,,,,,,,,,, ME/12-12-13 ,,,,,,,,,, DUE 12-26-1
FO-269899	12/12/2013	12/17/2013		Called to check wet carpet, found leaking valve in the rooms heat loop. Please reference FO-
FO-269922	12/13/2013	12/17/2013		Adding Pipefitter: Fabricate frame for new Gorman Rupp sewage ejector. See Mike Pummill ,,,
FO-269929	12/13/2013	12/24/2013		Plumbers,
FO-269931	12/13/2013			Trade: Pipefitter
FO-270088	12/16/2013	12/17/2013		PIPEFITTERS please repair dripping pipe from radiator at back door to BEECHER HOUSE. st
FO-270094	12/16/2013			PIPEFITTERS please replace trap in Larry Fodors office. Radiator not heating as it should. Co
FO-270095	12/16/2013			PIPEFITTERS please replace trap in lounge next to Larry Fodors office. radiator not heating a
FO-270897	12/17/2013	12/18/2013		FITTERS Please repair Humidity Valve with O-ring fitting. Leaking in DLAR. MED.
FO-271067	12/19/2013	12/20/2013		FITTERS,
FO-271204	12/23/2013	12/31/2013		live steam blowing through condensate
FO-271207	12/23/2013			condensate return pump room 11 failed ,,,,,,,,,, RC/12-23-13 ,,,,,,,,,, DUE 1-6-13
FO-271209	12/23/2013			See Project Manager Omar Alhyari (577-8983) for scheduling. Pipe fitters need to install isolati
T - Plasterer			2	
FO-268834	12/3/2013			WALL NEEDS TO BE REPAIRED SQUIRRELS HAVE EATEN A WHOLE IN WALL.
FO-270962	12/17/2013			There is a wall in the Fishbowl area that needs to be repaired plaster has been removed and t
T - Plumber			46	
FO-268662	12/2/2013	12/4/2013		Men's Restroom. 1st Stall is not working.....MM...12-2-13 Finished 12/6/2013 LT
FO-268665	12/2/2013			Plumber; Medium
FO-268679	12/2/2013	12/10/2013		R/R RM 143/RESTROOM (TOILET W/BAG OVER IT) ISN'T FLUSHING/....MM..12-2-13 Finis
FO-268712	12/2/2013	12/3/2013		R/R RM 13100.1/UNISEX RR ONLY TOILET NOT FLUSHING....MM/DB...12-3-13 Finished 12
FO-268796	12/3/2013	12/4/2013		please chk 2nd floor urinal constantly running, it's located closest to the wall and is out of servi
FO-268813	12/3/2013			Plumb Med. Priority
FO-268827	12/3/2013	12/5/2013		PLUMBER 4TH FLOOR WOMEN RESTROOM FAUCET NOT WORKING
FO-268828	12/3/2013	12/5/2013		PLUMBER MEN RESTROOM 1ST FLOOR URNAL NOT WORKING
FO-268978	12/4/2013			Please re-locate 2 centrifigal pumps from basement to science hall mech. room #3....MP/DB.
FO-268994	12/4/2013	12/4/2013		Trade: Plumber Priority: Medium
FO-269024	12/4/2013	12/31/2013		1ST FL WOMENS RM (2) SINKS LEAKING....RB/RC...12-4-13
FO-269039	12/4/2013	12/26/2013		WOMEN'S RESTROOM 4TH FLOOR--4 SINKS CLOGGED. PLEASE UNCLOG AS SOON A
FO-269107	12/5/2013	12/10/2013		plumber basement men restroom sink faucet
FO-269115	12/5/2013	12/18/2013		PLUMBER WOMEN RESTROOM 2ND FLOOR
FO-269116	12/5/2013	12/5/2013		Replace elements in domestic hot water tank 3rd floor janitors closet ,,,,,,,,,, MM/12-5-13 ,,
FO-269126	12/5/2013	12/23/2013		1ST URINAL IS NOT FLUSHING. 1ST FLOOR MEN'S RESTROOM....., RJC/RB 12-6
FO-269156	12/5/2013	12/10/2013		R/R 2ND FLR STAFF LNG ACROSS FROM CLINICAL SKILLS DEPT KITCHEN SINK COLD
FO-269160	12/5/2013	12/10/2013		R/R RM 136/WOMENS RR FIRST SINK (COMBINED) WTR FAUCET COMES OUT IN A TRI
FO-269225	12/6/2013	12/31/2013		R/R clear water pump near stairwell #1 ,,,,,,,,,, 12-6-13 ,,,,,,,,,, DUE 12-20-13 Finished
FO-269235	12/6/2013	12/6/2013		Faucet in left-hand sink does not work. Dead battery? ,,,,,,,,,, MM/12-9-13 ,,,,,,,,,, DU

WO	Recieved	Finished	Total	Request
FO-269268	12/6/2013	12/11/2013		The 2nd floor men's restroom urinal appears not
FO-269272	12/9/2013	12/9/2013		Plumbers please replace broken toilet seat in women's 1st floor restroom handicap stall.....
FO-269287	12/9/2013	12/23/2013		Repair leak under the sink RJC/RB 12-9-13 DUE 12-23-13 Finished 12/
FO-269340	12/9/2013	12/24/2013		R/R 3RD FLR WOMENS RR (ONLY ONE) SINK NEXT TO DISPENSER IS DRAINING VERY
FO-269343	12/9/2013	12/9/2013		Women's restroom, Margherio Conference Center: handicap toilet is out of order. Please repai
FO-269344	12/9/2013			Trade: Plumbers Priority: Medium
FO-269357	12/9/2013			Diconnect sink in basement and reconnect in Paint Shop. See Tim Herr for location
FO-269490	12/10/2013	12/10/2013		R/R slone valve room 153 RJC/RB 12-10-13 DUE 12-24-13 Finished 12/11/
FO-269491	12/10/2013	12/24/2013		7TH FL WATER FOUNTAIN NEEDS FILTER MP/DB 12-11-13 DUE 1
FO-269529	12/10/2013	12/20/2013		PLUMBERS
FO-269528	12/11/2013			Broken faucet at sink. AT present no handle.
FO-269629	12/11/2013	12/20/2013		R/R RM 215/LAB Three sinks are leaking in the embalming lab. The 1st two sinks and the 4th
FO-269805	12/12/2013			SINK DRAINS SLOWLY. ROOM 7908..... MP/DB 12-16-13 DUE 12-26-
FO-269960	12/13/2013	12/19/2013		LAB 260 WATER ASPORATER LEAKING ON FL
FO-269977	12/13/2013	12/16/2013		4TH FL WOMENS LEFT SINK NOT WORKING..... MP/DB 12-16-13 DUE 1
FO-270038	12/16/2013	12/17/2013		TOILET LEAKS WHEN FLUSHED. 1ST FLOOR LADIES RESTROOM..... RJC/RB 1
FO-270109	12/16/2013	12/18/2013		Restroom: apparent leak, possibly from toilet or sink. Water is puddling on the floor.....
FO-270909	12/17/2013	12/23/2013		Restroom 322.10: faucet is not working properly. Battery dying? MM/12-19-13
FO-270923	12/17/2013			(**)PLUMBERS: Please repair Sump Pump operation. Float does not work properly. Pump#2
FO-271004	12/18/2013	12/23/2013		PLUGGED TOILET. LADIES RESTROOM. ROOM 1378..... MM/12-19-13
FO-271029	12/18/2013	12/18/2013		RM 6013 LADIES RM NO WATER PLEASE SEE THERESA IN 6203 Finished 12-1
FO-271123	12/19/2013	12/23/2013		Restroom 322.10: toilet is slow/doesn't flush well..... MM/12-20-13 DUE 1-3
FO-271128	12/20/2013			Trade: Plumbers
FO-271155	12/20/2013	12/24/2013		plumbers please clear sink drain on left.in mens rm. priority,med.(sink over flows).....
FO-271251	12/23/2013			Plumber; Medium
FO-271461	12/27/2013	12/27/2013		R/R leaking faucet located on 3rd floor Mechanical room. Slop sink request will need to be fun
T - Roofing			1	
FO-269664	12/11/2013			Roofer Med Priority
Low			364	
T - Carpenter			108	
FO-268604	12/2/2013	12/2/2013		CARPENTER TO TIGHTEN ALL THE SCREWS TO MOUNTING PLATE 3RD FLOOR STAIR
FO-268655	12/2/2013	12/3/2013		Door not closing all the way. Doesn't shut on it's own. Finished 12/4/2013LT
FO-268689	12/2/2013	12/2/2013		cap3- 319 screw loose on door hinge state hall room 27 Finished 12/3/2013LT
FO-268695	12/2/2013	12/2/2013		cap3-347 screw missing loose on door hinge state hall rm. 111 Finished 12/3/2013LT
FO-268696	12/2/2013	12/2/2013		cap3 -356 screw missing loose on door hinge rm. 113 state hall Finished 12/3/2013LT
FO-268700	12/2/2013	12/2/2013		cap3-357 window diffuser not seated properly Finished 12/3/2013LT
FO-268842	12/2/2013	12/9/2013		In the lower level, one of the double doors leading to the staff only area (mechanical room hall
FO-268795	12/3/2013	12/4/2013		Loading dock pedestrian door 499-32SB has gap at bottom of door near the door frame. Easy
FO-268792	12/3/2013			TEAM LEADER TIME (DECEMBER 2013)
FO-268811	12/3/2013	12/4/2013		CARPENTER TO REPAIR HOLE IN DRY WALL ROOM # 1500 Finished 12/6/2013 LT
FO-268844	12/3/2013	12/5/2013		Replace Detex lock sytem on back exit door inside Room-598 to a mortised lockset system wi
FO-268830	12/3/2013	12/3/2013		cap3-353 window diffuser not seated properly Finished 12/4/2013LT
FO-268832	12/3/2013	12/3/2013		cap3-363 state hall screw missing loose on door hinge Finished 12/4/2013LT
FO-268835	12/3/2013	12/3/2013		cap3-368 screw missing loose on door hinge rm 117 Finished 12/4/2013LT
FO-268845	12/3/2013	12/3/2013		cap3-386 missing screw loose on door hinge rm. 123 state hall Finished 12/4/2013LT
FO-269006	12/4/2013	12/4/2013		cap3-349 state hall rm. 111 window diffuser not seated properly Finished 12/6/2013 LT
FO-269010	12/4/2013	12/4/2013		cap3-365 state hall rm. 115 window diffuser not seated properly Finished 12/6/2013 LT
FO-269011	12/4/2013	12/4/2013		cap3-384 state hall rm.124 windows boarded Finished 12/6/2013 LT

WO	Recieved	Finished	Total	Request
FO-269035	12/4/2013	12/5/2013		cap3-307 state hall basement mens bathroom tile loose above urinals Finished 12/10/2013LT
FO-269037	12/4/2013	12/5/2013		cap3-308 state hall basement wall cores between lockers Finished 12/10/2013LT
FO-269049	12/4/2013	12/6/2013		cap3-395 state hall missing wall base 1st floor exit 4 Finished 12/10/2013LT
FO-269054	12/4/2013	12/6/2013		cap3-369 state hall window diffuser not seated properly 1st. floor room 117 Finished 12/10/20
FO-269113	12/5/2013	12/9/2013		CARPENTERS,
FO-269117	12/5/2013	12/5/2013		CARPENTER TO ATTEND SAFETY MEETING (DECEMBER 2013) Finished 12/10/2013LT
FO-269118	12/5/2013			CARPENTER TO REPAIR THE HOLE IN THE CEMENT NORTH SIDE ALLEY RAMP @ STE
FO-269119	12/5/2013	12/5/2013		CARPENTER TO BARRICADE SIDE WALK SAFETY ISSUE Finished 12/10/2013LT
FO-269120	12/5/2013	12/6/2013		CARPENTERS TO SURVEY THE ROOF FOR GUARD RAILS Finished 12/10/2013LT
FO-269124	12/5/2013	12/10/2013		CARPENTERS TO REPAIR DOOR FLUSH BOLTS ROOM # 2105 NOT LATCHINGFinished
FO-269138	12/5/2013	12/10/2013		REATTACH PROJECTION SCREEN TO WALL. CLASSROOM 189.Finished 12/16/2013LT
FO-269367	12/5/2013	12/11/2013		Project Name: Remove anchor pads
FO-269157	12/5/2013	12/20/2013		Old Main . Please have Carpenter fabricate & install wooden shelf in the Engineer control roo
FO-269158	12/5/2013			Met. Center. Please have Carpenter fabricate & install wooden shelf in the Engineer control ro
FO-269159	12/5/2013	12/16/2013		Karmanos. Please have Carpenter fabricate & install wooden shelf in the Engineer control roo
FO-269161	12/5/2013	12/13/2013		Elliman. Please have Carpenter fabricate & install wooden shelf in the Engineer control room.
FO-269162	12/5/2013	12/11/2013		Bonstelle. Please have Carpenter fabricate & install wooden shelf in the Engineer control roo
FO-269163	12/5/2013	12/23/2013		CS Mott. Please have Carpenter fabricate & install wooden shelf in the Engineer control room.
FO-269164	12/5/2013	12/24/2013		Applebaum. Please have Carpenter fabricate & install wooden shelf in the Engineer control ro
FO-269165	12/5/2013			Skillman. Please have Carpenter fabricate & install wooden shelf in the Engineer control room
FO-269167	12/5/2013			University Tower. Please have Carpenter fabricate & install wooden shelf in the Engineer contr
FO-269168	12/5/2013			University Tower. Please have Carpenter fabricate & install wooden shelf in the Engineer contr
FO-269169	12/5/2013	12/10/2013		University Tower. Please have Carpenter fabricate & install wooden shelf in the Engineer contr
FO-269170	12/5/2013	12/10/2013		Manoogian. Please have Carpenter fabricate & install wooden shelf in the Engineer control roo
FO-269171	12/5/2013	12/10/2013		Chatsworth. Please have Carpenter fabricate & install wooden shelf in the Engineer control ro
FO-269173	12/5/2013			Chatsworth. Please have Carpenter fabricate & install wooden shelf in the Engineer control ro
FO-269174	12/5/2013	12/11/2013		5057 Woodwrad. Please have Carpenter fabricate & install wooden shelf in the Engineer contr
FO-269175	12/5/2013			5425 Woodward. Please have Carpenter fabricate & install wooden shelf in the Engineer contr
FO-269176	12/5/2013			Schaver. Please have Carpenter fabricate & install wooden shelf in the Engineer control room.
FO-269194	12/6/2013	12/30/2013		CARPENTERS TO PURCHASFinished 12/31/2013LT
FO-269224	12/6/2013	12/9/2013		R/R RM 1540 The door closest to the card access door in 1540 still does not close properly.
FO-269226	12/6/2013	12/10/2013		R/R RM 3348/WOMENS LOCKER RM ENTRANCE DOOR IS MISSING A SCREW FROM D
FO-269227	12/6/2013	12/10/2013		R/R RM 3348/WOMENS LOCKER RM BENCH NEAR ENTRANCE DOOR NEEDS TO BE SE
FO-269236	12/6/2013	12/30/2013		CARPENTERS TO REMOVE THE DAMAGED FENCEING IN THE MEDIA OF WARREN AV
FO-269362	12/9/2013	12/9/2013		cap3-372 state hall window diffuser not seated properly Finished 12/10/2013LT
FO-269365	12/9/2013	12/10/2013		cap-3 404 state hall missing wall base 2nd floor outside womens restroomFinished 12/16/201
FO-269368	12/9/2013	12/9/2013		cap3- 411 state hall window diffuser not seated properly 2nd floor room 218
FO-269372	12/9/2013	12/9/2013		cap3- 412 state hall wall diffuser not seated properly 2nd floor rm. 218 Finished 12/10/2013LT
FO-269388	12/9/2013	12/27/2013		R/R RM 138/SVC CTR NEED TO HAVE TRADES X SHTS CUT IN HALF Finished 12/30/201
FO-269441	12/10/2013	12/10/2013		cap3-390 state hall vct lifting off 1st floor rm. 128Finished 12/16/2013LT
FO-269443	12/10/2013	12/10/2013		cap3-391 state hall vct lifting off1st. floor rm. 129Finished 12/16/2013LT
FO-269445	12/10/2013	12/10/2013		cap3-409 state hall vct lifting off 2nd. floor rm. 219Finished 12/16/2013LT
FO-269457	12/10/2013			Trade: Carpenters
FO-269645	12/11/2013	12/12/2013		Parking Structure 8-
FO-269660	12/11/2013	12/13/2013		R/R RM 110/GYM Repair shoe (floor) medal molding inside gym 110 on the south side of the
FO-269663	12/11/2013	12/12/2013		CARPENTERS,
FO-269679	12/11/2013	12/11/2013		cap3-417 state hall vct lifting off 2nd floor in front of classroom rm. 216Finished 12/16/2013LT

WO	Recieved	Finished	Total	Request
FO-269680	12/11/2013	12/11/2013		cap3-418 state hall vct lifting off 2nd floor rm. 215Finished 12/16/2013LT
FO-269683	12/11/2013	12/11/2013		CARPENTER TO REMOVE BARRICADE WARREN AVE SIDEFinished 12/16/2013LT
FO-269797	12/12/2013	12/12/2013		CARPENTERS TO INSTALL KICK DOWN STOPS @ ALL GYM ENTRANCESFinished 12/16/
FO-269822	12/12/2013	12/13/2013		R/R 3RD FLR MENS RR (ONLY ONE)NEAR ELEVS REPAIR WINDOW BLINDSFinished 12/
FO-269829	12/12/2013	12/12/2013		cap3-447 state hall loose door hinge screw missing 3rd floorm 319Finished 12/16/2013LT
FO-269830	12/12/2013	12/13/2013		cap3-448 plywood nailed to door 3rd floor rm. 320Finished 12/16/2013LT
FO-269831	12/12/2013	12/12/2013		CARPENTERS TO CLEAN FOR THE CHRISTMAS PARTYFinished 12/16/2013LT
FO-269908	12/13/2013			cap3m- material required for entire building
FO-269910	12/13/2013			cap3m materials needed for entire building education
FO-269911	12/13/2013			cap3m material needed for entire building old main
FO-269913	12/13/2013			cap3m material needed for entire building state hall
FO-269917	12/13/2013			cap3m material needed for entire building welcome center
FO-270019	12/16/2013	12/19/2013		CARPENTERS TO SET UP FOR THE 2013 FP&M CHRISTMAS PARTY Finished 12/23/201
FO-270053	12/16/2013			Carpenters, please place weather stripping on bottom of door leading out to cooling tower.
FO-270080	12/16/2013	12/16/2013		Carpenters: please repair mechanical room door,the door hit the door jamb and doesn't latch
FO-270089	12/16/2013	12/16/2013		#75146 3 Keys and 1 Core Finished 12/17/2013LT
FO-270092	12/16/2013	12/16/2013		cap3-316 state hall tile lifting off basement rm 31 Finished 12/17/2013LT
FO-270098	12/16/2013	12/16/2013		cap3-421 state hall missing ceiling tiles rm. 213 Finished 12/17/2013LT
FO-270099	12/16/2013	12/16/2013		cap3- 424 state hall holes in ceiling tiles rm. 211 Finished 12/17/2013LT
FO-270100	12/16/2013	12/17/2013		cap3-439 state hall window diffuser not seated properly rm. 303 Finished 12/23/2013LT
FO-270124	12/16/2013			CARPENTRY please weatherstrip door to elevator mechanical room at MORT SCI. Door on N
FO-270907	12/17/2013	12/16/2013		To cover the cost for the Carpenter's jobs for the Winter Commencement at Matthaei
FO-270946	12/17/2013	12/17/2013		cap3- 427 state hall vct lifting off rm. 208 Finished 12/23/2013LT
FO-270948	12/17/2013	12/18/2013		cap3-464 state hall missing ceiling tiles rm. 334 Finished 12/23/2013LT
FO-271022	12/18/2013	12/20/2013		Carpenters: please anchor the following seats to the floor;
FO-271045	12/18/2013	12/18/2013		cap3-455 state hall vct lifting off rm. 327 Finished 12/23/2013LT
FO-271047	12/18/2013	12/18/2013		cap3-466 state hall vct lifting off rm. 334 Finished 12/23/2013LT
FO-271059	12/18/2013	12/19/2013		cap3-440 state hall missing ceiling tiles 3rd floor mens rm. Finished 12/23/2013LT
FO-271068	12/19/2013	12/26/2013		CARPENTERS,
FO-271103	12/19/2013	12/20/2013		Carpenters: Please repair door locks on doors to rooms 433 and 416. They do not latch. Priori
FO-271104	12/19/2013	12/23/2013		Carpenters: please repair loose floor tiles in following areas:
FO-271112	12/19/2013	12/19/2013		cap3-449 state hall missing ceiling tiles rm. 324 Finished 12/23/2013LT
FO-271131	12/20/2013	12/23/2013		Repair Coat storage rack detaching from Wall.
FO-271170	12/20/2013	12/20/2013		cap3-463 state hall missing ceiling tile 3rd floor womens restroom Finished 12/23/2013LT
FO-271171	12/20/2013	12/20/2013		cap3-467 state hall missing wall base 3rd floor rm. 334 Finished 12/23/2013LT
FO-271173	12/20/2013	12/23/2013		cap3-453 state hall chip in door 3rd. floor stair 4 Finished 12/26/2013LT
FO-271234	12/23/2013	12/23/2013		CARPENTERS TO PREPARE THE FOOD & ATTEND CHRISTMAS PARTY 2013 Finished 1
FO-271245	12/23/2013			CARPENTERS TO CLEAN UP CHRISTMAS PARTY 2013
FO-271361	12/24/2013	12/24/2013		cap3-815 welcome center provide corner wall protection 3rd floor staff kitchen Finished 12/26/
FO-271442	12/26/2013	12/24/2013		CARPENTERS TO LEAVE @ 11:30AM 12/24/1013 Finished 12/26/2013LT
FO-271446	12/26/2013	12/26/2013		cap3-845 welcome center realign metal cover panel at window 2nd floor Finished 12/27/2013L
FO-271447	12/26/2013	12/26/2013		cap3-843 replace damaged carpet tile 2nd floor welcome center main corridor Finished 12/27/
FO-271459	12/27/2013	12/27/2013		cap3- 830 welcome center wall protection 3rd. floor staff kitchen Finished 12/30/2013LT
T - Electrician			114	
FO-268675	12/2/2013	12/20/2013		Trade: Electrician Priority: Low
FO-268697	12/2/2013	12/4/2013		Circuit for room 104 and front reception area has tripped nine times today and we cannot figur
FO-268838	12/2/2013			we have lights out behind the front desk at the main lobby. Also need to have three controls c

WO	Recieved	Finished	Total	Request
FO-268821	12/3/2013	12/13/2013		1) 1 fixture out in mens restroom (10th floor, west wing)
FO-268822	12/3/2013	12/12/2013		2 fixtures out in room# 2125 Finished 12/13/2013LT
FO-268823	12/3/2013	12/12/2013		1 EP in first floor, ladies bathroom entrance, over head (student center side of building) Finish
FO-268824	12/3/2013			1) 2 EP in room# 239. Fixture is a retag, former date 10/31/13. From prereq. requesting more I
FO-268826	12/3/2013	12/17/2013		1 EP, fixture is between rooms 212 and 214 in the hallway Finished 12/18/2013LT
FO-268831	12/3/2013	12/5/2013		Lights out in Carp. break room. Please repair Finished 12/6/2013LT
FO-268972	12/4/2013	12/5/2013		Repair clock in hallway by room 256. Finished 12/6/2013LT
FO-268973	12/4/2013	12/4/2013		Repair clock in main Lobby. Finished 12/6/2013 LT
FO-268977	12/4/2013	12/5/2013		Trade: Electrician Priority: low
FO-268985	12/4/2013			repair replace the hand off auto switch
FO-268996	12/4/2013	12/3/2013		Time to complete PM work on generator, Finished 12/4/2013LT
FO-268997	12/4/2013	12/3/2013		Time to complete the PM work on Danto Generator. Finished 12/4/2013LT
FO-268998	12/4/2013	12/3/2013		Time to complete the PM work on the Generator. Finished 12/4/2013LT
FO-268999	12/4/2013	12/3/2013		Time to complete PM work on all 4 Generators. Finished 12/4/2013LT
FO-269028	12/4/2013	12/6/2013		Time for PM Technologies to oversee the Full Load Generator Test Friday 12/6/2013, at 2:15P
FO-269081	12/5/2013	12/11/2013		please move 40 gallon hot water tank from pipe shop to 60 west canfield basement. See Ray
FO-269085	12/5/2013	12/27/2013		4 fixtures out in room# 258 Finished 12/28/2013LT
FO-269086	12/5/2013			1 fixture out in room#255.
FO-269088	12/5/2013	12/9/2013		2 fixtures out in room# 601
FO-269089	12/5/2013			1 Fixture out in the Hall, back of the cages in the grounds Department.
FO-269090	12/5/2013	12/6/2013		1 Fixture out. Outdoor light alongside of the Knapp Building. The EP id the middle one. It's a M
FO-269091	12/5/2013	12/13/2013		1 Fixture out. Overhead light across from the elevator (1st floor). Its next to the monitor. Finish
FO-269130	12/5/2013	12/11/2013		1) 2 fixtures out in the hallway outside of ranges 140 and 257. (1st floor)
FO-269131	12/5/2013	12/13/2013		1 fixture out . Spot light outside of the Einstein Brothers Store. Finished 12/16/2013LT
FO-269183	12/6/2013	12/6/2013		Wire in Valve for Pool. Finished 12/10/2013LT
FO-269223	12/6/2013	12/12/2013		2 EP's in the box office - very dark The bulbs have been removed due to flashing rapidly URG
FO-269249	12/7/2013	12/31/2013		MEN'S ROOM #1346. MISSING GFI COVER. Finished 12/31/2013LT
FO-269257	12/7/2013			3RD FLOOR LADIES ROOM LAB WING SIDE. INVESTIGATE NOISY FAN. SEE CHET PUT
FO-269286	12/9/2013	12/20/2013		In room 3126, there is an EP over the desk, this is small private office and dim. Finished 12/2
FO-269320	12/9/2013	12/11/2013		GENERATOR TEST, to be done on December 11, 2013 @ 9:15 AM. Finished 12/12/2013LT
FO-269342	12/9/2013			Please have Maintenance Laborer take all wooden pallets from FP&M stockroom and deliver t
FO-269391	12/9/2013			Laborer; MediumR/R RM 00010/MECH RM Please remove the old blow down tank a
FO-269400	12/10/2013	12/19/2013		Electrician repair or re lamp three exterior pole lights servicing north Grounds storage yard. All
FO-269406	12/10/2013	12/12/2013		LABORER TO DELIVER ONE MAN LIFT FROM UGL TO MATTHAEI TUESDAY @ 2:15
FO-269422	12/10/2013	12/30/2013		There is 1 EP in classroom #25 of the basementFinished 12/31/2013LT
FO-269426	12/10/2013			There is 1 EP in cannister located at the 2nd floor level in stairwell H.
FO-269428	12/10/2013	12/20/2013		There is 1 EP in Dean's room office 1151 on the 1st floor of Engineering. Finished 12/23/2013
FO-269429	12/10/2013			Laborer Med. PriorityR/R RM 187.01/MECH RM Assist engineer in relocating work bench fr
FO-269431	12/10/2013			Repair clock in room 153.
FO-269434	12/10/2013	12/12/2013		R/R BLDG Light on South side on the roof is not working as far as we can tell. We have been
FO-269432	12/10/2013	12/10/2013		Repair clock in hallway near room 379. Finished 12/11/2013LT
FO-269433	12/10/2013	12/10/2013		Repair clock in hallway near room 425. Finished 12/11/2013LT
FO-269435	12/10/2013	12/10/2013		Repair clock in hallway near room 477. Finished 12/11/2013LT
FO-269580	12/10/2013			raise and adjust light covers in faculty offices
FO-269646	12/11/2013	12/12/2013		Parking Structure 5-
FO-269648	12/11/2013	12/12/2013		Repair clock on 4th floor. Finished 12/13/2013LT
FO-269653	12/11/2013	12/11/2013		This is for the time spent by Siemans to do the correction work on the Generator Transfer Gea

WO	Recieved	Finished	Total	Request
FO-269758	12/12/2013	12/17/2013		1 light out in room #0311 Finished 12/18/2013LT
FO-269761	12/12/2013	12/20/2013		In room #403 the fixture is a light in the ceiling to the left of the entrance. Finished 12/23/2013
FO-269763	12/12/2013	12/27/2013		2 EPs. In room #115 fixture over head of entrance. In 4th floor men's bathroom, fixture over la
FO-269765	12/12/2013	12/13/2013		In room #133 fixture is out over head upon entrances.. Finished 12/16/2013LT
FO-269766	12/12/2013	12/23/2013		1 fixture out in Stair B of 5th floor Finished 12/26/2013LT
FO-269768	12/12/2013	12/31/2013		1 fixture out in hallway alongside of room 1420. Finished 12/31/2013LT
FO-269787	12/12/2013	12/12/2013		Repair bad clock on 1st floor. Finished 12/13/2013LT
FO-269788	12/12/2013	12/12/2013		Bad clock on 1st floor. Finished 12/13/2013LT
FO-269812	12/12/2013	12/23/2013		Please have Maintenance Laborer move 3 metal cabinets from FP&M Stockroom to Holden W
FO-269827	12/12/2013	12/12/2013		Move man lift from Matthaai to UGL Primary room. Finished 12/13/2013LT
FO-269906	12/13/2013			Please have Maintenance Laborer deliver 4 pails Oxycor , 2 pails Quest from FP&M Stockroo
FO-269933	12/13/2013			R/R Please repair the space unit heaters over the doors in the garage area of 100 Antoinette.
FO-269946	12/13/2013	12/13/2013		There is 1 EP in front of Gym #111 and ladies room, light flickering constantly. had to remove
FO-269949	12/13/2013	12/19/2013		Basement ranges, panel switches 13,18,24 are not working, which is causing the lights to stay
FO-269954	12/13/2013	12/18/2013		Adding Electrician: Disconnect condensate pump #2 next to engineers office. See Ron Clark
FO-269958	12/13/2013	12/16/2013		Repair Clock in room 027. Finished 12/17/2013LT
FO-269959	12/13/2013	12/17/2013		Repair clock in room 029. Finished 12/18/2013LT
FO-269973	12/13/2013	12/23/2013		1 fixture out in room #145 Finished 12/26/2013LT
FO-269993	12/13/2013	12/20/2013		1 EP on the first floor in hallway across from the stairwell facing the reuther library on Finished
FO-270068	12/16/2013			Generators didn't start for Monday morning no load test this morning, and it didn't start last we
FO-270101	12/16/2013			2 fixtures out, EXIT signs outside of rooms 022 and 036.
FO-270103	12/16/2013			EXIT sign outside of the stairwell on 1st floor that leads to DAPCEP.
FO-270104	12/16/2013			Exit sign outside of the freight elevator on the 1st floor
FO-270128	12/16/2013	12/23/2013		6 fixtures out on the 5th floor of bio science just to the right of the elevators. The corridor is da
FO-270912	12/17/2013	12/18/2013		Repair clock in hallway on the 3rd floor.. Finished 12/19/2013LT
FO-270914	12/17/2013	12/18/2013		Repair clock in mens locker room.. Finished 12/19/2013LT
FO-270942	12/17/2013			Replace lights in rooms 153 and 182. There is a cover missing outside of room 153.Also if it's
FO-270985	12/18/2013	12/31/2013		The light lens on the 2nd floor outside of the elevator was hanging down & it would not go bac
FO-271042	12/18/2013	12/19/2013		Repair clock on first floor lounge. Finished 12/19/2013LT
FO-271044	12/18/2013	12/19/2013		Time for Electricians to attend Winter Carnival.. Finished 12/19/2013LT
FO-271046	12/18/2013	12/20/2013		There is 1 EP directly over customer work area. The area is difficult to diagnose check work ar
FO-271069	12/19/2013			Please have Maintenance Laborer deliver one pallet of salt to Chemistry building. Needed bef
FO-271079	12/19/2013			We have flickering lights or lights that are out in
FO-271088	12/19/2013	12/30/2013		2 EP in stairway facing the Prentice buildingFinished 12/31/2013LT
FO-271093	12/19/2013	12/19/2013		Time for Wolverine to repair Generator #3. Finished 12/19/2013LT
FO-271108	12/19/2013	12/20/2013		There is 1 EP in the meter room. This is very old. 8-2-13 Please forward to electricians. Finish
FO-271109	12/19/2013	12/19/2013		Time to attend Holiday dinner.. Finished 12/19/2013LT
FO-271116	12/19/2013			Purdy Library, 2nd Floor, Office Suite 231
FO-271132	12/20/2013	12/20/2013		Time for Wolverine to repair Generator #4 turbo. Finished 12/23/2013LT
FO-271157	12/20/2013	12/23/2013		There is 1 EP as soon as you enter the Dean's office room 3135. Please forward to electrician
FO-271159	12/20/2013	12/20/2013		Time to assist in replacing Lightening arrestors on Primary Cables. Finished 12/23/2013LT
FO-271160	12/20/2013	12/24/2013		There are 2 EPs directly over professor's desk. Please forward to electricians. Finished 12/26/
FO-271177	12/20/2013	12/20/2013		Replacement PPE flame resistant pants for WSU Electricians. MIOSHA requirement for arc fl
FO-271189	12/20/2013			electric shop.R/R RM 0195/MECH-BLR RM Have Dennis deliver 10 bags of softner salt. Use
FO-271235	12/23/2013	12/27/2013		Hallway outside of room 1616 has 3 lights out. Enter thru room 1600. 1 electrical problem. Fini
FO-271254	12/23/2013			2 EPs. Room 114 center desk fixture. Room 114.6 over head light fixture.
FO-271256	12/23/2013			3 EPs. 1 over exit sign. 2nd is third row from the stage in aisle way. State Hall side of the audit

WO	Recieved	Finished	Total	Request
FO-271260	12/23/2013	12/26/2013		2 EPs. Lights over the cabinets near the ranges (basement) Finished 12/27/2013LT
FO-271262	12/23/2013	12/27/2013		8 EPs. Hallway outside of ranges 6,7,8,23,29,30,35 and 48 (basement) Finished 12/28/2013LT
FO-271263	12/23/2013	12/26/2013		5 EPs. Ranges 17, 60, 81, 84 and 86. basement Finished 12/27/2013LT
FO-271264	12/23/2013	12/27/2013		1 EP in room #1545Finished 12/31/2013LT
FO-271399	12/24/2013			R/R RM 0033 2 Fluorescent lamps out. (CK LITES AFTER CHNGING ARE STILL OUT)
FO-271401	12/24/2013	12/24/2013		Time to cover Electricians for President Wilson's noon closing of the university. Finished 12/2
FO-271406	12/24/2013	12/27/2013		1 EP men's restroom between rooms 130 and 136Finished 12/31/2013LT
FO-271409	12/24/2013	12/26/2013		In room 136, 6 light lenses are missing. Please replace. I don't have any of the lenses in the c
FO-271410	12/24/2013	12/26/2013		Light switch is working in the stairwell outside of room 063 Finished 12/27/2013LT
FO-271412	12/24/2013			West stairwell facing 5057 Woodward has broken and cracked lenses. Also, there are 4 missi
FO-271417	12/24/2013			R/R RM 2620 BLOWN FUSE RESET BREAKER
FO-271452	12/26/2013			Maintenance Labor to clean up and dispose floor tile and concrete debris from second floor w
FO-271464	12/27/2013	12/27/2013		Install reset button inAir Handling Unit. Finished 12/28/2013LT
FO-271467	12/27/2013	12/30/2013		Repair reset buttons on Air Handlers 3, 5, 7, and the condensate in Alumni.Finished 12/31/20
FO-271473	12/30/2013	12/30/2013		Time for Cummins Bridgeway to repair Generator.Finished 12/31/2013LT
FO-271476	12/30/2013	12/27/2013		Time spent to get tire repaired, Electricians had to drive to Grounds, and they changed the tire
FO-271478	12/30/2013	12/30/2013		Time for Wolverinr to repair generator at the Towers. Finished 12/30/2013LT
T - Handyman			1	
FO-269020	12/4/2013			Office in Physics room # 13 in basement needs painting the color is WSU YELLOW.
T - Laborer			7	
FO-268852	12/3/2013	12/3/2013		Remove scaffold from basement. Finished 12/4/2013LT
FO-268995	12/4/2013	12/3/2013		Time for Dennis to complete job for Mario. Finished 12/4/2013LT
FO-269003	12/4/2013			Collect Insulation thru out the campus mechanical rooms and store in the sheetmetal area.
FO-269004	12/4/2013			Remove excess carpenter and plumbing material from penthouse and 1st. floor.
FO-269187	12/6/2013	12/9/2013		Adding Laborer: Please transport material from stockroom to scott hall . See Mike McAlindine
FO-269370	12/9/2013			Adding Laborer:Transport 3",4" galvanized pipe from Scott Hall mechanical room 100 back an
FO-271434	12/26/2013	12/24/2013		Time for Dennis to go to Home Depot, and pick-up Freezer. Finished 12/26/2013LT
T - Locksmith			43	
FO-268627	12/2/2013	12/2/2013		#73769 16 Keys Rooms 33462,33178,33230,33125 Finished 12/3/2013LT
FO-268628	12/2/2013	12/2/2013		#74699 1 Key Room 5113 Finished 12/3/2013LT
FO-268630	12/2/2013	12/2/2013		#45766 3 Keys Room 5108 Finished 12/3/2013LT
FO-268632	12/2/2013	12/2/2013		#73630 3 Keys Room 3330 Finished 12/3/2013LT
FO-268633	12/2/2013	12/3/2013		#72165 2 Keys Finished 12/4/2013LT
FO-268634	12/2/2013	12/3/2013		#70278 13 Keys Rooms 199,347,462,463 Finished 12/4/2013LT
FO-268685	12/2/2013	12/3/2013		71665 10-KEYS Finished 12/4/2013LT
FO-268794	12/3/2013			KEYS & CORES (DECEMBER 2013)
FO-268840	12/3/2013	12/3/2013		#75105 3 Keys Finished 12/4/2013LT
FO-269013	12/4/2013	12/5/2013		#75127 1 Core Finished 12/10/2013LT
FO-269014	12/4/2013	12/4/2013		#75121 4 Keys and 2 Cores Room 1115 Finished 12/6/2013 LT
FO-269029	12/4/2013	12/9/2013		#74304 1 Keys Room 1230 Finished 12/10/2013LT
FO-269030	12/4/2013	12/5/2013		#73759 15 Keys Room 341 Finished 12/10/2013LT
FO-269057	12/4/2013			#75128 4 Keys and 4 Cores Room 1305B
FO-269142	12/5/2013	12/11/2013		65920 10-KEYSFinished 12/16/2013LT
FO-269143	12/5/2013	12/9/2013		75102 3-KEYS Finished 12/10/2013LT
FO-269151	12/5/2013	12/9/2013		75130 1-KEY
FO-269336	12/9/2013	12/9/2013		74990 5-KEYS Finished 12/10/2013LT
FO-269403	12/10/2013	12/11/2013		#75134 1 Core
FO-269440	12/10/2013	12/10/2013		#75132 2 KeysFinished 12/16/2013LT

WO	Recieved	Finished	Total	Request
FO-269474	12/10/2013	12/10/2013		#75139 1 Key Room 314Finished 12/16/2013LT
FO-269476	12/10/2013	12/10/2013		#75137 2 Cores and 4 Keys Room 525Finished 12/16/2013LT
FO-269477	12/10/2013	12/10/2013		#75138 3 Keys and 2 Cores Room 433Finished 12/16/2013LT
FO-269478	12/10/2013	12/11/2013		#75136 3 Keys and 2 Cores Room 323Finished 12/16/2013LT
FO-269480	12/10/2013	12/11/2013		#75135 3 Keys and 2 Cores Room 251Finished 12/16/2013LT
FO-269481	12/10/2013	12/10/2013		#71552 4 KeysFinished 12/16/2013LT
FO-269482	12/10/2013	12/17/2013		#72525 4 Keys Finished 12/23/2013LT
FO-269748	12/12/2013	12/12/2013		#73696 10 KeysFinished 12/16/2013LT
FO-269821	12/12/2013	12/12/2013		#74804 6 KeysFinished 12/16/2013LT
FO-269823	12/12/2013	12/12/2013		#75144 2 Keys and 2 Cores Room 621Finished 12/16/2013LT
FO-269919	12/13/2013	12/13/2013		#73375 2 KeysFinished 12/16/2013LT
FO-269995	12/13/2013			To cover the cost to install final cores in rooms 114 and 116 (8 cores + keys) and labor at Edu
FO-270057	12/16/2013	12/16/2013		#71436 1 Key Room 1230 Finished 12/17/2013LT
FO-270058	12/16/2013	12/16/2013		#74302 1 Key Room 1206 Finished 12/17/2013LT
FO-270922	12/17/2013	12/17/2013		#75147 2 Keys 1 Core Room 3305 Finished 12/23/2013LT
FO-270938	12/17/2013	12/23/2013		#74451 6 Keys Finished 12/26/2013LT
FO-270939	12/17/2013	12/20/2013		#74169 12 Keys 1 Core Room 131 Finished 12/23/2013LT
FO-270992	12/18/2013	12/24/2013		#74265 2 Keys and 1 Core Room 1221 Finished 12/26/2013LT
FO-271150	12/20/2013			#72151 14 Keys
FO-271178	12/20/2013	12/26/2013		71387 3-KEYS Finished 12/27/2013LT
FO-271191	12/20/2013	12/30/2013		#74303 1 KeyFinished 12/31/2013LT
FO-271193	12/20/2013	12/26/2013		#74335 2 Keys Room 139 Tolan Park Finished 12/27/2013LT
FO-271471	12/26/2013	12/27/2013		Provide additional keys for access to the President's garage and apt. Finished 12/30/2013LT
T - Painter			37	
FO-268610	12/2/2013			PAINTERS TO MUDD & PAINT REPAIR OF HOLE CEILING 2ND FLOOR LOBBY AREA (H
FO-268612	12/2/2013	12/10/2013		PAINTERS TO MUDD & PAINT WALL BY DOOR HOLDER ROOM #3315.00
FO-268614	12/2/2013	12/24/2013		PAINTER TO MUDD & PAINT WALL @ WINDOW DROP WAS REPAIRED WIYH DRY WAL
FO-268618	12/2/2013			PAINTERS TO PAINT WINDOW FRAME STORE FRONT 1ST FLOOR E/W CORRIDOR NE
FO-268621	12/2/2013	12/11/2013		PAINTERS TO MUDD & PAINT DRY WALL CORNER BEAD REPAIR IN THE CLASROOM N
FO-268702	12/2/2013	12/4/2013		R/R PLASTER IN THE SOUTH STAIRWAY. Finished 12/6/2013 LT
FO-268704	12/2/2013	12/5/2013		R/R PLASTER IN THE WEST SOUTH STAIRWAY. Finished 12/6/2013 LT
FO-269056	12/4/2013	12/4/2013		PAINT TWO EXTERIOR DOORS. Finished 12/6/2013 LT
FO-269058	12/4/2013	12/7/2013		SAFETY TIME FOR THE EMONTH OF DECEMBER. Finished 12/10/2013LT
FO-269182	12/6/2013			Restroom stalls are covered with graffiti: 072,208, 170 and 270.
FO-269246	12/7/2013	12/11/2013		CAP-3 #746 REPAIR HOLES AND PAINT PARTITIONS. Finished 12/12/2013LT
FO-269247	12/7/2013	12/11/2013		CAP-3 #749 REPAIR HOLES AND PAINT PARTITIONS. Finished 12/12/2013LT
FO-269404	12/10/2013			CAP-3 #762 CLEAN, SCRAPE & PAINT CEILING.
FO-269596	12/10/2013			HANDYMAN TIME.
FO-269597	12/10/2013			MTL TIME.
FO-269581	12/11/2013			Material only for cap-3
FO-269591	12/11/2013			CAP-3 MATERIAL FOR EDUCATION FOR THE MONTH OF DECEMBER.
FO-269593	12/11/2013			CAP-3 FOR MATERIL ONLY. MATTHAEI.
FO-269599	12/11/2013			CAP-3 #998 CLEAN MASTIC FROM EXTERIOR OF BUILDING.
FO-269655	12/11/2013	12/11/2013		CAP-3 #747 CLEAN & PAINT WALL. Finished 12/12/2013LT
FO-269681	12/11/2013			CAP-3 #925 REFINISH / REPAINT DOORS, PAINT DOOR FRAMES TYPICAL.
FO-269746	12/12/2013	12/13/2013		CAP-3 #752 CLEAN AND PAINT WALLS.Finished 12/16/2013LT
FO-269964	12/13/2013			Adding Painter: repair ceiling crack and paint. See Mike McAlinden for location

WO	Recieved	Finished	Total	Request
FO-269979	12/13/2013	12/13/2013		CAP-3 #270 STICKERS AND CRACKED PAINT/PLASTER AT ELECTRICAL PANEL.Finishe
FO-269980	12/13/2013	12/26/2013		CAP-3 305 GRAFFITI ON TRASH CAN. Finished 12/27/2013LT
FO-269981	12/13/2013			CAP-3 370 TOUCH UP AND/OR REPAINT CLASSROOMS, ESPECIALLY NEAR ENRTYWA
FO-270133	12/16/2013	12/20/2013		paint restroom 107 north west hal.
FO-271050	12/18/2013	12/20/2013		CHRISTMAS PARTY TIME. Finished 12/23/2013LT
FO-271208	12/23/2013			PAINTERS: Please mud & paint new 2'x5' wall section in hall near loading dock. LOW
FO-271259	12/23/2013			cap3-957 replace delaminating laminate at soffit first floor elevator lobby ref :fo-266697
FO-271257	12/23/2013	12/26/2013		CAP-3 #757 REPAIR AND PAINT RUSTED DOOR FRAME. Finished 12/27/2013LT
FO-271441	12/26/2013			REPAIR ACCESS HOLE THAT WAS REPAIRED BY THE CARPENTERS ACROSS FROM
FO-271453	12/26/2013			CAP-3 #82 CLEAN AND/ OR PAINT CHAIR RAILS AS REQUIRED.
FO-271454	12/26/2013			CAP-3 #217 PAINT WALLS. OUTSIDE OF 0429.1
FO-271455	12/26/2013			CAP-3 #212 REPAIR WALL. BASEMENT STAIRWELL G
FO-271456	12/26/2013			CAP-3 #268 REPAINT CHAIR RAIL AS REQUIRED FIRST FLOOR CLASSROOMS.
FO-271457	12/26/2013			CAP-3 #269 WALL DAMAGE AT WINDOW. 1162.
T - Pipefitter			19	
FO-268982	12/4/2013	12/4/2013		PIPEFITTERS please replace leaking valve on drip leg behind east wall room#1 in BEECHER
FO-268984	12/4/2013	12/4/2013		Trade: Pipefitter Priority: Low
FO-269008	12/4/2013	12/10/2013		please take out air seperator and bypass line and plug both ends. see Corey or Tim for details
FO-269112	12/5/2013	12/6/2013		PIPEFITTER:
FO-269303	12/9/2013	12/17/2013		please repair flange leak on hydronic heating line in room 100....see Marty..ME/12-9-13,,,,,,,,,,,,,
FO-269307	12/9/2013	12/19/2013		please repair condensate reciver located in NW corner of room 100...ME/12-9-13,,,,,,,,,,,,, DU
FO-269494	12/10/2013			STEAMFITTERS-
FO-269605	12/11/2013	12/12/2013		R/R RM 102/STAGE Please repair the leaking steam valve on the southeast corner of the sta
FO-269824	12/12/2013			Pipefitters:
FO-270893	12/17/2013	12/17/2013		ADDING PLUMBERS
FO-270977	12/18/2013	12/19/2013		Pipefitter: Please replace defective room booster heating control valve.
FO-271011	12/18/2013	12/19/2013		Pipefitters: Please replace defective booster heating control valve.
FO-271012	12/18/2013	12/19/2013		Pipefitters: Please replace defective booster heating control valve.
FO-271013	12/18/2013	12/23/2013		Pipefitters: Please replace defective booster heating control valve.
FO-271014	12/18/2013	12/19/2013		Pipefitters: Please replace defective booster heating control valve.
FO-271015	12/18/2013	12/19/2013		Pipefitters: Please replace defective booster heating control valve.
FO-271020	12/18/2013			Pipefitters: please replace ahu 7 heating valve: valve is leaking by in closed position:
FO-271450	12/26/2013			Evaluate installing water meter for cooling tower ,,,,,,,,,,,,,, EA/RC 12-26-13 ,,,,,,,,,,,,,, DUE 1
FO-271475	12/30/2013	12/30/2013		Weld padlock to heavy duty chain for access to sliding gate.,,,,,,,,,,,,,, JH/12-30-13 ,,,,,,,,,,,,,,
T - Plumber			32	
FO-268622	12/2/2013	12/4/2013		please repair leak on trap in shop slop sink.....RC/RB...12-2-13 Finished 12/6/2013 LT
FO-268701	12/2/2013			R/R Room 6126 sink is clogged (located inside of Room 6124). A Tech came last week and s
FO-268797	12/3/2013			Please R&R both clear water sump pumps located near #3 stairwell near plenum....MP/DB...1
FO-268974	12/4/2013	12/24/2013		RE-stock service truck...MP/DB..12-4-13 ,,,,,,,,,,,,,, DUE 1-4-14 Finished 12/26/2013LT
FO-269079	12/5/2013	12/10/2013		Magherio women's restroom, handicapped stall toliet leaking ,,,,,,,,,,,,,, MM/12-6-13 ,,,,,,,,,,,,,,
FO-269181	12/6/2013	12/19/2013		Tiolet in Women's restroom #270 does not work.,,,,,,,,,,,,,, RJC/RB 12-6-13 ,,,,,,,,,,,,,, DUE 1
FO-269185	12/6/2013	12/19/2013		Men's restroom 3rd floor right off the front elevator the small urinal leaking water.,,,,,,,,,,,,,, M
FO-269228	12/6/2013	12/9/2013		R/R urinals 1st floor mens room near hall of fame display ,,,,,,,,,,,,,, MP/DB 12-6-13 ,,,,,,,,,,,,,,
FO-269234	12/6/2013	12/10/2013		R/R RM 1360 Sink (left) does not work. (PLS NOTE THE OTHER SINK IS WORKING FINE),,,
FO-269237	12/6/2013	12/10/2013		R/R RM 326 Faucet in left-hand sink does not work. Dead battery?,,,,,,,,,,,,, MM/12-9-13 ,,,,,,
FO-269250	12/7/2013	12/9/2013		MEN'S ROOM #1346. HANDICAP TOILET SEAT BROKEN. SAFETY ISSUE ,,,,,,,,,,,,,, MP/
FO-269251	12/7/2013			LADIES ROOM #1347. 1ST. SINK OUT OF ORDER.,,,,,,,,,,,,,, MP/DB 12-9-13 ,,,,,,,,,,,,,,
FO-269253	12/7/2013	12/11/2013		2ND FLOOR MEN'S ROOM LAB WING SIDE. TOILET BY WALL. BAD FLUSH.,,,,,,,,,,,,,, MP

WO	Recieved	Finished	Total	Request
FO-269256	12/7/2013	12/9/2013		3RD FLOOR LADIES ROOM LAB WING SIDE. HANDICAP TOILET BAGGED..... MP
FO-269261	12/8/2013	12/31/2013		Clear floor drains plugged up in mechanical room 25, (the hot room)..... RJC/RB 12-9-
FO-269274	12/9/2013	12/11/2013		Plumbers
FO-269484	12/9/2013			R/R needed bathroom fixture replacement in both 1st floor mens rooms MP/DB 1
FO-269487	12/9/2013			Administrative Time for December 2013
FO-269397	12/10/2013			The men's & women's drain in the 1st and 2nd restrooms needs to be snake!..... RJC/
FO-269488	12/10/2013	12/17/2013		R/R 1ST FLR (MAIN RESTROOM AREA) MENS RR ONE OF THE URINALS WILL NOT STO
FO-269530	12/11/2013	12/30/2013		In the Men's Room, in the basement of Prentis, the first urinal on the right hand side is stoppe
FO-269802	12/12/2013			Trade: Plumbers
FO-269813	12/12/2013			Install #2 sewage ejector in sub-basement MP/DB 12-12-13 DUE 1-12-
FO-269926	12/13/2013			Plumber
FO-269944	12/13/2013			P.M waterless urinals throughout building for month of December MM/13-13-13
FO-269963	12/13/2013	12/12/2013		Replace bradley hand sink . See Don Bear for locationMP/DB 12-12-13 DU
FO-270952	12/17/2013			P.M.waterless urinals for Month of Dec 2013 MP/DB 12-17-13 DUE 1-17-1
FO-270970	12/18/2013	12/23/2013		Second floor mens restroom first stall toilet out of order..... MM/12-19-13 DU
FO-270980	12/18/2013	12/20/2013		Entrance area D water linking for the water sprinkler.It's on the JC Lodge side water link fast.,,,
FO-270981	12/18/2013			On the new side Danto the waterless urinal smelling very bad in men's restroom in basement.
FO-271030	12/18/2013	12/18/2013		3rd floor womens room toilet leaking at wall MM/12-18-13 DUE 1-18-13
FO-271058	12/18/2013			Plumber
T - Roofing			2	
FO-269275	12/9/2013			ROOFER:
FO-271465	12/27/2013			Adding Roofer: Check ceiling leak when it rains. There is no plumbing leak. Leak only occurs
T - Sheetmetal			1	
FO-269962	12/13/2013			Sheetmetal/contractor, Please replace missing fin on outside air damper on AHU-2 in penthou
Routine			35	
T - Electrician			35	
FO-269278	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269279	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269280	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269281	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269282	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269283	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-269284	12/9/2013	12/13/2013		ROUTINE CHECK 12/9 THRU 12/13/2013. Finished 12/16/2013LT
FO-270025	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270026	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270027	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270028	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270029	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270030	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-270031	12/16/2013	12/23/2013		ROUTINE CHECK 12/16 THRU 12/20/13 Finished 12/26/2013LT
FO-271210	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271211	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271212	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271213	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271214	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271215	12/23/2013	12/27/2013		ROUTINE CHECK 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271239	12/23/2013	12/27/2013		ROUTINE CHECK of parking lots 12/23 THRU 12/27/13 Finished 12/28/2013LT
FO-271379	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14

WO	Recieved	Finished	Total	Request
FO-271380	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271381	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271382	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271383	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271384	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271385	12/24/2013			ROUTINE CHECK 12/30/13 THRU 1/3/14
FO-271387	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271388	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271389	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271390	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271391	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271392	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14
FO-271393	12/24/2013			ROUTINE CHECK 1/6 THRU 1/10/14

Scheduled Maint. (PM)

423

Engineering

391

Routine

391

E - Auxiliary

36

FO-270712	12/1/2013			PM - Fan Coil/HV/AC Unit
FO-270735	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-270737	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-270765	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-270720	12/2/2013	12/6/2013		PM - Emergency Shower/Eyewash Station
FO-270349	12/8/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270350	12/8/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270351	12/8/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270352	12/8/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270721	12/9/2013	12/13/2013		PM - Emergency Shower/Eyewash Station
FO-268752	12/10/2013	12/10/2013		Generator Maintenance, Monthly
FO-268754	12/11/2013	12/11/2013		Generator Maintenance, Monthly
FO-270700	12/11/2013			Replace Chemistry Exhaust Air Filters (FUME HOODS) North End
FO-270347	12/15/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270348	12/15/2013		12/18/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270722	12/16/2013	12/20/2013		PM - Emergency Shower/Eyewash Station
FO-268762	12/18/2013	12/18/2013		Generator Maintenance, Monthly
FO-270662	12/19/2013			PM - Air Handling Unit
FO-270663	12/19/2013			PM - Air Handling Unit
FO-270664	12/19/2013			PM - Air Handling Unit
FO-270759	12/21/2013			PM Replace Exhaust Air Filters
FO-270725	12/22/2013			Housing Fog Treatment
FO-270723	12/23/2013			PM - Emergency Shower/Eyewash Station
FO-268732	12/24/2013	12/24/2013		Generator Maintenance, Monthly
FO-268734	12/24/2013	12/24/2013		Generator Maintenance, Monthly
FO-268736	12/24/2013	12/24/2013		Generator Maintenance, Monthly
FO-268738	12/24/2013	12/24/2013		Generator Maintenance, Monthly
FO-268740	12/24/2013	12/24/2013		Generator Maintenance, Monthly
FO-270756	12/28/2013			PM Replace Exhaust Air Filters

WO	Recieved	Finished	Total	Request
FO-270757	12/28/2013			PM Replace Exhaust Air Filters
FO-270758	12/28/2013			PM Replace Exhaust Air Filters
FO-270760	12/28/2013			PM Replace Exhaust Air Filters
FO-270761	12/28/2013			PM Replace Exhaust Air Filters
FO-270343	12/29/2013		12/18/2013	PM - Air Handling Unit
FO-270344	12/29/2013		12/18/2013	PM - Air Handling Unit
FO-270724	12/30/2013			PM - Emergency Shower/Eyewash Station
E - Command Center			13	
FO-270373	12/3/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270400	12/3/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270401	12/3/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270402	12/3/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270443	12/5/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270659	12/5/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270660	12/5/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270661	12/5/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270667	12/6/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270363	12/10/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270364	12/10/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270361	12/13/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-270356	12/17/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
E - Director			30	
FO-270773	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270774	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270775	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270776	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270777	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270778	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270779	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270780	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270781	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270782	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270783	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270784	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270785	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270786	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270787	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270788	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270789	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270790	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270791	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270792	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270793	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270794	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270795	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270796	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270797	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270798	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water

WO	Recieved	Finished	Total	Request
FO-270799	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270800	12/1/2013			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water
FO-270810	12/1/2013			PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled
FO-270811	12/1/2013			PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled
E - MedPharm			17	
FO-270196	12/1/2013			PM - Reverse Osmosis Water Softener System
FO-270221	12/1/2013			HEPA Filter Replacement at Applebaum Pharmacy Building
FO-270176	12/3/2013			PM - Heat Exchanger and Economizer
FO-270224	12/4/2013			PM - Water Softener
FO-268759	12/6/2013			Generator Maintenance, Monthly
FO-270171	12/8/2013			PM - Centrifugal Pump, over 1 H.P.
FO-270172	12/9/2013			PM - Centrifugal Pump, over 1 H.P.
FO-270186	12/9/2013			PM - Fan Coil/HV/AC Unit
FO-270187	12/9/2013			PM - Fan Coil/HV/AC Unit
FO-270152	12/10/2013			PM - Centrifugal Pump, over 1 H.P.
FO-268748	12/13/2013	12/13/2013		Generator Maintenance, Monthly
FO-268750	12/13/2013	12/13/2013		Generator Maintenance, Monthly
FO-268765	12/17/2013			Generator Maintenance, Monthly
FO-270197	12/23/2013			PM - Absorption Unit
FO-270198	12/23/2013			PM - Absorption Unit
FO-268727	12/27/2013			Generator Maintenance, Monthly
FO-268729	12/27/2013			Generator Maintenance, Monthly
E - Midnight			6	
FO-270769	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-270367	12/13/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270368	12/13/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270369	12/13/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270370	12/13/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-270371	12/13/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - North			7	
FO-269264	12/2/2013	12/4/2013		PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-268767	12/13/2013			Generator Maintenance, Monthly
FO-270310	12/16/2013	12/17/2013		PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-270286	12/20/2013			PM - Domestic Water Heater, Steam
FO-270301	12/20/2013			PM - Heat Exchanger and Economizer
FO-268746	12/25/2013			Generator Maintenance, Monthly
FO-270311	12/30/2013	12/19/2013		PM - Grease Fan Bearings & Check Belts Bi-Monthly
E - Northeast			9	
FO-266370	12/1/2013	11/14/2013	11/14/2013	Generator Maintenance, Monthly
FO-266372	12/1/2013	11/11/2013	11/11/2013	Generator Maintenance, Monthly
FO-268768	12/6/2013	12/6/2013	12/6/2013	Generator Maintenance, Monthly
FO-268774	12/6/2013	12/6/2013	12/6/2013	Generator Maintenance, Monthly
FO-268776	12/6/2013	12/6/2013	12/6/2013	Generator Maintenance, Monthly
FO-268779	12/6/2013	12/6/2013	12/6/2013	Generator Maintenance, Monthly
FO-268756	12/17/2013			Generator Maintenance, Monthly
FO-268764	12/19/2013	12/19/2013		Generator Maintenance, Monthly
FO-268724	12/25/2013	12/12/2013		Generator Maintenance, Monthly
E - Preventative Maintenance			193	

WO	Recieved	Finished	Total	Request
FO-266521	12/1/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266545	12/1/2013			PM - Air Handling Unit
FO-266546	12/1/2013			PM - Air Handling Unit
FO-266550	12/1/2013		12/11/2013	Replace PRE-filters
FO-266551	12/1/2013		12/11/2013	Replace PRE-filters
FO-266552	12/1/2013		12/11/2013	Replace PRE-filters
FO-266553	12/1/2013		12/11/2013	Replace PRE-filters
FO-266554	12/1/2013		12/11/2013	Replace PRE-filters
FO-266555	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266556	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266557	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266559	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266560	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266561	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266562	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266563	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266564	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266565	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266566	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266567	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266568	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266569	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266570	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266571	12/1/2013	12/13/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266572	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266573	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266574	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266575	12/1/2013	12/21/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266576	12/1/2013	12/21/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266577	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266578	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266579	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266580	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266581	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266582	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266583	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266584	12/1/2013	12/21/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266585	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266586	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266587	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266588	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266589	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266590	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266591	12/1/2013	12/13/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266592	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266593	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266594	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-266595	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266596	12/1/2013	12/12/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266597	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266598	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266599	12/1/2013	12/13/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266600	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266601	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266602	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266603	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266604	12/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-266605	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-268018	12/1/2013			Replace PRE-filters
FO-268019	12/1/2013			Replace PRE-filters
FO-268020	12/1/2013			Replace PRE-filters
FO-268021	12/1/2013			Replace PRE-filters
FO-268022	12/1/2013			Replace PRE-filters
FO-268023	12/1/2013			Replace PRE-filters
FO-268024	12/1/2013			Replace PRE-filters
FO-268025	12/1/2013			Replace PRE-filters
FO-268026	12/1/2013			Replace PRE-filters
FO-268027	12/1/2013			Replace PRE-filters
FO-268028	12/1/2013			Replace PRE-filters
FO-268029	12/1/2013			Replace PRE-filters
FO-268030	12/1/2013			Replace PRE-filters
FO-268031	12/1/2013			Replace PRE-filters
FO-268032	12/1/2013			Replace PRE-filters
FO-268033	12/1/2013			Replace PRE-filters
FO-268034	12/1/2013			Replace PRE-filters
FO-268035	12/1/2013			Replace PRE-filters
FO-268036	12/1/2013			Replace PRE-filters
FO-268037	12/1/2013			Replace PRE-filters
FO-268038	12/1/2013			Replace PRE-filters
FO-268039	12/1/2013			Replace PRE-filters
FO-268040	12/1/2013			Replace PRE-filters
FO-268042	12/1/2013	12/20/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-266522	12/2/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266547	12/2/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-264661	12/3/2013		12/11/2013	Replace PRE-filters
FO-264662	12/3/2013	10/19/2013		Replace PRE-filters
FO-264663	12/3/2013	10/22/2013		Replace PRE-filters
FO-264664	12/3/2013	10/17/2013		Replace PRE-filters
FO-264665	12/3/2013	10/16/2013		Replace PRE-filters
FO-264666	12/3/2013		12/11/2013	Replace PRE-filters
FO-264667	12/3/2013		12/11/2013	Replace PRE-filters
FO-264668	12/3/2013		12/11/2013	Replace PRE-filters
FO-264669	12/3/2013		12/11/2013	Replace PRE-filters
FO-264670	12/3/2013		12/11/2013	Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-266523	12/3/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266526	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266527	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266528	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266529	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266530	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266531	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266532	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266533	12/3/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-266534	12/3/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-266535	12/3/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-266540	12/3/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-266541	12/3/2013	12/12/2013		PM - Fan Coil/HV/AC Unit
FO-266548	12/3/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266520	12/4/2013			PM - Air Handling Unit
FO-266525	12/4/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266538	12/4/2013			PM - Air Handling Unit
FO-266539	12/4/2013			PM - Air Handling Unit
FO-266549	12/4/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266558	12/4/2013			PM - Air Handling Unit
FO-266542	12/5/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266543	12/5/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266544	12/5/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266524	12/6/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-266536	12/6/2013			PM - Air Handling Unit
FO-266537	12/6/2013			PM - Air Handling Unit
FO-267157	12/7/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267185	12/7/2013			HEPA Filter Replacement at Applebaum Pharmacy Building
FO-267186	12/7/2013			Animal Lab Filter Changes for Applebaum
FO-267158	12/8/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267159	12/9/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267160	12/10/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267163	12/10/2013	12/11/2013		PM - Fan Coil/HV/AC Unit
FO-267164	12/10/2013	12/11/2013		PM - Fan Coil/HV/AC Unit
FO-267165	12/10/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-267166	12/10/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-267167	12/10/2013	12/13/2013		PM - Fan Coil/HV/AC Unit
FO-267168	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267169	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267172	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267173	12/10/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267174	12/10/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267175	12/10/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267176	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267177	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267178	12/10/2013	12/17/2013		PM - Fan Coil/HV/AC Unit
FO-267183	12/11/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-267184	12/11/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267179	12/12/2013			PM - Air Handling Unit
FO-267180	12/12/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267181	12/12/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267182	12/12/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263429	12/13/2013	12/13/2013		PM - Air Handling Unit
FO-267161	12/13/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267162	12/13/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267170	12/13/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267171	12/13/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267778	12/14/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267779	12/15/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267791	12/15/2013		12/11/2013	Replace PRE-filters
FO-267780	12/16/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-267795	12/16/2013	12/14/2013		PM - Air Handling Unit
FO-267796	12/16/2013	12/14/2013		PM - Air Handling Unit
FO-267797	12/16/2013	12/14/2013		PM - Air Handling Unit
FO-267798	12/16/2013	12/14/2013		PM - Air Handling Unit
FO-267799	12/16/2013	12/14/2013		PM - Air Handling Unit
FO-267781	12/17/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267782	12/17/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267783	12/17/2013	12/19/2013		PM - Fan Coil/HV/AC Unit
FO-267784	12/17/2013	12/20/2013		PM - Fan Coil/HV/AC Unit
FO-267785	12/17/2013	12/20/2013		PM - Fan Coil/HV/AC Unit
FO-267786	12/17/2013			PM - Fan Coil/HV/AC Unit
FO-267787	12/17/2013			PM - Fan Coil/HV/AC Unit
FO-267788	12/17/2013			PM - Fan Coil/HV/AC Unit
FO-267789	12/17/2013			PM - Fan Coil/HV/AC Unit
FO-267790	12/17/2013			PM - Fan Coil/HV/AC Unit
FO-267792	12/18/2013			PM - Air Handling Unit
FO-267793	12/18/2013			PM - Air Handling Unit
FO-267794	12/18/2013			PM - Air Handling Unit
FO-268487	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268488	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268489	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268490	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268491	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268492	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268493	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268494	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268495	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268496	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268497	12/24/2013			PM - Fan Coil/HV/AC Unit
FO-268478	12/27/2013			PM - Air Handling Unit
FO-268479	12/27/2013			PM - Air Handling Unit
FO-268480	12/27/2013			PM - Air Handling Unit
FO-268481	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-268482	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-268483	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-268484	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-268485	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-268486	12/27/2013		12/11/2013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - South			16	
FO-270753	12/7/2013			PM - Water Softener
FO-270635	12/8/2013			PM - Monthly AHU Inspection Clean Room Unit 1
FO-270621	12/10/2013			Monthly AHU Inspection Clean Room Unit 2
FO-268716	12/12/2013	12/20/2013		Generator Maintenance, Monthly
FO-268718	12/12/2013	12/20/2013		Generator Maintenance, Monthly
FO-268761	12/12/2013	12/12/2013		Generator Maintenance, Monthly
FO-270636	12/16/2013			PM - Water/Air Cooled Condenser
FO-268720	12/17/2013	12/17/2013		Generator Maintenance, Monthly
FO-268722	12/18/2013	12/18/2013		Generator Maintenance, Monthly
FO-268772	12/19/2013	12/20/2013		Generator Maintenance, Monthly
FO-270698	12/21/2013			PM - Centrifugal Pump, over 1 H.P.
FO-270702	12/21/2013			Replace Chemistry Exhaust Air Filters (FUME HOODS) North End
FO-270703	12/21/2013			Replace Chemistry PreFilters (AHU-1A/2A) North End
FO-270606	12/27/2013			PM - Domestic Water Heater, Electric
FO-270607	12/27/2013			PM - Domestic Water Heater, Electric
FO-270608	12/27/2013			PM - Domestic Water Heater, Electric
E - Southeast			61	
FO-270681	12/4/2013			PM - Harmsco Side Stream Filter
FO-270682	12/4/2013			PM - Harmsco Side Stream Filter
FO-270454	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270455	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270456	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270457	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270458	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270459	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270460	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270461	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270462	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270463	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270464	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270465	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270466	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270467	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270468	12/5/2013			PM - Heat Pumps (5057 Woodward)
FO-270688	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270689	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270690	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270691	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270692	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270693	12/11/2013			PM - Heat Pumps (5057 Woodward)
FO-270450	12/12/2013			PM - Heat Pumps (5057 Woodward)
FO-270451	12/12/2013			PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-270452	12/12/2013			PM - Heat Pumps (5057 Woodward)
FO-270453	12/12/2013			PM - Heat Pumps (5057 Woodward)
FO-270604	12/12/2013			PM - Heat Pumps (5057 Woodward)
FO-270605	12/12/2013			PM - Heat Pumps (5057 Woodward)
FO-268742	12/17/2013			Generator Maintenance, Monthly
FO-268744	12/17/2013			Generator Maintenance, Monthly
FO-270581	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270582	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270583	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270584	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270585	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270586	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270587	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270588	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270589	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270590	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270591	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270592	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270593	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270594	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270595	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270596	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270597	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270598	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270599	12/19/2013			PM - Heat Pumps (5057 Woodward)
FO-270626	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270627	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270628	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270629	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270630	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270631	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270632	12/20/2013			PM - Air Intake Dampers (Old Main)
FO-270610	12/27/2013			PM - Sump Pump
FO-270611	12/27/2013			PM - Sump Pump
FO-270617	12/27/2013			PM - Sump Pump
FO-270618	12/27/2013			PM - Sump Pump
E - West			3	
FO-270434	12/8/2013			PM - Domestic Water Heater, Gas
FO-268770	12/10/2013			Generator Maintenance, Monthly
FO-270396	12/19/2013			PM - Centrifugal Pump, over 1 H.P.
Trades			32	
Routine			32	
T - Electrician			32	
FO-268730	12/6/2013	12/6/2013		Generator Test Finished 12/10/2013LT
FO-268758	12/6/2013	12/6/2013		Generator Test Finished 12/10/2013LT
FO-268773	12/6/2013	12/6/2013		Generator Test Finished 12/10/2013LT
FO-268775	12/6/2013	12/6/2013		Generator Test Finished 12/10/2013LT

WO	Recieved	Finished	Total	Request
FO-268778	12/6/2013	12/6/2013	12/6/2013	Generator Test Finished 12/10/2013LT
FO-268751	12/10/2013	12/10/2013		Generator Test, to be done December 10, 2013 @ 1PM. Finished 12/11/2013LT
FO-268769	12/10/2013	12/10/2013		Generator Test, to be done on December 10, 2013 @ 7:15 AM. Finished 12/11/2013LT
FO-268753	12/11/2013	12/11/2013		Generator Test, to be done December 11, 2013 @ 1PM. Finished 12/12/2013LT
FO-268717	12/12/2013	12/12/2013		Generator Test, to be done December 12, 2013 @7:15AM Finished 12/13/2013LT
FO-268719	12/12/2013	12/12/2013		Generator Test, to be done December 12, 2013 A 7:15AM. Finished 12/13/2013LT
FO-268760	12/12/2013	12/16/2013		Generator Test, to be done December 12, 2013 @ 7:15 AM. Finished 12/17/2013LT
FO-268747	12/13/2013	12/13/2013		Generator Test, to be done December 13, 2013 @ 7:15AM.. Finished 12/16/2013LT
FO-268749	12/13/2013	12/13/2013		Generator Test, to be done December 13, 2013 @ 7:15AM.. Finished 12/16/2013LT
FO-268766	12/13/2013	12/13/2013		Generator Test, to be done December 13, 2013 @ 7:15 AM.. Finished 12/16/2013LT
FO-268715	12/17/2013	12/17/2013		Generator Test Finished 12/18/2013LT
FO-268721	12/17/2013	12/17/2013		Generator Test Finished 12/18/2013LT
FO-268741	12/17/2013	12/17/2013		Generator Test Finished 12/18/2013LT
FO-268743	12/17/2013	12/17/2013		Generator Test Finished 12/18/2013LT
FO-268755	12/17/2013			Generator Test
FO-268723	12/18/2013	12/18/2013		Generator Test. Finished 12/19/2013LT
FO-268757	12/18/2013	12/18/2013		Generator Test. Finished 12/19/2013LT
FO-268763	12/19/2013	12/19/2013		Generator Test. Finished 12/19/2013LT
FO-268771	12/19/2013	12/19/2013		Generator Test. Finished 12/19/2013LT
FO-268731	12/24/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 10:00AM. Finished 12/26/2013LT
FO-268733	12/24/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT
FO-268735	12/24/2013	12/24/2013		Generator Test, to be done 12/24/2013 @ 8AM. Finished 12/26/2013LT
FO-268737	12/24/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT
FO-268739	12/24/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT
FO-268725	12/25/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 7:15. Finished 12/26/2013LT
FO-268745	12/25/2013	12/24/2013		Generator Test, to be done 12/24/2013 Tuesday @ 7:15AM. Finished 12/26/2013LT
FO-268726	12/27/2013	12/20/2013		Generator Test Finished 12/23/2013LT
FO-268728	12/27/2013	12/20/2013		Generator Test Finished 12/23/2013LT

Total: 2127