

Facilities Operations Backlog as of 4/1/16

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Maint. Work Order				24	20	2	1	1	0	0	4
Engineering				5	4	0	1	0	0	0	1
Emergency				1	1	0	0	0	0	0	0
E - South				1	1	0	0	0	0	0	
FO-344868	4/15/2016	-14	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
High				1	1	0	0	0	0	0	0
E - Command Center				1	1	0	0	0	0	0	
FO-344878	4/15/2016	-14	Hold for Funds	Refr.crew:							
Medium				1	1	0	0	0	0	0	0
E - Command Center				1	1	0	0	0	0	0	
FO-343471	3/30/2016	2	Hold for Funds	boilers 1 2 3 have trouble maintaining loop temp,below set point, reset flame failure alar							
Low				2	1	0	1	0	0	0	1
E - Command Center				2	1	0	1	0	0	0	
FO-337648	1/22/2016	70	Hold for Funds	REPAIR LOW WATER CUT OUT. MAKE UP TANK.							
FO-344746	4/13/2016	-12	Hold for Funds	ac/burner crew-							
Trades				19	16	2	0	1	0	0	3
Emergency				1	1	0	0	0	0	0	0
T - Electrician				1	1	0	0	0	0	0	
FO-344868	4/15/2016	-14	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
High				4	4	0	0	0	0	0	0
T - Electrician				4	4	0	0	0	0	0	
FO-342136	3/15/2016	17	Hold for Funds	lollipop type lights around building and in front of structure #2 not working please check							
FO-342874	3/22/2016	10	Hold for Funds	Electricians-							
FO-343192	3/25/2016	7	Hold for Funds	trade electricians priority high							
FO-344409	4/7/2016	-6	Hold for Funds	R/R RM 2301/RESTROOM Hand dryer is not functioning. there was a report of a burnin							
Medium				2	2	0	0	0	0	0	0
T - Electrician				1	1	0	0	0	0	0	
FO-341930	3/10/2016	22	Hold for Funds	Check Community Arts, and other buildings for Emergency Lighting.							
T - Plumber				1	1	0	0	0	0	0	
FO-342830	3/22/2016	10	Hold for Funds	**WILL REVISIT IN SUMMER WHEN STEAM IS OFF AND CONDENSATE ID DRY ON							
Low				11	9	2	0	0	0	0	2
T - Carpenter				3	3	0	0	0	0	0	
FO-344995	4/18/2016	-17	Hold for Funds	REPAIR GUTTER ON SOUTHWEST CORNER.							
FO-345016	4/18/2016	-17	Hold for Funds	Carpenters: please repair roof gutters on north side of the building. priority: low.							
FO-345767	4/21/2016	-20	Hold for Funds	R/R BLDG The latches on the windows are broken or missing in several rooms and they							
T - Electrician				8	6	2	0	0	0	0	
FO-340735	2/29/2016	32	Hold for Funds	pls repair rest room exh fan motor circuit not running							
FO-340878	3/1/2016	31	Hold for Funds	Replace faulty blower motor on Exhaust Fan #14 at Bio-Science.							
FO-341792	3/9/2016	23	Hold for Funds	Light out in the Grounds' dept. I had to remove the bulb because it wouldn't stop flickerin							
FO-342204	3/16/2016	16	Hold for Funds	Replace Emergency light Batteries in Auditorium.							
FO-342943	3/23/2016	9	Hold for Funds	EMERGENCY ELEC							
FO-343295	3/28/2016	4	Hold for Funds	Extreme Air Hand Dryer is not working in Ladies Bathroom, UGL Room 2432.							
FO-343434	3/29/2016	3	Hold for Funds	the 2nd floor heating hot water pump trips off, pls repair							
FO-344767	4/13/2016	-12	Hold for Funds	The hand drier in the women's bathroom does not							

	Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Routine	1	0	0	0	1	0	0	1
T - Plumber	1	0	0	0	1	0	0	
FO-332597 11/15/2015 138	Hold for Funds	(HFF) PER DK 3/30						

Total: 24