

# Facilities Operations Work Orders Received 12/1/15 through 12/31/15

WO	Recieved	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1257</b>	
<b>Custodial</b>			<b>168</b>	
<b>Emergency</b>			<b>1</b>	
<b>C-Repair</b>			<b>1</b>	
FO-335174	12/18/2015	12/18/2015		A request from (T. Robertson), sector #6 Supervisor needs service repairs on a carpet extractor machine. from Sector # 9 area (Powr-Flite/PFX1380PH/SER.#-1011001165) Perfect Heat. The machine wand is broken and other problem.
<b>High</b>			<b>1</b>	
<b>Pest Controller</b>			<b>1</b>	
FO-334235	12/4/2015	12/23/2015	12/23/2015	MRS. WILSON SPOTTED A RAT BY THE BACK DOOR. PLEASE SEE HENRIETTA PEST CONTROL ISSUES ALSO WITHIN PRESIDENTS APT.
<b>Medium</b>			<b>5</b>	
<b>C-Repair</b>			<b>1</b>	
FO-335166	12/18/2015	12/21/2015		1st floor Women paper towel dispenser off the wall need new 1
<b>Pest Controller</b>			<b>4</b>	
FO-334009	12/1/2015	12/3/2015	12/3/2015	We are seeing rats in the cul-de-sac between 5425 and 5435 again ( the handicapped ramp and the walkway from the porch on 5425). I have not seen where they may be hiding, but they are definitely close. May we get another pest control visit, please?
FO-334176	12/3/2015	12/7/2015	12/15/2015	LAB RM 2520 BED BUG SITED, PLEASE CHECK AND SPRAY FOR BEDBUGS.
FO-334738	12/11/2015	12/14/2015	12/14/2015	BSMNT MENS RM BED BUGS
FO-335700	12/23/2015	12/23/2015	12/23/2015	OUTSIDE WINDOWS RATS ARE RUNNING AROUND THROUGH TRAPS
<b>Low</b>			<b>161</b>	
<b>C-Lighting</b>			<b>59</b>	
FO-333983	12/1/2015	12/1/2015		LIGHT CREW-PLEASE REPLACE BURNED OUT LIGHTS BY PUMP #3,MECH ROOM DARK PRIORITY MED
FO-334053	12/2/2015	12/2/2015		Room 443 - 1 LO
FO-334059	12/2/2015	12/4/2015		Light bulbs need replacing in garage area. Fixtures may possibly need repair as well. Room 1305 included.
FO-334070	12/2/2015	12/4/2015		lights still out
FO-334078	12/2/2015	12/4/2015		3rd floor - Women's R/R - 1 LO
FO-334102	12/2/2015	12/3/2015		Ceiling lights out in office- faculty member needs this light replaced asap
FO-334245	12/4/2015	12/7/2015		Several lights out in women's restroom. Please replace. Thank you.
FO-334278	12/7/2015	12/9/2015		Light Changers please replace bulb in basement ladies restroom.
FO-334284	12/7/2015			Relamp two light fixtures.
FO-334297	12/7/2015	12/9/2015		Mens Bathroom in suite 206, has a blown out light.
FO-334329	12/7/2015			REPLACE BLOWN LIGHT BULBS. ROOM 1151.
FO-334340	12/7/2015	12/10/2015		Relamp light fixture in Men's Shower.
FO-334349	12/7/2015	12/14/2015		Ceiling lights are out.
FO-334419	12/8/2015	12/10/2015		First floor - Admin side/open meeting area - 6 LO
FO-334448	12/8/2015	12/9/2015		UGL WRT Zone (Writing Center), Room 2310, has about 6 tube lights out. Check for key with Circulation Desk or Custodians
FO-334474	12/8/2015	12/10/2015		Men's Restroom has numerous lights out
FO-334471	12/9/2015	12/15/2015		5057, 3rd floor light out near room #3120.
FO-334472	12/9/2015	12/9/2015		2nd floor unisex restroom needs light.
FO-334512	12/9/2015			Magherio Conf lobby is dark. and in front of men's RR rm 144 lites out
FO-334542	12/9/2015	12/15/2015		Relamp light fixtures as needed.
FO-334555	12/9/2015	12/16/2015		3 lights out

WO	Recieved	Finished	Total	Request
FO-334557	12/9/2015	12/15/2015		Real Room Number 237.3. This is an academic office. Lights out. Please replace for Dr. Abu-Soud. Thank you.
FO-334581	12/10/2015	12/14/2015		There are 9 spot lights out between the front doors and the doors to the atrium. Please repair/replace.
FO-334601	12/10/2015	12/15/2015		2 lights out in 3341.1 (Ladies Restroom).
FO-334602	12/10/2015			2 lights out in hallway near elevator #5. 1 on the ceiling and 1 on the wall next to elevator.
FO-334627	12/10/2015	12/11/2015		Room 106 - please clean light fixtures.
FO-334629	12/10/2015	12/11/2015		W R/R near room 106, middle light is dim.
FO-334667	12/10/2015	12/14/2015		Ceiling lights need to be replaced in the faculty office, Rm. 4141.
FO-334673	12/10/2015	12/16/2015		LADIES RM 143 3 LIGHTS OUT
FO-334703	12/11/2015	12/14/2015		Men's restroom, 2nd floor. Lights out, please fix. Thank you.
FO-334772	12/11/2015	12/14/2015		Room 567 - 1 LO
FO-334775	12/11/2015	12/14/2015		Basement 008 - M R/R - 1 LO
FO-334777	12/11/2015	12/14/2015		Room 367 - 1 LO
FO-334782	12/11/2015	12/14/2015		REPLACE FLOURESCENT LIGHT BULB IN DOCK AREA.
FO-334832	12/14/2015			Relamp the light fixtures in the following areas of CMMG 3240.20;3240;3280.09;3280.1
FO-334848	12/14/2015			REPLACE BLOWN BULBS OUT SIDE OF ROOM 121 AND INSIDE ELEVATOR 2
FO-334921	12/15/2015	12/18/2015		Unisex restroom 2nd floor 2307 needs a light bulb.
FO-334991	12/16/2015	12/18/2015		light out in hallway on 3rd floor, by rooms 3211 and 3210.
FO-335021	12/16/2015	12/17/2015		Room 2335 seems to have some electrical issues and needs to be looked at. All of the lights do not come on.
FO-335035	12/16/2015	12/17/2015		EDC Basement room 0504.08 - Light out
FO-335051	12/16/2015	12/17/2015		4 light bulbs need to be replaced in the Kresge Auditorium. At this time the auditorium is available for the technician on the afternoon of December 16 and all day on December 17. Thank you.
FO-335038	12/16/2015	12/18/2015		Room 3103 - Strip of lights are out.
FO-335055	12/16/2015	12/18/2015		2nd floor - 12 lights out - men's dressing room; Please go to Box Office for key from 12pm to 6pm.
FO-335062	12/16/2015	12/21/2015		URGENT R/R RM 1253 HAS FLICKERING LITES THAT ARE DISTURBNING OCCUPANT
FO-335077	12/16/2015	12/22/2015		LIGHTS NEED REPLACING. ROOM 3141.2
FO-335177	12/18/2015			Lights underneath the tall cubicle area are flickering and others are out.
FO-335184	12/18/2015	12/22/2015		Stairwell C/1st floor - Light out behind door to basement stairs.
FO-335185	12/18/2015	12/21/2015		Stairwell A/1st floor - Light bulb out inside door to basement and light bulb out inside door to hallway. 2 bulbs total.
FO-335191	12/18/2015	12/21/2015		Light out over last stall in ladies restroom.
FO-335190	12/18/2015			3 lights out in lobby area outside ladies restroom.
FO-335192	12/18/2015			Light out over counter outside Margherio Conference Center.
FO-335201	12/18/2015			Relamp vertical light fixture just south of the elevators on the main 3rd floor corridor.
FO-335197	12/18/2015	12/22/2015		5th floor, D stairwell - 1 LO (Special Can Light)
FO-335199	12/18/2015	12/21/2015		Basement - A stairwell - 1 LO.
FO-335200	12/18/2015	12/22/2015		Basement - B stairwell - 1 LO.
FO-335203	12/18/2015	12/24/2015		Room 321 - 2 LO
FO-335202	12/18/2015			CARRIAGE HSE FOR TIERNEY BLDG R/R 2ND FLR NEED TO REPLACE SUB ROLL BURNT OUT & FLICKERING LITES
FO-335635	12/22/2015	12/22/2015		Room 008.40 (One light is out, and the second light is very dim) This room is located in the basement near custodial office 15. (Storage room area).
FO-335679	12/23/2015	12/24/2015		Room 210 - Panel Light - 1 LO
<b>C-Materials</b>			<b>5</b>	
FO-334033	12/2/2015			3 recycling bins to basement; 1 by elevator, 2 by handicap door.
FO-334121	12/2/2015			Need new recycling bin in room 711 HWCRC. The bin in there now is full.

WO	Recieved	Finished	Total	Request
FO-334778	12/11/2015			4 recycling bins need to be emptied and replaced. Department is in the process of moving, and regularly needs these emptied and returned.
FO-335118	12/17/2015			RECYCLING ON 3RD FLOOR NEAR 3103. CONTAINER OVERFLOWING.
FO-335205	12/18/2015			Recycling bin - pick up and replace - 3rd floor hall way, near 3103.
<b>C-Repair</b>			<b>22</b>	
FO-334093	12/2/2015	12/8/2015		Across from room 3391 - Towel Dispenser has been removed from wall - needs to be reattached.
FO-334214	12/4/2015			ADVANCE VACUUM, serial #1907677, THE HOUSING UNDER THE VACUUM IS BLOWING OUT DUST, HOUSING CRACKED AND HANDLE WILL NOT STAY IN UPRIGHT POSITION, SOMETIME IT WILL NOT CATC. VACUUM IN STOCK ROOM 021 IN
FO-334215	12/4/2015	12/22/2015		SANITAIRE VACUUM SC689, SERIAL #94525546, NO BAG, NO ROLLER/BRUSHES NOT WORKING WILL NOT COME ON, RUSTED IN SEVERAL AREAS. SCRAP OUT???
FO-334451	12/8/2015			Auto scrubber in basement of Applebaum model X24D-C Serial # 1983791 has a broken scrub brush, and water either comes out slowly or not at all.
FO-334568	12/10/2015	12/11/2015		Both roll towel dispensers in the 1st floor men's room 132 are broken.
FO-334574	12/10/2015	12/11/2015		Vacuum cleaner located in custodial closet 403 dirt cup (holder) won't level, vacuum releasing dirt & dust while vacuuming.  Model: SC887 Type: Sanitaire 3-3 Serial #:1339009034
FO-334575	12/10/2015	12/14/2015		Sanitaire vacuum in the chemistry building will not pick up.
FO-334576	12/10/2015			Auto scrubber in State Hall will not hold a charge at all.
FO-334611	12/10/2015	12/11/2015		Basement, south side, Women's R/R - Soap Dispenser is broken off of the wall.
FO-334623	12/10/2015			TENNANT FLOOR SWEEPER--BRUSHES NOT TURNING AND SHOWING F50 ON SCREEN. PLEASE CHECK FILTER/CHANGE FILTER IF NEEDED.
FO-334625	12/10/2015	12/15/2015		SANITAIRE VACUUM, SERIAL #112400571, MODEL #SC887, HOUSING IS BROKEN INTO PIECES. PLEASE REPAIR. LOCATED IN JANITOR CLOSET 13 IN BASEMENT OF PURDY LIBRARY.
FO-334626	12/10/2015			SANITAIRE VACUUM 0825001480, MODEL SC689, LOUD, BLOWING DUST FROM BOTTOM OF VACUUM, PLEASE CHECK SEALS. VACUUM LOCATED IN JANITOR CLOSET 13 IN BASEMENT OF PURDY LIBRARY.
FO-334679	12/11/2015			The Power Washer is not pumping out water.
FO-334749	12/11/2015	12/15/2015		the soap dispenser in the 2nd floor men's room 2238 is broken.
FO-334967	12/15/2015	12/16/2015		VACUUM CLEANER WAS TRANSFER FROM BLD TO CUSTOD. STOCKROOM FOR A BUSH ROLLER. (SANITAIRE/SC689/SER.#-0825003490) Made Out By: Handyman ALP
FO-334971	12/15/2015	12/18/2015		In the WDET RADIO STATION, soap dispenser need in women's restroom. NOT WDET RADIO TRANSMITTER.
FO-334993	12/16/2015	12/21/2015		Women's sanitary napkin holder is missing from 1st floor women's room (middle stall).
FO-334994	12/16/2015	12/21/2015		Soap dispenser is the ladies locker room (second dispenser on the wall) is broken.
FO-334995	12/16/2015	12/22/2015		Sanitaire Vacuum beater bar is broken. The vacuum is located in the custodial closet on the 1st floor.
FO-335116	12/17/2015	12/21/2015		WOMEN'S RESTROOM 2126, THE 4TH STALL TISSUE DISPENSER IS BROKEN. TAPE HOLDING IT TOGETHER. PLEASE REPAIR/REPLACE.
FO-335117	12/17/2015	12/21/2015		WOMEN RESTROOM THE TOWEL DISPENSER ON THE WEST WLL IS BROKEN. WILL NOT DISPENSE TOWEL WHEN HANDLE IS PULLED DOWN. PLEASE REPAIR/REPLACE.
FO-335235	12/21/2015	12/21/2015		Soap dispenser cover has broken off in women's restroom, 3rd floor.  THE REQUESTER IS SECTOR # 8 SUPERVISOR:
<b>C-Sector 01</b>			<b>10</b>	
FO-334137	12/3/2015			Rooms 230, 240, and student space - please scrub and wax floors.
FO-334440	12/8/2015	12/21/2015		This lab is in need of custodial service. The researcher says they are not getting any service. They would appreciate at least once a week service in the research lab.  We continue to have access issues but the task is complete

WO	Recieved	Finished	Total	Request
FO-334533	12/9/2015	12/21/2015		Requesting to have the conference room carpets shampooed and deep cleaned. Please coordinate with cleaning dates with Ferna Childs.  Task is complete
FO-335150	12/18/2015			2 cases of dial soap.
FO-335151	12/18/2015			2 cases of dial soap.
FO-335152	12/18/2015			2 cases of dial soap.
FO-335153	12/18/2015			2 cases of dial soap.
FO-335154	12/18/2015			2 cases of dial soap.
FO-335227	12/21/2015			I was asked if I could put in a request to have the floors mopped and waxed on Wednesday January 6, 2015 please? Also, I have been taking out my own trash these past few months. Do the custodians not have a key to this lab? I am running out of trash bags
FO-335554	12/22/2015	12/24/2015		Need general custodial service. Room needs regular trash pickup and also mopping.  Task is complete.
<b>C-Sector 02</b>			<b>8</b>	
FO-334231	12/4/2015			1st floor men's bathroom has extreme dirt under urinal area and needs deep scrubbing.
FO-334230	12/4/2015	12/3/2015		Please scrubbing and waxing rooms 4220,4240, 4254
FO-334232	12/4/2015	12/3/2015		Please scrubbing and waxing 4220, 4240, 4254
FO-334233	12/4/2015	12/4/2015		Please strip and wax 7205
FO-334543	12/9/2015			Room 3206 Scott Hall - Clean the carpet.
FO-334544	12/9/2015			Floor needs a good mopping.
FO-335022	12/16/2015			Real Room Number 125.1.Please shampoo carpet. Staff member moving into this office.Thank you.
FO-335168	12/18/2015			Rm. 1236 needs to be mopped. There is equipment in the room that's on wheels and will need to be moved, but the faculty person who is requesting the mopping said that if custodial staff needs others to move it, please mention it.
<b>C-Sector 03</b>			<b>1</b>	
FO-334590	12/10/2015	12/10/2015		5 boxes of gojo.
<b>C-Sector 04</b>			<b>4</b>	
FO-334492	12/9/2015			2 cases of dial soap.
FO-334494	12/9/2015			2 cases of dial soap.
FO-334495	12/9/2015			2 cases of dial soap.
FO-334769	12/11/2015			1 case gojo green.
<b>C-Sector 05</b>			<b>4</b>	
FO-334140	12/3/2015			Floors in PC lab 2351 and 2319 Need to be buffed and waxed.Best time to do this will be after final exams (Dec 22) and before classes start in the winter (Jan 11).
FO-334951	12/15/2015			2 cases of dial soap.
FO-334952	12/15/2015			2 cases of dial soap.
FO-334953	12/15/2015			1 case of dial soap.
<b>C-Sector 06</b>			<b>14</b>	
FO-334044	12/2/2015	12/8/2015		10 boxes of dial soap.
FO-334048	12/2/2015	12/8/2015		8 boxes dial soap.
FO-334162	12/3/2015	12/14/2015		Have hallway floors mopped and waxed (hallway from rm 300 to rm. 314. Please have done during final exam week of December 16. Thank you. Contact Gwen Cotton 7-3295
FO-334163	12/3/2015	12/22/2015		Shampoo rear corridor hallway.
FO-334164	12/3/2015	12/22/2015		Shampoo carpets in cubicles and main corridor.
FO-334166	12/3/2015	12/22/2015		Shampoo carpet in the Damon J. Keith break room.
FO-334639	12/10/2015			2 boxes of dial soap.
FO-334640	12/10/2015			2 boxes of dial soap.
FO-334641	12/10/2015			2 boxes of dial soap.
FO-334648	12/10/2015			2 boxes of dial soap.

WO	Recieved	Finished	Total	Request
FO-334657	12/10/2015			2 boxes of dial soap
FO-334663	12/10/2015			4 boxes of dial soap.
FO-334664	12/10/2015			2 boxes of gojo soap.
FO-334665	12/10/2015			2 boxes of gojo.
<b>C-Sector 07</b>			<b>9</b>	
FO-334016	12/2/2015	12/2/2015		Purdy Library, 3rd & 4th Floors Trash is overflowing and restrooms are filthy. Students and staff are complaining about the mess. Staff working in areas report that we have had no custodial service on 3rd & 4th floors since November 20th!  I called
FO-334079	12/2/2015	12/9/2015		4 cases of dial soap.
FO-334080	12/2/2015	12/15/2015		5 cases of dial soap.
FO-334081	12/2/2015	12/9/2015		4 cases of dial soap.
FO-334086	12/2/2015	12/9/2015		2 cases of dial soap.
FO-334089	12/2/2015	12/9/2015		4 cases of dial soap.
FO-335045	12/16/2015			Rehearsal room floors need to be waxed and buffed. Please schedule during the week of January 4th.
FO-335046	12/16/2015			Rehearsal room floors need to be waxed and buffed. Please schedule during the week of January 4th.
FO-335047	12/16/2015			Rehearsal room floors need to be waxed and buffed. Please schedule during the week of January 4th.
<b>C-Sector 08</b>			<b>7</b>	
FO-334136	12/3/2015	12/11/2015		For the carpenter's shop - scrub and wax the floor on December 11, 2015 for the Christmas party.
FO-334303	12/7/2015	12/11/2015		The carpet needs to be cleaned from a leak last week. Water flowed from the ceiling for two days and now there is a large, nasty, smelly stain that is on the carpet in the office and extends approximately 4 feet out into the hallway. There are
FO-334514	12/9/2015			4 cases of dial soap. As of this date my order never been drop off TW
FO-334515	12/9/2015			4 cases of dial soap. As of this date this order never been drop off TW
FO-334516	12/9/2015			8 cases of dial soap. As of this date this order never been drop off. TW
FO-334517	12/9/2015			6 cases of gojo soap. As of this date this order never been drop off. TW
FO-334908	12/14/2015			Please empty trash can that is outside of the front door of IBio at Woodward entrance. We need to know who is the scheduled person to service the IBio front entrance? Please contact Theresa Hill @ 7-0556. Thank you!
<b>C-Sector 09</b>			<b>7</b>	
FO-334954	12/15/2015	12/23/2015		1 case of dial soap.
FO-334955	12/15/2015	12/23/2015		1 case of dial soap.
FO-334956	12/15/2015	12/23/2015		1 case of dial soap.
FO-334957	12/15/2015	12/23/2015		1 case of dial soap.
FO-334958	12/15/2015	12/23/2015		1 case of dial soap.
FO-334959	12/15/2015	12/23/2015		1 case of dial soap.
FO-335012	12/16/2015	12/22/2015		please clean (vacuum and mop) rooms 253, 255, 262 and 296 on the second floor. Thank you
<b>Pest Controller</b>			<b>11</b>	
FO-333997	12/1/2015	12/3/2015	12/3/2015	R/R RM 11201 SHE HAS BABY MICE IN OFC YOU PUT DOWN STICKY TRAPS DOWN THEY AREN'T USING THEM WOULD LIKE IF POSSIBLE SOME OTHER SOLUTION CAN HELP HER OUT
FO-334091	12/2/2015	12/8/2015	12/8/2015	There is a report that there are ants in this lounge
FO-334097	12/2/2015	12/4/2015	12/4/2015	EXTERMINATION FOR MICE. ROOM 1120.1. CONTACT ALICIA.
FO-334409	12/8/2015	12/18/2015	12/18/2015	EXTERMINATION FOR MICE. ROOM 4224.

WO	Recieved	Finished	Total	Request
FO-334742	12/11/2015	12/18/2015	12/18/2015	R/R BSMNT MENS RR HAS BED BUGS
FO-334902	12/14/2015	12/14/2015	12/14/2015	Carpenter needed to reopen wall in stairwell (CC: Pest Control) to access pest problem (possible dead animal in wall).
FO-334931	12/15/2015	12/17/2015	12/17/2015	EXTERMINATION FOR BED BUGS. LOBBY
FO-335165	12/18/2015	12/21/2015	12/21/2015	EXTERMINATION FOR MICE AND FRUIT FLIES. 3RD FLOOR ROOM 354.
FO-335209	12/21/2015	12/21/2015	12/21/2015	9th floor, office 9100.3 mice in trap, please remove.
FO-335636	12/22/2015	12/22/2015	12/22/2015	POSSUM OUTSIDE OF FRONT ENTRANCE DOOR ON WARREN AVE.
FO-335653	12/22/2015	12/22/2015	12/22/2015	R/R BTWN THE BOOKSTORE & WELCOME CTR REPORTS OF AN INJURED POSSUM
<b>Engineering</b>			<b>438</b>	
<b>Emergency</b>			<b>16</b>	
<b>E - Auxiliary</b>			<b>2</b>	
FO-334595	12/10/2015	12/10/2015		CAFE KITCHEN HOT WATER IS SPEWING OUT OF HOSE TO THE SOUP KETTLE
FO-334969	12/15/2015	12/15/2015		FAP IS ACTIVE FOR SEVERAL APTS PLS CK W/DESK
<b>E - Command Center</b>			<b>1</b>	
FO-334392	12/8/2015	12/8/2015		DA HONEYWELL CONTROLLER NOT WORKING IN AUTO. BOILER ROOM.
<b>E - MedPharm</b>			<b>1</b>	
FO-334046	12/2/2015	12/2/2015		ACTIVE FIRE ALARM SOUNDING
<b>E - North</b>			<b>4</b>	
FO-334519	12/9/2015	12/9/2015		EMERGENCY ELEC R/R RM 00051/MECH RM DOMESTIC HOLD TANK AIR COMPRESSOR NOT STARTING ENTIRE BLDG ESPECIALLY 4TH FLR LOW WTR PRESSURE SINKS, TOILETS, URINALS (KITCHEN 4TH FLR)
FO-334527	12/9/2015	12/9/2015		EMERGENCY ELEC R/R RM 00051/MECH RM DOMESTIC HOLD TANK AIR COMPRESSOR NOT STARTING ENTIRE BLDG ESPECIALLY 4TH FLR LOW WTR PRESSURE SINKS, TOILETS, URINALS (KITCHEN 4TH FLR)
FO-334972	12/15/2015	12/15/2015		FAP IS ACTIVE
FO-335724	12/24/2015	12/24/2015		WEST ELEV SUMP PUMP IS IN ALARM
<b>E - Northeast</b>			<b>1</b>	
FO-335232	12/21/2015	12/21/2015		FIRE ALARM
<b>E - Preventative Maintenance</b>			<b>2</b>	
FO-333742	12/1/2015	12/1/2015		STRONG GAS SMELL IN THE AREA OF UNIT IN BACK OF BLDG & ALSO MAKING A VERY LOUD NOISE
FO-335257	12/21/2015	12/21/2015		LOADING DOCK DOOR STUCK OPEN SHOULD BE SECURED TONIGHT
<b>E - South</b>			<b>3</b>	
FO-334746	12/11/2015	12/11/2015		RM 0330 HAS A CLNG PIPE THAT HAS BROKEN
FO-334839	12/14/2015			RM 3210 BLOWN FUSE, EVENT IN PROGRESS
FO-335725	12/24/2015	12/24/2015		3rd flr OIL IS SPEWING OUT NEAR AREA? CAUSING FAP IS ACTIVE
<b>E - Southeast</b>			<b>1</b>	
FO-335707	12/23/2015	12/23/2015		BSMT AREA NEAR RESTAURANT 1ST FLR WATER IS FLOODING INTO BSMT FROM CLNG
<b>E - West</b>			<b>1</b>	
FO-335170	12/18/2015			ACTIVE FIRE ALARM
<b>High</b>			<b>227</b>	
<b>E - Auxiliary</b>			<b>15</b>	
H-56119	12/3/2015			dripping bathtub faucet.Heavy dripping no handle shifting stops it.authenticated user: Manaswini Remidi - fs2524requester ip address: 141.217.23.173
H-56125	12/3/2015			kitchen sing is leaking very badlyauthenticated user: Najeeb Arafat Mohammed - fr9153requester ip address: 141.217.23.175
H-56126	12/3/2015			URGENT: left side of kitchen sink: pipes are very loose underneath and is causing water to leak out.

WO	Recieved	Finished	Total	Request
H-56145	12/4/2015			Resident says that sink in kitchen is leaking. Resident says that an engineer was suppose to come to her apartment and take a look at the leak today (12/3/15) but did not. Resident is unable to use her kitchen sink and would like this issue fixed as soon
H-56172	12/5/2015			when we turn the heat on, after a while it smells funky authenticated user: Nicholas Groder - fv7713 requester ip address: 35.16.100.48
FO-334753	12/11/2015			FIRE TROUBLE ALARM.
H-56320	12/15/2015			There is a leak in the faucet in the bathroom.(The one attached to the bathtub) This needs an immediate repair. authenticated user: Shameemah Mohamed Thawoos - fp8856requester ip address: 35.16.67.224
H-56322	12/15/2015			Hot water in bathtub will not start, water continues to remain cold. authenticated user: Jeron Johnson - fa6854requester ip address: 166.176.251.196
H-56323	12/15/2015			the air conditioner is not producing heat authenticated user: Amedahe Senyo - fx8756requester ip address: 35.16.72.199
H-56338	12/16/2015			Engineering Request - Please replace light fixture in shower. Short is causing other lights to trip circuit #5 in breaker panel. authenticated user: Isabell Groves - fb2096requester ip address: 141.217.23.175
FO-335110	12/17/2015			No heat rooms 1, 2, 3,4
H-56352	12/17/2015			The kitchen tap is giving white cold water and white hot water which is not fit to drink.authenticated user: Mohit Kumar - fq4083requester ip address: 141.217.221.164
H-56400	12/22/2015			The light bulb is out in the shower and the switch for the bulb if turned on trips the bedroom and hallway lights. Engineers who came in earlier said that a fuse needed to be replaced, but the fuse was never replaced. Please fix this ASAP. authenticated
FO-335689	12/23/2015			SIMPLEX ALARM PANEL SOUNDING. 1ST FLOOR OFFICE.
H-56421	12/23/2015			Kitchen sink pipe leaking very severely. Thank you!authenticated user: Allison Zhang - ed4262requester ip address: 107.92.120.202
<b>E - Command Center</b>			<b>13</b>	
FO-334312	12/7/2015	12/8/2015		Control Engineer; High Please repair heat pump 1-57-071-HWP-015 located in the southeast wing on the fifth floor. The unit is not running.
FO-334395	12/8/2015	12/9/2015		Trade: Controls/Siemens Priority: High H&V #1 will not run, I had to place it in bypass at the drive, Siemens is in OCC mode, freeze stat is normal.
FO-334592	12/10/2015			Controls --Priority High R/R RM 108 Unit requires multiple daily manual resets. Unit is not switching correctly from cooling to heating modes. Setting off alarms in Software
FO-334591	12/10/2015			Controls --Priority High R/R RM 105 Unit requires multiple daily manual resets. Unit is not switching correctly from cooling to heating modes. Setting off alarms in Software
FO-334603	12/10/2015	12/14/2015		Control Engineer; High R/R RM 2022 Please repair the bad diaphragm in the control steam valve for the radiator in Suite 2022.
FO-334630	12/10/2015	12/21/2015		controls- R/R RM 00134 please replace stats in room 134.no way to control temperature with out this needed repair.rooms in complex in the 80s with the windows open.High priority.
FO-334779	12/11/2015	12/18/2015		Trade: Command Center Priority: High R/R RM 00000.62/MECHF007.07 in the subbasement for the hydronic system failed. All points showed cabinet error. Controller BATT light is on. Backup battery power supply may not be working properly. Plug was move
FO-334824	12/14/2015			Control Engineer; High R/R RM 10202 Please repair heat pump 2-58-071-HWP-106. The blower fan is not running, believe the motor capacitor is bad.
FO-334870	12/14/2015	12/15/2015		controls group, No. 1 boiler locked out on low water limit. will not reset please correct condition priority high
FO-335196	12/18/2015			AC Shop, High; Repair as needed York stand alone unit. High discharge temp. Only one of two compressors operating. Unit behind louvered doors across from Rm. 2109.
FO-335461	12/22/2015			Trade: Command CenterPriority: HighPlease repair WCIS on laptop computer.

WO	Recieved	Finished	Total	Request
FO-335463	12/22/2015		12/23/2015	boiler 1 will not start after power bump
FO-335660	12/22/2015			Controls -- Priority HighPlease repair #1 boiler pump controls. Control constantly trips causing boiler to kick out due to low water
<b>E - MedPharm</b>			<b>68</b>	
FO-333754	12/1/2015	12/1/2015		RM 200.06 HAS A LOW TEMP
FO-333772	12/1/2015	12/1/2015		JAFAR LECT HALL IS TOO HOT
FO-333946	12/1/2015	12/1/2015		RM 2115 IS TOO HOT
FO-333947	12/1/2015	12/1/2015		UPPER PENTHOUSE: RETURN FAN #6 BROKEN BELTS NEED REPAIRING
FO-333984	12/1/2015	12/1/2015		RM 9224 PLEASE CHANGE AIR VENT FILTER, IF RM IS LOCKED GO TO RM 9232
FO-333986	12/1/2015			RM 515 TOO HOT
FO-333988	12/1/2015	12/2/2015		RM 2148 TOO HOT
FO-334036	12/2/2015	12/2/2015		RM 200.13 HIGH TEMP
FO-334055	12/2/2015	12/14/2015		TRAP DOOR IS HANGING OPEN. PLEASE CLOSE. ROOM 199.
FO-334057	12/2/2015	12/2/2015		HIGH TEMP. ALARM. ROOM 8337.
FO-334072	12/2/2015			Room has positive air flow, needs to be negative.
FO-334143	12/3/2015			RM 0225 CAGE WASHER TEMP IS LOW ALSO NO STEAM
FO-334161	12/3/2015	12/9/2015		RM 200.13 HIGH TEMP
FO-334204	12/4/2015	12/8/2015		HIGH TEMPS. ROOMS 414, 415, 419 & 423.
FO-334239	12/4/2015	12/4/2015		FAP FIRE TROUBLE ALARM
FO-334290	12/7/2015			RM 415 HIGH TEMP
FO-334292	12/7/2015	12/14/2015		MECH RM 4210, BEEPING NOISE
FO-334299	12/7/2015	12/14/2015		RM 4229 REPLACE DIFUSSER COVER & FILTER
FO-334305	12/7/2015	12/7/2015		RM 2548 TOO COLD
FO-334316	12/7/2015	12/7/2015		RM 5234 & 5236 TOO COLD
FO-334320	12/7/2015	12/7/2015		2377 NO WATER PRESSURE
FO-334322	12/7/2015	12/7/2015		8327 NO WATER PRESSURE
FO-334389	12/8/2015	12/8/2015		LOW HUMIDITY. ROOM 200.06.
FO-334426	12/8/2015			Rooms need to be under negative pressure
FO-334433	12/8/2015			Room needs to be under negative pressure
FO-334434	12/8/2015			room needs to be under positive pressure
FO-334442	12/8/2015			ACTIVE FIRE ALARM
FO-334529	12/9/2015	12/12/2015		CEILING LEAK (STICKY SOLUTION). HALLWAY OUTSIDE OF ROOM 1311.
FO-334580	12/10/2015			RM 318 IS TOO COLD
FO-334594	12/10/2015	12/12/2015		TOO HOT. ROOM 1328.
FO-334615	12/10/2015	12/12/2015		RM 9115 BAD ODOR
FO-334628	12/10/2015	12/12/2015		RM 540.2 HAS A CLNG LEAK CLNG TILES ARE ABOUT TO COLLAPSE
FO-334697	12/11/2015			not enough air flow going into room
FO-334715	12/11/2015			RM 4367 TEMP ALARM
FO-334717	12/11/2015	12/12/2015		3RD FL CENTRAL CORRIDOR BURNING SMELL
FO-334721	12/11/2015	12/11/2015		ALARM SOUNDING. COLD ROOM. ROOM 4367.
FO-334726	12/11/2015	12/11/2015		RM 540.2 HAS A CLNG LEAK AGAIN SAME AREA
FO-334743	12/11/2015			RM 5441 WALK IN COLD RM BOX ISN'T COOLING IS GETTING HOT W/ALARM
FO-334830	12/14/2015	12/15/2015		ALL ANIMAL RM'S HIGH TEMP INCLUDING RM 7119
FO-334844	12/14/2015	12/15/2015		Room temperature is very high(79 degree now). Please open the air condition and change the filter. Thank you
FO-334860	12/14/2015	12/15/2015		HIGH HUMIDITY. THE ENTIRE 200 SUITE.
FO-334862	12/14/2015	12/15/2015		FIRE TROUBLE ALARM
FO-334875	12/14/2015	12/15/2015		RM 6111 TOO HOT



WO	Recieved	Finished	Total	Request
FO-334899	12/14/2015			RM 8327 (FISH RM) IS TOO COLD
FO-334900	12/14/2015			HIGH HUMIDITY. ROOM 0243.
FO-334937	12/15/2015			RM 6374 POWER OUT
FO-335017	12/16/2015			RM 00136 FREEZER #2 HAS HI TEMP ALARM ACTIVE
FO-335030	12/16/2015			RM 1540 TOO HOT
FO-335054	12/16/2015	12/23/2015		BLUE LECTURE HALL TOO COLD, EXAMS IN PROGRESS
FO-335064	12/16/2015			EXPERT SVCS CO SET OFF FAP BY ACCIDENT
FO-335104	12/17/2015			ANIMAL ROOMS ARE READING POSITIVE ROOMS 0501, 0507, 0510, 0513, 0514, 0520, 0522, 0234, 0239 & 0225. THEY SHOULD BE NEGATIVE. TO CONFIRM PLEASE CONTACT LAURA MCINTYRE.
FO-335142	12/18/2015			RM 6360 IS TOO COLD
FO-335173	12/18/2015			RM 5450 LOW TEMP ALARM
FO-335178	12/18/2015			COLD RM 5520 TOO COLD
FO-335213	12/21/2015			COLD ROOM 5441 IS NOT WORKING.
FO-335221	12/21/2015	12/23/2015		FIRE PANEL PEEPING ON FIRE SUPPRESSION SYSTEM
FO-335462	12/22/2015	12/23/2015		TOO HOT. 400 SUITE.
FO-335466	12/22/2015			RM 9228 SOMETHING IS OVERFLOWING FLOODING AREA? (BELIEVE A PIPE CONNECTED TO LARGE AUTOCLAVE IS BROKEN)
FO-335559	12/22/2015			7256 HIGH TEMP ALARM
FO-335560	12/22/2015			RM 8337 WALK IN COLD RM BOX HAS A HI TEMP ALARM ACTIVE
FO-335561	12/22/2015			RM 7212 WALK IN COLD RM BOX HAS A HI TEMP ALARM ACTIVE
FO-335562	12/22/2015	12/23/2015		HIGH TEMP. ROOM 4215.
FO-335563	12/22/2015			6238 HIGH TEMP ALARM
FO-335655	12/22/2015			RM 419 IS TOO HOT
FO-335685	12/22/2015	12/23/2015		On outside of the walkway on the south side of Scott Hall there is a piece of trim that needs to be screwed down. It is sticking out at a 90 degree angle and is a trip hazard for people walking by. See Sheryl in 1102 Scott Hall for exact locatio
FO-335675	12/23/2015			POSITIVE PRESSURE IN ROOMS 5540 AND 5565. SHOULD BE NEGATIVE. CONTACT SERENE TO CONFIRM.
FO-335681	12/23/2015			LOW TEMP. ROOM 0243.
FO-335721	12/24/2015			RM 0243 LOW TEMP
<b>E - North</b>			<b>27</b>	
FO-333774	12/1/2015	12/1/2015		RM 421 IS TOO HOT
FO-333954	12/1/2015	12/1/2015		3rd FL 3 NORTH, TOO COLD
FO-334019	12/2/2015	12/2/2015		LOADING DOCK GATE IS STUCK OPEN.
FO-334056	12/2/2015	12/2/2015		RM 321 TOO COLD
FO-334084	12/2/2015	12/2/2015		ENTIRE BLDG IS GETTING HOT WOULD LIKE HEAT TURNED DOWN JUST A BIT
FO-334202	12/4/2015	12/4/2015		PARTRIDGE AUD IS TOO HOT
FO-334210	12/4/2015	12/4/2015		This office is located within the 146 suite. It is on the outside wall. The temperature in this office needs to be adjusted. It's very cold in there.  Thank you!
FO-334307	12/7/2015			A/C (COOL AIR) AND HEAT FROM VENTS ARE BLOWING PAPERS ON DESK. ROOM 2097.
FO-334412	12/8/2015	12/8/2015		RM 421 TOO HOT
FO-334430	12/8/2015	12/8/2015		RM 134 TOO HOT
FO-334499	12/9/2015	12/9/2015		ENTIRE BLDG IS TOO HOT
FO-334530	12/9/2015	12/9/2015		PLEASE RESET MAIN EMERGENCY EXIT DOOR ALARM.
FO-334599	12/10/2015	12/10/2015		134 TOO HOT

WO	Recieved	Finished	Total	Request
FO-334621	12/10/2015	12/11/2015		OUTSIDE ART BLDG ACROSS FROM MCGREGOR, BIKE RACK IS LOOSE LOOKS LIKE IT MAY FALL OVER.
FO-334622	12/10/2015	12/10/2015		3RD FL TOO HOT
FO-334624	12/10/2015	12/10/2015		RM 395 TOO HOT
FO-334693	12/11/2015	12/11/2015		LIGHTS ARE FLICKERING. 1ST FLOOR MAIN LOBBY.
FO-334709	12/11/2015	12/11/2015		BLDG TOO HOT
FO-334748	12/11/2015	12/11/2015		FIRE TROUBLE ALARM. EAST ENTRANCE.
FO-334755	12/11/2015	12/11/2015		NO LIGHTS 1ST FLOOR LOBBY AND HALLWAY.
FO-334835	12/14/2015	12/14/2015		RM 1225 TOO WARM
FO-334837	12/14/2015	12/14/2015		RM 1550 TOO WARM
FO-334841	12/14/2015	12/14/2015		2095 COLD AIR BLOWING HARD
FO-335005	12/16/2015	12/16/2015		SUMP PUMP ALARM. EAST ELEVATOR.
FO-335025	12/16/2015	12/16/2015		BSMNT RM 55 WOOD SHOP TOO COLD
FO-335123	12/17/2015	12/17/2015		3RD FL AREA NEAR RM 350 & STACKS, OPEN AREA TOO COLD
FO-335237	12/21/2015	12/21/2015		RM 134 TOO WARM
<b>E - Northeast</b>			<b>26</b>	
FO-333778	12/1/2015	12/2/2015		2ND FLR MULTIPURPOSE RM IS TOO HOT
FO-333953	12/1/2015	12/1/2015		1ST FL STRONG GAS SMELL IN BUS SERVICE AREA
FO-334035	12/2/2015	12/4/2015		CUSTODIAL OFC IS TOO HOT
FO-334120	12/3/2015	12/4/2015		2ND FLR MULTIPURPOSE RM IS TOO HOT
FO-334129	12/3/2015	12/7/2015		BACK OFFICES 255 & 257 TOO COLD
FO-334293	12/7/2015	12/7/2015		2ND FL NO HEAT
FO-334296	12/7/2015	12/7/2015		BLDG TOO COLD, DIANE'S OFFICE AND CUSTODIAL OFFICE
FO-334326	12/7/2015	11/18/2015		4TH FL RM'S TOO HOT
FO-334391	12/8/2015			TOO HOT. 2ND FLOOR MULTI PURPOSE ROOM.
FO-334522	12/9/2015	12/9/2015		TOO HOT. ROOM 33 (SERVER ROOM) SEE CAROL TALBOT FOR KEY TO ROOM.
FO-334546	12/9/2015	12/9/2015		TOO COLD. 2ND FLOOR INCLUDING MRS. WILSON'S OFFICE.
FO-334588	12/10/2015	12/10/2015		2ND FL TOO COLD, FIRST LADY WILSON'S OFFICE ALSO VERY COLD...PLEASE UPDATE DENISE 577-9933 SHE WOULD LIKE A SPACE HEATER IF PROBLEM CAN'T BE FIXED.
FO-334608	12/10/2015			BSMT CARRIAGE HOUSE SIDE THERE'S A BROKEN PIPE & ITS LEAKING
FO-334612	12/10/2015	12/10/2015		OFFICE IS WARM, NEED TO KNOW HOW TO ADJUST TEMPERATURE. SEE DENISE GREEN.
FO-334650	12/10/2015	12/10/2015		LOUD NOISE COMING FROM ROOM 1015.
FO-334690	12/11/2015	12/11/2015		FIRE TROUBLE ALARM.
FO-334691	12/11/2015	12/11/2015		FIRE TROUBLE ALARM.
FO-334732	12/11/2015			ENTIRE SUB BSMT IS EXTREMELY HOT
FO-334884	12/14/2015			1ST FLR EARLY CHILD HOOD IS TOO HOT OVER 80degrees
FO-334929	12/15/2015	12/15/2015		LOW TEMP. ROOM 214.
FO-335041	12/16/2015			Check Vending machine outlets on the first and second level for power surges. Outlet is currently not working.
FO-335060	12/16/2015	12/16/2015		3RD FLR OFC @ TOP OF FRONT STRWL IS TOO COLD (door is closed however unlocked)
FO-335223	12/21/2015			DIANE'S OFFICE IS TOO WARM. WOULD LIKE TEMP BETWEEN 68-70 DEGREES
FO-335230	12/21/2015	12/21/2015		PLEASE LET AT&T INTO PHONE CLOSET. WAYNE (ATT) PARKED ACROSS FROM MORT SCI
FO-335236	12/21/2015	12/22/2015		REPLACE FAULTY SMOKE DETECTOR ON RTU #1. (FIRE ALARM). (MULTI-TASK)
FO-335673	12/23/2015	12/23/2015		TEMPERATURE ALARM. LOW TEMP. ALARM. ROOM 214.
<b>E - Preventative Maintenance</b>			<b>33</b>	
FO-334000	12/1/2015	12/2/2015		RM 313 IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-334001	12/1/2015	12/2/2015		RM 312 SINK IS LKNG FROM UNDERNEATH NEED TO SHUT WTR OFF (NOTE: REFERING REQ ALSO TO PLUMBERS)
FO-334007	12/1/2015	12/2/2015		RM 1814 BLOWN FUSE, PLEASE RESET BREAKER
FO-334008	12/1/2015	12/2/2015		RM 6203 BACK OF RM, NO POWER
FO-334183	12/3/2015	12/4/2015		URINAL OVERFLOWING. 4TH FLOOR MEN'S RESTROOM.
FO-334186	12/3/2015			3RD FL LADIES RM ALL SINKS ARE BACKED UP ..... GS/12-3-15 .....
FO-334254	12/4/2015	12/5/2015		LAB 407 NO STEAM TO AUTO CLAVE
FO-334255	12/4/2015	12/5/2015		GREEN BACK DOOR OUTSIDE HANDLE HAS FALLEN OFF
FO-334343	12/7/2015	12/8/2015		DOOR WON'T OPEN. ROOM 9370.
FO-334344	12/7/2015	12/10/2015		BSMNT RM 0367 FUSE MAKING A LOUD TICKING NOISE
FO-334462	12/8/2015	12/9/2015		TOO COLD. 2ND FLOOR INCLUDING MRS. WILSON'S OFFICE.
FO-334467	12/8/2015	12/9/2015		RM 303 TOO COLD
FO-334469	12/8/2015	12/8/2015		RM 3305 CEILING LEAK
FO-334561	12/9/2015	12/10/2015		URINALS NOT FLUSHING. MEN'S RESTROOM. ROOM 4101.
FO-334565	12/9/2015	12/9/2015		TOO COLD. 2ND FLOOR INCLUDING MRS. WILSON'S OFFICE.
FO-334661	12/10/2015	12/11/2015		RM 00010 CEILING IS LEAKING
FO-334674	12/10/2015	12/11/2015		RM 5234 TOO HOT
FO-334677	12/10/2015	12/10/2015		1ST FL LOBBY MOST OF THE LIGHTS ARE OUT
FO-334761	12/11/2015	12/12/2015		PLEASE LOCK ROOF DOOR HATCH. ROOM 4360.
FO-334765	12/11/2015	12/15/2015		NO POWER IN WALL OUTLETS. BACK OF OFFICE 6203.
FO-334787	12/11/2015	12/12/2015		In Rm. 3112 by the sink, there is no power coming from the two outlets. Please repair.
FO-334905	12/14/2015	12/14/2015		RM 3107 LOUD HISSING SOUND
FO-334909	12/14/2015	12/14/2015		WOMENS RM TOILET CONTINUOUSLY FLUSHING
FO-334989	12/15/2015	12/16/2015		Room extremely warm. Please adjust temp.
FO-335074	12/16/2015	12/16/2015		NE BACK OF BLDG WOMEN'S RM TOILET RUNNING
FO-335076	12/16/2015	12/17/2015		RM 102.8 RADIATOR LEAKING
FO-335081	12/16/2015	12/16/2015		2375 STRONG ODOR CAN BE SMELLED THROUGHOUT THE 2ND FL
FO-335128	12/17/2015	12/17/2015		BOILER ROOM ALARM.
FO-335130	12/17/2015			CONTRACTOR NEEDS ACCESS TO THE ROOF
FO-335176	12/18/2015			2222 BLOWN FUSE
FO-335256	12/21/2015			LOBBY TOO HOT
FO-335669	12/22/2015	12/23/2015		air conditionor is off and temperature in the room is too high, please come to check if the conditionor is broken, and adjust the temperature before holiday, thanks
FO-335670	12/22/2015			RM 214 LOW TEMP ALARM
<b>E - South</b>			<b>18</b>	
FO-333756	12/1/2015	12/1/2015		RM 111 IS EXTREMELY HOT (cannot hold classes)
FO-333950	12/1/2015	12/1/2015		BSMNT NEAR RM 10 AUDIBLE ALARM SOUNDING FROM DOORS
FO-334205	12/4/2015	12/4/2015		STE 101 (101-107) HAS A CHEMICAL SMELL
FO-334302	12/7/2015	12/7/2015		101 OFFICE BLOCK HAS A SOLVENT SMELL
FO-334333	12/7/2015	12/7/2015		There is the smell of sewer gas in the basement hallway and also the stairwell
FO-334437	12/8/2015	12/8/2015		Room is still too hot. Causing problems with research. The high temps are causing expensive malfunctions with the laser that is being used.
FO-334449	12/8/2015	12/8/2015		RM 2159 IS TOO COLD
FO-334531	12/9/2015	12/9/2015		WALL OUTLET IS NOT WORKING. ROOM 407.
FO-334535	12/9/2015	12/9/2015		Cold room is warm
FO-334536	12/9/2015	12/9/2015		FIRE TROUBLE ALARM.
FO-334692	12/11/2015	12/11/2015		LIGHTS ARE FLASHING. ROOM 1210, 1100 & LOBBY.
FO-334716	12/11/2015	12/11/2015		VERY LOUD NOISE COMING FROM ELECTRICAL ROOM 4173.
FO-334722	12/11/2015	12/11/2015		LOWER AUDITORIUM LIGHTS NOT WORKING, VERY DIM

WO	Recieved	Finished	Total	Request
FO-334735	12/11/2015			REPAIR LIGHT SENSORS. LIGHTS ARE GOING OFF EVERY 3 MINUTES. ROOM 1524. (MULTI-TASK)
FO-334754	12/11/2015	12/11/2015		FIRE TROUBLE ALARM.
FO-334756	12/11/2015	12/11/2015		BEEPING NOISE. 1ST FLOOR LOBBY.
FO-335549	12/22/2015	12/22/2015		ROTH ELEC NEEDS TO GET ACCESS. MEET IN RM 169
FO-335730	12/24/2015	12/24/2015		TEMP. IS TOO HIGH. ROOM 2523.
<b>E - Southeast</b>			<b>20</b>	
FO-334131	12/3/2015	12/3/2015		LOBBY AND THEATRE TOO HOT
FO-334221	12/4/2015	12/4/2015		1ST FLR IS TOO HOT
FO-334441	12/8/2015	12/8/2015		Classroom is very cold. Heat is not working.
FO-334455	12/8/2015	12/9/2015		RM 145.1 WATER IS LEAKING FROM FURNACE
FO-334545	12/9/2015	12/9/2015		RM 212 IS TOO COLD
FO-334585	12/10/2015	12/10/2015		RM 2022 RADIATOR TOO HOT MAKING HISSING SOUND
FO-334596	12/10/2015	12/10/2015		FIRE TROUBLE ALARM
FO-334609	12/10/2015	12/11/2015		LOUD BUZZING NOISE. ROOM 0014.
FO-334689	12/11/2015	12/11/2015		FIRE TROUBLE ALARM. ROOM 102.
FO-334704	12/11/2015	12/11/2015		LIGHTS ARE OUT. 3RD FLOOR HALLWAY NEAR ELEVATOR.
FO-334707	12/11/2015	12/11/2015		LIGHTS OUT. HALLWAY NEAR ROOM 3216.
FO-334826	12/14/2015	12/14/2015		RM 2402 EMERGENCY EXIT DOOR IS IN ALARM
FO-334973	12/15/2015	12/15/2015		NEED HEAT TURNED ON FOR THEATRE
FO-335031	12/16/2015	12/16/2015		FIRE TROUBLE ALARM.
FO-335098	12/17/2015			TOO HOT. ROOM 2022. PLEASE CONTACT SABRINA. ALSO FOLLOWING UP ON ONGOING PROBLEM WITH RADIATOR.
FO-335102	12/17/2015			FAP FIRE TROUBLE ALARM
FO-335159	12/18/2015	12/18/2015		FIRE ALARM.
FO-335176	12/18/2015			2222 BLOWN FUSE
FO-335183	12/18/2015	12/18/2015		6305.3 NO POWER
FO-335234	12/21/2015	12/21/2015		RM 5102 TOO COLD
<b>E - West</b>			<b>7</b>	
FO-334095	12/2/2015			RM 2225 TOO HOT
FO-334115	12/3/2015			POOL WATER IS VERY CLOUDY.
FO-334582	12/10/2015	12/10/2015		Fume Hood in room 1044 is not working
FO-334644	12/10/2015			TRAINING RM T-STAT ISN'T WRKNG
FO-334750	12/11/2015			POWER BUMP. PLEASE CHECK POOL.
FO-335106	12/17/2015			PLEASE ASSIST CONTRACTORS WITH OPENING ELEC CLOSET AND OTHER RM'S. THEY ARE WAITING IN RM 2108
FO-335179	12/18/2015	12/18/2015		BLDG TOO COLD
<b>Medium</b>			<b>62</b>	
<b>E - Command Center</b>			<b>11</b>	
FO-334167	12/3/2015	12/8/2015		AC Shop- R/R LOADING DOCK AREA please install new condensate pump on new heat pump. Medium priority EQ #071-HWP-210 (old HP) NOT IN TMA SYS
FO-334223	12/4/2015			5057 Woodward Communication Wiring Christmas Closure Special Project.  Please install and terminate network communication cabling (P1 Trunk) for Siemens TEC Controllers.
FO-334420	12/8/2015			HP 2-11  Replace Control Board Part # 71028004 Vendor: Griffin International

WO	Recieved	Finished	Total	Request
FO-334488	12/9/2015	12/14/2015		REF CREW R/R RM 00051.10/MECH RM #4 BOILER NEED A IGNITOR MEDIUM PR ATT AUBREY WALLER
FO-334719	12/11/2015	12/11/2015		BAS Med Priority AHU 2 overheating please check and make adjustments
FO-334797	12/13/2015	12/16/2015		Repair steam supply line control valve serving AHU-10 at Scott Hall. Steam is blowing through even when controller is set for 0%. Suspect bad diaphragm.
FO-334881	12/14/2015			Trade: Command Center Priority: Medium R/R RM 00133 Please supply the following Honeywell pneumatic thermostats. This is a follow up to FO 334408. Quantity Type 1 TP970A 2038U 3 TP970A 2004
FO-335043	12/16/2015			Ac Shop - - Medium - Lloyd - Please repair AHU 4 not heating
FO-335114	12/17/2015			BAS Section: Please create a campus generator overview graphics page for Insight.
FO-335225	12/21/2015			Trade: Controls/Siemens Priority: MediumBoilers #1 and #3 are not responding to the Preferred Instruments controller, when its calling for these boilers to be off they continue to run at about 50% firing rate. To get them to shut down I have to place the
FO-335718	12/24/2015			On Boiler #2 feed water pump the electric valve is opening but the pumps are not coming on.
<b>E - MedPharm</b>			<b>11</b>	
FO-334071	12/2/2015			TOO HOT. (RADIATOR IS UP TOO HIGH) ROOM 2206.
FO-334181	12/3/2015	12/4/2015		TOO COLD. 1ST FLOOR QUIET STUDY AREA.
FO-334304	12/7/2015			HEATER IS NOT WORKING. STAIRWELL 1F.
FO-334718	12/11/2015	12/11/2015		TOO HOT. ROOM 9345. PLEASE CALL SHERYL MACGILLIS.
FO-334845	12/14/2015	12/15/2015		TOO HOT. ROOM 5234.
FO-334846	12/14/2015	12/15/2015		TOO COLD. ROOM 8326.
FO-334853	12/14/2015	12/15/2015		TOO HOT. ROOM 2105.
FO-334949	12/15/2015	12/15/2015		TOO HOT. ROOM 354.
FO-335056	12/16/2015			Rooms 412, 416, 419, and 423 need filters changed.
FO-335044	12/16/2015	12/23/2015		TOO COLD. ROOM 1374.
FO-335105	12/17/2015	12/23/2015		PERIMETER HEAT IS NOT WORKING. ROOM 1261.
<b>E - North</b>			<b>13</b>	
FO-334096	12/2/2015	12/2/2015		TOO HOT. ROOM 134.
FO-334207	12/4/2015	12/4/2015		TOO HOT. BUILDING
FO-334314	12/7/2015	12/8/2015		TOO WARM. ROOM 143.
FO-334328	12/7/2015			COLD AIR BLOWING. ROOM 2095.
FO-334528	12/9/2015	12/9/2015		TOO HOT. ROOM 134.
FO-334538	12/9/2015	12/10/2015		TOO HOT. ROOM 30 (BASEMENT).
FO-334617	12/10/2015	12/10/2015		VERY COLD. 3-NORTH INCLUDING ROOM 311.
FO-334821	12/14/2015	12/14/2015		TOO COLD. BUILDING.
FO-335068	12/16/2015	12/16/2015		The heat on the 4th floor in FAB is too high again - it was actually perfect at the beginning of the week, now the temperature has crept up again over 77 degrees and is slowing inching towards 80. This seems like a waste of \$\$\$ to have a building heate
FO-335109	12/17/2015	12/17/2015		Woodshop in Art building basement is cold. This is a 2nd request.
FO-335108	12/17/2015	12/17/2015		TOO COLD. 3RD FLOOR - 3 NORTH.
FO-335157	12/18/2015	12/18/2015		PLEASE LET INDUSTRIAL ELECTRIC INTO BSMNT MECH RM
FO-335224	12/21/2015	12/21/2015		basement is too hot. Please adjust temp.
<b>E - Northeast</b>			<b>6</b>	
FO-333956	12/1/2015	12/1/2015		Cold Call Room 2024
FO-334024	12/2/2015	12/2/2015		COLD AIR BLOWING FROM VENT. SUITE 1202 (INSIDE OF ROOM 1200)
FO-334497	12/9/2015	12/16/2015		Students are complaining about cold air blowing rather than heat blowing in classroom 421

WO	Recieved	Finished	Total	Request
FO-334852	12/14/2015	12/14/2015		TOO HOT. DESIGN SERVICES AREA. SEE SANDY AND ALSO THE LADIES RESTROOM NEAR VENDING MACHINES.
FO-335052	12/16/2015	12/16/2015		TOO COLD. 2ND FLOOR MULTI-PURPOSE ROOM.
FO-335136	12/18/2015	12/18/2015		TOO COLD. ROOMS 251, 252, 120, 132, 119, 123, 210, & 257.
<b>E - Preventative Maintenance</b>			<b>6</b>	
FO-334100	12/2/2015	12/2/2015		The heat on the 4th floor is a bit high - can it get turned down? Seems like a waste of \$\$\$ to heat the building to such a high degree.
FO-334248	12/4/2015			TOO COLD. ROOM 318.
FO-334251	12/4/2015			TOO COLD. 1ST FLOOR QUIET STUDY AREA.
FO-334339	12/7/2015			Room is very cold
FO-334553	12/9/2015	12/10/2015		TOO HOT. ROOM 216.
FO-335254	12/21/2015			TOO HOT. 3RD FLOOR. SEE BRANDON CARTER.
<b>E - South</b>			<b>3</b>	
FO-334408	12/8/2015	12/10/2015		Too hot. Lab has been @ 90 degrees the last couple of days.
FO-334838	12/14/2015	12/14/2015		Room is very hot. Temps have gone from 80 to 82 in the last hour....
FO-335180	12/18/2015	12/23/2015		TOO COLD. ROOM 443.
<b>E - Southeast</b>			<b>8</b>	
FO-334052	12/2/2015	12/3/2015		Room is too hot. Please forward to Ken Brandt
FO-334300	12/7/2015	12/7/2015		TOO COLD. 5TH FLOOR EAST WING.
FO-334394	12/8/2015	12/8/2015		TOO HOT. ROOM 14109.4.
FO-334500	12/9/2015	12/9/2015		TOO COLD. ROOM 13400.1.
FO-334593	12/10/2015	12/10/2015		TOO COLD. ROOM 119.
FO-334727	12/11/2015	12/11/2015		TOO HOT. PLEASE TURN HEAT OFF. BUILDING.
FO-334869	12/14/2015	12/15/2015		The heating system is making an intermittent and distrubing noise. I think it makes the sound when the system is on and then goes away when the system is off.
FO-335011	12/16/2015	12/16/2015		PLEASE OPEN 2ND FL ELEC RM
<b>E - West</b>			<b>4</b>	
FO-333777	12/1/2015			Controls Med. Priority R/R RM 00195/MECH RM replace bad aquamatic valve or new valve head per Eldon Feedwater. Valve failed open.
FO-334825	12/14/2015			TOO HOT.
FO-335027	12/16/2015			TOO COLD. 1ST FLOOR CONFERENCE ROOM.
FO-335053	12/16/2015			TOO HOT. ROOM 2225.
<b>Low</b>			<b>132</b>	
<b>E - Area 1 Engineer</b>			<b>2</b>	
FO-334851	12/14/2015			log book
FO-335226	12/21/2015	12/21/2015		The heater does not work in my office room (14200.10). Thanks for help!
<b>E - Auxiliary</b>			<b>50</b>	
H-56066	12/1/2015			Our heat doesn't seem to be working.authenticated user: Emma Freeman - ft0795requester ip address: 35.16.224.46
H-56072	12/1/2015			no power in the kitchen an dinning areaauthenticated user: Jayasurya Santhana Gopal - fs0182requester ip address: 141.217.233.189
H-56083	12/1/2015			The air conditioner is broken. No matter what temperature we set it to, it remains hot in the room.authenticated user: Brittany Felder - ep4394requester ip address: 141.217.225.111
H-56088	12/2/2015	12/2/2015	12/8/2015	Sink rotor not working authenticated user: Pushkar Vyas - fs0175 requester ip address: 35.16.65.18
H-56091	12/2/2015			Electrical socket near the bed damaged.authenticated user: Vikrant Mogal - fg8028requester ip address: 35.16.64.175
H-56099	12/2/2015			The air conditioner in my room has stopped working. The thermostat is set to 67 degrees, but the current room temperature is reading 73 degrees. Also, the unit is making a sloshing noise when it runs. The fan is still working properly.authenticated user:

WO	Recieved	Finished	Total	Request
H-56101	12/2/2015			Air conditioning is broken. Room temperature won't dip below 75 degrees.authenticated user: Kareem Elhage - cq7219requester ip address: 35.16.96.74
H-56122	12/2/2015			The AC in the living room is broken. Please see if you can fix it! No Air is coming out of it.authenticated user: Michelle Talukder - ev6408requester ip address: 141.217.232.237
H-56105	12/2/2015			2nd bathroom (at the end of hallway - the one with a bathtub) shower head not working - very low pressure flow. authenticated user: Bushra Joarder - fs8073requester ip address: 35.16.70.185
H-56115	12/3/2015			The bathroom light is not working. Also, the bedroom socket is not working. Maybe the problem of line not the light bulb. Thank you.authenticated user: - requester ip address: 141.217.232.244
H-56109	12/3/2015			Ballasts out on 6,7,8,9. Marked by blue tape.
H-56110	12/3/2015			Ballasts out in the laundry and exercise room.
H-56128	12/3/2015			mechanical checkauthenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.215
H-56180	12/4/2015			Leaking shower, authenticated user: Vashti Timmons - fw6071requester ip address: 66.87.114.242
H-56161	12/5/2015			Our A.C is not working. authenticated user: Romulo Feitosa De Almeida - fy5801requester ip address: 35.16.97.17
H-56169	12/5/2015			Heat doesn't work. authenticated user: Anh-David Nguyen - fj2479 requester ip address: 35.16.98.117
H-56184	12/6/2015			Leaking faucet and leaking shower head needs repairauthenticated user: Thomas Cotter - fy9889requester ip address: 35.16.54.79
H-56198	12/7/2015			the last room in the hallway (big bedroom) - cool air coming out of vent although on high heat setting. authenticated user: Bushra Joarder - fs8073requester ip address: 35.16.73.82
H-56190	12/7/2015			AGAIN, The central heater is not working well! the weather and water is not warm.This is the second time that this problem happens during last month authenticated user: Faezeh Babaieasl - fc1002requester ip address: 35.16.79.54
H-56191	12/7/2015			URGENT!Vents in the third room (corner room) is blowing out cold air again, even with the heat cranked all the way up. Room is considerably colder than the rest of the apartment . Can't sleepauthenticated user: Sanjana Shahreen - eu7659requester ip ad
H-56216	12/8/2015			Water leaks underneath the kitchen's sink have been noticed since the last two days. Please have it fixed at the earliest.Thanks in advance. authenticated user: Srinivas Bondada - fr9008requester ip address: 35.16.72.162
H-56221	12/8/2015			Water is leaking from the shower in the first bathroom. Unable to close it completely. authenticated user: Vinod Kumar Ravi - fs2080requester ip address: 136.2.1.109
FO-334410	12/8/2015			no heat in room 1, 2, 3
H-56223	12/8/2015			Need garbage disposal replaced.
H-56227	12/8/2015			Heat and air does not work in the room. authenticated user: Allahnah Turner - fo0430 requester ip address: 35.16.97.221
H-56250	12/9/2015			Kitchen sink water leakagebathroom -2 sink repairauthenticated user: - requester ip address: 141.217.174.209
H-56246	12/9/2015			Washroom at the end of the room. can't control water temperature from the bathtub- it's either too cold or too hot. Also temperature fluctuates without turning knob. authenticated user: - requester ip address: 141.217.221.39
H-56241	12/10/2015			One of the pipes underneath the sink is leaking. authenticated user: - requester ip address: 35.16.102.39
H-56244	12/10/2015			The heat is broken. Only cold air comes out. It is the same problem that the other lounge had although thankfully that was fixed quickly. authenticated user: Allison Macielog - fh2695 requester ip address: 35.16.97.19
H-56251	12/10/2015			Towers 1st floor men's restroom. Sensor on stalls causing water to overflow - sensors need to be adjusted.
H-56253	12/10/2015			Please address the leak in this apartment.
H-56276	12/11/2015			Our air conditioner is set at 68 and it is 77 degrees in our roomauthenticated user: Samantha Guerra - fv5692requester ip address: 35.16.102.137

WO	Recieved	Finished	Total	Request
H-56282	12/12/2015			There is a weird sound coming from the pipes on the sink side of the wall in my bathroom. It has been going on for a 3-4 days continuously. authenticated user: Asia Hightower - ev4173requester ip address: 35.16.72.197
H-56284	12/13/2015			toilet flush knob to fixauthenticated user: Aakash Dubey - fx8776requester ip address: 35.16.79.160
H-56298	12/13/2015			Hello, We are experiencing problems with our air conditioning system. It is not emitting cold air. We have tried putting it in heat and then trying to make it run but it is not running and therefore our resting room temperature is around 80°F. Please try
H-56299	12/13/2015			a/c heater filter change authenticated user: Mason Mackenzie - fw7277 room 411 ghafari requester ip address: 35.16.105.7
H-56274	12/14/2015			The air conditioning is not working. It will try to turn on and then fail. authenticated user: Zachary Kinning - fx1151requester ip address: 35.16.103.241
H-56307	12/14/2015			Air conditioning is not working properly. room 506 Ghafari authenticated user: Nicole Fry - eq0918 requester ip address: 141.217.23.177
H-56340	12/16/2015			Continuous crackling sound or sound of sparking coming from near the heating vent.authenticated user: Naman Chopra - fq7231requester ip address: 35.16.71.88
H-56341	12/16/2015			The fire alarm in room 1315 keeps going off and saying there is an abnormality  authenticated user: Ni'Esha Wright - fh3756requester ip address: 141.217.23.173
H-56348	12/17/2015			Our heater is broken, it won't go past a certain temperature. It's been very cold and now that it is getting colder outside its been freezing. authenticated user: Jessica Rabban - fx2476requester ip address: 35.16.98.219
H-56346	12/17/2015			The air conditioning / heating unit will not stop blowing airauthenticated user: Michael Sowles - fv3664requester ip address: 35.16.102.188
H-56388	12/19/2015			ENGINEERING: Please repair plumbing underneath bathroom sink. (Work completed by P. Gipson on 12/18/15 and 12/19/15)authenticated user: Prentis Gipson - bq7019requester ip address: 141.217.23.219
H-56389	12/19/2015			The knob to flush the toilet is broken. It needs to be replaced.authenticated user: Amyra Woods - eh3128requester ip address: 35.16.7.152
H-56367	12/20/2015			The heating in the room does not work. authenticated user: Anna Bagnall - fo1173 requester ip address: 35.16.102.188
H-56368	12/20/2015			The heating doesn't work authenticated user: Anna Bagnall - fo1173 requester ip address: 35.16.102.188
H-56384	12/22/2015			The three compartment sink in back room of Starbucks has leaking pipes, needs to be fixed ASAP authenticated user: Cailey Stiteler - fh0205 requester ip address: 141.217.23.177
H-56403	12/22/2015			Urgent: The fire alarm notification for room #1315 won't clear from the fire panel and is causing fire alarm to sound off throughout the day. Please clear fire alarm notice for #1315.authenticated user: Isabell Groves - fb2096requester ip address: 141.2
H-56424	12/24/2015			I need the wall outlet in the bathroom repaired/looked at. I think when I blow dried my hair, I ended up messing up the outlet. My room number is 440.authenticated user: Raeyonn Starghill - fx0290requester ip address: 35.16.106.14
H-56438	12/28/2015			A/C is not working inside of the Asian Mart. Need it fixed ASAP pleaseauthenticated user: Chevonne Abrams - eh3331requester ip address: 141.217.23.178
<b>E - Command Center</b>			<b>23</b>	
FO-334124	12/3/2015			A/C Controls, R/R RM 103 please troubleshoot VAV LA.0.AH4.2.17 inside lab 103. Room temp is way under set point but the cold duct damper is open 100% (Temporarily set cold duct damper at 0%)
FO-334125	12/3/2015			A/C Controls, R/R RM 103 please troubleshoot VAV LA.0.AH4.2.11 inside lab 103. Room temp is way under set point but the cold duct damper is open 100% (Temporarily set cold duct damper at 0%)
FO-334126	12/3/2015			A/C Controls,R/R RM 103 please troubleshoot VAV LA.0.AH4.2.16 inside lab 103. Room temp is way under set point but the cold duct damper is open 100%



WO	Recieved	Finished	Total	Request
FO-334127	12/3/2015			A/C Controls, R/R RM 103 please troubleshoot VAV LA.0.AH4.2.18 inside lab 103. Room temp is way under set point but the cold duct damper is open 100%
FO-334128	12/3/2015	12/8/2015		BAS- R/R RM 138 investigate and resolve issues with reheats and radiant heat for conference room 3.
FO-334130	12/3/2015			Investigate & restore smoke evacuation system.
FO-334165	12/3/2015			Retrofit Unit so it only runs on call for heat, limiting run time, avoiding wear on expensive parts, while saving money
FO-334209	12/4/2015			Please remove refrigerant from old window air conditioner located outside FP&M Stockroom. Unit to be disposed of.
FO-334457	12/8/2015			pls repair the DA high water dump valve control loop as nesc.
FO-334521	12/9/2015			AC shop: R/R RM 103 please repair broken copper control air lines behind the room stat. Attention Gordy & Andy. Priority: med.
FO-334541	12/9/2015	12/9/2015		COMMAND CTR, R/R RM 00347.10 PLEASE CHANGE DAY SETPT ON FFC UNITS TO OAT- 40 DEGS AND LESS @ 75DEGS ROOM STPT AND 72DEGS ROOM STPT @ OAT- 44 DEGS AND HIGHER. PRIORITY-LOW
FO-334573	12/10/2015	12/10/2015		COMMAND CTR , 10 TEC'S IN THE E-WING IN NIGHT DEFAULT MODE, PLEASE CORRECT. PRIORITY-LOW
FO-334632	12/10/2015	12/10/2015		To refrigeration shop. R/R 00004.10 Please correct problem with humidifier ramp up program for insight system on SF-1. Humidifier valve hunts on start up.
FO-334636	12/10/2015			Controls --Priority High R/R RM 119 Heat Pump for Rm 119 too hot and kicks out. No heat to office In TMA Sys the HPs' listed from HP-001 thru HP-012 are all listed as 1st flr
FO-332104	12/12/2015	12/12/2015		Request to have BAS staff on site for damper replacement at Chemistry for Fume Hood Exhaust.
FO-334859	12/14/2015			CONTROLS (ANDY MCALPINE PLEASE)-R/R RM 000124 Please check sensor or program for HEX at Mort Sci room 124. 59 degree day HEX temps are 180/190 and HEX 1/3 valve is open w/ only 7 psi from control sent.
FO-334961	12/15/2015	12/24/2015		Honeywell Pneumatic Actuator MP918B 10061 8601 Spring Range: 8-13 PSI Qty: 2 \$282.63/ea
FO-335029	12/16/2015			BAS Section: Please replace ahu 4 high humidity limit: controller locking out pneumatic signal to valve.
FO-335088	12/17/2015	12/22/2015		Trade: Controls/Siemens Priority: Low On the EDC home page there are two buttons labeled Exhaust Fans, the graphic F090.EF can be removed because there are no points that are monitored for these fans. This will help in making the home page less confusing
FO-335212	12/21/2015			Controls inspect program for exhaust fan 4B. It won't ramp up in lead, and won't shut off in lag.
FO-335638	12/22/2015			CONTROLS- R/R RM 490.03 please r/r actuator or t stat for reheat in back hall study area on the 4th floor of Mort Sci. The actuator is stuck in the closed position. I was able to back off and open the valve some for flow to the area. There is no response
FO-335688	12/23/2015			B.A.S. crew: please replace damaged room thermostat, also for room 413. priority: low.
FO-335731	12/24/2015			BAS Section: R/R BSMT please change field panel IP to reflect WSU network changes: IP: 192.168.58.67 NM: 255.255.254.0 GW: 192.168.58.1
<b>E - MedPharm</b>			<b>14</b>	
FO-333750	12/1/2015	12/1/2015		lab is too hot, Investigator needs it to be much cooler in the room.
FO-333751	12/1/2015	12/1/2015		check to see if ventilation is working
FO-334074	12/2/2015			RM 418 HAS A FOUL ODOR LIKE SEWAGE

WO	Recieved	Finished	Total	Request
FO-334076	12/2/2015			SVC MAN FOR DHW TREATMENT (586-943-1162)
FO-334240	12/4/2015	12/12/2015		RM 3321 AVI NEEDS ACCESS TO ELEC CLOSET
FO-334241	12/4/2015	12/12/2015		RM 2136 IS TOO HOT
FO-334242	12/4/2015	12/11/2015		2ND FLR MD LABS NEAT RM 2136 IS TOO HOT
FO-334486	12/9/2015	12/9/2015		DLAR Area. Ceiling filters need to be changed
FO-334532	12/9/2015			Elevator B (closest to Mack) has not moved all morning; there is a good possibility that it is out of order and needs repair.
FO-334646	12/10/2015	12/11/2015		There will be a teaching lab this weekend from 8-5 on Sat (12/12) and 8:30-5 on Sun (12/13) in this room. It was very hot last weekend in this room. Please check the temperature BEFORE the lab each day and make necessary adjustments if needed.
FO-334695	12/11/2015			change ceiling filter
FO-335139	12/18/2015			NEED ACCESS PH FOR WTR TKS 248-798-9376
FO-335141	12/18/2015	12/18/2015		NEED ACCESS PH FOR WTR TKS 248-798-9376
FO-335601	12/22/2015			Rm. 4615 has no working lights in the office. Please repair.
<b>E - North</b>			<b>8</b>	
FO-333752	12/1/2015	12/1/2015		BSMNT FURNACE IS LEAKING CARPET IS WET
FO-333765	12/1/2015	12/1/2015		BLOWING HOT AIR AGAIN.
FO-334022	12/2/2015	12/2/2015		CORRIGAN SVC MAINTENANCE REP IS HERE & NEEDS ACCESS TO ROOF (@ roof ent)
FO-334295	12/7/2015	12/8/2015		It's very cold in this suite, more so in the offices. We would appreciate it if the temperature could be adjusted.  Thank you.
FO-334549	12/9/2015	12/9/2015		The heat on the 4th floor in FAB is a bit too high and it's uncomfortable - reaching almost 77 degrees. Seems like it's a waste of \$\$\$ to heat a building to this degree.
FO-334729	12/11/2015	12/11/2015		Window in 4037 FAB will not close. See main office for entry if not available.
FO-335557	12/22/2015	12/22/2015		log books
FO-335599	12/22/2015	12/23/2015		need 3 belts Gates 5VX 1800
<b>E - Northeast</b>			<b>10</b>	
FO-334077	12/2/2015	12/8/2015		Please cover AC unit in room 302. Unit is very drafty in the winter and the office gets cold.
FO-334334	12/7/2015			Please provide exhaust ventilation for the third and fourth floor bathrooms. This has been a problem for some time, and continues to be an issue. Not only does the ventilation not remove odors, but the "aroma" wafts into the hallways.
FO-334587	12/10/2015			Cold call 2024  Can the set point be raised to 71 degrees
FO-334605	12/10/2015	12/10/2015		The employees of the building are complaining about excessive heat. The temperature in the first floor office suite (134) is in the 80's.
FO-334699	12/11/2015			Replace the thermostats/room sensors for ALL SpacePac HVAC units. priority medium
FO-334708	12/11/2015			Henry Ford Data Analysis room and X-Ray room are having a brown out and power has been failing. Rooms 1034 & 1220
FO-334731	12/11/2015			2nd Floor Women's restroom in the first stall the toilet is not flushing properly.
FO-334943	12/15/2015			Cold call 1320
FO-335018	12/16/2015	12/16/2015		4th floor study hallway is very cold. It's located between the room 421 and 422. Please warm this space so that our students can study there. Thanks.
FO-335171	12/18/2015	12/18/2015		Supply garden hose and nozzle for cleaning basement of Tierney Carriage House.
<b>E - Preventative Maintenance</b>			<b>11</b>	
FO-333999	12/1/2015	12/2/2015		Thermostat does not appear to be working. Office and surrounding area remains cold even when thermostat is turned up.

WO	Recieved	Finished	Total	Request
FO-334185	12/3/2015	12/4/2015		RM 4126 IS TOO COLD
FO-334225	12/4/2015	12/9/2015		Belt Order for Day Shift  B-120 Qty: 2
FO-334461	12/8/2015	12/8/2015		room has low humidity
FO-334480	12/9/2015			Scott Hall 3rd Flr FCU Filters  3 DIFFERENT SIZE FILTERS FOR THE 3RD FLOOR FAN COIL UNITS  8-7/8 X 42-1/8 X 1 Qty: 18 8-7/8 X 33-5/8 X 1 Qty: 36 8-7/8 X 61-1/8 X 1 Qty: 15
FO-334784	12/11/2015	12/12/2015		RM 4360 PLS CLOSE ROOF DOOR
FO-335049	12/16/2015			Belt Order:  B79 Qty: 1
FO-335072	12/16/2015			The cooling tower on the roof pump shut down. Kamal was working in lab 1551 in EDC shut down. No cold water is coming through the engine. Contact Kamal at 313-424-2562. Thank you.
FO-335079	12/16/2015			BSMT NEED ACCESS TO ELEC CLOSET FOR REPAIR OF BODY COOLERS
FO-335169	12/18/2015	12/19/2015		Replace belts. B-75 Qty: 1
FO-335255	12/21/2015			RM 169 IS TOO COLD
<b>E - South</b>			<b>7</b>	
FO-334043	12/2/2015	12/22/2015		Laser room is very hot.
FO-334073	12/2/2015	12/3/2015		Cold air is blowing from the air vent located over desk. Can it be turned off?***ROOM 1106***
FO-334135	12/3/2015	12/4/2015		Please stop by room 2162, Dr. Wu's office, as he has expressed that his ceiling fan is making loud noises and would like for someone to look into this issue.
FO-334864	12/14/2015	12/14/2015		Lab is very hot
FO-335208	12/21/2015	12/21/2015		PUBLIC SAFETY RECEIVED A GENERATOR REFILL MESSAGE.
FO-335249	12/21/2015			Main men's room in Academic Advising, Suite 1600: toilet seat is off toilet. See Advisor Tyrone Austin if any questions.
FO-335553	12/22/2015	12/22/2015		Large amount of dust and debris come out of air vents. Need filter installed to keep dust from ruining equipment and experiments that are being run.
<b>E - Southeast</b>			<b>5</b>	
FO-334313	12/7/2015	12/10/2015		The heat in the undergraduate costume shop does not work.
FO-334631	12/10/2015			Controls, R/R 2ND FLR install access to exhaust dampers for animal rooms. Talk to engineer for specifics.
FO-334682	12/10/2015	12/11/2015		Loud clicking noise coming from ceiling in faculty office. Please forward to Ken Brandt
FO-335013	12/16/2015	12/16/2015		LEE FROM ALLIED BLDG SVCS' WOULD LIKE TO USE A LADDER FROM ELEC CL 550-7927
FO-335719	12/24/2015			WOULD LIKE TO SCHEDULE FOR ***MONDAY 12/28/15** ACCESS TO ROOF CALL 556-7175 (Mike) TO CHNG BILLBOARD ON ROOF
<b>E - West</b>			<b>2</b>	
FO-334539	12/9/2015	12/9/2015		Water filter needs replacing.
FO-335008	12/16/2015			RM 100/AUD @ ENTRANCE T-STAT IS HISSING LOUDLY DISTURBING CLASS TESTING
<b>Routine</b>			<b>1</b>	
<b>E - Preventative Maintenance</b>			<b>1</b>	
FO-333992	12/1/2015	12/8/2015		AHU-2 B-61 Qty: 4
<b>Grounds</b>			<b>1</b>	
<b>Low</b>			<b>1</b>	

WO	Recieved	Finished	Total	Request
<b>G - Physical Grounds</b>			<b>1</b>	
FO-335033	12/16/2015			Stock Issue Request: 3 cans of spray paint 5 rake handles
<b>Trades</b>			<b>650</b>	
<b>Emergency</b>			<b>44</b>	
<b>T - Carpenter</b>			<b>11</b>	
FO-333989	12/1/2015	12/2/2015		**ADDING CARPENTER: Please provide access in a couple walls to identify where leak is coming from. Walls are non-asbestos **SEE TROY or DON FOR LOCATIONS
				R/R RM 110 There are two large leaks in the ceiling. The ceiling tiles have fallen and in on
FO-334150	12/3/2015	12/3/2015		SOUTH SIDE SLIDING DOOR IS OFF TRACK, DOOR WON'T SLIDE.
FO-334152	12/3/2015	12/3/2015		BROKEN ENTRANCE DOOR #080-02S
FO-334179	12/3/2015	12/3/2015		STAIRWELL 2J BROKEN DOOR HANDLE, UNABLE TO GET IN AND OUT THE HANDLE IS WITHIN RM 1102
FO-334216	12/4/2015	12/4/2015		NORTH END EXTERIOR DOOR EARLY CHILDHOOD CTR, RELEASE LATCH NOT CATCHING LEAVING THE BLDG UNSECURED
FO-334220	12/4/2015	12/4/2015		DOOR # 155-09E OUTSIDE BROKEN DOOR HANDLE, THE HANDLE IS WITH TERRI IN RM 487
FO-334501	12/9/2015	12/9/2015		EMERGENCY CARP R/R RM 00225 INSIDE DOOR KNOB HAS FALLEN OFF UNABLE TO CLOSE (note: knob is in rm)
FO-334861	12/14/2015	12/14/2015		KEY WON'T TURN IN DOOR LOCK. ROOM 48.
FO-334865	12/14/2015	12/14/2015		KEY STICKS IN DOOR LOCK. ROOM 153.1.
FO-334950	12/15/2015	12/15/2015		FRONT DOOR 080-02S HANDICAP DOOR NOT WORKING, DOOR CLOSURE ISSUE
FO-335219	12/21/2015	12/21/2015		A key has broken off inside the lock going to the interior room. The lock can currently be turned without needing a key.
<b>T - Electrician</b>			<b>18</b>	
FO-333735	12/1/2015	12/1/2015		EMERGENCY ELEC R/R 1ST FLR HALLWAY SOUTHWEST FAP (PANEL DISPLAY) FIRE ALARM TAMPERED SWITCH BSMT RISER RM
FO-334034	12/2/2015	12/2/2015		BACK AREA NEAR FREIGHT ELEV AND RM 3539, ALL LIGHTS ARE OUT POSSIBLE BAD BREAKER
FO-334063	12/2/2015	12/2/2015		no power to building generators not working
FO-334257	12/5/2015	12/4/2015		Restore electrical power to circuits at Manoojian serving domestic water booster pumps and other equipment.
FO-334294	12/7/2015	12/9/2015		**ADDING ELECTRICIAN: Please check operations and power to booster pumps. See Don Bear (PLUMBER)684-0856
				Domestic Water Booster pumps failed this weekend. Please repair. We need these pumps for getting water in the boilers. ...., DB/12-
FO-334432	12/8/2015	12/8/2015		WIRES HANGING. ROOM 1600.
FO-334496	12/9/2015	12/11/2015		1 EP - Hall way, 1st floor - Light broken off in the fixture.
FO-334504	12/9/2015	12/10/2015		**ADDING ELECTRICIAN: Please disconnect condensate pump #2 in Lethal room and reconnect by end of the day. See Ron Clark
				Trade: PipeFitters Priority: High/Med Please replace the leaking seal on #2 condensate return pump in the Lethal room mechanical
FO-334519	12/9/2015	12/9/2015		EMERGENCY ELEC R/R RM 00051/MECH RM DOMESTIC HOLD TANK AIR COMPRESSOR NOT STARTING ENTIRE BLDG ESPECIALLY 4TH FLR LOW WTR PRESSURE SINKS, TOILETS, URINALS (KITCHEN 4TH FLR)

WO	Recieved	Finished	Total	Request
FO-334527	12/9/2015	12/9/2015		EMERGENCY ELEC R/R RM 00051/MECH RM DOMESTIC HOLD TANK AIR COMPRESSOR NOT STARTING ENTIRE BLDG ESPECIALLY 4TH FLR LOW WTR PRESSURE SINKS, TOILETS, URINALS (KITCHEN 4TH FLR)
FO-334552	12/9/2015	12/11/2015		walk through Matthaai fix all lights, exits, ebu's in gym, lockerrooms, hallways and bathrooms. for our children and their parents
FO-334694	12/11/2015	12/11/2015		LIFE GUARD TEMPERATURE CONTROL ALARM IS GOING OFF. MECHANICAL ROOM 1530.
FO-334771	12/11/2015	12/11/2015		generator running
FO-334819	12/12/2015	12/11/2015		electricians to answer fire alarm panel wont reset
FO-334827	12/14/2015	12/16/2015		PLEASE CHECK FAN #4, WON'T RUN. CONTACT ENGINEER.
FO-335716	12/24/2015			FIRE ALARM SYSTEM #2 HAS COM. LOSS.
FO-335736	12/28/2015			Check Lande AHU-1 freeze stat preventing fan operation.
FO-335757	12/29/2015			Power Outage, multiple buildings without power. Called in Electricians after calling Dave Kuffner.
<b>T - Pipefitter</b>			<b>3</b>	
FO-333989	12/1/2015	12/2/2015		**ADDING CARPENTER: Please provide access in a couple walls to identify where leak is coming from. Walls are non-asbestos **SEE TROY or DON FOR LOCATIONS
				R/R RM 110 There are two large leaks in the ceiling. The ceiling tiles have fallen and in on
FO-334122	12/3/2015	12/7/2015		RM 325 ACTIVE CEILING LEAK ,,,,,,,,,, ME/12/3/15 ,,,,,,,,,,
FO-334229	12/4/2015	12/7/2015		LAB 3329 STEAM CONDENSATE LEAK IN PIPE CHASE. ,,,,,,,,,, EA/12-4-15 ,,,,,,,,,,
<b>T - Plumber</b>			<b>12</b>	
FO-333769	12/1/2015	12/1/2015		EMERGENCY PLUM R/R RM 00032/MENS RR THERE'S A BLACK SUBSTANCE BACKING UP IN SINK DRAINS ,,,,,,,,, DB/12-1-15 ,,,,,,,,,,
FO-334002	12/1/2015	12/1/2015		R/R RM 312 SINK IS LKNG FROM UNDERNEATH (NOTE: LEFT MESSAGE TO ENG TO TURN WATER OFF) ,,,,,,,,,, GS/12-1-15 ,,,,,,,,,,
FO-334151	12/3/2015	12/3/2015		SHIPPING DOCK IS FLOODED. ,,,,,,,,,, MM/12-3-15 ,,,,,,,,,,
FO-334285	12/7/2015	12/9/2015		Domestic Water Booster pumps failed this weekend. Please repair. We need these pumps for getting water in the boilers. ,,,,,,,,,, DB/12-7-15 ,,,,,,,,,,
FO-334421	12/8/2015	12/8/2015		Purdy Library, 2nd Floor Handicap Restroom Toilet is plugged and overflowing. Please repair. Thank you. ,,,,,,,,,, GS/12-8-15 ,,,,,,,,,,
FO-334429	12/8/2015	12/8/2015		**DUPLICATE/ REFER TO FO#334421 JWT  2ND FL UNISEX RESTROOM, TOILET PLUGGED AND OVERFLOWING
FO-334506	12/9/2015	12/9/2015		NO WATER THROUGHOUT BUILDING.
FO-334547	12/9/2015	12/9/2015		EMERGENCY PLUM R/R RM 3328/MENS RR ONLY SINK IS PLUGGED & OVERFLOWED ,,,,,,,,,, GS/12-9-15 ,,,,,,,,,
FO-334583	12/10/2015	12/11/2015		FLUSH DRAIN RUNNING CONTINUOUSLY. LARGE ANIMAL ROOM. ROOM 0247. ,,,,,,,,, MM/12-10-15 ,,,,,,,,,,
FO-334843	12/14/2015	12/14/2015		MENS RM NEAR VENDING MACHINES, 1ST STALL TOILET IS GURGLING ,,,,,,,,,, TT/12-14-15 ,,,,,,,,,,
FO-335542	12/22/2015	12/22/2015		EMERGENCY PLUM R/R RM 9228 REPAIR DRAIN FUNNEL ON REAR AUTOCLAVE (wtr has been slowed down however its still leaking) ,,,,,,,,,, DB/12-22-15 ,,,,,,,,,,
FO-335546	12/22/2015	12/22/2015		MECH RM 100 REPLACE 3/4 in NIPPLE THAT CRACKED ,,,,,,,,,, DB/12-22-15 ,,,,,,,,,,
<b>High</b>			<b>166</b>	
<b>T - Carpenter</b>			<b>43</b>	
FO-333766	12/1/2015	12/2/2015		Carpenters (High) R/R RM 00139/MECHANICAL ROOM. AHU#1 BOTH SUPPLY AIR ACCESS DOORS ARE BROKEN CAUSING HEATING ISSUES. REPAIR/REPLACE
FO-333945	12/1/2015	12/2/2015		The Pocket Door to Conference Room 3517.01 is out of adjustment and will not lock.

WO	Recieved	Finished	Total	Request
FO-334012	12/2/2015	12/3/2015		Trade: Carpenter Priority: High Handicap door closer malfunction. Door no. 080E
FO-334031	12/2/2015			Purdy Library, 1st Floor Ceiling tile coming loose from ceiling outside of Room 133. **Safety Concern** Please repair.  Thank you.
FO-334045	12/2/2015	12/2/2015		R/R 1ST FLR STRWL A OUTSIDE DOOR HANDLE LEADING INTO STRWL IS VERY HARD TO MANUEVER
FO-334088	12/2/2015	12/3/2015		R/R RM 00256 KEYS ARE STICKING IN LOCK MECHANISM
FO-334094	12/2/2015	12/3/2015		The exterior doors on the Cass Entrance side of the building do not close properly after hours. If someone walks out of the locked building the doors do not latch back in the locked position.
FO-334169	12/3/2015			**ADDING CARPENTER: Please remove wood blocking previoslly made access hole in overhang to identify pipe leak. See Eric or Corey for location  Trade: Pipefitter Priority: High Please repair leak in the west overhang at Life Science. ,,,,,,,,,,,,,,,,,,
FO-334191	12/4/2015	12/7/2015		CARPENTRY- please create access hole so controls for heating can be accessed. need hole in most north west corner of ladies lav 1st floor by door. access need to be able to go through to hall ductwork where control is located for work. High Priority. Hon
FO-334243	12/4/2015			Many loose tiles by eastern door. Some of the loose tiles have been removed and are by the door near a shelf. There are still many loose tiles remaining on the floor. This is a trip hazard as someone almost tripped and fell. Please re-glue. Thank you.
FO-334244	12/4/2015	12/9/2015		More loose tiles outside north end of Room 317, near "ante room" 326. Please re-glue. Thank you.
FO-334250	12/4/2015	12/7/2015		RM 136 LOCK ON DOOR NOT TURNING PROPERLY, LOCK HAS BROKEN KEYS TRYING TO TURN
FO-334272	12/4/2015	12/7/2015		Door 062 08S THE OUTSIDE door handle has broken off entry is impossible .The handle is in the engineer office at Carol Dargin desk, this is for the Carpentry Department for repairs.
FO-334306	12/7/2015	12/8/2015		KEY WON'T PROPERLY TURN IN DOOR LOCK. ROOM 2119.
FO-334414	12/8/2015	12/8/2015		DOOR# 001-01E DOOR NOT UNLOCKING, BINDING
FO-334511	12/9/2015	12/9/2015		R/R 2ND FLR CTR STWL OUTSIDE DOOR HANDLE HAS FALLEN OFF (Handle is propping door open)
FO-334520	12/9/2015	12/10/2015		Locksmith: DA tank electrical cabinet door lock will not move with the proper key and I cannot close and secure cabinet door. Please repair. High Priority. See engineer for location and access.
FO-334534	12/9/2015	12/10/2015		The back exit door to the Dean's suite, by Rm. 2612, keys are sticking in the core or not turning at all. Please repair.
FO-334560	12/9/2015	12/10/2015		DOOR 008-03-SOUTH - REPAIR/REPLACE BROKEN DOOR CLOSER.
FO-334571	12/10/2015	12/10/2015		Carpenters  Repair door closer exterior main entrance door 003-south, screws missing.  High priority
FO-334579	12/10/2015	12/10/2015		carpenters: please repair handicap door push button on vestibule door next to door # 016-01-E, Priority: high.
FO-334645	12/10/2015	12/11/2015		CARPENTRY DEPT-NORTH ENTRANCE DOOR 156 03 S NOT CLOSING PROPERLY CAUSING SECURITY PROBLEMS,PRIORITY HIGH
FO-334660	12/10/2015	12/22/2015		Provide access in ceiling within lecture hall room 234 in ceiling above drop ceiling for plumbing repair access. See Gerry for detail Needed ASAP  **NON ASBESTOS SEE JOHN TOWLE IF NEEDED
FO-334671	12/10/2015			2ND FL WEST. END, LOUNGE AREA SHADE DOWN
FO-334700	12/11/2015	12/14/2015		DOOR WON'T UNLOCK WITH KEY. DOOR NEAREST TO DUMPSTER.
FO-334740	12/11/2015	12/22/2015		R/R ENTRANCE DOOR #189 09E DOOR LOCK IS JAMMING & NOT LOCKING COMPLETELY CAN PULL DOOR OPEN AFTER LOCKING FROM OUTSIDE

WO	Recieved	Finished	Total	Request
FO-334741	12/11/2015	12/22/2015		R/R ENTRANCE DOOR #189 10E DOOR LOCK IS JAMMING & NOT LOCKING COMPLETELY CAN PULL DOOR OPEN AFTER LOCKING FROM OUTSIDE
FO-334948	12/15/2015	12/16/2015		Repair lock on door in basement storage area. Difficult to open with key. Index to charge is 227960
FO-334978	12/15/2015			Several "asbestos" floor tiles on the first floor are cracked and loose or missing in several spots on the whole first floor. I have a complaint that people have slipped on the loose tiles.
FO-335004	12/16/2015	12/16/2015		DOOR NOT CLOSING. DOOR NEXT TO ROOM 0507.
FO-335016	12/16/2015			Evaluate material needed to remodel taking out floor mounted urinals and replacing with wall hung in men's room 332. See Gerry (PLUMBER) for info if needed
FO-335132	12/17/2015	12/21/2015		Lock on door is inoperative
FO-335241	12/21/2015	12/22/2015		RM 312 DOOR LOCK IS JAMMED
FO-335242	12/21/2015	12/22/2015		3RD FL CENTER STAIRWELL DOOR HINGES AT TOP ARE OUT
FO-335243	12/21/2015	12/23/2015		DOCK DOOR STUCK OPEN
FO-335460	12/22/2015	12/22/2015		DOOR LATCH IS LOOSE. 1ST FLOOR ANNEX BASKETBALL OFFICE.
FO-335464	12/22/2015	12/23/2015		Kresge door #027 06 W  Closer is not latching properly to secure closure of the door.
FO-335685	12/22/2015	12/23/2015		On outside of the walkway on the south side of Scott Hall there is a piece of trim that needs to be screwed down. It is sticking out at a 90 degree angle and is a trip hazard for people walking by. See Sheryl in 1102 Scott Hall for exact locatio
FO-335686	12/23/2015			Carpenters: Please repair or replace door closer on entrance door # 016-06-S, Hydraulic fluid has leaked out and it is not working properly. Priority: high.
FO-335706	12/23/2015	12/24/2015		R/R LOBBY The latch on the inner door is broken. The door cannot be opened from the outside. DOOR NEEDS REPAIRING BEFORE CLOSURE BLDG WILL BE OPEN
FO-335727	12/24/2015	12/28/2015		Lock on entry/exit door at back of the building, door number 064-03W, is sticking and difficult to open. Employees often have to jiggle keys to open the lock.
FO-335762	12/29/2015	12/30/2015		In room 3502.00 Staff Office the wall need to be opened up at the outlet on the wall facing the door, it shows signs of heat, and the Electricians has to pull new wire in to repair it. Please open wall for Electricians, and close it back when job is done
FO-335763	12/29/2015			In room 1535 there's a light out, and the Electricians need scaffold built to repair it, and removed when job is complete.
<b>T - Electrician</b>			<b>39</b>	
FO-333737	12/1/2015	12/18/2015		**ADDING ELECTRICIAN: Disconnect condensate #2 in room 00124. See Ron Clark  PIEFITTERS R/R RM 00124/MECH RM PLEASE condensate pump #2 at Mort Sci room 124. Pumps is not moving water. It will run, no leaks, no bearing problems...just doesn't pump an
FO-334032	12/2/2015			fix light outside of north entrance off presidents parking lot high hat in canopy area
FO-334159	12/3/2015			1520- The Ford Activity Center  Lights are not functioning properly. They will not turn on.
FO-334217	12/4/2015	12/4/2015		Round overhead light fixture near entrance to women's restroom is partially hanging down and could fall and injure someone. Room #1134.
FO-334227	12/4/2015	12/4/2015		Room 456 - EP - 4 LO ...TAGGED ELECTRICAL NEEDS TO BE FIXED ASAP
FO-334247	12/4/2015	12/7/2015		Room 268 - 2nd work order - lights are out. Customer called Custodial with what was originally a normal lights out request, that has been determined to be an electrical problem. Thank you.
FO-334260	12/5/2015	12/9/2015		**ADDING ELECTRICIAN: Please check power to hot water heater in STE 2800. Disconnect if heater still does not work. See Don Bear  STE 2800 WOMENS RM NO HOT WATER ,,,,,,,,,,,,,, DB/12-4-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-334327	12/7/2015	12/10/2015		ELECTRICIANS (MED HIGH)  FANS IN HEATERS FOR STAIR CASES B & F WILL NOT COME ON. HEATING VALVES ARE OPENING AND STATS ARE MAKING CONTACT. PLEASE CHECK FAN MOTORS
FO-334502	12/9/2015	12/9/2015		**ADDING ELECTRICIAN : Please verify voltage and phase of motor on pump CRS-001 in boiler room. **REPORT FINDINGS TO JOHN TOWLE *See Ron Clark if needed  Pipe Fitter; Medium Please repair the seals on the two condensate return pumps, 071-CRS-001
FO-334510	12/9/2015	12/9/2015		R/R 3RD FLR N.W. HALLWAY LITE SENSOR ISN'T TURNING LITES ON
FO-334540	12/9/2015	12/11/2015		LIGHTS ARE NOT COMING ON IN THE EVENING. OUTSIDE OF BUILDING ON THE SOUTH SIDE.
FO-334572	12/10/2015	12/10/2015		#3 Rooftop Unit will not start. Being held out by Gamewell rce-95 device, yet no trouble on panel. Stat and device are on 1st floor in seamstress shop.
FO-334578	12/10/2015	12/10/2015		EXIT SIGN IS HANGING. GYM 109. SEE BOB OSTROWSKI FOR LOCATION.
FO-334597	12/10/2015	12/11/2015		LADIES RM 3341 TAGGED LIGHT.
FO-334598	12/10/2015	12/14/2015		3RD FL HALLWAY OUTSIDE ELEV # 3 TAGGED LIGHT.
FO-334680	12/11/2015	12/14/2015		need light fixed suite 206 patient corridor by exam rm. 12
FO-334681	12/11/2015	12/11/2015		12-11-2015 at 1:00 pm training on fire alarm panel meet at fire alarm panel
FO-334735	12/11/2015			REPAIR LIGHT SENSORS. LIGHTS ARE GOING OFF EVERY 3 MINUTES. ROOM 1524. (MULTI-TASK)
FO-334774	12/11/2015			Room 270.1 - 4 LO there are 2 EP's in back of this lab...area is very dim.
FO-334855	12/14/2015	12/16/2015		RM 91 NEAR THE STAGE, LIGHT COVER IS OFF. PLEASE SEE TERRI IN RM 487 FOR THE COVER
FO-334898	12/14/2015	12/16/2015		R/R RM 1550 WALL CLOCK ISN'T WRKNG
FO-334922	12/15/2015	12/15/2015		ELECTRICIANS: PLEASE CHECK FIRE ALARM PANEL, TROUBLE ALARM GROUND FAULT, PRIORITY HIGH
FO-335023	12/16/2015			In room 109 they want an extra outlet added. See Sausha Kellogg 7-4224.
FO-335048	12/16/2015			MALL LIGHTS ARE OUT IN FRONT OF THE STUDENT CENTER BUILDING AND SURROUNDING AREAS LEADING TO ANTHONY WAYNE DRIVE.
FO-335069	12/16/2015	12/21/2015		Repair LED dusk to dawn light fixture over Exit door on Antoinette street. It does not come on at night.
FO-335096	12/17/2015	12/18/2015		Laborer (High Priority) R/R RM 0100/MECH DELIVER TO SCOTT HALL ROOM 100/MECH RM 1) NITROKLENZ 17010050 (25 PAILS) 2) WATER SOFTNER SALLT PELLETS 17010010 (1 PALLET FULL)
FO-335111	12/17/2015			Purdy Library 4th Floor, Stacks & Open Study Areas across from Room 446  Several rows of lights are off. All switches and breakers are on. Please turn on lights or repair. If needed, the key for the light panels is available at the Purdy Check Out d
FO-335155	12/18/2015	12/18/2015		Generator #14 (south) will not start, and Electricians found squirrels has built a nest, and destroyed the wiring to the controls.
FO-335186	12/18/2015			Light out in hallway outside room 1329. Tagged electrical since 2-9-15.
FO-335236	12/21/2015	12/22/2015		REPLACE FAULTY SMOKE DETECTOR ON RTU #1. (FIRE ALARM). (MULTI-TASK)
FO-335244	12/21/2015			trade electricians priority high R/R RM 00154/MECH RM please service boiler feed pump #1 this pump was just hooked up this morning went back to check status not working pump feels hot my have burn out
FO-335637	12/22/2015			ELECTRICIANS: R/R RM 4615 Please repair light switch in room 4615. No lights in room. High
FO-335717	12/24/2015			Electricians: R/R RM 1500 Please investigate missing EEPROM alarm on fire panel. Priority: High PLS NOTE: Eng did not specify which FAP. Also, another WO was entered refer to WO FO-335716
FO-335735	12/28/2015			Get Mobil Gas card from Dave Kuffner, fill fuel cans with Diesel Fuel, and fill fuel tank for Generator at 5435 Woodward.



WO	Recieved	Finished	Total	Request
FO-335741	12/28/2015			Fire Alarm was activated 12/24/2015, and Electricians checked system, but was called to UGL for Emergency. Electricians need to return to Rackham, trouble-shoot problem, and correct.
FO-335742	12/28/2015			**ADDING ELECTRICIAN: Please disconnect power on domestic hot water recirculation pump in mechanical room 23. Also see Gerry (Plumber) because this pump is being relocated to a more accessible and the power will also need to be relocated **NEEDS TO BE D
FO-335743	12/28/2015			**ADDING ELECTRICIAN: Please disconnect condensate pump #2 in sump pit in mechanical room 25. See Ron Clark or Jim Hill for detail **THIS NEEDS TO BE DISCONNECTED BY 7:30am ON Tuesday 12/29/15
				(**) PO REQ DK Repair #2 condensate return pump locat
FO-335761	12/29/2015			First thing in the morning check power at Bonstelle Theatre, and let Team Leader know if power is restored.
FO-335774	12/29/2015			**ADDING ELECTRICIAN: Please disconnect and reconnect domestic hot water circulation pump near kitchen. See Gerry (Plumber) for location
				(**) PO REQ DK 10/29 To plumbers. Please replace domestic hot water recirculation pump and install a drain and v
<b>T - Locksmith</b>			<b>3</b>	
FO-334194	12/3/2015	12/7/2015		New Key Lost / Stolen Key #: 9HA4A08 Key Holder ID: Louise Dezur Qty: 3  action: faculty stole key  Immediate Need by 12/7/2015 Account #: 124961
FO-334193	12/3/2015	12/7/2015		New Key Lost / Stolen Key #: 9HA5C06 Key Holder ID: Louise Dezur Qty: 3  action: Faculty Lost Keys  Immediate Need 12/7/2015 Account #: 124961
FO-335134	12/17/2015			New Key New Staff Member Key #: A2-10 Key Holder ID: College of Engineering, Dean's Office Qty: 2  action: For room 1151.1 New staff member **Rush request** Also sending email. Thank you.
<b>T - Painter</b>			<b>1</b>	
FO-334767	12/11/2015			Rm. 1233 has holes in the wall by the entrance and by the wall monitor that need to be repaired and painted.
<b>T - Pipefitter</b>			<b>17</b>	
FO-333753	12/1/2015	12/8/2015		R/R BSMT HALLWAY OUTSIDE OF MENS RR 00114 please have pipe fitters repair pipe patch that is leaking on the floor outside of restroom 0114. high priority. EA/12-1-15
FO-333767	12/1/2015	12/4/2015		To pipe fitters. R/R RM 00006.10/MECH RM Repair or replace defective F&W steam trap on coil for SF-1. High priority. JH/12-2-15

WO	Recieved	Finished	Total	Request
FO-333957	12/1/2015	12/18/2015		**ENGINEER TO REWRITE IF LEAK REAPPEARS JWT  Trade: Pipefitter Priority: High Please repair leak in the west overhang at Life Science. ,,,,,,,,,,,,,,,,,, EA/12-2-15 ,,,,,,,,,,,,,,
FO-334199	12/4/2015	12/7/2015		pipefitters R/R RM 00134 please replace radiator valve operator (dan Foss for 1/2 in valve) in Mr. Pecic's office. Room is overheating dramatically. Actuator will not close valve. Please give this attention ASAP. ,,,,,,,,,,,,,, JH/12-4-15 ,,,,,,,,,,,,,,
FO-334236	12/4/2015			Fitters -- Priority High Condensate Tank Leaks ,,,,,,,,,,,,,, ME/12-5-15 ,,,,,,,,,,,,,,
FO-334238	12/4/2015			Please replace feed water headers (all of them)on the feed water pump discharges at Chemistry. We are having issues with reduced water flow. ,,,,,,,,,,,,,, EA/12-5-15 ,,,,,,,,,,,,,,
FO-334468	12/8/2015	12/8/2015		**PLUMBER WORK ORDER/ REFER TO FO#334478 JWT  RM 4320 PIPE BURST, WATER IS EVERYWHERE...ENG ISOLATED LEAK
FO-334610	12/10/2015	12/21/2015		Pipe Fitter; High Please replace the bad 3/4 inch control steam valve, normally open, angle valve, 3 psi to 8 psi spring pressure. ,,,,,,,,,,,,,, ME/12-10-15 ,,,,,,,,,,,,,,
FO-334696	12/11/2015	12/15/2015		Fitters, repair a condensate leak in the steam system. leak location in the basement of the carriage house priority high ,,,,,,,,,,,,,, JH/12-14-15 ,,,,,,,,,,,,,,
FO-334820	12/14/2015			SteamFitter R/R RM 00100/MECH RM PLEASE REPLACE BAD Steam TRAP on main steam line entering scotthall,"no 11gn3 spirax sarco.Priority extremely HIGH.4 request,BOBICK !! GOT to be repaired now !! ,,,,,,,,,,,,,, ME/12-14-15 ,,,,,,,,,,,,,,
FO-334856	12/14/2015	12/15/2015		1ST FL NW ENTRANCE NEAR MAILBOXES, CEILING LEAK ,,,,,,,,,,,,,, EA/12-14-15 ,,,,,,,,,,,,,
FO-335010	12/16/2015	12/16/2015		**DUPLICATE /REFER TO FO#329515 JWT  R/R RM 00410/DLAR please have pipefitters remove chilled water supply and return lines on overhead cooling unit so electricians can access the removal of the motor. high priority.
FO-335082	12/16/2015	12/17/2015		Small water leak in pipes near stairway in 1st floor hallway. See Sandy for details. Thanks, Sandy ,,,,,,,,,,,,,, ME/ 12-17-15 ,,,,,,,,,,,,,,
FO-335210	12/21/2015			CEILING LEAK. ATRIUM NEAR ROOM 1400. ,,,,,,,,,,,,,, ME/12-21-15 ,,,,,,,,,,,,,,
FO-335218	12/21/2015	12/21/2015		CEILING LEAK. 1ST FLOOR LOBBY NEAR ROOM 103. ,,,,,,,,,,,,,, EA/12-21-15 ,,,,,,,,,,,,,,
FO-335231	12/21/2015			CONDENSATION PUMP IS NOT WORKING. CONDENSATION IS RUNNING ON FLOOR. BOILER ROOM. ,,,,,,,,,,,,,, RC/12-21-15 ,,,,,,,,,,,,,,
FO-335729	12/24/2015			**THIS IS WARRENTY WORK PER JAMES DARGA 12/28/15 JWT  There is a water leak in the Vivarium clean cage room 0140. Also the ceiling is starting to crack and separate from the leak. ,,,,,,,,,,,,,, JH/12-28-15 ,,,,,,,,,,,,,,
<b>T - Plumber</b>			<b>62</b>	
FO-334006	12/1/2015	12/7/2015		5th floor ladies restroom, the 3rd toilet from the entrance is not flushing properly and the water level remains low when it has finished running. Please repair. ,,,,,,,,,,,,,, MM/12-2-15 ,,,,,,,,,,,,,
FO-334060	12/2/2015	12/2/2015		1ST FL LADIES RM MIDDLE STALL TOILET CONTINUOUSLY RUNNING ,,,,,,,,,,,,,, TT/12-2-15 ,,,,,,,,,,,,,
FO-334117	12/3/2015	12/7/2015		SHOWER CONTINUOUSLY RUNNING. 1ST FLOOR WOMEN'S BASEKETBALL ROOM. SOUTH SIDE OF BLDG. ,,,,,,,,,,,,,, GS/12-5-15 ,,,,,,,,,,,,,,
FO-334119	12/3/2015	12/8/2015		TOILET CONTINUOUSLY FLUSHING. 1ST FLOOR WOMEN'S RESTROOM NEAR ELEVATOR. MIDDLE STALL ,,,,,,,,,,,,,, TT/12-5-15 ,,,,,,,,,,,,,,
FO-334177	12/3/2015	12/7/2015		URINAL OVERFLOWING. 4TH FLOOR MEN'S RESTROOM. ,,,,,,,,,,,,,, TT/12-3-15 ,,,,,,,,,,,,,
FO-334186	12/3/2015			3RD FL LADIES RM ALL SINKS ARE BACKED UP ,,,,,,,,,,,,,, GS/12-3-15 ,,,,,,,,,,,,,,
FO-334187	12/3/2015	12/8/2015		4TH FL LADIES RM 1ST STALL, WHEN TOILET IS FLUSHED IT LEAKS DOWN PIPE ,,,,,,,,,,,,, TT/12-3-15 ,,,,,,,,,,,,,,
FO-334206	12/4/2015	12/8/2015		STE 2800 WOMENS RM NO HOT WATER ,,,,,,,,,,,,,, DB/12-4-15 ,,,,,,,,,,,,,,
FO-334224	12/4/2015	12/23/2015		2nd floor ladies restroom - the first sink has a constant drip of water coming from the faucet. Please repair. ,,,,,,,,,,,,,, MM/12-4-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-334222	12/4/2015	12/4/2015		1ST FL LADIES RM TOILET PLUGGED DB/12-4-15
FO-334274	12/7/2015			PLUMBING DEPT-PLEASE CHECK LEAK IN SOUTHWEST INTERIOR ENTRANCE ,BY DOOR 150 07 W,PRIORITY HIGH CEILING LEAK TT/12-7-15
FO-334291	12/7/2015	12/7/2015		R/R slone on 3rd floor and faucet in 2nd floor bathroom . See DB for location if needed TT/12-7-15
FO-334309	12/7/2015	12/9/2015		TOILET IS PLUGGED. 1ST FLOOR UNISEX RESTROOM. GS/12-8-15
FO-334311	12/7/2015	12/8/2015		BOTH MEN'S RM HAVE LOW WATER PRESSURE TT/12-7-15
FO-334315	12/7/2015	12/9/2015		1ST FL CAFETERIA, DRINKING FOUNTAIN WATER BOTTLE FILLER SENSOR NOT WORKING MM/12-8-15
FO-334323	12/7/2015	12/7/2015		3RD FL NO WATER PRESSURE TT/12-7-15
FO-334324	12/7/2015			RM 306 NO WATER PRESSURE TO COMPRESSOR TT/12-7-15
FO-334324	12/7/2015			RM 306 NO WATER PRESSURE TO COMPRESSOR TT/12-7-15
FO-334330	12/7/2015	12/8/2015		WEAK FLUSHES IN TOILETS. 3RD FLOOR LADIES RESTROOM. TT/12-8-15
FO-334331	12/7/2015	12/8/2015		TOILETS NOT FLUSHING. 4TH FLOOR LADIES RESTROOM. TT/12-8-15
FO-334332	12/7/2015	12/9/2015		PIPE LEAK UNDERNEATH SINK. ROOM 410. MM/12-8-15
FO-334402	12/8/2015	12/12/2015		RM 2136.1 INNER LAB, CEILING LEAK *MM/EA/12-8-15
FO-334403	12/8/2015			(**) PO REQ DK 12/22 2nd LEAK (**) PO REQ DK 12/11 MCP  **ABATEMENT COMPLETED 12/10 JWT RM 2116.1 INNER LAB, CEILING LEAK *MM/EA/12-8-15
FO-334411	12/8/2015	12/8/2015		OUTSIDE RM 355 DRINKING FOUNTAIN NOT WORKING PROPERLY TT/12/8/15
FO-334459	12/8/2015	12/9/2015		LAB 3174 SINK LEAKING, PIPE UNDER SINK LEAK MAKING FLOOR TILES SQUISHY. TT/12-8-15
FO-334466	12/8/2015	12/10/2015		WOMENS RM 1360 LARGE STALL, TOILET HANDLE IS BROKEN MM/12-9-15
FO-334477	12/9/2015	12/10/2015		Trade: Plumber Priority: High R/R RM 351.30 The distilled water line is attached only at the ceiling level. The valve near the sink is not attached. The plastic pipe can be moved and may break at the top. Please secure the pipe properly. THIS IS A
FO-334478	12/9/2015	12/9/2015		PLUMBERS: R/R RM 4320 Please repair R O Line under sink in room 4320. System turned off in pipe chase last night due to flood. HIGH. MM/12-9-15
FO-334503	12/9/2015	12/9/2015		SINKS HAVE NO WATER 2ND FLOOR NORTH AND SOUTH SIDES.
FO-334505	12/9/2015	12/9/2015		1ST FLOOR TOILETS NOT FLUSHING.
FO-334507	12/9/2015	12/10/2015		R/R 2ND FLR West Wing restroom (on ONE SIDE OF 2137). Men's restroom: One sink TT/12-10-15
FO-334509	12/9/2015	12/10/2015		R/R 2ND FLR West Wing restroom (on ONE side of room 2137). Women's restroom: One stall isn't working. General flushing forrestrooms is low. TT/12-10-15
FO-334508	12/9/2015	12/10/2015		R/R 2ND FLR West Wing restrooms (on either side of room 2137). Men's restroom: One sink ISN'T WORKING TT/12-10-15
FO-334600	12/10/2015	12/11/2015		KITCHEN 2210 LEAK UNDER SINK TT/12-10-15
FO-334614	12/10/2015	12/10/2015		STE 1200 KITCHENETTE, NO WATER DB/ 12-10-15
FO-334675	12/10/2015	12/14/2015		4TH FL WOMENS RM HANDICAP STALL, TOILET SEAT LOOSE MM/12-14-15
FO-334676	12/10/2015	12/11/2015		First Floor Visitors Restroom off of the Atrium toilet sensor is not flushing on its own. TT/12-11-15
FO-334678	12/10/2015	12/11/2015		First Floor Visitors Restroom off of the Atrium toilet sensor is not flushing on its own. TT/12-11-15
FO-334714	12/11/2015	12/21/2015		Replace two leaking faucets Men's restroom Rm 440. GS/12-14-15
FO-334720	12/11/2015	12/14/2015		WOMENS RM TOILET HANDLE LEAKS WHEN FLUSHED ALSO LEAKS FROM TOP MM/12-14-15

WO	Recieved	Finished	Total	Request
FO-334760	12/11/2015			(**) PO REQ DK ORDER #2 (**) PO REQ DK 12/11 **WORK IN PROGRESS JWT 12/11 FLOOR DRAIN LEAKING IN ROOM 1330 AND LEAKING DOWN INTO ROOM 0330. ,,,,,,,,,,,,, TT/12-11-15 ,,,,,,,,,,,,,,
FO-334766	12/11/2015	12/15/2015		The 1st floor men's locker room has a toilet that is not flushing properly and almost full to the top with water. If someone flushes it, it will overflow. Please repair. ,,,,,,,,,,,,,, MM/12-14-15 ,,,,,,,,,,,,,,
FO-334816	12/14/2015	12/14/2015		**DUPLICATE/ REFER TO FO#334843  PLUGGED TOILET. (1ST TOILET) 1ST FLOOR MEN'S RESTROOM NEAR VENDING MACHINES.
FO-334840	12/14/2015	12/15/2015		FAUCET CONTINUOUSLY RUNNING. ROOM 5505. ,,,,,,,,,,,,,, MM/12/14/15 ,,,,,,,,,,,,,,
FO-334858	12/14/2015	12/14/2015		3RD FL WOMENS RM NEAR ELEV, TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,,,,,, TT/12-14-15 ,,,,,,,,,,,,,,
FO-334867	12/14/2015			Men's Restroom Rm. 240  Repair toilet leak. ,,,,,,,,,,,,,, GS/12-15-15 ,,,,,,,,,,,,,,
FO-334960	12/15/2015	12/15/2015		1st floor water fountain has orange rusty water coming out of it. Please service. ,,,,,,,,,,,,,, TT/12/15/15 ,,,,,,,,,,,,,,
FO-335014	12/16/2015	12/18/2015		(**) PO REQ DK 12/17 *WORK IN PROGRESS JWT  WATER TANK UNDERNEATH SINK IS LEAKING VERY BADLY. ROOM 4900. ,,,,,,,,,,,,,, TT/12-16-15 ,,,,,,,,,,,,,,
FO-335039	12/16/2015	12/16/2015		MENS AND WOMENS RM IN ATRIUM DRAINS BACKED UP ,,,,,,,,,,,,,, TT/12-16-15 ,,,,,,,,,,,,,
FO-335058	12/16/2015	12/17/2015		3RD FL LADIES RM SINK BACKED UP ,,,,,,,,,,,,,, TT/12-17-15 ,,,,,,,,,,,,,,
FO-335113	12/17/2015	12/18/2015		Toilet in the Dean's office overflows from the top of the tank. Please repair ASAP. NO ONE IS ANSWERING THE SERVICE CENTER LINE! ,,,,,,,,,,,,,, GS/12-17-15 ,,,,,,,,,,,,,,
FO-335222	12/21/2015			(**) PO REQ DK 12/22 **WORK IN PROGRESS JWT 12/21  HOT WATER SPRAYER WILL NOT TURN OFF. KITCHEN (BASEMENT),,,,,,,,,,,,,, TT/12-21-15 ,,,,,,,,,,,,,,
FO-335229	12/21/2015	12/22/2015		KITCHEN SINK PLUGGED ,,,,,,,,,,,,,, TT/12-22-15 ,,,,,,,,,,,,,,
FO-335238	12/21/2015			R/R 3RD FLR HALLWAY Water is leaking from UNDERNEATH @ WALL NEXT TO the water fountain outside of the restroom rm 3342. (Note leaks even when wtr fountain is being used) ,,,,,,,,,,,,, TT/12-22-15 ,,,,,,,,,,,,,,
FO-335246	12/21/2015			PLUMB R/R RM 326/MENS RR HANDICAP STALL TOILET IS PLUGGED UP ,,,,,,,,,,,,,, MM/12-22-15 ,,,,,,,,,,,,,,
FO-335551	12/22/2015			MENS RM WITHIN 1600, BROKEN TOILET SEAT ,,,,,,,,,,,,,, TT/12-23-15 ,,,,,,,,,,,,,,
FO-335639	12/22/2015	12/23/2015		Water won't go down the drain, sink has been plunged several times. ,,,,,,,,,,,,,, TT/12-23-15 ,,,,,,,,,,,,,,
FO-335640	12/22/2015	12/23/2015		R/R RM 00151/JANITORS' CLOSET Water won't go down the drain, sink has been plunged several times. ,,,,,,,,,,,,,, TT/12-23-15 ,,,,,,,,,,,,,,
FO-335659	12/22/2015	12/23/2015		1ST FL MENS RM LEFT SINK BEEPING ,,,,,,,,,,,,,, DB/12-23-15 ,,,,,,,,,,,,,,
FO-335704	12/23/2015			TOILET WON'T FLUSH. DEANS OFFICE ROOM 112. ,,,,,,,,,,,,,, GS/12-23-15 ,,,,,,,,,,,,,,
FO-335710	12/23/2015	12/23/2015		**DUPLICATE WORK ORDER JWT  Loading dock is flooded from the rain - needs to be pumped out
FO-335747	12/28/2015			Pump out loading dock ,,,,,,,,,,,,,, MM/12-28-15 ,,,,,,,,,,,,,,
<b>T - Roofing</b>			<b>1</b>	
FO-335544	12/22/2015			CEILING LEAK. 1ST FLOOR LOBBY NEAR ROOM 103. ,,,,,,,,,,,,,, EA/12-21-15 ,,,,,,,,,,,,,,
<b>Medium</b>			<b>130</b>	
<b>T - Carpenter</b>			<b>21</b>	
FO-334018	12/2/2015	12/7/2015		CARPENTERS, PLEASE REPAIR BROKEN FLOOR TILE IN VESTIBULE AT OUTSIDE DOORWAY #001-09-S.PRIORITY-MEDIUM
FO-334068	12/2/2015	12/2/2015		please fix door stop-rubber part has come off - thank you

WO	Recieved	Finished	Total	Request
FO-334114	12/3/2015	12/11/2015		**ADDING CARPENTER : Repair walls where access was made and replace ceiling tiles where needed from plumbing repairs. See Troy if needed  R/R RM 110 There are two large leaks in the ceiling. The ceiling tiles have fallen and in one area the water is s
FO-334118	12/3/2015	12/11/2015		Carpenters: Please secure seats # 101 and 102 in row E to the floor, seats are coming off the floor and not safe. Priority: med.
FO-334157	12/3/2015	12/4/2015		The Studio Theatre doors are not closing automatically properly. Can the close bars at the top of the doors be readjusted so that the doors close automatically properly? The door #s are 189 14BE, 189 15 BE, 189 16 BE, and 189 17 BE Please see Michael in
FO-334172	12/3/2015	12/4/2015		Carpenters: please repair door closer on handicap door inside vestibule next to door # 016-14-W, it's arm is off. Priority: med.
FO-334174	12/3/2015	12/4/2015		Carpenters: please repair or replace door closer on men's room 109 door, it slam hard when it closing. Priority: med.
FO-334308	12/7/2015	12/18/2015		Carpenters : Please replace broken ceiling tiles, priority med.
FO-334481	12/9/2015	12/28/2015		CARPENTERS: R/R RM 4320 Please replace several DAMAGED floor tiles in room 4320. MED.
FO-334655	12/10/2015	12/29/2015		**ADDING CARPENTER: Remove base cabinet for sink removal access. See Gerry for detail  (**) PO REQ DK 10/8 R/R RM 2131/LAB EAST SIDE SINK HAS A CRACK. WHEN IN USE IT LEAKS ..... GS/8-24-15 .....
FO-334799	12/13/2015	12/21/2015		Repair outside exit door # 050-09-N at Shapiro Hall. The door is rusted closed and cannot be opened.
FO-334895	12/14/2015	12/15/2015		LOCKSMITH, PLEASE REPAIR DEAD LOCKING LATCH ON DOORS FOR ROOMS 2412 & 3412. PRIORITY-MEDIUM
FO-335020	12/16/2015	12/28/2015		The door to room 0249 is really hard to open. Need someone to fix it before it becomes impossible to get into room.
FO-335103	12/17/2015			CARPENTERS: Please replace bad floor tiles in room 4341(trip hazard)MED.
FO-335207	12/21/2015	12/22/2015		Carpenters: Door 156 06W won't lock correctly. Priority: Medium
FO-335214	12/21/2015	12/22/2015		Carpenter Med Priority Please R/R door stop mens rest rm. basement by Custodial office, Broken 1/4 in lag. Door stop in engineers office on file cabinet by printer.
FO-335690	12/23/2015	12/23/2015		Carpenters: please repair class room 231 door, it is coming off it's hinges Priority: med.
FO-335737	12/28/2015	12/29/2015		Door closer on handicapped entrance door # 209-1-S at Tech Town has been binding and holding the door open wide sometimes when the door is opened wide with the handicapped control.
FO-335745	12/28/2015			**ADDING CARPENTER: Remove backsplash on counter top in lab 357 to access pipe repair. See Marty Elwart for detail  Trade: Pipefitter Priority: Medium Please repair steam leak in west lab table in room 357. .... ME/12-2-15 .....
FO-335749	12/28/2015	12/29/2015		Repair door synchronizer is preventing door from closing at Mathaei. Outside entrance door # 080-27-S
FO-335765	12/29/2015			Repair door closer on door #007-1-E at Chemistry. Closer is weak and does not pull door tightly close, preventing latching and leaving the door unsecure.
<b>T - Electrician</b>			<b>35</b>	
FO-333949	12/1/2015	12/1/2015		please install light fixture in roo 401
FO-334042	12/2/2015			ELECTRICAL DEPT-EXTERIOR OUTSIDE LIGHT BY BOILER ROOM DOOR 156-08-N NOT WORKING, DARK IN AREA AT NIGHT PLEASE CHECK PRIORITY MED
FO-334083	12/2/2015			Electrician; Medium R/R LOAD DOCK AREA Please repair the bad electrical outlets in the loading dock area.

WO	Recieved	Finished	Total	Request
FO-334116	12/3/2015			Trade: Laborer Priority: Low Please remove pipe fittings that were removed as part of the coil removal project in the "skinny stair" mechanical room (4038). Fittings are at the top of the stairs.
FO-334259	12/5/2015	12/7/2015		**ADDING ELECTRICIAN: Rewire condensate pump #2 in mechanical room 00124 and check rotation. If pump still will not move condensate call Ron Clark  PIEFITTERS R/R RM 00124/MECH RM PLEASE condensate pump #2 at Mort Sci room 124. Pumps is not moving w
FO-334273	12/5/2015			ELECTRICIANS: Please repair Basement EBU light systems. MED.
FO-334282	12/7/2015	12/8/2015		Trade: Electrician Priority: Medium The electric water heater is not working in the boiler room penthouse.
FO-334283	12/7/2015	12/8/2015		Electricians- medium priority- replace malfunctioning blower motor on entrance vestibule unit heater. Motor has bad capacitor or start winding and will not start automatically.
FO-334417	12/8/2015			Trade: Electrician Priority: Medium Please install 480volt plug that we can use to plug in the portable electric heater for freeze protection of the boiler blow down pipes.
FO-334458	12/8/2015	12/9/2015		check out boiler feed pump skid to prepare for retro fit of motors
FO-334525	12/9/2015	12/14/2015		Electricians Medium, R/R RM 00022/MECH RM Repair or replace as needed fluoresent light fixture not working over work bench.
FO-334666	12/10/2015	12/11/2015		**ADDING ELECTRICIAN: Please verify voltage and phase of booster pump in sub-basement. New and Old. See John Towle for detail  Please repair or replace sump pump #4. Pump is seized. Pump was previously disconnected electrically. ,,,,,,,,,,,,,, GS/1
FO-334706	12/11/2015	12/17/2015		Replace light bulbs in 3 fixtures in the Pipe Shop . See John
FO-334744	12/11/2015			trade electricains priority medium R/R 3RD/4TH FLRS electrical closets on both 3rd and 4th floors has loud humming noise coming from transformer inside electrical rooms
FO-334762	12/11/2015			Trade: LaborerPriority: Med.Please supply 1 drum of Neutramine XF-P 17070042
FO-334791	12/11/2015			**ADDING ELECTRICIAN: Disconnect sump pump #2 in basement mechanical room. pump to be removed. Rewire when replaced. See Gerry for detail  Trade: Plumber Priority: Medium Sump pump #2 located in fan room #2 is not pumping. Casing was warm and sump
FO-334866	12/14/2015	12/17/2015		restore fire panel when steam leak is contained
FO-334990	12/15/2015	12/16/2015		University clock is out of order. Please repair ASAP.
FO-335028	12/16/2015	12/17/2015		Electricians, Medium Multiple troubles on Fire alarm system, please repair as needed.
FO-335061	12/16/2015			Electricians Medium. R/R RM 502 Repair 4' light fixture as needed. Suspect bad ballast.
FO-335085	12/17/2015			**ADDING ELECTRICIAN: Disconnect power to circulation pump for water heater. pump on right hand side *See Gerry when disconnected  (**) PO REQ DK 12/7 PLUMBERS please r/r hot water circ pump. Received complaint of no hot water on 2nd floor. circ p
FO-335086	12/17/2015			*ADDING ELECTRICIAN: disconnect both condensate pumps one at a time and rewire when repaired. See Ron Clark for detail  (**) PO REQ DK 12/7 Pipefitters -- Priority Medium Condensate pumps need new seal ,,,,,,,,,,,,,, RC/7-27-15 ,,,,,,,,,,,,,,
FO-335093	12/17/2015	12/21/2015		Electricians, Medium: Repair or replace hall clock as needed, west end 4th floor. Clock is mounted and hard wired.

WO	Recieved	Finished	Total	Request
FO-335115	12/17/2015			Purdy Library 3rd FloorClock near Custodial Closet 335 is running one hour fast. Please reset.Thank you.
FO-335131	12/18/2015	12/18/2015		Time for crew to attend Respirator Fit Test with Elena.
FO-335189	12/18/2015			Outside room 146 (Student Lounge) - Light out, tagged electrical since 3/12/15.
FO-335216	12/21/2015			Repair/Re-lamp fixtures throughout the Mall, several is out.
FO-335541	12/22/2015			ELECTRICIANS: R/R PENTHOUSE Please disconnect Power from Motor on AHU #10. CONTRACTOR working on large fan. MED.
FO-335550	12/22/2015			PENTHOUSE: R/R PENTHOUSE Please replace Fan Motor on EF#17 . MED.
FO-335556	12/22/2015			Electricians Medium. R/R RM 108 Repair or replace hall clock 1st floor.
FO-335600	12/22/2015			trade electricians priority medium R/R RM 6152/MECH RM please replace or repair switch gear and fan for air handler # two supply fan drive the switch is broken and the fans have been removed
FO-335711	12/23/2015			Trade: Electricians Priority: Medium R/R E. LAWN The outside pole lights between Chemistry and State Hall and Science Hall are not on every morning at 7am, however several days I did not leave until 3:30pm, and the light were on..... Please adjust the l
FO-335726	12/24/2015			ELECTRICIANS:R/R ROOF AREA Please repair/ replace Fan Motor for EF#1 on roof. MED.
FO-335732	12/27/2015			Repair fire alarm trouble at Matthaei, "Smoke detector, 1st floor, hall by racquetball south".
FO-335778	12/30/2015			Replace missing duplex receptacle located in the old cafeteria/lunchroom in the basement area of Community Arts/Art, (near Room 050). There is exposed copper.
<b>T - Painter</b>			<b>2</b>	
FO-334099	12/2/2015	12/3/2015		Plaster Repair, Prime & Paint south wall, 1st floor.
FO-335656	12/22/2015			REPAIR CEILING DUE TO ROOF LEAK. 4TH FLOOR OUTSIDE ELEVATOR LOBBY CEILING.
<b>T - Pipefitter</b>			<b>35</b>	
FO-333994	12/1/2015			steam fitters- repair or replace malfunctioning feed water bypass valve and feed water valve to boiler number 2. ,,,,,,,,,,,,,, ME/12-2-15 ,,,,,,,,,,,,,,
FO-333996	12/1/2015			Trade: Pipefitter Priority: Medium Please repair steam leak in west lab table in room 357. ,,,,,,,,,,,,,, *ME/EA/12-2-15 ,,,,,,,,,,,,,,
FO-334013	12/2/2015	12/2/2015		**DUPLICATE/ REFER TO FO#333603 JWT  Repair support brackets on the top end of the wall-mounted radiator located behind the gas log fireplace in the foyer of Tierney Alumni House. The upper portion of the radiator is not supported or attached to the wal
FO-334014	12/2/2015	12/2/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVES ON BOTH FFC UNITS. PRIORITY-MEDIUM. ,,,,,,,,,,,,,, ME/12-2-15 ,,,,,,,,,,,,,,
FO-334066	12/2/2015	12/2/2015		FITTERS, PLEASE REMOVE LEAKING DIELECTRIC UNIONS ON # 1 FFC UNIT. PRIORITY-MEDIUM. ,,,,,,,,,,,,,, ME/12-2-15 ,,,,,,,,,,,,,,
FO-334114	12/3/2015	12/11/2015		**ADDING CARPENTER : Repair walls where access was made and replace ceiling tiles where needed from plumbing repairs. See Troy if needed  R/R RM 110 There are two large leaks in the ceiling. The ceiling tiles have fallen and in one area the water is s
FO-334208	12/4/2015			Steamfitters- Medium Priority. Repair steam coil leaks on AHU #1 and AHU #2.
FO-334404	12/8/2015			(**) PO REQ DK 12/18 Trade: Pipefitter Priority: Medium Please repair/replace leaking seal on condensate pump #2 in condensate receiver #4 located next to the surge tank in the Chemistry subbasement. ,,,,,,,,,,,,,, RC/12-8-15 ,,,,,,,,,,,,,,
FO-334405	12/8/2015	12/8/2015		Pipe fitters: please repair or replace leaking hot water reheat valve for south basement hallway, the reheat unit is in room 013. priority: med. ,,,,,,,,,,,,,, JH/12-8-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-334406	12/8/2015	12/9/2015		Pipe fitters: please repair or replace reheat control valve for room 103, the reheat unit is in mechanical room 016. Priority: med. Attention: Jim Hill. JH/12-8-15
FO-334460	12/8/2015	12/11/2015		FITTERS: Please repair two leaking pipes within AHU#1 return area in plenum. MED. ME/12-8-15
FO-334485	12/9/2015	12/9/2015		FITTERS, PLEASE REPAIR HWH FITTING LEAK & REPLACE BAD HWH SUPPLY VALVE ON #1 FFC UNIT. PRIORITY-MEDIUM ME/12-9-15
FO-334652	12/10/2015			PIPEFITTERS please replace reheat valve marked and ceiling panel open to indicate location at Mort sci in 1st floor lounge area.
FO-334653	12/10/2015			PIPEFITTERS please replace reheat valve marked and ceiling panel open to indicate location at Mort sci in 1st in hall outside of ladies lav.
FO-334658	12/10/2015	12/16/2015		Cut up and dispose of old 10' piece of 6" header on floor near glass storage in room 100 EA/12-10-15
FO-334730	12/11/2015			Pf Med Priority Replace 2 1/2 regulating valve to # 2 AHU. Valve is leaking through and overheating area. ME/12-14-15
FO-334752	12/11/2015			Pipe fitters: please repair hot water heating expansion tank, it is leaking from a few spots. priority: med. ME/12-14-15
FO-334822	12/14/2015			Pipefitter: Med Priority. Location: PH next to boiler #2 Please provide and install feed water sample sink and drain utilizing existing sample cooler connecting to city water for cooling source. At present the cooler is attached to the RO water sys. ,,
FO-334857	12/14/2015	12/15/2015		PIPEFITTERS please r/r leaking condensate line (marked w. rag) under HEX2 in room 124 @ Mort Sci. Thanks. ME/12-14 15
FO-334863	12/14/2015	12/15/2015		Pipefitters-please extend condensate drain line 6' toward ground to assist in proper drainage. Discharge line is in the alley. JH/12-14-15
FO-334868	12/14/2015	12/17/2015		Pipefitter: Med Priority Location: PH Please pipe side screen filter purge discharge to glycol make-up tank Contact Eng. Jim JH/12-15-15
FO-334974	12/15/2015			To pipe fitters. Repair flange leak on main steam bypass valve in room 25 behind AHU-6. EA/12-15-15
FO-335006	12/16/2015	12/21/2015		Trade: Pipe Fitter Priority: Medium R/R RM 4195/MECH BLR RM Replace leaking 3/4 inch elbow on make up water line to surge tank. Elbow has pin hole leak in it. ME/12-17-15
FO-335024	12/16/2015	12/18/2015		Replace valve head on water softener. New head in warehouse RC/12-17-15
FO-335026	12/16/2015			Steamfitters. Medium, Repair surface blow piping on steam boilers. See Engineer for details 734-286-4256 EA/12-17-15
FO-335087	12/17/2015			Trade: Pipe fitter Priority: Medium In room no. 102.8 control valve to radiator leaking. EA/12-17-15
FO-335121	12/17/2015			Fitter replace needle valve for surface blow down on boiler #1. JH/ 12-17-15
FO-335147	12/18/2015			trade pipe fitters priority medium please take look at asbestos showing on chill water pumps p2 and ps2
FO-335162	12/18/2015	12/21/2015		Pipe fitters: please replace leaking automatic air vent on hot water heating system in mechanical room ceiling close to elevator room. Priority: med. EA/12-21-15
FO-335247	12/21/2015			Pf med priority Repair steam coil leak ahu #7. ME/12-22-15
FO-335252	12/21/2015			REPAIR LEAKING IN STEAM HEATING COIL ON SAF-2 IN PENTHOUSE. MM/12-22-15
FO-335662	12/22/2015			Pipefitters -- Priority Medium Please replace #2 Boiler's stop value(swing value). Value does not hold ME/12-30-15
FO-335663	12/22/2015			Pipefitters -- Priority Medium Please replace #1 boiler's feedwater stop value (swing valve) Valve does not hold causing system to kick-out due to high water ME/12-30-15



WO	Recieved	Finished	Total	Request
FO-335664	12/22/2015			Pipefitters -- Priority Medium Please replace #3 boiler's feedwater stop value (swing valve) Valve does not hold causing system to kick-out due to high water ..... ME/12-30-15 .....
FO-335687	12/23/2015			FITTERS: Please repair leaking Steam Radiator in 3rd floor dressing room. MED..... EA/12-24-15 .....
<b>T - Plumber</b>				<b>36</b>
FO-333739	12/1/2015	12/3/2015		Trade: Plumber Priority: Medium R/R RM 00407/MENS RR Clogged urinal 1st from left. (313-424-9758)..... TT/12-1-15 .....
FO-333780	12/1/2015	12/7/2015		R/R RM 8336 SINK FAUCET IS LEAKING EVEN WHEN NOT IN USE (ACROSS FROM REFRIGERATOR) ..... MM/12-1-15 .....
FO-334017	12/2/2015	12/4/2015		There is a leaky faucet in the ladies rest room 148 1st floor. Leaking around the faucet to the floor ..... MM/12-2-15 .....
FO-334041	12/2/2015	12/4/2015		PLUMBERS PLEASE CLEAR DRAIN OUTSIDE BOILER ROOM DOOR 156-08-N,STANDING WATER PRIORITY MED ..... TT/12-2-15 .....
FO-334047	12/2/2015	12/3/2015		FLUSH HANDLE LEAKING. 3RD FLOOR LADIES RESTROOM. HANDICAP STALL. .... TT/12-2-15 .....
FO-334049	12/2/2015	12/3/2015		TOILET NOT FLUSHING PROPERLY (LOW WATER PRESSURE) 3RD FLOOR MEN'S RESTROOM. 1ST STALL. .... TT/12-2-15 .....
FO-334144	12/3/2015	12/7/2015		PLUGGED SINK. ROOM 4151. .... TT/12-3-15 .....
FO-334154	12/3/2015	12/23/2015		PLUMBERS: Please repair Leaking faucet in room 1113( Janitors closet) MED. .... MM/12-5-`15 .....
FO-334203	12/4/2015	12/8/2015		SINK IS COVERED WITH PLASTIC BAG WITH BROWN RESIDUE COMING FROM SINK DRAIN AND BROWN RESIDUE COMING FROM 2 MIDDLE TOILETS. .... GS/12-4-15 .....
FO-334246	12/4/2015			(**) PO REQ DK 12/18 Plumbers- med priority- Safety Equipment- Move eye wash station from old chemical station to the new chemical station. .... MM/12-4-15 .....
FO-334577	12/10/2015			plumb. Med Priority R/R 2ND FLR Replace drinking fountain filters building wide. refer to FO 334539 ..... TT/12-10-15 .....
FO-334643	12/10/2015	12/11/2015		PLUMBERS please r/r sloan valve on toilet in OFFICE ACROSS FROM 322. does not close completely. water is leaking by continuously..... TT/12-10-15 .....
FO-334649	12/10/2015			PLUMBERS please r/r city water valves leaking at packing on main line in basement at 5425 Woodward. .... TT/12-11-15 .....
FO-334651	12/10/2015			PLUMBERS please r/r sprinkler line isolation valve #3 in basement of 5425 woodward above fire pump continuous noticeable leaking from packing..... TT/12-17-15 .....
FO-334662	12/10/2015			Please repair or replace sump pump #4. Pump is seized. Pump was previously disconnected electrically. .... GS/12-10-15 .....
				**MATERIAL RECIEVED FROM FO#313656 Material on site
FO-334683	12/11/2015	12/14/2015		Trade: plumber Priority: Medium Ladies restroom: 1st stall from right toilet is clogged. .... TT/12-14-15 .....
FO-334684	12/11/2015	12/14/2015		Trade; Plumber Priority: Medium Ladies restroom : Handicap stall-Toilet leaking at spout. .... TT/12-14-15 .....
FO-334698	12/11/2015	12/15/2015		plumbers repair a leaking toilet north side third floor. toilet running priority medium ..... GS/12-14-15 .....
FO-334790	12/11/2015			Trade: Plumber Priority: Medium Sump pump #2 located in fan room #2 is not pumping. Casing was warm and sump level was not decreasing. .... GS/ 12-14-15 .....
				*Electrician Added 12/11/15 FO#334791 JWT
FO-334928	12/15/2015	12/15/2015		PLUMBERS, R/R 1407/RESTROOM PLEASE REPAIR TOILET FLUSH VALVE. PRIORITY-MEDIUM ..... TT/12-15-15 .....
FO-334975	12/15/2015	12/16/2015		Plumber cover up holes around water pipes at sink room AF-32 ..... MM/12-15-15 .....

WO	Recieved	Finished	Total	Request
FO-334996	12/15/2015			Trade: Plumber Priority: Medium Ladies restroom: 2nd stall -Toilet has problem with Sloan valve. Water running continuously. At present water isolated. ,,,,,,,,,, TT/12-16-15 ,,,,,,,,,
FO-335040	12/16/2015			FAUCET LEAK. ROOM 6119.,,,,,,,,,, MM/12-17-15 ,,,,,,,,,
FO-335042	12/16/2015	12/18/2015		TOILET IS NOT FLUSHING. LADIES RESTROOM. ROOM 1278, 1ST STALL. ,,,,,,,,, MM/12-17-15 ,,,,,,,,,
FO-335070	12/16/2015	12/23/2015		Plumbers, please snake out sink in room 14. ,,,,,,,,,, MM/ 12-17-15 ,,,,,,,,,
FO-335163	12/18/2015			Plumber inspect temperature control under lab sink. Cold water suddenly shuts off. ,,,,,,,,, MM/12-21-15 ,,,,,,,,,
FO-335164	12/18/2015			Plumber inspect no hot water at lab sink. ,,,,,,,,,, MM/12-21-15 ,,,,,,,,,
FO-335677	12/22/2015			Investigate water coming from the ground on south side of Matthaai between drive and new parking lot. Suspected failed Fire plug supply branch underground ,,,,,,,,,, DB/12-22-15 ,,,,,,,,,  DCSW has isolated water supply to 2 fire plugs. Repa
FO-335680	12/23/2015			PLUMBERS please r/r diaphragm(?) and shut off for toilet. leaks by and can hear water running all the time. water to toilet has been shut off and it still leaks by. 1st floor unisex toilet on left hand side entering from North door. ,,,,,,,,,,TT/12
FO-335705	12/23/2015			1ST FL MENS RM URINAL LEAKING FROM FLUSH VALVE ,,,,,,,,,, DB/12-23-15 ,,,,,,,,, ,,,,,,,,,
FO-335722	12/24/2015			PLUMBER PLEASE UN PLUG SINK ROOM 3 ,,,,,,,,,, TT/12-28-15 ,,,,,,,,,
FO-335733	12/27/2015			Repair Sloan flush valve assembly located on handicapped toilet in Men's Lav near 3106 of 5057 Woodward, (Maccabees). Toilet was running continuously. ,,,,,,,,,, TT/12-28-15 ,,,,,,,,, ,,,,,,,,,
FO-335738	12/28/2015			**ADDING PLUMBER: install sink to test boiler sample water. See Jim Hill for location ,,,,,,,,, DB/12-28-15 ,,,,,,,,,  Pipefitter: Med Priority. Location: PH next to boiler #2 Please provide and install feed water sample sink and drain
FO-335764	12/29/2015			Toilet drain is plugged up at Bonstelle Theater. This is the toilet located on the first floor near the north entrance, backstage area.,,,,,,,,,, MM/12-30-15 ,,,,,,,,,
FO-335768	12/29/2015			Repair toilet located in Men's lavatory, 3rd floor of Simons Building. Running continuously ,,,,,,,,, TT/12-30-15 ,,,,,,,,,
FO-335777	12/30/2015			The float ball controlling the storm water sump pumps at Kresge Library appears to be water bound and will not actuate pumps.,,,,,,,,,, DB/12-30-15 ,,,,,,,,,
<b>T - Roofing</b>			<b>1</b>	
FO-335253	12/21/2015			ROOF LEAK AT WEST LOBBY DOOR NEAR RM. 103.
<b>Low</b>			<b>303</b>	
<b>T - Carpenter</b>			<b>63</b>	
FO-334003	12/1/2015	12/2/2015		R/R RM 2215 Door is not consistently locking properly.
FO-334039	12/2/2015	12/31/2015		TEAM LEADER TIME ( DECEMBER 2015 )
FO-334051	12/2/2015	12/2/2015		Lock is not working correctly in Men's restroom. Lock is sticky and unable to lock door. Thank you.
FO-334075	12/2/2015	12/3/2015		CARPENTERS TO REFASTEN SIDE MOUNTING / INSIDE GATE MAIN ENTRANCE NEXT TO BOB'S OFFICE
FO-334098	12/2/2015	12/7/2015		CARPENTERS,PLEASE REPLACE WATER DAMAGED CEILING TILES.PRIORITY-LOW
FO-334101	12/2/2015			CARPENTERS TO REPAIR THE WALL IN THE SOFTBAL DUGOUT
FO-334195	12/4/2015	12/4/2015		Trade: Carpenter Priority: Lowthe east door into suite 2100 is slamming shut, please adjust or replace door closer.
FO-334212	12/4/2015	12/14/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-334213	12/4/2015	12/7/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR RM 4224. PRIORITY-LOW
FO-334287	12/7/2015	12/7/2015		CARPENTERS TO STRIP DOORS OF ALL USEABLE HARDWARE ROOM #3023

WO	Recieved	Finished	Total	Request
FO-334310	12/7/2015	12/9/2015		Batteries need to be changed on the door
FO-334341	12/7/2015	12/30/2015		CARPENTERS SAFETY MEETING DECEMBER 2015
FO-334342	12/7/2015	12/8/2015		REPAIR DAMAGED RESTROOM DOOR 1ST FLOOR
FO-334439	12/8/2015	12/9/2015		The closet door in the Dean's Office has come off the tracks. Please send someone today to have the problem resolved.
FO-334413	12/8/2015	12/8/2015		DOOR HANDLE IS BINDING. SUB-BASEMENT STAIRWELL B - NEAR ROOM 0129.
FO-334427	12/8/2015	12/9/2015		CARPENTERS, EGRESS WINDOW TO ROOF IS BINDING, PLEASE REPAIR. (ATTN: BRUCE ) PRIORITY-LOW
FO-334450	12/8/2015	12/11/2015		CARPENTERS TO REPLACE THE DAMAGED CEILING TILE & TUNE UP ALL GYM DOORS
FO-334464	12/8/2015	12/8/2015		CARPENTERS TO BRING XMAS PARTY TABLES FROM 1200 HOLDEN TO FP&M & CLEAN THE SMALL WAREHOUSE FOR THE PARTY
FO-334465	12/8/2015	12/8/2015		REPAIR DOOR 080-02-S CLOSER ARM / DISCONNECTED
FO-334607	12/10/2015	12/10/2015		NEED LOCK CUT OFF OF LOCKER. ROOM 206 - WOMEN'S LOCKER ROOM. LOCKER #31.
FO-334619	12/10/2015	12/14/2015		CARPENTERS, PLEASE REPAIR INNER DOOR GASKET. PRIORITY-LOW
FO-334620	12/10/2015	12/15/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-334739	12/10/2015			R/R BACKSTAGE GREEN RM The door leading from the greenroom into the theatre stage right vohm has a panel that is loose again. Can the door panel be reattached to the door? Need carpenter. Please see Michael in the box office for more information or exa
FO-334702	12/11/2015	12/14/2015		UGL inner entrance door, corresponding to outer door number 096-01E is squeaking. Other doors appear to be ok, but please check them all, inner and outer.
FO-334705	12/11/2015	12/21/2015		Replace broken locker handle on Locker # 84, located on the 2nd floor, outside MD lab 2343
FO-334724	12/11/2015	12/30/2015		CARPENTERS TO DEEP CLEAN SHOP
FO-334723	12/11/2015			Carpenters, replace one handicap parking sign and two Charfoos signs with F P M parking signs. priority medium
FO-334734	12/11/2015			Rm. 1233 has some warped and broken floor tiles that need replacing. Please do not do work before 12/17/15 due to an events/class being held.
FO-334747	12/11/2015			Blinds in the student lounge need to be put back up. The two pieces are by the window sill, so those don't need to be replaced. Few pieces of blinds on the 4th floor hallway which are also by the window sill, need to be put up.
FO-334781	12/11/2015			TILE IN ELEVATOR CRUMBLING, TRIP HAZARD. PLEASE REPLACE.
FO-334818	12/11/2015	12/23/2015		The wood walls on Elevator 2 is damaged and needs replacing.
FO-334823	12/14/2015			Carpenters: Med Priority.R/R PH Please fabricate and install removable ramp over steps in PH. Approximately 4 steps.NOTE: 4'x8' 3/4" plywood is on-site and is available for build if needed.
FO-334892	12/14/2015			Carpenters: Med Priority. R/R ENG'S OFC Please fabricate and hang approx. a 10ft x 1ft shelf over engineers office desk. L shape. Loretta Small(12/14/2015 07:50)-- 12/14/15 lps: wrkng on req Spoke w/Dave K for AD to sign off on req  12/14/15 lps: Sp
FO-334896	12/14/2015			Carpenters-please remove ceiling tile and grid for heat pump removal. Location is just off main elevator lobby (HP 2-58)See Andy or Gordie for details.
FO-334903	12/14/2015	12/28/2015		DOORS 023-1,2&3-E CLOSER ADJUSTMENTS DOORS SLAMMING
FO-334906	12/14/2015	12/22/2015		CARPENTERS TO CLEAN ALL LIGHT FIXTURES & PICKUP 125 CHAIRS FROM ST ANDREWS CHURCH
FO-334927	12/15/2015	12/16/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR ROOM 1372. PRIORITY-LOW

WO	Recieved	Finished	Total	Request
FO-334944	12/15/2015	12/16/2015		Repair or replace door closer on the entrance door on Ferry Mall. ASAP please as it threatens to break the glass by closing so hard. Index to charge is 227703
FO-334947	12/15/2015	12/16/2015		Repair single door in breezeway. It will not shut and stay locked. Breezeway is not secure. ASAP please. Index to charge is 227703
FO-334965	12/15/2015	12/16/2015		R/R (inside)STE RM 10.6 RM 6.1 The key for room 6.1 inside of room 10 will turn, but will not unlock the door. Needs to be repaired ASAP.
FO-334987	12/15/2015	12/30/2015		CARPENTERS TO SHEET & SET UP TABLES & CHAIRS.
FO-335059	12/16/2015	12/30/2015		Carpenters to install drywall in paint spray booth.
FO-335119	12/17/2015			CARPENTERS,PLEASE REPLACE WATER DAMAGED DRYWALL IN WINDOW COVES FOR ROOMS 1163 & 1151.PRIORITY-LOW
FO-335120	12/17/2015	12/23/2015		CARPENTERS, PLEASE SECURE #2 FFC UNIT TO WALL. PRIORITY-LOW
FO-335126	12/17/2015	12/18/2015		REPAIR BROKEN DOOR CLOSER. DOOR OUTSIDE OF ROOM 113.
FO-335133	12/18/2015	12/30/2015		CARPENTERS TO ATTEND CHRISTMAS PARTY
FO-335228	12/21/2015			Purdy Library, 1st Floor, Teaching Commons, Room 150  Tiles coming loose from ceiling, please reattach.  Thank you.
FO-335555	12/22/2015	12/23/2015		R/R RM 4159 Door is doesn't close on it's own and must be pulled shut. It may just need WD-40...but I'm not sure. Thanks!
FO-335602	12/22/2015	12/24/2015		R/R In suite 2290 (OT/PT) there two brown stained ceiling tiles near the back hall of the suite, which is by the exit door, that need to be replaced.
FO-335654	12/22/2015			CARPENTERS TO SUPPLY BARRACADES ON THE CROSSWALK SERVICE DRICE EAST ENTRANCE
FO-335703	12/23/2015	12/23/2015		B & E on main entry door please repair lock so door can be secured. Police NO. - W 153560076
FO-335691	12/23/2015			Carpenters: please install window blind, the blind has come off of it's roller. Also the same in room 328, 433 & 403. Priority: low.
FO-335692	12/23/2015			carpenters: please install door stop, it came off the wall, also the same for rooms 427 & 428. Priority: low.
FO-335693	12/23/2015			Carpenters: please replace damaged ceiling tile, also for room 212. priority: low.
FO-335699	12/23/2015	12/29/2015		Bottom hinge on door leading to loading dock is pulling away from door. Door is near Room 1500
FO-335701	12/23/2015	12/23/2015		CARPENTERS TO REMOVE NO SMOKING SIGN MAIN ENTRANCE ( MAROON SIGN )
FO-335709	12/23/2015			R/R RM 2545/GRP STUDY RM Just outside of room 2545, the drop ceiling is sagging. Looks like the holding track is broken.
FO-335712	12/23/2015	12/24/2015		KEYS ARE STUCK ON THE LAPIRA SIGN **SEE RESULTS**
FO-335744	12/28/2015			**ADDING CARPENTER: Replace missing ceiling tiles in the contractor area on the 1st floor. See Jim Hill for location if needed  (**) PO REQ DK 6-10-15 Trade: Pipefitters Priority: Medium Please repair leak in hydronic piping. Leak is from a cir
FO-335748	12/28/2015	12/29/2015		Repair door lockset on double doors to storage room located between the boiler rom and the N/E end of the pool at Mathaei. The lockset is very loose.
FO-335767	12/29/2015			CARPENTERS TO REPAIR CORNER END CAP 2ND FLOOR ACROOS FROM PIPE SHOP
FO-335780	12/30/2015			CARPENTER TO REPAIR DOOR 0612-02-2 VESTIBULE DOOR IS RUBBING RESTRICTING THE DOOR
FO-335785	12/30/2015			Repair shelf and bracket in Pipe Shop. See John Towle
<b>T - Electrician</b>				<b>76</b>
FO-333731	12/1/2015			time to enter tma for december

WO	Recieved	Finished	Total	Request
FO-333732	12/1/2015			team leader administrative time for Dec.
FO-333757	12/1/2015	12/3/2015		Room 123 has 1 electrical problem.
FO-333758	12/1/2015	12/3/2015		The conference room has an electrical problem. Enter thru room 123.
FO-333759	12/1/2015			Hallway outside of room 121. The 2 18w compact 2 pin fluorescent bulbs will not go up into the fixture because there is no back end inside of the fixture. Enter thru room 123.
FO-333779	12/1/2015			In the stairwell behind the guard's desk none of the lights are working at all. Please check the circuit.
FO-333951	12/1/2015	12/15/2015		3 LO - Cashier's Office, room 217
FO-333991	12/1/2015			repair and rebuild clocks throughout university Dec.
FO-334092	12/2/2015			3rd floor - Men's R/R - 2 LO
FO-334104	12/2/2015			2 EP - men's R/R
FO-334108	12/2/2015			1 EP - outside of 209 - Second Request
FO-334113	12/3/2015	12/3/2015		safety meeting (safety is everybody's job)
FO-334153	12/3/2015	12/9/2015		The hallway outside of room 1373 has 1 electrical problem.
FO-334155	12/3/2015	12/8/2015		The hallway across from room 2403 has 1 electrical problem.
FO-334156	12/3/2015	12/8/2015		Overhead light across from room 1209 has 1 electrical problem.
FO-334158	12/3/2015	12/10/2015		The hallway between room 133 and the stairwell facing Cass Avenue.
FO-334160	12/3/2015	12/17/2015		The hallway between room 245 and the stairwell facing Cass Avenue.
FO-334237	12/4/2015			Lights bulbs are out and need replacing.
FO-334258	12/5/2015			Send the A team to correct problem with the indicator lights serving the paint boot supply and exhaust fans. There are two indicator lights, one is supposed to indicate that the supply fan is in operation, and the other indicates that the exhaust fan is i
FO-334276	12/7/2015			The passenger elevator has 1 electrical problem.
FO-334277	12/7/2015	12/14/2015		Stairwell landing next to room 037 has an electrical problem.
FO-334289	12/7/2015	12/10/2015		Wayne State Police - several exterior lights burned out around the building.
FO-334337	12/7/2015	12/9/2015		Clock has stopped working.
FO-334338	12/7/2015	12/9/2015		Clock on wall has stopped working
FO-334398	12/8/2015	12/14/2015		Reset Three clocks: Room 1301 (office); 1303 (TV Studio); 1307 (Control Room).
FO-334415	12/8/2015			The hallway light outside of room 1604 has an electrical problem. Enter thru the student affairs office in room 1600.
FO-334416	12/8/2015			Room 3467 has an electrical problem.
FO-334418	12/8/2015			Hallway near room 3363 has an electrical problem.
FO-334422	12/8/2015			1 EP - The row is located on the 2nd floor, southwest side of the building. Between stacks 72 - 80.
FO-334423	12/8/2015			Room 48 - EP - 4 Lights out "2 inter-offices"
FO-334425	12/8/2015			Emergency - Room 326 - 4 out of 6 lights are out. Men's R/R.
FO-334435	12/8/2015			Request for Electrician: The electrical outlet on the wall facing the door got very hot after only a few minutes of use. In fact, it shows signs of heat failure. I know this happened on the other office on the opposite side of the wall last
FO-334479	12/9/2015			Room 2333 has 1 electrical problem.
FO-334487	12/9/2015			Electricians (Labor)- R/R RM 1195/MECH RM Please deliver 1) 50 bags of softener salt to boilerroom. FO-327252
FO-334489	12/9/2015			Electricians- Labor- med priority- R/R RM 1195/MECH BLR RM Please deliver 1) 1 barrel of Oxycor boiler chemical to boilerroom. FO-327252

WO	Recieved	Finished	Total	Request
FO-334498	12/9/2015			LABORER (DELIVER)(HIGH) R/R RM 00100/MECH RM DELIVER 1)1 PALLET OF WATER SOFT SALT PELLETS  FO#297963
FO-334513	12/9/2015			About 4 Lights out. Need a ladder. There is a switch not working in the room just past the front stairwell. Also see FO-332175 and FO-332212.
FO-334518	12/9/2015			LIGHT BULB REPLACED OVER DOOR #N13 ON NORTH SIDE OF BUILDING ENTERING THROUGH SIDE.
FO-334548	12/9/2015			Electrician R/R ROOF repair flood light on roof North side. Not working.
FO-334558	12/9/2015			Third floor Women's restroom. Electrical issue needs to be addressed for lights to work properly. Should be marked with tape, please repair. Thank you.
FO-334635	12/10/2015	12/10/2015		Repair bad clock in science storage room for classroom #253.
FO-334647	12/10/2015	12/14/2015		Repair bad clock in room #262.
FO-334701	12/11/2015			Trade: ElectricalPriority: MediumPlease provide two working 120v outlet at both swim pool for dolphins use.
FO-334711	12/11/2015	12/14/2015		Repair bad clock near room #269 above secretary's desk.
FO-334712	12/11/2015			BLOWN FUSE ON INVERTER RECEPTIFIER. 3RD FLOOR LOBBY NEAR PASSENGER ELEVATOR. CONTACT ENGINEER FOR MORE DETAILS.
FO-334725	12/11/2015	12/11/2015		ELECTRICIANS TO HARD WIRE STOVE CARPENTERS LUNCH ROOM
FO-334770	12/11/2015			1 EP - Men's Shower
FO-334850	12/14/2015			To electricians. R/R RM 00025/MECH RM AHU-9 for auditorium basement, the reset button will not function preventing the unit from being started. Please repair or replace.
FO-334854	12/14/2015	12/14/2015		training on gen test and load transfers
FO-334933	12/15/2015			Light crew: please replace burned out light bulbs in lower level lecture hall. priority: med.
FO-334985	12/15/2015			electrician R/R RM 2314/DLAR repair ceiling lights in animal rooms AF-14 and AF-22.
FO-334986	12/15/2015			Electrician R/R RM 2305/DLAR (AF-5)replace broken receptacle cover next to sink room AF-5
FO-335034	12/16/2015	12/16/2015		Tools ordered to replace ones that are damaged.  1-Fluke T5-1000 1-Phillips screwdriver Klein #603
FO-335063	12/16/2015	12/22/2015		Re-connect Boiler Feed Pump #1
FO-335071	12/16/2015	12/21/2015		Repair LED dusk to dawn light fixture on North side of building over Exit door behind London Luggage shop. Light does not come on at night.
FO-335075	12/16/2015	12/18/2015		CLOCK IS NOT WORKING. ROOM 3141.2
FO-335125	12/17/2015	12/17/2015		Time to attend Holiday Celebration
FO-335129	12/17/2015	12/18/2015		Trade: Laborer Priority: Medium R/R RM 00000.62/MECH-BLR RM Please deliver 6 drums total that are waiting in the stock room for this location. 1) 1-Neutramine XF-P, 2) 1-Aquaklean ODP, 3) 2-Lokor 2000M-P, and 4) 2-Halochlor C
FO-335138	12/18/2015	12/18/2015		Repair bad clock located in room #3133.
FO-335145	12/18/2015	12/21/2015		1 EP - Room 1253 - Deans office
FO-335149	12/18/2015			1 EP - 8th fl Men's R/R
FO-335156	12/18/2015	12/21/2015		UGL Elevator one ... nearest to main entrance ... has small circular ceiling light out. If any questions, ask for Marilyn at Circulation Desk.
FO-335161	12/18/2015	12/22/2015		PLEASE RESET FIRE ALARM PANEL. 1ST FLOOR (FIRE ALARM).
FO-335193	12/18/2015			In walkway from Scott Hall cafeteria. Light out, tagged electrical since 3/12/15.
FO-335195	12/18/2015	12/23/2015		Replace/repair motor on AHU #3, serves lobby area.
FO-335204	12/18/2015			Hallway across from room 321 - 2 LO

WO	Recieved	Finished	Total	Request
FO-335215	12/21/2015	12/21/2015		UGL vestibule ... between main doors and inner entrance doors ... all four recessed round ceiling lights are out (?)
FO-335239	12/21/2015			Lighting -- Priority High All lights are out in mechanical room. Bulb replacement needed
FO-335251	12/21/2015	12/21/2015		Repair bad clock on 1st floor near elevators.
FO-335543	12/22/2015			REPLACE LIGHT BULBS OUTSIDE OF 5743 WOODWARD.
FO-335667	12/22/2015			Repair light fixture added to pole light on Canfield shining on crosswalk at the entrance of Lande.
FO-335678	12/23/2015			1 EP - Outside of room 116 - The bulb has been replaced. Not lighting. Second Request.
FO-335682	12/23/2015			please have electricians check exhaust fan 63 in the penthouse this fan has stopped operating. the fan has power but the motor does not drive the fan. this operates an exhaust hood.
FO-335683	12/23/2015	12/23/2015		Please replace rusted conduit segment beneath southwest (exterior) porch.
FO-335708	12/23/2015			There is 1 EP in the hallway between gym 10 and 11 North side of bldg...
FO-335734	12/27/2015			Replace/repair pilot light on Kiln Exhaust Fan sconce switch located in room 060.5 of the Art Building. Light does not light when the fan is on.
<b>T - Locksmith</b>			<b>54</b>	
FO-333985	12/1/2015	12/3/2015		New KeyLost / StolenKey #: Core# 17B AL14Key Holder ID: Angelica ReynaQty: 3 Keysaction: This core was recently changed out but the keys were not left at the front desk. Please cut 3 keys.Account #: 228156
FO-333987	12/1/2015			Core Change Lost / Stolen Key #: Temp Cores Key Holder ID: Angelica Reyna Qty: 5 core with keys  action: Requesting 5 temp cores with keys. Next in series for DeRoy Account #: 228156
FO-334085	12/2/2015	12/9/2015		Core Change Lost / Stolen Key #: Core #AB31, Key #037059 Key Holder ID: Angelica Reyna Qty: 2 cores and 4 keys  action: one core for room, one core for mailbox, and 4 keys. ***Emergency core 11 is installed please return to front desk*** Account
FO-334037	12/2/2015	12/9/2015		KEYS & CORES ( DECEMBER 2015 )
FO-334038	12/2/2015			LOCKSHOP TRAINING ( DECEMBER 2015 )
FO-334149	12/3/2015	12/8/2015		New Key Lost / Stolen Key #: 40103 Key Holder ID: Daren Hubbard Qty: 1  action: Please provide one key for room 294. Account #: 153736
FO-334198	12/3/2015	12/8/2015		New Key New Staff Member Key #: 30375/ME Key Holder ID: College of Engineering, Dean's Office Qty: 2  action: One key is for new staff member, second key is to replace damaged key. Thank you.

WO	Recieved	Finished	Total	Request
FO-334196	12/3/2015	12/8/2015		<p>New Key New Staff Member Key #: C7 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: One key for new staff member, second key for Dean's Office. Thank you.</p>
FO-334192	12/3/2015	12/8/2015		<p>New Key New Space Assignment Key #: 31826 Key Holder ID: Dorothea Smith Qty: 1</p> <p>action: Employee was promoted to a new position and needs a new key. Account #: 165143</p>
FO-334281	12/4/2015			<p>New Key New Staff Member Key #: MCX, MJC, MB, MJB, also key for door to sector 9 custodial office at 5057 Woodward Key Holder ID: Valerie Harris Qty: 1 each action:</p>
FO-334280	12/4/2015	12/8/2015		<p>New Key New Staff Member Key #: 91889 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: Key for new staff member. Room is listed as "New Engg bldg master."</p>
FO-334279	12/4/2015	12/10/2015		<p>New Key New Staff Member Key #: Please see notes Key Holder ID: Kelly Cowser - New employee Qty: one of each</p> <p>action: Need different keys please. One of each. 89659 90514-1 12074</p>
FO-334317	12/7/2015	12/10/2015		<p>Core Change Lost / Stolen Key #: core: 17AAC.2 key #: 33934 Key Holder ID: Donnella Johnson Qty: 2 cores and 3 keys</p> <p>action: 1 room core, 1 mailbox core, and 3 keys Account #: 228200</p>
FO-334318	12/7/2015	12/9/2015		<p>Core Change Lost / Stolen Key #: core: 17AAC50, key #: 33982 Key Holder ID: Donnella Johnson Qty: 2 cores and 3 keys</p> <p>action: 1 mailbox core, 1 room core and 3 keys. PLEASE RETURN TEMP CORE TO FRONT DESK Account #: 228200</p>



WO	Recieved	Finished	Total	Request
FO-334319	12/7/2015			<p>New Key Lost / Stolen Key #: key core: 17AAB31, key: 33898 Key Holder ID: Donnella Johnson Qty: 2 cores and 3 keys</p> <p>action: 1 room core, 1 mailbox core, and 3 keys Account #: 228200</p>
FO-334321	12/7/2015	12/8/2015		<p>Core Change Lost / Stolen Key #: Key core: 17AAB5, key #: 33872 Key Holder ID: Donnella Johnson Qty: 2 cores and 3 keys</p> <p>action: 1 room core, 1 mailbox core, and 3 keys Account #: 228200</p>
FO-334388	12/7/2015			<p>New Key Damaged Key #: nsr 251 Key Holder ID: T. Mitchell Qty: 3 action: call tom Mitchell when ready p 313-684-5541</p>
FO-334444	12/8/2015	12/22/2015		<p>New Key New Staff Member Key #: 92164/A2 17 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: For ROOM 1163 (not an option under Area), key# 92164 core# A2 17, Engineering Business Office. One key is for myself, other k</p>
FO-334436	12/8/2015			<p>Replace Building Master in lock box. Access key is 89806.149 from design services.</p>
FO-334445	12/8/2015	12/22/2015		<p>New Key New Staff Member Key #: 20596 Key Holder ID: Lynnetta R Smith Qty: 3</p> <p>action: Need new keys for new faculty</p>
FO-334446	12/8/2015	12/22/2015		<p>New Key Lost / Stolen Key #: 20731 Key Holder ID: Lynnetta R Smith Qty: 5</p> <p>action: Need to replace keys</p>
FO-334447	12/8/2015	12/22/2015		<p>New Key New Staff Member Key #: 7930 Key Holder ID: Peijun Wang Qty: 1</p> <p>action: please cc April Wolak on the email awola@med.wayne.edu when the key is ready.</p>
FO-334490	12/9/2015	12/22/2015		<p>New Key New Space Assignment Key #: 64668 Key Holder ID: Paul Bishop Qty: 20</p> <p>action: Keys for new faculty workroom, room 2320, Old Main.</p>

WO	Recieved	Finished	Total	Request
FO-334589	12/10/2015	12/24/2015		<p>New Key New Staff Member Key #: 90373 &amp; FG.1 Key Holder ID: Anthony Carinci, CAPS Qty: 7 - 90373; 10 - FG.1</p> <p>action: CAPS on the 5th floor is adding additional staff and require more keys to the offices in their suite. They also requested ad</p>
FO-334634	12/10/2015	12/24/2015		<p>New Key New Space Assignment Key #: 13205 Key Holder ID: Mirabela Hali Qty: 1</p> <p>action: To be picked up by med school courier. (ok'd by Dr. Walz)</p>
FO-334637	12/10/2015	12/24/2015		<p>New Key New Staff Member Key #: G43 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: For room 1310. New request. Thank you.</p>
FO-334688	12/10/2015	12/24/2015		<p>Replacement New Staff Member Key #: 106E Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: Key for desk in front office/reception area of Dean's Office suites, new staff member.</p>
FO-334758	12/11/2015	12/21/2015		<p>New Key New Staff Member Key #: see request Key Holder ID: Thomas Edwards Qty: seven</p> <p>action: 14D1,X292,1A1A1X,X287,X2791, 61001-2,25296 Need by Dec.14,15</p>
FO-334831	12/11/2015	12/24/2015		<p>New Key New Space Assignment Key #: 72692 Room 3061 &amp; 2 keys for Room 3143 Key Holder ID: Dr. Stanley Shaprio &amp; Rob Pfaff Qty: 4</p> <p>action: Marilyn Vaughan Room 3094, History Dept. Account #: 125621</p>
FO-334834	12/14/2015			<p>Secondary door 4004 (see map attached) to conference room 4002 was re cored incorrectly. It should match room 4002 with core mark 11LA10-22. Please provide 3-Keys. This references FO-334112</p>
FO-334924	12/14/2015			<p>New Key Damaged Key #: 2628 Key Holder ID: Tiana Fluker Qty: 1 action: This is a sub-master key for the department (I didn't see an option for this in the "Area" category), we would like a replacement as soon as possible. Account #: 125861</p>

WO	Recieved	Finished	Total	Request
FO-334934	12/14/2015	12/24/2015		<p>New Key New Space Assignment Key #: Y14B Best Key Holder ID: Jonathan Keys, Orlandis McClain, Peter Belcher, Walter Miller Qty: 4</p> <p>action: Request 4 keys for Building Engineers(J.Keys O.McClain P.Belcher W. Miller) Janitorial Closets have shutof</p>
FO-334925	12/14/2015			<p>New KeyNew Staff MemberKey #: 27711Key Holder ID: Jill-Morgan AubertQty: 3action: We need interior office keys for new staff. Thank you.Account #: 113231</p>
FO-334976	12/15/2015			<p>New KeyNew Space AssignmentKey #: 11LA1017Key Holder ID: Lea R. MadjoffQty: 4action: Need KeysAccount #: 165221</p>
FO-334983	12/15/2015			<p>New KeyLost / StolenKey #: 22471Key Holder ID: Lea Thomas, Sausha KelloggQty: 2action: Lost key in locked office. Need two new keys for Business Manager and Membership Manager.Account #: 227845</p>
FO-334984	12/15/2015			<p>New KeyNew Staff MemberKey #: 71042 next availableKey Holder ID: Lynette RaeQty: 6action: New students joining the lab</p>
FO-335003	12/15/2015			<p>New KeyNew Staff MemberKey #: key 25305, core 14A22Key Holder ID: Jon BarthQty: 1 keyaction: Requesting second key for my office. Additional occupant due to the SCB 5th Floor renovation Account #: 228156</p>
FO-335002	12/15/2015			<p>Core Change Lost / Stolen Key #: 16AE4 Key Holder ID: Angelica Reyna Qty: 1 core and 3 keys</p> <p>action: 1 new core and 3 new keys. ***temp core installed please return to front desk Account #: 228167</p>
FO-335001	12/15/2015			<p>New KeyDamagedKey #: key 110645-3Key Holder ID: Angelica ReynaQty: 1 keyaction: cut 1 new keyAccount #: 228156</p>
FO-335000	12/15/2015	12/21/2015		<p>New Key Damaged Key #: key# is 037024 and core# is AF12 Key Holder ID: Angelica Reyna Qty: 1 key</p> <p>action: cut 1 key Account #: 228156</p>
FO-334999	12/15/2015			<p>New KeyDamagedKey #: Key #37183, Core #AD25Key Holder ID: Angelica ReynaQty: 1 Keyaction: cut 1 keyAccount #: 228156</p>
FO-334998	12/15/2015			<p>Core Change Lost / Stolen Key #: Temp Cores Key Holder ID: Donnella Johnson Qty: 5 temp cores with keys</p> <p>action: requesting 5 temp cores with keys, next in series for Ghafari Account #: 228200</p>
FO-334997	12/15/2015			<p>New KeyNew Space AssignmentKey #: Key 73927Key Holder ID: Jason DavisQty: 1action: 1 key for suite entrance (corridor 194 A/B), rooms 189, 190, 191, 192, 193, 195, 196, 197, 198, and 199.Account #: N/A</p>
FO-335037	12/16/2015			<p>ReplacementNew Staff MemberKey #: n-19Key Holder ID: William JohnsonQty: 2action: Key for filing cabinet.</p>
FO-335097	12/16/2015			<p>New KeyLost / StolenKey #: 101209Key Holder ID: Mustafa ZiyadQty: 1action: Key was accidentally thrown in trash at home.Account #: 137642</p>
FO-335100	12/16/2015			<p>New KeyNew Staff MemberKey #: 36668Key Holder ID: Cierra PamplinQty: 1action: Master key needed for new staff member</p>
FO-335101	12/17/2015			<p>New KeyNew Space AssignmentKey #: 4FA10Key Holder ID: Mike SUnderlikQty: 1action: Key for Gardiner Vose Contracting for their work in WDET</p>
FO-335095	12/17/2015			<p>New KeyLost / StolenKey #: 40857Key Holder ID: Confucius InstituteQty: 2action: I am not sure of the "area", but it would be the east side of the 11th floor in Confucius Institute section. I also have quite a few keys that don't have a home that I</p>

WO	Recieved	Finished	Total	Request
FO-335135	12/17/2015	12/21/2015		New Key Damaged Key #: X292 Key Holder ID: Anthony Carinci, Student Center Admin Qty: 1  action: Our office X292 key broke and we would like to order a replacement. We were able to get the broken piece out of the core, we just need a key.
FO-335188	12/18/2015			New KeyDamagedKey #: 7892Key Holder ID: Kathy Baklarz, DLAR Leader at Scott HallQty: 6action: Please provide more keys to the animal rooms at Scott Hall for DLAR employees. Many of their keys are damaged and will be returned to key shop for recycl
FO-335220	12/21/2015			New KeyLost / StolenKey #: 101209Key Holder ID: Mustafa ZiyadQty: 1action: Key was accidentally thrown in trash at home.Account #: 137642
FO-335540	12/21/2015			New KeyLost / StolenKey #: MS2 (qty: 2) also need MSB 5743 Woodward front door (MB)Key Holder ID: Diane SevignyQty: 2action: 2 each office key, MS21 each main building woodward door, MSBfor new Associate DirectorAccount #: 163781
FO-335465	12/21/2015			New KeyNew Staff MemberKey #: Key #63204 Core #RA 1X Key Holder ID: Theresa Y. Hill Qty: 4action: Please duplicate 4 keys. This a main suite door. Thank you!Account #: 146601
FO-335759	12/29/2015			Repair and replace all lock shop code books
<b>T - Painter</b>			<b>29</b>	
FO-333738	12/1/2015			Prep, Scrape - Prime an Paint Windows, Walls, Doors & Jambs in Green House.
FO-333741	12/1/2015			Prep-Scrape, Prime & Paint General Purpose Classrooms, Basement, First Floor.
FO-333743	12/1/2015			CLEAN & PAINT OVER GRAFFITTI, ENTIRE CAMPUS FOR MONTH OF DECEMBER.
FO-333749	12/1/2015			R/R RM 150 NEED 2 BOXES OF COPY PAPER
FO-333990	12/1/2015			HANDY MAN TIME ( DECEMBER 2015 )
FO-334015	12/2/2015			Patch - Prime & Paint Entryway walls.
FO-334103	12/2/2015			PAINTERS TO MUDD & PAINT DRYWALL PATCHES 2ND FLOOR & 3RD FLOOR LOCATIONS ( SEE STEPHEN THE CARPENTER FOR LOCATIONS )
FO-334107	12/2/2015			Please have Handyman take recycle containers to recycle yard. See Larry Cook/Lynda Kinder.
FO-334123	12/3/2015	12/3/2015		Men's Bathroom, 1st Floor, Clean & Paint over Graffiti in stalls.
FO-334178	12/3/2015	12/4/2015		SAFTEY TIME FOR THE MONTH OF DECEMBER.
FO-334252	12/4/2015	12/22/2015		Rm. 440--4th flr Men's Restroom. Please remove graffiti. 1st stall written in pencil  POLICE REPORT #W153380041
FO-334428	12/7/2015			Patch hole in the wall
FO-334386	12/8/2015	12/21/2015		Repair, Prime & Paint to finish all walls in north west Corridor, 1st Floor.
FO-334387	12/8/2015	12/14/2015		PAINTERS TO TOUCH UP ENTIRE BUILDING FOR COMMENCEMENTS
FO-334463	12/8/2015	12/10/2015		Repair Plaster, Around Entry Doors. Prime & Paint to finish.
FO-334473	12/9/2015	12/14/2015		Machine Sand floor 2,500 sq.' 4th floor Greenhouse.
FO-334524	12/9/2015	12/23/2015		Drywall needs to be patched/painted inside floor 2 (public area) Barrett Lounge.
FO-334550	12/9/2015			Painter,please paint wall next to 1311 door, to mechanical pipe chase,across from 1313 Data rm. wall is blistering dark brown solution on wall,FO-334529 priority High.
FO-334554	12/9/2015			PAINTERS TO MUDD & PAINT CEILNG DRYWALL REPAIRS GIRLS BATHROOM ONLY OPEN TO THE TRADES 7:00 AM TILL 1:00PM
FO-334656	12/10/2015			**ADDING PAINTERS: Seal floor around floor drain located at south west interior door . See Troy Taylor for detail  PLUMBING DEPT-PLEASE CHECK LEAK IN SOUTHWEST INTERIOR ENTRANCE ,BY DOOR 150 07 W,PRIORITY HIGH CEILING LEAK ,,,,,,,,,,,,,, TT/12
FO-334764	12/11/2015	12/15/2015		Plaster repair, Prime an Paint to finish, entryway to stage in basement.

WO	Recieved	Finished	Total	Request
FO-334842	12/14/2015	12/15/2015		PAINTERS TO POWER WASH ENTIRE RAMP TOP TO 1ST FLOOR TUESDAY 12/15/15
FO-334926	12/15/2015			PAINTERS,PLEASE PATCH/PAINT DAMAGED WALLS IN STAIRWELL-G , BSMT AREA.PRIORITY-LOW
FO-335194	12/18/2015	12/22/2015		Graffiti (ethnic slur) found written in UGL Study Carrel #M7 near to front in Extended Study Area. Police Officers provided Incident Report #W15-3570038. See either Marilyn W. or Matt W. at Circulation Desk if questions. (Per Police Officer, may re
FO-335758	12/29/2015			Prime... Floors in Greenhouse on 4th floor.
FO-335766	12/29/2015			PAINTERS TO MUD & PAINT DRYWALL PATCHES FROM WATER PIPE LEAKS, ROOM # 144
FO-335771	12/29/2015			First floor dressing room. Repair holes in wall/Plaster.
FO-335773	12/29/2015			Repair Plaster in vestibule at back Door first floor.
FO-335775	12/30/2015			PAINTERS TO PAINT CORNER WRAP SAFETY YELLOW & STRIPE.
<b>T - Pipefitter</b>			<b>41</b>	
FO-334010	12/1/2015	12/1/2015		processing time for paperwork, e-mails,phone calls, etc....CB.....12-1-15
FO-334011	12/1/2015	12/1/2015		work on facilitating emergency abatement job.....CB....12-1-15
FO-334067	12/2/2015	12/4/2015		FITTERS, PLEASE INSTALL TEE FITTINGS ON COPPER DRAIN LINES FOR OAHU#3 & 4 . PRIORITY-LOW ,,,,,,,,,,,,,, ME/12-2-15 ,,,,,,,,,,,,,,
FO-334087	12/2/2015	12/2/2015		facilitate emergency abatement job 3rd floor hallway.....CB...12-2-15
FO-334090	12/2/2015	12/2/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....12-2-15
FO-334188	12/3/2015	12/3/2015		processing time for paperwork, e-mails,phone calls, etc....CB....12-3-15
FO-334190	12/4/2015	12/3/2015		Safety meeting
FO-334271	12/6/2015	12/7/2015		Repair source of condensate leaking from the radiator in room 060.5 at the Art building and is seen on the cement patio area of the McGregor Pond. ,,,,,,,,,,,,,, JH/12-7-15 ,,,,,,,,,,,,,,
FO-334393	12/8/2015			please insulated pipe in SE corner of office. Please insulate entire length of pipe. thanks. ,,,,,,,,,,,,, CB/12-8-15 ,,,,,,,,,,,,,,
FO-334438	12/8/2015	12/8/2015		Check and repair as needed: Domestic hot water too hot, Please check heat exchanger steam controls ,,,,,,,,,,,,,, ME/12/8/15 ,,,,,,,,,,,,,,
FO-334452	12/8/2015	12/8/2015		gain access, start set up, and supervise insulation job in women's basketball locker room....CB....12-8-15
FO-334453	12/8/2015	12/8/2015		gain access to, start set up, and supervise insulation job.....CB....12-8-15
FO-334454	12/8/2015	12/8/2015		processing time for paperwork, e-mails, phone calls, etc....CB....12-8-15
FO-334491	12/9/2015	12/10/2015		R/R radiator valve 3rd floor ,,,,,,,,,,,,,, JH/12-9-15 ,,,,,,,,,,,,,,
FO-334564	12/9/2015	12/9/2015		gain acces, facilitate start up, and supervise 3 different abatement jobs....CB....12-9-15
FO-334566	12/9/2015	12/9/2015		processing time for paperwork, e-mails,phone calls, etc....CB...12-9-15
FO-334685	12/10/2015	12/10/2015		facilitate, supervise, and help start up for 3 abatement jobs.....CB....12-10-15
FO-334686	12/10/2015	12/10/2015		meet Dave K and contractor for walk through on asbestos quote.....
FO-334687	12/10/2015	12/10/2015		processing time for paperwork, e-mails, phone calls, etc....CB....12-10-15
FO-334633	12/10/2015	12/10/2015		Relocate material in shop. See John for detail ,,,,,,,,,,,,,, ME/12-10-15 ,,,,,,,,,,,,,,
FO-334654	12/10/2015			Tools for Marty Elwart Pipe Shop ,,,,,,,,,,,,,, ME/ 12-10-15 ,,,,,,,,,,,,,,
FO-334759	12/11/2015	12/11/2015		processing time for paperwork, e-mails, phone calls, etc....CB....12-11-15
FO-334800	12/13/2015	12/22/2015		(**) PO REQ DK 12/16 Replace faulty relief valve located on boiler #2 at Education. The second relief valve form the boiler is not seating and dripping at only 18 psi on the system. 3/4 x 1 NPT, Set 50 psi, 1,391,000 BTUH  (Note: This problem is occu
FO-334801	12/13/2015	12/22/2015		Replace faulty relief valve located on boiler #4 at Education. The second relief valve form the boiler is not seating and dripping at only 18 psi on the system.  (Note: This problem is occurring on two boilers, #2 and #4.) ,,,,,,,,,,,,,, EA/12-14-1
FO-334904	12/14/2015	12/14/2015		processing time for paperwork, e-mails, phone calls, etc....CB....12-14-15
FO-334935	12/15/2015	12/18/2015		Pipe fitters: Please install a drain valve at bottom of the steam riser to west side radiators: priority: low. ,,,,,,,,,,,,,, ME/12-15-15 ,,,,,,,,,,,,,,
FO-334980	12/15/2015	12/15/2015		processing time for paperwork, e-mails, phone calls, etc....CB....12-15-15

WO	Recieved	Finished	Total	Request
FO-334981	12/15/2015	12/15/2015		2 separate sight visits, one in the morning with OEHS department, and in the afternoon with contractor for an abatement/scaffold walk through....CB....12-15-15
FO-335167	12/17/2015	12/17/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....12-17-15
FO-335175	12/17/2015	12/17/2015		general shop clean-up and --organization of parts.....CB....12-17-15
FO-335146	12/18/2015	12/21/2015		Trade: Pipe Fitter Priority: Low Install new water softener head on boiler make up water softener. .... RC/12-21-15 .....
FO-335676	12/23/2015			Please repair the HVAC unit , the water supply line ( Braided) is leaking down into the Lab, water has been shut off both supply and returned to this unit so repairs can be made.
FO-335674	12/23/2015			insulate the steam line that goes through the 1st floor unisex bathroom directly across from the back stairs at Beecher House. The steam line is in the SW corner of the lav. Please cover. Room overheats. creates security issue b/c window gets left open. ,
FO-335723	12/23/2015	12/23/2015		processing time for paperwork for up-coming abatement jobs....
FO-335684	12/23/2015			Pipe fitters: please repair water leak on boiler #1 sample line just before the manifold. Priority: low..... ME/12/24/15 .....
FO-335769	12/29/2015			help abatement contractor set up gain access and supervise job....CB....12-29-15
FO-335770	12/29/2015			processing time for paperwork, e-mails, phone calls, etc....CB...12-29-15
FO-335772	12/29/2015			emergency parts run to Macomb for shut down job for Plumbers....CB....9-29-15
FO-335776	12/30/2015			The steam trap serving the heating coil on AHU-7 in Mechanical Rom 25 at Community Arts has a bad cover seal gasket and is blowing steam..... JH/12/30/15 .....
FO-335783	12/30/2015			provide access, help set up, and supervise abatement job...CB....12-30-15
FO-335784	12/30/2015			processing time for paperwork, e-mails, phone calls, etc....CB...12-30-15
<b>T - Plumber</b>			<b>39</b>	
FO-333740	12/1/2015			Administrative Time for DEC 2015
FO-334168	12/3/2015	12/7/2015		R/R RM 00051/Women's restroom toilet is clogged and it won't flush (it's been plunged several times, a bag has been placed over the toilet). .... TT/12-3-15 .....
FO-334171	12/3/2015	12/4/2015		1st floor mens room repair leaking faucet ..... MM/12-3-15 .....
FO-334189	12/4/2015	12/8/2015		2nd floor men's restroom in the back by freight elevator 1st stall won't flush. .... TT/12-4-15 .....
FO-334197	12/4/2015	12/7/2015		Trade: Plumber Priority: Low The back flow preventer is leaking on the fire pump water line in basement mechanical room of EDC. .... DB/12-4-15 .....
FO-334298	12/7/2015	12/10/2015		Mens Bathroom in suite 206, there is a problem with the urinal ..... MM/12-8-15 .....
FO-334336	12/7/2015	12/11/2015		Women's restroom (near Circulation desk) 1st flr Purdy ..... GS/12-7-15 .....
				Replace two toilet flush valves for women's toilet.
				See Jerry
FO-334385	12/8/2015	12/8/2015		Men's restroom (east side of elevator, only 1 restroom) 4th floor, water not going down in the first sink. .... TT/12-8-15 .....
FO-334475	12/8/2015	12/11/2015		R/R RM 327/Women's Restroom, problem with the sink furthest to the right. It appears battery on sink faucet needs to be replaced, no water will come out of sink FAUCET. .... MM/12-9-15 .....
FO-334476	12/9/2015	12/11/2015		R/R RM 326/Men's Restroom middle urinal has problem with the drain ..... MM/12-9-15 .....
FO-334493	12/9/2015	12/9/2015		R/R running shower in room 154.1 ..... DB/12-9-15 .....
FO-334523	12/9/2015	12/10/2015		Plumber, Low, Clear slow drain on left drinking fountain near elevators 4th floor. .... TT/12/10/15 .....
FO-334537	12/9/2015	12/9/2015		Turn water on to outside water spicket on west side of bld. Turn off at end of the day 12/9/15 ..... TT/ 12-9-15 .....
FO-334659	12/10/2015	12/18/2015		Replace 3 urinal flush valves in men's locker room ..... DB/12-10-15 .....
FO-334669	12/10/2015	12/15/2015		R/R RM 5333 The water faucets are not able to be shut off completely, and are dripping pretty badly. (observed while removing chemicals from the room) ..... MM/12-14-15 .....

WO	Recieved	Finished	Total	Request
FO-334713	12/11/2015	12/14/2015		Men's restroom Rm 240--Repair leak under sink. .... GS/12-14-15 .....
FO-334733	12/11/2015	12/15/2015		The first stall in the women's restroom #140 on the first floor of Purdy Library is not flushing..... GS/12-14-15 .....
FO-334792	12/11/2015			Replace leaking gasket on urinal 1st floor ..... MM/12-14-15 .....
FO-334798	12/13/2015			Restore water supply to custodial slop sink located in room 018 at Shapiro Hall. There is no water at the faucet and the drain trap dries out allowing sewer gasses to escape. Contact Custodial Supervisor Mayor Steve at 313-399-3341 for access to the room
FO-334893	12/14/2015			Plumbers: Med Priority. Location: PH W. side. R/R PH W Please provide and install slop sink, water connections and drain. Please see Jim for possible solutions. Loretta Small(12/14/2015 08:17)-- 12/14/15 lps: Per Dave K hold. Need to go to AD 12/1
FO-334894	12/14/2015			Plumbers: Med Priority. R/R Location: PH center Please install water hose connection in center of PH..... TT/ 12-15-15 .....
FO-334833	12/14/2015	12/15/2015		1st floor Men's bathroom in the EDC area has a plugged toilet and another one does not work. Thank you. .... TT / 12/14/15 .....
FO-334932	12/15/2015	12/14/2015		PLUMBER ORIENTATION
FO-334936	12/15/2015			To plumbers. Replace defective hot water circulation pump for Art in rm. 23 above door. ..... GS/12-15-15 .....
FO-334970	12/15/2015	12/15/2015		Clear floor drains on ramp so power washing can continue ..... DB/12-15-15 .....
FO-335050	12/16/2015			Transport new booster pumps Redman bought from Holden to Scoot Hall room 100 Also install these 4 pumps ..... DB/12-16-15 .....
FO-335107	12/17/2015	12/17/2015		4th floor Purdy Women's restroom:  1st stall toilet seat needs to be replaced. .... T%T/12-17-15 .....
FO-335245	12/21/2015	12/21/2015		EMERGENCY PLUM R/R BSMT IS FLOODED ..... GS/12-21-15 .....
FO-335248	12/21/2015	12/21/2015		**DUPLICATE WORK ORDER / REFER TO FO#334760 JWT  Lab 1330 water outlet blocked due to damage of outlet pipe. Blocking work was done and assured that it would be reopened in 24 hours, however, job is still incomplete. Please have someone resolve this iss
FO-335545	12/22/2015			PLUGGED SINK. 3RD FLOOR CUSTODIAL CLOSET. .... TT/12-30-15 .....
FO-335641	12/22/2015	12/23/2015		R/R 1ST FLR HALLWAY VENDING MACHINE AREA DRINKING FOUNT W/BOTTLE WTR DISPENSOR NEEDS A NEW FILTER (RED LITE IS ON) ..... DB/12-23-15 .....
FO-335658	12/22/2015			WATER DISPENSER IS NOT WORKING. HALLWAY NEAR ROOM 0109..... DB/12-23-15 .....
FO-335668	12/22/2015			WATER IS NOT FILLING UP IN TOILET. ROOM 112. .... GS/12-30-15 .....
FO-335739	12/28/2015			2- Drains are plugged in Greenhouse on 4rd floor ..... TT/12-28-15 .....
FO-335740	12/28/2015			Set up temporary sump for condensate pit in mechanical room 25 for Jim Hill ..... DB/12/28/15 .....
FO-335746	12/28/2015			Replacement heads for all 5 Plumbers snakes ..... DB/12/28/15 .....
FO-335779	12/30/2015			Ceiling leak basement mens room ..... DB/12-30-15 .....
FO-335781	12/30/2015			Replace gate valves in water meter room and provide future tie in for back feed water supply to Comm Arts ..... DB/12-30-15 .....
FO-335782	12/30/2015			Evaluate domestic back feed water supply from mechanical room 047 to Music that will ultimately provide a dedicated water supply for Presidents apartment ..... DB/12-30-15 .....
<b>T - Roofing</b>				<b>1</b>
FO-335558	12/22/2015			R/R ROOF Prevent water penetration from the roof and repair drywall in ceiling and walls in North east Freer House rooms 116.1, 218, 222 **PLEASE SEE RESULTS**Loretta Small(12/22/2015 10:44)-- 12/22/15 lps: I spoke w/Rose she says water is still coming
<b>Routine</b>				<b>7</b>
<b>T - Electrician</b>				<b>7</b>
FO-334023	12/1/2015			PS#1 ROUTINE CHECK 12/1 THRU 12/31/15

WO	Recieved	Finished	Total	Request
FO-334025	12/1/2015			PS#2 ROUTINE CHECK 12/1 THRU 12/31/15
FO-334026	12/1/2015			PS#3 ROUTINE CHECK 12/1 THRU 12/31/15
FO-334027	12/1/2015			PS#4 ROUTINE CHECK 12/1 THRU 12/31/15
FO-334028	12/1/2015			PS#5 ROUTINE CHECK 12/1 THRU 12/31/15
FO-334029	12/1/2015			PS#6 ROUTINE CHECK 12/1 THRU 12/31/15
FO-334030	12/1/2015			VARIOUS CAMPUS LOTS ROUTINE CHECK 12/1 THRU 12/31/15

## Scheduled Maint. (PM)

441

### Engineering

394

#### Routine

394

#### E - Auxiliary

21

FO-332830	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332831	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332842	12/1/2015		PM - Fan Coil/HV/AC Unit
FO-332856	12/1/2015	12/2/2015	PM - Monthly Fire Alarm/Fire Protection System Test
FO-332857	12/1/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-332858	12/1/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-332859	12/1/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-332860	12/1/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333401	12/7/2015		PM - Emergency Shower/Eyewash Station
FO-333400	12/8/2015		Generator Maintenance, Monthly
FO-333718	12/9/2015		Generator Maintenance, Monthly
FO-333722	12/14/2015		PM - Emergency Shower/Eyewash Station
FO-334379	12/16/2015		Generator Maintenance, Monthly
FO-334380	12/21/2015		PM - Emergency Shower/Eyewash Station
FO-334369	12/22/2015	12/22/2015	Generator Maintenance, Monthly
FO-334371	12/22/2015	12/22/2015	Generator Maintenance, Monthly
FO-334373	12/22/2015	12/22/2015	Generator Maintenance, Monthly
FO-334375	12/22/2015	12/22/2015	Generator Maintenance, Monthly
FO-334377	12/22/2015	12/22/2015	Generator Maintenance, Monthly
FO-334381	12/22/2015		Housing Fog Treatment
FO-334916	12/28/2015		PM - Emergency Shower/Eyewash Station

#### E - MedPharm

27

FO-331535	12/1/2015		Generator Maintenance, Monthly
FO-332673	12/1/2015		PM - Heat Exchanger and Economizer
FO-332674	12/1/2015		PM - Heat Exchanger and Economizer
FO-332675	12/1/2015		PM - Heat Exchanger and Economizer
FO-332677	12/1/2015		PM - Heat Exchanger and Economizer
FO-332678	12/1/2015	12/10/2015	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332679	12/1/2015	11/30/2015	PM - Fan Coil/HV/AC Unit
FO-332680	12/1/2015	12/2/2015	PM - Fan Coil/HV/AC Unit
FO-332681	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332682	12/1/2015		PM - Reverse Osmosis Water Softener System
FO-332683	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332684	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332685	12/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332686	12/1/2015		PM - Heat Exchanger and Economizer



WO	Recieved	Finished	Total	Request
FO-332687	12/1/2015	12/14/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332688	12/1/2015			PM - Water Softener
FO-332689	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332690	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332691	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332692	12/1/2015			Replace PRE-filters
FO-333387	12/8/2015			Generator Maintenance, Monthly
FO-333388	12/8/2015			Generator Maintenance, Monthly
FO-333703	12/15/2015			Generator Maintenance, Monthly
FO-334352	12/22/2015	12/22/2015		Generator Maintenance, Monthly
FO-334353	12/22/2015			Generator Maintenance, Monthly
FO-334910	12/23/2015			PM - Absorption Unit
FO-334911	12/23/2015			PM - Absorption Unit
<b>E - North</b>			<b>37</b>	
FO-332693	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332694	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332695	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332696	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332697	12/1/2015	12/8/2015		PM - Heat Exchanger and Economizer
FO-332698	12/1/2015	12/8/2015		PM - Heat Exchanger and Economizer
FO-332699	12/1/2015	12/21/2015		PM - Heat Exchanger and Economizer
FO-332700	12/1/2015	12/21/2015		PM - Heat Exchanger and Economizer
FO-332701	12/1/2015	12/21/2015		PM - Heat Exchanger and Economizer
FO-332702	12/1/2015	12/21/2015		PM - Heat Exchanger and Economizer
FO-332703	12/1/2015	12/17/2015		PM - Heat Exchanger and Economizer
FO-332704	12/1/2015	12/17/2015		PM - Heat Exchanger and Economizer
FO-332705	12/1/2015	12/8/2015		PM - Domestic Water Heater, Steam
FO-332706	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332707	12/1/2015	12/8/2015		PM - Heat Exchanger and Economizer
FO-332708	12/1/2015	12/9/2015		PM - Heat Exchanger and Economizer
FO-332709	12/1/2015	12/9/2015		PM - Heat Exchanger and Economizer
FO-332710	12/1/2015	12/9/2015		PM - Heat Exchanger and Economizer
FO-332711	12/1/2015	12/9/2015		PM - Heat Exchanger and Economizer
FO-332712	12/1/2015	12/8/2015		PM - Heat Exchanger and Economizer
FO-332713	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332714	12/1/2015	12/15/2015		PM - Heat Exchanger and Economizer
FO-332715	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332716	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332717	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332718	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332719	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332720	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

WO	Recieved	Finished	Total	Request
FO-332721	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332722	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332723	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332724	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332725	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332726	12/1/2015	12/2/2015		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-334407	12/8/2015	12/22/2015		AHU-2 Replace PRE-filters
FO-333704	12/11/2015	12/11/2015		Generator Maintenance, Monthly
FO-334912	12/23/2015			Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>16</b>	
FO-332727	12/1/2015			PM - Heat Exchanger and Economizer
FO-332728	12/1/2015			PM - Heat Exchanger and Economizer
FO-332729	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332730	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332731	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332732	12/1/2015	12/1/2015		PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled) Chillers
FO-332733	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-333389	12/4/2015			Generator Maintenance, Monthly
FO-333390	12/4/2015			Generator Maintenance, Monthly
FO-333391	12/4/2015			Generator Maintenance, Monthly
FO-333392	12/4/2015			Generator Maintenance, Monthly
FO-333705	12/15/2015			Generator Maintenance, Monthly
FO-334354	12/17/2015			Generator Maintenance, Monthly
FO-334355	12/22/2015	12/22/2015		Generator Maintenance, Monthly
FO-334356	12/22/2015	12/22/2015		Generator Maintenance, Monthly
FO-334913	12/23/2015	12/22/2015		Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>148</b>	
FO-331642	12/1/2015	12/15/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-331643	12/1/2015	12/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331644	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331645	12/1/2015	12/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331646	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331647	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331648	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331649	12/1/2015	12/2/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331650	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331651	12/1/2015	12/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331652	12/1/2015	12/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331653	12/1/2015	12/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331654	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-331655	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331656	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331657	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331658	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331659	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331660	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331661	12/1/2015	12/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331662	12/1/2015	12/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331663	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331664	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331665	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331666	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331667	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331668	12/1/2015	12/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331669	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331670	12/1/2015	12/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331671	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331672	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331673	12/1/2015	12/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331674	12/1/2015	12/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331675	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331676	12/1/2015	12/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331677	12/1/2015	12/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331678	12/1/2015	10/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331679	12/1/2015	12/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331680	12/1/2015	12/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331681	12/1/2015	12/2/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331682	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331683	12/1/2015	12/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331684	12/1/2015	12/2/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331685	12/1/2015	12/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331686	12/1/2015	12/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331687	12/1/2015	12/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331688	12/1/2015	12/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331689	12/1/2015	12/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331690	12/1/2015	12/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331691	12/1/2015	12/16/2015		Replace PRE-filters
FO-331692	12/1/2015	12/22/2015		Replace PRE-filters
FO-331693	12/1/2015	12/22/2015		Replace PRE-filters
FO-331694	12/1/2015	12/16/2015		Replace PRE-filters
FO-331695	12/1/2015	12/9/2015		Replace PRE-filters
FO-331696	12/1/2015	12/9/2015		Replace PRE-filters
FO-331697	12/1/2015	12/9/2015		Replace PRE-filters
FO-331698	12/1/2015	12/8/2015		Replace PRE-filters
FO-331699	12/1/2015	12/8/2015		Replace PRE-filters
FO-331700	12/1/2015	12/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331701	12/1/2015	12/21/2015		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-331702	12/1/2015	12/21/2015		Replace PRE-filters
FO-331703	12/1/2015	12/21/2015		Replace PRE-filters
FO-331704	12/1/2015	12/21/2015		Replace PRE-filters
FO-331705	12/1/2015	12/17/2015		Replace PRE-filters
FO-331706	12/1/2015	12/16/2015		Replace PRE-filters
FO-331707	12/1/2015	12/7/2015		Replace PRE-filters
FO-331708	12/1/2015	12/7/2015		Replace PRE-filters
FO-331709	12/1/2015	12/7/2015		Replace PRE-filters
FO-331710	12/1/2015	12/9/2015		Replace PRE-filters
FO-331711	12/1/2015	12/9/2015		Replace PRE-filters
FO-331712	12/1/2015	12/9/2015		Replace PRE-filters
FO-331713	12/1/2015			Replace PRE-filters
FO-331714	12/1/2015			Replace PRE-filters
FO-331715	12/1/2015			Replace PRE-filters
FO-331716	12/1/2015	12/23/2015		Replace PRE-filters
FO-331717	12/1/2015	12/23/2015		Replace PRE-filters
FO-331718	12/1/2015	12/23/2015		Replace PRE-filters
FO-331719	12/1/2015	12/15/2015		PM - Air Handling Unit (ANNUAL)
FO-331720	12/1/2015	12/15/2015		PM - Air Handling Unit (ANNUAL)
FO-331721	12/1/2015	12/16/2015		PM - Air Handling Unit (ANNUAL)
FO-331722	12/1/2015	12/16/2015		PM - Air Handling Unit (ANNUAL)
FO-331723	12/1/2015	12/16/2015		Replace PRE-filters
FO-331724	12/1/2015	12/16/2015		Replace PRE-filters
FO-331725	12/1/2015	12/16/2015		Replace PRE-filters
FO-331726	12/1/2015	12/15/2015		Replace PRE-filters
FO-331727	12/1/2015	12/17/2015		Replace PRE-filters
FO-331728	12/1/2015	12/17/2015		Replace PRE-filters
FO-331729	12/1/2015			Replace PRE-filters
FO-331730	12/1/2015			Replace PRE-filters
FO-331731	12/1/2015	12/22/2015		Replace PRE-filters
FO-331732	12/1/2015			Replace PRE-filters
FO-331733	12/1/2015			Replace PRE-filters
FO-331734	12/1/2015			Replace PRE-filters
FO-331735	12/1/2015			Replace PRE-filters
FO-331736	12/1/2015	12/19/2015		Replace PRE-filters
FO-331737	12/1/2015	12/19/2015		Replace PRE-filters
FO-331738	12/1/2015			Replace PRE-filters
FO-331739	12/1/2015			Replace PRE-filters
FO-331740	12/1/2015			Replace PRE-filters
FO-331741	12/1/2015			Replace PRE-filters
FO-331742	12/1/2015			Replace PRE-filters
FO-331743	12/1/2015	12/19/2015		Replace PRE-filters
FO-331744	12/1/2015			Replace PRE-filters
FO-331745	12/1/2015	12/22/2015		Replace PRE-filters
FO-331746	12/1/2015			Replace PRE-filters
FO-331747	12/1/2015			Replace PRE-filters
FO-331748	12/1/2015			Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-331749	12/1/2015			Replace PRE-filters
FO-331750	12/1/2015			Replace PRE-filters
FO-331751	12/1/2015			Replace PRE-filters
FO-331752	12/1/2015			Replace PRE-filters
FO-331753	12/1/2015			Replace PRE-filters
FO-331754	12/1/2015			Replace PRE-filters
FO-331755	12/1/2015			Replace PRE-filters
FO-331756	12/1/2015			Replace PRE-filters
FO-331757	12/1/2015	12/19/2015		Replace PRE-filters
FO-331758	12/1/2015	12/19/2015		Replace PRE-filters
FO-331759	12/1/2015	12/19/2015		Replace PRE-filters
FO-331760	12/1/2015	12/22/2015		Replace PRE-filters
FO-331761	12/1/2015	12/19/2015		Replace PRE-filters
FO-331762	12/1/2015	12/18/2015		Replace PRE-filters
FO-331763	12/1/2015	12/18/2015		Replace PRE-filters
FO-331764	12/1/2015	12/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331765	12/1/2015	12/15/2015		Replace PRE-filters
FO-331766	12/1/2015	12/15/2015		Replace PRE-filters
FO-331767	12/1/2015	12/11/2015		Replace PRE-filters
FO-331768	12/1/2015	12/11/2015		Replace PRE-filters
FO-331769	12/1/2015	12/10/2015		Replace PRE-filters
FO-331770	12/1/2015	12/10/2015		Replace PRE-filters
FO-331771	12/1/2015	12/16/2015		Replace PRE-filters
FO-331772	12/1/2015	12/15/2015		Replace PRE-filters
FO-331773	12/1/2015	12/15/2015		Replace PRE-filters
FO-331774	12/1/2015	12/15/2015		Replace PRE-filters
FO-331775	12/1/2015	12/23/2015		Replace PRE-filters
FO-331776	12/1/2015	12/22/2015		Replace PRE-filters
FO-331777	12/1/2015	12/18/2015		Replace PRE-filters
FO-331778	12/1/2015			Replace PRE-filters
FO-331779	12/1/2015	12/18/2015		Replace PRE-filters
FO-331780	12/1/2015	12/17/2015		Replace PRE-filters
FO-331781	12/1/2015			Replace PRE-filters
FO-331782	12/1/2015	12/18/2015		Replace PRE-filters
FO-331783	12/1/2015	12/17/2015		Replace PRE-filters
FO-331784	12/1/2015	12/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-331785	12/1/2015	12/22/2015		Replace PRE-filters
FO-331786	12/1/2015	12/22/2015		Replace PRE-filters
FO-331787	12/1/2015	12/22/2015		Replace PRE-filters
FO-331788	12/1/2015	12/16/2015		Replace PRE-filters
FO-332238	12/7/2015	12/23/2015		Animal Lab Filter Changes for Applelebaum
<b>E - South</b>			<b>35</b>	
FO-332734	12/1/2015	12/3/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-332805	12/1/2015	12/7/2015		PM - Domestic Water Heater, Electric
FO-332806	12/1/2015	12/7/2015		PM - Domestic Water Heater, Electric
FO-332807	12/1/2015	12/8/2015		PM - Domestic Water Heater, Electric
FO-332812	12/1/2015	12/7/2015		PM - Air Compressor, Reciprocating 5-40 H.P.

WO	Recieved	Finished	Total	Request
FO-332844	12/1/2015	12/9/2015		PM - Water Softener
FO-332850	12/1/2015	12/7/2015		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332851	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332852	12/1/2015	12/1/2015		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332855	12/1/2015			PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled) Chillers
FO-332861	12/1/2015	12/15/2015		PM - Heat Exchanger and Economizer
FO-333394	12/8/2015	12/17/2015		Monthly AHU Inspection Clean Room Unit 2
FO-333395	12/8/2015	12/4/2015		PM - Monthly AHU Inspection Clean Room Unit 1
FO-333707	12/10/2015	12/10/2015		Generator Maintenance, Monthly
FO-333709	12/10/2015	12/10/2015		Generator Maintenance, Monthly
FO-333721	12/10/2015	12/10/2015		Generator Maintenance, Monthly
FO-331948	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331949	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331950	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331951	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331952	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331953	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331954	12/12/2015	12/12/2015		PM - Air Handling Unit (ANNUAL)
FO-331964	12/12/2015	12/12/2015		Replace PRE-filters
FO-331965	12/12/2015	12/12/2015		Replace PRE-filters
FO-333724	12/12/2015			Replace PRE-filters
FO-333725	12/12/2015			Replace PRE-filters
FO-333726	12/12/2015			Replace PRE-filters
FO-333727	12/12/2015			Replace PRE-filters
FO-333728	12/12/2015			Replace PRE-filters
FO-333729	12/12/2015			Replace PRE-filters
FO-333730	12/12/2015			Replace PRE-filters
FO-333711	12/15/2015	12/15/2015		Generator Maintenance, Monthly
FO-334364	12/16/2015			Generator Maintenance, Monthly
FO-334384	12/17/2015	12/18/2015		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>102</b>	
FO-332735	12/1/2015			PM - Heat Exchanger and Economizer
FO-332736	12/1/2015			PM - Heat Exchanger and Economizer
FO-332737	12/1/2015			PM - Heat Exchanger and Economizer
FO-332738	12/1/2015			PM - Heat Exchanger and Economizer
FO-332740	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332741	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332742	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332743	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332744	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332745	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332746	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332747	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332748	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332749	12/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-332750	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332751	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332752	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332753	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332754	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332755	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332756	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332757	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332758	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332759	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332760	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332761	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332762	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332763	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332764	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332765	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332766	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332767	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332768	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332769	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332770	12/1/2015	12/1/2015		PM - Heat Pumps (5057 Woodward)
FO-332771	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332772	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332773	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332774	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332775	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332776	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332777	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332778	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332779	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332780	12/1/2015	12/2/2015		PM - Heat Pumps (5057 Woodward)
FO-332781	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332782	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332783	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332784	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332785	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332786	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332787	12/1/2015	12/3/2015		PM - Heat Pumps (5057 Woodward)
FO-332788	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332789	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332790	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332791	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332792	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332793	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332794	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332795	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332796	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-332797	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332798	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332799	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332800	12/1/2015	12/4/2015		PM - Heat Pumps (5057 Woodward)
FO-332801	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332802	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332803	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332804	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332808	12/1/2015			PM - Sump Pump
FO-332809	12/1/2015			PM - Sump Pump
FO-332810	12/1/2015			PM - Sump Pump
FO-332811	12/1/2015			PM - Sump Pump
FO-332813	12/1/2015			PM - Heat Exchanger and Economizer
FO-332814	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332815	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332816	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332817	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332818	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332819	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332820	12/1/2015			PM - Fan Coil/HV/AC Unit
FO-332833	12/1/2015			PM - Harmsco Side Stream Filter
FO-332834	12/1/2015			PM - Harmsco Side Stream Filter
FO-332835	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332836	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332837	12/1/2015	12/7/2015		PM - Heat Pumps (5057 Woodward)
FO-332838	12/1/2015	12/8/2015		PM - Heat Pumps (5057 Woodward)
FO-332839	12/1/2015	12/8/2015		PM - Heat Pumps (5057 Woodward)
FO-332840	12/1/2015	12/8/2015		PM - Heat Pumps (5057 Woodward)
FO-332845	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332846	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332847	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332854	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-333714	12/15/2015			Generator Maintenance, Monthly
FO-333716	12/15/2015			Generator Maintenance, Monthly
FO-334357	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334358	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334359	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334360	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334361	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334362	12/20/2015			PM - Air Intake Dampers (Old Main)
FO-334363	12/20/2015			PM - Air Intake Dampers (Old Main)
<b>E - West</b>			<b>8</b>	
FO-332739	12/1/2015			PM - Heat Exchanger and Economizer
FO-332832	12/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.



WO	Recieved	Finished	Total	Request
FO-332848	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332849	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-332853	12/1/2015			PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-333393	12/8/2015			PM - Domestic Water Heater, Gas
FO-333403	12/8/2015			Generator Maintenance, Monthly
FO-334918	12/24/2015			Generator Maintenance, Monthly
<b>Trades</b>			<b>47</b>	
<b>Routine</b>			<b>47</b>	
<b>T - Electrician</b>			<b>35</b>	
FO-332841	12/1/2015	12/1/2015		Generator Test
FO-333396	12/4/2015	12/4/2015		Generator Test
FO-333404	12/4/2015	12/4/2015		Generator Test
FO-333405	12/4/2015	12/4/2015		Generator Test
FO-333406	12/4/2015	12/4/2015		Generator Test
FO-333397	12/8/2015			Generator Test
FO-333398	12/8/2015			Generator Test
FO-333399	12/8/2015			Generator Test
FO-333402	12/8/2015			Generator Test
FO-333717	12/9/2015	12/9/2015		Generator Test
FO-333708	12/10/2015	12/10/2015		Generator Test
FO-333710	12/10/2015	12/10/2015		Generator Test
FO-333720	12/10/2015	12/10/2015		Generator Test
FO-333723	12/11/2015	12/11/2015		Generator Test
FO-333706	12/15/2015			Generator Test
FO-333712	12/15/2015	12/15/2015		Generator Test
FO-333713	12/15/2015			Generator Test
Generator test failed 12/15/2015, and Team Leader called for service 12/16/2015.				
FO-333715	12/15/2015	12/15/2015		Generator Test
FO-333719	12/15/2015	12/15/2015		Generator Test
FO-334365	12/16/2015	12/16/2015		Generator Test
FO-334378	12/16/2015	12/16/2015		Generator Test
FO-334382	12/17/2015			Generator Test
FO-334383	12/17/2015	12/17/2015		Generator Test
FO-334366	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 7:15 AM
FO-334367	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 2PM.
FO-334368	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 10AM.
FO-334370	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 8AM.
FO-334372	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 8AM.
FO-334374	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 8AM.
FO-334376	12/22/2015			Generator Test, Tuesday 12/22/2015 @ 8AM.
FO-334914	12/23/2015			Generator Test, Wednesday 12/23/2015 @ 7:15 AM.
FO-334915	12/23/2015			Generator Test, Wednesday 12/23/2015 @ 7:15 AM.
FO-334917	12/24/2015			Generator Test, Thursday 12/24/2015 @ 7:15 AM.
FO-334919	12/24/2015			Generator Test, Thursday 12/24/2015 @ 1PM.
FO-334920	12/24/2015			Generator Test, Thursday 12/24/2015 @ 1PM.

WO	Recieved	Finished	Total	Request
<b>T - Plumber</b>			<b>12</b>	
FO-331484	12/1/2015			PM - Main Drain with Copper Sulfate ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,,
FO-331485	12/1/2015	12/1/2015		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-331486	12/1/2015	12/10/2015		PM - Waterless Urinals ,,,,,,,,,,,,,, MM/12-1-15 ,,,,,,,,,,,,,,
FO-331487	12/1/2015	12/10/2015		PM - Waterless Urinals ,,,,,,,,,,,,,, TT/12-1-15 ,,,,,,,,,,,,,,
FO-331488	12/1/2015	12/8/2015		PM - Waterless Urinals ,,,,,,,,,,,,,, TT/12-1-15 ,,,,,,,,,,,,,,
FO-332994	12/1/2015	12/18/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,
FO-332995	12/1/2015	12/21/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,,
FO-332997	12/1/2015	12/17/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,
FO-332998	12/1/2015	12/17/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,
FO-332999	12/1/2015	12/15/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,
FO-333086	12/1/2015	12/18/2015		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,
FO-335137	12/18/2015			*REPAIR ADDED: Repair RPZ in boiler room ,,,,,,,,,,,,,, 12-18-15 ,,,,,,,,,,,,,,  2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,,,,

**Total: 1698**