

Facilities Operations Backlog as of 6/30/16

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Maint. Work Order				1599	582	224	145	361	235	52	1017
Custodial				122	74	11	4	16	16	1	48
High				4	2	0	0	0	2	0	2
C-Relief				1	0	0	0	0	1	0	
FO-321263	7/7/2015	359	Created	Unit is running Hot in Paint shop break room.							
C-Sector 02				2	1	0	0	0	1	0	
FO-331141	10/28/2015	246	Completed	ADDING CUSTODIAL 10/28/15 FOR CLEAN UP AFTER FLR DRAIN HAD BEEN CLEA							
FO-350276	6/20/2016	10	Created	This request is for carpet cleaning and cleaning the outside windows of the Shiffman Li							
C-Sector 09				1	1	0	0	0	0	0	
FO-350259	6/20/2016	10	Created	Please deep clean the carpet and dust and clean the entire office including air vents. Off							
Medium				2	1	0	0	1	0	0	1
C-Materials				1	0	0	0	1	0	0	
FO-337285	1/19/2016	163	Created	Emmanuel, move all chemicals from cage storage area and office 015 to room .057 of t							
C-Sector 07				1	1	0	0	0	0	0	
FO-349203	6/2/2016	28	Created	Room 004.1 need floor waxed.							
Low				116	71	11	4	15	14	1	45
C-Director				8	0	0	0	2	6	0	
FO-325042	8/20/2015	315	Created	20 packing boxes							
FO-325043	8/20/2015	315	Created	3 rolls of packing tape.							
FO-326984	9/15/2015	289	Created	Purdy Library, 1st Floor, 134 PurdyCleaning request: vacuum and wipe down cubicle							
FO-327069	9/16/2015	288	Created	Wash carpet in main office, 2040 F/AB							
FO-327087	9/16/2015	288	Created	First floor hallway needs to be mopped and waxed.							
FO-330848	10/23/2015	251	Created	Stock Issue Request: 1 small padlock with key.							
FO-339313	2/10/2016	141	Created	1st floor public ladies room lights over the counter are out.							
FO-342366	3/18/2016	104	Created	12 (ea) batteries.							
C-Lighting				34	31	2	0	1	0	0	
FO-343442	3/29/2016	93	Created	Replace light bulbs in track-lighting fixtures located outside the OneCard/Parking Servic							
FO-347527	5/17/2016	44	Created	Lights are out in Cold Room							
FO-347537	5/17/2016	44	Created	Relamp Light Fixtures in Md Labs as Follows:2106 -one lamp. 2228 - Three lamps; 22							
FO-350690	6/22/2016	8	Created	Room 2137 - Lights out							
FO-350691	6/22/2016	8	Created	Room 2125 - First floor - storage area - lights out							
FO-350756	6/23/2016	7	Created	Light out in stairwell - please stop at Box Office for direction.							
FO-350775	6/23/2016	7	Created	Room 487 - 2 panels, 4 LO.							
FO-350777	6/23/2016	7	Created	Basement, room 28 - 1 LO							
FO-350778	6/23/2016	7	Created	Basement, room 43 - 1 LO							
FO-350781	6/23/2016	7	Created	Stairwell B, between 2nd and 3rd fl - 1 LO							
FO-350790	6/23/2016	7	Created	There are a large group of lights out surrounding the hallway of Room 237. It is approxi							
FO-350792	6/23/2016	7	Created	There is also a large set of lights out in this open laboratory space, approximately 21 als							
FO-350794	6/23/2016	7	Created	Light out in stairwell from 2nd floor to 3rd floor (first landing).Please replace.Thank y							
FO-350796	6/23/2016	7	Created	Lobby area - first floor. 6 iights out by south (back) door. Please replace.Thank you.							
FO-350798	6/23/2016	7	Created	First floor lobby - by window. 4 spot lights out.Please replace.Thank you.Dawn C.							
FO-350804	6/23/2016	7	Created	Lobby - First floor, near front (north) door vestibule. One spot light out. Please replace.							
FO-350800	6/23/2016	7	Created	Light out.Please replace & thank you.							
FO-350805	6/23/2016	7	Created	Light out. In hallway by Room 317.							
FO-350806	6/23/2016	7	Created	Lightsout. In area between Room 305 and 308. Please replace.							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-350807	6/23/2016	7	Created	Room 342.3. Light out in front of this area.Please replace.							
FO-350808	6/23/2016	7	Created	Room 342.5. Lights in front area need to be replaced.							
FO-350809	6/23/2016	7	Created	Room 340.2 - First bay - need lightbulbs.Room 340.2 - Fifth bay - need lightbulbs.							
FO-350810	6/23/2016	7	Created	Near office areas & elevators. Tiles are loose and need to be replaced.							
FO-350819	6/23/2016	7	Created	2nd fl - Room 272 - Women's R/R - 1 LO							
FO-350820	6/23/2016	7	Created	Stairwell D - 2nd fl - 2 LO							
FO-350821	6/23/2016	7	Created	Stairwell B - 4th fl - 1 LO							
FO-350822	6/23/2016	7	Created	Stairwell C - 4th fl - 2 LO							
FO-350993	6/27/2016	3	Created	Light out on third floor around the corner from restroom 322.09							
FO-351016	6/27/2016	3	Created	2 lights out.							
FO-351020	6/27/2016	3	Created	1)Recessed light out over 1st floor drinking fountain. 2) recessed light out in hallway 3							
FO-351139	6/28/2016	2	Created	3rd fl stairwell B - 3 LO							
FO-351261	6/30/2016	0	Created	Six lights are out in the open meeting area on the first floor.							
FO-351295	6/30/2016	0	Created	Relamp Light Fixtures as required.							
FO-351297	6/30/2016	0	Created	Lights out in Office Service Room 4705 - 4th Floor. Please replace. Also, doors are not							
C-Materials				2	1	0	0	0	0	1	
FO-319568	6/15/2015	381	Created	Stock Issue Request: Shoe Covers							
FO-351278	6/30/2016	0	Created	Please remove filled recycle bins and replace with 8 large recycle bins on the loading do							
C-Projects				6	1	0	0	4	1	0	
FO-328326	9/29/2015	275	Created	Strip and wax labs 130 and 140. Please contact Dr. Brock at 577-3102 or at sbrock@ch							
FO-338130	1/28/2016	154	Created	In Rm. 5148 (new faculty professor) Please have custodial services clean the file cabine							
FO-338820	2/4/2016	147	Created	We need the vents cleaned for the entire first and second floors of the Law Library. See							
FO-341301	3/2/2016	120	Created	Custodial Request (Terri Robertson): Detail cleaning of all bathrooms.							
FO-341302	3/2/2016	120	Created	Custodial (Terri Robertson): Detail clean all restrooms in the Law School Building.							
FO-351011	6/27/2016	3	Created	Clean carpet in President's apartment.							
C-Relief				1	0	0	0	1	0	0	
FO-339719	2/16/2016	135	Created	Women's bathroom beside elevator on 4th floor, toilet is plugged.							
C-Repair				10	6	1	1	1	1	0	
FO-334623	12/10/2015	203	Project on hold	TENNANT FLOOR SWEEPER--BRUSHES NOT TURNING AND SHOWING F50 ON S							
FO-343048	3/23/2016	99	Project on hold	Tennant Nobles (NS20B00024979BU) Auto Scrubber does not work. The problem appe							
FO-345710	4/21/2016	70	Project is under construction	adhancer W28-C Serial:100000920. Scrubber's front end scrapes the floor, needs adjus							
FO-347755	5/20/2016	41	Created	Allied Eagle Parts. FY 2016. P0754070.							
FO-350103	6/16/2016	14	Created	Please repair Green noble wet dry vacuum. Motor is not working.. Housing is burn up an							
FO-350266	6/20/2016	10	Created	AUTO, SCRUBBER							
FO-350614	6/21/2016	9	Created	Please repair buffer at Scott Hall Basement in cage. Pacesetter 20' buffer motor not run							
FO-350705	6/22/2016	8	Created	Nobles Floor Sweeper needs some service repairs.							
FO-350776	6/23/2016	7	Created	Advance vacuum does not seem to have sufficient vacuum. Does not pick up powered							
FO-351246	6/30/2016	0	Created	The soap dispenser in the back bathroom inside the ladies locker room in the Fitness C							
C-Sector 02				15	11	0	1	1	2	0	
FO-329655	10/14/2015	260	Cancelled	Please strip, scrub and wax floor of room 7327.							
FO-330749	10/22/2015	252	Cancelled	Strip, scrub, and wax floors of lab area on the East side of the building (CMMG)							
FO-342950	3/23/2016	99	Created	Strip and wax floor in MRI lab 0121 (NOT the room where the magnet is housed). Pers							
FO-345751	4/21/2016	70	Created	Scrub and wax floor in lab 5339 and two small adjace rooms. Would like this work done							
FO-349035	6/1/2016	29	Created	Strip, scrub, wax MD Labs floors;MD lab Labs 2106, 2116, 2136,2115,2125,2135, 222							
FO-349488	6/7/2016	23	Created	6 cases of dial soap.							
FO-349489	6/7/2016	23	Created	4 cases of dial soap.							
FO-349498	6/7/2016	23	Created	4 cases of dial soap.							
FO-349501	6/7/2016	23	Created	4 cases of dial soap.							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349503	6/7/2016	23	Created	4 cases of dial soap.							
FO-349549	6/8/2016	22	Created	Room 1225 Lab - request to have floors cleaned/polished- please contact Dr. Neha Got							
FO-350200	6/17/2016	13	Created	Clean the Carpet in Bio Chemistry Office suite 4374 including interior offices 4376, 437							
FO-350608	6/21/2016	9	Created	This Request replaces the request below:Please cancel Request # 284925 FO-34903							
FO-350729	6/22/2016	8	Created	Scrub, wax cafeteria floor need to be done in two stages, grounds to shift and clear fur							
FO-350754	6/23/2016	7	Created	Please strip and wax the floor in lab 257 Lande. We would like the work done on Frida							
C-Sector 04				2	2	0	0	0	0	0	
FO-349514	6/7/2016	23	Created	Clean and wax/polish all floors in the animal facility. Due for bi-yearly attention, per Cus							
FO-349846	6/13/2016	17	Created	Requesting the floors in labs 3340, 3350 & 3360 be							
C-Sector 05				17	11	3	1	0	2	0	
FO-322594	7/21/2015	345	Created	Per Karen Wilson's request, we are trying to have the entire College of Engineering's ca							
FO-332401	11/11/2015	232	Created	Carpet shampooing requested. Preferably on a Saturday as classes are in session Mo							
FO-345721	4/19/2016	72	Cancelled	R/R RM 1410/CLASS RM Per Dr. Ku's request:							
FO-348239	5/24/2016	37	Created	Schedule carpet cleaning for 60-station computer labs, rooms 308, 328, 358, 368, small							
FO-348260	5/24/2016	37	Created	Strip and wax floors in the CIM Lab located on the first floor Engineering Technology Bld							
FO-348265	5/24/2016	37	Created	strip and wax floor at front hallway entrance							
FO-349651	6/9/2016	21	Created	Second Floor Room 264 mop & Wax for Jogindra Wadehra, phone 313-577-2740, wade							
FO-349652	6/9/2016	21	Created	Please strip and wax faculty office.							
FO-349935	6/14/2016	16	Created	Please strip and wax the floor in this office. Has not been done in a while.							
FO-349936	6/14/2016	16	Created	Floor needs to be stripped and waxed. Has not been done in a long time. Faculty mem							
FO-349937	6/14/2016	16	Created	Floor needs to be stripped and waxed. Has not been done for a long time.							
FO-349940	6/14/2016	16	Created	Floor needs to be stripped and waxed. Has not been done in a long time.							
FO-349941	6/14/2016	16	Created	This is a faculty Office. Floor need to be stripped and waxed. Has not been done in a l							
FO-349968	6/14/2016	16	Created	Floor needs stripping and waxing. Has not been done in a long time.							
FO-349969	6/14/2016	16	Created	Floor needs stripping and waxing. Has not been done in a long time.							
FO-349970	6/14/2016	16	Created	Floor needs stripping and waxing. Has not been done in a long time.							
FO-351238	6/29/2016	1	Created	Floor needs cleaning, stripping and waxing. Has not been done in a long time.							
C-Sector 06				2	2	0	0	0	0	0	
FO-349278	6/3/2016	27	Created	strip/wax 101 before 6/9/16							
FO-350023	6/15/2016	15	Created	Deep Clean the Partrich Auditorium and Balcony: Vacuum/shampoo carpetWipe do							
C-Sector 07				6	2	4	0	0	0	0	
FO-346819	5/4/2016	57	Created	refer to FO-346751 foul smells mens room 440, 4th floor Purdy,							
FO-347735	5/20/2016	41	Created	Need floors buffed and waxed							
FO-347736	5/20/2016	41	Created	Need floors buffed and waxed							
FO-347737	5/20/2016	41	Created	Need floors buffed and waxed							
FO-351135	6/28/2016	2	Created	Please arrange to have floors cleaned, polished, and light bulbs replaced. Please conta							
FO-351166	6/28/2016	2	Created	There is a lot of broken glass at the west wing							
C-Sector 08				1	0	1	0	0	0	0	
FO-347026	5/9/2016	52	Created	Tierney Alumni House needs to be vacuumed, especially on second floor and Mrs. Wils							
C-Sector 09				3	1	0	0	2	0	0	
FO-340416	2/24/2016	127	Created	4 cases of dial soap.							
FO-341459	3/4/2016	118	Created	2 cases of dial soap.							
FO-349180	6/2/2016	28	Created	please dust/clean room 247. thank you							
C-Sector 10				4	0	0	1	3	0	0	
FO-336652	1/11/2016	171	Created	Repair 3 vacuum cleaners. Not picking up.							
FO-338079	1/27/2016	155	Created	Please deliver to either a janitor's closet in C&IT OR a custodian in C&IT, per David Hou							
FO-339262	2/10/2016	141	Created	Stock Issue Request: Back Brace size large							
FO-344460	4/8/2016	83	Created	3 track light bulbs requested.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Pest Controller			5	3	0	0	0	2	0	
FO-320962	7/2/2015	364	Created	Stock issue: 1 Tyvak suit.						
FO-327818	9/22/2015	282	Created	1 harness set						
FO-351120	6/28/2016	2	Created	Please service the department of International Students and Scholars for Gnats.						
FO-351197	6/29/2016	1	Created	trade pest control priority highR/R RM 510/MECH RM please service mech rm area be						
FO-351222	6/29/2016	1	Created	Net bugs on the third floor in room 3506 in the AAB building.						
Engineering			611	233	128	77	159	9	5	378
Emergency			4	1	1	2	0	0	0	3
E - Command Center			1	1	0	0	0	0	0	
FO-350271	6/20/2016	10	Created	RM 1100 ACTIVE CEILING LEAK FROM HVAC CONDENSATE PUMP						
E - MedPharm			2	0	1	1	0	0	0	
FO-345768	4/21/2016	70	Created	RM 6639 WATER IS LKNG BEHIND WALL NEAR LAZER EQUIP (believe its the pipec						
FO-348218	5/24/2016	37	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING						
E - South			1	0	0	1	0	0	0	
FO-344868	4/15/2016	76	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT						
High			327	125	67	44	83	5	3	202
E - Auxiliary			6	2	2	2	0	0	0	
H-58066	4/15/2016	76	Created	There are three tubs in the bathroom; however, the one in the shower and the one over t						
H-58207	4/27/2016	64	Created	my sink in the bathroom is leakingauthenticated user: Madison Ford - es2236request						
H-58607	5/25/2016	36	Created	My air conditioning turns on but blows warm air instead of cold air.authenticated user:						
H-58608	5/27/2016	34	Created	Air conditioning is not working.authenticated user: Nicole Fry - eq0918requester ip a						
H-59025	6/26/2016	4	Created	A/C Unit is not working. Please service ASAP! Thank You!! :) authenticated user:						
H-59028	6/27/2016	3	Created	Air condition isn't working, room is set to cold settings, but room is still hot.authenticat						
E - Command Center			21	13	6	2	0	0	0	
FO-344798	4/14/2016	77	Created	Control section repair-room stat is not working properly, stat is receiving control air but t						
FO-344878	4/15/2016	76	Hold for Funds	Refr.crew:						
FO-347831	5/23/2016	38	Parts on Order	Controls High Priority						
FO-347832	5/23/2016	38	Parts on Order	Controls High Priority,						
FO-347833	5/23/2016	38	Created	BAS High Priority						
FO-348591	5/27/2016	34	Created	Refer/AC Shop:						
FO-348592	5/27/2016	34	Created	Refer/AC Shop:						
FO-348593	5/27/2016	34	Created	Refer/AC Shop:						
FO-349472	6/7/2016	23	Created	Controls please check regulating controls for 200.15 unit is in cool mode discharging						
FO-349762	6/12/2016	18	Created	the chiller 1 condenser cooling water inlet bray valve does not open when chiller starts						
FO-349089	6/13/2016	17	Created	unit serves 2nd floor not cooling						
FO-349849	6/13/2016	17	Created	Refrig. Crew: R/R PENTHOUSE Please check and repair #2 Boiler keeps tripping on fl						
FO-349845	6/13/2016	17	Created	neither compressor will run, reset all safety devices						
FO-349927	6/14/2016	16	Created	unit not cooling						
FO-349928	6/14/2016	16	Created	unit not cooling						
FO-350277	6/20/2016	10	Created	AC Shop-please check heat pump 4-8. Compressor						
FO-350561	6/21/2016	9	Created	Compressor #1 is running but not cooling fully. See Frank Van Oppens.						
FO-350654	6/22/2016	8	Created	CONTROLS /REFRIG CREWFUME HOOD #13 DOESN'T HAVE SUFFIENT AIR FL						
FO-350825	6/23/2016	7	Created	REFRIG CREW,						
FO-350986	6/27/2016	3	Created	CONTROLS (HIGH)R/R ROOF McQUAY UNIT AT 50% CAPACITY. CIRCUIT ONE D						
FO-351068	6/27/2016	3	Created	Purdy Library 1st Floor: Office Suite 122 Purdy (Home of Human Resources, Region B).						
E - MedPharm			183	58	41	27	57	0	0	
FO-338292	2/1/2016	150	Created	RM 00225/DLAR HAS POSITIVE AIR PRESSURE SHOULD BE NEGATIVE						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-338303	2/1/2016	150	Created							FAP FIRE TROUBLE ALARM
FO-338304	2/1/2016	150	Created							RM 5229 TOO HOT
FO-338353	2/1/2016	150	Created							RM 2248/CLASS RM HAS A LITE COVER HANGING DOWN-SAFETY ISSUE
FO-338750	2/3/2016	148	Created							RM 6321 TOO HOT
FO-338782	2/3/2016	148	Created							RM 5258 IS TOO HOT
FO-338783	2/3/2016	148	Created							RM 5258 AIR HANDLING IS TOO LOUD
FO-338980	2/5/2016	146	Created							RM 1200 TOO HOT
FO-339095	2/8/2016	143	Created							GREEN LECT HALL IS TOO COLD
FO-339096	2/8/2016	143	Created							RM 1328 IS TOO HOT
FO-339108	2/8/2016	143	Created							RM 6321 IS TOO HOT
FO-339213	2/9/2016	142	Created							RM 5213 IS TOO COLD
FO-339295	2/10/2016	141	Created							rm 5236 IS TOO HOT
FO-339332	2/11/2016	140	Created							GREEN LECT HALL IS TOO COLD
FO-339348	2/11/2016	140	Created							RM 411 LOW HUMIDITY
FO-339373	2/11/2016	140	Created							Please repair the light of Hood No 6 (Room No-3341). The light takes 40-45 minutes to
FO-339459	2/12/2016	139	Created							The fire alarm panel in the hallway next to the stage door. shows normal, but there a 6 o
FO-339776	2/16/2016	135	Created							GREEN LECT HALL IS TOO HOT
FO-340001	2/19/2016	132	Created							LAB 6321 TOO HOT, PLEASE ADJUST TEMP ASAP
FO-340010	2/19/2016	132	Created							R/R R 8229 SINK @ YOUR RIGHT AS YOU COME INTO RM HOT WATRER FAUCET
FO-340017	2/19/2016	132	Created							RM 9232 IS EXTREMELY HOT
FO-340087	2/22/2016	129	Created							RM 9228 AUTOCLAVE IS LKNG
FO-340254	2/23/2016	128	Created							RM 325 BODY COOLER RM TEMP TOO HIGH 72 SHOULD BE 65 PLEASE FIX ASA
FO-340328	2/24/2016	127	Created							RM 3325 TOO HOT
FO-340349	2/24/2016	127	Created							RM 324 TOO HOT
FO-340373	2/24/2016	127	Created							RM 521 TOO HOT
FO-340464	2/25/2016	126	Created							RM 200.02 HAS A HI TEMP ALARM
FO-340489	2/25/2016	126	Created							REQUESTING ENG INVESTIGATE LOADING DOCK DOOR NOT CLOSING PROPER
FO-340529	2/26/2016	125	Created							RM 1200 TOO HOT
FO-340619	2/29/2016	122	Created							STE 400 (entire) HAS HI TEMP
FO-340625	2/29/2016	122	Created							RM 7341 TOO HOT, INCUBATORS WITHIN RM ALARMS SOUNDING FIX ASAP
FO-340641	2/29/2016	122	Created							RM 6226 TOO HOT
FO-340737	2/29/2016	122	Created							RM 7354 IS EXTREMELY HOT
FO-341242	3/2/2016	120	Created							RM 325 TOO HOT
FO-341250	3/2/2016	120	Created							RM 5215 IS TOO COLD
FO-341444	3/4/2016	118	Created							RM 6353 NO LIGHTS, POSSIBLE CIRCUIT BREAKER
FO-341512	3/7/2016	115	Created							RM 5234 IS EXTREMELY HOT
FO-341568	3/7/2016	115	Created							RM 414 HAS A HI TEMP
FO-341775	3/9/2016	113	Created							RM 9344 IS EXTREMELY HOT EFFECTING LAB EQUIP
FO-341780	3/9/2016	113	Created							RM 5234 IS EXTREMELY HOT EFFECTING LAB EQUIP
FO-341896	3/10/2016	112	Created							RM 7341 TOO HOT
FO-341897	3/10/2016	112	Created							RM 8333 TOO HOT
FO-341908	3/10/2016	112	Created							RM 4263 PLEASE CHECK AIR PRESSURE
FO-342147	3/15/2016	107	Created							RM 403 HIGH TEMP
FO-342154	3/15/2016	107	Created							LOW TEMP. ROOM 249. CONTACT ERIN FOR DETAILS.
FO-342219	3/16/2016	106	Created							RM 00414/DLAR IS EXTREMELY HOT IS POSSIBLE TO LOWER TEMP DUE TO ANI
FO-342233	3/16/2016	106	Created							RM 403 HIGH TEMP, RM SHOULD BE 70 DEG OR BELOW
FO-342326	3/17/2016	105	Created							Please repair/replace the diffuser on the air supply duct in the back of the room so that

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-342425	3/21/2016	101	Created	LIGHT TIMER LIGHT IS FLICKERING AND WILL NOT COME ON. ROOM 0247.						
FO-342428	3/21/2016	101	Created	LAB 8217 TOO COLD						
FO-342438	3/21/2016	101	Created	LAB 4213 TOO COLD						
FO-342446	3/21/2016	101	Created	FAP FIRE PANEL IS SHOWING FIRE TROUBLE & SNDNG						
FO-343026	3/23/2016	99	Created	RM 6226/BIO HAZZARD LAB IS EXTREMELY HOT						
FO-343110	3/24/2016	98	Created	RM 414 HAS A HI TEMP						
FO-343112	3/24/2016	98	Created	LOADING DOCK CK CIRCUIT BREAKER THAT POWERS THE TRASH COMPACTOR						
FO-343127	3/24/2016	98	Created	POSSIBLE LEAK. WATER ON FLOOR. BASEMENT ROOM 0257.						
FO-343220	3/25/2016	97	Created	RM 2268 IS TOO COLD						
FO-343663	4/1/2016	90	Created	CONTRACTOR FOR DI WTR TKS NEED ACCESS TO PH TO UPGRADE-MICHAEL 2						
FO-343679	4/1/2016	90	Created	RM 3329.20 HA NO AIR FLOW/TOO HOT						
FO-344206	4/5/2016	86	Created	ALB 8229 LOW WATER PRESSURE						
FO-344317	4/6/2016	85	Created	RM 3256/LAB ONLY FUMEHOOD STOPPED WORKING (Note: if eng's unable to repai						
FO-344473	4/8/2016	83	Created	RM 3125 IS TOO COLD						
FO-344568	4/11/2016	80	Created	RM 403 HIGH TEMP. TEMP SHOULD BE 70 OR BELOW						
FO-344624	4/12/2016	79	Created	ENTIRE STE 200 HAS LOW HUMIDITY						
FO-344723	4/13/2016	78	Created	RM 1328 TOO COLD						
FO-344727	4/13/2016	78	Created	RM 6243 HAS NO STM TO IAUTOCLAVE AGAIN						
FO-344918	4/18/2016	73	Created	LOW HUMIDITY. ROOMS 200.07 AND 200.06.						
FO-344972	4/18/2016	73	Created	RM 5229 CHEMICAL HOOD NOT WORKING						
FO-345685	4/20/2016	71	Created	RM 403 HAS HI TEMP						
FO-345686	4/20/2016	71	Created	RM 414 HAS HI TEMP						
FO-345717	4/21/2016	70	Created	RM 200.06 HAS LOW HUMIDITY						
FO-345718	4/21/2016	70	Created	RM 200.07 HAS LOW HUMIDITY						
FO-345719	4/21/2016	70	Created	RM 403 HAS HI TEMP						
FO-345739	4/21/2016	70	Created	Refrigeration/controls						
FO-345747	4/21/2016	70	Created	RM 6137/OFC AIR CIRCULATION IS TOO NOISY CAN ANYTHING BE DONE?						
FO-345763	4/21/2016	70	Created	RM 5215 AIR VENTS ARE MAKING A LOUD NOISE						
FO-345813	4/22/2016	69	Created	RM 6137/OFC AIR CIRCULATION IS TOO NOISY CAN ANYTHING BE DONE? ***STI						
FO-345853	4/22/2016	69	Created	POSSIBLE FIRE ALARM SOUNDING						
FO-346048	4/25/2016	66	Created	RM 2213 TOO HOT						
FO-346058	4/25/2016	66	Created	RM 403 HAS HI TEMP SHOULD BE 77 OR BELOW						
FO-346093	4/26/2016	65	Created	TOO HOT. ANIMAL ROOM 5520.						
FO-346117	4/26/2016	65	Created	NO COMPRESSED AIR. WANT TO KNOW IF AIR TURNED OFF? BASEMENT ROO						
FO-346317	4/29/2016	62	Created	RM 206 IS TOO HOT						
FO-346330	4/29/2016	62	Created	RM 2341 TOO HOT						
FO-346832	5/4/2016	57	Created	RM 231 A STRONG SMELL (alcohol) COMING THRU VENTS						
FO-346910	5/5/2016	56	Created	During our last production the fire hose in the upper balcony began filling with water. the						
FO-346938	5/6/2016	55	Created	RM 200.06 HAS LOW HUMIDITY						
FO-346939	5/6/2016	55	Created	RM 200.07 HAS LOW HUMIDITY						
FO-346946	5/6/2016	55	Created	RM 8337 WALK IN COLD RM BOX HAS HI TEMP ALARM						
FO-346950	5/6/2016	55	Created	RM 8337 WALK IN COLD RM BOX HAS HI TEMP ALARM						
FO-346967	5/6/2016	55	Created	AHU #3 HIGH TEMP ALARM						
FO-346996	5/9/2016	52	Created	RM 200.06/DLAR HAS LOW HUMIDITY						
FO-346997	5/9/2016	52	Created	RM 200.07/DLAR HAS LOW HUMIDITY						
FO-346998	5/9/2016	52	Created	RM 200.08/DLAR HAS LOW HUMIDITY						
FO-347027	5/9/2016	52	Created	RM 2500 IS TOO HOT						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-347058	5/9/2016	52	Created				RM 3114 TOO COLD			
FO-347191	5/11/2016	50	Created				RM 2213 TOO WARM			
FO-347268	5/12/2016	49	Created				RM 2213 TOO HOT			
FO-347279	5/12/2016	49	Created				ANIMAL RM 5449 TOO COLD			
FO-347342	5/13/2016	48	Created				RM 2213 TOO HOT			
FO-347352	5/13/2016	48	Created				RM 8337 WALK IN COLD RM BOX HAS A HI TEMP ALARM			
FO-347373	5/13/2016	48	Created				RM 1374 KITCHENETTE AREA OF OFC ONE SIDE OF WALL WHERE APPLIANCES			
FO-347406	5/16/2016	45	Created				ENTIRE STE 200/DLAR HAS LOW HUMIDITY			
FO-347437	5/16/2016	45	Created				RM 4263 IS TOO COLD/COLD AIR IS BLOWING IN STILL			
FO-347438	5/16/2016	45	Created				RM 4374 IS TOO COLD/COLD AIR IS BLOWING IN STILL			
FO-347506	5/17/2016	44	Created				RM 4252 WALK IN COLD RM BOX HAS A HI TEMP ALARM			
FO-347554	5/18/2016	43	Created				RM 2213 TOO COLD			
FO-347589	5/18/2016	43	Created				RM 5344 TOO WARM			
FO-347590	5/18/2016	43	Created				RM 610 TOO HOT			
FO-347681	5/19/2016	42	Created				RM 2219 IS TOO HOT			
FO-347688	5/19/2016	42	Created				RM 2213 IS TOO COLD			
FO-347729	5/20/2016	41	Created				RM 5330 IS TOO HOT			
FO-347751	5/20/2016	41	Created				RM 0229 TEMP ALARM			
FO-347754	5/20/2016	41	Created				rm 4230, 4240, 4267 TOO HOT			
FO-348215	5/24/2016	37	Created				RM 5263 IS TOO HOT			
FO-348228	5/24/2016	37	Created				RM 6132 IS TOO HOT			
FO-348238	5/24/2016	37	Created				RM 224.2 DUE TO POWER PROBLEMS 5/23/16 INDEPENDENT CHILLER NEEDS T			
FO-348454	5/26/2016	35	Created				RM 200.06 HAS SEVERAL CLNG LEAKS COMING FROM CRACKS IN THE CLNG			
FO-348483	5/26/2016	35	Created				RM 4100 IS TOO HOT			
FO-348486	5/26/2016	35	Created				RM 72333 IS TOO HOT			
FO-348495	5/26/2016	35	Created				Please check MEC IDF/MDF room AC Units. Rooms Temp are 80 degF.			
FO-348518	5/26/2016	35	Created				RM 7207 IS TOO HOT			
FO-348519	5/26/2016	35	Created				RM 4263 IS TOO HOT			
FO-348538	5/26/2016	35	Created				ENTIRE 2ND FLR HAS A GAS SMELL LIKE BUNSON BURNER RIGHT AS YOU GET			
FO-348577	5/27/2016	34	Created				RM 9374 TOO HOT			
FO-348713	5/31/2016	30	Created				RM 411 HAS WHISTLING NOISE COMING IN THRU AIR VENTS			
FO-348718	5/31/2016	30	Created				RM 5125 WALK IN COLD RM HAS HI TEMP ALARM			
FO-348720	5/31/2016	30	Created				BSMT DOCK DOOR NOT LATCHING PROPERLY ? NEED DOOR #			
FO-348726	5/31/2016	30	Created				RM 5125 HIGH TEMP ALARM			
FO-348936	5/31/2016	30	Created				RM 6238 HIGH TEMP ALARM			
FO-348954	5/31/2016	30	Created				RM 1281 IS EXTREMELY HOT (OCCUPANT IS GETTING SICK)			
FO-349078	6/1/2016	29	Created				RM 5344 STILL TOO HOT PLEASE CHECK EQUIPMENT			
FO-349116	6/1/2016	29	Created				RM 3250 IS TOO HOT			
FO-349177	6/2/2016	28	Created				RM 0225 NO POWER TO WASHER			
FO-349182	6/2/2016	28	Created				RM 4356 IS TOO COLD			
FO-349183	6/2/2016	28	Created				RM 4360 IS TOO COLD			
FO-349240	6/3/2016	27	Created				RM 403 HIGH TEMP AND HIGH HUMIDITY			
FO-349244	6/3/2016	27	Created				PLEASE OPEN UTILITY RM NEAR 3461			
FO-349262	6/3/2016	27	Created				BSMT AUTOCLAVE FOR DLAR IS SMELLING UP THE BSMT AREA			
FO-349329	6/6/2016	24	Created				LAB 2105 SURGE PROTECTORS IN ELECTRICAL PANEL ARE ALARMING			
FO-349346	6/6/2016	24	Created				RM 3148 IS TOO COLD			
FO-349347	6/6/2016	24	Created				RM 0247 HIGH TEMP HIGH HUMIDITY			

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349360	6/6/2016	24	Created	RM 6353 HIGH TEMP ALARM							
FO-349464	6/7/2016	23	Created	RM 2217 TOO COLD							
FO-349519	6/7/2016	23	Created	For room 402 - not listed as an option. Please replace faucet on sink in restroom - origi							
FO-349563	6/8/2016	22	Created	LAB 3341 AIR FLOW NOT WORKING FOR THE HOOD							
FO-349577	6/8/2016	22	Created	RM 00200.06 HAS LOW HUMIDITY IT IS @ 20% SHOULD BE OVER 30%							
FO-349640	6/9/2016	21	Created	FISH RM 8327 TOO WARM							
FO-349742	6/10/2016	20	Created	The air pressure needs to be positive to the hall in room 0200.05 at Scott Hall.							
FO-349779	6/13/2016	17	Created	RM 7320 IS TOO HOT							
FO-349821	6/13/2016	17	Created	RM 00048 HAS A CLNG LEAK (STEADY LEAK)							
FO-350013	6/15/2016	15	Created	animal room is running a high temp							
FO-350022	6/15/2016	15	Created	RM 2629 IS TOO HOT							
FO-350056	6/16/2016	14	Created	RM 403 HIGH HUMIDITY							
FO-350058	6/16/2016	14	Created	RM 1600 IS TOO HOT							
FO-350065	6/16/2016	14	Created	RM 124 IS TOO COLD							
FO-350066	6/16/2016	14	Created	1ST FLR HALLWAY OUTSIDE OF RM 124 IS TOO COLD ALSO BACK AREA OF 1ST							
FO-350138	6/17/2016	13	Created	CEILING LEAK. ROOM 5501.							
FO-350156	6/17/2016	13	Created	BSMT HALLWAY & ALSO RM 425 (MORGUE AREA) HAS A ROTTEN SMELL							
FO-350222	6/20/2016	10	Created	RM 4374 CEILING HAS FLASHING LIGHT BLINKING ON AND OFF							
FO-350243	6/20/2016	10	Created	BSMNT ALL ANIMAL ROOMS HAVE HIGH HUMIDITY							
FO-350622	6/21/2016	9	Created	RM 1241 TOO HOT							
FO-350682	6/22/2016	8	Created	RM 410/DLAR HAS A CLNG LEAK (believe coming from condensation on pipes)							
FO-350683	6/22/2016	8	Created	BSMT HALLWAY OUTSIDE OF RM 425/DLAR DUE TO AUTOCLAVE IN USE IT IS E							
FO-350711	6/22/2016	8	Created	RM 410/DLAR CALLING AGAIN STILL HAS A CLNG LEAK (believe coming from conde							
FO-350743	6/23/2016	7	Created	RM 2620 IS TOO HOT							
FO-350749	6/23/2016	7	Created	RM 200.08 TOO COLD PLEASE SET TEMP AT 78 DEGREES							
FO-350763	6/23/2016	7	Created	RETURN FAN #2 ALARM.							
FO-350841	6/24/2016	6	Created	PROBLEM WITH AIR PRESSURE. ROOMS 0243 AND 0247.							
FO-350850	6/24/2016	6	Created	LOW TEMPERATURE AND LOW HUMIDITY. ROOM 5565.							
FO-350862	6/24/2016	6	Created	BAD FUMES ARE COMING THRU VENTS. ROOMS 310 AND 315.							
FO-351005	6/27/2016	3	Created	NO WATER ON THE 5TH FLOOR.							
FO-351040	6/27/2016	3	Created	ALARM SOUNDING. ROOM 5339.							
FO-351045	6/27/2016	3	Created	TOO HOT. COLD ROOM 5333.							
FO-351046	6/27/2016	3	Created	NO HOT WATER. ROOM 2330.							
FO-351133	6/28/2016	2	Created	LOW TEMP. ROOM 0249.							
FO-351167	6/29/2016	1	Created	FAP FIRE TROUBLE ALARM							
FO-351202	6/29/2016	1	Created	LOW TEMP. ROOM 0514.							
FO-351203	6/29/2016	1	Created	RM 610/AUD IS TOO COLD							
FO-351211	6/29/2016	1	Created	LOW TEMP. ALARM. ROOM 0229.							
FO-351243	6/30/2016	0	Created	Contractor-KR High Priority chemical storage in research lab- Cold box is operating at 5							
FO-351274	6/30/2016	0	Created	POWER BUMP APPR 10:45AM PLS CK EQUIP							
FO-351288	6/30/2016	0	Created	CHECK AIR CONDITIONER INSIDE ELEVATOR MACHINE ROOM.							
E - North				8	3	2	3	0	0	0	
FO-344869	4/15/2016	76	Created	FIRE TROUBLE ALARM							
FO-344874	4/15/2016	76	Created	FIRE TROUBLE ALARM.							
FO-344949	4/18/2016	73	Created	ENTIRE BLDG TOO HOT							
FO-347374	5/13/2016	48	Created	RM 150 IS TOO COLD							
FO-348351	5/25/2016	36	Created	RM 5278 IS TOO HOT							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349080	6/1/2016	29	Created	BLDG TOO COLD							
FO-349283	6/3/2016	27	Created	PRESIDENTS APTS PLEASE CHECK DRYER							
FO-351176	6/29/2016	1	Created	RM 140/AUD IS TOO COLD							
E - Northeast				9	7	0	1	0	0	1	
FO-319007	6/4/2015	392	Created	BLACK PARTICLES ON DESK MAYBE FALLING FROM CEILING VENT. ROOM 3666							
FO-346177	4/27/2016	64	Created	FIRE TROUBLE ALARM.							
FO-349315	6/6/2016	24	Created	FIRE TROUBLE ALARM.							
FO-349348	6/6/2016	24	Created	Controls/Refridge (High)							
FO-349705	6/10/2016	20	Created	BLDG FIRE TROUBLE ALARM							
FO-351023	6/27/2016	3	Created	2ND FLR IS TOO HOT							
FO-351026	6/27/2016	3	Created	2ND FLR ALSO CK SEWAGE SMELL							
FO-351196	6/29/2016	1	Created	RM 223 NEED BREAKER RESET							
FO-351273	6/30/2016	0	Created	POWER BUMP APPR 10:45AM PLS CK EQUIP							
E - Preventative Maintenance				8	3	0	0	0	3	2	
FO-318338	5/29/2015	398	Not Finished	FIRE ALARM SOUNDING Please check system for shorts in the Drum Area, this sho							
FO-319007	6/4/2015	392	Created	BLACK PARTICLES ON DESK MAYBE FALLING FROM CEILING VENT. ROOM 3666							
FO-324516	8/17/2015	318	Created	ALARM WONT RESET							
FO-331975	11/4/2015	239	Created	LIGHTS ARE NOT WORKING. ROOM 1310.							
FO-334186	12/3/2015	210	Created	3RD FL LADIES RM ALL SINKS ARE BACKED UP ,,,,,,,,,, GS/12-3-15 ,,,,,,,,,,							
FO-349414	6/6/2016	24	Created	RM 4131 OUTLETS NOT WORKING IN THE BACK OF ROOM PLEASE CHECK ALL							
FO-349524	6/7/2016	23	Created	The fume hood in this lab is very loud. Changing the							
FO-351164	6/28/2016	2	Created	CEILING LEAK. ROOM 4012.							
E - South				7	3	1	0	1	2	0	
FO-324398	8/14/2015	321	Completed	RECEPTION AREA ALARM PANEL ALARMING							
FO-334735	12/11/2015	202	Not Finished	REPAIR LIGHT SENSOSR. LIGHTS ARE GOING OFF EVERY 3 MINUTES. ROOM 1							
FO-338041	1/27/2016	155	Created	Trade: Command Center							
FO-348245	5/24/2016	37	Created	AUDITORIUM STE 1400 TOO COLD, PLEASE ADJUST TEMP							
FO-349592	6/8/2016	22	Created	FIRE TROUBLE ALARM.							
FO-351271	6/30/2016	0	Created	POWER BUMP APPR 10:45AM PLS CK EQUIP							
FO-351272	6/30/2016	0	Created	POWER BUMP APPR 10:45AM PLS CK EQUIP							
E - Southeast				82	33	15	9	25	0	0	
FO-338352	2/1/2016	150	Created	RM 2222 NEED BREAKER RESET							
FO-338681	2/2/2016	149	Created	INSIDE STE 2317 RM 2321 HAS BLACK SOOT COMING OUT OF AIR VENTS							
FO-339274	2/10/2016	141	Created	TOILET NOT FLUSHING. ROOM 3301. (AAUP OFFICE)							
FO-339346	2/11/2016	140	Created	CONTRACTOR NEEDS ACCESS TO TELCOM RM							
FO-339742	2/16/2016	135	Created	RM 109 LEAKING RADIATOR							
FO-339755	2/16/2016	135	Created	PLEASE GIVE JIM HEART ACCESS TO THE ROOF AT 12 NOON 734-709-5307							
FO-339980	2/19/2016	132	Created	FIRE TROUBLE ALARM							
FO-340106	2/22/2016	129	Created	JIM HART FROM 123 NET WILL BE ARRIVING AT 12PM PLEASE MEET BEHIND BL							
FO-340261	2/23/2016	128	Created	FIRE TROUBLE ALARM							
FO-340369	2/24/2016	127	Created	FIRE TROUBLE ALARM							
FO-340454	2/25/2016	126	Created	FIRE TROUBLE ALARM.							
FO-340559	2/26/2016	125	Created	FIRE TROUBLE ALARM							
FO-340719	2/29/2016	122	Created	RM 10505 AND SURROUNDING AREAS HAVE NO HEAT							
FO-341262	3/2/2016	120	Created	FIRE TROUBLE ALRM. PANEL IN BASEMENT.							
FO-341449	3/4/2016	118	Created	RM 112/AUDITORIUM HAS AN EVENT ALL DAY TODAY @ THE MOMENT IT IS TOO							
FO-341532	3/7/2016	115	Created	RM 2317 IS STILL TOO HOT ONGOING (pls speak w/Loretta) *HEALTH ISSUE*							
FO-341547	3/7/2016	115	Created	ENTIRE BLDG TOO WARM							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-341873	3/10/2016	112	Created	Entire building is cold, please adjust temperature.						
FO-342073	3/14/2016	108	Created	NO POWER IN ROOM 2222.						
FO-342283	3/17/2016	105	Created	POWER BUMP. FIRE TROUBLE ALARM.						
FO-342289	3/17/2016	105	Created	BLOWN FUSE. ROOM 5016.						
FO-342368	3/18/2016	104	Created	5TH FL RM BETWEEN 5300 & 5310 TOO COLD						
FO-342369	3/18/2016	104	Created	FIRE TROUBLE ALARM.						
FO-342875	3/22/2016	100	Created	RM 109 HAS A RADIATOR THAT IS MAKING A LOUD HISSING NOISE & ALSO LEA						
FO-342899	3/22/2016	100	Created	BSMT ARCHIVES/STUDENT RECORDS VAULT IS OVER 80degrees						
FO-343672	4/1/2016	90	Created	FIRE TROUBLE ALARM						
FO-343758	4/4/2016	87	Created	4TH FL SAR ENTRANCE NEAR STAIRWELL, LOUD NOISE ABOVE OCCUPANTS C						
FO-343773	4/4/2016	87	Created	VERY STRONG FOUL ODOR. 2ND FLOOR ROOM 201.4						
FO-344223	4/5/2016	86	Created	RM 201.4 STILL HAS A VERY STRONG CHEMICAL SMELL W/IN RM IS EVEN STRO						
FO-344501	4/8/2016	83	Created	1ST FLR LOBBY AREA JANITOR'S CLOSET HAS A SEWER GAS SMELL						
FO-344623	4/12/2016	79	Created	BLDG NEED TO REBOOT RTU (Refer to WO FO-343469 vendor)						
FO-344780	4/14/2016	77	Created	RM 5016 BLOWN FUSE						
FO-344927	4/18/2016	73	Created	TED WITH EXPERT SERVICES NEEDS TO GET INTO THE LOWER LEVEL LIBRARY						
FO-345623	4/19/2016	72	Created	RM 12002.3 IS TOO HOT						
FO-346945	5/6/2016	55	Created	FIRE TROUBLE ALARM						
FO-347479	5/17/2016	44	Created	BLDG FAP FIRE TROUBLE ALARM ACTIVE						
FO-347498	5/17/2016	44	Created	RM 3101 VENT MAKING LOUD NOISE						
FO-347517	5/17/2016	44	Created	BLDG FAP FIRE TROUBLE ALARM ACTIVE ***AGAIN***						
FO-347562	5/18/2016	43	Created	FIRE TROUBLE ALARM						
FO-347584	5/18/2016	43	Created	PLEASE OPEN 15002 CONTRACTOR AT DOOR WAITING FOR ENTRY						
FO-347661	5/19/2016	42	Created	FIRE TROUBLE ALARM						
FO-347720	5/20/2016	41	Created	HANDICAP ENTRANCE BOTH INSIDE/OUTSIDE ENTRY Door no. 071-002N WERE S						
FO-347795	5/23/2016	38	Created	Office is constantly cold, cannot regulate. Can vent be turned down or off? Thank you.						
FO-348236	5/24/2016	37	Created	RM 7904.2 TOO HOT						
FO-348458	5/26/2016	35	Created	RM 6303 IS STILL TOO HOT						
FO-348500	5/26/2016	35	Created	7TH FLR HALLWAY OUTSIDE OF RM 7908 ACU IS LKNG FROM CLNG						
FO-348505	5/26/2016	35	Created	RM 2317 TOO HOT						
FO-348510	5/26/2016	35	Created	FIRE TROUBLE ALARM						
FO-348560	5/27/2016	34	Created	RM 4226.06 IS EXTREMELY HOT						
FO-348719	5/31/2016	30	Created	4TH FL EAST WING HAS NO AIR, 4302/4000 TOO HOT						
FO-348934	5/31/2016	30	Created	RM 5016 TOO HOT						
FO-348943	5/31/2016	30	Created	FAP/BSMT FIRE TROUBLE ALARM						
FO-348984	5/31/2016	30	Created	RM 13001.1 NEED BREAKER RESET						
FO-348986	5/31/2016	30	Created	RM 13001.2 NEED BREAKER RESET						
FO-348988	5/31/2016	30	Created	RM 13001.3 NEED BREAKER RESET						
FO-349269	6/3/2016	27	Created	NO DOMESTIC HOT WATER						
FO-349339	6/6/2016	24	Created	FIRE TROUBLE ALARM.						
FO-349365	6/6/2016	24	Created	RM 12208.2 IS TOO HOT						
FO-349533	6/8/2016	22	Created	BLDG FAP FIRE TROUBLE ALARM						
FO-349700	6/10/2016	20	Created	BLDG FIRE TROUBLE ALARM						
FO-349723	6/10/2016	20	Created	RM 6230.01 NEED BREAKER RESET						
FO-349724	6/10/2016	20	Created	RM 6230.02 NEED BREAKER RESET						
FO-349829	6/13/2016	17	Created	RM 50000 IS EXTREMELY COLD						
FO-349830	6/13/2016	17	Created	RM 50002 IS EXTREMELY COLD						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349903	6/14/2016	16	Created	FAP FIRE TROUBLE ALARM ACTIVE AGAIN							
FO-349920	6/14/2016	16	Created	RM 6400 IS TOO COLD							
FO-350045	6/16/2016	14	Created	BLDG FAP FIRE TROUBLE ALARM ACTIVE							
FO-350087	6/16/2016	14	Created	FIRE TROUBLE ALARM							
FO-350255	6/20/2016	10	Created	RM 4108 NO AC TOO HOT							
FO-350269	6/20/2016	10	Created	SMOKY SMELL IN ROOM 207, BASEMENT AND THROUGHOUT BUILDING.							
FO-350720	6/22/2016	8	Created	8203.2 & 8001 TOO COLD							
FO-350721	6/22/2016	8	Created	8201 TOO HOT							
FO-350744	6/23/2016	7	Created	6201 CONF RM B TOO HOT, HEAT IS ON PLEASE ADJUST TEMP							
FO-350752	6/23/2016	7	Created	RM 6203 IS TOO HOT							
FO-350787	6/23/2016	7	Created	RM 2217 IS TOO COLD							
FO-351047	6/27/2016	3	Created	RM 8405.5 IS TOO HOT							
FO-351058	6/27/2016	3	Created	FAP FIRE TROUBLE ALARM							
FO-351071	6/27/2016	3	Created	ELEC							
FO-351101	6/28/2016	2	Created	FIRE TROUBLE ALARM.							
FO-351127	6/28/2016	2	Created	FIRE TROUBLE ALARM.							
FO-351140	6/28/2016	2	Created	FIRE TROUBLE ALARM.							
FO-351284	6/30/2016	0	Created	IDF (Intermediate Data Frame) Room 119 has audible alarm. Display on wall unit rea							
E - West				3	3	0	0	0	0	0	
FO-351224	6/29/2016	1	Created	RM 00025 CLNG TILES ARE DAMP & MISSING PLS CK FOR LEAK							
FO-351265	6/30/2016	0	Created	POWER BUMP APPR 10:45AM PLS CK EQUIP							
FO-351268	6/30/2016	0	Created	FIRE TROUBLE ALARM.							
Medium				94	43	19	10	21	1	0	51
E - Auxiliary				6	6	0	0	0	0	0	
H-58762	6/1/2016	29	Created	The higher urinal is not flushing.authenticated user: Andrew Moore - fh0457requester							
H-58897	6/16/2016	14	Created	The hot water from the shower is not working.authenticated user: Nicole Fry - eq0918							
H-58947	6/20/2016	10	Created	FRONT DESK: outlet damaged at Chats front deesk near fire alarm panel. authenticat							
H-59030	6/27/2016	3	Created	needs new shower headauthenticated user: Devan Keys - fv3230requester ip addres							
H-59093	6/27/2016	3	Created	Air conditioner not working authenticated user: Jamone Lewis - em8190requester ip							
H-59104	6/28/2016	2	Created	A/C in 532 is not working - Ghafari							
E - Command Center				23	12	5	5	1	0	0	
FO-343471	3/30/2016	92	Hold for Funds	boilers 1 2 3 have trouble maintaining loop temp,below set point, reset flame failure alar							
FO-344745	4/13/2016	78	Created	Trade: Command CenterPriority: MediumR/R RM 00000.62/MECH BLR RM Please							
FO-344747	4/13/2016	78	Created	Trade: Command Center							
FO-345629	4/19/2016	72	Not Finished	Trade: Command Center							
FO-345630	4/19/2016	72	Not Finished	Trade: Command Center							
FO-345793	4/22/2016	69	Created	Adjust/rebuild probes to pumps for condensate tank							
FO-346724	5/3/2016	58	Created	EMERGENCY/CONTROLS							
FO-347533	5/17/2016	44	Created	Trade: Command CenterPriority: MediumR/R PENTHOUSE The side stream filter f							
FO-347632	5/19/2016	42	Created	Trade: Refrig Crew Priority: Medium							
FO-347850	5/23/2016	38	Created	Repair RTU							
FO-348437	5/26/2016	35	Created	Trade: Control							
FO-348734	5/31/2016	30	Parts on Order	COMMAND CTR,							
FO-349534	6/8/2016	22	Created	Controls Crew-							
FO-349601	6/8/2016	22	Created	Boiler #2 does not start-up properly. See Greg Ray for details.							
FO-349730	6/10/2016	20	Parts on Order	Please provide and install air station (i.e. regulator and air dryer) for cooling tower conde							
FO-349767	6/11/2016	19	Created	Controls- med priority- Hot call room 8314-							
FO-349918	6/14/2016	16	Created	Trade: Controls Priority: Medium							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-350564	6/21/2016	9	Created	Repair air conditioning unit serving 306, Shapiro. Unit is not cooling. Condenser located							
FO-350658	6/22/2016	8	Created	Controls- med priority- repair/replace malfunctioning fire-eye on boiler number1.							
FO-351154	6/28/2016	2	Created	Repair spot cooler unit #4 located in grounds storage.							
FO-351242	6/30/2016	0	Created	Controls- Medium priority-R/R PH - AHU #12 has a hot deck steam valve that is huntin							
FO-351296	6/30/2016	0	Created	Controls: Med High PriorityR/R BLDG - NOTE: Chiller REQ in Operator 2 Concerning t							
FO-341941	9/1/2016	-63	Hold for Funds	Trade: Command Center							
E - MedPharm				32	12	10	2	8	0	0	
FO-331326	1/8/2016	174	Created	REFER SHOP:							
FO-336866	1/13/2016	169	Created	RM 2268/CLASS RM IS TOO COLD							
FO-336868	1/13/2016	169	Created	RM 3125/CLASS RM IS TOO COLD							
FO-337587	1/21/2016	161	Created	RM 6137 PLEASE CHECK AIR FLOW, OCCUPANTS EYES ARE RUNNING							
FO-338035	1/27/2016	155	Created	GARAGE/DOCK (BAY AREA) CLNG UNIT HEATER IS LEAKING CAUSING FLOODIN							
FO-341804	3/9/2016	113	Created	BSMT NEAR MORGUE RM 525 HAS A BAD SMELL							
FO-341890	3/10/2016	112	Created	RM 5344 IS STILL TOO HOT (from yesterday)							
FO-342101	3/14/2016	108	Created	3117, 3120, 3122, 3126, 3141 are all too cold.							
FO-346223	4/27/2016	64	Created	TOO HOT. FREEZER ROOM. ROOM 4210.							
FO-346334	4/29/2016	62	Created	TOO COLD. ROOM 2602.1							
FO-346380	5/2/2016	59	Created	clean dryer duct work							
FO-346794	5/4/2016	57	Created	RM 2320 TOO HOT.							
FO-346796	5/4/2016	57	Created	There seems to be no air flow in this office. This needs attention as CMMG wants to mo							
FO-346797	5/4/2016	57	Created	Room 3343 - Room is too hot. This is an on going problem and CMMG want to move a r							
FO-346818	5/4/2016	57	Created	NO AIR FLOW. ROOM 6111.							
FO-347316	5/12/2016	49	Created	TOO HOT IN ROOMS 2290 AND 2226.							
FO-347350	5/13/2016	48	Created	Temperature is too cold. 68 degrees. Engineer was out yesterday and rather than get							
FO-347526	5/17/2016	44	Created	TOO COLD. ROOM 3145.							
FO-348350	5/25/2016	36	Created	TOO HOT. ROOM 2540.							
FO-348496	5/26/2016	35	Created	TOO HOT. ROOMS 3250 & 3145.							
FO-349033	6/1/2016	29	Created	TOO COLD. ROOM 3430.							
FO-349250	6/3/2016	27	Created	RM 7119 PLEASE CHANGE FILTER							
FO-349713	6/10/2016	20	Created	TOO WARM. 1ST FLOOR.							
FO-349793	6/13/2016	17	Created	TOO HOT. ROOM 2213.							
FO-349990	6/15/2016	15	Created	TOO COLD. ROOM 2128.							
FO-350075	6/16/2016	14	Created	TOO HOT. ROOMS 5455, 5447 & 5451.							
FO-350085	6/16/2016	14	Created	RM 5263 IS STILL TOO HOT							
FO-350234	6/20/2016	10	Created	TOO HOT. ROOM 1548.							
FO-350240	6/20/2016	10	Created	TOO WARM. 1ST FLOOR INCLUDING ROOM 1130.							
FO-350268	6/20/2016	10	Created	TOO HOT. ROOM 3250.							
FO-350762	6/23/2016	7	Created	Can the air in the Admissions Office be turned down?							
FO-351137	6/28/2016	2	Created	TOO HOT. ROOM 2121.							
E - North				2	0	0	1	0	1	0	
FO-327014	9/16/2015	288	Created	Loose Breakers, please repair.							
FO-344572	4/11/2016	80	Created	Refrig. Crew:							
E - Northeast				2	2	0	0	0	0	0	
FO-350853	6/24/2016	6	Created	SEWAR SMELL IN THE AREA OF ROOM 033.							
FO-351280	6/30/2016	0	Created	TOO WARM. ROOM 083.							
E - Preventative Maintenance				1	1	0	0	0	0	0	
FO-351306	6/30/2016	0	Created	TOO HOT. ROOM 081.							
E - Southeast				26	8	4	2	12	0	0	

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-336924	1/14/2016	168	Created	TOO HOT. ROOM 2317.							
FO-338145	1/28/2016	154	Created	TOO COLD. 6000 SUITE INCLUDING ROOM 6402.9							
FO-338736	2/3/2016	148	Created	DOOR ALARM. EAST STAIRWELL. CANCEL WORK ORDER REQUEST PER JODY.							
FO-339100	2/8/2016	143	Created	The heater does not work again in office 14200.10. Please help to check it since the in							
FO-339525	2/15/2016	136	Created	Hi, Thanks for the staff's working on the heater last week. I am not sure have they co							
FO-339863	2/17/2016	134	Created	EXTREMELY COLD. ROOM 8202.3.							
FO-340105	2/19/2016	132	Created	COLD AIR BLOWING. ROOMS 13400.2 AND 13400.1.							
FO-341326	3/3/2016	119	Created	Please turn the heat back on, its cold in the building all week							
FO-341363	3/3/2016	119	Created	TOO COLD. ROOM 10505.							
FO-341437	3/4/2016	118	Created	REQUESTING TELCOM RM TO BE OPENED							
FO-341853	3/10/2016	112	Created	PROBLEM WITH AIR PRESSURE. DOORS HARD TO OPEN.							
FO-342055	3/14/2016	108	Created	TOO COLD. BUILDING							
FO-344996	4/18/2016	73	Created	AC does not work. It is so hot inside the office. Please help to check it.Thanks!							
FO-344994	4/18/2016	73	Created	TOO HOT. ROOM 12002.3							
FO-346750	5/3/2016	58	Created	TOO HOT. ROOM 12002.3.							
FO-348328	5/25/2016	36	Created	TOO HOT. ROOM 7906.1.							
FO-348369	5/25/2016	36	Created	TOO HOT. ENTIRE SUITE 2317.							
FO-348580	5/27/2016	34	Created	Very hot temperatures in all of Rackham Building. Air conditioner needs to be fixed AS							
FO-349092	6/1/2016	29	Created	TOO COLD. ROOM 14101.3.							
FO-349509	6/7/2016	23	Created	TOO COLD. ROOM 6400.							
FO-349841	6/13/2016	17	Created	Room 047 Dr. Rakhlin's lab in the basement is too cold.							
FO-350582	6/21/2016	9	Created	Air is not working properly. Office is too hot.							
FO-351014	6/27/2016	3	Created	TOO COLD. ROOM 4100.							
FO-351043	6/27/2016	3	Created	TOO COLD. ROOM 4226.							
FO-351105	6/28/2016	2	Created	No air. Office is too hot.							
FO-351107	6/28/2016	2	Created	No air. Office is too hot.							
E - West				2	2	0	0	0	0	0	
FO-351213	6/29/2016	1	Created	TOO COLD. ROOM 137.							
FO-351214	6/29/2016	1	Created	No air in office--too hot.							
Low				181	60	41	21	54	3	2	121
E - Area 2 Engineer				2	0	0	1	1	0	0	
FO-341271	3/2/2016	120	Created	request chemicals for boilers and 3 test kits							
FO-343671	4/1/2016	90	Created	replace leaking seal\bearing assembly for the hwh loop							
E - Auxiliary				34	19	11	2	2	0	0	
H-57257	2/11/2016	140	Created	In the 9th Floor Kitchenette, two of the ceiling lights have bad ballasts that need to be re							
H-57541	3/2/2016	120	Created	There are 3 hand sinks at Gold N Greens that need repair. One does not function, handl							
H-58084	4/18/2016	73	Created	AC is not working. Also, it sometimes makes a weird sound.authenticated user: Andre							
H-58235	4/29/2016	62	Created	The under sink garbage disposal grinder has stopped working. Because of it the kitchen							
H-58480	5/3/2016	58	Created	Leak in ceiling over door-side bed's night-stand.authenticated user: Austin Morales - fv							
H-58481	5/8/2016	53	Created	Toilet handle leaking when flushed authenticated user: Abigail Landskroener - fk9925							
H-58368	5/10/2016	51	Created	Toilet does not flush.authenticated user: Nicole Fry - eq0918requester ip address: 14							
H-58383	5/11/2016	50	Created	The exhaust in the bathroom is not working and a small door on our room's ceiling is op							
H-58415	5/12/2016	49	Created	ENGINEERING: Inspect shower for leaking issues.authenticated user: Prentis Gipson							
H-58412	5/12/2016	49	Created	Air conditioning unit isn't working. The vent isn't blowing out cool air.authenticated user							
H-58451	5/16/2016	45	Created	bathroom sink flange broke and needs to be replacedauthenticated user: Rheana Alle							
H-58509	5/19/2016	42	Created	Most inner bathroom vent isn't working and it is giving off a very bad smell. Smells like b							
H-58531	5/20/2016	41	Created	EXHAUST FAN IN KITCHEN NOT WORKINGauthenticated user: Suraj Varma Kalidin							
H-58598	5/26/2016	35	Created	light switch is not working at all - 627 Ghafari							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
H-58606	5/27/2016	34	Created	light switch broken off, 638 Ghafari						
H-58780	6/7/2016	23	Created	Problem with flush tank of Bathroom 2, water keeps flowing into the drain.authenticate						
H-58776	6/8/2016	22	Created	The Ac/Heat unit is not working properly. The cool setting is on but lounge is 82 degrees						
H-58828	6/10/2016	20	Created	A/C not working behind the front desk area - Ghafari						
H-58859	6/13/2016	17	Created	AC is brokeauthenticated user: Garrett Sears - fh9529requester ip address: 35.16.23						
H-58884	6/13/2016	17	Created	Shower is not working.authenticated user: Rheana Allen - fh1699requester ip addres						
H-58911	6/16/2016	14	Created	The water in the toilet nearest the door is constantly running making a waterfall like sou						
H-58912	6/17/2016	13	Created	hi, our apt #220, exhaust fan isn't working. the reason may be due to faulty cables. ple						
H-58920	6/17/2016	13	Created	Urinal in first floor bathroom is leaking.						
H-58930	6/17/2016	13	Created	Conference guest in ghafari hall has air that is not working properly. ie, hard to sleep.a						
H-59015	6/24/2016	6	Created	AC-Compressor not running. The room ranges from 78-80 degrees on any given day.a						
H-59098	6/24/2016	6	Created	Bathroom shower head is loose authenticated user: Dreana Williams - fi2266request						
H-59063	6/26/2016	4	Created	Kitchen sink motor not working.authenticated user: Swapnil Chouknis - fy4968reques						
H-59110	6/28/2016	2	Created	Doesn't have sink pop upauthenticated user: Thomas Wolf - fj0736requester ip addr						
H-59120	6/28/2016	2	Created	Kitchen sink grinder is not working and sink is clogged.authenticated user: Naman Ch						
H-59121	6/28/2016	2	Created	Power outlet not working.2nd bedroom, left wall, 1st outlet from door.authenticated u						
H-59103	6/28/2016	2	Created	A/C in room 515 does not work - Ghafari						
H-59109	6/29/2016	1	Created	The thermostat in Ahmad's office is completely blank. authenticated user: Amanda Fu						
H-59113	6/29/2016	1	Created	Dinning room light fixture is broken. authenticated user: Tamika Davis - eq2532reque						
H-59123	6/29/2016	1	Created	The crushers in the sink are not functioning properly.authenticated user: Karthik Shara						
E - Command Center			35	16	10	6	3	0	0	
FO-337648	1/22/2016	160	Hold for Funds	REPAIR LOW WATER CUT OUT. MAKE UP TANK.						
FO-342291	3/17/2016	105	Parts on Order	REFRIDGE/CONTROLS (MED)						
FO-343284	3/28/2016	94	Project is under construction	Boiler # 2 High Efficiency Gas Burner BACNet controller not communicating data to Insi						
FO-340347	4/1/2016	90	Created	Spring 2016 - (APRIL/MAY)						
FO-344746	4/13/2016	78	Hold for Funds	ac/burner crew-						
FO-344770	4/14/2016	77	Created	BAS section: Please run BLN wiring form office area rtu to rtu 1 in preparation for conn						
FO-344919	4/18/2016	73	Created	please have controls group check chilled water pump #3 will not run check graphics for						
FO-346236	4/28/2016	63	Project is under construction	BAS section: Please install virtual AEM into field panel for RTU 1, set up system on net						
FO-346274	4/28/2016	63	Created	HEATER MAKING A VERY LOUD NOISE. SOFTBALL BUILDING. BATTING TUNNEL						
FO-346907	5/5/2016	56		BAS- REWRITE TEC NIGHT SETBACK PROGRAMS FOR ALL PANELS. CURRENT						
FO-347008	5/9/2016	52	Parts on Order	Bas section:						
FO-347010	5/9/2016	52	Created	BAS Section:R/B BLDG Review hazmat bldg. usage, consult with bldg. coordinator r						
FO-347427	5/16/2016	45	Created	CONTROLS/SIEMENS						
FO-347435	5/16/2016	45	Created	BAS Section:						
FO-347599	5/18/2016	43	Created	Scott Hall - Rm 3329						
FO-347859	5/23/2016	38	Created	Following-up on air-conditioning in Tierney House with Carol Dargin and team. Air-condit						
FO-348484	5/26/2016	35	Created	AC Shop-						
FO-348499	5/26/2016	35		R/R RM 1281 please have controls make adjustment to room 1281. hot call						
FO-348523	5/26/2016	35	Created	REF SHOP						
FO-348953	5/31/2016	30	Hold for Funds	Controls						
FO-349085	6/1/2016	29	Created	saddle valve for humidification will not close off						
FO-349541	6/8/2016	22	Hold for Funds	Controls						
FO-349964	6/15/2016	15	Created	Heat Pump 4-12 Not Working						
FO-349965	6/15/2016	15	Created	Heat Pump 4-13 Not Working						
FO-349966	6/15/2016	15	Created	Heat Pump 4-15 Not Working						
FO-350082	6/16/2016	14	Created	BAS: R/R BSMT Please order and install a new PXC processor for generator field pa						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-350174	6/17/2016	13	Created	Repair condensing unit #2 is not functioning properly.						
FO-350279	6/20/2016	10	Not Finished	Attention: Carrol Dargen. Please can you send someone over to take a look at PS6 air c						
FO-350609	6/21/2016	9	Created	BAS section: Please troubleshoot boiler 2 Bacnet field panel connection issues.						
FO-350816	6/23/2016	7	Created	Controls group-						
FO-350844	6/24/2016	6	Created	Controls						
FO-351018	6/27/2016	3	Created	R/R PH please have the controls group check out tower #3 it is out of service.						
FO-351181	6/29/2016	1	Created	R/R RM 00100/MECH RM please have the controls group check float controls on make						
FO-351293	6/30/2016	0	Created	The first three fume hoods on the north wall are not						
FO-339198	7/1/2016	-1	Parts on Order	Boiler Crew-						
E - MedPharm			63	15	13	4	29	2	0	
FO-328269	9/29/2015	275	Created	ALL THE LIGHTS ARE OUT IN ROOM 247.						
FO-336480	12/22/2015	191	Created	R/R Room 406 Dryer vent needs to be cleaned out.						
FO-336393	1/7/2016	175	Created	in room 3220, the chemical fume hood has a high						
FO-336394	1/7/2016	175	Created	Fume hood #3 has a high face velocity (198 fpm).						
FO-336395	1/7/2016	175	Created	Fume hood #2 has a high face velocity (179 fpm).						
FO-336396	1/7/2016	175	Created	Fume hood #10 has a high face velocity (162 fpm).						
FO-336397	1/7/2016	175	Created	Fume hood #12 has a high face velocity (144 fpm).						
FO-336871	1/13/2016	169	Created	Fume hood #11 in this lab is running too low (68						
FO-337301	1/19/2016	163	Created	Refrig crew. Boiler no. 2 keeps tripping on flame failure. Priority high.						
FO-337574	1/21/2016	161	Created	Air filters need to be changed in rooms 404,411,412,413,414,415,416,417,419,423						
FO-337585	1/21/2016	161	Created	LAB 9327 FUME HOOD NOT OPERATING PROPERLY						
FO-338054	1/25/2016	157	Created	Filters in kitchen need to be changed. There are approximately 21 on the wall. The unit						
FO-337959	1/26/2016	156	Created	RM 1348/KITCHEN AREA VERIFY THE STANDARD REFRIGERATOR PROBLEM IT I						
FO-338093	1/28/2016	154	Created	The thermostat on the back side of the proscenium on the south side of the stage has di						
FO-338095	1/28/2016	154	Created	The battery backup system is reading "Output is on bypass". Is this normal? Please rep						
FO-338786	2/3/2016	148	Created	please deliver 15 bags of salt for Reverse Osmosis system in the penthouse Scott Hall						
FO-338789	2/3/2016	148	Created	please deliver 1 pallet of nikrocleanse to room 100 Scott Hall.FO-327323						
FO-338790	2/3/2016	148	Created	please deliver 15 bags of salt to 3rd floor mechanical area for reverse osmosis system a						
FO-338931	2/5/2016	146	Created	Elliman Day Engineer- med priority- please install filter material in Supply vents (5) of r						
FO-339032	2/5/2016	146	Created	Rm. 3530 has a Laminar Hood with a UV lamp out and needs replacing.						
FO-339439	2/12/2016	139	Created	Office is cold.						
FO-340458	2/25/2016	126	Created	RM 414 HASW A HI TEMP						
FO-340459	2/25/2016	126	Created	RM 200.06 HAS A LOW TEMP						
FO-340460	2/25/2016	126	Created	RM 200.07 HAS A LOW TEMP						
FO-341508	3/7/2016	115	Created	Eye wash in inner lab of MD lab 2125. need immediate attention , water pressure extre						
FO-341750	3/9/2016	113	Created	Tighten toilet seat bathroom room 402						
FO-341893	3/10/2016	112	Created	Lab 3341, fume hood 6 has a light out and needs replacing.						
FO-342220	3/16/2016	106	Created	CHEMICAL W/DRAWAL FO-327276						
FO-342843	3/22/2016	100	Created	Tony, there is a CFH in 4420, which is a room designated as a classroom. The hood i						
FO-343178	3/25/2016	97	Created	Eyewash system was installed in Lab 7130; customer currently has bucket under sink,						
FO-343427	3/29/2016	93	Created	Engineers. Please remove the filter type bonnets covering the supply air vents and repla						
FO-344375	4/7/2016	84	Created	Office 3515 needs to have the ceiling checked for possible leaks where stained ceiling ti						
FO-344519	4/8/2016	83	Created	PM Shift reported that AC-11 has many mechanical problems that will soon make it inop						
FO-344552	4/11/2016	80	Created	Rooms 3369, 3359, 3363 are very warm. Blowing hot ait. Need cooler air onto these are						
FO-346111	4/26/2016	65	Created	Please have Building engineer visit lab 4237 and remove the dirty old bonnets from the						
FO-346754	5/3/2016	58	Created	Rooms 411,412,413,414,415,416,417,419,423 All air filters due to be changed						
FO-346798	5/4/2016	57	Created	Vold room has been out of service for over a week. Needs attention.						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-347353	5/13/2016	48	Created	NEED ACCESS INTO BUILDING AND 3RD FLOOR MECHANICAL ROOM.							
FO-347803	5/23/2016	38	Created	Admissions Office is quite cold today. Is is possible to turn the heat up or the air down							
FO-348248	5/24/2016	37	Created	Please work with Dr. Sheshevia to get bonnets placed on supply ducts. Please make an							
FO-348254	5/24/2016	37	Created	The Emergency generator on the roof has been making a whining noise (either an alarm							
FO-348275	5/24/2016	37	Created	Room pressure is Positive, should be negative.							
FO-348456	5/26/2016	35	Created	Air conditioning not working in the server room.							
FO-348515	5/26/2016	35	Created	Rooms 5229 pls ck if all lites are out or if a couple (liting crew has already been there &							
FO-348521	5/26/2016	35	Created	Very Chilly in the Admissions Office.							
FO-348524	5/26/2016	35	Created	Closet- Rm. 214, 216, 218Gas Cylinder storage-Rm. 222Electrical closet- Rm. 221							
FO-348557	5/27/2016	34	Created	RM 00403 High temp							
FO-348558	5/27/2016	34	Created	RM 00403 High humidity							
FO-349010	5/31/2016	30	Created	Chemical Fume Hood glass is stuck and needs to be repaired.							
FO-349398	6/6/2016	24	Created	Very low water pressure in first sink on the right in Dr. Al-Katib's lab. Contact Allison a							
FO-349670	6/9/2016	21	Created	Engineer/Electricians - Room 2105 circuit breaker 31-33 will not reset. Please look at A							
FO-349768	6/11/2016	19	Created	very warm, no air flow.							
FO-349798	6/13/2016	17	Created	Bottom Chamber door on right in room 200.04 at Scott Hall has a broken door guide. T							
FO-349823	6/13/2016	17	Created	It's pretty chilly in the admissions office today, is it possible to turn the air down a little							
FO-350264	6/20/2016	10	Created	Office 1281 (Lisa Keane) is extremly hot.							
FO-350674	6/22/2016	8	Created	INVENTOR STOCK WITHDRAWAL FOR PROCEEDURE IN CLEANING EQUIP							
FO-350793	6/23/2016	7	Created	need to identify which elev is having a problem either 1 or 2							
FO-350817	6/23/2016	7	Created	Please adjust the timer on the lights along the sidewalk in front of Elliman. I noticed th							
FO-351190	6/29/2016	1	Created	The spray nozzle of the wet table leaks water when the water is turned on. In room 5							
FO-351198	6/29/2016	1	Created	RM 00243 HAS LOW TEMP							
FO-351200	6/29/2016	1	Created	RM 00247 HAS LOW TEMP							
FO-351201	6/29/2016	1	Created	RM 00249 HAS LOW TEMP							
FO-351212	6/29/2016	1	Created	FIRE TROUBLE ALARM.							
E - North				5	1	1	1	1	0	1	
FO-316486	5/4/2015	423	Not Finished	ROOF HATCH ALARM							
FO-343147	3/24/2016	98	Created	Ceiling leak in Mens restroom in Com Art bldg.							
FO-345680	4/20/2016	71	Created	PLD TECH NEEDS ACCESS TO PRIMARY RM PH #313-971-2778							
FO-347666	5/19/2016	42	Created	GALLERY AREA BLOWN FUSE							
FO-351207	6/29/2016	1	Created	mechanical room making a weird loud noise.							
E - Northeast				3	1	1	0	1	0	0	
FO-337747	1/25/2016	157	Created	2ND FL MRS WILSON'S AREA OUTLETS NOT WORKING, UNABLE TO USE PHONE							
FO-346916	5/5/2016	56	Created	cooler alarm is sounding. temp is 50 degrees should be 38-44 degrees							
FO-349229	6/3/2016	27	Created	ASSIST & MEET W/WTR SAMPLING PH #248-763-4915							
E - Preventative Maintenance				1	1	0	0	0	0	0	
FO-351160	6/28/2016	2	Created	The occupants of Rm 410.2 are stating that the room is rather cold. The digital therm							
E - South				6	1	1	1	2	0	1	
FO-312363	3/24/2015	464	Created	CALLED SCHINDLER ELEV CO FOR OFC WING PASS ELEV 2ND FLR DOORS CLO							
FO-342837	3/22/2016	100	Created	Emergency safety shower has very low flow.							
FO-342838	3/22/2016	100	Created	Emergency safety shower has very low flow.							
FO-345695	4/20/2016	71	Created	The power outlets are out in room 2041. Thank you.							
FO-347344	5/13/2016	48	Created	NEED ACCESS TO ROOF							
FO-349817	6/13/2016	17	Created	AC is constantly running so we are too cold in room 150 Art Bldg.							
E - Southeast				31	5	4	6	15	1	0	
FO-334631	12/10/2015	203	Created	Controls,							
FO-337686	1/22/2016	160	Created	No air circulation/heat. Please reset HVAC system.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-338117	1/28/2016	154	Created	The heater does not work today. Last time the staff told me it needs some manual res						
FO-338172	1/29/2016	153	Created	3rd floor Ladies restroom has a foul odor coming from floor drain.						
FO-338302	2/1/2016	150	Created	There is a leak in the ceiling in the audiology clinic room in the basement in their office r						
FO-339566	2/15/2016	136	Created	#2 GAS VALVE WILL NOT LIGHT.						
FO-339982	2/19/2016	132	Created	Thermostat in main room is leaking. Have inspection soon. Needs to be adjusted please						
FO-340733	2/29/2016	122	Created	No power to outlets in room 205, perhaps a fuse blown						
FO-341217	3/2/2016	120	Created	EngineerR/R RM 00010/MECH RM replace #1 condensate pump seal on receiver CP-						
FO-341275	3/2/2016	120	Created	NEED ACCESS TO TELE CLOSET						
FO-341510	3/7/2016	115	Created	Getting complaints that it is cold in room 207.						
FO-341519	3/7/2016	115	Created	Upper floors (3 and 4) temps are rising, too warm.						
FO-342432	3/21/2016	101	Created	Mrs. Garza-Prisby said her office is very cold she is in the basement room 004.1.						
FO-342850	3/22/2016	100	Created	Engineer-R/R RM 00030/MECH RM please replace blown fuse in Main Air Compresso						
FO-342863	3/22/2016	100	Created	HOLE NEAR SINK IN CLOSET INSIDE ROOM 8201. PLEASE CHECK.						
FO-342885	3/22/2016	100	Created	I am in 201.4, but don't see that on the list. My radiator was making a funny noise yest						
FO-344425	4/8/2016	83	Created	Three questions --						
FO-344845	4/15/2016	76	Created	The heat sensor is malfunction. The office is extremely hot.						
FO-346176	4/27/2016	64	Created	In cage holding area, the smoke detector has broken. Needs to be replaced, covered, s						
FO-346178	4/27/2016	64	Created	Outside the room, in the middle of the hallway, there is a ceiling leak. Thank you, Susa						
FO-346180	4/27/2016	64	Created	Chronic leak in hallway, because of roof leak. Bucket catching water in the hallway. Tha						
FO-346309	4/29/2016	62	Created	Room 205 at Mott needs to be negative to the hallway. EF-12 needs its timer replaced i						
FO-347012	5/9/2016	52	Created	(ANS MACH/MESSAGE FROM 5/6/16) PUTNAM SIDE HANDICAP DOOR NOT WORK						
FO-347153	5/10/2016	51	Created	TOO HOT. ROOM 2320. (GO THROUGH ROOM 2317)						
FO-348339	5/25/2016	36	Created	The A/C is not working properly, Its too hot in the room feels like 90 degrees. PLEASE						
FO-348485	5/26/2016	35	Created	Engineer--R/R RM 9405.40 Please check air flow and temperatures in Room 9405.4						
FO-349251	6/3/2016	27	Created	Air Conditioner does not work. Please help to turn on the switch. Thanks!						
FO-349925	6/14/2016	16	Created	The temp. is very high. There is no air circulating.						
FO-350700	6/22/2016	8	Created	NEED TO VERIFY WHICH ELEV ISN'T WRKING FREIGHT/NORTH PASS WHICH ON						
FO-350813	6/23/2016	7	Created	Its very warm in the front parlor and in the hall.						
FO-351217	6/29/2016	1	Created	DTE ENERGY NEED ACCESS TO BUILDING. DAVE 313-485-9572.						
E - West			1	1	0	0	0	0	0	
FO-350172	6/17/2016	13	Created	Repair/replace filter on leaking unit in the pool area basement east wall.						
Routine			5	4	0	0	1	0	0	1
E - Northeast			5	4	0	0	1	0	0	
FO-342426	3/21/2016	101	Created	PM to be performed by engineer on overtime to prevent interruption of service in the buil						
FO-351143	6/28/2016	2	Created	Engineer to clean coils on #1 chiller.						
FO-351144	6/28/2016	2	Created	Engineer to clean coils on #2 chiller.						
FO-351145	6/28/2016	2	Created	Engineer to clean coils on #3 chiller.						
FO-351146	6/28/2016	2	Created	Engineer to clean coils on #4 chiller.						
Grounds			15	4	1	0	6	4	0	11
High			4	0	0	0	3	1	0	4
G - Physical Grounds			4	0	0	0	3	1	0	
FO-333160	11/20/2015	223	Created	GLASS ON SIDEWALK BY BUS SHELTER ON ANTHONY WAYNE DRIVE & KIRBY.						
FO-336543	1/11/2016	171	Created	OUTSIDE MAIN ENTRANCE RAMP HAS A SHEET OF ICE						
FO-339912	2/18/2016	133	Created	the driveway behind Reuther heading to Jacob House has a huge oil slick or spill needs						
FO-341473	3/4/2016	118	Created	OUTSIDE OF UGL BLDG NEAR PARKING LARGE CHUNKS OF ICE MELTING FROM						
Medium			3	1	1	0	0	1	0	2
G - Physical Grounds			3	1	1	0	0	1	0	

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-334651	12/10/2015	203	Created	PLUMBERS please r/r sprinkler line isolation valve #3 in basement of 5425 woodward a						
FO-347497	5/17/2016	44	Created	Grounds request: Please trim the tree in the courtyard (east side). It is hanging over						
FO-350788	6/23/2016	7	Created	pls remove / weed whip weeds inside and out side of generator yard and near cooling to						
Low			8	3	0	0	3	2	0	5
G - Physical Grounds			8	3	0	0	3	2	0	
FO-332456	11/12/2015	231	Created	The employee entrance on the north side of the building has a large amount of bird drop						
FO-335033	12/16/2015	197	Created	Stock Issue Request:						
FO-336684	1/12/2016	170	Created	Ramp to get into the parking lot behind the building is very icy and several people have						
FO-339082	2/6/2016	145	Created	I would like to request for our courtyards to be cleaned. Thank you.						
FO-339745	2/16/2016	135	Created	Request salt to be placed on Cass side of the building due to icy conditions. Employee						
FO-350167	6/17/2016	13	Created	use vacuum to clean bottom of granite fountain						
FO-350955	6/24/2016	6	Created	Weeds inside fenced area are 2-3 tall, in front of building. Ned cut down and perhaps sp						
FO-351011	6/27/2016	3	Created	Clean carpet in President's apartment.						
Trades			851	271	84	64	180	206	46	580
Emergency			13	10	2	1	0	0	0	3
T - Carpenter			4	4	0	0	0	0	0	
FO-349910	6/14/2016	16	Created	LOADING DOCK DOOR IS STUCK IN THE UP POSITION.						
FO-349942	6/14/2016	16	Not Finished	HANDICAP DOORS WON'T OPEN.						
FO-350223	6/20/2016	10	Created	LOADING DOCK DOOR IS BROKEN.						
FO-351223	6/29/2016	1	Created	EMERGENCY CARP						
T - Electrician			6	4	1	1	0	0	0	
FO-344868	4/15/2016	76	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT						
FO-348218	5/24/2016	37	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING						
FO-349392	6/6/2016	24	Created	EMERGENCY ELEC						
FO-350859	6/24/2016	6	Created	EMERGENCY ELEC						
FO-350938	6/24/2016	6	Created	Check domestic water heater #1 for power or burned heating elements. Update building						
FO-351253	6/30/2016	0	Created	FIRE TROUBLE ALARM. (BATTERY)						
T - Pipefitter			1	0	1	0	0	0	0	
FO-348331	5/25/2016	36	Created	RM 9228 PIPE BURST ,,,,,,,,,,,,,,,,,, EA/5-25-16 ,,,,,,,,,,,,,,,,,,						
T - Plumber			2	2	0	0	0	0	0	
FO-351281	6/30/2016	0	Created	URINAL PIPE HAVE BURST MEN'S RESTROOM ON THE SOUTHSIDE OF THE FOO						
FO-351282	6/30/2016	0	Created	LOW TO NO WATER PRESSURE IN RESTROOMS ON ALL FLOORS,,,,,,,,,,,,,,,,, DB/6						
High			244	63	18	15	69	65	14	181
T - Carpenter			18	13	0	2	2	1	0	
FO-334671	12/10/2015	203	Created	2ND FL WEST. END, LOUNGE AREA SHADE DOWN						
FO-336514	1/8/2016	174	Hold for Funds	Follow up on work order - FO 334978 from December. I have received another request/						
FO-339303	2/10/2016	141	Hold for Funds	Replace broken floor tiles in hallway outside room						
FO-345790	4/22/2016	69	Created	Erect Scaffolding so Controls Group can install the actuators for the 3 way valve located						
FO-346322	4/29/2016	62	Created	WOMENS RM 2116 DOOR NOT LOCKING						
FO-348976	5/31/2016	30	Created	GARAGE DOOR NOT SECURING						
FO-349187	6/2/2016	28	Created	HANDICAP BUTTON NOT WORKING ENTRANCE DOOR DOESN'T OPEN WHEN P						
FO-349357	6/6/2016	24	Created	GARAGE DOOR NOT WORKING						
FO-349518	6/7/2016	23	Created	MAIN ENTRANCE PLEASE REMOVE EXTERIOR TILE SO PEST CONTROLLER CAN						
FO-350129	6/16/2016	14	Hold for Funds	Carpenters, High, Please seal threshold at Putnam lobby doors, rain water coming into						
FO-351147	6/28/2016	2	Created	CARP						
FO-351192	6/29/2016	1	Created	R/R BLDG ENTRY Door 499-14N needs door closer work. Officers and custodians rep						
FO-351194	6/29/2016	1	Created	R/R BLDG ENTRANCE Door 499-01N need door closer adjustment. Doors slam shut a						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-351195	6/29/2016	1	Created	R/R BLDG ENTRANCE Door 499-02N need door closer adjustment. Doors slam shut a							
FO-351225	6/29/2016	1	Created	**ADDING CARPENTERS: replace damaged and missing ceiling tiles in room 313 ASA							
FO-351241	6/30/2016	0	Created	Trade: CarpentryPriority:HighR/R BLDG ENTRANCE DOOR #499-02N won't secure.							
FO-351239	6/30/2016	0	Created	CARP:							
FO-351302	6/30/2016	0	Created	CARP (Okay for Friday Morn)							
T - Electrician				73	18	3	2	25	24	1	
FO-318338	5/29/2015	398	Not Finished	FIRE ALARM SOUNDING Please check system for shorts in the Drum Area, this sho							
FO-324398	8/14/2015	321	Completed	RECEPTION AREA ALARM PANEL ALARMING							
FO-324501	8/17/2015	318	Created	ELECTRICIANS : PLEASE REPLACE OR REPAIR MOTOR TO BOILER ROOM EXHA							
FO-324516	8/17/2015	318	Created	ALARM WONT RESET							
FO-326240	9/2/2015	302	Created	LIGHTS WON'T TURN OFF. ROOM 028.							
FO-327110	9/17/2015	287	Created	Please remove concrete debris from drain repair at garage door of Carpenter lock up 2e							
FO-328514	10/1/2015	273	Created	Laborer -- Priority HighPlease deliver 5 buckets of Oxykor S1100 to boiler room							
FO-328597	10/2/2015	272	Created	There is one of two lights that needs Electrician to fix (shortin light) that is in the vohm le							
FO-328704	10/5/2015	269	Created	ELECTRICAL DEPT-PLEASE CHECK TRANSFORMER BOX IN MECH RM 5,BOX MA							
FO-330887	10/25/2015	249	Created	ELECTRICIANS/ PLEASE CHECK THE VFD ON EXHAUST FAN #9 FAN WONT STAR							
FO-331975	11/4/2015	239	Created	LIGHTS ARE NOT WORKING. ROOM 1310.							
FO-332010	11/5/2015	238	Created	Requesting engineer - No power in rm. 300.2 Prentis.							
FO-332010	11/5/2015	238	Created	Requesting engineer - No power in rm. 300.2 Prentis.							
FO-332248	11/10/2015	233	Created	Change burnt out lights in Room 125 suite at Matthaei. Please see Bob Ostrowski on an							
FO-332530	11/13/2015	230	Created	LABORER TO VACUME & SWEEP UNDER THE SAWS , WORK BENCHES, THE CA							
FO-332609	11/15/2015	228	Created	ELECTRICIANS: PLEASE CHECK HOT WATER PUMP #16, PUMP WONT START LO							
FO-332982	11/18/2015	225	Created	Electricians please open 4800v chiller breaker for Trane. Please contact Mike Polio 248-							
FO-333072	11/18/2015	225	Created	R/R RM 00051/MECH RM HVU #14/Wall unit motor has gone bad							
FO-333326	11/23/2015	220	Created	Remove 3 electrical whips and cap existing wires at the floor junction boxes at the base							
FO-333545	11/25/2015	218	Created	R/R Room 3800 - Overhead light in employee's cube - 1 LO. (Occupant is having a very							
FO-333545	11/25/2015	218	Created	R/R Room 3800 - Overhead light in employee's cube - 1 LO. (Occupant is having a very							
FO-333658	11/30/2015	213	Created	Electricians please close 4800v disconnect for the Bio-Science chiller today please. Me							
FO-334735	12/11/2015	202	Not Finished	REPAIR LIGHT SENSOSR. LIGHTS ARE GOING OFF EVERY 3 MINUTES. ROOM 1							
FO-334774	12/11/2015	202	Created	Room 270.1 - 4 LO							
FO-335111	12/17/2015	196	Created	Purdy Library 4th Floor, Stacks & Open Study Areas across from Room 446							
FO-336413	1/7/2016	175	Created	Time for Safety Meeting for month of January 2016.							
FO-336500	1/8/2016	174	Created	Please install existing aquastat and so we can put pump back in service. The Fitters (Jo							
FO-336770	1/13/2016	169	Created	The alarm horn for the fire evacuation system DOESN'T work , during fire test the horn							
FO-337015	1/15/2016	167	Hold for Funds	Trade: Electricians							
FO-337971	1/26/2016	156	Created	Check, and set limit switches on gate so it will close without causing the chain to come							
FO-338089	1/27/2016	155	Created	This is for the elertical Department please drain water out of light in room 1215 due to l							
FO-338094	1/28/2016	154	Created	The main circuit breaker labeled "House lights" is off yet the house lights are on. Is this							
FO-338163	1/29/2016	153	Created	ADDING ELECTRICIAN : Check switck boxes for sump pumps in basement storage roo							
FO-339318	2/10/2016	141	Hold for Funds	RM 150 LIGHT SWITCH NOT WORKING PROPERLY, ALL THE LIGHTS WONT TUR							
FO-339374	2/11/2016	140	Created	In 3250 (lab), one of the Bio Hood UV lights is broken and needs replacing.							
FO-339442	2/12/2016	139	Created	R/R RM 2218 REPLACED EP 4-4-16 TAGGED LITE (Note: there is only 1 lite out of 2							
FO-340060	2/20/2016	131	Created	please have electricianscheck north supply fan on ahu-8 tripping on overload. reset br							
FO-340306	2/24/2016	127	Created	Electricians- Fire Panel High Priority- Fire Trouble light on Simplex Fire Panel for Scott							
FO-340523	2/26/2016	125	Created	High Priority Need Electricians to replace light bulbs on 2 outdoor lollipop lights on Cas							
FO-341353	3/3/2016	119	Created	**ADDING ELECTRICIAN: Replace condensate pump motor on pump #1 on receiver un							
FO-341402	3/3/2016	119	Created	3rd floor safety lights are out and need repair. They are supposed to come on when pow							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-341495	3/5/2016	117	Created	Trade: ElectricianPriority: HighFire alarm in trouble.						
FO-341837	3/10/2016	112	Created	Trade: ElectricianPriority: HighR/R BSMT AREA Fire alarm trouble. Ground Fault.						
FO-342038	3/12/2016	110	Created	please have electricians check lsp-1 the motor to this trash pump on the dock makes I						
FO-342136	3/15/2016	107	Hold for Funds	lollipop type lights around building and in front of structure #2 not working please check						
FO-342305	3/17/2016	105	Created	Electrician please troubleshoot EX-Fan motor #42, BRK. trip when start button push.Loc						
FO-342372	3/18/2016	104	Hold for Funds	**ADDING ELECTRICIAN ; Please check float switch #2 . See Gerry (Plumber)						
FO-342874	3/22/2016	100	Hold for Funds	Electricians-						
FO-343192	3/25/2016	97	Hold for Funds	trade electricians priority high						
FO-343222	3/25/2016	97	Created	R/R BLDG Please test and repair the emergency battery units on wall within corridors of						
FO-344409	4/7/2016	84	Hold for Funds	R/R RM 2301/RESTROOM Hand dryer is not functioning. there was a report of a burnin						
FO-346343	4/29/2016	62	Created	R/R BASEBALL FIELD ELECTRICAL OUTLET ON B.B. SCOREBOARD HAS RUSTED						
FO-347029	5/9/2016	52	Hold for Funds	MENS RM 2301 HAND DRYER NOT WORKING						
FO-348530	5/26/2016	35	Hold for Funds	repair trash pump. only one working.						
FO-348594	5/27/2016	34	Created	Work order for purchase of UPS unit for overcurrent relays in the Main switch gear for b						
FO-348951	5/31/2016	30	Hold for Funds	ELECTRICIANS						
FO-349210	6/2/2016	28	Created	ELECTRICIANS						
FO-349363	6/6/2016	24	Created	Electrician						
FO-349728	6/10/2016	20	Created	Electricians R&R light fixtures in Gross anatomy labs basement Scott Hall. New class b						
FO-349758	6/10/2016	20	Created	Electricians to replace bad breaker on Elliman chiller that just received new panel install						
FO-349773	6/13/2016	17	Created	Please check Fire Alarm Panel.						
FO-350162	6/17/2016	13	Created	ELEC						
FO-350262	6/20/2016	10	Created	Electricians:Please repair fire panel trouble: "Power supply failure." Was able to silen						
FO-350583	6/21/2016	9	Created	RM 91 CLOCK NOT WORKING						
FO-350764	6/23/2016	7	Created	Trade: Electricians						
FO-350843	6/24/2016	6	Created	ELECTRICIANS: R/R PENTHOUSE Please install a temporary 220volt tap in Penthou						
FO-350842	6/24/2016	6	Created	Transport material and equipment from Pipe Shop to location at Scott Hall mechanical r						
FO-351021	6/27/2016	3	Created	ELEC						
FO-351162	6/28/2016	2	Created	Trade: Electricians						
FO-351183	6/29/2016	1	Created	R/R RM 00100/MECH RM please have electricians check fault alarm on fire alarm panel						
FO-351240	6/29/2016	1	Created	R/R RM 14200.60/OFC The light sensor located right near the double door entry is not						
FO-351258	6/30/2016	0	Created	Due to a power surge, room 116 is completely dark.						
FO-351279	6/30/2016	0	Created	Trade: Electricians						
T - Pipefitter			46	11	6	2	11	12	4	
FO-315918	4/30/2015	427	Created	Pig Room - Please replace normally open valve with n/c 3-8# valve. See engineer for d						
FO-317776	5/20/2015	407	Created	(**) PO REQ DK 2/1						
FO-317844	5/21/2015	406	Created	Pipefitters: High, Repair coil leak fan AHU-3,,,,,,,,,,,,, EA/5-22-15 ,,,,,,,,,,,,,,						
FO-320545	6/25/2015	371	Created	Trade: Pipefitter						
FO-321013	7/6/2015	360	Created	CEILING LEAK. 1ST FLOOR ROOM 136.....ME.....7-6-15						
FO-321515	7/10/2015	356	Created	(**) PO REQ DK **REM 2/15/16						
FO-322897	7/27/2015	339	Created	Fitters,						
FO-323146	7/29/2015	337	Created	RM 1318 ACTIVE CEILING LEAK ,,,,,,,,,,,,,, EA/7-29-15 ,,,,,,,,,,,,,,						
FO-323861	8/6/2015	329	Created	MD 2136 INNER RM CEILING LEAK.....EA,,,,,,,,,8-7-15						
FO-324113	8/11/2015	324	Created	1318 CEILING LEAK.....EA.....8-11-15						
FO-324254	8/12/2015	323	Created	please assist Engineers by breaking unions on #3 boiler on front blow down see Smiley.						
FO-325233	8/24/2015	311	Cancelled	FITTERS: PLEASE REPAIR #2 HEAT EXCHANGER TUBE BUNDLE APPEARS TO H						
FO-326618	9/9/2015	295	Created	please chk ceiling leak in room 1209.....ME.....9-9-15						
FO-331146	10/28/2015	246	Created	CEILING LEAK. ROOM 205. ,,,,,,,,,,,,,, ME/10-28-15 ,,,,,,,,,,,,,,						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-332142	11/6/2015	237	Created	R/R RM 7341 INSULATE CEILING DRAIN PIPE, CB/11-6-15							
FO-332463	11/12/2015	231	Created	(**) PO REQ DK *REM 2/15							
FO-337473	1/20/2016	162	Created	leak right above the front desk. Looks like it's coming from the trap.....GS....1-20-16....							
FO-337478	1/20/2016	162	Created	(**) PO REQ DK							
FO-337778	1/25/2016	157	Created	(**) PO RE DK 4/4 VALVE ORDER							
FO-338778	2/3/2016	148	Created	Steam coil leak on #1 air handler. It needs to be repaired....., ME/2-3-16							
FO-339354	2/11/2016	140	Created	(**) PO REQ DK 4/4							
FO-339416	2/12/2016	139	Created	**PRIORITY LOWERED/WORK IN PROGRESS JWT							
FO-339806	2/17/2016	134	Created	Trade: Steam fitter							
FO-340257	2/23/2016	128	Created	(**) PO REQ TH 4/11							
FO-340452	2/25/2016	126	Created	Pipe fitters: Please repair or replace leaking reheat valve for room 200, it is leaking thro							
FO-342900	3/22/2016	100	Created	(**) PO REQ TH 4/11							
FO-343214	3/25/2016	97	Created	(**) PO REQ DK 4/8							
FO-344411	4/7/2016	84	Created	Please replace leaking condensate pump Seal:							
FO-344934	4/18/2016	73	Created	(**) PO REQ DK 4/27							
FO-346977	5/6/2016	55	Created	PIPEFITTER: HIGH PRIORITY							
FO-347083	5/9/2016	52	Created	Please fix leaking ceiling and replace ceiling tiles that fell from the ceiling and onto the fl							
FO-347181	5/11/2016	50	Created	Pf med high Priority							
FO-347466	5/16/2016	45	Created	Trade: Pipe fitters							
FO-348192	5/24/2016	37	Created	Pf High Priority							
FO-348507	5/26/2016	35	Created	CEILING PIPE LEAK. ROOM 9320....., JH/5-26-16							
FO-349108	6/1/2016	29	Created	FITTERS							
FO-349943	6/14/2016	16	Created	Fitters please check 12" chill water piping above AC-11 for flange leak,or if only conden							
FO-350088	6/16/2016	14	Created	BSMNT WOMENS RM ACTIVE CEILING LEAK, ME/6-16-16							
FO-350089	6/16/2016	14	Created	NEAR RM 241&242 ACTIVE CEILING LEAK WHERE BLDG CONNECTS TO SHIFFM							
FO-350187	6/17/2016	13	Created	trade pipefitters priority high please service office area 2123 leaking from actuator and p							
FO-350253	6/20/2016	10	Created	Trade: Pipefitter							
FO-350662	6/22/2016	8	Created	Trade: Pipefitter							
FO-351013	6/27/2016	3	Created	CEILING LEAK. ROOM 415....., ME/6/28							
FO-351115	6/28/2016	2	Created	FITTERS: PLEASE REPAIR MULTIPLE LEAKS ON THE HYDRONIC HOT WATER SY							
FO-351162	6/28/2016	2	Created	Trade: Electricians							
FO-351249	6/30/2016	0	Created	steamfitters							
T - Plumber				87	19	8	7	20	25	8	
FO-319581	6/15/2015	381	Created	4th floor mens room 1st stall water is running out of bottom of toilet....., GS/ 6-15-							
FO-319962	6/16/2015	380	Created	R/R 3RD FLR MENS RR 3RD URINAL IS PLUGGED UP, MP/6-16-15							
FO-319977	6/16/2015	380	Created	**ADDING PLUMBER: Repair leaking floor drain traps from 1st floor possible janitors si							
FO-320120	6/18/2015	378	Created	PIPE LEAK. FRONT OF JANITOR'S CLOSET. 1ST FLOOR....., DB/6-18-15 ,,,							
FO-320572	6/25/2015	371	Created	(**) PO REQ DK 7/31							
FO-320572	6/25/2015	371	Created	(**) PO REQ DK 7/31							
FO-320623	6/26/2015	370	Created	The commode in the smaller stall in this ladies lavatory appears to leaking water out the							
FO-320705	6/29/2015	367	Created	Ceiling tiles have fallen down in room 422. They are waterlogged....., *DB/ME/6-2							
FO-320871	7/1/2015	365	Created	(**) PO REQ DK PLATES / MIXING VALVES							
FO-321325	7/8/2015	358	Created	Please have plumbers repair-replace leaking hot water hose on bottle washer.							
FO-321982	7/14/2015	352	Created	Seal around drain near AH#11. Pipefitter has rerouted piping that was going to this drain							
FO-322094	7/16/2015	350	Created	Plumbers please troubleshoot eyewash stations in labs,2115,2126 suspect mixing valve							
FO-322202	7/17/2015	349	Created	LAB 252 SINK ACROSS FROM FUME HOOD 3&4, HOT WATER HANDLE IS FALLIN							
FO-323714	8/5/2015	330	Created	(**) PO REQ DK 12/9 / *REM 2/15							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-323786	8/5/2015	330	Created	RM 9215 FAUCET WON'T TURN OFF ,,,,,,,,,,,,,, MM/8-5-15 ,,,,,,,,,,,,,,						
FO-323786	8/5/2015	330	Created	RM 9215 FAUCET WON'T TURN OFF ,,,,,,,,,,,,,, MM/8-5-15 ,,,,,,,,,,,,,,						
FO-325201	8/24/2015	311	Created	Replace spigot on the south side of stadium. Same faucet was leaking last fall water sh						
FO-326644	9/9/2015	295	Created	REPAIR RO WATER LINE, SHUT OFF VALVE ON 4TH FL						
FO-326644	9/9/2015	295	Created	REPAIR RO WATER LINE, SHUT OFF VALVE ON 4TH FL						
FO-327265	9/21/2015	283	Created	Plumbers:						
FO-328256	9/29/2015	275	Created	WOMENS RESTROOM 143 TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,,,,,, MM/9-2						
FO-328286	9/29/2015	275	Created	LAB 160 FH 5 WATER LEAKING FROM THE BOTTOM OF HOOD ,,,,,,,,,,,,,, GS/9-29-						
FO-328286	9/29/2015	275	Created	LAB 160 FH 5 WATER LEAKING FROM THE BOTTOM OF HOOD ,,,,,,,,,,,,,, GS/9-29-						
FO-329976	10/19/2015	255	Created	R/R RM 3338/MENS RR HANDICAP STALL SEEMS TO BE BACKING UP W/SEWAG						
FO-330603	10/20/2015	254	Created	(**) PO REQ DK 12/7 / *REM 2/15						
FO-330603	10/20/2015	254	Created	(**) PO REQ DK 12/7 / *REM 2/15						
FO-331035	10/27/2015	247	Created	RM 9232 ROTTEN SMELL FROM SINK ,,,,,,,,,,,,,, MM/10-27-15 ,,,,,,,,,,,,,,						
FO-331035	10/27/2015	247	Created	RM 9232 ROTTEN SMELL FROM SINK ,,,,,,,,,,,,,, MM/10-27-15 ,,,,,,,,,,,,,,						
FO-331141	10/28/2015	246	Completed	ADDING CUSTODIAL 10/28/15 FOR CLEAN UP AFTER FLR DRAIN HAD BEEN CLEA						
FO-332198	11/9/2015	234	Created	(**) PO#2 REQ DK 5/23						
FO-334186	12/3/2015	210	Created	3RD FL LADIES RM ALL SINKS ARE BACKED UP ,,,,,,,,,,,,,, GS/12-3-15 ,,,,,,,,,,,,,,						
FO-334324	12/7/2015	206	Created	RM 306 NO WATER PRESSURE TO COMPRESSOR ,,,,,,,,,,,,,, TT/12-7-15 ,,,,,,,,,,,,,,						
FO-334324	12/7/2015	206	Created	RM 306 NO WATER PRESSURE TO COMPRESSOR ,,,,,,,,,,,,,, TT/12-7-15 ,,,,,,,,,,,,,,						
FO-336460	1/8/2016	174	Created	(**) PO REQ DK 2/15						
FO-336693	1/12/2016	170	Created	LOADING DOCK IS FLOODED AND VERY ICY.						
FO-336854	1/13/2016	169	Created	The water faucet in the 1st floor ladies room is spraying out water. The faucet turns on b						
FO-337475	1/20/2016	162	Created	(**) PO REQ DK 2/15						
FO-337665	1/22/2016	160	Created	(**) PO REQ DK 2-15						
FO-338717	2/3/2016	148	Created	Trade: Plumber						
FO-338926	2/4/2016	147	Created	(**) PO REQ DK 2/23						
FO-339381	2/11/2016	140	Created	*WATER RESTORED 2/11 JWT						
FO-339381	2/11/2016	140	Created	*WATER RESTORED 2/11 JWT						
FO-339408	2/12/2016	139	Created	Trade: Plumber						
FO-340305	2/24/2016	127	Created	Plumbers- High Priority- Plugged toilet in the dean's office. Please clear and restore to						
FO-340618	2/29/2016	122	Created	Plumb High Priority						
FO-340741	2/29/2016	122	Created	Plumb High Priority						
FO-341488	3/1/2016	121	Created	(**) PO REQ DK 3/7						
FO-341257	3/2/2016	120	Created	(**) PO REQ DK 6/23 #2 ORDER						
FO-341422	3/4/2016	118	Created	SHOWER IS LEAKING. ROOM 200.1. ,,,,,,,,,,,,,, TT/3-4-16 ,,,,,,,,,,,,,,						
FO-342247	3/16/2016	106	Created	(**) PO REQ DK 4/8						
FO-342897	3/22/2016	100	Created	R/R RM 00405/CLASS LAB and 00314 TROUBLESHOOT WHY Emergency safety sho						
FO-342959	3/23/2016	99	Cancelled	WOMENS RM NEAR LUNCHROOM, 1ST STALL CLOGGED TOILET						
FO-343549	3/31/2016	91	Created	**ADDING PLUMBER: R/R Y-joint from roof conductor. Leaking down to 4th floor. See						
FO-343634	4/1/2016	90	Created	STANDING WATER - GULLEN MALL BETWEEN SHAPERO HALL AND LAW LIBRAR						
FO-344234	4/5/2016	86	Created	(**) PO REQ DK 4/12						
FO-344323	4/6/2016	85	Created	WOMENS RM 272 3RD SINK IS BAGGED ,,,,,,,,,,,,,, GS/4-6-16 ,,,,,,,,,,,,,,						
FO-344577	4/11/2016	80	Created	2ND FL MENS RM URINAL IS PLUGGED AND OVERFLOWING ,,,,,,,,,,,,,, GS/4-11-						
FO-344806	4/14/2016	77	Created	CHANGE WATER FILTERS UNDERNEATH SINK. 1ST FLOOR ALSO EVALUATE/CH						
FO-345028	4/18/2016	73	Created	LOWER LEVEL WATER FOUNTAIN FILTER NEEDS REPLACING ,,,,,,,,,,,,,, TT/4-18						
FO-345881	4/25/2016	66	Created	Plumbers please repair leaking 3" flange water supply to low/pressure Lab Heater,priorit						
FO-346458	5/2/2016	59	Not Finished	WATER FOUNTAIN CONTINOUS TO RUN MINUTES AFTER BUTTON IS RELEASED						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-346733	5/3/2016	58	Created	Move items from back wall in Plumbers cage in mechanical room 100 so Electricians ca							
FO-347281	5/12/2016	49	Created	*PART ORDERED FOR REPAIR 5/13/16 JWT*PRIORITY LOWERED / WORK IN PRO							
FO-347298	5/12/2016	49	Created	(**) PO REQ DK 6/13							
FO-347397	5/16/2016	45	Cancelled	LOADING DOCK IS FLOODED.							
FO-347626	5/19/2016	42	Created	(**) PO REQ TH 5/31							
FO-348332	5/25/2016	36	Created	Trade: Plumber Priority: High							
FO-348471	5/26/2016	35	Created	Lab 2335 FLOOR DRAIN is still having drainage issues. Please have someone come b							
FO-349159	6/2/2016	28	Created	BSMNT NEAR FILTERS ACTIVE LEAK FROM RISING PIPE *TT/JH/6-2-1							
FO-349478	6/7/2016	23	Created	trade plumbers priority high please repair leaking compression fitting in basement anima							
FO-349645	6/9/2016	21	Created	R/R RM 319/MENS RR both toilets in the men's restroom are broken: one won't flush an							
FO-349911	6/14/2016	16	Created	Plumbers: Med High Priority.							
FO-350047	6/16/2016	14	Not Finished	LAB 3240 CRACKED SINK LEAKING MM/6-16-16							
FO-350144	6/17/2016	13	Created	CEILING LEAK. ROOM 2123..... TT/ 6-17-16							
FO-350155	6/17/2016	13	Created	trade plumbers priority high please service domestic water heater lochinvaair it may have							
FO-350227	6/20/2016	10	Created	Clear urinal drain on 1st floor room 1238 MM/6-20-16							
FO-350265	6/20/2016	10	Created	WATER FOUNTAIN LEAKING AT BOTTON. WATER ON FLOOR. 1ST FLOOR NOR							
FO-350571	6/21/2016	9	Created	Plumb. High Priority							
FO-350607	6/21/2016	9	Created	(**) PO REQ DK							
FO-350627	6/21/2016	9	Created	BSMNT WOMENS RM LAST SINK WONT STOP RUNNING MM/6/22.....							
FO-350992	6/27/2016	3	Created	PLUM							
FO-351035	6/27/2016	3	Created	PLUM							
FO-351039	6/27/2016	3	Created	LEAK UNDERNEATH SINK. MEN'S RESTROOM. ROOM 9101. SINK CLOSEST TO							
FO-351111	6/28/2016	2	Created	TOILET NOT FLUSHING. 1ST FLOOR DISPATCH OFFICE..... MM/6/28							
FO-351152	6/28/2016	2	Created	PLUMBER							
FO-351193	6/29/2016	1	Created	PLUM							
FO-351205	6/29/2016	1	Created	PLUM							
T - Roofing				18	2	1	2	11	1	1	
FO-308197	2/9/2015	507	Created	**ADDING ROOFER: Repair roof sump leaking into building. See description below JW							
FO-331128	10/28/2015	246	Created	R/R 3RD FLR "E" BLDG STRWL F ROOF LEAKING							
FO-338924	2/4/2016	147	Created	From Jason (Aramark)... "One of the two leaks occurs in heavy rain out of the sky lig							
FO-339910	2/18/2016	133	Created	**On 2/18/16 this was looked at. No Piping to be repaired. Turned over to Tim Herr on 2/							
FO-340388	2/24/2016	127	Created	ROOFER:							
FO-340423	2/24/2016	127	Created	ROOF LEAK ABOVE WEST ENTRANCE. CONTANT NATHAN CRIST FOR DETAILS.							
FO-341721	3/9/2016	113	Created	Roofers							
FO-343068	3/24/2016	98	Created	Trade: RooferPriority: Medium to HighCeiling leak. Possibly through soffit.							
FO-343126	3/24/2016	98	Created	4TH FL STORAGE AREA WOODCOCK SIDE ACTIVE CEILING LEAK							
FO-343142	3/24/2016	98	Created	3RD FL NEAR ELEV ACTIVE LEAK FROM ROOF							
FO-343528	3/30/2016	92	Created	ROOFER							
FO-343569	3/31/2016	91	Created	WEST STAIRWELL LEADING TO ROOF,ACTIVE CEILING LEAK LEAKING DOWN T							
FO-343628	3/31/2016	91	Created	**ADDING ROOFER:							
FO-344424	4/8/2016	83	Created	Trade: RooferPriority: Medium to HighCeiling leak outside R-302.Electrical EMT tu							
FO-344977	4/18/2016	73	Created	**ADDING ROOFER; Roof leak in room 256. *No Pipe Leak, See Jim Hill for detail							
FO-348392	5/25/2016	36	Created	ROOFER							
FO-350104	6/16/2016	14	Created	Leak from roof above desk/station (room) 144 in the main receiving area of the buildin							
FO-350107	6/16/2016	14	Created	OUTSIDE 271 ACTIVE CEILING LEAK FROM ROOF							
T - Sheetmetal				2	0	0	0	0	2	0	
FO-323417	7/31/2015	335	Created	TINSMITHREPLACE MISSING/BROKE BRACKETS ON #1 & #6 EXHAUST FANS							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-323667	8/4/2015	331	Created	D. Kuffner, Insulation - High Priority						
Medium			157	41	22	11	26	49	8	116
T - Carpenter			12	9	2	1	0	0	0	
FO-343769	4/4/2016	87	Created	**ADDING CARPENTER: Replace damaged wood base molding in basement. See Gerr						
FO-347230	5/11/2016	50	Created	Door 062-03W stays ajar & won't latch intermittently. Door isn't closing flush to door st						
FO-347481	5/17/2016	44	Hold for Funds	pls build elevated cat walk around the dearator in the bsmt of usb/fpm 2"-3" of standing						
FO-349096	6/1/2016	29	Created	**ADDING CARPENTER: Evaluate Labor cost and material needed to install 2 concrete						
FO-349345	6/6/2016	24	Created	Repair outside entrance door 023 03 E. Door is sticking closed.						
FO-349459	6/7/2016	23	Created	Carpenters-Please install grab bars in rest room near toilet. Medium Priority						
FO-349493	6/7/2016	23	Created	**ADDING CARPENTER: Evaluate cost for wood trim work to upgrade 4 drinking fountai						
FO-350134	6/17/2016	13	Created	Carpenters- Med priority- Replace leak damaged ceiling tile in room 313.						
FO-350584	6/21/2016	9	Created	Trade: Contractor Priority: Medium						
FO-350636	6/21/2016	9	Created	Applebaum 5th floor needs new ceiling tiles in hallways by rooms: 5154, 5148, 5136, 5						
FO-350738	6/23/2016	7	Created	Trade: CarpenterPriority: MediumPlease replace ceiling tiles in the hallway near the						
FO-351229	6/29/2016	1	Created	R/R decorative second floor banister on the Cass side. See James for location. This is a						
T - Electrician			41	10	4	1	7	19	0	
FO-324233	8/12/2015	323	Created	Labore- Tower chemicals- med priority. Please deliver 2 barrels each of the following ch						
FO-324457	8/17/2015	318	Created	please have laborer deliver 1 pallet of salt to room 100 for water softner.						
FO-324497	8/17/2015	318	Created	Electricians: please trouble shoot and repair FCU-3 blower motor in mechanical room 4						
FO-324718	8/18/2015	317	Created	pls deliver 3 pails of nitrokleanse and 1 bag of oil dry and one small pail of boiler refacto						
FO-327014	9/16/2015	288	Created	Loose Breakers, please repair.						
FO-327078	9/16/2015	288	Created	Please move 3 new boiler feed pumps from the stockroom to the Music boiler room loca						
FO-327197	9/18/2015	286	Created	Clocks in classrooms have the wrong time- please correct them.room 117room 02						
FO-327996	9/24/2015	280	Created	Electrician, Medium Priority, Repair fire panel, Trouble Signal, Card #5 LED Reset Contr						
FO-327998	9/24/2015	280	Created	ElectricalMedium priorityFire panel /Security panel has trouble alarm. Earth/Ground.						
FO-329000	10/6/2015	268	Created	Trade : ElectricianPriority: MediumPlease replace two light fixture at 2nd floor and 3r						
FO-330683	10/21/2015	253	Created	Transport duct hoist from Pipe Shop to Elliman.						
FO-332099	11/6/2015	237	Created	ELECTRICIAN - Please tuck point and replace missing brickwork on front handicap ra						
FO-333044	11/18/2015	225	Created	please have laborer deliver a pallet of salt to room 100 scott hall						
FO-333341	11/23/2015	220	Created	Trade: Laborer						
FO-334042	12/2/2015	211	Created	ELECTRICAL DEPT-EXTERIOR OUTSIDE LIGHT BY BOILER ROOM DOOR 156-08-N						
FO-334116	12/3/2015	210	Created	Trade: Laborer						
FO-334273	12/5/2015	208	Created	ELECTRICIANS: Please repair Basement EBU light systems. MED.						
FO-334762	12/11/2015	202	Created	Trade: LaborerPriority: Med.Please supply 1 drum of Neutramine XF-P 17070042						
FO-334791	12/11/2015	202	Created	**ADDING ELECTRICIAN: Disconnect sump pump #2 in basement mechanical room. p						
FO-337541	1/21/2016	161	Created	Electrician, medium, Please replace smoke detector next to basement mechanical room						
FO-338146	1/28/2016	154	Created	To electricians. Replace defective toggle switch on Alumni Kitchen exhaust fan and, def						
FO-338719	2/3/2016	148	Created	Trade: ElectricalPriority: MediumPlease install blank plate cover to cover hollow spac						
FO-340574	2/26/2016	125	Created	LOT 15 & MALL NEAR COHN BLDG (2) BLUE LIGHTS OUT						
FO-341905	3/10/2016	112	Created	trade electricains priority medium						
FO-341930	3/10/2016	112	Hold for Funds	Check Community Arts, and other buildings for Emergency Lighting.						
FO-343419	3/29/2016	93	Created	Dusk to Dawn exterior light on North side of building does not come on at night. Please						
FO-346329	4/29/2016	62	Created	We have a few lights over pool out, and need them lamped as soon as possible.						
FO-346923	5/5/2016	56	Created	Wayne State Police - several hanging exterior lights						
FO-347467	5/17/2016	44	Created	Trade: Electrician						
FO-347779	5/23/2016	38	Created	AIR HANDLER #3 OFF ON LOW TEMP. AND WON'T RESTART. PENTHOUSE						
FO-348475	5/26/2016	35	Created	EMERGENCY ELEC						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349109	6/1/2016	29	Created	Meet the lighting crew at 7:45 to collect 2 Bakers Scaffold, and take to new location. Ho							
FO-349531	6/8/2016	22	Created	AIR HANDLER #2 IS DOWN. ROOM 0130.							
FO-349994	6/15/2016	15	Created	Electricians: R/R BLDG Please relamp the burned-out outside building illumination lig							
FO-349993	6/15/2016	15	Created	Electricians: R/R BLDG Please relamp three burned-out walkway lights on the North si							
FO-350121	6/16/2016	14	Created	ELECTRICIANS,R/R RM 00336 BAD MOTOR ON CFC UNIT PLEASE REPAIR.PRI							
FO-350154	6/17/2016	13	Created	elect.R/R WAREHOUSE replace burnt out overhead lights in the storage area priority							
FO-350964	6/24/2016	6	Created	Trade: Electrician							
FO-350976	6/27/2016	3	Created	Electricians, troubleshoot ground fault on 14th floor phone jack.							
FO-351017	6/27/2016	3	Created	Evaluate cost to reinforce failing lift gate steel							
FO-351177	6/29/2016	1	Created	Assist Plumber in removing snake from drain on Thursday 6/30. See Gerry for location							
T - Locksmith				1	1	0	0	0	0	0	
FO-350211	6/18/2016	12	Created	Repair faulty door lock cylinder on the Male Cadet Locker Room at Public Safety. Very d							
T - Painter				3	1	2	0	0	0	0	
FO-346874	5/5/2016	56	Created	**ADDING PLASTERER: Repair wall / ceiling in 1st floor janitor closet when plumbing re							
FO-346879	5/5/2016	56	Created	PLASTER/ PAINTER: Please repair hole in ceiling (drywall) due to a valve leak in hallw							
FO-350108	6/16/2016	14	Created	**ADDING PAINTER: Please seal and paint ceiling in room 417. Leak has been repaire							
T - Pipefitter				38	7	3	3	4	17	4	
FO-316727	5/6/2015	421	Created	(**) PO REQ DK 1/6 WITH PFA#772061 JWT							
FO-319578	6/15/2015	381	Not Finished	PF Med Priority							
FO-319887	6/15/2015	381	Not Finished	(**) PO REQ DK 6-17-15							
FO-320726	6/29/2015	367	Created	Trade: Pipefitter							
FO-323228	7/30/2015	336	Created	steam fitters- med priority- repair leaking steam flange on cage wash water heater (DH							
FO-323764	8/5/2015	330	Created	(**) PO REQ DK 11/23							
FO-323938	8/7/2015	328	Created	STEAMFITTERS-PLEASE REPAIR 3/4 INCH NIPPLE LEAK IN HOT WATER PERIMIT							
FO-324033	8/10/2015	325	Created	(**) PO REQ DK 11/23							
FO-324033	8/10/2015	325	Created	(**) PO REQ DK 11/23							
FO-324749	8/18/2015	317	Created	STAEMFITTERS-PLEASE UNPLUG CHIILLED WATER COIL CONDENSTATE DRIP P							
FO-326288	9/3/2015	301	Created	(**) PO REQ DK 11/23							
FO-326608	9/9/2015	295	Created	(**) PO REQ DK 11/23							
FO-329821	10/16/2015	258	Created	Trade: Pipefitter Priority: Medium							
FO-329851	10/16/2015	258	Created	(**) PO REQ DK 12/7 *REM 2/15							
FO-331581	11/2/2015	241	Created	Re-insulate plumbing repairs on hot / cold water lines in girls basketball locker room abo							
FO-331999	11/5/2015	238	Created	(**) PO REQ DK *REM 2/15							
FO-333690	11/30/2015	213	Created	(**) PO REQ DK 2/1							
FO-334208	12/4/2015	209	Created	Steamfitters- Medium Priority. Repair steam coil leaks on AHU #1 and AHU #2.							
FO-334652	12/10/2015	203	Created	PIPEFITTERS please replace reheat valve marked and ceiling panel open to indicate lo							
FO-334653	12/10/2015	203	Created	PIPEFITTERS please replace reheat valve marked and ceiling panel open to indicate lo							
FO-334822	12/14/2015	199	Created	Pipefitter: Med Priority.							
FO-338741	2/3/2016	148	Created	Trade: Pipe Fitters							
FO-338866	2/4/2016	147	Created	(**) PO REQ DK 2/22							
FO-339541	2/15/2016	136	Created	(**) PO REQ DK 2/23							
FO-343283	3/28/2016	94	Created	FITTERS: Please replace reheat valve in room 2148. MED., EA/3-28-16							
FO-344321	4/6/2016	85	Created	(**) PO REQ DK 4/8							
FO-344667	4/12/2016	79	Created	(**) PO REQ DK 4/27							
FO-346237	4/28/2016	63	Created	pipe fitters priority medium R/R ROOF AREA please repair or patch hole onside of cooli							
FO-346747	5/3/2016	58	Created	Pipe fitters: Please install a 2" cap or plug on drain line for chilled water strainer to AHU-							
FO-347816	5/23/2016	38	Created	(**) PO REQ DK 6/16							
FO-347856	5/23/2016	38	Created	Fitters (Med)Replace leaking regulating valve located in hallway ceiling hatch as you							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349219	6/2/2016	28	Created	Trade: Pipefitter						
FO-349729	6/10/2016	20	Created	Pipe fitters:						
FO-350659	6/22/2016	8	Created	Steam Fitters- Medium Priority- Repair steam leak on						
FO-351033	6/27/2016	3	Created	FITTERS: Please repair flange fitting on HEAT EXCHANGER. MED. ME/6/2						
FO-351257	6/30/2016	0	Created	STEAM FITTERS						
FO-351275	6/30/2016	0	Created	Fitters replace 1/2 inch solenoid valve on the blow down line for the cooling tower. priorit						
FO-351283	6/30/2016	0	Created	Trade: Pipefitters						
T - Plumber			53	12	10	6	12	12	1	
FO-319982	6/16/2015	380	Created	Plumbers:						
FO-321401	7/9/2015	357	Created	Plumb. Med. Priority						
FO-321557	7/12/2015	354	Created	Repair sump pump #1 at loading dock of Scott Hall. The pump it tripping out the motor s						
FO-322179	7/17/2015	349	Created	**REFER TO FO#326441 JWT						
FO-322179	7/17/2015	349	Created	**REFER TO FO#326441 JWT						
FO-323444	8/3/2015	332	Created	Plumbers: Please replace all cracked and leaking sewer line in mechanical room 15. Pri						
FO-323452	8/3/2015	332	Created	The water fountain on the 3rd floor (at the junction of North and South Wing) is not worki						
FO-325297	8/25/2015	310	Created	Trade: PlumberPriority: MediumPlease repair Sloan valve. Toilet won't flush.						
FO-325298	8/25/2015	310	Created	Trade: PlumberPriority: MediumRepair Sloan valve. Toilet leaking water.						
FO-325541	8/27/2015	308	Created	PLUMBERS: Please repair Safety Eye Sationnear room 3341(north). MED						
FO-326421	9/4/2015	300	Created	Trade: Plumbers						
FO-330862	10/23/2015	251	Created	Plumbers- med- Replace seals and bearing on domestic water booster pumps 1& 2 in						
FO-335738	12/28/2015	185	Created	**ADDING PLUMBER: install sink to test boiler sample water. See Jim Hill for location ,						
FO-338256	1/29/2016	153	Created	Please tighten all toilet seats..... TT/1-30-16						
FO-338318	2/1/2016	150	Created	(**) PO REQ DK 2/22						
FO-338806	2/3/2016	148	Created	2nd floor drinking fountain-water tastes horrible GS/2-4-16						
FO-339196	2/9/2016	142	Created	Replace 3 flush valves in the Public restroom basement floor near room 014						
FO-339726	2/16/2016	135	Created	(**) PO REQ DK 4/8						
FO-340745	2/29/2016	122	Created	(**) PO REQ DK 4/12						
FO-341414	3/4/2016	118	Created	To plumbers. Janitors sink in rm 118 will not unclog. Also, faucet on hot will not shut off						
FO-341802	3/9/2016	113	Created	R/R RM 3337/MENS RR 1ST URINAL HAS BEEN BAGGED OVER A MONTH (ORIGI						
FO-342253	3/16/2016	106	Created	Plumbers: please unplug 1st toilet on the right in men's room 104. Priority: med.....						
FO-342830	3/22/2016	100	Hold for Funds	**WILL REVISIT IN SUMMER WHEN STEAM IS OFF AND CONDENSATE ID DRY ON						
FO-342832	3/22/2016	100	Created	Above RM. 118- Janitor Closet, faucet is leaking TT/3-22-16						
FO-343177	3/25/2016	97	Created	(**) PO REQ DK 4/8						
FO-344785	4/14/2016	77	Created	(**) PO REQ DK 4/20						
FO-344942	4/18/2016	73	Created	(**) PO REQ DK 5/16						
FO-345756	4/21/2016	70	Created	(**) PO REQ DK 5/16						
FO-345909	4/25/2016	66	Created	Plumbers, woman rest room on the south end of the basement east toilet needs the flus						
FO-346290	4/28/2016	63	Created	(**) PO REQ DK 5/16						
FO-346292	4/28/2016	63	Created	(**) PO REQ DK 5/16						
FO-346872	5/5/2016	56	Created	PLUMBERS,						
FO-346892	5/5/2016	56	Created	Plumbers-Please repair leak in roof drain line. See Engineer. Medium Priority						
FO-347082	5/9/2016	52	Created	Basement -south side Women's restroom has a toilet stall (3rd one from the entry) that						
FO-347236	5/11/2016	50	Cancelled	R&R garbage disposal Hot Kitchen. Please see Bobby for location.						
FO-347282	5/12/2016	49	Created	Plumbers, please repair/replace emergency shower located 2nd floor SW corner near ro						
FO-347349	5/13/2016	48	Created	(**) PO REQ DK 6/20						
FO-347572	5/18/2016	43	Created	Cooling tower make up water meter is 25 ft off the floor and 2 ft over making it difficult to						
FO-347660	5/19/2016	42	Created	Turn water supply off to 2 drinking fountains						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-348286	5/24/2016	37	Created	Plumbers:							
FO-348949	5/26/2016	35	Created	Shut off water service to 2 bagged drinking fountains one on 4th floor and the other in th							
FO-349243	6/3/2016	27	Created	PLUM							
FO-349536	6/8/2016	22	Created	Trade: Plumbers							
FO-349537	6/8/2016	22	Created	Trade: Plumbers							
FO-349548	6/8/2016	22	Created	Plumber replace water filter under kitchen sink.....MM/6-8-16							
FO-349618	6/9/2016	21	Created	PLUMBERS,							
FO-349971	6/15/2016	15	Created	PLUMBER 4TH FLOOR WATER FOUNTAIN NOT WORKING .							
FO-350020	6/15/2016	15	Created	Trade: Plumbers							
FO-350040	6/16/2016	14	Created	PLUMBERS,							
FO-350757	6/23/2016	7	Created	PLUMBERS,							
FO-351128	6/28/2016	2	Created	2 PLUGGED TOILETS COVERED WITH BAGS. 2ND FLOOR WOMEN'S RESTROOM							
FO-351186	6/29/2016	1	Created	ADDING PLUMBER: Clear down spouts. See Jim the Laborer for detail, 6/29 ,,,							
FO-351230	6/29/2016	1	Created	TOILET IS PLUGGED. 1ST FLOOR LADIES RESTROOM.							
T - Roofing				8	1	1	0	3	1	2	
FO-305966	1/13/2015	534	Created	Water leaking from roof and in the hallway							
FO-320724	6/29/2015	367	Created	**ADDING ROOFER: Structural leak at Corner of building leaking into atrium during rain							
FO-333206	11/20/2015	223	Created	repair leaks in the chimney on the Carriage House above the galleries							
FO-340441	2/25/2016	126	Created	Roof repair- medium priority- repair roof leaks on the south east corner of the building.							
FO-341779	3/9/2016	113	Created	Roofer R/R ROOF repair flashing over entry south side priority medium							
FO-343600	3/31/2016	91	Created	Trade: Roofer Priority: MediumR/R 3RD FLR Have roof leaking water onto EDC 3rd flo							
FO-347418	5/16/2016	45	Created	(Roof Leak) Med priorityR/R 4TH FLR Repair roof leak outside of room 458 on first flo							
FO-350122	6/16/2016	14	Created	roof repair- around refrigeration lines which go through the roof in room 4606. water is le							
T - Sheetmetal				1	0	0	0	0	0	1	
FO-319159	6/8/2015	388	Created	Trade: Sheet Metal							
Low				423	150	42	37	85	87	22	273
T - Carpenter				29	10	8	5	6	0	0	
FO-340405	2/24/2016	127	Created	Carpenters: Please replace damaged window blind on south window, it has a large cut i							
FO-340406	2/24/2016	127	Created	Carpenters: Please repair or replace roller clutch for the blind on 2nd window from north,							
FO-341316	3/3/2016	119	Created	Carpenters (Med High)Install hatch in open space above door in women's restroom 1							
FO-341555	3/7/2016	115	Created	VENDOR (GRAINGERS) TO SUPPLY WORN OUT SHOP TOOLS							
FO-341794	3/9/2016	113	Hold for Funds	**ADDING CARPENTER : Please replace or reset all loose tites in bathroom of office 29							
FO-341855	3/9/2016	113	Created	next to cubicle #444.26, 4th floor, there is duct tape around the seal of the window and a							
FO-344995	4/18/2016	73	Hold for Funds	REPAIR GUTTER ON SOUTHWEST CORNER.							
FO-345016	4/18/2016	73	Hold for Funds	Carpenters: please repair roof gutters on north side of the building. priority: low.							
FO-345767	4/21/2016	70	Hold for Funds	R/R BLDG The latches on the windows are broken or missing in several rooms and they							
FO-346341	4/29/2016	62	Hold for Funds	R/R all damaged and missing ceiling tiles in hallways on 1st, 2nd and 3rd floors.							
FO-346348	4/29/2016	62	Created	R/R RM 1121 Door knob of room 1121 needs to be checked. The teeth on the door jam							
FO-346433	5/2/2016	59	Created	CARPENTERS TO BUILD PLATFORM DECKING FOR THE ENGINEERS ROOF TOP							
FO-346691	5/3/2016	58	Created	please reattach aluminum siding on new addition roof level east side of bldg.all work ca							
FO-346697	5/3/2016	58	Created	please R/R window cords and weights on all windows that are not working on north side							
FO-346703	5/3/2016	58	Created	R/R all window ropes and weights on north side windows that do not work.							
FO-346848	5/4/2016	57	Hold for Funds	Room 4235, Replace broken, loose and missing floor							
FO-346921	5/5/2016	56	Hold for Funds	please replace severely damaged floor tiles just outside the elevator on 4th floor of COE							
FO-347522	5/17/2016	44	Created	carpenter install a ramp on containment berm in 3rd floor mechanical room behind the e							
FO-347675	5/19/2016	42	Created	To cover the Carpenters portion of this Plumbing job.							
FO-349057	6/1/2016	29	Created	TEAM LEADER TIME (JUNE 2016)							
FO-349838	6/13/2016	17	Created	CARPENTER TO REPLACE WATER DAMAGED CEILING TILES WEST ENTRANCE							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349840	6/13/2016	17	Created	CARPENTERS TO CONTACT JEFF BLOCK TO FIND THE LOCATION OF THE BIRD							
FO-350651	6/22/2016	8	Created	r/r all classroom doors on 2nd floor, adjust and rubercate all hinges,mortise locks and cl							
FO-350818	6/23/2016	7	Created	CARPENTERS,							
FO-350973	6/24/2016	6	Created	Signs vandalized at McGregor, AAB, Cohn and Education Buildings. Police report #W1							
FO-351125	6/28/2016	2	Created	Purdy Library 2nd Floor							
FO-351130	6/28/2016	2	Created	REPLACE DAMAGED CEILING TILE. ROOM 4320 (ENTER THRU ROOM 4324)							
FO-351226	6/29/2016	1	Created	R/R LOBBY/VESTIBULE REPLACE WATER DAMAGED CLNG TILES6/29/16 lps: No							
FO-351300	6/30/2016	0	Created	CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES ON 3RD FL							
T - Electrician				172	58	18	16	33	47	0	
FO-323420	8/3/2015	332	Created	Old Main - Cass Avenue entrance - lollipop lights							
FO-323761	8/5/2015	330	Created	Dr. Lai's basement lab #315 has 2 light bulb fixtures that are burnt out. Thank you.							
FO-324213	8/12/2015	323	Created	R/R 4TH FLR OUTSIDE OF SVC. ELEV. REPLACE TAGGED LITES/EP							
FO-324226	8/12/2015	323	Created	Labore- Tower chemicals- med priority.							
FO-324386	8/13/2015	322	Created	Parking Lot 11 - Blue light phone light in the middle of the parking lot is burned out.T							
FO-324298	8/13/2015	322	Created	Range 139 has an electrical problem.							
FO-324303	8/13/2015	322	Created	The entrance light has an electrical problem.							
FO-324305	8/13/2015	322	Created	Light over the Einstein Brothers food cart. (1st floor)							
FO-324306	8/13/2015	322	Created	Hallway outside room 1111.							
FO-324777	8/18/2015	317	Created	1 EP - StairwelID (basement) - the fixture is the only wall light there is tagged.							
FO-324780	8/18/2015	317	Created	2 EPs - 351 & 325, both of these fixtures are located in hallway above these room numb							
FO-325204	8/24/2015	311	Created	Electrician; High							
FO-326210	9/2/2015	302	Created	LABORER							
FO-327105	9/16/2015	288	Created	Ceiling exhaust fan has a bad motor , unit will not run, this with wo- 327094.This is f							
FO-327103	9/17/2015	287	Created	There are 3 locations with lights out in the Hallway, in front of room 123, room 125, and							
FO-328269	9/29/2015	275	Created	ALL THE LIGHTS ARE OUT IN ROOM 247.							
FO-328622	10/2/2015	272	Created	Relamp Flickering light Fixture in MD Lab 2136. There is 1 electrical problem in room 21							
FO-328676	10/3/2015	271	Created	Please replace dimmer switch the white light circuit of the pin rail at the south wall. This							
FO-329053	10/6/2015	268	Created	**ADDING ELECTRICIAN: Disconnect electrical to each of the 8 heating recirculation p							
FO-331383	10/29/2015	245	Created	2 EPs - patient corridor - lights are blown out. Taped.							
FO-331384	10/29/2015	245	Created	1 EP - 3rd floor hallway - in front of elevators.							
FO-331498	11/2/2015	241	Created	team leader administrative time for month of november							
FO-331565	11/2/2015	241	Created	The room to the right of the front stairwell has a switch that is not working. (1st floor)							
FO-331620	11/2/2015	241	Created	time to enter to for November							
FO-332037	11/5/2015	238	Created	Room 10 - tube light is out.							
FO-332188	11/9/2015	234	Created	time for laborer to clean the trades shop and to do work throughout the univrsity							
FO-332636	11/16/2015	227	Created	The high bay area above the Property Office storage and e-waste cage has very many li							
FO-332978	11/18/2015	225	Created	LABORER							
FO-333127	11/19/2015	224	Created	LABORER,							
FO-333177	11/20/2015	223	Created	The entire warehouse need lights replaced to include							
FO-333544	11/25/2015	218	Created	1 LO - Outside, Front Porch, area facing Cass.							
FO-333546	11/25/2015	218	Created	Room 59 - 4 LO...							
FO-333625	11/30/2015	213	Created	R/R GARAGE AREA Please have Dennis deliver							
FO-333640	11/30/2015	213	Created	Laborers-							
FO-333679	11/30/2015	213	Created	SURPLUS AREA LOUD BUZZING NOISE FROM LIGHT							
FO-334092	12/2/2015	211	Created	3rd floor - Men's R/R - 2 LO							
FO-334104	12/2/2015	211	Created	2 EP - men's R/R							
FO-334108	12/2/2015	211	Created	1 EP - outside of 209 - Second Request							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-334237	12/4/2015	209	Created							Lights bulbs are out and need replacing.
FO-334422	12/8/2015	205	Created							1 EP - The row is located on the 2nd floor, southwest side of the building. Between stac
FO-334423	12/8/2015	205	Created							Room 48 - EP - 4 Lights out "2 inter-offices"
FO-334425	12/8/2015	205	Created							Emergency - Room 326 - 4 out of 6 lights are out. Men's R/R.
FO-334487	12/9/2015	204	Created							Electricians (Labor)-
FO-334489	12/9/2015	204	Created							Electricians- Labor- med priority-
FO-334498	12/9/2015	204	Created							LABORER (DELIVER)(HIGH)
FO-334701	12/11/2015	202	Created							Trade: ElectricalPriority: MediumPlease provide two working 120v outlet at both swi
FO-334770	12/11/2015	202	Created							1 EP - Men's Shower
FO-335809	1/4/2016	178	Created							Time for Team Leader for the month of January, 2016.
FO-336332	1/6/2016	176	Created							Please switch the start up - position for the Generators at the Computer Center, so if the
FO-336623	1/11/2016	171	Created							VFD's for AHU's 3 & 4 need control cards checked.
FO-336791	1/13/2016	169	Created							1 EP - Outside room 237 - This is a wall mounted light. Bulbs have been replaced.
FO-337658	1/22/2016	160	Created							Room 243 - 6 LO
FO-337747	1/25/2016	157	Created							2ND FL MRS WILSON'S AREA OUTLETS NOT WORKING, UNABLE TO USE PHONE
FO-338090	1/28/2016	154	Created							The two halogen 220v work lights on the south side of the stage are burned out. At least
FO-338092	1/28/2016	154	Created							There is no power at the outlets under the desk in this control booth. These are needed
FO-338096	1/28/2016	154	Created							The night time security lights on the north side of the building are not operating after dar
FO-338160	1/29/2016	153	Created							**ADDING ELECTRICIAN: Assist in installing 4 new booster pumps located in mechanic
FO-338200	1/29/2016	153	Created							Time for Contractor to come out, and repair Dimmer Board at the theatre.
FO-339176	2/9/2016	142	Created							Assist plumbers/fitters with domestic water pumps replacement.
FO-339429	2/12/2016	139	Created							Please check the electrical plug under the time clock outside my office. I had two time c
FO-339850	2/17/2016	134	Created							EP - North and South Stairwells, lower auditorium. 2 fixtures each in these stairwells hav
FO-340059	2/20/2016	131	Created							please have electricianscheck north supply fan on ahu-8 tripping on overload. reset br
FO-340735	2/29/2016	122	Hold for Funds							pls repair rest room exh fan motor circuit not running
FO-341729	3/9/2016	113	Created							The hallway between the stairwell and the basketball court has 2 electrical problems. To
FO-341731	3/9/2016	113	Created							The lights across from the emergency stairwell are too high to reach. A GIRF will need t
FO-341752	3/9/2016	113	Created							3 EPs, W R/R - Main Level - There were five out. Two lit up, the other three just had the
FO-341766	3/9/2016	113	Created							Trade: Laborer
FO-341792	3/9/2016	113	Hold for Funds							Light out in the Grounds' dept. I had to remove the bulb because it wouldn't stop flickeri
FO-342004	3/11/2016	111	Hold for Funds							correct EBU system at theatre
FO-342184	3/15/2016	107	Created							fix hanging light at entrance
FO-342204	3/16/2016	106	Hold for Funds							Replace Emergency light Batteries in Auditorium.
FO-342209	3/16/2016	106	Created							The hallway light over the weight lifting area has 1 electrical problem. (Basement) A GIR
FO-342927	3/22/2016	100	Created							Room 1507. Clock is behind 1 hour
FO-342943	3/23/2016	99	Hold for Funds							EMERGENCY ELEC
FO-343080	3/24/2016	98	Hold for Funds							Replacing missing shade on light fixture in second floor back hallway outside of unisex b
FO-343199	3/25/2016	97	Created							1st floor - W R/R - 2 LO
FO-343254	3/28/2016	94	Created							1st floor - quiet lounge - Lights out. The bottom bulb in the first hanging light upon entra
FO-343295	3/28/2016	94	Hold for Funds							Extreme Air Hand Dryer is not working in Ladies Bathroom, UGL Room 2432.
FO-343434	3/29/2016	93	Hold for Funds							the 2nd floor heating hot water pump trips off, pls repair
FO-343536	3/30/2016	92	Created							Ink cartridges for printer
FO-343731	4/4/2016	87	Created							Replace two or more burned out florescent bulbs in room 358 Manoogian. This request
FO-344312	4/6/2016	85	Created							please check breaker and motor for proper operation
FO-344346	4/6/2016	85	Created							Lab 10 - 2 LO
FO-344347	4/6/2016	85	Created							Lab 75 - 4 LO
FO-344662	4/12/2016	79	Created							**ADDING ELECTRICIAN: Install step down transformer and electrical upgrades to acc

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-344767	4/13/2016	78	Hold for Funds							The hand drier in the women's bathroom does not
FO-344833	4/15/2016	76	Created							CLEAN UP ROOF AREA.
FO-344978	4/18/2016	73	Created							UGL lights out: First Floor: Emergency Stairwell near to Room 1234; one light out room
FO-345617	4/19/2016	72	Created							None of the spot lights in the gym are working at all. They are too high to reach. (1st flo
FO-345754	4/21/2016	70	Created							ELECTRIANS TO REMOVE A LIGHT 2ND FLOOR NEW OFFICE SECTION SEE BRU
FO-345755	4/21/2016	70	Created							The stairwell landing facing Cass Ave. has 1 electrical problem.(3rd floor) I had to remov
FO-345765	4/21/2016	70	Hold for Funds							Out light bulbs in the building in the following rooms:
FO-345836	4/22/2016	69	Created							**ADDING ELECTRICIAN: Please hook up electric to 6 new re-circulation pumps locate
FO-345875	4/25/2016	66	Created							Remove light fixture in room 0518 so Engineer can access lint vent, and replace when v
FO-346217	4/27/2016	64	Created							ELECTRICIANS,
FO-346220	4/27/2016	64	Created							ELECTRICIANS,R/R BLDG PLEASE REPLACE DEFECTIVE EBU'S IN STAIRWELL
FO-346758	5/3/2016	58	Created							Recycle the F/E's on the third floor.
FO-346761	5/3/2016	58	Created							There are three lights out in our 562 computer lab, and also in the "ante room" between
FO-347073	5/9/2016	52	Created							(**) PO REQ DK 5/16
FO-347482	5/17/2016	44	Hold for Funds							pls repair electric motor exh fan not running in the bsmt of fpm
FO-347565	5/18/2016	43	Created							Room 2137 - 4 LO
FO-347567	5/18/2016	43	Created							Room 2125 - 1st storage area on the right - all lights are out.
FO-347569	5/18/2016	43	Created							RM 2600 PLEASE REPLACE LIGHT BULBS...
FO-347600	5/18/2016	43	Created							pls deliver 1 barrel of lokor to comp center boiler room
FO-347764	5/20/2016	41	Created							Relamp the three Lecture hals as needed:
FO-347785	5/23/2016	38	Created							The wall light in room 220 has 1 electrical problem.
FO-347827	5/23/2016	38	Created							please check for power to cooling tower fan motor
FO-348288	5/24/2016	37	Created							Please have Maintenance Laborer take scrap metal containers to the scrap yard.
FO-348309	5/25/2016	36	Created							The lights behind the green wall has 3 electrical problems. 2 of them are mercury bulbs.
FO-348316	5/25/2016	36	Created							Fire trouble alarm intermittently goes active. Need
FO-348375	5/25/2016	36	Created							Electricians R&R (3) tagged light fixtures in room 125.2.
FO-348404	5/25/2016	36	Created							Room 004 - 2 LO - EP
FO-348517	5/26/2016	35	Created							R/R RM 315 Reflective light lens has fallen out of the ceiling along with ceiling tiles and i
FO-348534	5/26/2016	35	Created							Electrician
FO-348715	5/31/2016	30	Created							The spotlights outside of room 1600 has 2 electrical problem.
FO-348716	5/31/2016	30	Created							Room 231 has 2 electrical problems.(Basement)
FO-348942	5/31/2016	30	Created							1)light flickering in Ladies Rest Room, Room 1134, behind Circulation Desk. Per Lightin
FO-348978	5/31/2016	30	Created							Time for Laborer to clean shops for Tradesmen for the month of June 2016.
FO-348985	5/31/2016	30	Created							Time for Electricians to Repair/Replace clocks throughout campus for the month of Jun
FO-348989	5/31/2016	30	Created							Team Leader Administrative Time for the month of June 2016.
FO-349006	5/31/2016	30	Created							There is no electrical power under the counter in this control booth. We are currently run
FO-349041	6/1/2016	29	Created							3rd floor several light out in ceiling, cubicle #'s 341.39, 341.48, 341.41, and 341.48.
FO-349058	6/1/2016	29	Created							3rd fl - Women's R/R - 4th stall, LO
FO-349077	6/1/2016	29	Created							The track light has 1 electrical problem. 1 of the lights didn't work in the fixture. (3rd floor
FO-349103	6/1/2016	29	Created							Lighting repair center stairwell lights between 2nd and 3rd floor. Too high to reach.
FO-349193	6/2/2016	28	Created							Room 133 has 1 electrical problem.
FO-349238	6/3/2016	27	Created							Room 1341 has 2 electrical problems. Now there are a total 4 electrical problems in this
FO-349364	6/6/2016	24	Created							Att: ElectriciansR/R RM 00428/HALL Hi-hat lights along catwalk in Schaver Music Rec
FO-349411	6/6/2016	24	Created							Room 032 - 2 EP
FO-349412	6/6/2016	24	Created							Room 251 - 2 EP
FO-349504	6/7/2016	23	Created							Please clean off the roof.
FO-349535	6/8/2016	22	Created							The hallway near the glass facing the State Hall. It's just past the circular stairwell. (1st f

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349551	6/8/2016	22	Created	Light bulb out in front of room 122.						
FO-349565	6/8/2016	22	Created	*6/13/16 - 2 EP, outside of elevators*						
FO-349678	6/9/2016	21	Created	LABORER TO BRING BACK TO FP&M ALL THE SCAFFOLD @ VARIOUS LOCATION						
FO-349746	6/10/2016	20	Created	Replace 24 T8s in Room 101 of State Hall.						
FO-349934	6/14/2016	16	Created	1. Replace burned out bulb in room 385 (inner door 390). Room has restricted lock so						
FO-349957	6/14/2016	16	Created	Need Light bulb replacement. Light out in vohm, auditorium, lobby, basement area and						
FO-349992	6/15/2016	15	Created	The wall light next to the elevator has 1 electrical problem. (1st floor) A GIRF will have t						
FO-350014	6/15/2016	15	Created	R/R ROOF There may be a bad motor on the MED Commons exhaust fan #2. This is I						
FO-350021	6/15/2016	15	Created	Electricians, R/R PENTHOUSE please wire new outside air damper motors on AHU-1.						
FO-350032	6/15/2016	15	Created	Office 1157 (within Dean's/Business Office Suite) bulbs in overhead light are out. All bul						
FO-350060	6/16/2016	14	Created	2 lights replaced on the 1st floor circulation desk						
FO-350150	6/17/2016	13	Created	Room 256 has 1 electrical problem.						
FO-350180	6/17/2016	13	Created	Office 3116 has fixture that needs both lights replaced just inside the door. Please repla						
FO-350195	6/17/2016	13	Created	3 lights out in fume hood 6.						
FO-350605	6/21/2016	9	Created	The light outside of the elevator has 1 electrical problem. (2nd floor)						
FO-350634	6/21/2016	9	Created	Applebaum 5th floor needs lights replaced in hallway by rooms: 5138, 5148, 5128, 512						
FO-350672	6/22/2016	8	Created	The switch in the waiting room is not working.						
FO-350698	6/22/2016	8	Created	electricianR/R PENTHOUSE replace burned out light bulbs for all electrical equipment						
FO-350722	6/22/2016	8	Created	R/R RM 5131 The slider light switch in one of our ancillary rooms is						
FO-350751	6/23/2016	7	Created	The hallway outside of Range 258 has 1 electrical problem. (2nd floor)						
FO-350834	6/23/2016	7	Created	2nd fl - room 237 - See front desk first. Also there are lights outside of rooms, 200, 211,						
FO-350839	6/24/2016	6	Created	Room 2343 has 1 electrical problem.						
FO-350990	6/27/2016	3	Created	Room # 271 - EPs - 3 fixtures out.						
FO-350991	6/27/2016	3	Created	Room 237 - 7 fixtures out.						
FO-351098	6/28/2016	2	Created	The overhead light outside of the guard's desk has 1 electrical problem.						
FO-351185	6/29/2016	1	Created	R/R RM 6204 have electricians check nac panels 12 and 13 on the 6th floor.						
FO-351174	6/29/2016	1	Created	The men's locker room has 1 electrical problem. (Basement) A GIRF has to be generate						
FO-351191	6/29/2016	1	Created	trade labor priority high						
FO-351221	6/29/2016	1	Created	R/R RM 00100/MECH RM please have electricians check air compressor #1 will not cyc						
FO-351215	6/29/2016	1	Created	Time for taking/picking up Ford Transit to/from Ford (Maxey) Dealership for repair.						
FO-351231	6/29/2016	1	Created	Have Jim deliver						
FO-351232	6/29/2016	1	Created	Have Jim deliver						
FO-351259	6/30/2016	0	Created	The entrance light has 1 electrical problem.						
FO-351260	6/30/2016	0	Created	The Men's restroom has 1 electrical problem. (3rd floor)						
FO-351263	6/30/2016	0	Created	Range 202 has 1 electrical problem.						
FO-351267	6/30/2016	0	Created	Lights over the table and chairs. It's outside of range 173. (1st floor)						
FO-351276	6/30/2016	0	Created	Connected labs 4230 & 4240 have about 6 lights out that need repair. Room 4230 has 1						
FO-351292	6/30/2016	0	Created	Electrician						
FO-351289	6/30/2016	0	Created	Purdy Library 1st Floor, Room 131						
FO-351294	6/30/2016	0	Created	There are two overhead hoods broken in the third floor lab. The UV lights are also brok						
T - Handyman			2	0	0	2	0	0	0	
FO-344528	4/11/2016	80	Created	Move Custodial key cabinet for Sector 9 from current Sector 9 office (east end of Macca						
FO-344529	4/11/2016	80	Created	Move Custodial key cabinet for Sector 7 from current Sector 7 office (Room 014), to Ro						
T - Laborer			2	0	0	1	0	1	0	
FO-324960	8/19/2015	316	Created	LABORER: Please have Laborer transport material form stock room to State Hall. See						
FO-345862	4/22/2016	69	Created	build scaffold for electricians hold for tear down						
T - Locksmith			38	34	1	0	3	0	0	
FO-342261	3/16/2016	106	Created	New KeyNew Space AssignmentKey #: 25300Key Holder ID: Thomas J. Edwards						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-343040	3/23/2016	99	Created	New KeyNew Space AssignmentKey #: Brown Box key for General LecturesKey H						
FO-344277	3/29/2016	93	Created	New Key						
FO-348445	5/26/2016	35	Created	room 158- broken key in key core.						
FO-349059	6/1/2016	29	Created	KEYS & CORES (JUNE 2016)						
FO-349307	6/2/2016	28	Created	Core ChangeNew Space AssignmentKey #: 30AAB7 - SCB StorageKey Holder ID:						
FO-349308	6/2/2016	28	Created	Core ChangeNew Space AssignmentKey #: 14A1Key Holder ID: N/AQty: 1a						
FO-349309	6/2/2016	28	Created	Core Change						
FO-349481	6/2/2016	28	Created	Replacement						
FO-349333	6/6/2016	24	Created	98-Keys needed for Atchison Dorm Rooms (All Floors) See attached list. Keys blanks wi						
FO-349407	6/6/2016	24	Created	CARPENTER TO UNLOCK CASSIE'S OFFICE DOOR & PROVIDE NEW KEYS						
FO-350113	6/16/2016	14	Created	New KeyLost / StolenKey #: HON 110EKey Holder ID: Louise DezurQty: 2ac						
FO-350112	6/16/2016	14	Created	New KeyLost / StolenKey #: M32Key Holder ID: Louise DezurQty: 2action:						
FO-350110	6/16/2016	14	Created	New KeyLost / StolenKey #: M120Key Holder ID: Louise DezurQty: 2action:						
FO-350139	6/16/2016	14	Created	New KeyNew Staff MemberKey #: 89641-25Key Holder ID: Daniel Desantis, Linda						
FO-350137	6/16/2016	14	Created	New KeyNew Space AssignmentKey #: 31305 / Core G-26xKey Holder ID: College						
FO-350136	6/16/2016	14	Created	New KeyNew Space AssignmentKey #: 111509Key Holder ID: Sharon PepeQty:						
FO-350185	6/17/2016	13	Created	New Key						
FO-350574	6/17/2016	13	Created	New KeyNew Space AssignmentKey #: 7AA12.7, 27273Key Holder ID: StaffQty:						
FO-350572	6/17/2016	13	Created	New KeyLost / StolenKey #: 67156Key Holder ID: Jackie BaldygaQty: 10acti						
FO-350568	6/17/2016	13	Created	New KeyLost / StolenKey #: 67657Key Holder ID: Jackie BaldygaQty: 5actio						
FO-350565	6/20/2016	10	Created	New KeyLost / StolenKey #: SMMP9Key Holder ID: carol talbottQty: 3action:						
FO-350618	6/21/2016	9	Created	New KeyNew Staff MemberKey #: 76811Key Holder ID: Jason D. CruzQty: 1						
FO-350616	6/21/2016	9	Created	New KeyLost / StolenKey #: 111509Key Holder ID: Sharon PepeQty: 7actio						
FO-350684	6/22/2016	8	Created	ReplacementLost / StolenKey #: 103TAKey Holder ID: Bruce MorganQty: Two						
FO-350845	6/23/2016	7	Created	New KeyLost / StolenKey #: 108R, 125R,130R, 133R,140E, 159R, 818EKey Holde						
FO-350857	6/24/2016	6	Created	New KeyNew Staff MemberKey #: 16AD7 No CoreKey Holder ID: Angelica Reyna						
FO-350988	6/24/2016	6	Created	New KeyNew Staff MemberKey #: 10AE28XKey Holder ID: Roselle CooperQty: 3						
FO-350945	6/24/2016	6	Created	New KeyNew Staff MemberKey #: 72365.1Key Holder ID: Valeria CookQty: 2						
FO-351051	6/27/2016	3	Created	New KeyNew Staff MemberKey #: 7892Key Holder ID: Ben KidderQty: 2acti						
FO-351052	6/27/2016	3	Created	New KeyNew Staff MemberKey #: 7892Key Holder ID: Runsheng HeQty: 1a						
FO-351053	6/27/2016	3	Created	New KeyNew Space AssignmentKey #: 7892Key Holder ID: Robert LasleyQty: 1						
FO-351173	6/28/2016	2	Created	ReplacementLost / StolenKey #: unknowmKey Holder ID: shelley cliftonQty: 2						
FO-351172	6/28/2016	2	Created	New KeyNew Staff MemberKey #: 120317Key Holder ID: Margaret Qty: 1act						
FO-351171	6/28/2016	2	Created	New KeyNew Space AssignmentKey #: 101327Key Holder ID: Amy HaysQty: 2						
FO-351244	6/29/2016	1	Created	New KeyNew Space AssignmentKey #: Core G-66 (32ST)Key Holder ID: College o						
FO-351248	6/30/2016	0	Created	New KeyNew Staff MemberKey #: 28613Key Holder ID: Derrielle GoodwinQty: 1						
FO-351298	6/30/2016	0	Created	New KeyNew Staff MemberKey #: 19185-23Key Holder ID: Roselle CooperQty: 4						
T - Painter			24	22	2	0	0	0	0	
FO-347483	5/17/2016	44	Created	Trade: PainterPriority: LowPlease scrape and paint the cooling tower pipes on both						
FO-347536	5/17/2016	44	Created	Repair, Prime & paint to finish, all study rooms on 1st floor.						
FO-348987	5/31/2016	30	Created	Patch, sand, Prime & Paint walls in library area.						
FO-349056	6/1/2016	29	Created	HANDY MAN TIME (JUNE 2016)						
FO-349128	6/1/2016	29	Created	PAINT SAFTEY GATE FOR LIFT IN BASEMENT.						
FO-349141	6/2/2016	28	Created	CLEAN & PAINT OVER GRAFFITI FOR THE MONTH OF JUNE.						
FO-349142	6/2/2016	28	Created	PAINTING BIDS, & MAINETENACE JOBS FOR THE MONTH OF JUNE.						
FO-349899	6/14/2016	16	Created	Clean, Scrape & Paint all Garbage can lids.						
FO-350029	6/15/2016	15	Created	PAINTERS TO MUD & PAINT CEILING RIGHT ABOVE MAIN ENTRANCE 1ST FLOO						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-350183	6/17/2016	13	Created	Paint Black handrail, entire campus.							
FO-350256	6/20/2016	10	Created	PAINTER TO TOUCH UP AREA BEHIND RECEPTION COUNTER STUDENT ACADE							
FO-350628	6/21/2016	9	Created	PAINTERS TO ORDER 2 CASES OF SILKA FLEX 1A EXTERIOR CAULK LIMESTON							
FO-350631	6/21/2016	9	Created	Scrape, Prime & Paint gang box for plumbers							
FO-350830	6/23/2016	7	Created	Paint the exterior steel on the roof.							
FO-350868	6/24/2016	6	Created	FIRE EXT NEED TO RECHARGE DISCREPANCY FOR 001727 [01727] NEAR RM 149							
FO-350946	6/24/2016	6	Created	FIRE EXT NEEDS RECHARGE [02]; [01727] NEAR RM 149 1ST FLR HALLWAY (OR							
FO-350947	6/24/2016	6	Created	FIRE EXT NEEDS RECHARGE [02]; [7009] STAGE (ORM WO# 000855)							
FO-350962	6/24/2016	6	Created	FIRE EXT PIN MISSING [01]; [7009] STAGE (ORM WO# 000856)							
FO-351073	6/27/2016	3	Created	Connecting hallway between room 404 & 405 North wall, Plaster Repair & Paint.							
FO-351096	6/28/2016	2	Created	R/R 2ND FLR paint RAMP LEADING TO 3RD FLR							
FO-351097	6/28/2016	2	Created	R/R 2ND FLR MAIN HALLWAYS paint walls.							
FO-351156	6/28/2016	2	Created	FIRE EXT {Incident:[01] PIN MISSING; [015LM]: NEAR STRWL"A" 1ST FLR HALLWA							
FO-351169	6/29/2016	1	Created	SCRAPE, PRIME & PAINT TO FINISH ALL BENCHES, ENTIRE CAMPUS.							
FO-351170	6/29/2016	1	Created	SCRAPE, PRIME & PAINT ALL HANDRAIL, NORTH & SOUTHSIDE OF BUILDING.							
T - Pipefitter				39	6	3	3	8	11	8	
FO-315927	3/26/2015	462	Created	desired_date: 04/30/2015							
FO-317219	5/1/2015	426	Created	funding_source: Deferred Maintenancefunding_year: 2015project_description: 5 cam							
FO-327157	5/27/2015	400	Created	contact_email: dkuffner@wayne.edudesired_date: 06/30/2015funding_source: deferr							
FO-318201	5/28/2015	399	Created	The relief valve's body plug blew out , isolated the system ,and put boilers back in servic							
FO-319894	6/15/2015	381	Created	Steam supply gate valve on AH#6 is leaking through. Please replace 1 1/2" gate valve ,,							
FO-320421	6/23/2015	373	Created	PIPEFITTERS							
FO-320728	6/29/2015	367	Created	R/R abated condensate return piping in penthouse ,,,,,,,,,, EA/6-29-15 ,,,,,,,,,,							
FO-320821	6/30/2015	366	Created	(**) PO REQ DK 7/30 *REM 2/15							
FO-322044	7/15/2015	351	Created	Pipe fitters: please repair steam leaks on 3 flanges on steam main line to PRVs. Priority							
FO-322148	7/16/2015	350	Created	(**) PO REQ DK 7/3 *REM 2/15							
FO-322879	7/24/2015	342	Created	(**) PO REQ DK 7/30 *REM 2/15							
FO-323814	8/6/2015	329	Created	please repair loose railing on the southside stairs.....EA....8-5-15							
FO-324275	8/13/2015	322	Created	FITTERS,							
FO-325320	8/25/2015	310	Created	Needs an inhibitor injection point on the main header for the cooling tower. This will req							
FO-328672	10/3/2015	271	Created	Due to continual water leak, please repair plaster, repaint and clean up fallen plaster in t							
FO-329268	10/9/2015	265	Created	Pipefitters to remove both ERC coils inside ahu's 1 and 2. Located in penthouse. Old sy							
FO-329640	10/14/2015	260	Created	(**) PO REQ DK 1/6							
FO-332190	11/9/2015	234	Created	(**) PO REQ DK 12/7 *REM 2/15							
FO-335676	12/23/2015	190	Created	Please repair the HVAC unit , the water supply line (Braided) is leaking down into the							
FO-335927	1/4/2016	178	Created	(**) PO REQ DK 2/1/16 JWT							
FO-336898	1/14/2016	168	Created	Insulate duct work in basement vending area that is dripping from condensation. See Tr							
FO-338059	1/27/2016	155	Created	Install blow down controller from Eldon. See engineer for details/location,,,,,,,,,,,,, R							
FO-338265	1/30/2016	152	Created	Replace pipe machine dies 1/8" thru 2" ,,,,,,,,,, JT/ 1-30-16 ,,,,,,,,,,							
FO-339476	2/13/2016	138	Created	Replacement of 2 impact guns ,,,,,,,,,, JH/2-13-16 ,,,,,,,,,,							
FO-340026	2/19/2016	132	Created	Steven Pecic 10/23/2014 11:20 - Plant Fund Request Number ONLY: Scott Hall Mecha							
FO-341774	3/9/2016	113	Created	(**) PO REQ DK 4/8							
FO-342462	3/21/2016	101	Created	R/R leaking tube bundle in domestic water heater in basement mechanical room ,,,,,,,,,,							
FO-344193	4/5/2016	86	Created	(**) PO REQ DK 5/16							
FO-344290	4/6/2016	85	Created	FITTERS,							
FO-346106	4/26/2016	65	Created	(**) PO REQ DK 5/16							
FO-347367	5/13/2016	48	Created	Need 2 ridged shaft couplings for chill water Dezurik diversion butterfly valves located in							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-347801	5/23/2016	38	Created	Repair condensate receiver pump bolts if possible for future replacement of condensate							
FO-348241	5/24/2016	37	Created	FITTERS,							
FO-349916	6/14/2016	16	Created	(**) PO REQ DK 6/14							
FO-350726	6/22/2016	8	Created	Fitter R/R RM 2218 inspect operation of domestic hot water heater for glass wash.							
FO-350851	6/24/2016	6	Created	wet ceiling tiles in lab 315. Please repair leak..... CB/6/24							
FO-351180	6/29/2016	1	Created	R/R RM 00100/MECH RM please have pipe fitters repair leaks on hydronics supply line i							
FO-351175	6/29/2016	1	Created	Check with Jon or Percy on a cooling problem for the Laser lab per Steven							J
FO-351227	6/29/2016	1	Created	Room 3217 steam control valve leaking, Corey has isolated							CB/6/29
T - Plumber				101	20	10	8	28	26	9	
FO-307587	1/30/2015	517	Created	Trade: Plumber							
FO-313377	4/1/2015	456	Created	(**) PO REQ DK ON FO#313380GS FOR BOTH CHILLER UNITS JWT							
FO-313380	4/1/2015	456	Created	(**) PO REQ DK 10/6 Both Chiller Units JWT / **REM 2/15/16							
FO-317222	5/6/2015	421	Created	contact_email: aa9028@wayne.edu							
FO-317928	5/22/2015	405	Not Finished	(**) PO #1 REQ DK 5-29-15							
FO-318333	5/29/2015	398	Created	Kresge Library 3rd floor Men R.R. & Purdy Library 2nd floor Men R.R. #240 there is a							
FO-318387	6/1/2015	395	Not Finished	(**) PO REQ DK 2/22 STEEL							
FO-320769	6/30/2015	366	Created	Water is dripping from Fawcett near door # 027 06 W along the wall outside of the Kre							
FO-320827	6/30/2015	366	Created	Women restroom #130 on the first floor one of the toilets is broken..... DB/6-30-15							
FO-321456	7/9/2015	357	Created	Cinder block is wet from ceiling to floor at the entrance of the department. Not sure if thi							
FO-322056	7/15/2015	351	Created	Check drain line on 2nd floor master bathroom. Leak showing up in ceiling of front room							
FO-322790	7/23/2015	343	Created	Trade: Plumber Priority: Low							
FO-322801	7/23/2015	343	Created	please repair/replace zurn optyic faucet in room 419.....GS/7-23-15							
FO-322804	7/23/2015	343	Created	please repair/replace 4 leaking faucets in womens staff restroom romm 233..... GS/7-							
FO-323446	8/3/2015	332	Created	Plumbers: Please replace cracked and leaking storm drain line inside mechanical room							
FO-323776	8/5/2015	330	Created	R/R RM 13124/WOMENS RR All three toilets in the women's restroom are leaking from							
FO-324403	8/14/2015	321	Created	Replace leaking urinal PRV for 1st and 2nd floor mens room, DB/8-14-15							
FO-325126	8/21/2015	314	Created	Replace leaking urinal PRV for 1st and 2nd floor mens room, DB/8-14-15							
FO-325299	8/25/2015	310	Created	Purdy Library 1st Floor Staff Women's restroom							
FO-325538	8/27/2015	308	Created	(**) PO REQ DK 9/28							
FO-325789	9/1/2015	303	Created	(**) PO REQ DK 12/7							
FO-326398	9/4/2015	300	Not Finished	After last night's hard rain we noticed a substantial							
FO-327156	9/17/2015	287	Created	contact_email: aa9028@wayne.edu							
FO-327159	9/17/2015	287	Created	Plant Fund Account - Campus Water Bottle Filling Stations.							
FO-327785	9/22/2015	282	Created	Plumbers, restore water pressure to urinal tanks in mens basement bathroom							
FO-330791	10/22/2015	252	Created	R/R Room 300- toilet fixture is loose from the floor, and seat is loose from the fixture.							
FO-331068	10/27/2015	247	Created	(**) PO REQ DK 12/17 /*REM 2/15							
FO-331482	10/31/2015	243	Created	(**) PO REQ DK 12/7 / *REM 2/15							
FO-331489	10/31/2015	243	Created	(**) PO REQ DK 12/8 *REM 2/15							
FO-331923	11/4/2015	239	Created	(**) PO REQ DK 4/4							
FO-334798	12/13/2015	200	Created	Restore water supply to custodial slop sink located in room 018 at Shapiro Hall. There is							
FO-334893	12/14/2015	199	Created	Plumbers: Med Priority.							
FO-334894	12/14/2015	199	Created	Plumbers: Med Priority.							
FO-335050	12/16/2015	197	Created	(**)PO REQ #2 DK 2/15							
FO-335782	12/30/2015	183	Created	Evaluate domestic back feed water supply from mechanical room 047 to Music that will							
FO-337091	1/17/2016	165	Created	*Check on dock in the mornings and Keep loading dock free of water and debris as nee							
FO-337094	1/17/2016	165	Created	Repair Delta kitchen faucet leaking at cam packing located in Workroom 122 at 60 W. H							
FO-337095	1/17/2016	165	Created	Repair Delta faucet located in lavatory near Room 110 is leaking at cam packing. 60 W.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-337096	1/17/2016	165	Created	Repair low hot water pressure and flow to the second level of 60 W. Hancock, including						
FO-338161	1/29/2016	153	Created	(**) PO REQ DK 4/4 REVISED ETNA						
FO-338268	1/29/2016	153	Created	Please tighten all toilet seats.						
FO-338269	1/29/2016	153	Created	Please repair toilet with bag over it. It has been						
FO-338270	1/29/2016	153	Created	water fountain near 1515 is not working. Please						
FO-338358	2/1/2016	150	Created	The toilet in the stall in 2438 is leaking water on the						
FO-338751	2/3/2016	148	Created	(**) PO REQ DK 2/22						
FO-338938	2/5/2016	146	Created	(**) PO REQ DK 2/23						
FO-339071	2/6/2016	145	Created	Please install a cold water line up to the rooftop decking so that the air conditioning syst						
FO-339202	2/9/2016	142	Created	R/R Basement floor SOUTHEND NEAR ELEVS' women's public bathroom 1ST stall TO						
FO-339211	2/9/2016	142	Created	R/R 1st floor SOUTHEND mens public restroom - south end of the building need 4 OUT						
FO-340307	2/24/2016	127	Created	Trade: PlumberPriority: Medium2nd stall on left has leaking tail pipe and need Sloan						
FO-340442	2/25/2016	126	Created	Sanitary waste pipe is leaking at ceiling, and at floor elbow.,,,,,,,,,, TT/2-25-16 ,,,,,,						
FO-340563	2/26/2016	125	Created	Repair flush valve assembly on the 1st toilet to the left in Men's lavatory, near 338 Cohn						
FO-341487	3/4/2016	118	Created	Please repair toilet seat in women's bathroom on 1st floor near elevator. The seat is off						
FO-341515	3/7/2016	115	Created	Replace gate valves in water meter room ,,,,,,,,,,DB/3-7-16 ,,,,,,,,,,						
FO-341570	3/7/2016	115	Created	Material for backflows in all cold rooms ,,,,,,,,,, DB/ 3-7-16 ,,,,,,,,,,						
FO-341720	3/9/2016	113	Created	Please repair urinal on 1st floor. Appears to be plugged.						
FO-341818	3/9/2016	113	Created	Investigate water in Parking Lot possible water main leak ,,,,,,,,,, JT/3-9-16 ,,,,,,,,,,						
FO-342069	3/11/2016	111	Created	R/R water main leak in parking lot ,,,,,,,,,, DB/3-11-16 ,,,,,,,,,,						
FO-342169	3/15/2016	107	Created	(**) PO REQ DK 4/8						
FO-342275	3/16/2016	106	Created	Slop-sink in the janitors closet is leaking. ,,,,,,,,,, GS / 3-18-16 ,,,,,,,,,,						
FO-343008	3/23/2016	99	Created	Organize plumbing parts room ,,,,,,,,,, DB/3-23-16 ,,,,,,,,,,						
FO-343398	3/29/2016	93	Created	1st floor men's room near room 1118, second stall toilet seat broken.,,,,,,,,,, TT/3-2						
FO-343620	3/31/2016	91	Created	1st floor, last stall (handicap stall), mens restroom,						
FO-347670	4/1/2016	90	Cancelled	Suite 350 remove steel pipe (Abandoned Drain Line)so carpet can be put down ,,,,,,,,,,						
FO-343721	4/4/2016	87	Created	(**) PO REQ DK 4/8						
FO-344232	4/5/2016	86	Created	Evaluate replacing sump pumps with new Submersible Shredders ,,,,,,,,,, DB/4-5-16 ,						
FO-344677	4/13/2016	78	Created	(**) PO REQ DK 4/27						
FO-344926	4/18/2016	73	Created	TOILET SEAT IS BROKEN. WOMEN'S RESTROOM. ROOM 0129. 1ST STALL.,,,,,,,,,,						
FO-345679	4/20/2016	71	Created	R/R RM 128/LNGE Please repair garbage disposal unit under sink in staff lounge. Unit i						
FO-346204	4/27/2016	64	Created	PLUMBERS TO DISCONNECTED PVC PIPE TO ALLOW THE CARPENTERS TO SET						
FO-346232	4/27/2016	64	Created	Sink is leaking in the Woman's restroom on the first floor.						
FO-346804	5/4/2016	57	Created	Plumbers: please repair middle sink in ladies room 102, it doesn't work . Priority: low.,,,,,,						
FO-346808	5/4/2016	57	Created	Plumbers: please unplug 1st toilet from right in ladies room 130. priority: low.,,,,,,,,,,						
FO-346868	5/5/2016	56	Created	BACKFLOW TESTERS YEARLY RECALIBRATION ,,,,,,,,,, DB/5-5-16 ,,,,,,,,,,						
FO-347256	5/11/2016	50	Created	Evaluate pool level issue ,,,,,,,,,, DB/5-11-16 ,,,,,,,,,,						
FO-347370	5/13/2016	48	Created	Evaluate fire meter change request at Chatsworth, Rackham, CJI, Bio Engineer. See Jo						
FO-347548	5/17/2016	44	Created	In room 1213 Evaluate replacing current fire protection meter pit manhole cover so DW						
FO-347550	5/17/2016	44	Created	Evaluate running utility's for washer and dryer for Diana from grounds ,,,,,,,,,, TT/5-						
FO-347775	5/20/2016	41	Created	Please repair the leak coming from the room above main entry to building ,						
FO-348405	5/25/2016	36	Created	Evaluate cost to install 3 more bottle filling stations. See Jackie Baldyga 313 577 2057 f						
FO-348564	5/27/2016	34	Created	R/R RM 00154/LAB DI Faucet is leaking and will not turn off completely ,,,,,,,,,, M						
FO-349322	6/2/2016	28	Created	SAFETY MEETING ,,,,,,,,,, MM/6-2-16 ,,,,,,,,,,						
FO-349235	6/3/2016	27	Created	Administrative Time for June 2016						
FO-349465	6/7/2016	23	Created	Cut waste stack at 10th floor to retrieve wedged sewer cable ,,,,,,,,,, GS/6/7/16 ,,,,,,						
FO-349484	6/7/2016	23	Created	Replacement 1 1/4" snake ,,,,,,,,,, GS/6-7-16 ,,,,,,,,,,						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-349508	6/7/2016	23	Created	Have new tags created for backflow testing ,,,,,,,,,,,,,, DB/6-7-16 ,,,,,,,,,,,,,,							
FO-349571	6/8/2016	22	Created	Pump out loading dock after each rain until jetting can be funded ,,,,,,,,,,,,,, MM/6-8-16 ,,							
FO-349699	6/10/2016	20	Created	R/R RM 00451/DLAR Drain pipe going under sink and into wall in room 451 at Lande ne							
FO-349710	6/10/2016	20	Created	R/R RM 00451/DLAR Copper water pipe going to rackwasher in room 451 at Lande nee							
FO-350132	6/17/2016	13	Created	Plumbers -Medium priority- Please clear clogged drain underneath the minus 80 freezer.							
FO-350173	6/17/2016	13	Created	Repair/replace PRV in pool area basement along east wall near pot filter. PRV eight fee							
FO-350228	6/20/2016	10	Cancelled	First bathroom sink faucet is broken.							
FO-350784	6/23/2016	7	Created	Ladies restroom, toilet set broken in second stall. please fix/replace thank you ,,,,,,,,,,,,,,							
FO-350954	6/24/2016	6	Created	Water in women's shower stall will not turn on.,,,,,,,,,,,,,, GS/6-27 ,,,,,,,,,,,,,,							
FO-351062	6/27/2016	3	Created	PLUM							
FO-351117	6/28/2016	2	Created	Plumbers,							
FO-351151	6/28/2016	2	Created	R/R 13TH FLR Men's bathroom #13128-nearest Freight Elevator - Water will not go dow							
FO-351168	6/28/2016	2	Created	PLUMBERS/Refer to FO-350030:							
FO-351158	6/28/2016	2	Created	Repairs for Victaulic hand groover ,,,,,,,,,,,,,, DB/6/28 ,,,,,,,,,,,,,,							
FO-351285	6/30/2016	0	Created	ladies restroom next to #203-please fix toilet seat and check for leak in third stall. the toil							
FO-351286	6/30/2016	0	Created	2nd floor ladies restroom - please fix faucet at middle sink -does not work (no water flow							
T - Roofing				11	0	0	2	5	2	2	
FO-312372	3/24/2015	464	Created	Repair/Replace 2 flashings on the rear side of the FP&M Grounds department building.							
FO-318286	5/29/2015	398	Created	Roofer; Medium							
FO-330526	10/20/2015	254	Created	Carpenters please shingle roof at Freer House with shingles located in the basement (at							
FO-331223	10/28/2015	246	Created	ROOF LEAKS IN ROOMS 4001 AND 4339. Repairs have been made. Tracking rain day							
FO-340389	2/24/2016	127	Created	R/R RM 00316 3rd floor, Office #316, window is leaking water, do have a waste basket							
FO-341836	3/9/2016	113	Created	R/R Roofer needed for leak in NE area of building at 1200 Holden The leak is over							
FO-342040	3/13/2016	109	Created	Water dripping through wall at top, on south side, 2nd flr, Kresge. This problem was rep							
FO-342054	3/14/2016	108	Created	SKYVIEW CENTER GLASS LEAKING							
FO-343202	3/25/2016	97	Created	To roofers. Skylight in this bathroom is leaking please repair.							
FO-343669	4/1/2016	90	Created	ROOFER,PLEASE REPAIR ROOF LEAK.PRIORITY-LOW							
FO-344423	4/8/2016	83	Created	RoofersRepair rain water leak into Lethal Chamber.							
T - Sheetmetal				5	0	0	0	2	0	3	
FO-307827	2/4/2015	512	Created	Trade: Sheet MetalPriority: LowPlease replace missing guards on exhaust fans 5 &							
FO-312617	3/27/2015	461	Created	Sheet Metal- please install new flex duct and or transition duct on new heat pump instal							
FO-315320	4/21/2015	436	Created	Ex Fans #1 & #6 on roof have broken cover clamps that need to be replaced.							
FO-337594	1/21/2016	161	Created	Purdy Library Basement							
FO-342199	3/15/2016	107	Created	Trade: Sheet MetalPriority: HighPlease repair duct connectors for fume hood 260-8							
Routine				14	7	0	0	0	5	2	7
T - Electrician				9	7	0	0	0	2	0	
FO-323561	8/4/2015	331	Created	PS#1 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015							
FO-331817	11/3/2015	240	Not Finished	CAMPUS LOTS ROUTINE CHECK 11/1 THRU 11/30/15							
FO-349061	6/1/2016	29	Created	PS#1 - Routine Check - 6/1 thru 6/30/16							
FO-349062	6/1/2016	29	Created	PS#2 - Routine Check - 6/1 thru 6/30/16							
FO-349065	6/1/2016	29	Created	PS#3 - Routine Check - 6/1 thru 6/30/16							
FO-349066	6/1/2016	29	Created	PS#4 - Routine Check - 6/1 thru 6/30/16							
FO-349067	6/1/2016	29	Created	PS#5 - Routine Check - 6/1 thru 6/30/16							
FO-349068	6/1/2016	29	Created	PS#6 - Routine Check - 6/1 thru 6/30/16							
FO-349070	6/1/2016	29	Created	Campus Lots - Routine Check - 6/1 thru 6/30/16							
T - Plumber				5	0	0	0	0	3	2	
FO-311522	3/17/2015	471	Created	(**) PO REQ DK 12/7							
FO-316655	5/5/2015	422	Created	BFS/2015							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-325105	8/21/2015	314	Created	Please Test, Inspect and Repair Backflow Devices in Building. Complete Testing Recor						
FO-329205	10/8/2015	266	Created	BFS/2015						
FO-332597	11/15/2015	228	Hold for Funds	(HFF) PER DK 3/30						

Total: 1599