

Facilities Operations Work Orders Received 4/1/2014 through 4/30/2014

WO	Recieved	Finished	Total	Request	
Maint. Work Order (MWRf)			2005		
Custodial			183		
High			1		
C-Lighting			1		
FO-282419	4/23/2014	4/24/2014		2 lights out in room# 26.1, Basement.	
Medium			2		
C-Repair			1		
FO-281023	4/8/2014			First Floor Women's Restroom	1. Paper toweling dispenser does not operate pr
C-Sector 02			1		
FO-280855	4/7/2014	4/7/2014		Scrub floor in inblaming room 521	
Low			178		
C-Director			4		
FO-281292	4/10/2014	4/10/2014		custodial to provide supplies for 5425 Woodward project. Provided are: toilet Paper Dispenser,	
FO-281338	4/11/2014			custodial to provide support for Admitted Students Day on Saturday April 12, 2014 to the follo	
FO-281702	4/15/2014	4/15/2014		Custodial to provide Saturday support for events.	
FO-281719	4/15/2014	4/25/2014		Custodial to provide support for Students Day via Admissions Office. Custodial to support: Co	
C-Lighting			76		
FO-280075	4/1/2014	4/3/2014		Light bulb needs to be replaced in the garage near the time clock at the north back entrance.	
FO-280101	4/1/2014	4/2/2014		2 or 3 lights need to replaced in room# 0274	
FO-280116	4/1/2014	4/1/2014		Light bulb out :	
FO-280159	4/1/2014	4/2/2014		Hallway outside room 322: burned out lightbulb, please replace.	
FO-280160	4/1/2014	4/2/2014		Hallway outside room 232: burned out lightbulb, please replace.	
FO-280171	4/1/2014	4/2/2014		Lights flickering in room 2221.	
FO-280184	4/1/2014	4/2/2014		In the handicap stall of the 2nd floor men's restroom the light is out. Task Complete.	
FO-280505	4/2/2014	4/3/2014		Please replace all of the the lights in the cold room (please see Jim Stoddart about this when t	
FO-280521	4/2/2014	4/2/2014		light bulbs out in room 300.6, and 300.1. Task 300.6 complete. Task 300.1 has been sent to el	
FO-280573	4/2/2014	4/3/2014		Stairwell J between Ground and 1st floor there	
FO-280575	4/2/2014	4/3/2014		Stairwell A on ground floor there is a light out;	
FO-280576	4/2/2014	4/4/2014		Ground floor in front of elevators there is a	
FO-280625	4/3/2014	4/3/2014		Some of the lights are out in the Women's	
FO-280751	4/4/2014	4/7/2014		Light out in Law IT Suite #3320	
FO-280785	4/4/2014	4/7/2014		Entryway to room 230: light bulb burned out above door (second door). Please replace.	
FO-280838	4/7/2014	4/8/2014		Hallway outside 310: burned out lightbulb, please replace.	
FO-280882	4/7/2014	4/8/2014		3 lights out in lobby.	
FO-280883	4/7/2014	4/8/2014		Lights out downstairs lobby. Task Complete.No problems.	
FO-280893	4/7/2014	4/8/2014		lights dim in hall outside of suite 2317. Would like brighter lights.	
FO-281010	4/8/2014	4/9/2014		Room 2106 - MD Lab - Several bubls burnt out in thrird row of lights and entire panel out in 3rd	
FO-281011	4/8/2014	4/9/2014		Room 2116 - MD Lab - Several bulbs burnt out or flickering in 2nd row, 3rd row and 5th row of	
FO-281012	4/8/2014	4/9/2014		Room 2136 - MD Lab - lights burnt out in 1st and 4th rows, please fix.	
FO-281013	4/8/2014	4/9/2014		Room 2228 - MD Lab - lights burnt out in 2nd and 5th rows, please fix.	
FO-281014	4/8/2014	4/9/2014		Room 2258 - MD Lab - lights burnt out in 1st and 4th rows, and entire panel out in 5th row, ple	
FO-281020	4/8/2014	4/8/2014		3rd floor ladies room has a burned out bulb in front of the middle stall.	
FO-281057	4/8/2014	4/9/2014		Real room number is 125.4.	
FO-281085	4/9/2014	4/9/2014		There is a light out in the 2nd floor office hallway between rooms 248 & 246. This task is com	
FO-281101	4/9/2014	4/10/2014		light bulb out on the fourth floor	

WO	Recieved	Finished	Total	Request
FO-281102	4/9/2014	4/9/2014		Light Bulb out in 300.6, and 300.1 This task has been attended to. F O 280579 is the electri
FO-281106	4/9/2014	4/9/2014		light bulb out in the ladies room, 7204
FO-281119	4/9/2014	4/10/2014		Three burned-out lightbulbs in new portion of building, as you enter Scott Hall.
FO-281201	4/10/2014	4/14/2014		Purdy Library, 2nd Floor
FO-281202	4/10/2014	4/11/2014		Purdy Library, 3rd Floor
FO-281273	4/10/2014	4/11/2014		There are about 5-6 lights out in the
FO-281359	4/11/2014	4/14/2014		ceiling light bulb needs replacing, requests a softer light, not the bright one, request for TODA
FO-281372	4/11/2014	4/14/2014		Need cool lights in front of Dean's office on 1st floor. This request has been taken care of.No
FO-281405	4/11/2014	4/15/2014		To swap out all of the CFL's in MCR with
FO-281513	4/14/2014	4/15/2014		Burned out lightbulbs, please replace.
FO-281532	4/14/2014	4/15/2014		Room 5350 as 11 lights that are out. Please change them. Thanks!
FO-281562	4/14/2014	4/15/2014		3 lights out in room 415. Task Complete.
FO-281564	4/14/2014	4/15/2014		Burned out lightbulb just inside door, please replace.
FO-281673	4/15/2014	4/16/2014		Hallway by room 3338 (hallway outside lecture halls) several burnt out lights - please fix.
FO-281675	4/15/2014	4/16/2014		Hallway by room 3338 (hallway outside lecture halls) Light lens is hanging open - please fix.
FO-281715	4/15/2014	4/16/2014		Room 3220 has lights out. Please change. Thanks.
FO-281761	4/16/2014	4/18/2014		Light Changers please replace burned out lights in mens restroom 19. Task Complete.
FO-281762	4/16/2014	4/18/2014		Light Changers please replace burned out lights in room 211. Task Complete.
FO-281763	4/16/2014	4/18/2014		Light Changers please replace burned out lights in mens restroom 210. Task Complete.
FO-281787	4/16/2014	4/16/2014		Two pod lights in our staff office waiting area
FO-281950	4/18/2014	4/21/2014		2 light bulbs out in hallway outside of room 2133
FO-282014	4/21/2014	4/22/2014		One ceiling light bulb is out.
FO-282037	4/21/2014	4/21/2014		Relamp light fixture in room 150.8.
FO-282112	4/21/2014	4/22/2014		3rd floor, front of room 363, 2light bulbs are out. Task Complete.
FO-282118	4/21/2014	4/22/2014		6th floor, near Conference A, 2nd light of the main corridor is out
FO-282119	4/21/2014	4/22/2014		light flickering in room 4200.
FO-282285	4/22/2014	4/23/2014		Hallway outside 212.06: burned out lightbulb, please replace.
FO-282294	4/22/2014	4/23/2014		lights in the East elevator are burned out
FO-282335	4/22/2014			Please replace bulb outside lab door. Also,
FO-282398	4/23/2014	4/28/2014		Please relamp fixtures in room 285 on the mezzanine.
FO-282420	4/23/2014	4/24/2014		4th floor, records office, lights are dim and flickering
FO-282462	4/24/2014	4/24/2014		Need lights blubs changed. 7 light blubs need to be changed. Need bright white energy efficie
FO-282463	4/24/2014	4/24/2014		Needs light blubs changed in this office. This is a GTA office. 3 lights blubs need to be chang
FO-282537	4/24/2014	4/25/2014		Hallway outside room 212.01: burned out lightbulb, please replace.
FO-282538	4/24/2014	4/25/2014		6 of the 7 lights are out in the women's restroom on the law classroom side of the building.
FO-282601	4/25/2014	4/25/2014		1 Light panel is out. Located outside of Room 3127.
FO-282602	4/25/2014	4/30/2014		One Pendant Light (over 1356) and one ceiling light bulb is out (1352.1) in the cafeteria.
FO-282630	4/28/2014	4/29/2014		Various assorted bulbs out in UGL, all floors including Collaborative Study Room. All is up to p
FO-282704	4/28/2014			3 lights out in 4632 and 1 light flickering in 2651
FO-282705	4/28/2014	4/29/2014		Lights out in men's room
FO-282794	4/29/2014	4/29/2014		Lighting Crew; Medium
FO-282795	4/29/2014	4/29/2014		Lighting Crew; Medium
FO-282810	4/29/2014	4/29/2014		Reported by Library Dean's Office that lights are out in Kitchen of Library Dean's Office Suite,
FO-282832	4/29/2014	4/29/2014		Purdy Library, 1st Floor
FO-282837	4/29/2014			Light bulbs need to be replaced.
FO-282845	4/29/2014			Replace light bulbs.
FO-282843	4/29/2014	4/30/2014		Service elevator off dock there two light out in the elevator.

WO	Recieved	Finished	Total	Request
FO-282882	4/29/2014			In the Women's lockerroom #176 there are three lights out.
C-Materials			27	
FO-280118	4/1/2014	4/2/2014		NEED LARGE MAT AT ENTRANCE DOOR TO CONTROL STATION/SERVICE CENTER AR
FO-280522	4/2/2014	4/10/2014		One floor mat needed for front building entrance.
FO-280530	4/2/2014	4/2/2014		3 Rugs to be laid at East Entrance
FO-280654	4/3/2014	4/10/2014		6 rolls of tape.
FO-280986	4/8/2014	4/10/2014		Allied Order to purchase 15 magnet Bars @ \$13.49 ea
FO-281090	4/9/2014	4/10/2014		Purchase a back brace
FO-281104	4/9/2014	4/11/2014		recycling bin pickup and drop off in room 5230
FO-281105	4/9/2014	4/10/2014		recycling bin pickup and drop off in room 3100
FO-281124	4/9/2014	4/16/2014		deliver on next tuesday, at KEIST COMMONS i.e, april 15th :
FO-281369	4/11/2014	4/11/2014		Need big trash bin to 3660 AAB
FO-281474	4/14/2014			room# 3103
FO-281477	4/14/2014	4/17/2014		room# 7233, 2 recycle bins need to be dropped off
FO-281677	4/15/2014	4/17/2014		2 recycle bins need to be picked up and 2 drop-off outside of room, 357
FO-281678	4/15/2014	4/17/2014		2 recycle bins need to be replaced in 3rd floor
FO-281852	4/17/2014			recycle bin needs to be picked up and dropped off at room 3100
FO-281898	4/17/2014			Recycle bin pickup in room 3178
FO-281900	4/17/2014			Recycle bin pickup in room 7233 and drop off new bin.
FO-281944	4/18/2014	4/22/2014		big Dumpster needed at room 3660
FO-281945	4/18/2014			big recycle bin needed at room 2155.15, 2nd floor
FO-282114	4/21/2014			Grey recycle bin needs to be picked up and dropped off in room, 7233
FO-282115	4/21/2014	4/22/2014		a large dumpster needed by room 3660
FO-282116	4/21/2014			recycle bin needs to be picked up and dropped off in room 300
FO-282117	4/21/2014	4/22/2014		room 3660, empty and bring back dumpster
FO-282309	4/22/2014			RECYCLE BIN PICKED UP AND DROPPED OFF IN ROOM , 2155
FO-282504	4/24/2014			need big black recycle bin emptied and returned at 3178 FAB
FO-282505	4/24/2014			Gondola to be picked up and returned 1900 AAB
FO-282534	4/24/2014			recycle bin pick up and replacement
C-Projects			1	
FO-281361	4/11/2014	4/17/2014		We would like the 3rd floor cleaned and wax by April 22, 2014. We are having a tour on April 2
C-Repair			13	
FO-280150	4/1/2014			UGL 3rd floor mens room 3438/tissue dispenser key broke off in the dispenser
FO-280152	4/1/2014			2 tissue dispensers broke(tape holding them close)1st floor suite 1600 ladies room SASS Dep
FO-280187	4/2/2014			Walk behind burnisher:Nobles Model(612966)Serial(612966-10153712). Has broken drive pad
FO-280524	4/2/2014			Please replace the c-fold paper towel dispenser with a regular roll dispenser. The dispenser is
FO-280755	4/4/2014			Soap dispenser broke/1st bathroom inside of basement ladies lockerroom
FO-280783	4/4/2014			In the 1st floor ladies room middle stall the silver wax paper bag holder has falling off the wall.
FO-281275	4/10/2014	4/22/2014		The paper towel dispenser is coming off the wall. Please resecure it to the wall.
FO-281358	4/11/2014			Install sanitary disposal container in this unisex restroom.
FO-281812	4/16/2014			Ladies room - Papertowel dispenser is broken. Please fix/replace.
FO-281917	4/18/2014			SOAP DISPENSER IS BROKEN. 3RD FLOOR WOMEN'S RESTROOM NEAR ELEVATOR.
FO-282370	4/23/2014			Men's Restroom on the 5th floor,the paper towel dispenser broken needs new one,
FO-282625	4/28/2014			We have 3 carpet juans that needs repairs you can come an check out this issue.
FO-282790	4/29/2014			1st Floor Men's restroom soap dispenser off the wall needs new 1
C-Sector 02			8	
FO-281315	4/8/2014	4/8/2014		Scub and wax room 8327 scott hall
FO-281316	4/11/2014	4/9/2014		scrub and wax labs 9224,9252 of Scott Hall

WO	Recieved	Finished	Total	Request
FO-281317	4/11/2014	4/10/2014		Scrub and wax lab 9232 of Scott Hall
FO-281383	4/11/2014	4/11/2014		Scrub an waxed lab 5321 of Scott Hall
FO-281519	4/14/2014	4/14/2014		Shampoo carpet from water leak from ceiling room 9105
FO-281710	4/15/2014	4/24/2014		Room 1213 needs carpet shampooed. There are spots in the carpet from the Board of Gover
FO-282120	4/21/2014			Rooms 4105 and 4117 (these are conncting rooms). Please strip and wax lab floors. Pleas
FO-282431	4/23/2014			Please stip and wax lab floors. Please contact Philip Alther at 577-3089 to schedule time and
C-Sector 03			5	
FO-280175	4/1/2014	4/1/2014		2 cases of dial soap
FO-280177	4/1/2014	4/1/2014		2 cases of dial soap
FO-280178	4/1/2014	4/1/2014		2 cases of dial soap
FO-280179	4/1/2014	4/1/2014		2 cases of dial soap
FO-280180	4/1/2014	4/1/2014		2 cases of dial soap
C-Sector 04			3	
FO-282539	4/11/2014	4/18/2014		Request to have University daycare center floors scrubbed and waxed.Rooms #185, #178, #1
FO-281817	4/16/2014	4/24/2014		Room 2519 is very dirty. It was reserved and is very dirty. Thank you.
FO-282355	4/22/2014			Special custodial cleaning for May 4th event
C-Sector 05			6	
FO-280504	4/2/2014	4/26/2014		carpet cleaning for the entire 1st floor and through out faculty offices, also located on the 1st fl
FO-280633	4/3/2014	4/3/2014		Rm531 Manoogian, trash has not been empty or large trash can in hallway
FO-282271	4/22/2014	4/22/2014		The following room has been shower scrub and waxed.339,357,375,379.
FO-282383	4/23/2014			and 4167 - the custodian on our floor says that
FO-282618	4/28/2014	4/28/2014		The following rooms has been shower scrub and wax,363,367,369,373.
FO-282791	4/29/2014	4/28/2014		The following room has been shower scrub and wax.The # is 359.
C-Sector 06			10	
FO-280652	4/3/2014	4/18/2014		2 cases of dial soap
FO-280653	4/3/2014	4/18/2014		2 cases of dial soap
FO-280655	4/3/2014	4/18/2014		2 cases of dial soap
FO-280661	4/3/2014	4/18/2014		2 cases of dial soap
FO-280665	4/3/2014	4/18/2014		2 cases of dial soap
FO-280666	4/3/2014	4/18/2014		2 cases of gojo
FO-280667	4/3/2014	4/18/2014		1 case of gojo
FO-280894	4/7/2014	4/10/2014		The department of Sociology is having a Student Award ceremony on Thur. April 10, 2104, 4:0
FO-281150	4/9/2014			Requesting that the Carpet be cleaned in Dr. K. Brown's Office (suite 2245 Sociology Departm
FO-281469	4/14/2014			Clean and wax floors in Art Collection Offices, 0014 Old Main - sub-basement. Alarmed area.
C-Sector 07			7	
FO-280071	4/1/2014	4/2/2014		Purdy Library, 1st Floor, Rooms 132 & 133
FO-280885	4/7/2014	4/10/2014		Purdy Library, 1st Floor Staff Women's and Handicap restrooms.
FO-281121	4/9/2014			Hallway needs to be waxed - @ 2 years since last done
FO-281122	4/9/2014			Hallway needs to be waxed - @ 2 years since last done
FO-281389	4/11/2014			Carpet in front of Office #230, 2nd floor has a large brown looking stain on the carpet directly i
FO-282013	4/21/2014	4/21/2014		Purdy 4th Floor - Room 428, 438, 450
FO-282405	4/23/2014	4/25/2014		Clean both levels of the Elaine L. Jacob Gallery with mop machine and windows (including sta
C-Sector 08			4	
FO-280740	4/4/2014	4/12/2014		Clean the carpet in the halls and offices on the 1st floor.
FO-280843	4/7/2014			Sub Basement-Basement, Ground, 1st and Second Floor, scrub and wax floors, includes ven
FO-281099	4/9/2014	4/28/2014		6 cases of dial Soap and 6 cases of Gojo Soap . I never did get the soap order. I did put in a r
FO-282372	4/23/2014	4/27/2014		Can we have the weekend crew shower
C-Sector 09			14	

WO	Recieved	Finished	Total	Request
FO-280786	4/5/2014	4/5/2014		Vacuum, scrub & extract the carpet in 5th floor rooms 5364 & 5370.
FO-281180	4/9/2014	4/9/2014		3 cases of dial soap
FO-281181	4/9/2014	4/9/2014		3 cases of dial soap
FO-281182	4/9/2014	4/9/2014		1 case of dial soap
FO-281183	4/9/2014	4/9/2014		1 case of dial soap
FO-281184	4/9/2014	4/9/2014		1 case of dial soap
FO-281185	4/9/2014	4/9/2014		1 case of dial soap
FO-281186	4/9/2014	4/9/2014		2 cases of dial soap
FO-281187	4/9/2014	4/9/2014		2 cases of dial soap
FO-281188	4/9/2014	4/9/2014		2 cases of dial soap
FO-281189	4/9/2014	4/9/2014		2 cases of dial soap
FO-281404	4/11/2014			Please strip and wax hallway floors. Please contact Krista Mitchell at 7-9028 to schedule date
FO-281727	4/15/2014	4/16/2014		10 Soak socks
FO-282878	4/29/2014			Standing water on the floor just outside of the
Routine			2	
C-Director			2	
FO-281691	4/15/2014			Fo for All American Window Cleaners, Presidents Inauguration (Mcgregor, walkway@ McGreg
FO-281693	4/15/2014			Fo for All American Window Cleaners, spring cleanup(state hall entrance, wlcome center low
Engineering			702	
Emergency			32	
E - Auxiliary			2	
H-44858	4/1/2014	4/2/2014	4/15/2014	Outlets and lights in bedroom and bathroom are not working.
H-44914	4/4/2014	4/7/2014	4/23/2014	P trap under the kitchen sink is completely broken.
E - Command Center			2	
FO-280794	4/7/2014	4/7/2014		EMERGENCY/CONTROLS
FO-280802	4/7/2014	4/7/2014		REFR CREW: BOILER #1 WILL NOT START BOILER #2 TRIPS OFF ON NO WATER.
E - MedPharm			4	
FO-280800	4/7/2014	4/7/2014		ADDING: EMERGENCY/PLUM
FO-281349	4/11/2014	4/14/2014		EMERGENCY/PIPE
FO-281378	4/11/2014	4/14/2014		EMERGENCY/PIPE
FO-281674	4/15/2014	4/16/2014		EMERGENCY ELEC
E - North			2	
FO-281703	4/15/2014	4/16/2014		EMERGENCY
FO-282087	4/21/2014	4/21/2014		WATER COMING FROM UNDERNEATH MECHANICAL ROOM DOOR. 3RD FLOOR ROOM
E - Preventative Maintenance			5	
FO-281557	4/14/2014	4/15/2014		RM 8/MECH RM WATER IS RUNNING OUT FROM UNDERNEATH DOOR
FO-282362	4/22/2014	4/23/2014		CONTRACTOR: RAYNOR OVERHEAD DOOR CO
FO-282525	4/24/2014	4/25/2014		CALLED SCHINDLER ELEV FOR #1 ELEV ENTRAPMENT DON'T KNOW WHAT FLR
FO-282606	4/25/2014	4/26/2014		(AFTERNOON SHIFT PLS CK & PUT CAUTION TAPE/SIGNAGE OUT FOR THE FOLLOW
FO-282881	4/29/2014	4/30/2014		RM 114 UNABLE TO SECURE DOOR, SECURITY ISSUE.
E - South			14	
FO-281238	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281241	4/10/2014	4/10/2014		ADDING:
FO-281242	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281244	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281245	4/10/2014	4/11/2014		POWER BUMP APPRR 11:40AM
FO-281246	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM

WO	Recieved	Finished	Total	Request
FO-281248	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281249	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281250	4/10/2014	4/11/2014		POWER BUMP APPRR 11:40AM
FO-281252	4/10/2014	4/11/2014		POWER BUMP APPRR 11:40AM
FO-281253	4/10/2014	4/11/2014		POWER BUMP APPRR 11:40AM
FO-281879	4/17/2014	4/17/2014		RM 420/LAB INVESTIGATE FLOODING COMING FROMN THE CLNG
FO-282276	4/22/2014	4/22/2014		EMERGENCY/CARP
FO-282576	4/25/2014	4/30/2014		OUTSIDE SOUTH SIDE OF BLDG CEMENT AROUND THE SEWER HEAD HAS COLLAPSE
E - Southeast			1	
FO-282628	4/28/2014	4/28/2014		RM 1319/CLASS RM UNABLE TO UNLOCK DOOR
E - West			2	
FO-281247	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
FO-281251	4/10/2014	4/10/2014		POWER BUMP APPRR 11:40AM
High			173	
E - Auxiliary			22	
H-44878	4/2/2014	4/9/2014	4/9/2014	EMERGENCY REQUEST. Both the refrigerator (and microwave) have lost power. Suspect it i
H-44877	4/3/2014	4/4/2014		The water leaks from the toilet every time it is flushed.
FO-280722	4/4/2014	4/4/2014		FIRE TROUBLE ALARM
H-44915	4/4/2014	4/7/2014	4/15/2014	Water coming from around the bottom of the toilet.
H-44959	4/7/2014	4/6/2014	4/15/2014	Toilet Refilling ver slowly and will not flush using handle.
H-45022	4/11/2014	4/13/2014	4/15/2014	The bathroom sink drain is leaking. Please look into it as soon as possible.
FO-281374	4/11/2014	4/11/2014		FAP FIRE TROUBLE ALARM ACTIVE
H-45051	4/13/2014			I think there is a rag stuck in my garbage disposal. Garbage disposal is not working.
H-45085	4/15/2014	4/15/2014	4/17/2014	The toilet will not flush.
H-45086	4/15/2014	4/15/2014	4/17/2014	The tiolet will not flush and needs fixing ASAP.
H-45088	4/15/2014	4/15/2014	4/17/2014	Kitchen sink has a leak
H-45114	4/18/2014	4/18/2014	4/22/2014	The garbage disposal is broken, causing the sink to be flooded. Needs to be fixed.
FO-282024	4/21/2014	4/21/2014		ACTIVE FIRE ALARM 9TH FL
H-45148	4/21/2014		4/22/2014	The kitchen's sink is leaking and needs fixing ASAP.
H-45154	4/21/2014		4/22/2014	Stove is sparking
H-45185	4/23/2014		4/25/2014	There is a leak behind the sink in the bathroom
FO-282546	4/25/2014	4/25/2014		WATER PIPE ON WEST SIDE OF BLDG BUST WATER SHOOTING OUT FROM PIPE
FO-282685	4/27/2014	4/28/2014		ENGINEER TO VERIFY EXACT DOOR #S' CARPENTERS: Please adjust door closer nad str
H-45247	4/28/2014			Please check out the leak in the lobby. It is coming from the loose panel above the caution si
H-45256	4/28/2014			Kitchen sink right hand dramage pipe is leakingauthenticated user: Daniel Krupp - fn5223re
H-45270	4/29/2014			The flusher in the rest room is not working from yesterday.Water is not coming to flush. So ca
H-45271	4/29/2014			Toilet is continuously running.
E - Command Center			16	
FO-280792	4/7/2014	4/8/2014		Trade: Controls
FO-280803	4/7/2014	4/7/2014		REFR CREW: BOILER #4 WILL NOT START
FO-280889	4/7/2014	4/10/2014		Control Engineer; High
FO-281200	4/10/2014	4/10/2014		#3 BOILER GOING OUT ON FLAME FAILURE. (MECHANICAL ROOM) TOP LEVEL BOILE
FO-281219	4/10/2014			Trae: Controls Priority: High
FO-281256	4/10/2014			Ac Controls High Priority
FO-281418	4/12/2014			COMMAND CENTER: Please check the operation of the #1 chiller oil pump and oil pump sole
FO-281508	4/14/2014	4/24/2014		A/C LEAKING. ROOM 146.
FO-281744	4/16/2014			DOORS BLOWING OPEN CHECK AIR PRESSURE THROUGHOUT LAW COMPLEX.
FO-281769	4/16/2014			Boilers & controls-Boiler #1 has not been in operation since 4-14-14 on afternoon's.Engineer o

WO	Recieved	Finished	Total	Request
FO-281793	4/16/2014			CONTROLS (HIGH)
FO-281809	4/16/2014			Trade: Controls
FO-281840	4/17/2014	4/17/2014		Controls: High Priority
FO-282390	4/23/2014	4/23/2014		BOILER ALARM. SEE ENGINEER
FO-282456	4/24/2014	4/25/2014		Mitsubishi split system has one bad condensate pump, other units will not run
FO-282642	4/28/2014			FURNACE KEEPS IGNITING, MAKING A LOUD EXPLODING SOUND.
E - MedPharm			68	
FO-280121	4/1/2014	4/1/2014		RM 8125 HIGH TEMP
FO-280123	4/1/2014	4/1/2014		200 STES HIGH HUMIDITY
FO-280126	4/1/2014	4/1/2014		LAB 103 TOO HOT
FO-280482	4/2/2014			Air pressure in rooms 205, 215,217,219,221,216 is positive to the hallway it needs to be negat
FO-280532	4/2/2014			ENGINEER
FO-280823	4/7/2014	4/7/2014		RM 5341/DLAR HAS LOW HUM
FO-280824	4/7/2014	4/7/2014		RM 5351/DLAR HAS LOW HUM
FO-280987	4/8/2014	4/8/2014		VACUUM IS NOT WORKING. BASEMENT ROOM 121.
FO-281113	4/9/2014	4/9/2014		EXHAUST FAN IS MAKING VERY LOUD NOISE. 3RD FLOOR MEN AND WOMEN RESTR
FO-281233	4/10/2014	4/10/2014		LAB 0413 TEMP TOO HOT, HUMIDITY VERY LOW
FO-281276	4/10/2014			Room 9332 - Exhaust vent in room is very noisy. Please correct. Please note, this room is be
FO-281326	4/11/2014	4/11/2014		RM 121/DLAR OXYGEN VACUUM SYS ISN'T WORKING
FO-281330	4/11/2014	4/11/2014		CAFETERIA 1350 TOO HOT, EVENT TAKING PLACE PLEASE COME ASAP
FO-281334	4/11/2014	4/11/2014		RM 200.08 LOW TEMP
FO-281339	4/11/2014			AUTOCCLAVE IS MALFUNCTIONING. ROOM 2314.
FO-281340	4/11/2014	4/11/2014		INSIDE RM 1102, SHERYL,KRISTEN,AND BOB'S OFFICE TOO HOT
FO-281355	4/11/2014			8125 HIGH TEMP
FO-281363	4/11/2014	4/11/2014		HIGH TEMP. ROOMS AF12, AF14, AF18, AF20, AF22, AF24, AF26 & AF28.
FO-281420	4/14/2014	4/14/2014		HIGH TEMP. ALARM. ROOM 413.
FO-281435	4/14/2014	4/14/2014		High temp
FO-281423	4/14/2014	4/14/2014		HIGH TEMP. ROOM AF24.
FO-281436	4/14/2014	4/14/2014		High temp
FO-281437	4/14/2014	4/14/2014		high temp
FO-281438	4/14/2014	4/14/2014		high temp
FO-281462	4/14/2014			TOO HOT. ROOM 8128.
FO-281487	4/14/2014	4/14/2014		FRONT ENTRANCE DOORS #01S AND 02S ARE NOT CLOSING. PLEASE VERIFY.
FO-281492	4/14/2014	4/14/2014		TOO HOT. ANIMAL ROOMS 5455, 5449, 5445, 5453, 5451, 5450.02, 5520 AND 5530.
FO-281493	4/14/2014	4/14/2014		BSMT ENTIRE DLAR FACILITIES HAS HI HUMIDITY
FO-281504	4/14/2014	4/14/2014		ENTIRE BLDG IS TOO HOT
FO-281509	4/14/2014	4/14/2014		RM 0250 IS EXTREMELY HOT AFFECTING INSTRUMENTS
FO-281510	4/14/2014	4/14/2014		DOCK AREA TRUCK IS STUCK ON THE BLACK LEVER
FO-281651	4/15/2014			BLUE LECT HALL IS EXTREMELY COLD/FREEZING
FO-281657	4/15/2014			RM 200.07/DLAR LOW TEMP
FO-281660	4/15/2014	4/15/2014		RM 200.08/DLAR LOW TEMP
FO-281668	4/15/2014	4/15/2014		TOO COLD. BASEMENT ANIMAL QUARTERS.
FO-281696	4/15/2014	4/15/2014		RM AF-24 HAS HI TEMP
FO-281698	4/15/2014	4/16/2014		R/R RM 9105 REPAIR ROOF APPEARS TO BE COMING FROM ROOF DRAIN IN UPPER
FO-281700	4/15/2014			RM 1331/SERVER RM SUPPLIMENTAL HVAC LOCATED IN CLNG FAILED 3xs' (once 4/14/
FO-281915	4/18/2014			There is a gritty white powder comming from the fan and blowing around inside the cold room.
FO-281951	4/18/2014	4/29/2014		ICE ON WALK IN COOLER. ROOM 5441.02.

WO	Recieved	Finished	Total	Request
FO-282010	4/21/2014			LAB 7259 TOO HOT
FO-282019	4/21/2014			HIGH TEMPS. ROOMS 200.06, 200.10, 200.03, 200.09 & 8125.
FO-282046	4/21/2014			AHU#3 DISCHARGE HIGH TEMP
FO-282082	4/21/2014	4/21/2014		TOO HOT. ANIMAL ROOM 5449.
FO-282086	4/21/2014	4/21/2014		HIGH TEMP. ROOM 5455.
FO-282288	4/22/2014	4/22/2014		HIGH HUMIDITY. ROOM 5449.
FO-282289	4/22/2014			8th & 9th FL NO IONIZED WATER
FO-282315	4/22/2014			NO DISTILLED WATER ON THE 7TH FLOOR.
FO-282328	4/22/2014			AHU #3 HAS HI TEMP ALARM ACTIVE
FO-282384	4/23/2014			LOW TEMPS. ROOMS 200.07, 200.08, 200.03 & 416.
FO-282385	4/23/2014			LOW HUMIDITY IN ROOMS 200.09, 200.06, 200.01 & 200.04
FO-282408	4/23/2014	4/23/2014		HIGH TEMP. ROOM 5665.
FO-282460	4/24/2014	4/24/2014		LOW HUMIDITY IN ROOMS AF12, AF18, AF22, AF24, AF26 & AF28.
FO-282554	4/25/2014			RM 3250 COLD RM TOO HOT
FO-282555	4/25/2014			BSMT SMALL ANIMAL QUAARTERS HAS HUMIDITY
FO-282563	4/25/2014			GENERATOR FUEL IS LOW ALARM (RECORDING)
FO-282566	4/25/2014			GENERATOR RUNNING ALARM
FO-282567	4/25/2014			GENERATOR TROUBLE ALARM
FO-282569	4/25/2014			AHU #3 IS IN ALARM
FO-282573	4/25/2014			POWER FAIL ALARM
FO-282597	4/25/2014	4/25/2014		4th fl/9TH FL FOUL SMELL COMING FROM VENTS
FO-282632	4/28/2014	4/29/2014		RM 200.01/DLAR HAS HI TEMP
FO-282633	4/28/2014	4/29/2014		RM 200.01/DLAR HAS LOW HUMIDITY
FO-282637	4/28/2014	4/29/2014		RM 200.06/DLAR HAS HI TEMP
FO-282638	4/28/2014	4/29/2014		RM 200.06/DLAR HAS LOW HUM
FO-282646	4/28/2014	4/28/2014		5465 TOO HOT. PLEASE UPDATE DAISY
FO-282654	4/28/2014	4/29/2014		COLD RM NOT WORKING
FO-282846	4/29/2014			AHU #3 HAS HI TEMP ALARM
E - North			8	
FO-280978	4/8/2014	4/8/2014		PLEASE CHECK TO SEE IF THIS IS A REIMBURSABLE ISSUE 3RD FL ACROSS FROM 32
FO-281136	4/9/2014	4/11/2014		need 4 B-97 belts, fan off line
FO-281207	4/10/2014	4/10/2014		RM 4145 BLOWER STILL BLOWING
FO-281237	4/10/2014			ADDING
FO-281464	4/14/2014	4/14/2014		ENTIRE 4TH FLR AIR VENTILATION IS BLOWING VERY LOUD
FO-281643	4/15/2014	4/17/2014		PRESIDENT'S APT
FO-281842	4/17/2014			CONTRACTOR/RAYNOR OVERHEAD DOOR:
FO-282840	4/29/2014	4/29/2014		BLDG NO WATER
E - Northeast			2	
FO-280068	4/1/2014	4/1/2014		POSSIBLE LEAK (CARPET IS WET). HALLWAY OUTSIDE OF ROOM
FO-280495	4/2/2014	4/2/2014		RM 222 & 249 TOO COLD
E - Preventative Maintenance			32	
FO-280168	4/1/2014	4/2/2014		AICG RM 1212 LOSS POWER
FO-280172	4/1/2014	4/2/2014		3RD FL DOOR ALARM SOUNDING
FO-280181	4/1/2014	4/2/2014		LAB 3330 TOO COLD
FO-280571	4/2/2014	4/3/2014		CEILING LEAK. ROOM 595.
FO-280572	4/2/2014	4/3/2014		LAB 480 TOO HOT
FO-280580	4/2/2014	4/3/2014		FIRE ALARM SOUNDING
FO-280582	4/2/2014	4/3/2014		LAB 380 TOO HOT

WO	Recieved	Finished	Total	Request
FO-280672	4/3/2014	4/4/2014		CEILING LEAK. ROOM 359.
FO-280680	4/3/2014	4/4/2014		SHIFFMAN LIBRARY NEAR RM 120/121 LOUD BANGING NOISE FROM PIPE IN CEILING.
FO-280688	4/3/2014	4/4/2014		RM 308,328,358,368 TOO HOT
FO-280767	4/4/2014	4/5/2014		RM 320 ALL FUMEHOODS ARE IN ALARM
FO-280772	4/4/2014	4/4/2014		BLDG TOO HOT, INAGURATION GOING ON PLEASE COME ASAP
FO-280892	4/7/2014	4/9/2014		SHIFFMAN LIBRARY LOUD BANGING NOISE NEAR RM 122. PLEASE COME ASAP NOIS
FO-280895	4/7/2014	4/7/2014		RM 289 OVERHEAD LIGHTS NOT WORKING
FO-281177	4/9/2014	4/10/2014		LAB 2177 TOO HOT TO PERFORM EXPERIMENTS
FO-281281	4/10/2014	4/10/2014		AHU-3 DISCHARGE HIGH TEMP
FO-281296	4/10/2014	4/10/2014		RM 1328 TOO HOT, PLEASE COME ASAP
FO-281300	4/10/2014	4/10/2014		ANIMAL QUARTERS TOO HOT 80 DEGREES
FO-281561	4/14/2014	4/15/2014		R/R ENTRANCE DOOR #080-13N PANIC BAR IS BROKEN
FO-281565	4/14/2014	4/15/2014		RM 318 CLNG ACU IS DRIPPING WATER & CHUNKS OF ICE IS FALLING OUT THIS IS NE
FO-281816	4/16/2014	4/17/2014		Room 2621 has a ceiling leak.
FO-281897	4/17/2014	4/18/2014		CEILING LEAK. 4TH FLOOR SOUTH HALLWAY. NEAR RED ELEVATORS.
FO-281899	4/17/2014	4/17/2014		BLOWN CIRCUIT. WALL OUTLETS ARE NOT WORKING. ROOM 126.
FO-281963	4/18/2014	4/18/2014		BLDG FAP FIRE TROUBLE ALARM ACTIVE
FO-282126	4/21/2014	4/22/2014		BLDG TOO HOT, EVENT AT 5:30 BOARD OF GOVERNORS
FO-282128	4/21/2014	4/22/2014		9TH FL LAB NO WATER
FO-282446	4/23/2014	4/24/2014		RM 2126.4 CEILING LEAKING SENT TO PLUMBER ON PREV WO, WATER IS SITTING IN
FO-282610	4/25/2014	4/30/2014		FIRE ALARM
FO-282697	4/28/2014			STEAM LEAK NEAR BAY DOOR/ROCKS
FO-282876	4/29/2014			Exhaust fans and/or air handling unit is not working properly.
FO-282869	4/29/2014			THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED
FO-282880	4/29/2014	4/30/2014		RM 243 FUME HOOD KEEPS ALARMING
E - South			16	
FO-280565	4/2/2014	4/3/2014		LAB 380 TOO HOT
FO-280997	4/8/2014	4/8/2014		NW CORNER OF BLDG SMELLS LIKE GAS
FO-281019	4/8/2014	4/8/2014		ALL FUME HOODS ALARMS SOUNDING. ROOM 320.
FO-281022	4/8/2014	4/8/2014		LAB 180 ALL FUME HOODS ALARMING
FO-281360	4/11/2014	4/11/2014		VENT IS MAKING NOISE. ROOM 2025
FO-281527	4/14/2014	4/17/2014		TOO HOT. ROOM 1600. (2ND REQUEST)
FO-281645	4/15/2014	4/15/2014		RM 26.1/DLAR HAS HI TEMP ALARM
FO-281646	4/15/2014	4/15/2014		RM 26.21/DLAR HAS HI TEMP ALARM
FO-281647	4/15/2014	4/15/2014		RM 26.22/DLAR HAS HI TEMP ALARM
FO-281648	4/15/2014	4/15/2014		RM 26.27/DLAR HAS HI TEMP ALARM
FO-281739	4/15/2014			RM 318 CLNG ACU IS DRIPPING WATER & CHUNKS OF ICE IS FALLING OUT THIS IS NE
FO-282018	4/21/2014	4/21/2014		FUME HOOD #2 GOING OFF HIGH FLOW ERROR
FO-282290	4/22/2014	4/22/2014		HIGH TEMP. ROOM 430.
FO-282306	4/22/2014	4/22/2014		27.4 LOW TEMP ALARM
FO-282331	4/22/2014	4/22/2014		27.3 LOW TEMP ALARM
FO-282488	4/24/2014			LAB 40 TOO HOT
E - Southeast			5	
FO-280599	4/3/2014	4/3/2014		CHEMICAL SMELL COMING FROM VENTS - 2ND FLOOR TEXT BOOK AREA.
FO-282006	4/21/2014			ANIMAL RM's ARE POSITIVE SHOULD BE NEGATIVE. AF14,AF18,AF22,AF24,AF23,AF29
FO-282007	4/21/2014	4/21/2014		HIGH TEMPS LOW HUMIDITY; AF12,AF28,AF26,AF24,AF22
FO-282278	4/22/2014	4/22/2014		HIGH TEMP. ON COOLER.
FO-282406	4/23/2014	4/23/2014		BOX OFFICE HAS A BAD SMELL COULD BE DEAD ANIMAL OR SEWER PLEASE CHECK

WO	Recieved	Finished	Total	Request
E - West			4	
FO-281794	4/16/2014	4/17/2014		Chemical fume hood in room 240 is running at 45 feet per minute, it needs to be adjusted to 8
FO-282429	4/23/2014			ADDING PLUM
FO-282508	4/24/2014	4/25/2014		LAB 290 TOO HOT
FO-282876	4/29/2014			Exhaust fans and/or air handling unit is not working properly.
Medium			308	
E - Auxiliary			55	
H-44869	4/1/2014	4/4/2014		The disposal in the sink does not work. The sink also has trouble draining large amounts of w
H-44857	4/1/2014	4/2/2014	4/15/2014	The kitchen disposer is not working.
H-44873	4/2/2014	4/4/2014	4/15/2014	Bathroom sink is leaking heavily
H-44884	4/2/2014	4/3/2014	4/4/2014	Our thermostat is broken.
H-44900	4/3/2014	4/4/2014	4/4/2014	Heat is not working, red light is on also.
H-44912	4/4/2014			3 canisters are broken and the 2 in the ceiling have bad ballasts.
H-44918	4/4/2014			Pipes in shower rattle real loud whenever water is in use. The problem had been reported onc
H-44919	4/5/2014	4/7/2014		Toilet not flushing. Sometimes barely builds up enough pressure to flush and sometimes not a
H-44928	4/5/2014	4/7/2014	4/15/2014	The kitchen sink is leaking in the garbage disposal area.
H-44920	4/6/2014	4/7/2014		Shower head is leaking excessively even when turned off.
H-44931	4/6/2014	4/8/2014	4/15/2014	Toilet leaks out the bottom and leaves a huge puddle. Bathroom faucet drips.
H-44923	4/6/2014			One of the metal pieces in the vent is broken.
H-44948	4/6/2014	4/7/2014	4/7/2014	Need air filters replaced.
H-44957	4/7/2014			Engineer says the combustion fan on BSG-001 is broken. Please order replacement
H-44960	4/7/2014	4/9/2014	4/15/2014	Bathroom sink is dripping.
H-44995	4/9/2014	4/10/2014		Heat is broken again - thermostat all the way up, only cold air coming out
H-45017	4/10/2014	4/11/2014	4/15/2014	Leaked from shut off valve on the toilet
H-45025	4/11/2014		4/14/2014	Living Room light is burnt out and the air conditioning is not working.
H-45030	4/11/2014	4/17/2014	4/21/2014	My AC in my room stopped working. no mater what setting I put the thermostat to it wont cool
H-45032	4/11/2014	4/18/2014	4/21/2014	Air conditioner will not work.
H-45049	4/13/2014	4/13/2014	4/17/2014	Toilet has no water and noises from the toilet.
H-45041	4/13/2014	4/17/2014	4/21/2014	Our AC isn't working. We've had it on for the past week but the room hasn't dropped from 77 d
H-45043	4/14/2014	4/17/2014	4/21/2014	A/C isn't working- staying at 78 degrees
H-45044	4/14/2014	4/17/2014	4/21/2014	The air conditioning does not work in our room. It is really hot in our room.
H-45045	4/14/2014	4/18/2014	4/21/2014	A/C not working properly
FO-281431	4/14/2014	4/14/2014		TOO HOT. ROOM 135.
H-45053	4/14/2014	4/14/2014	4/17/2014	The toilet does not flash properly. Thank you.
H-45078	4/14/2014	4/17/2014	4/21/2014	AC is not working. Blows out warm air.
H-45081	4/15/2014	4/17/2014	4/21/2014	Thermostat doesn't seem to be working. Only Fan is working but not Thermostat
H-45082	4/15/2014	4/17/2014	4/21/2014	The air conditioning is broken. The room is not cooling like the thermostat says it should.
H-45093	4/16/2014	4/23/2014	4/23/2014	Our air conditioning is broken. The transparent tab below the thermostat is highlighted in red.
H-45109	4/17/2014			There is a water leak in the bathroom sink. Please look into it ASAP.authenticated user: Sun
H-45129	4/18/2014	4/23/2014	4/23/2014	Our thermostat has stopped working.
H-45126	4/21/2014		4/21/2014	Electricity Outage - Outlet in bedroom on East wall continuously trips circuit. Outlet sparked o
FO-282084	4/21/2014	4/21/2014		A/C NOT WORKING. WDET TRANSMITTER BLDG.
H-45179	4/21/2014	4/24/2014	4/25/2014	Air conditioning isn't working. The red light is on at the bottom of the box
H-45178	4/21/2014			My air conditioner is not working. The red light below the thermostat is on and remains on eve
H-45174	4/22/2014			Air is not working red light on thermostat keeps coming on. Room is hotauthenticated user: J
H-45162	4/22/2014			Water is running in bathroom sink and Tub authenticated user: Tamika Davis - eq2532requ
H-45186	4/23/2014		4/13/2014	Toilet handle is not flushing correctly.
H-45187	4/23/2014		4/25/2014	Light bulbs in kitchen, living room, and bathroom do regularly work after replacing them. There

WO	Recieved	Finished	Total	Request
H-45194	4/23/2014			#1 Bathroom sink has leaked for a long time, had not been fixed with first work order. Also is
H-45282	4/29/2014			Please perform a engineering check on this room.
H-45283	4/29/2014			Please perform a engineering check on this room.
H-45284	4/29/2014			Please perform a engineering check on this room.
H-45285	4/29/2014			Please perform a engineering check on this room.
H-45286	4/29/2014			Please perform a engineering check on this room.
H-45287	4/29/2014			Please perform a engineering check on this room.
H-45288	4/29/2014			Please perform a engineering check on this room.
H-45289	4/29/2014			Please perform a engineering check on this room.
H-45290	4/29/2014			Please perform a engineering check on this room.
H-45291	4/29/2014			Please perform a engineering check on this room.
H-45292	4/29/2014			Please perform a engineering check on this room.
H-45293	4/29/2014			Please perform a engineering check on this room.
H-45294	4/29/2014			Please perform a engineering check on this room.
E - Command Center			41	
FO-280185	4/2/2014	4/16/2014		Please check operation of preheat coil heating valve. (Located in Mech Rm 1500) Does not a
FO-280481	4/2/2014			Trade: BAS Engineer
FO-280595	4/3/2014			Trade: Controls Priority: Medium
FO-280669	4/3/2014			Investigate and correct cause of faulty temperature control on #3 dom water heater.
FO-280724	4/4/2014			Found on CSD-1
FO-280725	4/4/2014			Found on CSD-1
FO-280726	4/4/2014			Found on CSD-1
FO-280727	4/4/2014			Found on CSD-1
FO-280759	4/4/2014			controls- an on going problem with the room 117 unit has not been corrected.the fan is not wo
FO-280762	4/4/2014			Please repair ACU 2 condenser fan and controls. Fan is cycling on and off every10 seconds.
FO-280790	4/6/2014	4/7/2014		Repair boiler #2 control circuit. Blown control fuses.
FO-280840	4/7/2014	4/7/2014		Switch lead pump between pump 20 and pump 21.See Charles Redmond.
FO-280848	4/7/2014	4/10/2014		CONTROLS please r/r #1 boiler at 5425 Woodward. Boiler is currently OOS due to numerous
FO-280988	4/8/2014	4/16/2014		Controls Medium Priority
FO-281166	4/9/2014	4/16/2014		Parts required:
FO-281274	4/10/2014	4/22/2014		Inspect roof top colling unit. Possible blown charge. See jonathan Williams for details pager
FO-281444	4/14/2014	4/16/2014		AC-Shop: Please repair or replace Boiler #1 feed water modulating level control. it sometimes
FO-281688	4/15/2014	4/18/2014		Troubleshoot operation of Spence valve.
FO-281825	4/17/2014			Trade: Controls Priority: High
FO-281855	4/17/2014			Trade: Controls
FO-281859	4/17/2014	4/18/2014		pls check repair replace tstat on
FO-281895	4/17/2014			RMS 1107.4 & 1107.5 CLNG VENT IS MAKING A LOUD NOISE.
FO-281985	4/20/2014			Repair AHU-1 return air fan speed control. The RAF constantly stays at 15 hz, and the buildin
FO-281995	4/21/2014	4/29/2014		A/C Controls, Please put AHU-3 on an ouside air temperature reset schedule. It currently has
FO-281996	4/21/2014	4/29/2014		A/C Controls, Please put AHU-4 on an ouside air temperature reset schedule. It currently has
FO-281997	4/21/2014	4/29/2014		A/C Controls, Please put AHU-5 on an ouside air temperature reset schedule. It currently has
FO-281998	4/21/2014	4/29/2014		A/C Controls, Please put AHU-6 on an ouside air temperature reset schedule. It currently has
FO-282026	4/21/2014	4/29/2014		Controls group, replace air motor for this room,. Air mortor located on AHU #2 penthouse. pre
FO-282055	4/21/2014			AC shop. Please replace heat pump for room 410.
FO-282056	4/21/2014			AC shop. Please replace heat pump for room 409.
FO-282057	4/21/2014			AC shop. Please replace heat pump for room 409.
FO-282058	4/21/2014			AC shop. Please replace heat pump for room 427.

WO	Recieved	Finished	Total	Request
FO-282102	4/21/2014			Controls: MED Priority,
FO-282404	4/23/2014			Inspect controls to roof top unit that serves AD office. Verify thermostat operation and continu
FO-282424	4/23/2014			Repair control serving reheat heat exchanger. Loop is overheating.
FO-282536	4/24/2014	4/28/2014		Refridgeration crew: Replace missing spring on cam for gas valve actuator on #1 boiler. Priorit
FO-279456	4/29/2014			Trade: Controls Priority: Medium
FO-278769	4/29/2014			Control Engineer; Medium
FO-278772	4/29/2014			Control Engineer; Medium
FO-282805	4/29/2014	4/29/2014		CONTROLS/BAS (HIGH)
FO-282334	4/29/2014			Controls (High Priority)
E - MedPharm			53	
FO-280119	4/1/2014	4/1/2014		TOO HOT. ROOM 313.
FO-280629	4/3/2014	4/3/2014		RM 2125 IS TOO HOT
FO-280631	4/3/2014	4/3/2014		RM 2135 IS TOO HOT
FO-280650	4/3/2014			RM 3343.1 IS TOO COLD
FO-280729	4/4/2014	4/4/2014		ENTIRE BLDG IS GETTING HOT CANNOT HERE FANS RUNNING EITHER
FO-280825	4/7/2014	4/7/2014		RM 8219 ACU IS STILL TOO LOUD
FO-280846	4/7/2014	4/7/2014		1102.3 TOO HOT, EXCESSIVE HOT AIR BLOWING
FO-280856	4/7/2014	4/7/2014		RM 5150 IS TOO COLD
FO-281021	4/8/2014	4/8/2014		TOO HOT. AUDITORIUM.
FO-281159	4/9/2014	4/9/2014		TOO COLD. ROOM 5150.
FO-281236	4/10/2014	4/10/2014		Ladies Restroom - No Hot Water
FO-281259	4/10/2014	4/10/2014		RM 1301 LOW WTR PRESSURE FOR TANK
FO-281351	4/11/2014	4/11/2014		RM 202 TOO HOT
FO-281366	4/11/2014	4/11/2014		RM 5150 TOO COLD
FO-281445	4/14/2014	4/14/2014		It is 80 degrees and rising in 324. We are used to this toward the end of the day, but it is no w
FO-281446	4/14/2014			TOO HOT. ROOM 6263.
FO-281449	4/14/2014	4/14/2014		TOO HOT. BUILDING INCLUDING ROOM 202.
FO-281451	4/14/2014			CEILING A/C IS NOT WORKING. ROOM 1331.
FO-281453	4/14/2014			TOO HOT. ROOM 5344, 5324 AND 9245.
FO-281455	4/14/2014			TOO HOT. ROOM 3240.
FO-281471	4/14/2014			RM 6226 IS EXTREMELY TOO HOT
FO-281470	4/14/2014	4/14/2014		TOO HOT. ROOM 103.
FO-281486	4/14/2014	4/14/2014		TOO WARM. ROOMS 313 AND 312.
FO-281489	4/14/2014	4/15/2014		TOO HOT. ROOM 131.
FO-281515	4/14/2014	4/14/2014		1ST FLR RESTAURANT IS TOO HOT
FO-281663	4/15/2014	4/15/2014		RM 241/CLASS IS TOO HOT
FO-281665	4/15/2014	4/15/2014		RM 241/CLASS IS TOO HOT
FO-281666	4/15/2014	4/15/2014		RM 242/CLASS IS TOO HOT
FO-281803	4/16/2014			PARTICALS BLOWING FROM CEILING VENTS. ROOMS 1107.4 AND 1107.5.
FO-281845	4/17/2014			RM 1328 IS TOO HOT (BLOOD DRIVE)
FO-281867	4/17/2014			GREEN LECT HALL IS TOO HOT
FO-281869	4/17/2014			RM 1350/CAFETERIA IS TOO HOT
FO-281870	4/17/2014			RM 200.06 HAS HI TEMP
FO-281871	4/17/2014			RM 200.06 HAS LOW HUMIDITY
FO-281927	4/18/2014	4/23/2014		PARTICALS ARE COMING THRU CEILING VENTS. ROOM 3126.
FO-282000	4/21/2014	4/21/2014		TOO HOT. ROOM 202.
FO-282066	4/21/2014	4/21/2014		TOO HOT. ROOM 0540.

WO	Recieved	Finished	Total	Request
FO-282096	4/21/2014			Fitters please repair leaky chill water recirculating pump on AHU-6 in room 12.
FO-282320	4/22/2014	4/22/2014		TOO COLD. MAGERIO.
FO-282339	4/22/2014	4/22/2014		RM AF-24 HAS LOW HUMIDITY
FO-282346	4/22/2014			RM 3343.1 IS STILL TOO COLD
FO-282347	4/22/2014			RM 1233 IS TOO COLD
FO-282357	4/22/2014			Close chiller for the season
FO-282393	4/23/2014			TOO COLD. ROOM 5250.
FO-282430	4/23/2014			ADDING PIPE
FO-282479	4/24/2014			TOO HOT. ROOM 7259.
FO-282489	4/24/2014			TOO COLD. ROOM 3343.1
FO-282548	4/25/2014			RM 200.03/DLAR HAS LOW TEMP
FO-282558	4/25/2014	4/25/2014		RM 5250 IS TOO COLD
FO-282575	4/25/2014	4/29/2014		RM 1116 TOO COLD
FO-282653	4/28/2014	4/29/2014		Room 0410 at Scott Hall too hot. Even with the new exhaust it still reaches the 80 degree mar
FO-282819	4/29/2014	4/29/2014		Please replace the dirty air filters in the
FO-282852	4/29/2014			Room 9332 - Please correct loud vent noise. Room is used to house animals and MUST be fi
E - North			22	
FO-280103	4/1/2014	4/1/2014		BLDG TOO HOT
FO-280114	4/1/2014	4/1/2014		TOO WARM. ROOM 134.
FO-280715	4/4/2014	4/4/2014		1ST FLR KITCHEN/MENS RR/WOMENS RR HAVE NO HOT WTR
FO-281239	4/10/2014	4/10/2014		BLDG TOO COLD
FO-281347	4/11/2014	4/11/2014		BLDG TOO HOT, WOULD LIKE CHILLER TURNED ON. EVENTS TODAY THROUGH THE
FO-281417	4/14/2014	4/14/2014		TOO HOT. CONFERENCE CENTER.
FO-281458	4/14/2014	4/14/2014		A/C LEAKING. ROOM 146.
FO-281506	4/14/2014			Room 25 Large set of condensate pumps (pit) not functioning. One pump is dead and the othe
FO-281516	4/14/2014	4/30/2014		1ST FLR HALLWAY NEAR RM 134 HAS A LEAK PERIODICALLY ESPECIALLY WHEN IT R
FO-281520	4/14/2014	4/14/2014		RM 134 IS TOO HOT
FO-281556	4/14/2014	4/14/2014		RM 4283 IS TOO HOT
FO-281910	4/18/2014	4/19/2014		TOO STUFFY. 3RD FLOOR.
FO-281932	4/18/2014	4/18/2014		RM 2097 AIR FLOW IS BLOWING HI DISTURBING PAPERS FROM DESK
FO-281952	4/18/2014	4/18/2014		TOO HOT. KITCHEN.
FO-282021	4/21/2014	4/21/2014		TOO HOT. BUILDING.
FO-282041	4/21/2014	4/21/2014		Please turn off the heat. The thermostat in my
FO-282272	4/22/2014			TOO HOT. BUILDING.
FO-282279	4/22/2014	4/24/2014		Temperature needs to be adjusted. It is extremely hot in here.
FO-282585	4/25/2014	4/25/2014		The librarians in this suite are saying the temperature is getting colder. They say it's about 62
FO-282659	4/28/2014	4/28/2014		2ND FL STAIRWELL DOORS AJAR SETTING OFF DOOR ALARMS, POSITIVE AIR PRESS
FO-282850	4/29/2014	4/29/2014		RM 441 IS TOO HOT/STUFFY
FO-282856	4/29/2014			RM 206 IS TOO HOT
E - Northeast			23	
FO-280098	4/1/2014	4/1/2014		NO AIR CIRCULATING. BLDG.
FO-280636	4/3/2014	4/3/2014		Cold call. Turned up thermostat this morning (8am), still cold.
FO-280747	4/4/2014	4/4/2014		repair HVAC unit or stat that controls heating and cooling on the first floor of Freer house Roo
FO-280810	4/7/2014	4/7/2014		1ST FL TOO COLD
FO-280826	4/7/2014	4/7/2014		2ND FLR FAN UNIT ISN'T RUNNING
FO-280963	4/8/2014	4/8/2014		POD HANDLE WON'T OPEN. 1ST FLOOR LOBBY.
FO-281107	4/9/2014	4/9/2014		TOO HOT. 3RD FLOOR.
FO-281108	4/9/2014	4/9/2014		TOO COLD. ROOM 3113.

WO	Recieved	Finished	Total	Request
FO-281142	4/9/2014	4/9/2014		1ST FL RECEPTION AREA TOO HOT
FO-281262	4/10/2014	4/10/2014		TOO HOT. 3RD FLOOR.
FO-281343	4/11/2014	4/11/2014		TOO COLD. CUSTODIAL OFFICE. SEE THERESA.
FO-281345	4/11/2014	4/11/2014		TOO COLD. ROOM 120.
FO-281428	4/14/2014	4/14/2014		TOO WARM. BUILDING.
FO-281523	4/14/2014	4/14/2014		RM 1550/AUD HALL IS EXTREMELY HOT
FO-281718	4/15/2014	4/15/2014		TOO COLD. 4TH FLOOR INCLUDING ROOMS 401, 402 AND 403.
FO-281918	4/18/2014	4/18/2014		TOO COLD. ROOM 120.
FO-281999	4/21/2014	4/21/2014		TOO HOT. 2ND FLOOR. SEE SYLVIA
FO-282022	4/21/2014	4/21/2014		1ST FL TOO HOT SPECIFICALLY RM 113 SEE CAROL
FO-282034	4/21/2014	4/21/2014		Too hot in office spaces - Spring/Summer environmental modifications needed.
FO-282079	4/21/2014	4/21/2014		VERY COLD. SERVICE CENTER
FO-282378	4/23/2014			POD DOOR WILL NOT OPEN. 1ST FLOOR LOBBY.
FO-282388	4/23/2014			RM 120 IS TOO COLD
FO-282403	4/23/2014	4/23/2014		main office is to cold.
E - Preventative Maintenance			44	
FO-280170	4/1/2014	4/1/2014		STE 1200 IS TOO HOT
FO-280173	4/1/2014	4/1/2014		3RD FL CASS AVE END, LIGHTS NOT ON
FO-280578	4/2/2014	4/3/2014		RM 342 IS TOO HOT TEMPERATURE SENSITIVE EQ IS IN ALARM
FO-280581	4/2/2014	4/3/2014		ENTIRE BLDG TOO HOT
FO-280583	4/2/2014	4/3/2014		RM 321 TOO HOT
FO-280678	4/3/2014	4/4/2014		Room 3250 has a light bulb in a small biohood out . Please see Sara once you get to the lab
FO-280682	4/3/2014	4/3/2014		RM 337 CEILING LEAK
FO-280746	4/4/2014	4/10/2014		Temperature in room is still high, around 78 degrees and the humidity is still 17 percent.
FO-280765	4/4/2014	4/5/2014		INSIDE WDET IN THE BACK AREA BY THE MUSIC LIB THERE IS A CLNG LEAK (DOESN'
FO-280778	4/4/2014	4/8/2014		SHIFFMAN:LOUD BANGING NOISE AT THE BACK OF LIBRARY
FO-281054	4/8/2014	4/9/2014		4th Floor temperature is rising to an average temp of 83, please adjust.
FO-281052	4/8/2014	4/9/2014		RM 4145 VERY LOUD, BLOWER ON
FO-281172	4/9/2014	4/9/2014		RM 228/PRINT RM IS EXTREMELY HOT
FO-281173	4/9/2014	4/9/2014		RM 3315 NEED BREAKER RESET
FO-281174	4/9/2014	4/9/2014		RM 3317 NEED BREAKER RESET
FO-281282	4/10/2014	4/10/2014		ATRIUM/LOBBY AREA EVENT TODAY @3:15pm UNTIL 7-8PM WOULD LIKE HEAT TO BE
FO-281284	4/10/2014	4/11/2014		TOO HOT. ROOM 380.
FO-281297	4/10/2014	4/11/2014		CLS office suites (rooms 401-404) are extremely hot.
FO-281295	4/10/2014	4/11/2014		RM 2177 TOO HOT
FO-281298	4/10/2014	4/10/2014		1ST FL TOO HOT
FO-281398	4/11/2014	4/12/2014		TOO HOT. BUILDING INCLUDING ROOM 206.
FO-281403	4/11/2014	4/16/2014		RM 431 IS TOO HOT
FO-281406	4/11/2014	4/16/2014		RM 100 TOO HOT
FO-281407	4/11/2014	4/16/2014		BLDG TOO HOT
FO-281466	4/14/2014			R/R RM 3101 REPLACE DIAPHRAM ON TOILET CONTINOUSLY FLUSHING. ROOM 3101.
FO-281552	4/14/2014	4/15/2014		RM 3103 IS TOO HOT
FO-281567	4/14/2014	4/16/2014		Replace Belts
FO-281734	4/15/2014	4/16/2014		TOO COLD. NEED HEAT TURNED ON. BUILDING.
FO-281737	4/15/2014	4/15/2014		RM 3343.1 IS TOO COLD
FO-281895	4/17/2014			RMS 1107.4 & 1107.5 CLNG VENT IS MAKING A LOUD NOISE.
FO-281901	4/17/2014	4/18/2014		Spray booth supply air heat is too high. Please adjust to a reasonable temperature. thanks.

WO	Recieved	Finished	Total	Request
FO-281961	4/18/2014	4/19/2014		RM 6409.5 HVAC IS VERY LOUD/ALSO COLD
FO-282105	4/21/2014	4/22/2014		BLDG TOO HOT PLEASE UPDATE DEE 7-2720
FO-282107	4/21/2014	4/22/2014		TOO HOT. ROOM 4092.
FO-282108	4/21/2014	4/22/2014		BLOWER BLOWING VERY HARD. ROOM 4145.
FO-282125	4/21/2014	4/22/2014		Heaters are all on in the walkway between
FO-282127	4/21/2014	4/22/2014		RM 3125 TOO HOT
FO-282445	4/23/2014	4/24/2014		RM 3212 IS EXTREMELY HOT
FO-282605	4/25/2014	4/25/2014		RM 113/WOMENS RR TOILET CON'T RUNNING
FO-282692	4/28/2014	4/28/2014		RM 3105 TOO COLD
FO-282696	4/28/2014	4/29/2014		RM 109 WATER LEAKING FROM VENT.
FO-282864	4/29/2014	4/30/2014		HALLWAY OUTSIDE 13201.7 TOO COLD
FO-282877	4/29/2014	4/30/2014		Room 8205 (inside room 8203) No air flow coming from the vents. Please correct ASAP.
FO-282874	4/29/2014	4/30/2014		RM 105 RESET BREAKER
E - South			27	
FO-280078	4/1/2014	4/1/2014		TOO WARM. BASEMENT ROOM 50.
FO-280099	4/1/2014	4/1/2014		Heater on the first floor in stairwell A is making a loud banging noise. I had phone calls from r
FO-280130	4/1/2014	4/2/2014		Lab is very hot (over 80° F).
FO-280149	4/1/2014	4/2/2014		RM 050 IS STILL TOO HOT
FO-280640	4/3/2014	4/3/2014		LAB 40 TOO HOT
FO-281005	4/8/2014	4/8/2014		Room is very warm. Students are complaining.
FO-281218	4/10/2014	4/10/2014		Room very warm. Thermostats set at 68 temps almost 80 in room.
FO-281394	4/11/2014	4/11/2014		TOO HOT. ROOM 40.
FO-281429	4/14/2014	4/17/2014		TOO HOT. ROOMS 0242 AND 0247.
FO-281442	4/14/2014	4/14/2014		Too Hot - Offices/StoreRoom are over 80 degrees.
FO-281459	4/14/2014	4/14/2014		TOO HOT. ROOM 101 (101.1 THRU 101.6)
FO-281463	4/14/2014	4/14/2014		TOO HOT. ROOM 1600.
FO-281476	4/14/2014	4/14/2014		BSMT BOOK STORAGE IS TOO HOT FOR BOOKS
FO-281479	4/14/2014	4/14/2014		RM 2177 IS TOO HOT
FO-281783	4/16/2014	4/17/2014		NO STEAM IN AUTOCLAVE. ROOM 0250.
FO-281922	4/18/2014	4/18/2014		4TH FLR HALLWAY NEAR W. SIDE RED ELEV CLNG IS LKNG
FO-282025	4/21/2014	4/21/2014		TOO HOT. ROOM 40.
FO-282042	4/21/2014	4/21/2014		Very warm (77°F and climbing). Also, the pipes are banging.
FO-282070	4/21/2014	4/22/2014		TOO HOT. ROOM 2177.
FO-282283	4/22/2014	4/22/2014		TOO HOT. BUILDING INCLUDING ROOM 3100.
FO-282325	4/22/2014	4/22/2014		LAB 4151.1 TOO HOT
FO-282543	4/25/2014	4/25/2014		RM 431 IS TOO HOT
FO-282579	4/25/2014	4/28/2014		LAB 40 TOO HOT
FO-282648	4/28/2014	4/28/2014		RM 226 TOO COLD
FO-282667	4/28/2014	4/28/2014		BSMNT RM 25 TOO COLD
FO-282674	4/28/2014	4/28/2014		Trade: South Engineer
FO-282831	4/29/2014	4/29/2014		Trade: Engineer South
E - Southeast			22	
FO-280148	4/1/2014	4/1/2014		Staff on the 4th floor are complaining that it is a too warm on the east end of floor. Please adj
FO-280605	4/3/2014	4/3/2014		Staff on 1st floor, lobby are complaining that are cold, please adjust building temperature.
FO-280630	4/3/2014	4/3/2014		Please adjust cooling system blowers/fans. They are on way to high making it very cold on up
FO-280637	4/3/2014	4/3/2014		Entire 3rd and 4th floor staff are complaining that it is too cold in the building. Please adjust e
FO-280645	4/3/2014	4/3/2014		RM 0143 IS STILL TOO COLD, COLD AIR COMING FROM VENT AND CHECK WINDOW S
FO-280858	4/7/2014	4/7/2014		ENTIRE BLDG IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-281452	4/14/2014	4/14/2014		TOO HOT. ROOM 416.
FO-281501	4/14/2014	4/14/2014		RM 00014 HAS A CLNG LEAK
FO-281653	4/15/2014	4/15/2014		ENTIRE BLDG IS EXTREMELY COLD/FREEZING
FO-281722	4/15/2014	4/16/2014		TOO COLD. ROOM 3315.
FO-281788	4/16/2014	4/16/2014		TOO COLD. ROOMS 8307 & 8307.2.
FO-281805	4/16/2014	4/16/2014		LOUD NOISE COMING FROM VENTILATION. ROOM 14003.1
FO-281856	4/17/2014	4/17/2014		office 2155.23 (Bonita's), the vent blowing out cold air, it is too cold.
FO-281861	4/17/2014	4/17/2014		BLOWER IS VERY LOUD AND BLOWING AND IT IS VERY COLD. ROOM 6409.
FO-281883	4/17/2014	4/17/2014		3RD FLR IS TOO COLD
FO-281884	4/17/2014	4/17/2014		4TH FLR IS TOO COLD
FO-282319	4/22/2014	4/22/2014		13001.2 TOO COLD
FO-282400	4/23/2014	4/23/2014		TOO HOT. ROOM 6307.2
FO-282427	4/23/2014	4/24/2014		13th flr HALLWAY NEAR STE 13201.7 AIR IS BLOWING VERY HARD
FO-282473	4/24/2014	4/24/2014		RM 3212 VERY HOT, NOISE COMING FROM VENTS PLEASE UPDATE WITH FINDINGS.
FO-282477	4/24/2014	4/24/2014		13th flr HALLWAY NEAR STE 13201.7 AIR IS BLOWING VERY HARD
FO-282811	4/29/2014	4/29/2014		Entire building is cold, please adjust temperature.
E - West			21	
FO-280093	4/1/2014	4/1/2014		RM 308 TOO HOT, OVER 80 DEGREES
FO-280095	4/1/2014			ROOFTOP UNIT 100 NOT HEATING
FO-280129	4/1/2014	4/1/2014		Temperature registering 83 degrees - too hot
FO-280537	4/2/2014	4/2/2014		RM 308 TOO HOT, OVER 80 DEGREES
FO-281139	4/9/2014	4/9/2014		RM 308 IS EXTREMELY HOT
FO-281140	4/9/2014			RM 100/LECT HALL IS TOO HOT
FO-281203	4/10/2014	4/10/2014		TOO WARM. 1ST FLOOR.
FO-281371	4/11/2014	4/11/2014		RM 586 & 592 TOO HOT
FO-281382	4/11/2014	4/11/2014		RM 100/LECT HALL IS EXTREMELY HOT
FO-281454	4/14/2014	4/15/2014		RM 586 IS TOO HOT
FO-281456	4/14/2014	4/15/2014		RM 592 IS TOO HOT
FO-281457	4/14/2014	4/15/2014		RM 308 IS TOO HOT
FO-281460	4/14/2014	4/14/2014		RM 328 IS TOO HOT
FO-281461	4/14/2014	4/15/2014		RM 385 IS TOO HOT
FO-281490	4/14/2014	4/18/2014		TOO HOT. ROOM 100.
FO-281495	4/14/2014	4/17/2014		RM 100 IS STILL TOO HOT
FO-281670	4/15/2014	4/15/2014		TOO HOT. ROOM 2116.
FO-282004	4/21/2014	4/23/2014		TOO HOT. BUILDING.
FO-282020	4/21/2014	4/28/2014		2ND FL TOO HOT 2138-2218
FO-282387	4/23/2014	4/23/2014		1156 & 1154 TOO COLD ENTIRE 1ST FL
FO-282577	4/25/2014	4/30/2014		The radiator in office is always on blowing out hot air which makes it extremely hot. Need som
Low			189	
E - Auxiliary			60	
H-44879	4/2/2014	4/3/2014	4/9/2014	In our kitchen, grease or something has fouled the drain. It seems that crusher was also block
H-44881	4/3/2014	4/3/2014	4/9/2014	Bedroom blinds are broken. Kitchen sink is leaking under cabinet (garbage disposal?) Kitch
H-44886	4/3/2014	3/31/2014	4/9/2014	replace RAF 1 belt
H-44888	4/3/2014	4/10/2014	4/23/2014	Replace gfi in kitchen of apt. 1101
H-44891	4/3/2014	4/9/2014	4/15/2014	Mechanical check
H-44892	4/3/2014	4/4/2014	4/15/2014	Mechanical check
H-44893	4/3/2014	4/4/2014	4/15/2014	Mechanical check
H-44905	4/4/2014	4/4/2014	4/9/2014	The grinder in the kitchen is not working. Water is accumulating in the sink. One of the kitchen

WO	Recieved	Finished	Total	Request
H-44901	4/4/2014	4/9/2014	4/15/2014	The heater in my room used to give few very loud noise infrequently. But recently it gives not s
H-44910	4/4/2014	4/4/2014	4/23/2014	The shower in this apartment won't turn on.
H-44926	4/4/2014	4/7/2014	4/23/2014	Kitchen sink pipes are leaking into underneath cabinet.
H-44933	4/4/2014	4/8/2014	4/23/2014	***URGENT***
H-44934	4/5/2014	4/8/2014	4/23/2014	the food disposal is not working
H-44935	4/6/2014	4/14/2014	4/24/2014	The base of the sink handle in the kitchen starts leaking when I open the water tap.
H-44930	4/6/2014	4/8/2014	4/15/2014	The sink in the kitchen leaks water.
H-44936	4/6/2014	4/8/2014	4/23/2014	Ask for the repair of the sink garbage disposal at kitchen, which make us have no way to clea
H-44961	4/7/2014	4/8/2014	4/9/2014	The grinder is not repaired completely.The person who came for repair last week has kept a b
H-44972	4/7/2014	4/10/2014	4/8/2014	Hey, Please help fix my garbage grinder (under the kitchen sink) it won't work ..Tnx
H-44975	4/8/2014	4/10/2014	4/8/2014	Kitchen garbage disposal does not function properly. When I turn the drain on, water and smal
H-44988	4/8/2014	4/9/2014	4/23/2014	the toilet in the first bathroom on the right does not stop flushing properly, after I flush it contin
H-44994	4/8/2014	4/10/2014		My room number is 534 and I live in Ghafari hall. I dropped an earring in the sink and I need a
H-44983	4/9/2014	4/10/2014		Outlet on the wall broken and loose between rooms 327 and 329.
H-45001	4/9/2014	4/10/2014	4/23/2014	Charger plug in's are not working in the Hall and 2nd no Bedroom. It seems there may be som
H-45003	4/10/2014	4/10/2014	4/23/2014	Garbage disposal-- our garbage disposal is messed up. It has stopped up our kitchen sink, ca
H-45023	4/10/2014			loud noise coming from toilet
H-45015	4/10/2014	4/16/2014	4/28/2014	Gasket missing in garbage disposal
H-45021	4/10/2014			Please fix the shower.authenticated user: Suryakanth Krishna Sumanth Chebolu - fk3954r
H-45026	4/11/2014	4/14/2014	4/17/2014	When the kitchen sink faucet is turned on, water comes out from the side, causing a big mess
H-45031	4/11/2014	4/14/2014	4/17/2014	Our deposit system (garbage disposal?)in the kitchen sink is not working.
H-45062	4/12/2014	4/15/2014	4/28/2014	The kitchen stove exhaust is not working. On both high and low settings, it is either very slow
H-45028	4/13/2014			Dropped an earring in the sink. Needs it to be removed ASAP
H-45050	4/14/2014	4/15/2014	4/28/2014	The toilet in bathroom 2 keeps flushing, it doesn't turn off - making it unusable
H-45055	4/14/2014	4/14/2014	4/28/2014	The electrical socket in my room no longer works. I have tried the switch and plugging differe
H-45076	4/15/2014	4/15/2014	4/28/2014	Far bathroom is not working properly.
H-45090	4/15/2014			The heater in the main living room is broken. The thermostat screen is blank and appears to h
H-45103	4/16/2014			Kitchen Sink not working.Water leakageauthenticated user: Vikas Sanghavi - fl4163req
H-45105	4/16/2014			1. Closet door of 1st bedroom broken2. Exhaust fan of 2nd restroom not workingUrgent Att
H-45120	4/18/2014			Ceiling is leaking water.
H-45121	4/18/2014			Replace garbage disposal
H-45127	4/18/2014			My shower head is leaking and has been for the last few days. It's actually gotten progressivel
H-45130	4/18/2014			Erator not working.authenticated user: Sanjana Prabhakar - fd0456requester ip address: 3
H-45136	4/19/2014			Garbage disposal is not working. The sink in the first bathroom does not drain properly.auth
H-45140	4/20/2014			the kitchen sink is blocked because the rotor dosent work. olease help.authenticated user: P
H-45137	4/20/2014			In the second bathroom, the bath tub pipe is leaking . Kindly fix it.authenticated user: Harikis
H-45142	4/21/2014			request for the repair of kitchen sink garbage disposer, it's not working at all, thanks.authenti
H-45155	4/21/2014			The garbage disposal does not work. It makes a weird noise and doesn't grind anything, water
H-45152	4/22/2014		4/21/2014	kitchen light needs to be replaced
H-45196	4/23/2014			1. The right side of my mirror medicine cabinet needs to be put back on its track. 2. My toilet
H-45188	4/23/2014			Mechanical check
H-45191	4/23/2014			Mechanical check
H-45195	4/24/2014	4/24/2014		Dripping shower head
H-45216	4/24/2014			Frisbee was thrown on the roof of Gold N Greens and a ladder is needed for it to be removed.
H-45212	4/25/2014			the lights in the corridor and bathroom, the sink stirring in the kitchen, and one shower in the i
H-45215	4/25/2014			Please repair or replace the faucet in the kitchen sink.
H-45221	4/25/2014			Garbage Disposalaauthenticated user: Emily Bryce - cp8833requester ip address: 35.16.73.

WO	Recieved	Finished	Total	Request
H-45229	4/26/2014			The garbage disposal / sink in the kitchen is leaking water whenever I run water in kitchen.a
H-45225	4/26/2014		4/28/2014	The disposal in the kitchen sink is not working.
H-45266	4/29/2014			Kitchen sink disposer does not work authenticated user: Hui Guan - bb1733requester ip ad
H-45279	4/29/2014			Room heating system is not working and became very cold,difficult to stay. Please rectify imm
H-45281	4/29/2014			The hot water tap in the shower is not working.authenticated user: Ashley Fry - ej8471requ
E - Command Center			51	
FO-280082	4/1/2014	4/1/2014		R/R RM 0100/MECH RM air compressor #2 not sequencing please check air compressor. Thi
FO-280112	4/1/2014	4/11/2014		Trade: Controls
FO-280507	4/2/2014			A/C Controls, please repair/replace bad Siemens control in panel behind AHU-4 (AHU-5 zone
FO-280560	4/2/2014			Trade: ControlsPriority: MediumR/R 8TH FLR Please supply one Honeywell 8" Diaphrag
FO-280616	4/3/2014	4/4/2014		Trade: Controls
FO-280642	4/3/2014			Controls: Med High Priority.
FO-280757	4/4/2014			CSD-1 results found:
FO-280793	4/7/2014	4/16/2014		Trade: Controls
FO-280880	4/7/2014			Trade: Controls Priority: HighTag #090-COT-002R/R ROOF Pneumatic cooling tower valve
FO-280966	4/8/2014			CSD-1 results:
FO-280967	4/8/2014	4/8/2014		CSD-1 results:
FO-280968	4/8/2014			CSD-1 results:
FO-280970	4/8/2014	4/8/2014		Fuse blew on boiler 1 burner motor. Check burner motor.
FO-281017	4/8/2014			repair HVAC unit or stat that controls heating and cooling on the first floor of Freer house Roo
FO-281036	4/8/2014	4/16/2014		CONTROLS please replace leaking 8 inch diaphragm on Honeywell mp953c1075 actuator for 1
FO-281299	4/10/2014	4/16/2014		Needle Nose pliers- 3R211 (Price \$27.70)
FO-281481	4/14/2014			HONEYWELL:
FO-281484	4/14/2014			HONEYWELL:
FO-281529	4/14/2014	4/24/2014		HEAT PUMP WILL NOT RESET. TOO HOT. ROOM 50.2
FO-281568	4/15/2014	4/25/2014		HONEYWELL: Request Honeywell Tech; Bob Slick to perform software installs; NTE (4) Hrs.
FO-281725	4/15/2014			R/R RM 00025/MECH RM Fan HV-1 for hot kitchen has defective return air damper motor. Re
FO-281726	4/15/2014			A/C shop
FO-281797	4/16/2014			"Data Drop" mechanical room 1618
FO-281789	4/16/2014	4/22/2014		CSD-1 results:
FO-281790	4/16/2014			CSD-1 results:
FO-281791	4/16/2014			CSD-1 results:
FO-281792	4/16/2014			CSD-1 results:
FO-281795	4/16/2014			CSD-1 results:
FO-281798	4/16/2014			CSD-1 results:
FO-281804	4/16/2014			Control Engineer; High
FO-281866	4/17/2014			Trade: Controls
FO-281877	4/17/2014			Control Engineer; Medium
FO-281986	4/20/2014			Repair reheat control serving mixing box in hallway outside of Room 0407. Hot air blowing fro
FO-281987	4/20/2014			The mixing box reheat, (VAV?), serving the hallway outside of Room 0325 at Law Library is bl
FO-282011	4/21/2014			A/C shop repair boiler #1. No low water alarm.
FO-282323	4/22/2014			controls group,
FO-282329	4/22/2014			Investigate and correct cause of faulty temperature control on #2 dom water heater.
FO-282395	4/23/2014			Refg. Crew:
FO-282396	4/23/2014			Refg. Crew:
FO-282471	4/24/2014			The following fume hoods are not in the airflow range of 80 fpm:
FO-282509	4/24/2014			Control Engineer; High

WO	Recieved	Finished	Total	Request
FO-282512	4/24/2014			Control Engineer; High
FO-282518	4/24/2014			Trade: Controls
FO-282542	4/25/2014	4/25/2014		Request Honeywell [Rich Moon] to assist Maureen with AHU-1 damper issues. NTE (4) HRS.
FO-282631	4/28/2014	4/28/2014		CONTROLS CREW,
FO-282668	4/28/2014	4/30/2014		Evaluate relay and panel for air handler 1 and 2
FO-282694	4/28/2014	4/29/2014		Trade: Controls
FO-279378	4/29/2014			Refr Crew:
FO-279639	4/29/2014			Controls group.
FO-278819	4/29/2014			Trade: Controls
FO-279420	4/29/2014			A/C shop
E - MedPharm			22	
FO-280088	4/1/2014			R/R ROOF please replace the fills ON cooling tower #1 IT IS in bad shape. heat transfer probl
FO-280089	4/1/2014			Please
FO-280097	4/1/2014	4/1/2014		Temperature in mouse room is 80 degrees and the humidity is 17%. This has been a constant
FO-280492	4/2/2014			Air pressure in rooms ; 2314,2316, 2318, 2320, 2322 and 2323 is positive to the hall, it needs
FO-280497	4/2/2014			Room 2307 has duct tape over the exhaust vent. We need to have the exhaust fixed correctly
FO-280499	4/2/2014	4/2/2014		WORK W/BRUNER PLUM CO W/CHEM FEED STATION
FO-280559	4/2/2014	4/2/2014		Room 3329 - Please adjust temperature in room to be no more than 71 degrees. Please note
FO-280607	4/3/2014	4/3/2014		Nozzle on emergency eyewash station leaks
FO-280609	4/3/2014	4/3/2014		Nozzle on emergency eyewash station leaks
FO-280956	4/8/2014	4/21/2014		ELECTRICIANS,
FO-281231	4/10/2014			RM 9320 1ST BENCH @ ENT DOOR WHEN FAUCET IS ON IT TURNS ON THE FAUCET I
FO-281342	4/11/2014	4/29/2014		Yesterday my large animal freezer was cleaned out of animals. Needs to be defrosted and I n
FO-281348	4/11/2014	4/11/2014		We had a fire drill this morning and yes its loud, which is expected. Most fire drill tests happe
FO-281432	4/14/2014			Upper floors, 3rd and 4th floors temperature is too warm, average temp is 84. Please cool it d
FO-281679	4/15/2014	4/15/2014		Room is too warm. Thermostat currently reads 76 degrees. This is the third business day in a
FO-281728	4/15/2014			Please change filters in ceiling as soon as possible. There are black particles all over the lab.
FO-281814	4/16/2014			FILTER NEED TO BE CHANGED. ROOM 7119.
FO-282273	4/22/2014	4/22/2014		Whole building is humid and stuffy; thermostats read 73. Please bring temperature down and
FO-282472	4/24/2014			The following fume hoods need to be ajusted to proper airflow range of 80 -120 feet per minut
FO-282522	4/24/2014			CONTRACTOR: KROPF MECH SVC:
FO-282664	4/28/2014	4/28/2014		Check for electrical power to cold room 3250 compressor
FO-282841	4/29/2014			MEET W/GOLDEN REFRIGERANT LOADING DOCK AREA PER CHARLES R APPR 1:30p
E - North			10	
FO-280084	4/1/2014	4/11/2014		Parts for pump repair FAB #2.
FO-280494	4/2/2014	4/3/2014		granger
FO-281206	4/10/2014	4/21/2014		Supply belts for change out at FAB on all four RTU's.
FO-281499	4/14/2014	4/30/2014		Supply Belts for South Fume hood exhaust #3 and #4 at Chemistry
FO-281502	4/14/2014	4/30/2014		Seal for HHW pump 3
FO-282286	4/22/2014	4/22/2014		Thermostat does not work; turn it to 60 degrees, nothing, turn it to 80 degrees, nothing. It is al
FO-282382	4/23/2014	4/24/2014		Kresge Library, 1st Floor, Open Study Area
FO-282426	4/23/2014	4/24/2014		Kresge Library, 1st Floor, Near Stair #4
FO-282468	4/23/2014	4/28/2014		Please check source of leak on ceiling in stairwell (leads from 1st floor to Print Room). If the l
FO-282813	4/29/2014	4/29/2014		Staff is reporting temp in this suite is 62, very cold for them. Please have someone come and
E - Northeast			4	
FO-280753	4/4/2014	4/11/2014		Clean condenser coils on RTU's.
FO-280754	4/4/2014			Clean condenser coils on RTU's.
FO-280756	4/4/2014			Clean condenser coils on RTU's.

WO	Recieved	Finished	Total	Request
FO-282530	4/24/2014			Furnace #5 in the Art Sculpture Foundry makes an explosion sound and then turns off.
E - Preventative Maintenance			14	
FO-280186	4/2/2014	4/14/2014		Replace Belts.
FO-280590	4/3/2014	4/14/2014		Misc Filter Order:
FO-280697	4/4/2014			Misc Filter Order -
FO-280864	4/7/2014	4/25/2014		request assignment of afternoon engineer to assist in conducting an evacuation drill, drill to b
FO-280887	4/7/2014	4/8/2014		Electrical issues in room 1212. Room is blowing breakers. Thank you.
FO-281563	4/14/2014	4/15/2014		R/R RM 2551 The lock core on lab 2551 in the EDC is eating keys. The lock works, but it is v
FO-281741	4/15/2014	4/16/2014		The auxillary air conditioners are off. We need to have them turned on for air circulation in thi
FO-281975	4/19/2014	4/30/2014		Replace Belts on unit.
FO-281976	4/19/2014	4/30/2014		Replace Belts on unit.
FO-281977	4/19/2014	4/30/2014		Replace Belts on unit.
FO-282264	4/22/2014	4/29/2014		Replace Belts.
FO-282369	4/23/2014			Replace Belt
FO-282540	4/25/2014	4/30/2014		Exhaust fan belt order
FO-282695	4/28/2014	4/28/2014		R/R 3RD FLR STRWL We have a burning smell in the back stairwell (emergency exit stairwell
E - South			20	
FO-280091	4/1/2014	4/1/2014		Room at 76* F, please lower to 74/72* F.
FO-280092	4/1/2014	4/1/2014		Humidity levels seem to be dropping at night to very low levels, 19-23%. Daytime running at 3
FO-280094	4/1/2014	4/1/2014		Cage washer doesn't seem to be venting steam from washer at end of cycle. Damper/fan iss
FO-280860	4/7/2014	4/7/2014		We are again having a strong Sewer gas smell in entire building. Getting complaints from all f
FO-280861	4/7/2014	4/8/2014		Loud noise coming from vent in the hallway right outside room 3002 next to doors that lead to
FO-280969	4/8/2014	4/9/2014		The Hood is 0331.2 is not working. It needs to be looked at. Thank you.
FO-280998	4/8/2014	4/11/2014		Please supply parts for engineer
FO-281006	4/8/2014	4/8/2014		Room too warm. Students are opening windows which is effecting fume hoods.
FO-281190	4/9/2014	4/17/2014		Synthetic oil for gearbox on cooling tower.
FO-281211	4/10/2014			Room 310.5 walk in cooler short cycling.
FO-281364	4/11/2014	4/11/2014		Repair fume hood exhaust #1
FO-281443	4/14/2014	4/14/2014		Complaints that the entire building is very hot - over 80 degrees.
FO-281680	4/15/2014	4/15/2014		Yet again our everyday Sewer gas smell in basement, stairwells and hallways.
FO-281697	4/15/2014	4/15/2014		Heater in stairwell A - first floor by doors to State Hall is making a Loud banging noise.
FO-281823	4/16/2014	4/17/2014		There is a large pipe (maybe an air duct)
FO-281906	4/17/2014	4/22/2014		There is a large pipe (maybe an air duct)
FO-282101	4/21/2014	4/22/2014		TOO HOT. ROOM 0050.
FO-282476	4/24/2014	4/24/2014		This fume hood is still not working - We may need to follow up on this one hood.
FO-282483	4/24/2014	4/24/2014		Room is very cold. Thermostat not working.
FO-282515	4/24/2014	4/24/2014		Fume hood will not shut off. Researcher said that they were able to control it by switch in lab
E - Southeast			5	
FO-280526	4/2/2014			CHECK WINDOW SEAL FOR POSSIBLE LEAK. (WARPED)
FO-281145	4/9/2014	4/9/2014		3rd Floor, East end of building is very warm. please adjust temperature only on the east end.
FO-281388	4/11/2014	4/11/2014		Temperature is reaching 84 on the east end of building. Please adjust - Too Hot.
FO-281521	4/14/2014	4/14/2014		Blower in faculty office is not working.
FO-281843	4/17/2014	4/17/2014		BSMT HALLWAY NEAR RM 0159 FIRE EXIT DOOR - DOOR HANDLE IS BROKEN
E - West			3	
FO-280085	4/1/2014	4/11/2014		Engineering
FO-280100	4/1/2014	4/11/2014		Air flow coming out of ducts is so large that it
FO-281433	4/14/2014	4/17/2014		TOO HOT. ROOM 3170.

WO	Recieved	Finished	Total	Request
Grounds			5	
High			1	
G - Physical Grounds			1	
FO-281279	4/10/2014			Ray Lindenmuth, Grounds Supervisor, says: he cannot do this job.
Medium			1	
G - Physical Grounds			1	
FO-282123	4/21/2014	4/22/2014		Clean up leaves and debris in the early childhood
Low			1	
G - Moving/Storage			1	
FO-281707	4/15/2014	4/17/2014		Please move and put together the desk that is currently sitting in my office to my lab on the se
Routine			2	
G - Physical Grounds			2	
FO-280516	4/2/2014	4/7/2014		This Work Order is a recreation of Work Order FO-280506.
FO-281497	4/14/2014			Received in Grounds 4/15/14 - given to Don Wrench.
Trades			1115	
Emergency			102	
T - Carpenter			26	
FO-280077	4/1/2014	4/1/2014	4/29/2014	RM 2122 KEY BROKE OFF IN LOCK. Finished 4/7/2014LT
FO-280125	4/1/2014	4/1/2014	4/29/2014	R/R RM 108/EISTEINS Arm on door has broken off again causing door not to close.
FO-280124	4/1/2014	4/1/2014	4/29/2014	HANDICAP DOOR IS OFF TRACK.. Finished 4/7/2014LT
FO-280136	4/1/2014	4/1/2014	4/29/2014	EMERGENCY CARP:
FO-280618	4/3/2014	4/4/2014		DOOR WON'T OPEN WITH KEY. ROOM 0231. Finished 4/7/2014LT
FO-280711	4/4/2014	4/4/2014		EMERGENCY CARP
FO-280720	4/4/2014	4/4/2014		EMERGENCY CARP
FO-280839	4/7/2014	4/7/2014		Police Report #W14-040798 - Please R/R Keypad Door Lock to suite 3320 (Law IT Dept.) is b
FO-280841	4/7/2014	4/7/2014		Loading Dock Door is not working. The key tumler or
FO-280879	4/7/2014	4/7/2014		ENTRANCE DOOR, DOOR HANDLE BROKEN. COULD POSSIBLY LEAD TO INJURY. Finis
FO-280985	4/8/2014	4/9/2014		FIRE DOOR WON'T STAY UP. 1ST FLOOR NEAR ROOM 116. Finished 4/29/2014LT
FO-281029	4/8/2014	4/8/2014		BOILER RM DOOR NEAR TENNIS COURTS NOT LOCKING. Finished 4/9/2014LT
FO-281123	4/9/2014	4/9/2014		Room 2564 the lock is spinning when I put the key into the lock. It is urgent for us to have this
FO-281132	4/9/2014	4/9/2014		EMERGENCY/CARP
FO-281505	4/14/2014	4/16/2014		EMERGENCY/CARP:
FO-281703	4/15/2014	4/16/2014		EMERGENCY
FO-281925	4/18/2014	4/21/2014		EMERGENCY/CARP
FO-282023	4/21/2014	4/24/2014		**Adding Carpenter: Provide access in ceiling outside 2301 to repair condensate leak and put
FO-282276	4/22/2014	4/22/2014		EMERGENCY/CARP
FO-282277	4/22/2014	4/22/2014		EMERGENCY CARP:
FO-282362	4/22/2014	4/23/2014		CONTRACTOR: RAYNOR OVERHEAD DOOR CO
FO-282386	4/23/2014	4/23/2014		REPAIR DOOR LOCK. DOOR WILL NOT OPEN WITH KEY. ROOM 2071 (PROFESSOR IS
FO-282560	4/25/2014	4/28/2014		EMERGENCY CARP
FO-282821	4/29/2014	4/29/2014		EMERGENCY CARP
FO-282872	4/29/2014	4/29/2014		EMERGENCY CARP
FO-282881	4/29/2014	4/30/2014		RM 114 UNABLE TO SECURE DOOR, SECURITY ISSUE.
T - Electrician			43	
FO-280070	4/1/2014	4/1/2014	4/29/2014	WALL OUTLET IS NOT WORKING. HOT KITCHEN - SEE NICK FOR LOCATION. Finished
FO-280113	4/1/2014	4/2/2014		FIRE TROUBLE ALARM Finished 4/4/2014LT
FO-280511	4/2/2014	4/2/2014		PRONG HAS BROKEN OFF IN WALL OUTLET. ROOM 124. Finished 4/4/2014LT

WO	Recieved	Finished	Total	Request
FO-280512	4/2/2014	4/3/2014		ahu 2 vfd drive fault condition
FO-280525	4/2/2014	4/2/2014		FIRE TROUBLE ALARM Finished 4/4/2014LT
FO-280566	4/2/2014	4/3/2014		FIRE ALARM Finished 4/4/2014LT
FO-280598	4/3/2014	4/3/2014		Trade: Electrician
FO-280600	4/3/2014	4/4/2014		Trade: Electrician
FO-280602	4/3/2014	4/3/2014		EMERGENCY ELEC
FO-280603	4/3/2014	4/3/2014		EMERGENCY ELEC
FO-280979	4/8/2014	4/7/2014		REPAIR LIGHT FIXTURE - LIGHTS BLEW OUT. ROOM 2351. Finished 4/11/2014LT
FO-280982	4/8/2014	4/7/2014		LIGHTS ARE OUT. HALLWAY OUTSIDE OF ROOM 327. PLEASE CHECK Finished 4/11/2
FO-281152	4/9/2014	4/10/2014		TROUBLESHOOT #14 HYDRONIC HOT WATER HEATING PUMP. ROOM 100. SEE ENGI
FO-281153	4/9/2014	4/9/2014		FIRE TROUBLE ALARM. ELECTRICAL CLOSET ROOM 102. Finished 4/11/2014LT
FO-281209	4/10/2014	4/10/2014		FIRE TROUBLE ALARM Finished 4/11/2014LT
FO-281217	4/10/2014	4/10/2014		FIRE TROUBLE ALARM Finished 4/11/2014LT
FO-281234	4/10/2014	4/10/2014		EMERGENCY ELEC
FO-281323	4/11/2014	4/11/2014		FIRE TROUBLE ALARM. Finished 4/14/2014LT
FO-281327	4/11/2014	4/11/2014		#5 FAN WON'T START UP. SEE ENGINEER Finished 4/14/2014LT
FO-281350	4/11/2014	4/11/2014		FIRE TROUBLE ALARM. Finished 4/14/2014LT
FO-281425	4/14/2014	4/15/2014		MEDICAL VACUUM SYSTEM, INSPECT AND CORRECT CAUSE OF INTERMINTENT OPE
FO-281427	4/14/2014	4/14/2014		REPAIR VARIABLE FREQUENCY DRIVE SERVING HV1 (HOT KITCHEN). KEEPS TRIPPI
FO-281674	4/15/2014	4/16/2014		EMERGENCY ELEC
FO-281681	4/15/2014	4/15/2014		AIR HANDLER #4 UNIT WON'T START. OFF ON FREEZE STAT. PENTHOUSE. SEE EN
FO-281749	4/16/2014	4/16/2014		DOMESTIC WATER BOOSTER PUMP NOT WORKING. ROOM 51 Finished 4/18/2014LT
FO-281778	4/16/2014	4/28/2014		ELECTRICIANS please inspect r/r electrical to unit heater center front in garage. round heatin
FO-281946	4/18/2014	4/18/2014		We have low water pressure in all the restrooms in the building. Also the toliets are not flushin
FO-281959	4/18/2014	4/22/2014		LIGHT TIMER WILL NOT COME ON. MEN'S RESTROOM. ROOM 1328.Finished 4/23/2014
FO-281991	4/21/2014	4/21/2014		Investigate and correct of bolts/screws out of fan motor. Finished 4/22/2014LT
FO-281993	4/21/2014	4/21/2014		COOLING TOWER PUMP 8 OVER TEMPERATURE. PENTHOUSE. Finished 4/22/2014LT
FO-282016	4/21/2014			TROUBLESHOOT VFD4 CONDENSING PUMP#8 FAN WON'T RUN
FO-282078	4/21/2014	4/22/2014		FIRE TROUBLE ALARM.Finished 4/23/2014LT
FO-282330	4/22/2014	4/24/2014		CHECK FUSES TO PUMP ON RO SYSTEM. PENTHOUSE.Finished 4/25/2014
FO-282374	4/23/2014	4/23/2014		Transport booster pump from stockroom to basement mecanical room Finished 4/23/2014LT
FO-282394	4/23/2014	4/24/2014		EMERGENCY/ELEC
FO-282461	4/24/2014	4/24/2014		FIRE TROUBLE ALARMFinished 4/25/2014
FO-282469	4/24/2014	4/25/2014		EMERGENCY ELEC
FO-282487	4/24/2014	4/24/2014		RM 7374 INNER OFFICE POWER OUT LIGHTS AND ELECTRICAL OUTLETSFinished 4/25/
FO-282613	4/26/2014	4/25/2014		Restore power to classroom lights on the South side of the first floor. Classes taking place this
FO-282785	4/29/2014	4/29/2014		Lights are out in Ludington mall by St. Andrews/Manoogian.
FO-282806	4/29/2014			EMERGENCY ELEC
FO-282834	4/29/2014			FIRE TROUBLE ALARM
FO-282839	4/29/2014	4/29/2014		EMERGENCY ELEC
T - Locksmith			1	
FO-280086	4/1/2014	4/1/2014	4/29/2014	Room #13 in basement.Supervisor's key broke off in the door need it remove and need new k
T - Pipefitter			13	
FO-280716	4/4/2014	4/4/2014		HALLWAY OUTSIDE RM 417 CEILING LEAK ,,,,,,,,,, ME/4-4-14 ,,,,,,,,,, DUE ASAP Fi
FO-280973	4/8/2014	4/8/2014		AIR HANDLER 12. 1/2 INCH PIPE BROKEN ON CHILL WATER LINE. SEE ENGINEER.,,,,,,
FO-280999	4/8/2014	4/8/2014		CEILING LEAK. ROOM 9105 ,,,,,,,,,, RC/ 4-8-14 ,,,,,,,,,, DUE ASAP Finished 4/9/2014LT
FO-281198	4/10/2014	4/17/2014		(**) P.O. Req DK
FO-281349	4/11/2014	4/14/2014		EMERGENCY/PIPE

WO	Recieved	Finished	Total	Request
FO-281378	4/11/2014	4/14/2014		EMERGENCY/PIPE
FO-281908	4/18/2014	4/18/2014		OPEN A DISCHARGE BUTTERFLY VALVE FROM #1 ABSORBER. PENTHOUSE. SEE EN
FO-281956	4/18/2014	4/18/2014		EMERGENCY PIPE
FO-281992	4/21/2014	4/22/2014		CEILING LEAKS. ROOM AF7 AND HALLWAY OUTSIDE OF ROOMS 2301 AND AF3.....
FO-282324	4/22/2014	4/23/2014		PLEASE REPAIR/REPLACE PVC PIPING UNDERNEATH COOLING TOWER. (ROOFTOP
FO-282391	4/23/2014	4/23/2014		**Refer to FO#281168 JWT
FO-282619	4/28/2014			EMERGENCY/PIPE
FO-282826	4/29/2014			REPAIR LEAKING CHILLED WATER COIL FCU#1 FCU#2 RC/4-30-14
T - Plumber			19	
FO-280717	4/3/2014	4/3/2014		Drinking fountain loose from wall 1st floor MP/DB 4-3-14 DUE ASAP Finish
FO-280600	4/3/2014	4/4/2014		Trade: Electrician
FO-280699	4/4/2014	4/4/2014		Basement Men's restroom pipe leaking from toilet. Flooding restroom. MP/DB 4-4
FO-280735	4/4/2014	4/14/2014		RM 6126 PIPE OUT OF WALL LEAKING MM/ 4-4-14 DUE ASAP Finishe
FO-280741	4/4/2014	4/4/2014		Please clear sink room 440 RB/ 4-4-14 DUE ASAP Finished 4/7/2014LT
FO-280748	4/4/2014	4/17/2014		EMERGENCY PLUM
FO-280800	4/7/2014	4/7/2014		ADDING: EMERGENCY/PLUM
FO-281154	4/9/2014	4/9/2014		TOILET OVERFLOWING. BASEMENT MEN'S RESTROOM. NEAR ROOM 025.
FO-281162	4/9/2014	4/9/2014		please replace P-Trap which has fallen off the sink 13th floor unisex restroom....MP/ DB 4-9-1
FO-281199	4/10/2014	4/10/2014		SLOP SINK IS PLUGGED. ROOM 7100 (CUSTODIAL CLOSET)..... MM / 4-10-14
FO-281303	4/10/2014	4/10/2014		**Adding Electrician: Please turn heat trace, water heaters, and heat back on at Stadium by Fr
FO-281656	4/15/2014	4/15/2014		EMERGENCY PLUMBER
FO-281926	4/18/2014	4/18/2014		**Cancelled JWT
FO-281989	4/20/2014	4/20/2014		**Handled by Engineer JWT
FO-282291	4/22/2014			TRENCH DRAIN IS PLUGGED. ROOM 0235..... MM/ 4-22-14 DUE ASAP
FO-282363	4/23/2014	4/24/2014		Please repair broken tees on hose bibs on the top level of the structure on the west side.....
FO-282466	4/24/2014	4/25/2014		PLEASE REPAIR LEAKING BACKFLOW PREVENTER. ROOM 4461. MM/ 4-2
FO-282661	4/28/2014			BSMNT; UTILITY CLOSET FLOOR DRAIN BACKING UP DB/ 4-28-14
FO-282842	4/29/2014			EMERGENCY (PLUMBING) POSSIBLE CONTRACTOR
High			281	
T - Carpenter			53	
FO-280111	4/1/2014	4/4/2014		Trade: Carpenter
FO-280176	4/1/2014	4/3/2014		LAB 10 KEY GETTING STUCK. Finished 4/7/2014LT
FO-280182	4/1/2014	3/31/2014	4/29/2014	The south entrance to the faculty lounge
FO-280183	4/1/2014	4/3/2014		The internal door keypad to the student board
FO-280523	4/2/2014	4/8/2014		Lab 5230 needs tiles re-glued. They are lifting up. THIS IS A TRIP HAZARD AND THE SEC
FO-280531	4/2/2014	4/3/2014		West Door facing Alumini House is stuck in open position. Finished 4/7/2014LT
FO-280533	4/2/2014	4/4/2014		Lock is very difficult to turn and open. This is a
FO-280539	4/2/2014	4/3/2014		1ST FL JANITOR's CLOSET DOOR HANDLE BROKEN OFF. Finished 4/7/2014LT
FO-280551	4/2/2014			** Adding Carpenter: Disconnect 1 piece sink and counter top 0209 and deliver back to Pipe S
FO-280668	4/3/2014	4/4/2014		R/R RM 5159/LAB MAIN HALLWAY ENTRANCE DOOR ISN'T LATCHING CLOSE CAUSING
FO-280738	4/3/2014	4/7/2014		Arm on the outside glass door is broke. Finished 4/9/2014LT
FO-280739	4/3/2014	4/7/2014		Hinge on outside door is broken. Finished 4/9/2014LT
FO-280689	4/3/2014			Adding Carpenter: Please remove and replace cider block to access plumbing repair near 1st
FO-280733	4/4/2014	5/4/2014		R/R ENT DOOR #609 05N OUTSIDE HANDICAP PUSH BUTTON WILL NOT OPEN EXTETR
FO-280804	4/7/2014	4/8/2014		BACK DOOR DOESN'T CLOSE PROPERLY, SECURITY ISSUE Finished 4/9/2014LT
FO-280806	4/7/2014	4/8/2014		The middle outside front door is sticking and not
FO-281031	4/8/2014	4/8/2014		2ND FL LADIES RM STALL DOOR LOCKED, NOT IN USE Finished 4/9/2014LT
FO-281092	4/9/2014			CARPENTERS: Please replace broken floor tiles in room 4420. Trip/ Safety. MED.

WO	Recieved	Finished	Total	Request
FO-281100	4/9/2014			REMOVE METAL END CUP FROM SIDE OF BLDG. NEAR GARAGE DOOR. SEE SANDY
FO-281137	4/9/2014	4/10/2014		Door 203-05S is not securing consistently. Continuous-hinged door doesn't close flush. Some
FO-281224	4/10/2014	4/10/2014		HALLWAY OUTSIDE RM 150, WHOLE IN WALL Finished 4/11/2014LT
FO-281362	4/11/2014	4/11/2014		STAIRWELL DOOR NEAR RM 122 NOT SECURED Finished 4/16/2014LT
FO-281370	4/11/2014	4/14/2014		2ND FL SOUTH SIDE STAIRWELL DOOR HANDLE NOT WORKING PROPERLY Finished 4
FO-281385	4/11/2014			CARPENTERS: Please replace bad floor tiles in room 4230 trip/ safety MED.
FO-281426	4/14/2014	4/14/2014		Please repair the broken sheer cord at the Alumni House (Apt). Finished 4/16/2014LT
FO-281468	4/14/2014	4/16/2014		WINDOW LATCH IS BROKEN. WINDOW HAS FLOWN OPEN. ROOM 214. Finished 4/18/2
FO-281503	4/14/2014	4/14/2014		apartment door latch is broken, need locksmith, resident cannot close and lock door. Finished
FO-281498	4/14/2014	4/24/2014		R/R 3RD FLR HALLWAY NEAR DOUBLE DOORS LEADING TO BRIDGE & RM 3244 GLUE
FO-281545	4/14/2014			Trade: Carpenters
FO-281659	4/15/2014	4/16/2014		please replace ceiling tiles that are about to collapsse in 2nd floor unisex restroom, there was
FO-281701	4/15/2014			ADDING CARP:
FO-281717	4/15/2014	4/17/2014		HOSE BIBBS ARE COMING OFF WALL. ROOMS 5520 AND 5530....., MM/ 4-16-14 ,,
FO-281736	4/15/2014	4/16/2014		Law Library's door 053-22E scrapes frame and keeps door ajar. Finished 4/18/2014LT
FO-281738	4/15/2014	4/16/2014		Law Library's door 053-23E won't close completely. Door stays ajar. Finished 4/18/2014LT
FO-281747	4/16/2014			Provide access in 1st floor mechanical room wall . See Mike Pummill for location
FO-281773	4/16/2014	4/16/2014		Our keys are getting stuck in the door to receiving room# 112 on the side leading into the build
FO-281774	4/16/2014	4/17/2014		Room 421 the push panel to exit the room sticks and you have to push it several times before
FO-281820	4/17/2014	4/17/2014		RE: Door # 12N-B (Loading Dock Door)
FO-281827	4/17/2014			ADDING ELEC/MAIN LABORER
FO-281842	4/17/2014			CONTRACTOR/RAYNOR OVERHEAD DOOR:
FO-281851	4/17/2014	4/18/2014		Removable mullion between doors 01E & 02E is too loose at bottom. Causes latching failure
FO-281878	4/17/2014			Carpenter; High
FO-281990	4/21/2014	4/21/2014		Trade: Carpenter
FO-282062	4/21/2014	4/22/2014		RM 215 FALLING PROJECTION SCREEN NEEDS TO BE REPAIRED
FO-282265	4/22/2014	4/22/2014		Please adjust North entrance doors 11 & 12 - not securing. Finished 4/23/2014LT
FO-282421	4/23/2014	4/23/2014		DOOR WON'T CLOSE PROPERLY. CAUSING ALARMS TO PUBLIC SAFETY. SUB-BASE
FO-282650	4/28/2014			Trade: Carpenter
FO-282660	4/28/2014	4/28/2014		DOOR #603-10N INSIDE DOOR, SLAMS SHUT COULD POSSIBLY BREAK GLASS
FO-282662	4/28/2014	4/28/2014		DOOR # 080-025 HANDICAP DOOR ARM BROKEN
FO-282687	4/28/2014			**Adding Carpenter: Provide access in ceiling outside 2301 to repair condensate leak and put
FO-282830	4/29/2014			416 CONF RM A LEAKING WINDOW SEAL, RM WILL BE OCCUPIED FROM 11:30am to 1:
FO-282869	4/29/2014			THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED
FO-282873	4/29/2014			THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED
T - Electrician			76	
FO-280083	4/1/2014	4/2/2014		In the circulation area where counseling of students happens there is a noise that is constantly
FO-280106	4/1/2014			Install light on pole to illuminate street next to drive way off Scott Hall.
FO-280115	4/1/2014	4/1/2014	4/29/2014	elect.
FO-280132	4/1/2014	4/1/2014	4/29/2014	R/R BLDG FAP FIRE TROUBLE ALARM W/RESET THEN ACTIVE AGAIN Finished 4/4/2014
FO-280142	4/1/2014	4/1/2014	4/29/2014	Trade electrcians Prioity high
FO-280500	4/2/2014	4/3/2014		Adding Electrician: Please upgrade electrical outlet for bottle filling station near room 0108. Se
FO-280520	4/2/2014	4/2/2014		WALL OUTLETS ARE NOT WORKING. HALLWAY OUTSIDE OF ROOM 0330. Finished 4/4/
FO-280534	4/2/2014	4/3/2014		Basement, DUNGEON room, (room where the Pepsi stored) 1 electrical problem. As soon as
FO-280593	4/3/2014	4/3/2014		Time for Safety Meeting for the month of April, 2014. Finished 4/4/2014LT
FO-280594	4/3/2014	4/3/2014		Install 20 Amp receptacle for Public Safety. Finished 4/4/2014LT
FO-280615	4/3/2014			ELECTRICIAN

WO	Recieved	Finished	Total	Request
FO-280632	4/3/2014	4/4/2014		2ND FL COMPUTER LAB, TO THE LEFT OF ELEV. OUTLETS NOT WORKING. PLEASE S
FO-280657	4/3/2014	4/4/2014		Mcgregor Conference Center - Fire trouble
FO-280656	4/3/2014	4/4/2014		Trouble-shoot Ground Fault on circuit 22 on the Fire Panel.. Finished 4/7/2014LT
FO-280760	4/4/2014	4/7/2014		AICHE (Room 1212) has been having odd outages for the past couple of weeks. The right an
FO-280832	4/7/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-280844	4/7/2014	4/7/2014		Diss-connect, remove portable heaters from the hallway, and store them in the stockroom with
FO-280991	4/8/2014	4/9/2014		Trade: Electricians
FO-280989	4/8/2014	4/7/2014		WALL OUTLETS ARE NOT WORKING. ROOM 105. Finished 4/11/2014LT
FO-281035	4/8/2014	4/9/2014		**Adding Electrician: Please replace controller on HWH near Boilers. See John Towle for contr
FO-281050	4/8/2014	4/7/2014		Time for PM Technologies to come out, and service AC Generator. Finished 4/11/2014LT
FO-281051	4/8/2014	4/10/2014		4TH FL NEAR SAR LOUD BUZZING NOISE Finished 4/11/2014LT
FO-281111	4/9/2014			Electricains: High Priority.
FO-281155	4/9/2014	4/9/2014		R/R RM 180 FAP FIRE TROUBLE ALARM ACTIVATED Finished 4/11/2014LT
FO-281171	4/9/2014	4/11/2014		RM 1303 TV STUDIO LOSS POWER TO OUTLETS Finished 4/14/2014LT
FO-281223	4/10/2014	4/16/2014		ELECTRICIANS FIRST BEFORE: Contractor (Fife Pearce) Supervisor(CRedman) (High Piori
FO-281225	4/10/2014	4/16/2014		ELECTRICIANS FIRST BEFORE: Contractor (Fife Pearce) Supervisor(CRedman) (High Piori
FO-281226	4/10/2014	4/16/2014		ELECTRICIANS FIRST BEFORE: Contractor (Fife Pearce) Supervisor(CRedman) (High Piori
FO-281230	4/10/2014	4/10/2014		MULTI-PURPOSE BLDG LIGHT POLL ON THE GROUND NEAR SIDEWALK BETWEEN TE
FO-281257	4/10/2014			ELECTRICIANS,R/R RM 0001/MECH RM PLEASE REPAIR BAD MAKE-UP WATER CIRC
FO-281260	4/10/2014	4/11/2014		Cafeteria has no power at the outlets which are on the columns in the cafeteria. Both Nnorth c
FO-281304	4/10/2014	4/21/2014		Please transport snake machine and assist Ray Banbury in basement mechanical room Frida
FO-281336	4/11/2014	4/11/2014		Elect. High Priority
FO-281346	4/11/2014	4/11/2014		R/R LOWER LEVEL BY THE LAUNDRY RM NEAR DOCK DOOR AREA INSIDE THE EXCE
FO-281352	4/11/2014	4/11/2014		Transport 4" backflow from stockroom to Parking Structure #8 at 1:30pm on Friday 4-11-14.
FO-281354	4/11/2014	4/14/2014		Called this in to Loretta this morning, here is detail per Al Bartlett of TRC:
FO-281393	4/11/2014	4/14/2014		BLOWN FUSE. ROOM 6304. Finished 4/16/2014LT
FO-281424	4/14/2014	4/14/2014		WALL OUTLET (GFI)NOT WORKING. BREAK ROOM. Finished 4/16/2014LT
FO-281478	4/14/2014	4/15/2014		please check electrical side for issues preventing motor start Finished 4/16/2014LT
FO-281526	4/14/2014	4/15/2014		Electricians:
FO-281555	4/14/2014	4/15/2014		R/R RM 5341 REPLACE MISSING WALL OUTLET COVER ON WEST WALL Finished 4/16/2
FO-281649	4/15/2014	4/15/2014		pls check pump motor vfd for proper
FO-281664	4/15/2014	4/15/2014		Trace out Bus Duct, and open all swing jacks so Utilities Instrumentation can megger Bus Duc
FO-281708	4/15/2014	4/17/2014		Room 1350 has a short in the light switch. Finished 4/18/2014LT
FO-281730	4/15/2014	4/17/2014		Electricians:
FO-281735	4/15/2014	4/17/2014		DOORS BLOWING OPEN CHECK AIR PRESSURE THROUGHOUT LAW COMPLEX. Finish
FO-281746	4/16/2014			panel has 2 trouble issues
FO-281768	4/16/2014			ELECTRICIANS (HIGH)
FO-281786	4/16/2014	4/23/2014		ELECTRICIANS (HIGH)
FO-281810	4/16/2014	4/17/2014		Trade: Electrician Priority: High
FO-281827	4/17/2014			ADDING ELEC/MAIN LABORER
FO-281919	4/18/2014	4/18/2014		FIRE EXTINGUISHERS NEED REPLACING. BACK DOOR OF PUBLIC SAFETY.Finished 4/
FO-281923	4/18/2014	4/18/2014		R/R RM 200.14/DLAR LITE TIMER ISN'T KEEPING TIME CORRECTLYFinished 4/21/2014L
FO-281970	4/18/2014	4/21/2014		** Adding Electrician: Rewire condensate pump #1 rm 410 . See Ron Clark if needed Finished
FO-281972	4/18/2014	4/21/2014		**Adding Electrician: Rewire condensate pump #1 in mechanical room #1. See Ron Clark if ne
FO-282033	4/21/2014	4/22/2014		Possible electrical hazzard, Matthaei Athletic Shed!
FO-282038	4/21/2014			On the forth floor Carpenters are working off a scaffold, and noticed a fixture about to fall, Plea
FO-282106	4/21/2014	4/22/2014		disconnect number 1 steam condensate pump reference fo#(281801)Finished 4/23/2014LT

WO	Recieved	Finished	Total	Request
FO-282338	4/22/2014	4/22/2014		Please check power supply to TRC condensing unit, power supply is outside east side of buil
FO-282379	4/23/2014	4/23/2014		R/R BLDG FAP FIRE TROUBLE ALARM ACTIVE Finished 4/23/2014LT
FO-282402	4/23/2014	5/25/2014		150 & 152 ELECTRICITY IS NOT COMING THROUGH CORRECTLY Finished 4/29/2014LT
FO-282417	4/23/2014	4/23/2014		Room 5364 - Outlet on wall not working - please troubleshoot. Outlet is located on south wall
FO-282415	4/23/2014	4/24/2014		Unwire booster pump motor that has been removed from pump and rewire it on new booster p
FO-282423	4/23/2014	4/25/2014		Trade: Laborer
FO-282438	4/23/2014	4/23/2014		Move motor to back of Bio-Science, and wait for Connelly to pick it up to the roof. Finished 4/2
FO-282475	4/24/2014	4/25/2014		R/R RM 102/MECH RM FIRE TROUBLE ALARM IS ACTIVE Finished 4/29/2014LT
FO-282523	4/24/2014	4/24/2014		Install contactors for water pumps for contractor to correct wiring/troubleshoot connections.Fin
FO-282614	4/26/2014	4/25/2014		Pull circuit for Duct Detector from Fire Panel, to Duct in Mechanical room air handling unit first
FO-282626	4/27/2014	4/28/2014		ELECTRICIANS:
FO-282623	4/28/2014			R/R BLDG FAP FIRE TROUBLE ALARM ACTIVE
FO-282627	4/28/2014	4/29/2014		Adding Electrician: Please disconnect hot water heater and reconnect when Plumber is compl
FO-282641	4/28/2014			Evaluation of booster pump operations with Vendor on Tuesday 4-29-14. See John in Pipe Sh
FO-282658	4/28/2014	4/28/2014		RM 155 LIGHTS NOT WORKING, FUSE POSSIBLY BLOWN Finished 4/29/2014LT
FO-282817	4/29/2014	4/29/2014		LAB 270 FUME HOOD #11 2 OUTLETS NOT WORKINGFinished 4/30/2014LT
FO-282833	4/29/2014	4/28/2014		control air compressor # 1 will not run Finished 4/30/2014LT
FO-282854	4/29/2014			Trade: Electricians
T - Laborer			1	
FO-280501	4/2/2014	4/2/2014		Please transport 12' ladder from USB to Physics basement coorador. See Ray Banbury for hel
T - Locksmith			8	
FO-280624	4/3/2014	3/31/2014		75486 1-Core 5-Keys. Finished 4/7/2014LT
FO-280996	4/8/2014	4/8/2014		DESK IN HALLWAY ACROSS FROM RM 321, DESK DRAWER UNABLE TO UNLOCK Finis
FO-281032	4/8/2014	4/8/2014		2-Keys UM288 FILE CABINET Finished 4/9/2014LT
FO-281287	4/10/2014	4/14/2014		75495 2-CORES FOR ROOM 4121 (18J-33) Finished 4/16/2014LT
FO-281395	4/11/2014	4/14/2014		fire door on west side of new Panda Express has a dead bolt installed ..MUST remove to com
FO-281756	4/16/2014	4/17/2014		#75351 4 Keys Room 3153 Finished 4/18/2014LT
FO-282005	4/21/2014	4/23/2014		#75510 1 Key Finished 4/23/2014LT
FO-282517	4/24/2014	4/24/2014		75515 4-KEYSFinished 4/25/2014
T - Painter			1	
FO-281042	4/8/2014	4/10/2014		Painters (High)
T - Pipefitter			64	
FO-280107	4/1/2014	4/3/2014		Fitters:
FO-280108	4/1/2014	4/9/2014		Trade: Pipefitter
FO-280120	4/1/2014	4/1/2014	4/29/2014	CEILING LEAK. ROOM 415. (CONTACT SHERYL MCGILLIS) ,,,,,,,,,, ME/4-1-14 ,,,,,,,,,,
FO-280140	4/1/2014			CEILING LEAK. FACULTY LOCKER ROOM. ROOM 154.1
FO-280480	4/1/2014	4/1/2014	4/29/2014	**Engineer taking care of JWT
FO-280498	4/2/2014	4/8/2014		Fitters, please repair leak in steam coil on AHU-2. Priority: high,,,,,,,,,,,,, ME/ 4-3-14 ,,,,,,,,,,
FO-280567	4/2/2014	4/3/2014		RM 333 CEILING LEAK ,,,,,,,,,,,,,, ME/4-3-14 ,,,,,,,,,,,,,, DUE 4-4-14 Finished 4/4/2014LT
FO-280591	4/3/2014	4/4/2014		Please repair condensate line in the penthouse.
FO-280608	4/3/2014	4/7/2014		**Refer to FO#281208 for re-insulation JWT
FO-280626	4/3/2014	4/3/2014		**Duplicate Work Order Refer To FO#280973 JWT
FO-280641	4/3/2014	4/7/2014		Trade: Plumber Priority: High
FO-280713	4/4/2014			fitters-R/R SUB BSMT sump pump #-2 leaking from seal,smell somewhat bad through buildi
FO-280795	4/7/2014	4/8/2014		** Duplicate/ Refer to FO#280496
FO-280796	4/7/2014	4/8/2014		**Duplicate / Refer to FO#280498 JWT
FO-280818	4/7/2014	4/7/2014		EMERGENCY/PIPE
FO-280870	4/7/2014	4/8/2014		STEAMFITTERS PLEASE INVESTIGATE LEAK IN ROOMS 585,595,597 AND HALLWAY B

WO	Recieved	Finished	Total	Request
FO-280955	4/8/2014	4/7/2014		**Duplicate Work Order / Refer to FO#280958 JWT
FO-280958	4/8/2014			(**) P.O. Req DK
FO-280964	4/8/2014	4/8/2014		** Design Services project JWT
FO-280995	4/8/2014			Plumbers:
FO-281002	4/8/2014			OUTSIDE RM 302 CEILING LEAK VERY CLOSE TO ELECTRICAL OUTLET RB /
FO-281004	4/8/2014	4/10/2014		Pipefitters-please extend supply and return lines so existing hoses will reach new heat pump.
FO-281044	4/8/2014	4/10/2014		FITTERS (HIGH PRIORITY)
FO-281221	4/10/2014	4/11/2014		pipefitter
FO-281235	4/10/2014	4/10/2014		Duplicate Work Order / Refer to FO#281293 JWT
FO-281232	4/10/2014			RM 415 WATER PIPE LEAKING OVER AUTO CLAVE, LEAKING ON CONTROLS SEE DEB
FO-281277	4/10/2014	4/11/2014		Fitter replace section of water line that split on make up water to cooling tower. Emergency for
FO-281324	4/11/2014	4/11/2014		**Duplicate / Refer to FO#281430 / Work in Progress JWT
FO-281430	4/14/2014	4/15/2014		CEILING STEAM PIPE LEAKING. ROOM 451. ME/4-14-14 DUE ASA
FO-281465	4/14/2014	4/14/2014		R/R steam leak in eleavator switch room. JH/ 4-14-14 DUE ASAP Finish
FO-281472	4/14/2014	4/15/2014		CEILING LEAK. 2ND FLOOR UNISEX RESTROOM NEAR ROOM 224..... MP/DB 4-1
FO-281518	4/14/2014	4/15/2014		PIPEFITTERS
FO-281566	4/14/2014	4/14/2014		R/R condenser return valves / can not operate JH / 4-14-14 DUE ASAP Fini
FO-281671	4/15/2014	4/15/2014		**Contractor repairing JWT
FO-281687	4/15/2014	4/17/2014		PIPE
FO-281706	4/15/2014	4/18/2014		Room 2208 has a small leak. You can see it through the tiles in the office. Please assist. Th
FO-281765	4/16/2014	4/17/2014		Fitters, please repair leak in steam coil on AHU-2 in PH. Priority: high EA/ 4-16-14 ,
FO-281772	4/16/2014	4/17/2014		Pf Med-High Priority
FO-281838	4/17/2014	4/18/2014		Plumbers:
FO-281874	4/17/2014			Trade: Pipefitters
FO-281875	4/17/2014	4/23/2014		Trade: Pipefitters.
FO-281876	4/17/2014	4/21/2014		Trade: Pipefitters.
FO-281886	4/17/2014	4/23/2014		Fitters,
FO-281965	4/18/2014	4/18/2014		Fitters please repair steam leak at flange near reducing station in PH (located above air compr
FO-281969	4/18/2014			Steam Leak abouve AH#2 on steam supply to air handler coil. Replace gasket at flange befor
FO-282094	4/21/2014			Ahu-3 on the third floor has a chill coil leak and needs repair. High- High Priority. M
FO-282280	4/22/2014	4/23/2014		FITTERS: Please repair coil leak on AHU#9
FO-282298	4/22/2014	4/22/2014		CEILING LEAK HALLWAY BETWEEN 200.04 & 200.05 RC/ 4-22-14 DU
FO-282332	4/22/2014	4/24/2014		Fitters, please repair leak in steam coil on AHU-1. Priority: high JH/ 4-23-14
FO-282389	4/23/2014	4/24/2014		RM 2126.4 CEILING LEAKING BADLY JH/ 4-23-14 DUE ASAPFinished
FO-282439	4/23/2014	4/24/2014		Fitters, please repair leak in steam coil on AHU-2. Priority: high JH/4-23-14
FO-282551	4/25/2014			Trade: Pipefitter
FO-282565	4/25/2014			HALLWAY OUTSIDE RM 2238 CEILING LEAK JH/ 4-25-14 DUE ASAP
FO-282570	4/25/2014			Fitters, please repair leak in steam coil on AHU-2. Priority: highME/ 4-25-14
FO-282591	4/25/2014			Lowered Priority JWT
FO-282600	4/25/2014			Trade: Pipefitter
FO-282616	4/26/2014			Repair leaking heating control valve located above the ceiling in 319. Relatively minor leak bei
FO-282634	4/28/2014			Fitters, please repair steam leak on AHU-1. Priority: high
FO-282635	4/28/2014			Fitters, please repair steam leak on AHU-2. Priority: high
FO-282636	4/28/2014			Fitters, please repair steam leak on AHU-4. Priority: high
FO-282643	4/28/2014			1366 CEILING LEAK, TILE FELL FROM CEILING EA/4-28-14 DUE AS
FO-282656	4/28/2014			Trade: Pipefitters
FO-282671	4/28/2014			Trade: Pipefitter

WO	Recieved	Finished	Total	Request
FO-282697	4/28/2014			STEAM LEAK NEAR BAY DOOR/ROCKS
T - Plumber			69	
FO-280135	4/1/2014	4/14/2014		Trade: Plumbers
FO-280556	4/1/2014	4/1/2014	4/29/2014	Please repair leaking tank on toilet in master bath . Per Mrs.Wison,,,,,,,,,,,,, MP/DB 4-1-14 ,,,,
FO-280146	4/1/2014	4/2/2014		R/R RM 108/MENS RR HANDICAP STALL TOILET IS LKNG FROM BOTTOM (BAG IS OVE
FO-280162	4/1/2014	4/9/2014		Room 212.15 (inside suite 206): sink drips/leaks - cannot be entirely shut off. Please repair.,,,,
FO-280154	4/1/2014	4/2/2014		TOILET NOT FLUSHING. DEANS OFFICE. ROOM 441,,,,,,,,,,,,, RB/ 4-2-14 ,,,,,,,,,, D
FO-280528	4/2/2014	4/8/2014		(**) P.O. Req DK
FO-280538	4/2/2014	4/2/2014		repair leaking back flow preventer for hot water heating make up water.....DB...4-2-13 Finishe
FO-280557	4/2/2014	4/4/2014		R/R RM 398/MENS RR HANDICAP STALL TOILET WILL NOT STOP FLUSHING ,,,,,,,,,,
FO-280564	4/2/2014	4/7/2014		** Priority Lowered / Work in Progress JWT
FO-280597	4/3/2014	4/22/2014		PLUMBERS,
FO-280619	4/3/2014	4/7/2014		FLOOR DRAINS SLOWLY. ROOM 0235,,,,,,,,,,,,, MM/ 4-3-14 ,,,,,,,,,, DUE 4-5-14 Finish
FO-280635	4/3/2014			Men's restroom has urinal (middle) that is not flushing. Room 2111. Please help. ,,,,,,,,,, M
FO-280676	4/3/2014			RM 0354 - GRAD STUDENT INSIDE SAYS ONLY SINK IS BADLY PLUGGED UP
FO-280685	4/3/2014	4/4/2014		4TH FL MENS RM STALL BAGGED, TOILET CLOGGED ,,,,,,,,,, RB / 4-3-14 ,,,,,,,,,, D
FO-280768	4/4/2014	4/4/2014		Walk through to check bathrooms ,,,,,,,,,, RB/ 4-4-14 ,,,,,,,,,, DUE ASAP Finished 4/7/201
FO-280807	4/7/2014	4/8/2014		**Duplicate work order / Refer to FO#280800 JWT
FO-280853	4/7/2014	4/8/2014		2nd Floor - Men's Restroom - Urinal flushes and
FO-280872	4/7/2014	4/7/2014		**Building Coordinator to notify Pipe Shop when active JWT
FO-280878	4/7/2014	4/7/2014		The faucet in room 2329 at Karmanos runs constantly. Cannot shut it off.,,,,,,,,,, DB/ 4-7-1
FO-280959	4/8/2014	4/10/2014		PIPE LEAKING BEHIND TOILET. LADIES RESTROOM. ROOM 1234. SMALL STALL.,,,,,,
FO-280976	4/8/2014	4/8/2014		**Duplicate / Refer to FO280999 JWT
FO-280984	4/8/2014	4/14/2014		1ST FL MENS RM 2ND STALL NOT FLUSHING ,,,,,,,,,, RB/ 4-8-14 ,,,,,,,,,, DUE 4-10-14
FO-280990	4/8/2014	4/10/2014		NO WATER FROM FAUCET. NO BATTERY 3RD FLOOR MEN'S RESTROOM.,,,,,,,,,, M
FO-280992	4/8/2014	4/9/2014		Water fountain is not working. Show opens Friday 4/11. Please repair as soon as possible.,,,,
FO-281025	4/8/2014	4/11/2014		Basement - Women's Rest Room
FO-281095	4/9/2014	4/9/2014		2cnd floor mens room urinal continually flushing/marked priority high because the water is ove
FO-281117	4/9/2014	4/10/2014		Left-hand toilet out of order (currently NO WORKING TOILETS in this restroom),,,,,,,,,, M
FO-281144	4/9/2014	4/14/2014		1ST FL 3rd STALL TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,, MM / 4-10-14 ,,,,,,,,,,
FO-281293	4/10/2014	4/14/2014		There is water leaking from the ceiling of room 2520 / Leak located in room 3528 coming from
FO-281302	4/10/2014	4/11/2014		**Refer to FO#282708 for repairs JWT
FO-281365	4/11/2014	4/11/2014		MARGHERIO; MENS RM 125 URINAL RUNNING OVER ,,,,,,,,,, MM/ 4-11-14 ,,,,,,,,,,
FO-281421	4/14/2014	4/15/2014		LEAK ON LINE SERVICING DRINKING FOUNTAIN. (OUTSIDE OF ROOM 120) ,,,,,,,,,,
FO-281559	4/14/2014			INSIDE RM 1520 UNISEX BATH RM ONLY TOILET ISN'T FLUSHING ,,,,,,,,,, RB/ 4-16-14
FO-281713	4/15/2014	4/17/2014		Room 3250 has half of the faucets leaking (approximately four); there is a bad drip. Thanks.,,,,
FO-281748	4/16/2014	4/16/2014		3RD FL WOMENS RM 3 TOILETS BAGGED HANDICAP OVERFLOWING ,,,,,,,,,, RB/ 4-1
FO-281767	4/16/2014	4/16/2014		** Refer to Vendor work order FO#278984 JWT
FO-281770	4/16/2014	4/16/2014		Both Vacuum pumps need a new 3/4" Solenoid to be installed just before the water flow switc
FO-281785	4/16/2014	4/23/2014		(**) P.O. Req DK
FO-281802	4/16/2014	4/23/2014		Ceiling leak above ceiling tile near mens room on 5th floor near room 5114. Fix leak, replace t
FO-281808	4/16/2014	4/17/2014		TOILET DRAINS SLOWLY. WOMEN'S RESTROOM. ROOM 1378. ,,,,,,,,,,MM/ 4-16-14 ,,
FO-281828	4/17/2014	4/17/2014		please r&r 2nd floor drinkning fountain drain line leaking on floor below.....MP/DB...4-17-14
FO-281847	4/17/2014	4/22/2014		Low water pressure from both hot and cold water faucets in this bathroom (the one by the stair
FO-281862	4/17/2014	4/17/2014		Please repaiir sink/drain in mens locker room overflowing and wont stop running....MM/...4-17-
FO-281942	4/18/2014	4/21/2014		3rd floor handicap ladies room toilet will not stop running. ,,,,,,,,,, MM/ 4-18-14 ,,,,,,,,,, D
FO-281947	4/18/2014			Trade: Plumbers

WO	Recieved	Finished	Total	Request
FO-281948	4/18/2014			SINK CRACKED. ROOM 2131. ,,,,,,,,,, MP/DB 4-18-14 ,,,,,,,,,, DUE ASAP
FO-281949	4/18/2014	4/23/2014		TOILET CONTINUOUSLY FLUSHING AND SPRAYING WATER ON FLOOR. 5TH FLOOR LA
FO-281957	4/18/2014			NO HOT WATER. ROOM 205.,,,,,,,,,, MM/ 4-18-14 ,,,,,,,,,, DUE ASAP
FO-281978	4/19/2014	4/21/2014		please unclog lav sink room 1238, this is the 24hour area and its the only mens room. ,,,,,,,,,,
FO-281994	4/21/2014	4/22/2014		PLUMBERS,
FO-282035	4/21/2014	4/23/2014		TOILET CONTINUOUSLY FLUSHING. ROOM 2022. ,,,,,,,,,, MP/DB 4-21-14 ,,,,,,,,,, D
FO-282051	4/21/2014	4/26/2014		3RD FL MENS RM ACROSS FROM RM 3105 TOILET RUNNING ,,,,,,,,,, MP/DB 4-25-14 ,,,
FO-282103	4/21/2014	4/26/2014		10TH FL MENS RM MIDDLE STALL TOILET LEAKING AROUND BASE ,,,,,,,,,, MP/DB 4-2
FO-282121	4/21/2014	4/24/2014		Two sinks in the early childhood center are not
FO-282124	4/21/2014	4/23/2014		7TH FL MENS RM GRADUATE AREA TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,, MP/
FO-282353	4/22/2014	4/23/2014		**Refer to FO#282352 JWT
FO-282358	4/22/2014			TOILETS LEAKING AT BOTTOM. LADIES RESTROOM. ROOM 1378,,,,,,,,,,,,, MM/ 4-23-14
FO-282429	4/23/2014			ADDING PLUM
FO-282481	4/24/2014	4/24/2014		1ST FL UNISEX RESTROOM FAUCET LOOSE, CUSTODIAN BELIEVES SOMEONE IS TRY
FO-282550	4/25/2014			MAIN FL NEAR HANDICAP STALL WATER FOUNTAIN CONTINUOUSLY RUNNING ,,,,,,,,,,
FO-282556	4/25/2014			MENS RM 3RD & 4TH FL WOMENS RM 4TH FL ALL SEEM TO RUN OVER AFTER BEING
FO-282603	4/25/2014			We are still getting complaints about the hot water in this building. Currently it's coming out at
FO-282665	4/28/2014			7TH FL MENS RM URINALS NOT FLUSHING ,,,,,,,,,, RB/4-28-14 ,,,,,,,,,, DUE ASAP
FO-282666	4/28/2014			2ND FL WATER FOUNTAIN, WATER COMES OUT BROWNISH COLOR
FO-282686	4/28/2014			Lowered to High / To Return 4-30-14 9:00 AM JWT
FO-282822	4/29/2014			RM 8255 HOT WATER NOT WORKING ,,,,,,,,,, RB/ 4-29-14 ,,,,,,,,,, DUE 5-1-14
FO-282823	4/29/2014			R/R RM 382/JANITOR'S CLOSET SLOP SINK COLD WTR FAUCET WILL NOT SHUTR-OFF
FO-282824	4/29/2014			RM 9204 DRAIN CLOGGED ,,,,,,,,,, RB/ 4-29-14 ,,,,,,,,,, DUE 5-1-14
FO-282836	4/29/2014			Trade: Plumbers
T - Roofing			8	
FO-280670	4/3/2014	4/4/2014		3RD FL CEILING LEAK OUTSIDE 3129 & 3109. REPAIRS MADE. 4-4-14. TAH
FO-280679	4/3/2014	4/4/2014		ROOF LEAK INSIDE RM 413 CAUSING IT TO LEAK INSIDE ELEV. ENG SHAH INVESTIGA
FO-281055	4/8/2014	4/17/2014		There is a leak above the doorway. Please not this is a separate leak from what was called in
FO-281698	4/15/2014	4/16/2014		R/R RM 9105 REPAIR ROOF APPEARS TO BE COMING FROM ROOF DRAIN IN UPPER
FO-281701	4/15/2014			ADDING CARP:
FO-281742	4/15/2014	4/28/2014		RUSH-URGENT-REQUEST
FO-282814	4/29/2014			RM 5625 CEILING LEAK, FLASHING LEAK SEE TONY CRAWLEY
FO-282827	4/29/2014			Roofing High Priority
T - Sheetmetal			1	
FO-280117	4/1/2014			Trade: SheetmetalPriority: HighR/R 2ND FLR Numerous complaints the fume hoods do
Medium			181	
T - Carpenter			43	
FO-280493	4/2/2014	4/3/2014		CARPENTERS: Please repair inner entrance door near guard desk. Door closer torn off frame
FO-280508	4/2/2014	4/4/2014		Carpenter; Medium
FO-280540	4/2/2014	4/3/2014		2ND FL DOOR TO THE RIGHT OF ELEV, DOOR CLOSURE BROKEN. NO DOOR NUMBER
FO-280638	4/3/2014	4/4/2014		Blind is falling down at one end from the window.. Finished 4/7/2014LT
FO-280728	4/4/2014	4/7/2014		Door closer is not working repair or replace. Finished 4/9/2014LT
FO-280780	4/4/2014	4/9/2014		SIGN OUTSIDE AT THE SIDE DOOR IS FALLING OFF. YELLOW SCHOOL OF BUSINESS
FO-280781	4/4/2014	4/8/2014		Replace two ceiling tiles in WDET Music Library damaged from water leaking from apartment
FO-280847	4/7/2014	4/23/2014		MAIN LOUNGE, WINDOW SHADE CHAIN BROKEN Finished 4/23/2014LT
FO-280993	4/8/2014	4/9/2014		Carpenters Med. Priority
FO-281000	4/8/2014	4/10/2014		RM 100 DOOR SQUEAKS VERY LOUDLY. DOOR IN BACK CLOSEST TO MONITOR. Finis
FO-281015	4/8/2014	4/9/2014		Room 2248 - MD Lab - Door handle is very hard to turn and open, please fix. Finished 4/11/20

WO	Recieved	Finished	Total	Request
FO-281027	4/8/2014			CARPENTERS: Please replace bad floor tiles in room 4240. Trip/ Safety MED.
FO-281024	4/8/2014	4/9/2014		2. First stall door handle broken off Finished 4/11/2014LT
FO-281053	4/8/2014	4/23/2014		Vent in door is missing a piece of quarter round and loose, eventually will fall out of the door.
FO-281161	4/9/2014	4/10/2014		INTERIOR DOOR ADJACENT TO DOOR 027-6W DOOR REMAINS AJAR. Finished 4/11/201
FO-281301	4/10/2014			Adding Carpenter: Please provide access in wall next to drinking fountain on 1st floor near 15
FO-281305	4/10/2014	4/25/2014		Please mount posting board in Pipe Shop. See John for location Finished 4/29/2014LT
FO-281320	4/11/2014	4/16/2014		Carpenters-Please rebuild ceiling in hallway near room 402.*Medium Priority* Finished 4/18/20
FO-281408	4/12/2014			Repair wall from pluming repair in room 14200. Also fire ext cabinet back needs repair near el
FO-281411	4/12/2014			**Adding Carpenter: Repair block wall or cover hole in machine shop where new utility sink is t
FO-281439	4/14/2014			Carpenter build support under duct for AH-1 exhaust under energy recovery coil so engineer c
FO-281642	4/14/2014	4/16/2014		Matthaei
FO-281731	4/15/2014	4/16/2014		CARPENTERS,
FO-281782	4/16/2014	4/18/2014		The rolling door that separates the Hyge sled lab (1100) and the Instron lab (1139) needs to b
FO-281819	4/17/2014	4/23/2014		Please replace ceiling tiles in Rms 2609 & 2627. Finished 4/23/2014LT
FO-281848	4/17/2014	4/23/2014		CARPENTER PLEASE REPLACE WATER DAMAGE CEILING TILE ROOM 489
FO-281849	4/17/2014	4/23/2014		CARPENTER PLEASE REPLACE WATER DAMAGE CEILING TILE OUTSIDE OF ROOM
FO-281865	4/17/2014	4/29/2014		ADDING CARP: R/R 1ST FLR LADIES RM REPLACE DAMAGED CLNG TILES DUE TO TH
FO-281966	4/18/2014	4/24/2014		Replace stained ceiling tiles room 2208 and 2148Finished 4/25/2014
FO-281974	4/19/2014	4/24/2014		Please repair broken glass – Main entrance, Door 080-04S
FO-282015	4/21/2014	4/22/2014		FRONT DOORS 096-01E,096-02E,096-03E,096-04E NOT CLOSING TIGHTLY Finished 4/23/
FO-282017	4/21/2014	4/22/2014		EMPLOYEE ENTRANCE 096-26N DOOR NOT CLOSING TIGHTLY. Finished 4/23/2014LT
FO-282052	4/21/2014	4/22/2014		Continuous-hinged loading dock door 026-12NB scrapes door frame; keeps it from securing s
FO-282074	4/21/2014	4/24/2014		Carpenters-please remove ceiling grid for heat pump replacement by room 409-medium priorit
FO-282075	4/21/2014	4/24/2014		Carpenters-please remove ceiling grid for heat pump replacement by room 410-medium priorit
FO-282076	4/21/2014	4/24/2014		Carpenters-please remove ceiling grid for heat pump replacement by room 427-medium priorit
FO-282433	4/23/2014			Carpenter; Medium
FO-282454	4/24/2014	4/24/2014		lock stickingFinished 4/25/2014
FO-282561	4/25/2014			CARPENTERS:R/R ROOF Please install 2 Cooling Tower Platforms on roof towers at Phar
FO-282581	4/25/2014			Please replace missing floor tiles in the hallway adjacent to room 3087.2
FO-282670	4/28/2014			Carpenters please replace damaged ceiling tile Stairwell is located in hallway from cass entra
FO-282820	4/29/2014			Trade: CARP Priority: MediumR/R 3RD FLR Water is leaking in at Window Wall of the EDC
FO-282835	4/29/2014			Purdy Library, 4th Floor, Room 426 (corner office).
T - Electrician			39	
FO-280188	4/2/2014			Continuous issues with intermittent trouble alarms. Ground fault,
FO-280513	4/2/2014	4/7/2014		Electrician; Medium
FO-280773	4/4/2014	4/7/2014		Work Order # FO-278225 was reported incorrectly. The AC unit is fine it's the electrical outlet t
FO-280782	4/4/2014	4/21/2014		WDET Music Library ceiling light is not working due to water leak. (The leak has been fixed by
FO-280821	4/7/2014	4/7/2014		LAMP ON PROJECTOR NEEDS TO BE REPLACED. RM OPEN: M&W 12-4:30 Tues,Th,Fri
FO-280960	4/8/2014	4/10/2014		HANDLE HAS COME OFF HAND DRYER. LADIES RESTROOM. ROOM 1238. (24 HR. ST
FO-281026	4/8/2014	4/9/2014		electricans, repair or replace TORK timer for the north security outside light. priority medium
FO-281033	4/8/2014			Relamp all Mall Lights.
FO-281059	4/8/2014	4/9/2014		Three Rows of lights are out, we think it may be linked to the water leak. Also the light switch i
FO-281058	4/8/2014			The aluminum frame around the light fixture is not screwed into the ceiling. It is hanging. Plea
FO-281084	4/9/2014	4/10/2014		HV-1 VFD Fault
FO-281175	4/9/2014	4/10/2014		RM 385 WALL CLOCK TIME IS OFF Finished 4/11/2014LT
FO-281216	4/10/2014	4/15/2014		Cover plate needed for electrical outlet. Thank you, Susan Finished 4/16/2014LT
FO-281286	4/10/2014	4/28/2014		Investigate and correct cause of pump 20 tripping on overload(s) Finished 4/29/2014LT

WO	Recieved	Finished	Total	Request
FO-281332	4/11/2014	4/11/2014		ELECTRICIANS
FO-281511	4/14/2014	4/21/2014		Build scaffold in room 1545 Friday morning first thing, and remove it when lights are complete
FO-281546	4/14/2014	4/17/2014		Investigate and correct cause of med vac intermittant operation Finished 4/18/2014LT
FO-281684	4/15/2014	4/23/2014		ballast bad , light over MCC-1, can't see panel Finished 4/23/2014LT
FO-281686	4/15/2014	4/28/2014		ahu 2 vfd drive fault condition
FO-281689	4/15/2014	4/15/2014		ELECTRICIANS
FO-281692	4/15/2014	4/15/2014		Time for Generator to be serviced by Wolverine Power. Finished 4/16/2014LT
FO-281724	4/15/2014	4/18/2014		Trade: Electrician
FO-281729	4/15/2014	4/18/2014		electrician
FO-281813	4/16/2014	4/18/2014		Trade: Electricians
FO-281821	4/17/2014			Pick-up pole that was knocked down, make safe, and try to replace.
FO-281905	4/18/2014	4/17/2014		Time for Utilities Instrumentation to PM #2 Breaker for the transfer switch. Finished 4/18/2014
FO-281971	4/18/2014	4/21/2014		**Adding Electrician: Check heating elements on hot water tank rm 1349. See Mike McAlinden
FO-281988	4/20/2014	4/21/2014		Repair fire trouble.
FO-282027	4/21/2014			R/R RM 400.10/MECH RM Electrician heat trace the blow down lines on boiler #3.
FO-282050	4/21/2014	4/23/2014		Trade: Electricians
FO-282053	4/21/2014	4/22/2014		Laborer (Electrician); Please deliver 3 heat pumps to Thompson House. AC crew will assist at
FO-282435	4/23/2014	4/24/2014		**Adding Electrician: Rewire condensate pump #1 in basement mechanical room. See Ron Cl
FO-282436	4/23/2014	4/24/2014		**Adding Electrician: Dewire only one of the condensate pumps in basement mechanical room
FO-282448	4/24/2014	4/25/2014		Lights are out in parking booth. (Not the parking structure office)
FO-282586	4/25/2014	4/29/2014		Electricians:
FO-282797	4/29/2014			ELECTRICIANR/R RM 00051/MECH RM PLEASE REPAIR OR REPLACE FAULTY LIGHT
FO-282829	4/29/2014			Please have Maintenance Laborer deliver copier located outside Stockroom window to Dave K
FO-282857	4/29/2014			Trade: Laborer
FO-282879	4/29/2014			RE: Law Library
T - Laborer			1	
FO-282612	4/25/2014			Adding Laborer: Insulate exposed domestic water lines from plumbing repair in garage. See M
T - Locksmith			1	
FO-280710	4/4/2014			Replace broken OE31 key for Aubrey Waller.
T - Painter			2	
FO-281056	4/8/2014	4/16/2014		Paint is peeling and chipping in classroom. Finished 4/18/2014LT
FO-282669	4/28/2014			PAINTERS please replace damaged ceiling tile and paint/repair minor water damage on wall i
T - Pipefitter			36	
FO-280073	4/1/2014	4/2/2014		Pipefitters: R/R leaking steam heating coils AHU-1 ,,,,,,,,,,,,,, JH/4-2-14 ,,,,,,,,,,,,,, DUE 4-15-
FO-280496	4/2/2014	4/8/2014		Fitters, please repair leak in steam coil on AHU-1. ,,,,,,,,,,,,,, ME/ 4-3-14 ,,,,,,,,,,,,,, DUE 4-4-14
FO-280518	4/2/2014			(**) P.O. Req DK
FO-280601	4/3/2014	4/14/2014		PIPEFITTERS PLEASE REPLACE ALL ELBOW AND OTHER PIPING TO BOTH ABSORBE
FO-280620	4/3/2014	4/10/2014		please have pipefitters repair mounting bracket for return fan-4 the outer and inner nuts are w
FO-280714	4/4/2014			Trade: Pipefitter Priority: Medium
FO-280758	4/4/2014			Trade: Pipefitters
FO-280869	4/7/2014			PIPEFITTERS,
FO-281003	4/8/2014			Pipefitters: MED HIGH Priority
FO-281191	4/9/2014	4/10/2014		** Dave Kuffner sending to Vendor JWT 4-10-14
FO-281261	4/10/2014			Condensate pump #1 has defective check valve and condensate pump #2 has broken seal an
FO-281333	4/11/2014	4/15/2014		PIPEFITTER
FO-281386	4/11/2014	4/21/2014		FITTERS:
FO-281524	4/14/2014			PIPEFITTERS,
FO-281676	4/15/2014	4/16/2014		**This is a Departmental Repair JWT

WO	Recieved	Finished	Total	Request
FO-281716	4/15/2014	4/17/2014		FITTERS: Please install check valves in the three chemical lines on D.A. TANK. MED.,,,,,,,,,,
FO-281904	4/18/2014	4/18/2014		Please replace leaking control valve in rm 0215.,,,,,,,,,, JH/4-18-14 ,,,,,,,,,, DUE 5-1-14
FO-281964	4/18/2014	4/24/2014		R/R steam valve 5th floor mechanical room ,,,,,,,,,, JH/ 4-18-14 ,,,,,,,,,, DUE 5-2-14Finis
FO-282008	4/21/2014			fitters: please replace bearing assembly on unit #13 leaking bad mechanical room 253 ,,,,,,,,,,
FO-282009	4/21/2014	4/24/2014		Fitter repair steam leak in unit heater #2. ,,,,,,,,,, ME/ 4-21-14 ,,,,,,,,,, DUE 5-5-14Finishe
FO-282036	4/21/2014			FITTERS: Please repair coil leak on AHU#8
FO-282097	4/21/2014	4/23/2014		Fitters please repair leaky chill water valve on AHU-3 in room PH.,,,,,,,,,, ME/4-23-14 ,,,,,,,,,,
FO-282098	4/21/2014			Fitters please replace/repair water regulating valve in PH. Valve is located above chilled water
FO-282313	4/22/2014			R/R RM 114 RERHEAT LEAKING FOR VAV We have a leak in room 114. The engineer has I
FO-282307	4/22/2014			ELECTRICIAN
FO-282373	4/23/2014			replace frozen 3/4 polly valve into
FO-282425	4/23/2014			AHU-3 has a plugged heating coil and leaking isolation valves. Please repair or replace coil, a
FO-282430	4/23/2014			ADDING PIPE
FO-282447	4/24/2014			Packing is leaking on 8" control valve on fire protection system (inside boiler rm)
FO-282470	4/24/2014			PIPEFITTERS please r/r dripping condensate line in room 124. condensate line appears to be
FO-282482	4/24/2014			CEILING LEAK (TILES WET). WOMEN'S RESTROOM. ROOM 502.,,,,,,,,,, ME/4-25-14 ,,,
FO-282553	4/25/2014			FITTERS: Please repair / replace heating valve in room 0540 NORTH VAV. MED. ,,,,,,,,,,
FO-282590	4/25/2014			Pipe fitter; Medium
FO-282657	4/28/2014			Trade: Pipefitters
FO-282930	4/28/2014			Repair 2ed leak from ceiling in hallway near room 2301 ,,,,,,,,,, EA/4-28-14 ,,,,,,,,,, DUE
FO-282682	4/28/2014			R/R cracked return condensor water valves on roof.,,,,,,,,,, ME/4-28-14 ,,,,,,,,,, DUE 5-1
T - Plumber			54	
FO-280074	4/1/2014			Plumbers: Please disconnect water softener water supply remove softener off deteriorating st
FO-280079	4/1/2014			Plumbing: Please install emergency eye wash station next to chemical feed station located in
FO-280127	4/1/2014	4/2/2014		BASEMENT MEN'S RESTROOM TOILET LEAKING FROM PIPE. ,,,,,,,,,, MP/DB 4-2-14 ,,,,
FO-280139	4/1/2014	4/1/2014	4/29/2014	*Duplicate Work Order JWT
FO-280483	4/2/2014	4/2/2014		**Duplicate Work Order JWT
FO-280517	4/2/2014	4/8/2014		Plumber; Medium
FO-280622	4/3/2014			Plump Med. Priority
FO-280623	4/3/2014	4/7/2014		plumb Med. Priority
FO-280628	4/3/2014	4/15/2014		TOILET WON'T FLUSH. 2ND FLOOR LADIES ROOM INSIDE LOCKER ROOM.,,,,,,,,,, M
FO-280706	4/4/2014			Trade: Plumber Priority: MediumR/R RK 4116/PENTHOUSE Please clear floor drain it is plu
FO-280784	4/4/2014			3rd floor ladies restroom has a broken toilet seat in the handicapped stahl.
FO-280787	4/6/2014			Repair leaks in 1/2 inch copper water line serving the hose bibb near outside exit door 078 08
FO-280822	4/7/2014	4/10/2014		Restroom 210: sink works intermittently, replace battery in faucet.,,,,,,,,,, MM/4-8-14 ,,,,,,,,,,
FO-280842	4/7/2014	4/7/2014		*Duplicate work Order JWT
FO-280857	4/7/2014	4/9/2014		R/R 2ND FLR MENS RR 2 OUT OF 3 SINK FAUCETS AREN'T WORKING NO RUNNING W
FO-280888	4/7/2014	4/10/2014		Men's restroom: right-hand stall is out of order. Toilet is bagged to prevent use.,,,,,,,,,, MM/4-
FO-280957	4/8/2014	4/9/2014		The water fountain control button does not work, The
FO-280983	4/8/2014	4/14/2014		1ST FL LADIES RM TOILET SEAT BROKEN OFF FAR STALL ,,,,,,,,,, RB/ 4-8-14 ,,,,,,,,,,
FO-280994	4/8/2014	4/10/2014		MENS RM 2238 LEAK BEHIND TOILET ,,,,,,,,,, RB/ 4-8-14 ,,,,,,,,,, DUE 4-22-14 Finishe
FO-281129	4/9/2014			** This FO# is for processing payment for service provided from FO#267326. P.O. was never
FO-281134	4/9/2014			R/R BSMT MENS RR URINAL (BAGGED) IS STOPPED UP ,,,,,,,,,, MP/DB 4-10-14 ,,,,,,,,,,
FO-281143	4/9/2014			WOMENS RM LEFT STALL, TOILET RUNS TOO LONG ,,,,,,,,,, RB / 4-10-14 ,,,,,,,,,, DU
FO-281197	4/10/2014	4/16/2014		PLUMBERS
FO-281270	4/10/2014	4/15/2014		PIPE LEAKING AT FLUSH HANDLE. ROOM 2238.,,,,,,,,,, MM/ 4-10-14 ,,,,,,,,,, DUE 4-2
FO-281285	4/10/2014			Plumber; Medium

WO	Recieved	Finished	Total	Request
FO-281356	4/11/2014	4/15/2014		Faucet stopped working - replace battery?,,,,,,,,,,,,, MM/ 4-14-14 ,,,,,,,,,,,,,, DUE 4-25-14 Fini
FO-281357	4/11/2014	4/15/2014		Toilet seat is loose - please tighten,,,,,,,,,,,,, MM/ 4-14-14 ,,,,,,,,,,,,,, DUE 4-25-14 Finished 4/1
FO-281466	4/14/2014			R/R RM 3101 REPLACE DIAPHRAM ON TOILET CONTINUOUSLY FLUSHING. ROOM 3101.
FO-281654	4/15/2014	4/17/2014		Trade Plummers,Priority medium
FO-281655	4/15/2014	4/15/2014		**Duplicate Work Order /Refer to FO#281745 JWT
FO-281667	4/15/2014			Plumbers: \
FO-281745	4/16/2014			Backflow preventer in the boiler rm leaking,,,,,,,,,,,,,DB/ 4-16-14 ,,,,,,,,,,,,,, DUE 4-29-14
FO-281815	4/16/2014			LOW WATER PRESSURE. ROOM 1200.
FO-281824	4/17/2014			Trade: Plumber Priority: Medium
FO-281841	4/17/2014			HOT WATER IS WARM. 1ST FLOOR EMPLOYEE LOUNGE. ROOM 1349,,,,,,,,,,,,, MM/ 4-
FO-281865	4/17/2014	4/29/2014		ADDING CARP: R/R 1ST FLR LADIES RM REPLACE DAMAGED CLNG TILES DUE TO TH
FO-281916	4/18/2014	4/18/2014		**Duplicate / Refer to FO#282481 JWT
FO-281943	4/18/2014	4/23/2014		MEN'S RESTROOM 12TH FLOOR THE SINK IS CLOGGED. DEBRIS COMING OUT OF DR
FO-281967	4/18/2014			R/R #2 booster pump / check tank fill for obstruction ,,,,,,,,,,,,,, RB/ 4-18-14 ,,,,,,,,,,,,,, DUE 5-2
FO-281973	4/19/2014			Please unplug floor drain in penthouse near chilled water pumps.
FO-281979	4/19/2014			Repair sanitary pit sump pump. One pump is out of service and the cover is out of place. Odor
FO-282039	4/21/2014	4/24/2014		Plumbers:
FO-282040	4/21/2014			Plumbers:
FO-282071	4/21/2014	4/26/2014		TOILET CONTINUOUSLY FLUSHING. 4TH FLOOR LADIES RESTROOM. HANDICAP STAL
FO-282321	4/22/2014			R/R 7TH FLR SOUTHEND NEAR RM 7802 UNISEX RR ONLY TOILET CONSTANTLY RUN
FO-282312	4/22/2014	4/24/2014		TOILET CONTINUOUSLY FLUSHING. CONFERENCE ROOM 3301,,,,,,,,,,,,, MP/DB 4-22-1
FO-282354	4/22/2014			Plumbers -- 1st floor women's restroom water leaking into stall
FO-282399	4/23/2014			Restroom 210: toilet seat is loose, and toilet appears to be detaching from wall,,,,,,,,,,,,,
FO-282544	4/25/2014			trade plummers,priority meduim,
FO-282608	4/25/2014			R/R RM 3390/WOMENS RR 1ST STALL TOILET IS LKNG @ FLUSH HANDLE
FO-282620	4/25/2014			R/R 1ST FLR Ladies rest room across R0129 has a ceiling leak.
FO-282624	4/26/2014			PLUMBERSR/R RM 108/WOMENS LOCKER RM Please replace or repair sloan valve in mi
FO-282629	4/27/2014			PLUMBERS,R/R RM 0100/MECH RM PLEASE REPAIR FLANGE LEAK ON DOMESTIC H
FO-282689	4/28/2014			R/R RM 440/LAB SINK ACROSS FROM FUMEHOOD #2 IS PLUGGED NEED TO BE CLEAR
T - Roofing			5	
FO-280660	4/3/2014	4/4/2014		ROOF LEAK. HALLWAY OUTSIDE OF ROOM 3141. ROOFER SCHEDULED. 4-4-14. TAH.
FO-280698	4/3/2014			Please check on roof leak in rooms 337, and 359, this is for work orders, 280672 and 2806
FO-281409	4/12/2014	4/12/2014		**Engineering to repair Humidifier JWT
FO-281771	4/16/2014			Roofers: please repair roof leak in room 238. priority: med. AL IDENTIFIED THAT IT IS A RO
FO-282838	4/29/2014			NEAR RM 335 ON THE PORCH CEILING LEAK
Low			521	
T - Carpenter			78	
FO-280069	4/1/2014	4/1/2014	4/29/2014	PLEASE INSTALL COAT RACK. SERVICE CENTER.. Finished 4/7/2014LT
FO-280072	4/1/2014	4/16/2014		R/R RM 150/AD-SVC CTR OFC PUNCH LIST FOR MOVE JOB FROM OLD SVC CTR TO N
FO-280090	4/1/2014	4/4/2014		Please have Carpenters cut long wooden pallet (approx. 12 feet) into 4 foot sections. Pallet is
FO-280105	4/1/2014	4/3/2014		State Hall 1st floor Outside handi-cap door 016-14-W is Malfunctioning - near ladies room 102
FO-280131	4/1/2014	4/7/2014		1st floor rubber stripping need to be replaced on carpet in front of public elevator. Finished 4/9
FO-280143	4/1/2014	4/7/2014		Loose heat grate near the front door. This area is part of the inauguration.
FO-280490	4/2/2014	4/7/2014		R/R RM 110 Please note broken door closure at the Football Stadium (Building)....Room 110
FO-280491	4/2/2014	4/7/2014		R/R 1ST FLR Please note broken door closure at the Football Stadium (Building)....the Room
FO-280502	4/2/2014	4/7/2014		one ceiling tile replacement needed in the copy/workroom, 1st floor, room 1159.2. Finished 4/
FO-280558	4/2/2014	4/4/2014		Lab #1360 the door gets stuck and cannot open with a key, after rotating clockwise and count
FO-280554	4/2/2014			Locksmith training for Jeff Hammell. For the month of April

WO	Recieved	Finished	Total	Request
FO-280627	4/3/2014	4/4/2014		SECURE CLOCK TOWER ACCESS PANEL.. Finished 4/7/2014LT
FO-280659	4/3/2014			KEYS & CORES (APRIL 2014)
FO-280662	4/3/2014	4/7/2014		TEAM LEADER TIME (APRIL 2014) Finished 4/9/2014LT
FO-280664	4/3/2014	4/3/2014		CARPENTERS SAFETY MEETING (APRIL 2014). Finished 4/7/2014LT
FO-280712	4/4/2014	4/7/2014		R/R RM 00012.10/Boiler Room @ matthaei - Outside door handle needs repair across from th
FO-280719	4/4/2014	4/8/2014		R/R RM 309 RE-ATTACH The sign for Rm 309 has come loose from the
FO-280742	4/4/2014	4/8/2014		CARPENTERS,
FO-280850	4/7/2014	4/7/2014		The main entrance, the handicap button fell off to open the main front door. Finished 4/9/2014
FO-280849	4/7/2014	4/7/2014		REPAIR CLOSER UNISEX BATHROOM 1ST FLOOR Finished 4/9/2014LT
FO-280852	4/7/2014			CARPENTERS TO REPAIR FIRE SAFETY LANE 2ND FLOOR OUTSIDE PIPE SHOP (SAF
FO-280977	4/8/2014	4/9/2014		Kresge Library, 1st Floor Entrance
FO-281243	4/8/2014	4/11/2014		Door will not latch. Finished 4/16/2014LT
FO-281098	4/9/2014	4/10/2014		WALL BORDER HAS COME OFF WALL - 1ST FLOOR HALLWAY NEAR ROOM 169. Finish
FO-281120	4/9/2014	4/23/2014		CAP-3 EXTRA- R/R FLOOR TILE IN ROOM 315. LIGHT COLOR TILE LIFTING. REQUESTED
FO-281127	4/9/2014	4/11/2014		R/R RM 301 REPAIR & RE-ALIGN WINDOW FRAME & LATCH One of the curved storm wind
FO-281138	4/9/2014			R/R RM 150/AUD RE-HANG FLAGS THAT HAVE FALLEN FROM THE WALLS ALSO PLS C
FO-281141	4/9/2014			R/R RM 150.80 The door that leads from the spectator seats to the pool balcony will not unloc
FO-281147	4/9/2014	4/9/2014		R/R ENT DOOR #080-B-2N Outside boiler room door will not unlock...Door # 080 B 2N
FO-281146	4/9/2014	4/9/2014		CARPENTER TO RELOCATE BOILER PUMP SHELF BOILER ROOM Finished 4/11/2014LT
FO-281255	4/9/2014	4/10/2014		The room is actually an employee lounge. The door will not remain latched when it is locked.
FO-281205	4/10/2014	4/10/2014		CARPENTER TO REPAIR CEILING GRID RIGHT SIDE OF THE ROOM LECTURE HALL #1
FO-281229	4/10/2014			Carpenters, please build scaffolding outside cooling tower for access to change fan belts.
FO-281278	4/10/2014	4/16/2014		Upper anchor latch on entrance door (small door on left) is broken and wood on door is split.
FO-281280	4/10/2014	4/11/2014		Purdy Library, 4th Floor
FO-281321	4/11/2014	4/16/2014		Carpenters-Please rebuild ceiling in room 001. (computer lab in basement). *Medium Priority*
FO-281400	4/11/2014	4/11/2014		CARPENTERS TO UNLOAD 23 PROJECTION SCREENS TO THE STOCK ROOM Finished
FO-281416	4/12/2014	4/29/2014		Please build a storage / transportation wood box on wheels for pipe machine grouvung head .
FO-281714	4/14/2014	4/16/2014		today's high wind has blown door 085 04W off it's hinges, JUST DO IT, I have already spoken
FO-281482	4/14/2014	4/16/2014		Please cover access hole in wall with plywood . 1st floor last room on Woodward side closest t
FO-281709	4/14/2014	4/16/2014		Electronic lock on door malfunctioning.
FO-281531	4/14/2014	4/25/2014		Room 9105 - Please replace ceiling tile that was damaged and removed due to ceiling leak. Fi
FO-281536	4/14/2014	4/15/2014		CARPENTERS TO DEMO ENCLOSER DUE TO HIGH WINDS Finished 4/16/2014LT
FO-281705	4/14/2014	4/17/2014		Please move and put together the desk that is currently sitting in my office to my lab on the se
FO-282356	4/15/2014	4/24/2014		R/R RM 1300 HAS A BAD CORE
FO-281711	4/15/2014			Room 1233 and 1241 has many white tiles that are cracked and buckling. Please fix. Thanks
FO-281712	4/15/2014	4/16/2014		In State Hall 125 there is an access panel
FO-281752	4/16/2014	4/16/2014		MAKE INSERT FOR FIVE GALLON BUCKET, SO CAP WILL NOT POP OUT. Finished 4/18/
FO-281931	4/16/2014			This request is for Parking Structure # 6 @ 61 Putnam St. Sheet metal is missing off of the w
FO-281829	4/17/2014	4/24/2014		R/R RM 21 (17) Multiple broken chairs in Prentis classrooms 21. Would like to see if they can
FO-281830	4/17/2014	4/18/2014		R/R RM 0123/RES LAB Large Hole in the wall needs to be covered. Room 00123 at Elliman
FO-281833	4/17/2014	4/24/2014		R/R RM 27 (40) Multiple broken chairs in Prentis classroom 27 (40). Would like to see if they
FO-281850	4/17/2014	4/18/2014		CARPENTERS,
FO-281928	4/17/2014	4/21/2014		They are having troubles with locking their door from the inside. (probably for all the times that
FO-281929	4/17/2014	4/17/2014		Door will not unlock. Please open. Finished 4/18/2014LT
FO-281914	4/17/2014	4/21/2014		Cabinet door fell off hinges. Finished 4/22/2014LT
FO-281930	4/18/2014	4/18/2014		Little Asian Markeet the door (104-04 W)won't close properly. Thank you Finished 4/21/2014L
FO-281980	4/19/2014	4/21/2014		Provide access to building via outside door located on South or East side of building so that W

WO	Recieved	Finished	Total	Request
FO-282030	4/21/2014	4/22/2014		The lock on the door is very hard to lock, both inside and out. Thanks
FO-282073	4/21/2014	4/24/2014		Carpenters-please remove ceiling grid for heat pump replacement by room 409Finished 4/25/
FO-282090	4/21/2014	4/22/2014		Please have Carpenters cut in half two long (8') pallets located outside of FP&M stockroom do
FO-282267	4/21/2014	4/24/2014		replace missing ceiling tileFinished 4/25/2014
FO-282310	4/22/2014	4/22/2014		Rooms 0501 through 0515 need door knob adjustment. Please give to Mike Pines I have alre
FO-282322	4/22/2014	4/22/2014		RE-ATTACH THE VISION WALL CAP ON THE NORTH-WEST VISION WALL ON THE ROO
FO-282349	4/22/2014	4/23/2014		R/R RM 2133 ADJUST Window in office is very difficult to open and close. Finished 4/23/2014
FO-282440	4/23/2014	4/24/2014		Please have locksmith check/repair function of Little Asia Mart entrance door, reported that th
FO-282453	4/24/2014	5/24/2014		R/R RM 200.15/DLAR Lock stickingFinished 4/25/2014
FO-282455	4/24/2014	4/24/2014		R/R RM 418/DLAR Lock stickingFinished 4/25/2014
FO-282458	4/24/2014	4/24/2014		R/R RM 413/DLAR Lock stickingFinished 4/25/2014
FO-282450	4/24/2014			Kresge Library, 1st Floor, Near Stair #4
FO-282457	4/24/2014	4/23/2014		CARPENTER TO HANG PLANT & WHITE BOARD Finished 4/23/2014LT
FO-282520	4/24/2014	4/25/2014		R/R RM 0008.10/Main Data Frame (MDF) ADJUST/RE-ALIGN DOOR CLOSUREroom 8.1's d
FO-282545	4/25/2014			CARPENTERS, R/R BSMT PLEASE REPLACE MISSING & WATER DAMAGED CEILING
FO-282571	4/25/2014	4/28/2014		R/R 3RD FLR Door closer on 3rd floor's north stair door needs adjustment so that door will clo
FO-282574	4/25/2014	4/28/2014		R/R 3RD FLR Door closer on 3rd floor's south stair door needs adjustment so that door will clo
FO-282649	4/28/2014	4/29/2014		CARPENTERS,
FO-282690	4/28/2014			R/R BATH RM THAT SVCS' THE LOUNGE The actual space is room 35 and it's the men's/ha
FO-282825	4/29/2014			Purdy Library 1st Floor, Main EntranceR/R BLDG Interior Handicap door 026 01S - hinge is
T - Electrician			184	
FO-280080	4/1/2014	4/2/2014		R/R RM 0013/MECH RM DELIVER Boiler Chemical Supplies Please supply:
FO-280102	4/1/2014	4/9/2014		3 EP's on 4th floor :
FO-280109	4/1/2014	4/4/2014		2 Celing Panels are out (4 lights bulbs in each panel)
FO-280110	4/1/2014			Time to rebuild clocks, check clocks, and order parts for the month of April.
FO-280153	4/1/2014			2 EPs. Women's locker room.
FO-280155	4/1/2014	4/12/2014		1 EP. Entrance light. Too high to reach. Finished 4/14/2014LT
FO-280156	4/1/2014	4/12/2014		6 EP. Lights between entrance and the climbing wall (1st floor). Too high to reach. Finished 4/
FO-280157	4/1/2014			1 EP on bridge (4th floor)
FO-280158	4/1/2014			1 EP. Elevator.
FO-280161	4/1/2014			1 EP in lobby. Light fixture is over the main sw and is too high.
FO-280503	4/2/2014	4/3/2014		Please have Maintenance Laborer deliver salt from FP&M stockroom to Music building. Finish
FO-280527	4/2/2014			light bulb out in room 2800...just as you come in the suite.... this is tagged..2/2014
FO-280570	4/2/2014			Room 141 - Margherio Conference Center - Several spotlights on the stage and in perimeter p
FO-280574	4/2/2014	4/18/2014		Room 1341 has 2 EPs.Finished 4/21/2014LT
FO-280577	4/2/2014	4/7/2014		2 EPs. In Magherio Conference Center. Outside room-144-147 Finished 4/9/2014LT
FO-280579	4/2/2014	4/11/2014		1 EP. 3rd floor. The fixture is located in front of cubicle 300.1 Finished 4/14/2014LT
FO-280592	4/3/2014	4/3/2014		THERE IS A SMOKING HOT SPOT IN THE FLOWER BED BY THE SOUTH MAIN ENTRAN
FO-280596	4/3/2014	4/3/2014		ELECTRICIAN TO REMOVE 2 LIGHT FIXTURES FOR THE CARPENTERS TO CHANGE O
FO-280606	4/3/2014	4/4/2014		Please have Maintenance Laborer pick up from Holden Warehouse 4 drawer lateral file cabine
FO-280610	4/3/2014	4/4/2014		Repair bad clock in room 37.. Finished 4/7/2014LT
FO-280611	4/3/2014	4/4/2014		Repair bad clock in room 61.. Finished 4/7/2014LT
FO-280612	4/3/2014	4/4/2014		Repair bad clock in room 65.. Finished 4/7/2014LT
FO-280613	4/3/2014	4/4/2014		Repair bad clock in room 124.. Finished 4/7/2014LT
FO-280614	4/3/2014	4/4/2014		Repair bad clock in room 263.. Finished 4/7/2014LT
FO-280671	4/3/2014	4/23/2014		1 EP in basement lounge. Finished 4/23/2014LT
FO-280673	4/3/2014	4/15/2014		1 EP range 302 (2nd floor) Finished 4/16/2014LT

WO	Recieved	Finished	Total	Request
FO-280674	4/3/2014	4/18/2014		Lights over the tables and chairs outside of range 147. (1st floor)Finished 4/21/2014LT
FO-280675	4/3/2014	4/25/2014		Lights over the tables and chairs outside of range 173. (1st floor) Finished 4/29/2014LT
FO-280707	4/4/2014	4/18/2014		R/R RM 103.10/CONF RM The light switch in the Conference Room does NOT always turn off
FO-280709	4/4/2014	4/7/2014		Electricians
FO-280734	4/4/2014	4/18/2014		1 fixture out in the ground floor, in front of the elevatorsFinished 4/21/2014LT
FO-280752	4/4/2014	4/21/2014		R/R BLDG Clean out gutters on the Freer House. Thank you
FO-280750	4/4/2014	4/4/2014		Remove Scaffolding from mechanical room, and put back in storage.. Finished 4/7/2014LT
FO-280761	4/4/2014	4/7/2014		ELECTRICIANS TO REMOVE LIGHT FIXTURE & EXIT SIGN SO THE CARPENTER CAN R
FO-280777	4/4/2014	4/14/2014		Room 3250 had a light bulb in a small biohood out. They put normal bulb instead of UV. Plea
FO-280779	4/4/2014	4/10/2014		Please have Maintenance Laborer remove/dispose of particle board located outside of new Co
FO-280788	4/6/2014	4/8/2014		Replace 24-hour timer with a 7-day timer on AHU-1, Art Building Finished 4/9/2014LT
FO-280789	4/6/2014	4/18/2014		Repair lighting control timer located in custodial closet near the basement mechanical room. (
FO-280890	4/7/2014	4/12/2014		1st Floor - Personal Training Office - Motion
FO-280827	4/7/2014	4/7/2014		Repair bad clock in room 0103.
FO-280828	4/7/2014	4/7/2014		Repair bad clock in room 0105. Finished 4/11/2014LT
FO-280829	4/7/2014	4/10/2014		Repair bad clock in room 0106. Finished 4/11/2014LT
FO-280830	4/7/2014	4/7/2014		Repair bad clock in room 0134. Finished 4/9/2014LT
FO-280831	4/7/2014	4/7/2014		Repair bad clock in room 0162. Finished 4/11/2014LT
FO-280833	4/7/2014	4/10/2014		Repair bad clock in room 1111.
FO-280834	4/7/2014	4/9/2014		REpair bad clock in room 1115. Finished 4/11/2014LT
FO-280835	4/7/2014	4/7/2014		Repair bad clock in room 1305. Finished 4/9/2014LT
FO-280836	4/7/2014	4/10/2014		Repair bad clock in room 1319. Finished 4/11/2014LT
FO-280837	4/7/2014	4/9/2014		Repair bad clock in hallway on the first floor in Stairway B. Finished 4/11/2014LT
FO-280881	4/7/2014	4/22/2014		R/R REPLACE SEVERAL BURNT OUT LITES ON BOTH NORTH/SOUTH AREAS Need som
FO-280873	4/7/2014	4/7/2014		Repair Clock in room 326. Finished 4/9/2014LT
FO-280886	4/7/2014	4/14/2014		1 EP. Women's restroom (1st floor) West end. Finished 4/16/2014LT
FO-280961	4/8/2014	4/7/2014		MAKE THREE 30 FEET CHARGING CORDS FOR THE ELECTRIC VEHICLES. Finished 4/1
FO-281009	4/8/2014	4/23/2014		Room 2115 - MD Lab - entire light panel not working - 1st row center light. Please fix. 1 electri
FO-281030	4/8/2014	4/23/2014		Replace the light lens in the women's restroom on the 9th floor. Finished 4/23/2014LT
FO-281060	4/8/2014	4/9/2014		Request for electrical power to be provided to mall area for Campus Activities Event. Please p
FO-281043	4/8/2014			Pleas have Dennis deliver 25 bags of softener salt for the boilers to 3rd floor mechanical room
FO-281049	4/8/2014	4/11/2014		Time for Electricians to clean out truck, and drop off at Collision shop. Then pick it up when c
FO-281091	4/9/2014	4/7/2014		Time for Electrician to take truck in to the Collision shop.
FO-281125	4/9/2014			To cover the cost for WSU Electricians for electrical preventative maintenance work at Scott H
FO-281148	4/9/2014			Please have Maintenance Labored take wooden pallets from FP&M stockroom to Holden Wa
FO-281178	4/9/2014	4/24/2014		1 EP outside room 206 lecture hall.Finished 4/25/2014
FO-281179	4/9/2014	4/25/2014		1 EP 3rd floor ladies restroom. Finished 4/29/2014LT
FO-281240	4/10/2014	4/11/2014		remove plastic sheeting from air dampers in room 102, primary electrical room.charge to 2281
FO-281215	4/10/2014	4/24/2014		Rooms 9263 and 9263.3 has lights out. Room 9263 has 2 electrical problems. Room 9263.3 h
FO-281212	4/10/2014	4/24/2014		1 fixture out in room 125.4Finished 4/25/2014
FO-281214	4/10/2014	4/14/2014		4 fixtures out in the cafe, flood lights over vending machine Finished 4/16/2014LT
FO-281227	4/10/2014	4/10/2014		R/R RM 150.1/SVC CTR NEED MAINT LABORER TO PICK UP 2 DRAWER FILE & DELIVE
FO-281228	4/10/2014	4/24/2014		Please have Maintenance Laborer pick up 2 drawer file cabinet from Holden Warehouse and
FO-281258	4/10/2014	4/28/2014		3 fixtures out. 3 burned out light bulbs in new portion of building as you enter scott hall, 2nd flo
FO-281271	4/10/2014	4/11/2014		R/R RM 0025/MECH RM Condensate pump 1 will not run, there is power at the unit but DOES
FO-281264	4/10/2014	4/25/2014		1 EP in 4th floor, kitchenette. The fixture is over the sink Finished 4/29/2014LT
FO-281265	4/10/2014			EP :

WO	Recieved	Finished	Total	Request
FO-281269	4/10/2014			R/R RM 425/MECH-BLR RM Boiler #1 continues to trip off on Hi gas pressure cut out. This re
FO-281266	4/10/2014	4/29/2014		1 fixture out. light over the stairwell going towards the student commons area. (Basement) A s
FO-281268	4/10/2014	4/14/2014		1 fixture out in the hallway outside of women's restroom (
FO-281272	4/10/2014	4/11/2014		R/R RM 0025/MECH RM Condensate pump 2 will not run, there is power at the unit but DOES
FO-281313	4/11/2014	4/14/2014		Repair bad clock in room 508. Finished 4/16/2014LT
FO-281314	4/11/2014	4/14/2014		Repair bad clock in room 556. Finished 4/16/2014LT
FO-281344	4/11/2014	4/11/2014		Take a portable generator to the Electricians workin for Utilities Instrumentation for the day, an
FO-281353	4/11/2014	4/25/2014		R/R BLDG Fix/replace burnt out light at front (south)
FO-281384	4/11/2014	4/25/2014		R/R RM 00010/MECH RM Lighting in half of mechanical room 10 did not come back on after p
FO-281387	4/11/2014	4/25/2014		R/R RM 00025/MECH RM Install a single flood light on board above chemical test station. Fini
FO-281390	4/11/2014	4/22/2014		1 EP. EXIT sign inside of the loading dock. 1st flr.Finished 4/23/2014LT
FO-281391	4/11/2014	4/15/2014		1 row of new lights, 2nd floor open study area. The problem looks like a or circuit breaker. Fini
FO-281392	4/11/2014	4/16/2014		4 rows, 3rd floor open study area. This problem looks like a or circuit breaker. Fixtures on the
FO-281402	4/11/2014			R/R BLDG Rooms 3305, 3307, and 3129 - Please repair fire alarm devices that were shorted
FO-281419	4/14/2014	4/15/2014		Repair/replace faulty GFCI receptical located in break room. Serves microwave oven. Finishe
FO-281480	4/14/2014	4/16/2014		LABORER TO HELP THE CARPENTERS DEMO & DISPOSE OF THE EXTERIOR PLASTIC
FO-281530	4/14/2014			Office 1150 and 1151 have lights that are broke and burnt out. Thank you.
FO-281528	4/14/2014	4/15/2014		Lights out in art gallery. There are 22 electrical problems. Finished 4/16/2014LT
FO-281652	4/15/2014	4/29/2014		R/R RM 3320 please have electricians mount motor on
FO-281661	4/15/2014	4/21/2014		please pick-up old backflow preventor and discard located in mechanical room at parking stru
FO-281662	4/15/2014	4/16/2014		please deliver steam coil to room 0047 in basement of art building, coil is in a crate outside Pi
FO-281695	4/15/2014	4/16/2014		Confined awareness Training class will be held on the 3rd floor, Jeff Tolles, and Steve Persyn
FO-281699	4/15/2014	4/18/2014		R/R 3RD FLR Emergency light in stacks area near the service
FO-281720	4/15/2014	4/28/2014		1 row new lights EP. 2nd floor open study area. The row is located on the second floor facing
FO-281721	4/15/2014			At WDET there are 15 EPs in the MCR. They want to swap out all cfl floods in MCR with dimm
FO-281723	4/15/2014			please deliver gondolla with no holes or cracks in it, (waterproof) to 1st floor old wing near frei
FO-281740	4/15/2014	4/15/2014		Purchase tools for Fire Alarm Electricians. Finished 4/16/2014LT
FO-281751	4/15/2014			Three additional light bulbs burned out. Please replace. There are 3 electrical problems.
FO-281760	4/16/2014			Electrician repair ceiling light above chiller.
FO-281777	4/16/2014			Fluorescent light bulb needs to be replaced in the copier room near the reception area.
FO-281780	4/16/2014	4/16/2014		Time to have Utilities Instrumentations to repair the 2000 Amp vault, and megger bus duct. Fi
FO-281799	4/16/2014			Lights are out in room 170.
FO-281844	4/17/2014	4/18/2014		R/R 1ST FLR NEAR STAGE PILLAR SITUATED ON THE LEFT LITE IS BLINKINGFinished 4
FO-281860	4/17/2014	4/19/2014		NEED FLOW SWITCH AND ELECTRICAL HOOKED UP. BASEMENT SPRINKLER. ROOM
FO-281872	4/17/2014	4/25/2014		1 EP in hall outside of room 610 (basement) Finished 4/29/2014LT
FO-281873	4/17/2014			1 EP in room 610 (basement)
FO-281880	4/17/2014	4/28/2014		4 EP in 1st floor open study area facing com. arts building. 4 ceiling lights (the square ones).
FO-281889	4/17/2014			LABORERS (HIGH)
FO-281881	4/17/2014			3 EP's in the lobby. In need of electricians service; getting dark.
FO-281882	4/17/2014	4/24/2014		2 EPs on 3rd floor. 2 fixtures screwed shut can't open to change bulbs. The fixtures are both o
FO-281890	4/17/2014			LABORER (HIGH)
FO-281892	4/17/2014			LABORER (HIGH)R/R PH DELIVER:1) 15 PAILS OF NITROKLENZ TO PENTHOUSE
FO-281891	4/17/2014	4/21/2014		please assist in moving heating coils into room 25... Finished 4/22/2014LT
FO-281958	4/18/2014	4/28/2014		271 - 471- Womens Restroom , 4th Floor. 3 fixtures out. 1 EP in study area 271 - 1EP in sittin
FO-281981	4/19/2014	4/25/2014		Repair motor starter on AC-5, (African Heritage room supply fan). Will not stop via momentary
FO-281982	4/19/2014			Install 7-Day programmable timer on Supply Air fan AC-5, serving the African Heritage room.
FO-281984	4/20/2014	4/21/2014		Remove metal debris from hallway in basement of Art building across from Metal Smithing Ro

WO	Recieved	Finished	Total	Request
FO-282029	4/21/2014			There are 3 EP's.
FO-282061	4/21/2014			room 16 mechanical room
FO-282067	4/21/2014			Motorist ran over a light pole at Gullen Mall @ Warren early Sunday morning around 1:30 am,
FO-282113	4/21/2014	4/29/2014		1 of the track lights is out in room 105. The track light has an electrical problem.Finished 4/30/
FO-282269	4/22/2014	4/22/2014		Repair Clock on first floor.Finished 4/23/2014LT
FO-282281	4/22/2014	4/29/2014		Light bulbs need to be replaced in this conference room. This room is used several times a d
FO-282295	4/22/2014	4/28/2014		Light ballast is burned out, lighting crew checked it out several weeks ago and turned in a wor
FO-282311	4/22/2014	4/23/2014		Laborer-Please move new crane from stockroom to the Chemistry sub basement. Remove old
FO-282359	4/22/2014	4/22/2014		Move Electricians from Engineering tech back to FAB.Finished 4/23/2014LT
FO-282407	4/23/2014			in room 152, copy room there is 1 EP. The light is strobbing.
FO-282409	4/23/2014	4/24/2014		1 EP , outside of room 251, 2nd floorFinished 4/25/2014
FO-282410	4/23/2014			1 fixture out in the hallway by the pool
FO-282412	4/23/2014			1 fixture out in room 1367
FO-282413	4/23/2014	4/28/2014		1 EP, 3rd floor, mens room. fixture located over inner restroom door. Finished 4/29/2014LT
FO-282414	4/23/2014	4/28/2014		1 EP in the fish bowl (Half Landing)
FO-282416	4/23/2014			Electric wall heater in parking structure office not working.
FO-282418	4/23/2014			6 FIXTURES OUT IN ROOM 4654, 4671, 4802.
FO-282422	4/23/2014			Trade: Laborer
FO-282428	4/23/2014			Electrician; LowR/R RM 195/MECH RM Please repair the bad light bulbs located on the VF
FO-282432	4/23/2014			Deliver duct hoist to Scott Hall Penthouse, and bring it back when they finish using it.
FO-282434	4/23/2014			Deliver the One Man Lift to Applebaum, and bring it back when job is complete.
FO-282464	4/24/2014	4/28/2014		R/R BLDG (Garage) please have Dennis deliver:
FO-282465	4/24/2014	4/29/2014		R/R RM 0195/MECH-BLR RM Please have Dennis deliver:
FO-282492	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to Bi
FO-282493	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to U
FO-282494	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to E
FO-282496	4/24/2014	4/29/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to M
FO-282497	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to El
FO-282499	4/24/2014	4/29/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to P
FO-282500	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor , 1 keg Aquaklean & 1 keg Halochlor to 5
FO-282501	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Lokor Computing MRO building. Finished 4/29/2
FO-282503	4/24/2014	4/28/2014		Please have Maintenance Laborer take 1 keg Halochlor & 1 keg Aquakleen to Prentis building
FO-282506	4/24/2014			Relamp Mall Lights.
FO-282526	4/24/2014	4/25/2014		1 EP. Hallway outside of range 305 (2nd flr) Finished 4/29/2014LT
FO-282527	4/24/2014	4/25/2014		There is 1 EP as you come in the front door directly in front of the elevator. Finished 4/29/201
FO-282528	4/24/2014			2 EPs. Records 4th floor.
FO-282529	4/24/2014			1 EP hallway outside of room 212.06
FO-282535	4/24/2014	4/29/2014		Please check and repair if necessary motor on pump #1 for condenser.Finished 4/30/2014LT
FO-282531	4/24/2014			2 EPs. The fixtures are located in the center study area next to the center building supports.
FO-282532	4/24/2014			2 EPs. The fixtures are located in the center study area next to the center building supports.
FO-282533	4/24/2014	4/28/2014		2 EPs. 1 outside of room 1696. 1 outside of room 1689. Finished 4/29/2014LT
FO-282541	4/25/2014	4/25/2014		Service from Cloverdale Finished 4/29/2014LT
FO-282559	4/25/2014			please pick-up heat exchanger, spence valve, trap assembly etc, located in 1st floor mechanic
FO-282582	4/25/2014			EXIT sign outside of room 060.5. has 1 electrical problem.
FO-282583	4/25/2014			1 of the switches next to room 063 isn't working.
FO-282584	4/25/2014			EXIT sign near room 037 is an electrical problem.
FO-282589	4/25/2014	4/25/2014		please pick up insulation at wharehouse in livonia..insulation needs to be installed asap for O

WO	Recieved	Finished	Total	Request
FO-282621	4/26/2014			ELECTRICIANS:R/R OUTSIDE The east pole lights are out of service at Old Main, please re
FO-282622	4/26/2014			ELECTRICIAN: R/R OUTSIDE @ SCB The lighting is very poor at the south exit of SCB. Ple
FO-282651	4/28/2014			ADDING PAINTERS
FO-282688	4/28/2014			Connect Condesate pump.
FO-282698	4/28/2014			2 EPs room 208. The bulbs have been replaced.
FO-282699	4/28/2014			1 EP in 114. First fixture over the entrance of the room inside the office.
FO-282700	4/28/2014			1 EP. 1st floor student academic success services. The fixture is at the right of the information
FO-282701	4/28/2014			1 EP in 3rd floor men's restroom. can't open fixture to change bulbs.
FO-282702	4/28/2014			2 EPs in room 160. 2 EXIT signs are out.
FO-282703	4/28/2014			1 EP. pole light (1st floor). It's a mercury bulb.
FO-282707	4/28/2014			**Adding Laborer: Provide scaffold for Plumbing repair to be made in basement mechanical ro
FO-282709	4/28/2014			Adding Laborer: Transport lift to Stadium to make Pluming repair and return lift. See Mike Pu
FO-282710	4/28/2014			**Adding Electrician: Verify heat trace on water supply to Stadium bathrooms is working and a
FO-282796	4/29/2014			R/R RM 00051/MECH RM labor remove material from mech room 51low pr
FO-282804	4/29/2014			R/R 150 SUPERVISORS' OFC WE NEED 2 BOXES OF COPY MACHINE PAPER
FO-282816	4/29/2014	4/29/2014		Time for Wolverine to do the Load Bank on the generator.
FO-282859	4/29/2014			Trade: Laborer
T - Laborer			1	
FO-280718	4/4/2014	4/16/2014		Handy man: please remove heavy miscellaneous old parts from State Hall and Deroy Auditori
T - Locksmith			52	
FO-280076	4/1/2014	4/1/2014	4/29/2014	75481 2-KEYS RM 4121. Finished 4/7/2014LT
FO-280134	4/1/2014	4/1/2014	4/29/2014	72441 1-KEY. Finished 4/7/2014LT
FO-280137	4/1/2014	4/1/2014	4/29/2014	71224 2-KEYS RM 2334. Finished 4/7/2014LT
FO-280151	4/1/2014	4/1/2014	4/29/2014	73416 3-KEYS. Finished 4/7/2014LT
FO-280486	4/2/2014	4/2/2014		#75483 2 Keys Room 429. Finished 4/7/2014LT
FO-280487	4/2/2014	3/31/2014		#73441 1 Core Room 407. Finished 4/7/2014LT
FO-280547	4/2/2014	4/2/2014		75484 2-desk keys for service center area. Finished 4/7/2014LT
FO-280563	4/2/2014	4/2/2014		75485 3-KEYS. Finished 4/7/2014LT
FO-280646	4/3/2014			Please supply a new key duplicator from IDN Door Hardware and Sales QUOTE NO.
FO-280649	4/3/2014	4/3/2014		71554 1-CORE 3-KEYS. Finished 4/7/2014LT
FO-280658	4/3/2014			Please replace the Grinder/brush in the lockshop. Grainger Quote Number 2020849454
FO-280797	4/7/2014	4/7/2014		#75487 10 Keys Finished 4/9/2014LT
FO-280798	4/7/2014	4/7/2014		#71612 6 Keys Room 2224 Finished 4/9/2014LT
FO-280799	4/7/2014	4/7/2014		#71613 5 Keys Finished 4/9/2014LT
FO-280845	4/7/2014	4/7/2014		#74846 3 Keys Finished 4/9/2014LT
FO-280884	4/7/2014	4/7/2014		74390 -2-KEYS Finished 4/9/2014LT
FO-280962	4/8/2014	4/11/2014		75489 2-PADLOCKS Finished 4/16/2014LT
FO-280974	4/8/2014	4/8/2014		73440 1- KEY Finished 4/9/2014LT
FO-281039	4/8/2014	4/8/2014		Request
FO-281093	4/9/2014	4/9/2014		#75187 2 Keys Room 300.18 Finished 4/11/2014LT
FO-281094	4/9/2014	4/9/2014		#74638 2 Keys Room 3108 Finished 4/11/2014LT
FO-281267	4/10/2014	4/14/2014		75492 8-KEYS Finished 4/16/2014LT
FO-281328	4/11/2014	4/14/2014		#75497 4 Keys and 2 Cores Room 408 Finished 4/16/2014LT
FO-281329	4/11/2014	4/16/2014		#75496 4 Keys and 2 Cores Room 610 Finished 4/18/2014LT
FO-281337	4/11/2014	4/11/2014		#75438 3 Keys Finished 4/16/2014LT
FO-281447	4/14/2014	4/11/2014		#44478 4 Keys Room 150 Finished 4/16/2014LT
FO-281448	4/14/2014	4/11/2014		#44479 4 Keys Room 150 Finished 4/16/2014LT
FO-281542	4/14/2014	4/18/2014		75501 REQUEST 75501 Finished 4/21/2014LT

WO	Recieved	Finished	Total	Request
FO-281754	4/16/2014	4/21/2014		#75188 1 Core Room 448 Finished 4/22/2014LT
FO-281755	4/16/2014	4/18/2014		#75387 4 Keys Room 231 Finished 4/21/2014LT
FO-281757	4/16/2014	4/17/2014		#75335 9 Keys Rooms 2332,335,0327 Finished 4/18/2014LT
FO-281759	4/16/2014	4/17/2014		#74048 3 Keys Room 123 Finished 4/18/2014LT
FO-281766	4/16/2014	4/16/2014		Make key for Elevator so Electricians can repair Bus Duct. Finished 4/18/2014LT
FO-281806	4/16/2014	4/18/2014		71297 2-KEYS Finished 4/21/2014LT
FO-281864	4/17/2014	4/17/2014		42166 1-KEY Finished 4/18/2014LT
FO-281911	4/18/2014	4/18/2014		#75508 1 Core 3-KEYS Room 225 Finished 4/21/2014LT
FO-281912	4/18/2014	4/18/2014		#74684 1 Key Room 76811 Finished 4/21/2014LT
FO-281913	4/18/2014	4/18/2014		#74670 1 Key Finished 4/21/2014LT
FO-282003	4/21/2014	4/23/2014		#75509 2 Keys and 2 Cores Room 718 Finished 4/23/2014LT
FO-282343	4/22/2014	4/24/2014		#75175 1 KeyFinished 4/25/2014
FO-282484	4/24/2014	4/25/2014		locksmith w/o please replace/recore as necessary the lunch service kiosk security door in the l
FO-282485	4/24/2014	4/24/2014		Locksmith w/o, please replace/recore as necessary the lunch service kiosk security door in th
FO-282490	4/24/2014	4/24/2014		Require 2 keys for security cover (cover on thermostat)Finished 4/25/2014
FO-282495	4/24/2014	4/24/2014		#75442 1 KeyFinished 4/25/2014
FO-282498	4/24/2014	4/25/2014		#71188 2 Key Finished 4/29/2014LT
FO-282502	4/24/2014	4/25/2014		#75513 1 Key Room 157 Finished 4/29/2014LT
FO-282592	4/25/2014	4/25/2014		#75517 1 Key Finished 4/29/2014LT
FO-282604	4/25/2014	4/29/2014		#75518 6 Keys
FO-282639	4/28/2014	4/28/2014		75423 3-KEYS
FO-282807	4/29/2014			#75520 2 Keys and 2 Cores Room 1507
FO-282808	4/29/2014			#73323 2 Keys Room 3117
FO-282871	4/29/2014			75521 10-KEYS
T - Painter			46	
FO-280067	4/1/2014	4/15/2014		Please paint all classroom unit vent heates on 1st floor. Finished 4/16/2014LT
FO-280064	4/1/2014	4/1/2014	4/29/2014	please paint information board for Pipe shop, see John.. Finished 4/4/2014LT
FO-280128	4/1/2014			CLEAN OFF OR PAINT OVER GRAFFITI ON CAMPUS.
FO-280731	4/2/2014	4/28/2014		PAINTERS
FO-280488	4/2/2014	4/2/2014		PAINTERS TO PAINT REPLACEMENT CEILING TILES FOR MEGANS OFFICE Finished 4/4
FO-280544	4/2/2014	4/25/2014		SAFETY TIME FOR THE MONTH OF APRIL.
FO-280546	4/2/2014	4/10/2014		R/R WALL DUE TO WALL LEAK. HANCOCK LOBBY. Finished 4/11/2014LT
FO-280549	4/2/2014	4/3/2014		R/R WALL IN UNI-SEX RESTROOM FIRST FLOOR. Finished 4/4/2014LT
FO-280550	4/2/2014	4/2/2014		R/R BEAM IN THE HALLWAY ON THE SOUTH SIDE. FIRST FLOOR. Finished 4/4/2014LT
FO-280639	4/3/2014	4/17/2014		PAINTERS TO CAULK CRACKS & GAPS ON THE PLASTIC CEILING IN THE ANIMAL QUA
FO-280683	4/3/2014	4/7/2014		1. I need to have some brackets removed from the wall, have the anchors pulled out, the hole
FO-280744	4/4/2014	4/4/2014		Re-paint ceiling tile in Megan's Office. Finished 4/7/2014LT
FO-280745	4/4/2014	4/4/2014		Paint access panel outside of 225. Finished 4/7/2014LT
FO-280763	4/4/2014	4/7/2014		Painters: Please paint a new access panel in the hallway ceiling in front of room 225 to match
FO-281115	4/9/2014			HANDYMAN TIME.
FO-281116	4/9/2014			MTL TIME.
FO-281128	4/9/2014	4/17/2014		PAINTERS TO MUDD 2 SMALL HOLES ON A WALL ROOM # 0123 Finished 4/18/2014LT
FO-281131	4/9/2014	4/14/2014		PAINTER TO PAINT WALL REPAIRS MADE FOR THE PLUMBERS 1ST FLOOR WOMENS
FO-281160	4/9/2014			please repair wall 1st stall trades restroom.....
FO-281397	4/10/2014	4/23/2014		Office 6203.4 needs to have anchors pulled out of 3 of the walls in the office, the holes repara
FO-281288	4/10/2014	4/11/2014		PAINT THE HANDRAILS AND STRINGERS ON STAIRWAY. HANCOCK SIDE. Finished 4/14
FO-281289	4/10/2014	4/10/2014		TRAINING Finished 4/11/2014LT

WO	Recieved	Finished	Total	Request
FO-281325	4/11/2014			451-B paint and patch crack in ceiling
FO-281512	4/14/2014	4/14/2014		Third floor, north west corner. R/R ceiling, wall, and access panel due to roof leak Finished 4/1
FO-281683	4/15/2014			PAINT AS NEEDED IN STAIRWAY-S
FO-281894	4/16/2014	4/17/2014		oehs CONFINE SPACE TRAINING Finished 4/18/2014LT
FO-281960	4/18/2014	4/22/2014		paint hallways in the sub-basement.Finished 4/23/2014LT
FO-282109	4/21/2014			Clean crystal chandeliers in office, one large and one small. This is a "just do it" request. Aut
FO-282110	4/21/2014			Clean crystal chandelier in office. This is a "just do it" request. Authorization and index to cha
FO-282317	4/21/2014			Paint the WSU standard W on the front drive of UT facing the building centered on the lobby, t
FO-282081	4/21/2014	4/22/2014		PAINTER TO PAINT DOOR VENT MOLDING ROOM # 2301.00Finished 4/23/2014LT
FO-282270	4/22/2014	4/28/2014		PAINTERS TO MUDD & PAINT WALL NEXT TO DRINKING FOUNTAIN NEAR ROOM #1526
FO-282333	4/22/2014	4/22/2014		4th floor West side. Paint access panel Finished 4/23/2014LT
FO-282552	4/25/2014	4/28/2014		PAINTERS TO MUDD & PAINT CEILING OUTSIDE ROOM # 2301 AF3& AF7 Finished 4/29/
FO-282562	4/25/2014			PATCH AND PAINT WALL WHERE EBU'S WERE REMOVED.
FO-282615	4/26/2014	4/28/2014		POWER WASH THE RAMP. Finished 4/29/2014LT
FO-282651	4/28/2014			ADDING PAINTERS
FO-282799	4/29/2014			CAP-3 #160 PAINT TOUCH UP.
FO-282800	4/29/2014			CAP-3 #167 PAINT TOUCH UP.
FO-282801	4/29/2014			CAP-3 #297 PAINT TOUCH UP.
FO-282802	4/29/2014			CAP-3 #19 PAINT TOUCH UP.
FO-282803	4/29/2014			CAP-3 #25 PAINT TOUCH UP.
FO-282844	4/29/2014			SAFETY TIME FOR THE MONTH OF APRIL 2014.
FO-282847	4/29/2014			Painter R/R 3RD FLR HALLWAY IN FRONT OF RM 3087.10 DOORS repair water damaged
FO-282848	4/29/2014			CAP-3 # 840 PAINT ACCESS PANEL TO MATCH CEILING.
FO-282849	4/29/2014			CAP-3 # 841 PATCH AND PAINT HOLES.
T - Pipefitter			110	
FO-279861	4/1/2014			(**) Coil Delivery expected 4-7-14 JWT
FO-280163	4/1/2014	4/1/2014	4/29/2014	investigate penthouse mech room for possible new sink instalation see fo #279050...CB...4-1-1
FO-280164	4/1/2014	4/1/2014	4/29/2014	investigate conductor/ddrain line busted near second floor...evaluate for scaffling..see fo#2783
FO-280165	4/1/2014	4/1/2014	4/29/2014	investigate 4th floor ceiling leak, aand speak with Kelly Gottsmen for acuracy....CB...4-1-14...s
FO-280166	4/1/2014	4/1/2014	4/29/2014	take vendor to various buildings for Asbestos quotes.....CB.....4-1-14 Finished 4/4/2014LT
FO-280167	4/1/2014	4/1/2014	4/29/2014	processing time paperwork, e-mails, phone calls, etc....CB...4-1-14 Finished 4/4/2014LT
FO-280169	4/1/2014	4/1/2014	4/29/2014	assist laborer in romoving duct hoist from mech room and cleaning up debris....CB...4-1-14 Fin
FO-280542	4/2/2014	4/2/2014		investigated a plumbing leak with the plumber to facilitate a repair.....CB.4-2-14 Finished 4
FO-280543	4/2/2014	4/2/2014		processing time for various hot work permits through-out campus.....CB.4-2-14 Finished 4/
FO-280545	4/2/2014	4/2/2014		chase down paperwork,post asbestos notifications, speak to building coordinators, provide bill
FO-280548	4/2/2014	4/2/2014		processing time for e-mails, phone calls,paperwork, etc....CB...4-2-14 Finished 4/4/2014LT
FO-280700	4/3/2014	4/3/2014		take camera and try to identify pipe leak basement level...CB...4-3-14 Finished 4/4/2014LT
FO-280701	4/3/2014	4/3/2014		chk floor floor ceiling ,leak...this leak is now active due to rain...please diagnose....CB...4-3-14
FO-280702	4/3/2014	4/3/2014		assist abatement company on set-up and location....CB...4-3-14 Finished 4/4/2014LT
FO-280703	4/3/2014	4/3/2014		processing time for hot work permits.....CB...4-3-14 Finished 4/4/2014LT
FO-280704	4/3/2014	4/3/2014		processing time for paperwork,e-mails, phone calls etc.... Finished 4/4/2014LT
FO-280705	4/3/2014	4/3/2014		investigate damaged sink in DLAR area basement surgery lab....CB...4-3-14 Finished 4/4/201
FO-280651	4/3/2014	4/22/2014		PLEASE fab motor support on PENNANT BOILER WATER HEATER PUMP to help with vibra
FO-280708	4/4/2014			Pipefitters-R/R RM 0001/CENTRAL COMPUTER OR TELECOMM please install pipe extens
FO-280766	4/4/2014	4/4/2014		processing time paper work, e-mails phone calls...4-4-14 Finished 4/7/2014LT
FO-280769	4/4/2014	4/4/2014		set abatement crew up with 2 jobs, open doors chk progress inspect after completion commun
FO-280770	4/4/2014	4/4/2014		investigate outside drinking fountain leaking by tennis courts...CB...4-4-14.... Finished 4/7/201

WO	Recieved	Finished	Total	Request
FO-280771	4/4/2014	4/4/2014		set up emergency asbestos job, paperwork, communications, scheduling, personel,etc.... Fini
FO-280859	4/7/2014	4/7/2014		energy curtailment meeting....CB...4-7-14 Finished 4/9/2014LT
FO-280862	4/7/2014	4/7/2014		processing time for e-mails,phone calls,communications etc...4-7-14....CB. Finished 4/9/2014
FO-280863	4/7/2014	4/7/2014		escort contractor from Gaurdian to education, gain access tio mechanical room and help in di
FO-280865	4/7/2014	4/7/2014		remove all asbestos notifications from Fridays jobs, log info, file, and print new quotes for upc
FO-280871	4/7/2014			R/R RM 0025/MECH RM Repair or replace chilled water coil on SF-4 for Community Arts stair
FO-280874	4/7/2014			R/R RM 00025/MECH RM Repair or replace cooling coil for SF-8,,,,,,,,,,,,, CB/4-8-14 ,,,,,,,,,,
FO-280972	4/8/2014	4/10/2014		PIPEFITTERS,
FO-281045	4/8/2014	4/8/2014		chk various ceiling leaks through-out campus...CB...4-8-14 Finished 4/9/2014LT
FO-281046	4/8/2014	4/8/2014		processing time for Hot Work Permits.....CB.....4-8-14 Finished 4/9/2014LT
FO-281047	4/8/2014	4/8/2014		processing time, phone calls ,e-mails,texting,communications.....CB...4-8-14 Finished 4/9/201
FO-281048	4/8/2014	4/8/2014		Investigate pipe leak in clock tower and try to come up with a way to repair....CB...4-8-14 Finis
FO-281156	4/9/2014			Fitters,R/R PENTHOUSE please repair leaks in steam coil on AHU-1.
FO-281157	4/9/2014			Fitters,R/R PENTHOUSE please repair leaks in steam coil on AHU-2.
FO-281163	4/9/2014	4/9/2014		processing time, phone calls, e-mails,paperwork,communications etc.....CB...4-9-14 Finished
FO-281165	4/9/2014	4/9/2014		please check chilled water coils for condition prior to cooling season room 25 ahu #8 and ahu
FO-281168	4/9/2014			Assist Eletricians with Hot water heater controller and settings ,,,,,,,,,,,,,, EA / 4-9-14 ,,,,,,,,,,
FO-281167	4/9/2014	4/9/2014		processing time hot work permits....CB...4-9-14... Finished 4/14/2014LT
FO-281169	4/9/2014	4/9/2014		inspect various asbestos jobs for pipe shop.....CB...4-9-14 Finished 4/14/2014LT
FO-281318	4/10/2014	4/10/2014		processing time for hot work permits at various buildings on campus.....4-10-14....CB Finished
FO-281319	4/10/2014	4/10/2014		processing time fro e-mails, phone calls, paperwork, etc.....CB...4-10-14 Finished 4/14/2014L
FO-281322	4/10/2014	4/10/2014		show abatement jobs to contractor....CB...4-10-14 Finished 4/14/2014LT
FO-281208	4/10/2014	4/11/2014		**Please re-insulate this area / Repair now complete / Verify heat trace is still in service befor
FO-281367	4/11/2014			Work Order to purchase Hilti power tools for Pipe Shop ,,,,,,,,,,,,,, JT / 4-11-14 ,,,,,,,,,,,,,, DUE
FO-281373	4/11/2014	4/11/2014		investigate possible asbestos on piping for plumbing repair....CB...4-11-14 Finished 4/14/201
FO-281376	4/11/2014	4/11/2014		processing time for e-mails,phone calls, paperwork, corespondence, etc....4-11-14....CB Finis
FO-281377	4/11/2014	4/11/2014		processing time for hot work permits,various buildings through-out campus.....CB..4-11-14
FO-281379	4/11/2014	4/11/2014		investigate ceiling leak on second floor of new wing lab 2520.....CB...4-11-14 Finished 4/14/20
FO-281380	4/11/2014	4/11/2014		assist Laborer in loading, unloading, and delivering back flow preventor to structure 8 mechani
FO-281381	4/11/2014	4/11/2014		chk hot water temp guage on domestic water in boiler nroom.....4-11-14.....CB Finished 4/1
FO-281414	4/12/2014			R/R smaller steam relief valve near chiller in basement mechanical room ,,,,,,,,,,,,,, JH/4-12-1
FO-281415	4/12/2014			Mount all thread container and hook for hose to clean snakes . See John for location ,,,,,,,,,,,,,,
FO-281440	4/14/2014			Fitter replace leaking steam valve for humidifier on AH-1 & 1A,,,,,,,,,,,,,,,,, ME/4-14-14 ,,,,,,,,,,,,,,
FO-281544	4/14/2014			Fitter, install drain lines at energy recovery coils for AH-1, 2, 4, and 5 so engineer can clean th
FO-281547	4/14/2014	4/14/2014		investigate numerous ceiling leaks on 5th floor near elavators and conference room....CB.4-14
FO-281548	4/14/2014	4/14/2014		please investigate broken chiller line on cooling tower on roof....CB...4-14-14 Finished 4/16/20
FO-281549	4/14/2014	4/14/2014		chk boiler pump on package boiler for bad bearings....CB...4-14-14 Finished 4/16/2014LT
FO-281550	4/14/2014	4/14/2014		processing time for e-mails,phone calls, coorespondence, etc.... Finished 4/16/2014LT
FO-281551	4/14/2014	4/14/2014		take contractor to look at asbestos job....CB.4-14-14 Finished 4/16/2014LT
FO-281553	4/14/2014	4/14/2014		pay a visit to D.L.A.R. department and talk to Sue about her cracked lab sink...CB....4-14-14 F
FO-281554	4/14/2014	4/21/2014		please repair seperated drain on west end Herman Nelson hydronic pump....see Carl for exact
FO-281832	4/16/2014	4/16/2014		post abatment notifications and schedule asbestos job with Bob O.....CB...4-16-14 Finishe
FO-281834	4/16/2014	4/16/2014		processing time to chase down signatures and get project notification signed by all parties for
FO-281836	4/16/2014	4/16/2014		processing time for e-mails ,paperwork, phone calls, etc....CB...4-16-14 Finished 4/18/2014LT
FO-281837	4/16/2014	4/16/2014		processing time for hot work permits.....4-16-14.CB Finished 4/18/2014LT
FO-281839	4/16/2014	4/16/2014		chk ceiling leak first floor nears womens restroom.possible asbestos.....CB.....4-16-14 Finishe
FO-281779	4/16/2014			PIPEFITTERS please r/r leaking valve at blowdown for water column. leaking at packing gland

WO	Recieved	Finished	Total	Request
FO-281781	4/16/2014			PIPEFITTERS please replace seals on both condensate pumps in the basement at 5435 Woo
FO-281801	4/16/2014	4/23/2014		STEAM FITTERS-PLEASE REPAIR LEAKING SEALS IN #1CONDENSTATE RECIEVER PU
FO-281818	4/16/2014	4/16/2014		Confined Space Training DB/EA 4-16-14 Finished 4/18/2014LT
FO-281935	4/18/2014	4/18/2014		processing time hot work permits.....CB.4-18-14 Finished 4/21/2014LT
FO-281936	4/18/2014	4/18/2014		set contractor up with access and job (asbestos removal).....CB....4-18-14 Finished 4/21/20
FO-281938	4/18/2014	4/18/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.4-18-14 Finished 4/21/2014
FO-281939	4/18/2014	4/18/2014		shaparone contractor for insulation work at bio-sci.....CB....4-18-14 Finished 4/21/2014LT
FO-281953	4/18/2014			Fitter repair large condensat leak under steel plate in floor. JH/ 4-18-14
FO-281983	4/19/2014	4/19/2014		set up third shift asbestos jobs for next week...CB...4-19-14 Finished 4/21/2014LT
FO-282327	4/21/2014			Clinic Visit for Injury 4-21-14 JH/ 4-21-14
FO-282045	4/21/2014			FITTERS: Please repair leaking steam regulator on Domestic Hot Water Tank #3
FO-282092	4/21/2014	4/21/2014		chase down signatures and communicate with all involved on water shutdown for this Saturda
FO-282093	4/21/2014	4/21/2014		take contractor to roof to quote insulation on cooling tower.CB.4-21-14 Finished 4/22/2014LT
FO-282095	4/21/2014	4/21/2014		take Dave K over to look at leaking roof conductor in clock tower.....CB....4-21-14 Finish
FO-282099	4/21/2014	4/21/2014		processing time for hot work permits.....CB.4-21-14 Finished 4/22/2014LT
FO-282100	4/21/2014	4/21/2014		processing time e-mails, phone calls,coorespondence, etc....CB...4-21-14 Finished 4/22/2014
FO-282274	4/22/2014			Pf Med Priorityty
FO-282275	4/22/2014			Pf Med Priorityty
FO-282337	4/22/2014	4/22/2014		consumable purchase for Pipe Shop (silver solder, oxygen, and acetylene tanks)..... CB
FO-282342	4/22/2014	4/22/2014		processing time hot work permits.....CB.4-22-14Finished 4/25/2014
FO-282344	4/22/2014	4/22/2014		take contractor for quote on asbestoes removal.....CB...4-22-14Finished 4/25/2014
FO-282345	4/22/2014	4/22/2014		processing time, project notification for Elleman shutdown on 5-3-14.....CB..4-22-14Finished
FO-282348	4/22/2014	4/22/2014		processing time e-mails, phone calls, paperwork, etc.....CB.4-22-14Finished 4/25/2014
FO-282441	4/23/2014	4/23/2014		get final signatures, make copies, and pass out copies of notification for elleman steam shutd
FO-282442	4/23/2014	4/23/2014		meeting with Jon Fredricks about list of jobs that he wants done.....CB.4-23-14Finished 4/2
FO-282443	4/23/2014	4/23/2014		processing time hot work pefrmits..CB.4-23-14Finished 4/25/2014
FO-282444	4/23/2014	4/23/2014		processing time e-mails,phone calls,paperwork,etc...CB..4-23-14Finished 4/25/2014
FO-282510	4/24/2014	4/24/2014		meeting with building coordinator on possible building shutdown.....CB.....4-14-14Finished
FO-282511	4/24/2014	4/24/2014		procesing time paperwork, e-mails,phone calls, etc.....CB.4-24-14Finished 4/25/2014
FO-282514	4/24/2014	4/24/2014		processing time for hot work permits...CB.....4-24-14Finished 4/25/2014
FO-282516	4/24/2014	4/24/2014		investigate steam leak on 3rd and 5th floors.....CB.4-24-14Finished 4/25/2014
FO-282598	4/25/2014			processing time for hot work permits...CB.4-25-14
FO-282599	4/25/2014			processing time for e-mails, paperwork,phone calls etc.....CB...4-25-14
FO-282788	4/28/2014			processing time hot work permits..CB.....4-28-14
FO-282789	4/28/2014			processing time e-mails, phone calls,paperwork, etc.....CB..4-28-14
FO-282792	4/28/2014			start prepping for abatement removal, notifications, bills of lading, postings, etc.....CB...4-2
FO-282793	4/28/2014			visit with Bob O from Mathaeii for this weeks scheduled job, go over details, etc.....CB...4-28-
FO-282866	4/29/2014			processing time for paperwork, e-mails, phone calls.....cb...4-29-14
FO-282868	4/29/2014			take coil vendor to 4 different buildings and looked at about a dozen coils.CB.4-29-14
FO-282870	4/29/2014			set up project notification for shutdown, collect all signatures, copy and return.....CB...4-29-1
FO-282875	4/29/2014			get bills of lading and asbestos notifications from OEHS and prepare them for posting.....CB..
T - Plumber			46	
FO-280141	4/1/2014	4/14/2014		Prentis building 2cnd floor mens(no room numbee) near room 226 urinal backed up
FO-280145	4/1/2014	4/14/2014		Prentis building 2cnd floor ladies room(no room number)sink draining very slow
FO-280561	4/1/2014			Administrative Time for April 2014
FO-280509	4/2/2014			Plumbers: please unplug north and south ponds drain lines. Priority: low..... MP/DB 4
FO-280515	4/2/2014			** Work in Progress / Abatement Requested 4-2-14 . Access Denined at this time to Abate. Pr

WO	Recieved	Finished	Total	Request
FO-280536	4/2/2014	4/2/2014		**Duplicate Work Order / Refer to FO#281038 JWT
FO-280648	4/3/2014			R/R RM 2312 Sink is dripping - will not turn completly off. ,,,,,,,,,, MM/ 4-3-14 ,,,,,,,,,, DUE
FO-280851	4/7/2014	4/8/2014		1st Floor - Men's Restroom - Left hand side
FO-280971	4/8/2014	4/17/2014		TAKE SHOP WATER OFF THE FIRE LINE AND CONNECT TO THE RIGHT SUPPLY LINE
FO-281038	4/8/2014			**Lowered Priorty / Work in Progress / Emergency Corrected JWT
FO-281040	4/8/2014	4/14/2014		2cnd floor water fouhtain located in the hall next to room 210.1 - backed up/water drains very v
FO-281041	4/8/2014	4/15/2014		1st floor mens room on the Cass side of building - middle stall toilet backed up. toilet is bagged
FO-281149	4/9/2014			(**) P. O. Req DK
FO-281222	4/10/2014	4/10/2014		R/R RM 326/Men's restroom: faucet in middle sink does not work - replace battery? ,,,,,,,,,,
FO-281396	4/11/2014	4/26/2014		3rd Floor - Short Water Fountain - Fountain
FO-281412	4/12/2014	4/24/2014		R/R slone shut off valve on 8th floor mes room. west end ,,,,,,,,,, MP/DB 4-12-14 ,,,,,,,,,,
FO-281413	4/12/2014			Service Propress Gun Locking Pin ,,,,,,,,,, JT 4-12-14 ,,,,,,,,,, DUE 5-12-14
FO-281485	4/14/2014			Research leak in ceiling near room 272. See Alex for details ,,,,,,,,,,MP/DB 4-14-14 ,,,,,,,,,,
FO-281488	4/14/2014			** !st booster pump is beyond repairs. Please replace before service from Macomb can move
FO-281650	4/14/2014			R/R RM 344/LAB Sink is clogged in room 344. Has standing water.,,,,,,,,,, RB / 4-16-14 ,,,
FO-281672	4/15/2014	4/23/2014		TOILET SPLASHES WATER WHEN FLUSHED. 4TH FLOOR LADIES RESTROOM. ,,,,,,,,,,
FO-281704	4/15/2014			Please clear the two floor drains in the boiler room nearest the boiler blowdown line discharge.
FO-281733	4/15/2014	4/17/2014		R/R DRAIN TO EYE WASH, SO IT CAN BE TESTED WITHOUT FLOODING THE FLOOR.,,,,
FO-281758	4/16/2014			Plumber replace damaged water filter for ice maker in room 012.,,,,,,,,,, MM/4-16-14 ,,,,,,,,,,
FO-281764	4/16/2014			** Lowered Priorty / Work In Progress Emergency Corrected JWT
FO-281796	4/16/2014	4/21/2014		NEED FLOW SWITCH AND ELECTRICAL HOOKED UP. BASEMENT SPRINKLER. ROOM
FO-281811	4/16/2014			Ladies room - Handicapped stall - toilet seat is broken - please fix/replace. ,,,,,,,,,, MM/4-1
FO-281934	4/18/2014	4/21/2014		Sink backed up 1st floor restroom 1238 (its bagged),,,,,,,,,, MM/ 4-18-14 ,,,,,,,,,, DUE 5-
FO-281937	4/18/2014			3rd floor restroom 332 toilet seat broke ,,,,,,,,,, MP/DB 4-18-14 ,,,,,,,,,, DUE 5-18-14
FO-281940	4/18/2014			** Priorty lowered / part on order JWT
FO-281954	4/18/2014	4/21/2014		Plumber repair urinal, mens room center. runs continously.,,,,,,,,,, MM/ 4-18-14 ,,,,,,,,,, D
FO-281955	4/18/2014			Plumber repair toilet 1st floor women center ,,,,,,,,,, MM/ 34-18-14 ,,,,,,,,,, DUE 5-18-14
FO-281968	4/18/2014	4/24/2014		Right sink plugged draining very slow . Mens room #54 ,,,,,,,,,, RB/ 4-18-14 ,,,,,,,,,, DUE
FO-282316	4/22/2014			R/R 1st floor men's room, near classroom #1108, (there is no room number) the sink on the ri
FO-282340	4/22/2014			PVC glue shop stock ,,,,,,,,,, MP/DB 4-22-14 ,,,,,,,,,, DUE 5-22-14
FO-282351	4/22/2014			please order sloan parts for stock in piperoom.....
FO-282352	4/22/2014			**Lowered Priority / Temporary in Place JWT
FO-282371	4/23/2014			The women's restroom sink on the 5th floor leaking facuet need to replace.,,,,,,,,,, MP/DB
FO-282401	4/23/2014			R/R Restroom 211: toilet appears to be detaching from the wall.,,,,,,,,,, MM/ 4-25-14
FO-282452	4/24/2014			faucet leaking ,,,,,,,,,, MM/ 4-25-14 ,,,,,,,,,,DUE 5-24-14
FO-282593	4/25/2014			R/R KITCHEN In the room off of the cold kitchen next to the walk in refrigerator are condensat
FO-282617	4/26/2014			**Install pump when it is returned from being serviced from FO#273692 JWT
FO-282645	4/28/2014			CAP-3 #305, ada toilet basement mensroom replace sloan valve.....DB...4-28-14
FO-282647	4/28/2014			CAP-3 (material for CAP # 3)...
FO-282652	4/28/2014			CAP-3 #40, outside cap cleanout....MM...4-28-14
FO-282708	4/28/2014			R/R water supply and Turn water back on to Stadium bathrooms. See Bob when complete ,,,,
T - Roofing			4	
FO-281016	4/8/2014			** Changing to Roofer. CB seen Tim on this 4-8-14 JWT / Lowered priorty per Tim
FO-281410	4/12/2014	4/14/2014		Duplicate / Refer to FO#281016 JWT
FO-281933	4/18/2014	4/18/2014		R/R ROOF REVEIW ROOF PROBLEMS REPAIR WHERE NECESSARY.REPAIRS WERE M
FO-282305	4/22/2014			Replace/Repair a piece of roof material that fell off the roof of Old Main. The piece that fell off

Routine 30

T - Electrician 30

WO	Recieved	Finished	Total	Request
FO-280147	4/1/2014	4/9/2014		GEN TEST Wednesday 4/9/2014 @ 9:15 AM Finished 4/11/2014LT
FO-280811	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280812	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280813	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280814	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280815	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280816	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-280817	4/7/2014	4/11/2014		ROUTINE CHECK 4/7 THRU 4/11/14 Finished 4/14/2014LT
FO-281533	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281534	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281535	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281537	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281538	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281539	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-281540	4/14/2014	4/18/2014		ROUTINE CHECK 4/14 THRU 4/18/14Finished 4/21/2014LT
FO-282296	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282297	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282303	4/22/2014	4/24/2014		Generator Test Thursday, 4/24/2014 @ 7:15 AMFinished 4/25/2014
FO-282299	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282300	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282301	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282302	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282304	4/22/2014	4/25/2014		ROUTINE CHECK 4/21 THRU 4/25/14 Finished 4/29/2014LT
FO-282675	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282676	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282677	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282678	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282679	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282680	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14
FO-282681	4/28/2014			ROUTINE CHECK 4/28 THRU 5/2/14

Scheduled Maint. (PM)

886

Engineering

853

Emergency

1

E - Area 2 Engineer

1

FO-281902 4/17/2014

PM Vacuum pump system. Finished 4/4/13LT

Routine

852

E - Auxiliary

40

FO-278714 4/1/2014

PM - Air Handling Unit

FO-278715 4/1/2014

PM - Air Handling Unit

FO-278716 4/1/2014

PM - Air Handling Unit

FO-278717 4/1/2014

PM - Air Handling Unit

FO-278718 4/1/2014

PM - Air Handling Unit

FO-278719 4/1/2014

PM - Centrifugal Pump, over 1 H.P.

FO-278720 4/1/2014

PM - Centrifugal Pump, over 1 H.P.

FO-278721 4/1/2014

PM - Centrifugal Pump, over 1 H.P.

FO-278735 4/1/2014

PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-278736	4/1/2014	4/28/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-278737	4/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-278738	4/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-278739	4/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-279320	4/2/2014	4/15/2014		PM - Air Handling Unit
FO-279321	4/2/2014	4/15/2014		PM - Air Handling Unit
FO-279337	4/7/2014	4/11/2014		PM - Emergency Shower/Eyewash Station
FO-278713	4/8/2014	4/8/2014		Generator Maintenance, Monthly
FO-279335	4/9/2014	4/9/2014		Generator Maintenance, Monthly
FO-280026	4/13/2014			Boiler Rear Refractory Inspection - 60 " Boiler
FO-280028	4/13/2014			PM - Centrifugal Pump, over 1 H.P.
FO-280029	4/13/2014			PM - Centrifugal Pump, over 1 H.P.
FO-280030	4/13/2014			PM - Centrifugal Pump, over 1 H.P.
FO-280027	4/14/2014	4/18/2014		PM - Emergency Shower/Eyewash Station
FO-280014	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280019	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280020	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280021	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280022	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280023	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280024	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280025	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279578	4/16/2014	4/16/2014		Generator Maintenance, Monthly
FO-280928	4/21/2014	4/25/2014		PM - Emergency Shower/Eyewash Station
FO-279568	4/22/2014	4/22/2014		Generator Maintenance, Monthly
FO-279569	4/22/2014	4/22/2014		Generator Maintenance, Monthly
FO-279570	4/22/2014	4/22/2014		Generator Maintenance, Monthly
FO-279571	4/22/2014	4/22/2014		Generator Maintenance, Monthly
FO-279572	4/22/2014	4/22/2014		Generator Maintenance, Monthly
FO-281620	4/25/2014	4/25/2014		Boiler Rear Refractory Inspection - 60 " Boiler
FO-281621	4/28/2014			PM - Emergency Shower/Eyewash Station
E - Command Center			1	
FO-279338	4/2/2014			Boiler Rear Refractory Inspection - 60 " Boiler
E - MedPharm			67	
FO-278601	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278602	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278603	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278604	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278605	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278606	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278607	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278608	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278609	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278610	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278611	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278612	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278613	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278614	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-278615	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278616	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278617	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278618	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278619	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278620	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278621	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278622	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278623	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278624	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278625	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278626	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278627	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278628	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278629	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278630	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278631	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278632	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278633	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278634	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278635	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278636	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-278637	4/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-279278	4/4/2014			PM - Sump Pump
FO-279279	4/4/2014	4/29/2014		PM - Sump Pump
FO-279280	4/4/2014			PM - Water Softener
FO-279576	4/4/2014	4/4/2014		Generator Maintenance, Monthly
FO-279574	4/11/2014			Generator Maintenance, Monthly
FO-279575	4/11/2014			Generator Maintenance, Monthly
FO-279863	4/15/2014	4/29/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279864	4/15/2014	4/29/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279865	4/15/2014	4/16/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279866	4/15/2014	4/17/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279867	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279868	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279869	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279870	4/15/2014	4/21/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279871	4/15/2014	4/28/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279872	4/15/2014	4/21/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279873	4/15/2014	4/21/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279874	4/15/2014	4/29/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279875	4/15/2014	4/29/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279876	4/15/2014	4/10/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280903	4/18/2014	4/29/2014		PM - Domestic Water Heater, Steam
FO-280904	4/18/2014	4/29/2014		PM - Domestic Water Heater, Steam
FO-280905	4/21/2014			PM - Domestic Water Heater, Steam
FO-280906	4/21/2014			PM - Domestic Water Heater, Steam

WO	Recieved	Finished	Total	Request
FO-280907	4/21/2014			PM - Domestic Water Heater, Steam
FO-279566	4/25/2014			Generator Maintenance, Monthly
FO-279567	4/25/2014			Generator Maintenance, Monthly
FO-281569	4/25/2014			PM - Condensate Return Pump
FO-281570	4/25/2014			PM - Condensate Return Pump
FO-281571	4/25/2014			PM - Condensate Return Pump
E - North			87	
FO-277480	4/1/2014	4/21/2014		Replace PRE-filters
FO-277481	4/1/2014	4/9/2014		Replace PRE-filters
FO-277482	4/1/2014	4/21/2014		Replace PRE-filters
FO-277483	4/1/2014	4/8/2014		Replace PRE-filters
FO-278640	4/1/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278641	4/1/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278642	4/1/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278643	4/1/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278644	4/1/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278645	4/1/2014	4/22/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278646	4/1/2014	4/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278647	4/1/2014	4/14/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278648	4/1/2014	4/25/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278649	4/1/2014	4/25/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278650	4/1/2014	4/11/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278651	4/1/2014	4/11/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278652	4/1/2014	4/21/2014		PM - Cooling Tower Start-up
FO-279287	4/2/2014			PM - Heat Exchanger and Economizer
FO-279288	4/2/2014	4/22/2014		PM - Heat Exchanger and Economizer
FO-279289	4/2/2014	4/25/2014		PM - Heat Exchanger and Economizer
FO-279290	4/2/2014	4/25/2014		PM - Heat Exchanger and Economizer
FO-279291	4/2/2014	4/28/2014		PM - Heat Exchanger and Economizer
FO-279284	4/3/2014			PM - Forced Air Furnace (Jacob House) - Summer
FO-279285	4/3/2014			PM - Forced Air Furnace (Jacob House) - Summer
FO-279286	4/3/2014			PM - Forced Air Furnace (Jacob House) - Summer
FO-279282	4/4/2014	4/2/2014		PM - Unspecified
FO-279283	4/4/2014	4/2/2014		PM - Unspecified
FO-279292	4/7/2014	4/11/2014		PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-279580	4/11/2014	4/30/2014		Generator Maintenance, Monthly
FO-279877	4/11/2014		4/2/2014	PM - Air Handling Unit
FO-279878	4/11/2014		4/2/2014	PM - Air Handling Unit
FO-279879	4/11/2014		4/2/2014	PM - Air Handling Unit
FO-279880	4/11/2014		4/2/2014	PM - Air Handling Unit
FO-279891	4/11/2014			PM - Sump Pump
FO-279892	4/11/2014			PM - Sump Pump
FO-279893	4/11/2014			PM - Sump Pump
FO-279894	4/11/2014			PM - Sump Pump
FO-279895	4/11/2014			PM - Sump Pump
FO-279896	4/11/2014			PM - Sump Pump
FO-279897	4/11/2014			PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-279898	4/11/2014			PM - Sump Pump
FO-279899	4/11/2014			PM - Sump Pump
FO-279900	4/11/2014			PM - Sump Pump
FO-279901	4/11/2014			PM - Sump Pump
FO-279902	4/11/2014			PM - Sump Pump
FO-279881	4/15/2014	4/10/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279882	4/15/2014	4/9/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279883	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279884	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279885	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279886	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279887	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279888	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279889	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279890	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279903	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279904	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279905	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279906	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279907	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279908	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279909	4/15/2014			PM - Outside/Fresh Air Intake Screens
FO-279910	4/15/2014			PM - Condensate Return Pump
FO-279911	4/15/2014			PM - Condensate Return Pump
FO-279912	4/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-279913	4/15/2014	4/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279914	4/15/2014	4/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279915	4/15/2014	4/21/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280908	4/18/2014	4/9/2014		PM - Unspecified
FO-280909	4/18/2014	4/9/2014		PM - Unspecified
FO-280910	4/21/2014	4/15/2014		PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-279573	4/23/2014	4/24/2014		Generator Maintenance, Monthly
FO-281574	4/23/2014			PM - Heat Exchanger and Economizer
FO-281575	4/23/2014			PM - Heat Exchanger and Economizer
FO-281585	4/23/2014	4/24/2014		PM - Domestic Water Heater, Electric
FO-281576	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281577	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281578	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281579	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281580	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281581	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281582	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281583	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281584	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281572	4/25/2014	4/22/2014		PM - Sump Pump
FO-281573	4/25/2014	4/21/2014		PM - Sump Pump
FO-281586	4/27/2014			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
E - Northeast			49	
FO-278653	4/1/2014			PM - Water/Air Cooled Condenser
FO-278654	4/1/2014			PM - Water/Air Cooled Condenser
FO-278658	4/1/2014			PM - Water/Air Cooled Condenser
FO-278659	4/1/2014			PM - Water/Air Cooled Condenser
FO-278660	4/1/2014			PM - Water/Air Cooled Condenser
FO-278661	4/1/2014			PM - Water/Air Cooled Condenser
FO-278662	4/1/2014			PM - Water/Air Cooled Condenser
FO-278663	4/1/2014			PM - Water/Air Cooled Condenser
FO-278664	4/1/2014			PM - Water/Air Cooled Condenser
FO-278665	4/1/2014			PM - Water/Air Cooled Condenser
FO-278666	4/1/2014			PM - Water/Air Cooled Condenser
FO-278667	4/1/2014			PM - Water/Air Cooled Condenser
FO-278668	4/1/2014			PM - Water/Air Cooled Condenser
FO-278669	4/1/2014			PM - Water/Air Cooled Condenser
FO-278670	4/1/2014			PM - Water/Air Cooled Condenser
FO-278671	4/1/2014	4/4/2014		PM - Water/Air Cooled Condenser
FO-278672	4/1/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-278673	4/1/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-278674	4/1/2014	4/30/2014		PM - Water/Air Cooled Condenser
FO-278675	4/1/2014	4/30/2014		PM - Water/Air Cooled Condenser
FO-279293	4/4/2014			PM - Fan Coil/HV/AC Unit
FO-279294	4/4/2014			PM - Fan Coil/HV/AC Unit
FO-279295	4/4/2014			PM - Fan Coil/HV/AC Unit
FO-279297	4/4/2014	4/4/2014		Generator Maintenance, Monthly
FO-279298	4/4/2014	4/4/2014		Generator Maintenance, Monthly
FO-279299	4/4/2014	4/4/2014		Generator Maintenance, Monthly
FO-279300	4/4/2014	4/4/2014		Generator Maintenance, Monthly
FO-279918	4/11/2014			PM - Fan Coil/HV/AC Unit
FO-279919	4/11/2014			PM - Fan Coil/HV/AC Unit
FO-279920	4/11/2014			PM - Fan Coil/HV/AC Unit
FO-279921	4/11/2014			PM - Fan Coil/HV/AC Unit
FO-279296	4/15/2014			Generator Maintenance, Monthly
FO-279296	4/15/2014			Generator Maintenance, Monthly
FO-279916	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279917	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279922	4/15/2014	4/30/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279923	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-279924	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-279925	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-279926	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-279927	4/15/2014	4/25/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279579	4/17/2014	4/17/2014		Generator Maintenance, Monthly
FO-280911	4/18/2014			PM - Fan Coil/HV/AC Unit
FO-280912	4/18/2014			PM - Fan Coil/HV/AC Unit
FO-279565	4/23/2014			Generator Maintenance, Monthly
FO-281590	4/24/2014			PM - Domestic Water Heater, Gas

WO	Recieved	Finished	Total	Request
FO-281587	4/25/2014			PM - Fan Coil/HV/AC Unit
FO-281588	4/25/2014			PM - Fan Coil/HV/AC Unit
FO-281589	4/25/2014			PM - Fan Coil/HV/AC Unit
E - Preventative Maintenance			366	
FO-269709	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-269876	4/1/2014	4/2/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-275552	4/1/2014	4/4/2014		Replace PRE-filters
FO-275553	4/1/2014	4/5/2014		Replace PRE-filters
FO-275554	4/1/2014	4/5/2014		Replace PRE-filters
FO-275555	4/1/2014	4/4/2014		Replace PRE-filters
FO-275556	4/1/2014	4/4/2014		Replace PRE-filters
FO-275557	4/1/2014	4/17/2014		Replace PRE-filters
FO-275558	4/1/2014	4/17/2014		Replace PRE-filters
FO-275559	4/1/2014	4/30/2014		Replace PRE-filters
FO-275560	4/1/2014	4/30/2014		Replace PRE-filters
FO-275561	4/1/2014	5/1/2014		Replace PRE-filters
FO-275562	4/1/2014	4/26/2014		Replace PRE-filters
FO-275563	4/1/2014	4/30/2014		Replace PRE-filters
FO-275564	4/1/2014			Replace PRE-filters
FO-275565	4/1/2014	4/17/2018		Replace PRE-filters
FO-275566	4/1/2014	4/17/2014		Replace PRE-filters
FO-275567	4/1/2014	4/3/2014		Replace PRE-filters
FO-275568	4/1/2014	4/3/2014		Replace PRE-filters
FO-275569	4/1/2014	4/3/2014		Replace PRE-filters
FO-275570	4/1/2014	4/3/2014		Replace PRE-filters
FO-275571	4/1/2014	4/8/2014		PM - Air Handling Unit (ANNUAL)
FO-275572	4/1/2014	4/8/2014		PM - Air Handling Unit (ANNUAL)
FO-275573	4/1/2014	4/10/2014		PM - Air Handling Unit (ANNUAL)
FO-275574	4/1/2014	4/18/2014		PM - Air Handling Unit (ANNUAL)
FO-275575	4/1/2014	4/19/2014		PM - Air Handling Unit (ANNUAL)
FO-275576	4/1/2014	4/19/2014		PM - Air Handling Unit (ANNUAL)
FO-275577	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275578	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275579	4/1/2014	4/24/2014		PM - Air Handling Unit (ANNUAL)
FO-275580	4/1/2014	4/24/2014		PM - Air Handling Unit (ANNUAL)
FO-275581	4/1/2014	4/26/2014		PM - Air Handling Unit (ANNUAL)
FO-275582	4/1/2014	4/29/2014		PM - Air Handling Unit (ANNUAL)
FO-275583	4/1/2014	4/26/2014		PM - Air Handling Unit (ANNUAL)
FO-275584	4/1/2014	4/29/2014		PM - Air Handling Unit (ANNUAL)
FO-275585	4/1/2014	4/11/2014		Replace PRE-filters
FO-275949	4/1/2014			PM - Air Handling Unit (ANNUAL)
FO-277255	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277256	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277257	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277258	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277259	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277260	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-277308	4/1/2014	4/15/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277309	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277310	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277311	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277312	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277313	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277314	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277315	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277316	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277317	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277318	4/1/2014	4/26/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277319	4/1/2014	4/26/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277320	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277321	4/1/2014	4/26/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277322	4/1/2014	4/26/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277323	4/1/2014	4/26/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277324	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277325	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277326	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277327	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277328	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277329	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277330	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277331	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277332	4/1/2014	4/19/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277333	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277334	4/1/2014	4/28/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277335	4/1/2014	4/28/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277336	4/1/2014	4/28/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277337	4/1/2014	4/28/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277338	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277339	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277340	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277341	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277342	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277343	4/1/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-277344	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277345	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277346	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277347	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277348	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277349	4/1/2014			PM - Fan Coil/HV/AC Unit
FO-277350	4/1/2014	3/28/2014		Replace PRE-filters
FO-277351	4/1/2014	3/28/2014		Replace PRE-filters
FO-277352	4/1/2014	3/28/2014		Replace PRE-filters
FO-277353	4/1/2014	3/25/2014		Replace PRE-filters
FO-277354	4/1/2014	3/25/2014		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-277355	4/1/2014	3/26/2014		Replace PRE-filters
FO-277356	4/1/2014	4/1/2014		Replace PRE-filters
FO-277357	4/1/2014	4/1/2014		Replace PRE-filters
FO-277358	4/1/2014	4/1/2014		Replace PRE-filters
FO-277359	4/1/2014	4/1/2014		Replace PRE-filters
FO-277360	4/1/2014	4/1/2014		Replace PRE-filters
FO-277361	4/1/2014	4/1/2014		Replace PRE-filters
FO-277362	4/1/2014	4/1/2014		Replace PRE-filters
FO-277363	4/1/2014	4/22/2014		Replace PRE-filters
FO-277364	4/1/2014	3/28/2014		Replace PRE-filters
FO-277365	4/1/2014	3/27/2014		Replace PRE-filters
FO-277366	4/1/2014	4/29/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277367	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277368	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277369	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277370	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277371	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277372	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277373	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277374	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277375	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277376	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277377	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277378	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277379	4/1/2014	4/25/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277380	4/1/2014	4/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277381	4/1/2014	4/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277382	4/1/2014	4/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277383	4/1/2014	4/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277384	4/1/2014	4/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277385	4/1/2014	4/19/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277386	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277387	4/1/2014	4/19/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277388	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277389	4/1/2014	4/5/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277390	4/1/2014	4/23/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277391	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277392	4/1/2014	4/2/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277393	4/1/2014	4/18/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277394	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277395	4/1/2014	4/17/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277396	4/1/2014	4/9/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277397	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277398	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277399	4/1/2014	4/2/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277400	4/1/2014	4/11/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277401	4/1/2014	4/10/2014		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-277402	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277403	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277404	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277405	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277406	4/1/2014	4/9/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277407	4/1/2014	4/9/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277408	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277409	4/1/2014	4/17/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277410	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277411	4/1/2014	4/11/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277412	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277413	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277414	4/1/2014	4/16/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277415	4/1/2014	4/30/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277416	4/1/2014	4/23/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277417	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277418	4/1/2014	5/1/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277419	4/1/2014	5/1/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277420	4/1/2014	4/17/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277421	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277422	4/1/2014	4/11/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277423	4/1/2014	4/7/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277424	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277425	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277426	4/1/2014	4/7/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277427	4/1/2014	4/4/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277428	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277429	4/1/2014	4/2/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277430	4/1/2014	4/3/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277431	4/1/2014	3/27/2014		Replace PRE-filters
FO-277432	4/1/2014	3/27/2014		Replace PRE-filters
FO-277433	4/1/2014	3/29/2014		Replace PRE-filters
FO-277434	4/1/2014	3/29/2014		Replace PRE-filters
FO-277435	4/1/2014	4/16/2014		Replace PRE-filters
FO-277436	4/1/2014	4/18/2014		Replace PRE-filters
FO-277437	4/1/2014	4/22/2014		Replace PRE-filters
FO-277438	4/1/2014	4/23/2014		Replace PRE-filters
FO-277439	4/1/2014	4/24/2014		Replace PRE-filters
FO-277440	4/1/2014	4/22/2014		Replace PRE-filters
FO-277441	4/1/2014			Replace PRE-filters
FO-277442	4/1/2014	4/17/2014		Replace PRE-filters
FO-277448	4/1/2014	4/16/2014		Replace PRE-filters
FO-277449	4/1/2014	4/11/2014		Replace PRE-filters
FO-277450	4/1/2014	4/12/2014		Replace PRE-filters
FO-277451	4/1/2014	4/10/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-277454	4/1/2014		4/1/2014	Replace PRE-filters
FO-277455	4/1/2014		4/1/2014	Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-277456	4/1/2014		4/1/2014	Replace PRE-filters
FO-277457	4/1/2014	4/24/2014		Replace PRE-filters
FO-277458	4/1/2014	4/24/2014		Replace PRE-filters
FO-277459	4/1/2014		4/1/2014	Replace PRE-filters
FO-277460	4/1/2014		4/1/2014	Replace PRE-filters
FO-277461	4/1/2014		4/1/2014	Replace PRE-filters
FO-277462	4/1/2014		4/1/2014	Replace PRE-filters
FO-277463	4/1/2014		4/1/2014	Replace PRE-filters
FO-277464	4/1/2014		4/1/2014	Replace PRE-filters
FO-277465	4/1/2014		4/1/2014	Replace PRE-filters
FO-277466	4/1/2014		4/1/2014	Replace PRE-filters
FO-277467	4/1/2014		4/1/2014	Replace PRE-filters
FO-277468	4/1/2014		4/1/2014	Replace PRE-filters
FO-277469	4/1/2014		4/1/2014	Replace PRE-filters
FO-277470	4/1/2014	4/26/2014		Replace PRE-filters
FO-277471	4/1/2014	4/22/2014		Replace PRE-filters
FO-277472	4/1/2014	4/17/2014		Replace PRE-filters
FO-277473	4/1/2014	4/17/2014		Replace PRE-filters
FO-277474	4/1/2014	4/17/2014		Replace PRE-filters
FO-277475	4/1/2014	4/26/2014		Replace PRE-filters
FO-277476	4/1/2014	4/26/2014		Replace PRE-filters
FO-277477	4/1/2014	4/22/2014		Replace PRE-filters
FO-277478	4/1/2014	4/2/2014		Replace PRE-filters
FO-277479	4/1/2014	4/2/2014		Replace PRE-filters
FO-277484	4/1/2014			Replace PRE-filters
FO-277485	4/1/2014			Replace PRE-filters
FO-277486	4/1/2014			Replace PRE-filters
FO-277487	4/1/2014	4/19/2014		Replace PRE-filters
FO-277488	4/1/2014	4/22/2014		Replace PRE-filters
FO-277489	4/1/2014			Replace PRE-filters
FO-277490	4/1/2014			Replace PRE-filters
FO-277491	4/1/2014			Replace PRE-filters
FO-277492	4/1/2014			Replace PRE-filters
FO-277493	4/1/2014			Replace PRE-filters
FO-277494	4/1/2014			Replace PRE-filters
FO-277495	4/1/2014			Replace PRE-filters
FO-277496	4/1/2014			Replace PRE-filters
FO-277497	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277498	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277499	4/1/2014	4/8/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277951	4/1/2014	4/28/2014		Replace PRE-filters
FO-277952	4/1/2014	4/28/2014		Replace PRE-filters
FO-277953	4/1/2014	4/28/2014		Replace PRE-filters
FO-277954	4/1/2014	4/28/2014		Replace PRE-filters
FO-277955	4/1/2014	4/28/2014		Replace PRE-filters
FO-277956	4/1/2014	5/1/2014		Replace PRE-filters
FO-277957	4/1/2014	5/1/2014		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-277958	4/1/2014		4/2/2014	Replace PRE-filters
FO-277959	4/1/2014		4/2/2014	Replace PRE-filters
FO-277960	4/1/2014		4/2/2014	Replace PRE-filters
FO-277961	4/1/2014		4/2/2014	Replace PRE-filters
FO-277962	4/1/2014		4/2/2014	Replace PRE-filters
FO-277963	4/1/2014		4/2/2014	Replace PRE-filters
FO-277964	4/1/2014		4/2/2014	Replace PRE-filters
FO-277965	4/1/2014		4/2/2014	Replace PRE-filters
FO-277966	4/1/2014		4/2/2014	Replace PRE-filters
FO-277967	4/1/2014		4/2/2014	Replace PRE-filters
FO-277968	4/1/2014		4/2/2014	Replace PRE-filters
FO-277969	4/1/2014		4/2/2014	Replace PRE-filters
FO-277970	4/1/2014		4/2/2014	Replace PRE-filters
FO-277971	4/1/2014		4/2/2014	Replace PRE-filters
FO-277972	4/1/2014		4/2/2014	Replace PRE-filters
FO-279862	4/1/2014	4/17/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-282364	4/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-282365	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-282366	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-282367	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-282368	4/1/2014	4/23/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-282884	4/1/2014	4/30/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-277628	4/4/2014		4/1/2014	PM - Air Handling Unit
FO-278112	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278113	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278114	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278115	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278116	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278117	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278118	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278119	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278120	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278121	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278122	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278123	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278124	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278125	4/8/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278229	4/11/2014		4/1/2014	PM - Air Handling Unit
FO-278740	4/15/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278741	4/15/2014		4/8/2014	PM - Fan Coil/HV/AC Unit
FO-278742	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278743	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278744	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278745	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278746	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278747	4/15/2014			PM - Fan Coil/HV/AC Unit
FO-278748	4/15/2014			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-278872	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278873	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278874	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278875	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278876	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278877	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278878	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278879	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278880	4/17/2014			PM - Fan Motor Box (Old Main)
FO-278881	4/17/2014			PM - Fan Motor Box (Old Main)
FO-279342	4/20/2014		4/1/2014	PM - Unit/Space Heater
FO-279343	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279344	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279345	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279346	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279347	4/22/2014			PM - Fan Coil/HV/AC Unit
FO-279348	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279349	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279350	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279351	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279352	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279353	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279354	4/22/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-279355	4/22/2014			PM - Fan Coil/HV/AC Unit
FO-279356	4/22/2014			PM - Fan Coil/HV/AC Unit
FO-280044	4/29/2014			PM - Fan Coil/HV/AC Unit
FO-280045	4/29/2014			PM - Fan Coil/HV/AC Unit
FO-280046	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280047	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280048	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280049	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280050	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280051	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280052	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280053	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280054	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280055	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280056	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280057	4/29/2014	5/1/2014		PM - Fan Coil/HV/AC Unit
FO-280059	4/29/2014		4/2/2014	PM AHU - Belts & Lubrication
FO-280060	4/29/2014		4/2/2014	PM AHU - Belts & Lubrication
E - South			41	
FO-278676	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278677	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278678	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278679	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278723	4/1/2014	4/2/2014		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-278724	4/1/2014	4/2/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278725	4/1/2014	4/2/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278726	4/1/2014	4/2/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278727	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279339	4/2/2014	4/7/2014		PM INSPECT AND CLEAN COIL
FO-279340	4/2/2014	4/7/2014		PM INSPECT AND CLEAN COIL
FO-279341	4/2/2014	4/7/2014		PM INSPECT AND CLEAN COIL
FO-279317	4/8/2014	4/10/2014		Monthly AHU Inspection Clean Room Unit 2
FO-279318	4/8/2014			PM - Annual Inspection of Air Handling Unit
FO-279319	4/8/2014	4/10/2014		PM - Monthly AHU Inspection Clean Room Unit 1
FO-279562	4/10/2014	4/16/2014		Generator Maintenance, Monthly
FO-279563	4/10/2014	4/16/2014		Generator Maintenance, Monthly
FO-279577	4/10/2014	4/10/2014		Generator Maintenance, Monthly
FO-279328	4/15/2014	4/15/2014		Generator Maintenance, Monthly
FO-279929	4/15/2014	4/23/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279930	4/15/2014	4/17/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279934	4/15/2014	4/22/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-279936	4/15/2014	4/28/2014		PM - Heat Exchanger and Economizer
FO-279937	4/15/2014	4/28/2014		PM - Heat Exchanger and Economizer
FO-279945	4/15/2014	4/28/2014		PM - Water/Air Cooled Condenser
FO-279991	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280017	4/15/2014	4/17/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280031	4/15/2014	4/16/2014		PM - Centrifugal Pump, over 1 H.P.
FO-280032	4/15/2014	4/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-280033	4/15/2014	4/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-280034	4/15/2014	4/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-280035	4/15/2014	4/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-280036	4/15/2014	4/16/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280037	4/15/2014	4/16/2014		PM - Water Booster Pump
FO-280038	4/15/2014	4/16/2014		PM - Water Booster Pump
FO-280039	4/15/2014	4/16/2014		PM - Centrifugal Pump, over 1 H.P.
FO-280040	4/15/2014	4/16/2014		PM - Centrifugal Pump, over 1 H.P.
FO-280041	4/15/2014	4/16/2014		PM - Harmsco Side Stream Filter
FO-279564	4/16/2014	4/16/2014		Generator Maintenance, Monthly
FO-279581	4/17/2014	4/17/2014		Generator Maintenance, Monthly
FO-281610	4/24/2014	4/28/2014		PM - Roof Sumps - Zone 2, Area 3
E - Southeast			140	
FO-278684	4/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-278685	4/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-278686	4/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-278687	4/1/2014	4/2/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278688	4/1/2014	2/24/2014	4/29/2014	PM - Centrifugal Pump, over 1 H.P.
FO-278689	4/1/2014	2/24/2014	4/29/2014	PM - Centrifugal Pump, over 1 H.P.
FO-278690	4/1/2014	2/6/2014	4/29/2014	PM - Centrifugal Pump, over 1 H.P.
FO-278691	4/1/2014	2/6/2014	4/29/2014	PM - Centrifugal Pump, over 1 H.P.
FO-278692	4/1/2014	2/6/2014	4/29/2014	PM - Centrifugal Pump, over 1 H.P.
FO-278693	4/1/2014	4/25/2014		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-278694	4/1/2014	4/25/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278734	4/1/2014			PM - Water/Air Cooled Condenser
FO-279306	4/3/2014	4/3/2014		PM - Heat Pumps (5057 Woodward)
FO-279307	4/3/2014	4/3/2014		PM - Heat Pumps (5057 Woodward)
FO-279308	4/3/2014	4/3/2014		PM - Heat Pumps (5057 Woodward)
FO-279309	4/3/2014	4/3/2014		PM - Heat Pumps (5057 Woodward)
FO-279310	4/3/2014	4/3/2014		PM - Heat Pumps (5057 Woodward)
FO-279311	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279312	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279313	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279314	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279315	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279316	4/3/2014	4/4/2014		PM - Heat Pumps (5057 Woodward)
FO-279322	4/3/2014	4/18/2014		PM - Domestic Water Heater, Electric
FO-279323	4/3/2014			PM - Domestic Water Heater, Gas
FO-279301	4/4/2014	4/16/2014		PM - Chemical Feed/Metering Pump/Controller
FO-279302	4/4/2014	4/16/2014		PM - Chemical Feed/Metering Pump/Controller
FO-279303	4/4/2014	4/16/2014		PM - Chemical Feed/Metering Pump/Controller
FO-279304	4/4/2014	4/16/2014		PM - Chemical Feed/Metering Pump/Controller
FO-279325	4/4/2014			PM - Harmsco Side Stream Filter
FO-279326	4/4/2014			PM - Harmsco Side Stream Filter
FO-279946	4/10/2014	4/10/2014		PM - Heat Exchanger and Economizer
FO-279947	4/10/2014	4/10/2014		PM - Heat Exchanger and Economizer
FO-279949	4/10/2014	4/10/2014		PM - Heat Pumps (5057 Woodward)
FO-279950	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279951	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279952	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279953	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279954	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279955	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279956	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279957	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279958	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279959	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279960	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279961	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279962	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279963	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279964	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279965	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279966	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279967	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279968	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279969	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279970	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279971	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279972	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-279973	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279974	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279975	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279976	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279977	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279978	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279979	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279980	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279981	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279982	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279983	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279984	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279985	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-279986	4/10/2014	4/11/2014		PM - Heat Pumps (5057 Woodward)
FO-280005	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280006	4/10/2014	4/14/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280007	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280008	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280009	4/10/2014	4/14/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280010	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280011	4/10/2014	4/14/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280012	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-280013	4/10/2014	4/10/2014		PM - Chilled Water Coils - Refill (Old Main)
FO-279281	4/15/2014	4/29/2014		Generator Maintenance, Monthly
FO-279331	4/15/2014	4/29/2014		Generator Maintenance, Monthly
FO-279333	4/15/2014	4/29/2014		Generator Maintenance, Monthly
FO-279928	4/15/2014			PM - Centrifugal Pump, over 1 H.P.
FO-279931	4/15/2014			PM - Centrifugal Pump, over 1 H.P.
FO-279932	4/15/2014			PM - Centrifugal Pump, over 1 H.P.
FO-279933	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279935	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279948	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279989	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279990	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279992	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280018	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280042	4/15/2014	4/29/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280043	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-280916	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)
FO-280917	4/17/2014	4/17/2014		PM - Heat Pumps (5057 Woodward)
FO-280918	4/17/2014	4/17/2014		PM - Heat Pumps (5057 Woodward)
FO-280919	4/17/2014	4/17/2014		PM - Heat Pumps (5057 Woodward)
FO-280920	4/17/2014	4/17/2014		PM - Heat Pumps (5057 Woodward)
FO-280921	4/17/2014	4/17/2014		PM - Heat Pumps (5057 Woodward)
FO-280922	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)
FO-280923	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)
FO-280924	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-280925	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)
FO-280926	4/17/2014	4/18/2014		PM - Heat Pumps (5057 Woodward)
FO-280913	4/18/2014			PM - Condensate Return Pump
FO-280914	4/18/2014			PM - Condensate Return Pump
FO-280927	4/22/2014			PM - Domestic Water Heater, Gas
FO-281618	4/23/2014			Gas Fired Furnace
FO-281619	4/23/2014	4/22/2014		PM - Humidifier
FO-281622	4/23/2014			Gas Fired Furnace
FO-281623	4/23/2014			Gas Fired Furnace
FO-281624	4/23/2014			Gas Fired Furnace
FO-281591	4/24/2014	4/24/2014		PM - Air Handling Unit
FO-281592	4/24/2014	4/24/2014		PM - Air Handling Unit
FO-281593	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281594	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281595	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281596	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281597	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281598	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281599	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281600	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281601	4/24/2014	4/25/2014		PM - Heat Pumps (5057 Woodward)
FO-281602	4/24/2014	4/28/2014		PM - Heat Pumps (5057 Woodward)
FO-281603	4/24/2014	4/28/2014		PM - Heat Pumps (5057 Woodward)
FO-281604	4/24/2014	4/28/2014		PM - Roof Sumps - Zone 2, Area 3
FO-281605	4/24/2014	4/21/2014		PM - Roof Sumps - Zone 2, Area 3
FO-281606	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281607	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281608	4/24/2014	4/28/2014		PM - Roof Sumps - Zone 2, Area 3
FO-281609	4/24/2014	4/30/2014		PM - Roof Sumps - Zone 2, Area 3
FO-281611	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281612	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281613	4/24/2014			PM - Roof Sumps - Zone 2, Area 3
FO-281614	4/24/2014	4/29/2014		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-281615	4/24/2014	4/29/2014		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-281616	4/24/2014	4/29/2014		PM - Steam Valves to PreHeat Coils - Close (Old Main)
FO-281617	4/24/2014	4/29/2014		PM - Steam Valves to PreHeat Coils - Close (Old Main)
E - West			61	
FO-275588	4/1/2014	4/7/2014		PM - Air Handling Unit (ANNUAL)
FO-275589	4/1/2014			PM - Air Handling Unit (ANNUAL)
FO-275590	4/1/2014	4/21/2014		PM - Air Handling Unit (ANNUAL)
FO-275591	4/1/2014	4/21/2014		PM - Air Handling Unit (ANNUAL)
FO-275592	4/1/2014	4/21/2014		PM - Air Handling Unit (ANNUAL)
FO-275593	4/1/2014	4/9/2014		PM - Air Handling Unit (ANNUAL)
FO-275594	4/1/2014	4/9/2014		PM - Air Handling Unit (ANNUAL)
FO-275595	4/1/2014	4/9/2014		PM - Air Handling Unit (ANNUAL)
FO-275596	4/1/2014	4/11/2014		PM - Air Handling Unit (ANNUAL)
FO-275597	4/1/2014	4/18/2014		PM - Air Handling Unit (ANNUAL)

WO	Recieved	Finished	Total	Request
FO-275598	4/1/2014	4/18/2014		PM - Air Handling Unit (ANNUAL)
FO-275599	4/1/2014	4/18/2014		PM - Air Handling Unit (ANNUAL)
FO-275600	4/1/2014	4/21/2014		PM - Air Handling Unit (ANNUAL)
FO-275601	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275602	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275603	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275604	4/1/2014	4/22/2014		PM - Air Handling Unit (ANNUAL)
FO-275605	4/1/2014	4/23/2014		PM - Air Handling Unit (ANNUAL)
FO-275606	4/1/2014	4/23/2014		PM - Air Handling Unit (ANNUAL)
FO-275607	4/1/2014	4/23/2014		PM - Air Handling Unit (ANNUAL)
FO-278698	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278699	4/1/2014	4/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278700	4/1/2014	4/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278701	4/1/2014	4/7/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278702	4/1/2014	4/7/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278703	4/1/2014	4/8/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278704	4/1/2014	4/8/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278705	4/1/2014	4/9/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278706	4/1/2014	4/9/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278707	4/1/2014	4/10/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278708	4/1/2014	4/11/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278709	4/1/2014	4/15/2014		PM - Centrifugal Pump, over 1 H.P.
FO-278710	4/1/2014			PM - Water/Air Cooled Condenser
FO-278711	4/1/2014			PM - Water/Air Cooled Condenser
FO-279324	4/3/2014			PM - Domestic Water Heater, Electric
FO-279305	4/5/2014	4/18/2014		PM - Heat Exchanger and Economizer
FO-278733	4/8/2014			Generator Maintenance, Monthly
FO-280016	4/10/2014			PM - Domestic Water Heater, Electric
FO-279939	4/13/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279940	4/13/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279941	4/13/2014	4/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279942	4/13/2014	4/22/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279943	4/13/2014	4/22/2014		PM - Centrifugal Pump, over 1 H.P.
FO-279938	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279944	4/15/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-279987	4/15/2014			PM - Clean MEB AC unit Condenser
FO-279988	4/15/2014			PM - Clean MEB AC unit Condenser
FO-279993	4/15/2014			PM - Water/Air Cooled Condenser
FO-279994	4/15/2014			PM - Water/Air Cooled Condenser
FO-279995	4/15/2014			PM - Water/Air Cooled Condenser
FO-279996	4/15/2014			PM - Water/Air Cooled Condenser
FO-279997	4/15/2014			PM - Water/Air Cooled Condenser
FO-279998	4/15/2014			PM - Water/Air Cooled Condenser
FO-279999	4/15/2014			PM - Water/Air Cooled Condenser
FO-280000	4/15/2014			PM - Water/Air Cooled Condenser
FO-280001	4/15/2014			PM - Water/Air Cooled Condenser
FO-280002	4/15/2014			PM - Water/Air Cooled Condenser

WO	Recieved	Finished	Total	Request
FO-280003	4/15/2014			PM - Clean MEB AC unit Condenser
FO-280004	4/15/2014			PM - Clean MEB AC unit Condenser
FO-280015	4/15/2014	4/15/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-280915	4/20/2014	4/23/2014		PM - Water Softener
Trades			33	
Medium			1	
T - Plumber			1	
FO-281483	4/14/2014	4/14/2014		PM Vacuum pump system. Finished 4/4/13LT
Routine			32	
T - Electrician			32	
FO-279543	4/4/2014	4/4/2014		Generator Test Friday 4/4/2014 @ 2:15.. Finished 4/7/2014LT
FO-279553	4/4/2014	4/4/2014		Generator Test Friday 4/4/2014 @ 7:15 AM.. Finished 4/7/2014LT
FO-279559	4/4/2014	4/4/2014		Generator Test Friday 4/4/2014 @ 2:15 PM.. Finished 4/7/2014LT
FO-279560	4/4/2014	4/4/2014		Generator Test Friday 4/4/2014 @ 2:15 PM.. Finished 4/7/2014LT
FO-279561	4/4/2014	4/4/2014		Generator Test Friday 4/4/2014 @ 7:15 PM.. Finished 4/7/2014LT
FO-279557	4/8/2014	4/7/2014		Generator Test Tuesday 4/8/2014 @ 7:15 AM. Finished 4/11/2014LT
FO-278712	4/8/2014	4/7/2014		Generator Test Tuesday 4/8/2014 @ 1PM. Finished 4/11/2014LT
FO-279334	4/9/2014	4/9/2014		Generator Test Wednesday 4/9/2014 @ 1PM. Finished 4/11/2014LT
FO-279537	4/10/2014	4/10/2014		Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/11/2014LT
FO-279538	4/10/2014	4/10/2014		Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/11/2014LT
FO-279554	4/10/2014	4/10/2014		Generator Test Thursday 4/10/2014 @ 9:30 AM. Finished 4/11/2014LT
FO-279550	4/11/2014	4/11/2014		Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT
FO-279551	4/11/2014	4/11/2014		Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT
FO-279556	4/11/2014	4/11/2014		Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT
FO-279329	4/15/2014	4/16/2014		Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/18/2014LT
FO-279336	4/15/2014	4/16/2014		Generator Test Tuesday 4/15/2014 @ 9:15 AM. Finished 4/18/2014LT
FO-279327	4/15/2014	4/16/2014		Generator Test Tuesday 4/15/2014 @ 7:15 AM. Finished 4/18/2014LT
FO-279330	4/15/2014	4/16/2014		Generator Test Tuesday 4/15/2014 @ 8:15 AM. Finished 4/18/2014LT
FO-279332	4/15/2014	4/16/2014		Generator Test Tuesday 4/15/2014 @ 8:15 AM. Finished 4/18/2014LT
FO-279539	4/16/2014	4/16/2014		Generator Test Wednesday 4/16/2014 @ 10AM. Finished 4/18/2014LT
FO-279552	4/16/2014	4/17/2014		Generator Test Wednesday 4/16/2014 @ 7:15 AM. Finished 4/18/2014LT
FO-279555	4/17/2014	4/17/2014		Generator Test Thursday 4/17/2014 @ 7:15 AM. Finished 4/18/2014LT
FO-279558	4/17/2014	4/17/2014		Generator Test Thursday 4/17/2014 @ 7:15 AM. Finished 4/18/2014LT
FO-279544	4/22/2014	4/22/2014		Generator Test Tuesday 4/22/2014 @ 10AM.Finished 4/23/2014LT
FO-279545	4/22/2014	4/22/2014		Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT
FO-279546	4/22/2014	4/22/2014		Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT
FO-279547	4/22/2014	4/22/2014		Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT
FO-279548	4/22/2014	4/22/2014		Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT
FO-279540	4/23/2014	4/23/2014		Generator Test Wednesday 4/23/2014 @ 7:15 AM. Finished 4/23/2014LT
FO-279549	4/23/2014	4/23/2014		Generator Test Wednesday 4/23/2014 @ 7:15 AM. Finished 4/23/2014LT
FO-279541	4/25/2014	4/25/2014		Generator Test Friday 4/25/2014 @ 7:15 AM. Finished 4/29/2014LT
FO-279542	4/25/2014	4/25/2014		Generator Test Friday 4/25/2014 @ 10AM. Finished 4/29/2014LT

Total: 2891