

# Facilities Operations PM DUE DATE Analysis from 12/01/2013 through 12/31/2013

Finish Date Due Date

Total per Trade

## Engineering

125 of 252 50%

### E - Auxiliary

13 of 37 35%

FO-270709	Routine	Scheduled Maint. (PM)	12/13/2013	12/15/2013	2	PM - Cooling Tower, 500 - 1000 Tons	Isolated, drained and rinsed out tower.	False
FO-270710	Routine	Scheduled Maint. (PM)	12/13/2013	12/15/2013	2	PM - Cooling Tower, 500 - 1000 Tons	Isolated, drained flushed and laid up for the winter.	False
FO-270720	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	PM - Emergency Shower/Eyewash Station	tested system	False
FO-268752	Routine	Scheduled Maint. (PM)	12/10/2013	12/11/2013	1	Generator Maintenance, Monthly	Assisted with test. Checked fluid levels, battery condition and cleaned area.	False
FO-268754	Routine	Scheduled Maint. (PM)	12/11/2013	12/12/2013	1	Generator Maintenance, Monthly	Found oil level low after the last PM by the contractor. Ask elect. to reschedule test when level is restored.	False
FO-270721	Routine	Scheduled Maint. (PM)	12/13/2013	12/14/2013	1	PM - Emergency Shower/Eyewash Station	Tested system.	False
FO-270722	Routine	Scheduled Maint. (PM)	12/20/2013	12/21/2013	1	PM - Emergency Shower/Eyewash Station	Tested system	False
FO-268732	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels, batteries and voltage output	False
FO-268734	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels, batteries and system operation.	False
FO-268736	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels, batteries and system operation.	False
FO-268738	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels, batteries and system operation.	False
FO-268740	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels, batteries and system operation. Closed out FO	False
FO-268762	Routine	Scheduled Maint. (PM)	12/18/2013	12/18/2013	0	Generator Maintenance, Monthly	Checked fluid levels, batteries and assisted with test.	False
FO-270707	Routine	Scheduled Maint. (PM)	12/18/2013	12/15/2013	-3	PM - Cooling Tower, 500 - 1000 Tons	Tower isolated, drained, swept out, rinsed out and laid up for winter.	False
FO-262704	Routine	Scheduled Maint. (PM)	12/4/2013	11/30/2013	-4	PM - Heat Exchanger and Economizer	Checked units operation.	False
FO-262705	Routine	Scheduled Maint. (PM)	12/4/2013	11/30/2013	-4	PM - Heat Exchanger and Economizer	Checked units operation.	False
FO-262706	Routine	Scheduled Maint. (PM)	12/4/2013	11/30/2013	-4	PM - Heat Exchanger and Economizer	Checked units operation.	False
FO-270706	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons	Tower drained, swept out, rinsed out and chemical feed system removed.	False
FO-270665	Routine	Scheduled Maint. (PM)	12/20/2013	12/15/2013	-5	PM - Cooling Tower, 500 - 1000 Tons	Tower drained, swept out and power washed.	False
FO-270704	Routine	Scheduled Maint. (PM)	12/20/2013	12/15/2013	-5	PM - Cooling Tower, 500 - 1000 Tons	Tower drained, swept out, rinsed out and the chemical feed system removed.	False
FO-270705	Routine	Scheduled Maint. (PM)	12/20/2013	12/15/2013	-5	PM - Cooling Tower, 500 - 1000 Tons	Tower drained, swept out, rinsed out and the chemical feed system removed.	False
FO-270726	Routine	Scheduled Maint. (PM)	12/12/2013	11/15/2013	-27	PM - Air Handling Unit, HV Type	Changed air filters, checked belts and dampers, cycled burner and tested controls.	False

			Finish Date	Due Date	Total per Trade				
FO-262685	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Air Handling Unit	Changed filters, checked belts, lubed bearings and motor.	False	
FO-270713	Routine	Scheduled Maint. (PM)	12/18/2013	11/15/2013	-33	PM - Air Handling Unit, HV Type	Changed air filters, checked belts and dampers, tested burner and controls.	False	
FO-263255	Routine	Scheduled Maint. (PM)	12/4/2013	10/27/2013	-38	PM - Centrifugal Pump, over 1 H.P.	Checked operation, lubed bearings and motor, cleaned area.	False	
FO-262690	Routine	Scheduled Maint. (PM)	12/2/2013	10/22/2013	-41	PM - Air Handling Unit	Changed filters and checked unit operation.	False	
FO-262691	Routine	Scheduled Maint. (PM)	12/2/2013	10/22/2013	-41	PM - Air Handling Unit	Changed filters and checked unit operation.	False	
FO-262688	Routine	Scheduled Maint. (PM)	12/2/2013	10/22/2013	-41	PM - Air Handling Unit	Changed filters and checked unit operation.	False	
FO-262687	Routine	Scheduled Maint. (PM)	12/2/2013	10/22/2013	-41	PM - Air Handling Unit	Changed filters and checked ooperation.	False	
FO-262689	Routine	Scheduled Maint. (PM)	12/2/2013	10/22/2013	-41	PM - Air Handling Unit	Changed filters and checked unit operation.	False	
FO-263256	Routine	Scheduled Maint. (PM)	12/4/2013	10/13/2013	-52	PM - Centrifugal Pump, over 1 H.P.	Checked operation and pressures, lubed bearings and motor, cleaned area.	False	
FO-262698	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked unit operation.	False	
FO-262699	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked unit operation.	False	
FO-262701	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked unit operation.	False	
FO-262702	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked units operation.	False	
FO-262703	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked units operation.	False	
FO-262710	Routine	Scheduled Maint. (PM)	12/4/2013	10/8/2013	-57	PM - Centrifugal Pump, over 1 H.P.	Checked units operation.	False	
E - MedPharm							2 of 7	29%	
FO-268748	Routine	Scheduled Maint. (PM)	12/13/2013	12/14/2013	1	Generator Maintenance, Monthly		False	
FO-268750	Routine	Scheduled Maint. (PM)	12/13/2013	12/14/2013	1	Generator Maintenance, Monthly		False	
FO-262483	Routine	Scheduled Maint. (PM)	12/4/2013	12/2/2013	-2	PM - Centrifugal Pump, over 1 H.P.		False	
FO-266343	Routine	Scheduled Maint. (PM)	12/17/2013	11/9/2013	-38	Generator Maintenance, Monthly		False	
FO-266345	Routine	Scheduled Maint. (PM)	12/17/2013	11/9/2013	-38	Generator Maintenance, Monthly		False	
FO-260763	Routine	Scheduled Maint. (PM)	12/17/2013	10/12/2013	-66	Generator Maintenance, Monthly		False	
FO-260761	Routine	Scheduled Maint. (PM)	12/17/2013	10/12/2013	-66	Generator Maintenance, Monthly		False	
E - North							3 of 17	18%	
FO-270311	Routine	Scheduled Maint. (PM)	12/19/2013	1/4/2014	16	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB Rooftop Units]		False	
FO-270310	Routine	Scheduled Maint. (PM)	12/17/2013	12/21/2013	4	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB Rooftop Units]		False	
FO-269264	Routine	Scheduled Maint. (PM)	12/4/2013	12/7/2013	3	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB Rooftop Units]		False	
FO-270253	Routine	Scheduled Maint. (PM)	12/17/2013	12/15/2013	-2	PM - Punch Tubes - Chiller/Absorber		False	
FO-270233	Routine	Scheduled Maint. (PM)	12/18/2013	12/15/2013	-3	PM - Punch Tubes - Chiller/Absorber		False	
FO-262579	Routine	Scheduled Maint. (PM)	12/13/2013	11/30/2013	-13	PM - Centrifugal Pump, over 1 H.P.	Lubricated pump, checked operation	False	
FO-262580	Routine	Scheduled Maint. (PM)	12/13/2013	11/30/2013	-13	PM - Centrifugal Pump, over 1 H.P.	Checked pump operation, lubricated	False	

			Finish Date	Due Date					Total per Trade	
FO-262544	Routine	Scheduled Maint. (PM)	12/16/2013	11/30/2013	-16	PM - Centrifugal Pump, over 1 H.P.			False	
FO-260519	Routine	Scheduled Maint. (PM)	12/4/2013	11/14/2013	-20	PM - Water/Air Cooled Condenser			Cleaned coil, changed filters checked operation of unit.	False
FO-260520	Routine	Scheduled Maint. (PM)	12/4/2013	11/14/2013	-20	PM - Water/Air Cooled Condenser			Cleaned coil, changed filters, checked unit op.	False
FO-260521	Routine	Scheduled Maint. (PM)	12/4/2013	11/14/2013	-20	PM - Water/Air Cooled Condenser			Cleaned coils, checked unit operation	False
FO-262564	Routine	Scheduled Maint. (PM)	12/16/2013	11/15/2013	-31	PM - Centrifugal Pump, over 1 H.P.			At this time, Trane Tech. is working on chiller. I am not able to work on the pump as I would be in the way of chiller repairs.	False
									Found no problems while servicing pump.	
FO-262565	Routine	Scheduled Maint. (PM)	12/16/2013	11/15/2013	-31	PM - Centrifugal Pump, over 1 H.P.			At this time, Trane Tech is working on chiller replacment control panel, and I would be in the way of repairs if I worked on cond pump.	False
									Finished servicing pump, and found no problems to report.	
FO-262563	Routine	Scheduled Maint. (PM)	12/17/2013	11/15/2013	-32	PM - Centrifugal Pump, over 1 H.P.			Serviced pump and found no problems to report.	False
FO-260524	Routine	Scheduled Maint. (PM)	12/18/2013	11/11/2013	-37	PM - Water/Air Cooled Condenser				False
FO-260523	Routine	Scheduled Maint. (PM)	12/20/2013	11/11/2013	-39	PM - Water/Air Cooled Condenser				False
FO-262545	Routine	Scheduled Maint. (PM)	12/16/2013			PM - Centrifugal Pump, over 1 H.P.				False
E - Northeast									6 of 29	21%
FO-268724	Routine	Scheduled Maint. (PM)	12/12/2013	12/26/2013	14	Generator Maintenance, Monthly			levels good. belts good. flexible connections good. dampers DID NOT CLOSE COMPLETELY. HOSE CLAMPS SHOW SOME SIGNS OF CORROSION. fuel level is good.	False
FO-268768	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Maintenance, Monthly				False
FO-268779	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Maintenance, Monthly				False
FO-268774	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Maintenance, Monthly				False
FO-268776	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Maintenance, Monthly				False
FO-268764	Routine	Scheduled Maint. (PM)	12/19/2013	12/19/2013	0	Generator Maintenance, Monthly			checked gas train, ckecked oil level block heaters battery conections, water level,exhaust system, damper motors	False
FO-266319	Routine	Scheduled Maint. (PM)	12/2/2013	11/28/2013	-4	Generator Maintenance, Monthly			checked levels, belts, flexible hose connections, etc. there has been on problem with the float sticking for the transfer pump. A.H. has req in.	False
FO-262613	Routine	Scheduled Maint. (PM)	12/2/2013	11/15/2013	-17	PM - Centrifugal Pump, over 1 H.P.			This HW circ. pump is no longer there. It has been removed. The bearing assembly is there, but not the pump.	False
FO-262614	Routine	Scheduled Maint. (PM)	12/2/2013	11/15/2013	-17	PM - Centrifugal Pump, over 1 H.P.			this pump does not work. needs taken apart. shaft is frozen. motor may be good. needs further follow up. I lubricated it. still didn't move. will submit work request.	False

			Finish Date	Due Date	Total per Trade			
FO-266366	Routine	Scheduled Maint. (PM)	12/2/2013	11/14/2013	-18	Generator Maintenance, Monthly	inspected levels, flexible connections, and belts. Fuel level 3/8th when checked.	False
FO-258072	Routine	Scheduled Maint. (PM)	12/12/2013	11/16/2013	-26	PM - Domestic Water Heater, Steam	This HEX is currently out of service. The controls appear to work, but the HEX is isolated and no related pumps are operable. This needs further attention.	True
FO-262628	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.		False
FO-262629	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.		False
FO-262622	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.	lubricated pump and motor bearings inspected coupling	False
FO-262623	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.	lubricated motor and pump, inspected coupling, checked operation	False
FO-262624	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.	lubricated motor and bearing assmby checked coupling	False
FO-262625	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.	lubricated motor and bearing assmby, checked operation, checked coupling	False
FO-262626	Routine	Scheduled Maint. (PM)	12/2/2013	10/31/2013	-32	PM - Centrifugal Pump, over 1 H.P.	pump no longer in service. Please trmove from system	False
FO-260737	Routine	Scheduled Maint. (PM)	12/2/2013	10/24/2013	-39	Generator Maintenance, Monthly		False
FO-262615	Routine	Scheduled Maint. (PM)	12/9/2013	10/31/2013	-39	PM - Centrifugal Pump, over 1 H.P.	inspected pump. checked alignment. checked for proper operation. lubricated. cleaned.	False
FO-262616	Routine	Scheduled Maint. (PM)	12/9/2013	10/31/2013	-39	PM - Centrifugal Pump, over 1 H.P.	inspected pump. checked alignment. checked for proper operation. lubricated. cleaned.	False
FO-262618	Routine	Scheduled Maint. (PM)	12/11/2013	10/31/2013	-41	PM - Centrifugal Pump, over 1 H.P.	this circ pump is obsolete. system is no longer in service. please remove from pm's.	False
FO-259250	Routine	Scheduled Maint. (PM)	12/3/2013	10/19/2013	-45	PM - Unit/Space Heater	checked operation lubricated bearings, checked thermostat, cleaned coils	False
FO-259252	Routine	Scheduled Maint. (PM)	12/3/2013	10/19/2013	-45	PM - Unit/Space Heater	lubricated bearings cleaned coil checked operation checked thermostat	False
FO-259251	Routine	Scheduled Maint. (PM)	12/4/2013	10/19/2013	-46	PM - Unit/Space Heater	checked operation, bearning have been ordered, cheched operation of thermostat.	False
FO-259248	Routine	Scheduled Maint. (PM)	12/4/2013	10/19/2013	-46	PM - Unit/Space Heater	This unit is radiation only ,no filter, no motor , no fan. cleaned fins released air from auto vent	False
FO-259249	Routine	Scheduled Maint. (PM)	12/4/2013	10/19/2013	-46	PM - Unit/Space Heater	Checked operation, cleaned filter, lubricated bearings, checked thermostat	False
FO-260525	Routine	Scheduled Maint. (PM)	12/2/2013	10/14/2013	-49	PM - Sump Pump	checked operation lubricated	False
FO-260526	Routine	Scheduled Maint. (PM)	12/2/2013	10/14/2013	-49	PM - Sump Pump		False
E - Preventative Maintenance							85 of 116	73%
FO-269546	Routine	Scheduled Maint. (PM)	12/20/2013	1/28/2014	39	PM - Fan Coil/HV/AC Unit		False
FO-269544	Routine	Scheduled Maint. (PM)	12/20/2013	1/28/2014	39	PM - Fan Coil/HV/AC Unit		False
FO-269545	Routine	Scheduled Maint. (PM)	12/20/2013	1/28/2014	39	PM - Fan Coil/HV/AC Unit		False

			Finish Date	Due Date				Total per Trade
FO-270827	Routine	Scheduled Maint. (PM)	12/24/2013	1/28/2014	35	PM - Fan Coil/HV/AC Unit		False
FO-270828	Routine	Scheduled Maint. (PM)	12/24/2013	1/28/2014	35	PM - Fan Coil/HV/AC Unit		False
FO-270826	Routine	Scheduled Maint. (PM)	12/24/2013	1/28/2014	35	PM - Fan Coil/HV/AC Unit		False
FO-270824	Routine	Scheduled Maint. (PM)	12/24/2013	1/28/2014	35	PM - Fan Coil/HV/AC Unit		False
FO-270825	Routine	Scheduled Maint. (PM)	12/24/2013	1/28/2014	35	PM - Fan Coil/HV/AC Unit		False
FO-267797	Routine	Scheduled Maint. (PM)	12/14/2013	1/6/2014	23	PM - Air Handling Unit		False
FO-267798	Routine	Scheduled Maint. (PM)	12/14/2013	1/6/2014	23	PM - Air Handling Unit		False
FO-267799	Routine	Scheduled Maint. (PM)	12/14/2013	1/6/2014	23	PM - Air Handling Unit		False
FO-267795	Routine	Scheduled Maint. (PM)	12/14/2013	1/6/2014	23	PM - Air Handling Unit		False
FO-267796	Routine	Scheduled Maint. (PM)	12/14/2013	1/6/2014	23	PM - Air Handling Unit		False
FO-263429	Routine	Scheduled Maint. (PM)	12/13/2013	1/3/2014	21	PM - Air Handling Unit		False
FO-267164	Routine	Scheduled Maint. (PM)	12/11/2013	12/31/2013	20	PM - Fan Coil/HV/AC Unit		False
FO-267163	Routine	Scheduled Maint. (PM)	12/11/2013	12/31/2013	20	PM - Fan Coil/HV/AC Unit		False
FO-266572	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266578	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266560	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266566	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266574	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266563	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266589	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266590	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266596	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266570	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266569	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266579	Routine	Scheduled Maint. (PM)	12/12/2013	12/31/2013	19	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-267781	Routine	Scheduled Maint. (PM)	12/19/2013	1/7/2014	19	PM - Fan Coil/HV/AC Unit		False
FO-267782	Routine	Scheduled Maint. (PM)	12/19/2013	1/7/2014	19	PM - Fan Coil/HV/AC Unit		False
FO-267783	Routine	Scheduled Maint. (PM)	12/19/2013	1/7/2014	19	PM - Fan Coil/HV/AC Unit		False
FO-267165	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-267166	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-267167	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-266571	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266591	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266599	Routine	Scheduled Maint. (PM)	12/13/2013	12/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-267784	Routine	Scheduled Maint. (PM)	12/20/2013	1/7/2014	18	PM - Fan Coil/HV/AC Unit		False

			Finish Date	Due Date				Total per Trade
FO-267785	Routine	Scheduled Maint. (PM)	12/20/2013	1/7/2014	18	PM - Fan Coil/HV/AC Unit		False
FO-267168	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-267169	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-267172	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-267176	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-267177	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-267178	Routine	Scheduled Maint. (PM)	12/17/2013	12/31/2013	14	PM - Fan Coil/HV/AC Unit		False
FO-266526	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266532	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266541	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266527	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266528	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266529	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266530	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266531	Routine	Scheduled Maint. (PM)	12/12/2013	12/24/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-267173	Routine	Scheduled Maint. (PM)	12/19/2013	12/31/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-267174	Routine	Scheduled Maint. (PM)	12/19/2013	12/31/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-267175	Routine	Scheduled Maint. (PM)	12/19/2013	12/31/2013	12	PM - Fan Coil/HV/AC Unit		False
FO-266533	Routine	Scheduled Maint. (PM)	12/13/2013	12/24/2013	11	PM - Fan Coil/HV/AC Unit		False
FO-266534	Routine	Scheduled Maint. (PM)	12/13/2013	12/24/2013	11	PM - Fan Coil/HV/AC Unit		False
FO-266535	Routine	Scheduled Maint. (PM)	12/13/2013	12/24/2013	11	PM - Fan Coil/HV/AC Unit		False
FO-266540	Routine	Scheduled Maint. (PM)	12/13/2013	12/24/2013	11	PM - Fan Coil/HV/AC Unit		False
FO-266598	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266597	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266562	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266581	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266555	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266557	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266573	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266583	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266605	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-268042	Routine	Scheduled Maint. (PM)	12/20/2013	12/31/2013	11	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266575	Routine	Scheduled Maint. (PM)	12/21/2013	12/31/2013	10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266576	Routine	Scheduled Maint. (PM)	12/21/2013	12/31/2013	10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-266584	Routine	Scheduled Maint. (PM)	12/21/2013	12/31/2013	10	PM - Monthly Fire Alarm/Fire Protection System Test		False

			Finish Date	Due Date				Total per Trade
FO-262798	Routine	Scheduled Maint. (PM)	12/5/2013	12/10/2013	5	PM - Air Handling Unit, HV Type		False
FO-262799	Routine	Scheduled Maint. (PM)	12/5/2013	12/10/2013	5	PM - Air Handling Unit, HV Type		False
FO-265788	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265790	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265791	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265792	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265793	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265794	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265786	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265789	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265785	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265787	Routine	Scheduled Maint. (PM)	12/10/2013	12/10/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-265795	Routine	Scheduled Maint. (PM)	12/11/2013	12/10/2013	-1	PM - Fan Coil/HV/AC Unit		False
FO-265796	Routine	Scheduled Maint. (PM)	12/11/2013	12/10/2013	-1	PM - Fan Coil/HV/AC Unit		False
FO-265797	Routine	Scheduled Maint. (PM)	12/11/2013	12/10/2013	-1	PM - Fan Coil/HV/AC Unit		False
FO-265798	Routine	Scheduled Maint. (PM)	12/11/2013	12/10/2013	-1	PM - Fan Coil/HV/AC Unit		False
FO-265141	Routine	Scheduled Maint. (PM)	12/10/2013	12/3/2013	-7	PM - Fan Coil/HV/AC Unit		False
FO-265142	Routine	Scheduled Maint. (PM)	12/10/2013	12/3/2013	-7	PM - Fan Coil/HV/AC Unit		False
FO-263522	Routine	Scheduled Maint. (PM)	12/10/2013	12/1/2013	-9	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-263525	Routine	Scheduled Maint. (PM)	12/10/2013	12/1/2013	-9	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-263523	Routine	Scheduled Maint. (PM)	12/11/2013	12/1/2013	-10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-263524	Routine	Scheduled Maint. (PM)	12/11/2013	12/1/2013	-10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-262097	Routine	Scheduled Maint. (PM)	12/10/2013	11/30/2013	-10	PM - Air Handling Unit		False
FO-262098	Routine	Scheduled Maint. (PM)	12/10/2013	11/30/2013	-10	PM - Air Handling Unit		False
FO-263503	Routine	Scheduled Maint. (PM)	12/11/2013	12/1/2013	-10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-262100	Routine	Scheduled Maint. (PM)	12/11/2013	11/30/2013	-11	PM - Air Handling Unit		False
FO-262099	Routine	Scheduled Maint. (PM)	12/11/2013	11/30/2013	-11	PM - Air Handling Unit		False
FO-263440	Routine	Scheduled Maint. (PM)	12/4/2013	11/22/2013	-12	PM - Air Handling Unit	checked operation of the heating valve and thermostat, changed filter. checked fan operation	False
FO-263441	Routine	Scheduled Maint. (PM)	12/4/2013	11/22/2013	-12	PM - Air Handling Unit	checked operation of heating valve and thermostat, checked operation of fan changed filter	False
FO-262101	Routine	Scheduled Maint. (PM)	12/12/2013	11/30/2013	-12	PM - Air Handling Unit		False
FO-262102	Routine	Scheduled Maint. (PM)	12/12/2013	11/30/2013	-12	PM - Air Handling Unit		False
FO-262103	Routine	Scheduled Maint. (PM)	12/12/2013	11/30/2013	-12	PM - Air Handling Unit		False

			Finish Date	Due Date	Total per Trade				
FO-263443	Routine	Scheduled Maint. (PM)	12/5/2013	11/22/2013	-13	PM - Air Handling Unit	cleaned filter, lubricated fan checked operation of heating valve and thermostat	False	
FO-263442	Routine	Scheduled Maint. (PM)	12/5/2013	11/22/2013	-13	PM - Air Handling Unit	cleaned filter, lubricated fan motor, checked operation of heating valve and thermostat	False	
FO-263444	Routine	Scheduled Maint. (PM)	12/6/2013	11/22/2013	-14	PM - Air Handling Unit	cleaned filter, lubricated fan checked operation of the heating valve and thermostat	False	
FO-263445	Routine	Scheduled Maint. (PM)	12/6/2013	11/22/2013	-14	PM - Air Handling Unit	cleaned filter, lubricated fan and motor, checked operation of the heating valve and thermostat	False	
FO-263446	Routine	Scheduled Maint. (PM)	12/6/2013	11/22/2013	-14	PM - Air Handling Unit	cleaned filter, lubricated fan and motor, checked operation of the heating valve and thermostat	False	
FO-261002	Routine	Scheduled Maint. (PM)	12/3/2013	11/15/2013	-18	PM - Air Handling Unit		False	
FO-263447	Routine	Scheduled Maint. (PM)	12/12/2013	11/22/2013	-20	PM - Air Handling Unit	check fan and motor checked operation of thermostat and heating valve	False	
FO-263448	Routine	Scheduled Maint. (PM)	12/12/2013	11/22/2013	-20	PM - Air Handling Unit	checked and lubricated fan and motor, checked operation of heating valve and stat. cleaned filter	True	
FO-263449	Routine	Scheduled Maint. (PM)	12/13/2013	11/22/2013	-21	PM - Air Handling Unit	checked unit operation, cleaned filter, lubricated fan and motor checked operation of the thermostat and heating valve	False	
FO-263450	Routine	Scheduled Maint. (PM)	12/16/2013	11/22/2013	-24	PM - Air Handling Unit	Checked unit operation, cleaned filter, lubricated fan and motor, checked operation of thermostat and heat valve	False	
FO-263451	Routine	Scheduled Maint. (PM)	12/16/2013	11/22/2013	-24	PM - Air Handling Unit	checked operation of unit, lubricated fan and motor, cleaned filter, checked operation of thermostat and heating valve	False	

#### E - South

**16 of 40 40%**

FO-268761	Routine	Scheduled Maint. (PM)	12/12/2013	12/13/2013	1	Generator Maintenance, Monthly			False
FO-268720	Routine	Scheduled Maint. (PM)	12/17/2013	12/18/2013	1	Generator Maintenance, Monthly			False
FO-270408	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270409	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270411	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270412	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270413	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270727	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270728	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270729	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270730	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270731	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-270732	Routine	Scheduled Maint. (PM)	12/19/2013	12/20/2013	1	PM - Centrifugal Pump, over 1 H.P.			False
FO-268722	Routine	Scheduled Maint. (PM)	12/18/2013	12/18/2013	0	Generator Maintenance, Monthly			False
FO-270410	Routine	Scheduled Maint. (PM)	12/20/2013	12/20/2013	0	PM - Centrifugal Pump, over 1 H.P.			False



			Finish Date	Due Date				Total per Trade
FO-270699	Routine	Scheduled Maint. (PM)	12/20/2013	12/20/2013	0	PM - Centrifugal Pump, over 1 H.P.		False
FO-268772	Routine	Scheduled Maint. (PM)	12/20/2013	12/19/2013	-1	Generator Maintenance, Monthly		False
FO-270342	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons		False
FO-270750	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons		False
FO-270624	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons		False
FO-270399	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Punch Tubes - Chiller/Absorber	Equipment marked inactive 12-19-13. cld	False
FO-270366	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons	Work order issued wrong time of year, 6 inches of snow on roof. Too cold to run any water to clean sump.	False
FO-270355	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons		False
FO-270669	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Cooling Tower, 500 - 1000 Tons		False
FO-270398	Routine	Scheduled Maint. (PM)	12/19/2013	12/15/2013	-4	PM - Punch Tubes - Chiller/Absorber	Equipment marked inactive on 12-19-13.	False
FO-268716	Routine	Scheduled Maint. (PM)	12/20/2013	12/13/2013	-7	Generator Maintenance, Monthly		False
FO-268718	Routine	Scheduled Maint. (PM)	12/20/2013	12/13/2013	-7	Generator Maintenance, Monthly		False
FO-270615	Routine	Scheduled Maint. (PM)	12/19/2013	12/1/2013	-18	PM - Centrifugal Pump, over 1 H.P.		False
FO-270404	Routine	Scheduled Maint. (PM)	12/19/2013	11/30/2013	-19	PM - Vacuum Pump		False
FO-270405	Routine	Scheduled Maint. (PM)	12/19/2013	11/30/2013	-19	PM - Vacuum Pump		False
FO-270644	Routine	Scheduled Maint. (PM)	12/19/2013	11/23/2013	-26	PM - Roof Sumps - Zone 2, Area 3		False
FO-270442	Routine	Scheduled Maint. (PM)	12/19/2013	11/22/2013	-27	PM - Heat Exchanger and Economizer		False
FO-270353	Routine	Scheduled Maint. (PM)	12/18/2013	11/16/2013	-32	PM - Water Softener		False
FO-270614	Routine	Scheduled Maint. (PM)	12/19/2013	11/15/2013	-34	PM - Centrifugal Pump, over 1 H.P.		False
FO-270390	Routine	Scheduled Maint. (PM)	12/19/2013	11/14/2013	-35	PM - Chemical Feed/Metering Pump/Controller		False
FO-270389	Routine	Scheduled Maint. (PM)	12/19/2013	11/14/2013	-35	PM - Chemical Feed/Metering Pump/Controller		False
FO-270392	Routine	Scheduled Maint. (PM)	12/23/2013	11/14/2013	-39	PM - Heat Exchanger and Economizer		False
FO-270393	Routine	Scheduled Maint. (PM)	12/23/2013	11/14/2013	-39	PM - Heat Exchanger and Economizer		False
FO-270388	Routine	Scheduled Maint. (PM)	12/19/2013	11/4/2013	-45	PM - Chemical Feed/Metering Pump/Controller		False
FO-270754	Routine	Scheduled Maint. (PM)	12/19/2013	10/29/2013	-51	PM - Harmsco Side Stream Filter		False

#### E - Southeast

0 of 5 0%

FO-262533	Routine	Scheduled Maint. (PM)	12/3/2013	11/30/2013	-3	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION, LUBE PUMP & MTR, CLEAN UNIT & AREA.	False
FO-262537	Routine	Scheduled Maint. (PM)	12/3/2013	11/30/2013	-3	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION, LUBE PUMP & MTR, CLEAN UNIT & AREA.	False
FO-262534	Routine	Scheduled Maint. (PM)	12/3/2013	11/30/2013	-3	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION, LUBE PUMP & MTR, CLEAN UNIT & AREA.	False
FO-262535	Routine	Scheduled Maint. (PM)	12/3/2013	11/30/2013	-3	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION, LUBE PUMP & MTR, CLEAN UNIT & AREA.	False
FO-262536	Routine	Scheduled Maint. (PM)	12/3/2013	11/30/2013	-3	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION, LUBE PUMP & MTR, CLEAN UNIT & AREA.	False

**Finish Date Due Date**

**Total per Trade**

**E - West**

**0 of 1 0%**

FO-270417	Routine	Scheduled Maint. (PM)	12/24/2013	11/14/2013	-40	PM - Chemical Feed/Metering Pump/Controller	False
-----------	---------	-----------------------	------------	------------	-----	---	-------

**Trades**

**30 of 51 59%**

**T - Electrician**

**30 of 51 59%**

FO-268726	Routine	Scheduled Maint. (PM)	12/20/2013	12/28/2013	8	Generator Test Finished 12/23/2013LT	False
FO-268728	Routine	Scheduled Maint. (PM)	12/20/2013	12/28/2013	8	Generator Test Finished 12/23/2013LT	False
FO-268745	Routine	Scheduled Maint. (PM)	12/24/2013	12/26/2013	2	Generator Test, to be done 12/24/2013 Tuesday @ 7:15AM. Finished 12/26/2013LT	False
FO-268725	Routine	Scheduled Maint. (PM)	12/24/2013	12/26/2013	2	Generator Test, to be done 12/24/2013 Tuesday @ 7:15. Finished 12/26/2013LT	False
FO-268778	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Test Finished 12/10/2013LT	False
FO-268773	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Test Finished 12/10/2013LT	False
FO-268775	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Test Finished 12/10/2013LT	False
FO-268730	Routine	Scheduled Maint. (PM)	12/6/2013	12/7/2013	1	Generator Test Finished 12/10/2013LT	False
FO-268769	Routine	Scheduled Maint. (PM)	12/10/2013	12/11/2013	1	Generator Test, to be done on December 10, 2013 @ 7:15 AM. Finished 12/11/2013LT	False
FO-268751	Routine	Scheduled Maint. (PM)	12/10/2013	12/11/2013	1	Generator Test, to be done December 10, 2013 @ 1PM. Finished 12/11/2013LT	False
FO-268753	Routine	Scheduled Maint. (PM)	12/11/2013	12/12/2013	1	Generator Test, to be done December 11, 2013 @ 1PM. Finished 12/12/2013LT	False
FO-268719	Routine	Scheduled Maint. (PM)	12/12/2013	12/13/2013	1	Generator Test, to be done December 12, 2013 A 7:15AM. Finished 12/13/2013LT	False
FO-268717	Routine	Scheduled Maint. (PM)	12/12/2013	12/13/2013	1	Generator Test, to be done December 12, 2013 @7:15AM Finished 12/13/2013LT	False
FO-268749	Routine	Scheduled Maint. (PM)	12/13/2013	12/14/2013	1	Generator Test, to be done December 13, 2013 @ 7:15AM.. Finished 12/16/2013LT	False
FO-268747	Routine	Scheduled Maint. (PM)	12/13/2013	12/14/2013	1	Generator Test, to be done December 13, 2013 @ 7:15AM.. Finished 12/16/2013LT	False
FO-268715	Routine	Scheduled Maint. (PM)	12/17/2013	12/18/2013	1	Generator Test Finished 12/18/2013LT	False
FO-268741	Routine	Scheduled Maint. (PM)	12/17/2013	12/18/2013	1	Generator Test Finished 12/18/2013LT	False
FO-268743	Routine	Scheduled Maint. (PM)	12/17/2013	12/18/2013	1	Generator Test Finished 12/18/2013LT	False
FO-268723	Routine	Scheduled Maint. (PM)	12/18/2013	12/19/2013	1	Generator Test. Finished 12/19/2013LT	False
FO-268739	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT	False
FO-268733	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT	False
FO-268735	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Test, to be done 12/24/2013 @ 8AM. Finished 12/26/2013LT	False

			Finish Date	Due Date				Total per Trade
FO-268737	Routine	Scheduled Maint. (PM)	12/24/2013	12/25/2013	1	Generator Test, to be done 12/24/2013 Tuesday @ 8AM. Finished 12/26/2013LT		False
FO-268758	Routine	Scheduled Maint. (PM)	12/6/2013	12/6/2013	0	Generator Test Finished 12/10/2013LT		False
FO-268766	Routine	Scheduled Maint. (PM)	12/13/2013	12/13/2013	0	Generator Test, to be done December 13, 2013 @ 7:15 AM.. Finished 12/16/2013LT		False
FO-268721	Routine	Scheduled Maint. (PM)	12/17/2013	12/17/2013	0	Generator Test Finished 12/18/2013LT		False
FO-268757	Routine	Scheduled Maint. (PM)	12/18/2013	12/18/2013	0	Generator Test. Finished 12/19/2013LT		False
FO-268771	Routine	Scheduled Maint. (PM)	12/19/2013	12/19/2013	0	Generator Test. Finished 12/19/2013LT		False
FO-268763	Routine	Scheduled Maint. (PM)	12/19/2013	12/19/2013	0	Generator Test. Finished 12/19/2013LT		False
FO-268731	Routine	Scheduled Maint. (PM)	12/24/2013	12/24/2013	0	Generator Test, to be done 12/24/2013 Tuesday @ 10:00AM. Finished 12/26/2013LT		False
FO-268760	Routine	Scheduled Maint. (PM)	12/16/2013	12/13/2013	-3	Generator Test, to be done December 12, 2013 @ 7:15 AM. Finished 12/17/2013LT		False
FO-266340	Routine	Scheduled Maint. (PM)	12/2/2013	11/28/2013	-4	Generator Test on Wednesday November 27, at 7:15AM. Finished 12/2/2013LT		False
FO-266320	Routine	Scheduled Maint. (PM)	12/2/2013	11/28/2013	-4	Generator Test on Wednesday, November 27, 2013 @ 7:15AM. Finished 12/2/2013LT		False
FO-266316	Routine	Scheduled Maint. (PM)	12/2/2013	11/19/2013	-13	Generator Test Finished 12/2/2013LT		False
FO-266312	Routine	Scheduled Maint. (PM)	12/2/2013	11/15/2013	-17	Generator Test Finished 12/2/2013LT		False
FO-266355	Routine	Scheduled Maint. (PM)	12/2/2013	11/15/2013	-17	Generator Test Finished 12/2/2013LT		False
FO-266348	Routine	Scheduled Maint. (PM)	12/2/2013	11/14/2013	-18	Generator Test Finished 12/2/2013LT		False
FO-266314	Routine	Scheduled Maint. (PM)	12/3/2013	11/15/2013	-18	Generator Test Finished 12/2/2013LT		False
FO-266346	Routine	Scheduled Maint. (PM)	12/2/2013	11/13/2013	-19	Generator Test Finished 12/2/2013LT		False
FO-266342	Routine	Scheduled Maint. (PM)	12/2/2013	11/9/2013	-23	Generator Test Finished 12/2/2013LT		False
FO-266344	Routine	Scheduled Maint. (PM)	12/2/2013	11/9/2013	-23	Generator Test Finished 12/2/2013LT		False
FO-266361	Routine	Scheduled Maint. (PM)	12/2/2013	11/8/2013	-24	Generator Test Finished 12/2/2013LT		False
FO-266332	Routine	Scheduled Maint. (PM)	12/26/2013	11/27/2013	-29	Generator Test on Tuesday November 26, at 8:00AM. Finished 11/27/2013LT		False
FO-266371	Routine	Scheduled Maint. (PM)	12/2/2013	11/2/2013	-30	Generator Test Finished 12/2/2013LT		False
FO-266369	Routine	Scheduled Maint. (PM)	12/2/2013	11/2/2013	-30	Generator Test Finished 12/2/2013LT		False
FO-266325	Routine	Scheduled Maint. (PM)	12/2/2013	11/2/2013	-30	Generator Test Finished 12/2/2013LT		False
FO-266353	Routine	Scheduled Maint. (PM)	12/2/2013	11/1/2013	-31	Generator Test Finished 12/2/2013LT		False
FO-268777	Routine	Scheduled Maint. (PM)	12/12/2013	11/2/2013	-40	Generator Test Finished 12/12/2013LT		False
FO-260768	Routine	Scheduled Maint. (PM)	12/12/2013	10/16/2013	-57	Generator Test Finished 12/12/2013LT		False
FO-260779	Routine	Scheduled Maint. (PM)	12/12/2013	10/11/2013	-62	Generator Test Finished 12/12/2013LT		False
FO-260772	Routine	Scheduled Maint. (PM)	12/12/2013	10/4/2013	-69	Generator Maintenance, Monthly Finished 12/12/2013LT		False

**Finish Date   Due Date**

**Total per Trade**

**Total: 155 of 303 59%**