

Facilities Operations Work Orders Recieved 8/1/2012 - 8/31/2012

				Total	
Maint. Work Order (MWRF)				2305	
Custodial				299	
Emergency				1	
C-Sector 01				1	
FO-224442	8/1/2012	8/2/2012			RM 233 MEET W/ENG @ RM SOMETHING IS LKNG INSIDE LAB CAUSING FLOODING IN
High				9	
C-Director				4	
FO-225747	8/14/2012	8/14/2012	8/14/2012		Custodial to provide bathroom materials for each restroom at 1200 Holden.
FO-225954	8/16/2012	8/23/2012	8/23/2012		To cover the cost for Custodial to strip and wax 5 labs in Physics Building. Rooms 142, 159, 1
FO-226484	8/22/2012	8/6/2012			Custodial to Provide support for Friday/Saturday(August 24th & 25th 2012) Football event at M
FO-226510	8/22/2012				Custodial to provide support for the Dlectricity event at the Welcome Center: Friday October 5,
C-Lighting				1	
FO-225266	8/7/2012	8/8/2012			There are 5 incandescent bulbs that are burned out.
C-Projects				1	
FO-227044	8/29/2012				Engineering Technology Scrub and Wax floors in classrooms: 2005, 2021,2007, 2020, 2020A.
C-Repair				1	
FO-225873	8/16/2012	8/20/2012			Repair yellow wringer. Wringer needs nut/bolt in handle.
C-Sector 02				2	
FO-226024	8/16/2012	8/16/2012			clean carpet in room 3125.
FO-226025	8/17/2012	8/17/2012			Dust and vacuum and wipe down alll desk.
Medium				54	
C-Lighting				30	
FO-224536	8/2/2012				Bulb change in small corridor near dock area.
FO-225131	8/6/2012	8/7/2012			A research assistant has notified me that there are 4 light bulbs out in his office, room 2122 of
FO-225242	8/7/2012	8/7/2012			Lights out outside of Rm 341 and Rm 321.
FO-225236	8/7/2012				several lites in hall x75550
FO-225353	8/8/2012	8/15/2012			Need 2 light bulbs replaced in 0243. Please and thank you!!
FO-225354	8/8/2012	8/10/2012			This is the little area BEFORE the door that out to loading dock (outside Room 104).
FO-225359	8/8/2012	8/9/2012			Relamp hall at North exit door to parking lot behind London Luggage.
FO-225362	8/8/2012	8/9/2012			Relamp fixtures in electrical substation room.
FO-225478	8/10/2012	8/13/2012			Room 1378 - Women's room - several burnt out light bulbs, please fix.
FO-226522	8/22/2012				2ND FL LIGHT BEEPING NEAR SAR LIGHT NEEDS TO BE CHANGED
FO-226609	8/23/2012				2 lightbulbs out. Please replace.
FO-226618	8/24/2012				3rd floor Custodian Closet light out need too replace
FO-226677	8/24/2012				Lights out mens restroom 130
FO-226839	8/27/2012				5244 Please replace light bulbs. Thank you. 2 electrical problems.
FO-226880	8/27/2012				Please replace burned out track lights.
FO-226886	8/27/2012				Please replace burned out lights.
FO-226945	8/27/2012				Lab Room 2407 - Lightbulb is out and needs to be replaced in lab.
FO-226946	8/27/2012				West stairwell has lighting problems. Main light is burnt out. Secondary light switch will not re
FO-227007	8/28/2012				Room 1261, Lights are flickering in office
FO-227010	8/28/2012				Please replace light bulb in Dean' s bathroom above the toilet... this is the 2nd request
FO-227074	8/28/2012				Replaced blub in kitchen. Need light fixture in bathroom
FO-227080	8/29/2012				Relamp 2 fixtures in room 293, executive offices.
FO-227077	8/29/2012				Replace burnt out light bulbs in mens and womens restroom on the 2nd floor of the Office Win

Total

FO-227098	8/29/2012		R/R RM 321/WOMENS RM LITE IS FLICKERING NEED TO BE CHNG'D OR TAGGED
FO-227129	8/29/2012		Need light bulb replaced in ceiling of Ladies Restroom on 1st floor (lobby).
FO-227130	8/29/2012		Need ceiling light bulb replaced directly in front of mens restroom in 1st floor (lobby)
FO-227136	8/30/2012		Half lights out in rm #123. Circulation desk at UGL left message for professor working in room
FO-227462	8/30/2012		Please replace burned out lights in the Ladies restroom.
FO-227463	8/30/2012	8/31/2012	Please replace burned out lights in lab 3119, 3120, 3121, 3122 and 3124.
FO-227566	8/31/2012		50th Anniversary on the 8th of september. Event starts early evening. Fred would like a walk
C-Materials		2	
FO-225425	8/9/2012	8/14/2012	Recycling Pick Up
FO-227488	8/31/2012	8/31/2012	Shredded paper pickup in dock area of fab.
C-Relief		2	
FO-224809	8/3/2012		The auto scrubber in the community arts building will not pick up water. It needs to be repaired
FO-224811	8/3/2012		The auto scrubber here in Student Center will not pick up or distribute water. It needs to be repaired
C-Repair		8	
FO-225482	8/10/2012	8/13/2012	soap dispenser broken in ladies restroom, 2nd floor Old Main, by the elevators
FO-226242	8/20/2012	8/23/2012	Repair of extension cord. Cord has exposed wiring near end.
FO-226423	8/22/2012		Powr Flite Perfect Heater Power Extractor: Sector 3 janitors are utilizing this machine over in
FO-226617	8/24/2012		Lady Restroom 4th floor the soap dispenser off the wall
FO-226932	8/27/2012		Women's Restroom - The first stall's toilet
FO-227465	8/30/2012		Custodian removed broken soap dispenser. Please replace with a new one.
FO-227469	8/31/2012		Repair or replace tissue dispenser in Women's restroom on 13th floor 2nd stall bottom broken
FO-227544	8/31/2012		Paper towel dispenser broke mens room 109 State hall 1st floor
C-Sector 02		2	
FO-224422	8/1/2012	8/1/2012	outside windows around the front side of Scott Hall. Left side of building facing Lande. from driveway
FO-224429	8/1/2012	8/1/2012	shampooed carpet stains in suite 322,315,317,318,315.8, also hallway by 317.5-318,desk area
C-Sector 04		1	
FO-225392	8/8/2012	8/11/2012	Need one office carpet cleaned asap. There is large area of mold on carpet. WDET- first floor
C-Sector 05		5	
FO-225179	8/6/2012	8/20/2012	Custodian has requested Room 2220 to have carpet shampooed.
FO-225180	8/6/2012	8/20/2012	Custodian has requested floor to be waxed from copy area to elevator.
FO-225181	8/6/2012	8/9/2012	Custodian requests " shower scrub" for all bathrooms in building.
FO-226948	8/27/2012		Carpet Cleaned. Major stains on the carpet.
FO-227051	8/28/2012		Room 3125 still needs dusting (windows, blinds, desk drawers have dust on them) Please make
C-Sector 07		1	
FO-225610	8/10/2012	8/15/2012	We would like the carpeting cleaned in this suite of rooms.
C-Sector 08		1	
FO-225461	8/10/2012		NEED CLEAN UP (PINK NAIL POLISH) ON FLOOR AND SMELLS. 4TH FLOOR LADIES RESTROOM
C-Sector 09		2	
FO-225271	8/8/2012	8/11/2012	Shampoo/extract the Lecture Hall classrooms in Law School Bldg:
FO-227041	8/29/2012	8/16/2012	Strip / wax office rm. 71
Low		233	
C-Director		3	
FO-225344	8/9/2012		Light is out on the 1st floor at exit 6 State Hall
FO-225719	8/14/2012	8/18/2012	Clean and wax floor to lower level VIP Rec Room in Student Center. Charge to account 22714
FO-226663	8/24/2012		FO Contractors clothing. Uniforms for Custodial Supervisors and Directors
C-Lighting		90	
FO-224383	8/1/2012	8/2/2012	Light out Deans office room #1253
FO-224400	8/1/2012	8/2/2012	2nd floor (DLAR).

Total

FO-224446	8/1/2012	8/2/2012	2- lights out in supervisor locker room on the 2nd floor
FO-224450	8/1/2012	8/3/2012	REPLACE LIGHT - HALLWAY OUTSIDE OF THE PURCHASING DEPT. ROOM 4200.
FO-224502	8/2/2012	8/2/2012	Ceiling light out in room #2228.
FO-224787	8/2/2012	8/3/2012	6th floor - Replace lighting in restroom (across from kitchen area-adjacent to lobby area)
FO-224819	8/3/2012	8/6/2012	Ceiling lights out in room 3335
FO-225205	8/7/2012	8/9/2012	Bulb out in 6th floor restroom, across from reception area, business offices
FO-225267	8/7/2012		Lights out ladies restroom near the guard desk near the front entrance.
FO-225367	8/9/2012	8/9/2012	REPLACE BURNT OUT LIGHT BULB. ROOM 1001.
FO-225406	8/9/2012	8/17/2012	2 bulbs out rm 487 Manoogian
FO-225459	8/10/2012		Light flashing in room 3800
FO-225609	8/10/2012		replace fluorescent light in my office
FO-225654	8/13/2012	8/16/2012	Room 2116 - Light bulb burnt out in 5th row. Please fix
FO-225655	8/13/2012	8/16/2012	Room 2106 - Light panel flickering in 2nd row. Please fix
FO-225656	8/13/2012	8/16/2012	Room 2258 - Several light burnt out in 2nd and 5th rows. Please fix
FO-225658	8/13/2012		Room 2248 - Several light burnt out in 1st and 3rd rows and light panel flickering in 4th row. Pl
FO-225660	8/13/2012	8/16/2012	Room 2228 - Light burnt out in 1st row and light panel flickering in 4th row. Please fix
FO-225662	8/13/2012	8/16/2012	Room 2228 - Please replace missing light bulb in study carol between computer stations 1 & 2
FO-225644	8/13/2012		2 lights out in room 481 (go through 487)
FO-225712	8/14/2012	8/14/2012	Hallway outside room 212.08: burned out light bulb, please replace.
FO-225705	8/14/2012	8/14/2012	LIGHT FLICKERING. 1ST FLOOR LADIES RESTROOM NEAR LUNCH ROOM.
FO-225725	8/14/2012	8/14/2012	Elevator #2 has light out
FO-225743	8/14/2012	8/16/2012	30 LIGHTS ARE OUT. BASEMENT ROOM 10.
FO-225785	8/15/2012	8/16/2012	Auditorium lights need replacement
FO-225920	8/16/2012	8/16/2012	Rooms: 405, 407, 410 & 419 all have ceiling
FO-225938	8/16/2012	8/17/2012	In the lobby on the ramps into the theatres, lights are out at both ends of the ramps
FO-225942	8/16/2012		2 bulbs out in Rm 3168 Engineering
FO-225950	8/16/2012	8/17/2012	Contact Lee 7-2614 at Old Main for Access to Room 108 Schaver - Several Bulbs Out
FO-225984	8/16/2012	8/16/2012	Four light bulbs burned out in main elevator.
FO-225987	8/16/2012		Room 3144 light bulbs need to be replaced.
FO-226122	8/17/2012	8/21/2012	Both elevators, 01 and 02, need light bulbs replaced. I need on in the smaller (01) elevator an
FO-226276	8/20/2012		Please replace the burned out lamps associated with the security monitor's desk. Located in t
FO-226292	8/20/2012		6 lights out in room #4705
FO-226327	8/21/2012	8/21/2012	2 lightbulbs out. Please replace. For further information, contact Robert Lasley at 577-9444.
FO-226328	8/21/2012	8/21/2012	Lightbulbs out in east stairwell between floors 1 and 2. Please replace.
FO-226329	8/21/2012		lightbulbs out in southeast corner fire exit, first floor. Please replace. Thanks!
FO-226333	8/21/2012		Lights are out in the large animal rooms, 0231,0235,0243,0247,0249. Thank you, Susan
FO-226431	8/21/2012	8/22/2012	Ceiling light covers are falling off and need to be fixed.
FO-226432	8/21/2012	8/22/2012	There are bulbs out in two fixtures. The same has occurred in room 355 and room 369.
FO-226385	8/21/2012		R/R RM 4402.20 The overhead light needs to be replaced. (THIS IS STILL OUT PLS GO TO
FO-226469	8/22/2012	8/22/2012	Room 411 (Animal Quarters) - ceiling lights out
FO-226600	8/22/2012		Relamp fixture in room 150. Please see Alex Stephens for instructions.
FO-226515	8/22/2012		We submitted a request back on July 23rd to have four burned out lights replaced in our Suite
FO-226516	8/22/2012		Two lights are flickering in faculty office. Contact: Dr. Parijuli at 7-6377 or 7-0629 for access.
FO-226519	8/22/2012		Relamp 2 round fixtures in Lobby area.
FO-226521	8/22/2012	8/28/2012	Light bulb needs replacing over Dean's toilet.
FO-226524	8/22/2012		Room 2407 - Lights are not functioning properly.
FO-226603	8/22/2012		The portico (porch) lights on the Hancock side of the Hilberry Theatre need to be relaced. The

Total

FO-226551	8/23/2012	8/23/2012	Light out in Jim's office.
FO-226604	8/23/2012	8/29/2012	Dean's Bathroom inside of 1241 has a ceiling
FO-226595	8/23/2012		REPLACE lgths THAT are not working in room 3528.
FO-226578	8/23/2012		Light out inside box office (long light bulb).
FO-226627	8/23/2012	8/28/2012	3 lightbulbs out. Please replace.
FO-226628	8/23/2012		4 lightbulbs out. Please replace.
FO-226629	8/23/2012		1 lightbulbsout. Please replace.
FO-226588	8/23/2012		2 lights out in room 631
FO-226630	8/23/2012		1 lightbulb out. Please replace.
FO-226631	8/23/2012		4 lightbulbs out. Please replace.
FO-226652	8/23/2012		1 lightbulb out. Please replace.
FO-226632	8/23/2012		3 lightbulbs out. Please replace.
FO-226633	8/23/2012		3 lightbulbs out. Please replace.
FO-226634	8/23/2012		3 lightbulbs out. Please replace.
FO-226639	8/23/2012		2 lightbulbs out. Please replace.
FO-226640	8/23/2012		4 lightbulbs out. Please replace.
FO-226653	8/23/2012		4 lightbulbs out. Please replace.
FO-226641	8/23/2012		2 lightbulbs out. Please replace.
FO-226642	8/23/2012		Lights in main hallway are flickering and beeping.
FO-226643	8/23/2012		2 lightbulbs out. One light cover missing. Please replace.
FO-226646	8/23/2012		3 lightbulbs out and one missing cover. Please replace.
FO-226647	8/23/2012		Lights are flickering and beeping in the lobby behind the front counter.
FO-226648	8/23/2012		2 lightbulbs out. Please replace.
FO-226656	8/24/2012		Cube lights out in room 1328.
FO-226774	8/27/2012	8/27/2012	Light out in room 1326
FO-226863	8/27/2012	8/28/2012	R/R RM 1540/CLASS-LAB NEED TWO LITES TAKEN OUT @ FRONT OF LAB NEAR SCRE
FO-226894	8/27/2012		basement florescent lights out.
FO-226910	8/27/2012	8/28/2012	Light out in childrens bathroom rm #154
FO-226922	8/27/2012	8/28/2012	Light out in room 4055
FO-226958	8/28/2012		Lights out in room 123.1 123.5 123.6
FO-226979	8/28/2012		Lights out in suite #1330
FO-227000	8/28/2012		1 panel 2 lights out in rm #349
FO-227002	8/28/2012	8/30/2012	womens restroom light out
FO-227035	8/28/2012		light out in room 423
FO-227057	8/29/2012	8/29/2012	FO for chris and Jessica to go to Stockroom and light bulbs bulbs for St. Andrews.
FO-227061	8/29/2012		Lights out room 423
FO-227086	8/29/2012		10 lights out in room #1330
FO-227100	8/29/2012		light out in deans office #1241
FO-227152	8/30/2012		lights out in room 112, 114, and 114.6
FO-227499	8/31/2012		There are several lightbulbs blown out in the
FO-227547	8/31/2012		4th floor stairwell light is burned out. Please replace.

C-Materials

66

FO-224419	8/1/2012	8/2/2012	Needs large black recycle bin delivered to room #3054
FO-224815	8/3/2012	8/3/2012	Rags for Sector 6
FO-224816	8/3/2012	8/6/2012	2 cs Dial Soap for Student Center
FO-224818	8/3/2012	8/6/2012	2 cs Dial Soap for Law Library
FO-224820	8/3/2012	8/6/2012	1 cs Dial soap for Alumni House.

Total

FO-224821	8/3/2012	8/6/2012	1 cs Dial soap for Education.
FO-224822	8/3/2012	8/6/2012	2 cs Dial soap for FAB.
FO-224823	8/3/2012	8/6/2012	1 cs Dial soap for Cohn Building.
FO-224824	8/3/2012	8/6/2012	1 cs Dial soap for Community Arts Building.
FO-224825	8/3/2012	8/6/2012	2 cs Gojo soap for Law Library.
FO-224826	8/3/2012	8/6/2012	2 cs Gojo soap for McGregor.
FO-225136	8/6/2012	8/7/2012	7 cs Dial Soap for 5057 Woodward.
FO-225137	8/6/2012	8/6/2012	4 cs Dial Soap for Purdy kresge Library.
FO-225138	8/6/2012	8/7/2012	2 cs Dial Soap for 110 E. Warren
FO-225140	8/6/2012	8/7/2012	2 cs Dial Soap for Science Hall.
FO-225143	8/6/2012	8/6/2012	5 cs Dial Soap for Old Main.
FO-225145	8/6/2012	8/6/2012	1 cs Dial Soap for Rackham.
FO-225149	8/6/2012	8/6/2012	3 cs Dial Soap for Welcome Center.
FO-225172	8/6/2012	8/9/2012	2 recycle bins emptied and replaced. room #300.
FO-225173	8/6/2012	8/6/2012	1 bin on 3rd floor and 1 bin in basement near the elevator. Large grey recycle bins need empt
FO-225235	8/7/2012	8/8/2012	EQUIPMENT TRANSFER:
FO-225278	8/8/2012	8/9/2012	Please remove large paper recycle container. No longer needed. Thank you for your support.
FO-225409	8/9/2012	8/14/2012	Recycling bin pick up and empty, next to room 3219 Science Hall
FO-225473	8/10/2012	8/10/2012	2 cs Dial Soap for Student Center
FO-225475	8/10/2012	8/10/2012	2 cs Dial Soap for Welcome Center.
FO-225476	8/10/2012	8/10/2012	2 cs Dial Soap for Old Main.
FO-225477	8/10/2012	8/10/2012	2 cs Dial Soap for Mazurak.
FO-225615	8/13/2012	8/13/2012	5 cases of dial soap
FO-225616	8/13/2012	8/13/2012	5 cases of dial soap
FO-225617	8/13/2012	8/13/2012	5 cases of dial soap
FO-225619	8/13/2012	8/13/2012	5 cases of dial soap
FO-225626	8/13/2012	8/14/2012	Recycling Pick Up
FO-225657	8/13/2012	8/15/2012	4 cs Dial Soap for Manoogian.
FO-225659	8/13/2012	8/15/2012	2 cs Dial Soap for General Lecture.
FO-225661	8/13/2012	8/15/2012	6 cs Dial Soap for Engineering.
FO-225663	8/13/2012	8/15/2012	3 cs Dial Soap for Biological Sciences Building.
FO-225665	8/13/2012	8/15/2012	2 boxes of Rags for sector 5.
FO-225714	8/14/2012	8/14/2012	Recycling Pick Up
FO-225748	8/14/2012	8/15/2012	2 recycle bins need pickup and replacement on the 2nd floor. contact starlight for specific loc
FO-225824	8/15/2012	8/21/2012	8 cs Dial Soap for AAB.
FO-225826	8/15/2012	8/21/2012	4 cs GoJo Soap 4 cs Dial Soap for Computer Center.
FO-225828	8/15/2012	8/21/2012	6 cs GoJo Soap 10 cs Dial Soap for Mathaei.
FO-225829	8/15/2012	8/21/2012	4 cs Dial Soap for University Custodial/Grounds.
FO-225830	8/15/2012	8/21/2012	3 cs GoJo and 3 cs Dial Soap for Knapp.
FO-225833	8/15/2012	8/21/2012	4 cs GoJo and 3 cs Dial Soap for Freer House.
FO-225868	8/16/2012	8/16/2012	EQUIPMENT TRANSFER: AUTO SCRUBBER (ADVANCE/CONV.) From building to stockroo
FO-226353	8/21/2012	8/21/2012	3 boxes of rags to Matthaei
FO-226359	8/21/2012	8/22/2012	3 cs Dial Soap for State Hall
FO-226360	8/21/2012	8/22/2012	3 cs Dial Soap for Chemistry.
FO-226361	8/21/2012	8/21/2012	3 cs Dial Soap for Undergraduate Library.
FO-226362	8/21/2012	8/21/2012	2 cs Dial Soap for Recreation and Fitness Center.
FO-226363	8/21/2012	8/21/2012	2 cs Dial Soap for Prentis.

Total

FO-226367	8/21/2012	8/21/2012	1 cs Rags for State Hall
FO-226366	8/21/2012	8/21/2012	2 cs Dial Soap for Science & Engineering Library.
FO-226370	8/21/2012	8/22/2012	1 cs Rags for Fitness.
FO-226372	8/21/2012	8/22/2012	1 cs Rags for Prentis.
FO-226375	8/21/2012	8/22/2012	1 cs Rags for Chemistry
FO-226376	8/21/2012	8/22/2012	1 cs Rags for UGL.
FO-226378	8/21/2012	8/22/2012	2 cs Rags for Simon/Thompson home
FO-226380	8/21/2012	8/22/2012	2 cs Rags for Rands/linsell House
FO-226382	8/21/2012	8/22/2012	2 cs Rags for Bonstell / Hilberry
FO-226386	8/21/2012	8/22/2012	2 cs Rags for Science and Eng. Library.
FO-226589	8/23/2012	8/23/2012	2 cs Dial Soap for UGL.
FO-226590	8/23/2012	8/23/2012	2 cs Dial Soap for State Hall.
FO-226591	8/23/2012	8/23/2012	2 cs Dial Soap for Old Main.
FO-226934	8/27/2012	8/28/2012	Recycle bin pickup. Contact Greg for location.
C-Projects		1	
FO-226559	8/23/2012		Detroit Hardware Co- Purchase a Rubber Message Bath Spray Hose
C-Repair		44	
FO-224364	8/1/2012		Advance Nilfisk Upright Buffer Machine; Model Pacesetter 20HD; Ser. no. HF1843 (The buffer
FO-224473	8/2/2012	8/2/2012	Koblenz (Commercial Upright Vacuum Cleaner); Model U75; Ser. no. 071-12-0352: The rubbe
FO-224543	8/2/2012	8/2/2012	Needs some supplies from (FPM / Stockroom), for work area and service repairs on equipmen
FO-224569	8/3/2012	8/3/2012	Nilfisk Advance Upright Buffer machine; Model no. Pacesetter 200 HD; Ser. no. 1619708: Re
FO-224832	8/3/2012		Upright sanitaire vacuum with red bag & dirte cup 040# -replace electrical cord, belt won't stay
FO-224871	8/3/2012	8/8/2012	Please replace the toilet paper dispenser in the first stall, cover is broken.
FO-224856	8/5/2012	8/7/2012	Powr. Flite (Perfect Heat) Carpet Extractor; Mofrl no. PFX1380PH; Ser. no. 1011001165: Issu
FO-224857	8/5/2012		Equipment located in the Law Classroom Janitor closet (no room number listed on door): Kent
FO-225122	8/6/2012		Sanitaire upright vacuum red bag/dirt cup - electrical cord needs to be replace located in State
FO-225244	8/7/2012	8/8/2012	Ladies restroom 1st floor near the janitors closet broken toilet paper dispenser.
FO-225552	8/8/2012		R/R RM 3127 Install paper towel dispenser in CMMG interactive (3rd floor).
FO-225471	8/10/2012	8/13/2012	Womens restroom 2nd floor near room #2155 soap dispensor is broken
FO-225686	8/14/2012	8/16/2012	Sector 9 Project Crew "Yellow Extension Cord": Requires a new plug adaptor head. Can you
FO-225770	8/15/2012	8/16/2012	Sector 9 project crew "Orange Extension Cord" as the plug adaptor head started making a po
FO-225810	8/15/2012	8/16/2012	Vacuum cleaner from computer center not picking up. Needs repair. It will be in the stockroo
FO-225863	8/15/2012	8/16/2012	NEED TO ORDER SOME BATTERIES FOR EQUIPMENT (AUTO, SCRUBBERS) MACHINE.
FO-225866	8/16/2012		Repair vacumn in Rm. 2506.
FO-225959	8/16/2012	8/23/2012	R/R 1ST FLR WOMENS RM (ONLY WOMENS RM) PAPER TOWEL DISPENSER IS BROKE
FO-226047	8/17/2012		Rm. 0235: Nilfisk Advance Adphibian Auto Scrubber; Ser. no. 1000001296: Repair squeegee
FO-226048	8/17/2012	8/28/2012	Rm. 0235: B&R Kent Wet/Dry Vac: Model no. WD260F; Ser. no. 982800169: Suction hose h
FO-226049	8/17/2012		Kent carpet extractor machine (was
FO-226050	8/18/2012		Panasonic Vacuum Cleaner; Model MCV121501; Ser. no. 23612318: Discovered (came upon)
FO-226051	8/18/2012		Sanitaire vacuum cleaner (notes Sector 3); Model SC699; Ser.no. 0825003441: Came upon th
FO-226052	8/18/2012		Rm. 106: Nilfisk Advance Convertamatic X24D-C; SErn. 1983771: Suction hose needs to be r
FO-226053	8/18/2012		Rm. 106: Tennant Nobles AXP Typhoon EV Wet & Dry Vac; Ser. no. 10331599: Custodian inf
FO-226054	8/18/2012		Basement Receiving area next to rm. 518: Nilfisk Advance Convertamatic; Ser. no. 1955712:
FO-226055	8/18/2012		Janitor closet: 1326: Electrolux Sanitaire Vacuum Cleaner; Ser. no. 0825003476; No beeder b
FO-226057	8/18/2012		Rm. 107: Nilfisk Advance Auto Scrubber; Model: Convertamatic X28D-C; Serial no. 1965237: I
FO-226058	8/18/2012		Rm. 030.1: Nilfisk Advance (small auto scrubber); Model no. Micromax 20DX; Ser.no. 064825
FO-226128	8/20/2012	8/23/2012	SOAP DISPENSER IS BROKEN. LADIES RESTROOM - NEAR OLD STOCKROOM.
FO-226254	8/20/2012		received vacuum bags for Advance upright spectrum 12P, Advance proteam back pack and di

Total

FO-226260	8/20/2012	8/23/2012	Broken towel dispensor in unisex bathroom located within suite 1600, near 1629.
FO-226389	8/21/2012	8/23/2012	R/R 4TH FLR ONLY WOMENS RM SOAP DISPENSER IS BROKEN NEEDS REPLACING
FO-226391	8/21/2012	8/23/2012	R/R 1ST FLR WOMENS RM NEXT TO STE 1900/EMP SVCS SOAP DISPENSER IS BROKE
FO-226536	8/23/2012		Rm. 278: Nilfisk Advance Convertamatic Auto Scrubber; Serial no. 1955713: Machine was pla
FO-226537	8/23/2012		Rm. 278: Nilfisk Advamce Adhancer Auto Scrubber; Ser. no. 1000001323: Custodian, myself
FO-226889	8/27/2012		Vac Cleaners Sanitaire won't pickup. Carla will bring it to FPM stockroom
FO-226891	8/27/2012		Need new Auto Scrubber blades - Housed in the back men's locker-room
FO-226937	8/27/2012		NEEDS SOME BATTERIES FROM (HARRIS, BATTERY CO.) FOR AUTO SCRUBBERS
FO-226939	8/28/2012		NEED SOME (NOBLES / TENNANT CO.) EQUIPMENT PARTS FOR AUTO SCRUBBER, FL
FO-226940	8/28/2012		NEED TO ORDER SOME (NILFISK-ADVANC)EEQUIPMENT REPAIR PARTS FOR (AUTO S
FO-226980	8/28/2012		Andre to go to Allied for mop ringer set and supplies
FO-227031	8/28/2012	8/28/2012	NEED SOME SUPPLIES FROM (DETROIT, HARDWARE) FOR SERVICE REPAIRS IN CUS
FO-227498	8/30/2012		Toilet tissue dispenser is broken on the 1st floor ladies room 1st stall.
C-Sector 01		2	
FO-225953	8/16/2012		Please schedule carpet cleaning--room is available during the day--let me know day/time.
FO-226636	8/23/2012		We would like to have the carpet cleaned in our offices and common areas.
C-Sector 02		3	
FO-224533	8/2/2012	8/2/2012	shampoo capert in Aud, conference room 1130, hallway carpet on left side of office area 3rd fl
FO-225985	8/16/2012		We would to have the carpet cleaned. Office is vacant so anytime will work.
FO-225986	8/16/2012		We would like to have the carpet cleaned. Office is vacant so anytime will work.
C-Sector 03		1	
FO-225270	8/7/2012	8/7/2012	One case of Dial hand soap for the Purdy/Kreesge Library.
C-Sector 04		10	
FO-224362	8/1/2012	8/1/2012	Srcub and re-coat floor in Room 191.
FO-224363	8/1/2012	7/31/2012	Scrub and refinish floors in Rooms 185 and 178.
FO-224853	8/4/2012	8/6/2012	Scrub and refinish 187, 186, 193 and corridor.
FO-225514	8/11/2012	8/11/2012	Shampoo carpet in main corridor at Tower Pre-school.
FO-225685	8/14/2012	8/14/2012	Shampoo carpet in Room 191, 190 and 185.
FO-225844	8/15/2012	8/16/2012	Shampoo carpet in Room 181 and 193.
FO-225865	8/16/2012	8/16/2012	Shampoo carpet in Room 192 and 178.
FO-226422	8/22/2012	8/22/2012	Shampoo carpet in Room 176 and 181.
FO-226602	8/22/2012		Carpet cleaning
FO-226534	8/22/2012	8/23/2012	Shampoo carpet in Rooms 170 and 182 and front corridor.
C-Sector 05		5	
FO-224806	8/3/2012	8/15/2012	All Faculty offices: Carpet shampoo needed in
FO-226322	8/20/2012		Please strip and wax the floors in office 222 of
FO-226398	8/21/2012		Requet to clean carpet, dust shelves, wipe down funiture, clean desks, etc for new faculty.
FO-226401	8/21/2012	8/24/2012	Carpet needs to be shampooed
FO-227053	8/28/2012		Room 3125 still needs dusting (windows, blinds, desk drawers have dust on them) Please ma
C-Sector 06		2	
FO-225940	8/16/2012		Carpet in numerous offices need to be machine cleaned: 4249, 51, 52, 57, 59, 62, 64, 65, 66,
FO-226430	8/21/2012		One of the lights in room 1320 is out and need
C-Sector 07		3	
FO-224505	8/2/2012	8/22/2012	Clean and wax floors in rooms #4342, #4347, #4348 and hallways of photography lab area of t
FO-225914	8/16/2012	8/20/2012	Carpet cleaning
FO-226318	8/20/2012	8/24/2012	Clean two heavy spills located in Conference Room A - 6th. floor. (See or call Felicia for detai
C-Sector 08		2	
FO-224484	8/1/2012	8/5/2012	Room 146 - Student Lounge - Please shampoo carpet in Student Lounge. Work should be do

Total			
FO-225840	8/15/2012		Please pick-up, clean, & return floor mat runners at Main entrance on Woodward, South (Anto
C-Sector 09		1	
FO-224568	8/2/2012	8/3/2012	Strip/wax my office area rm. 130
Routine		2	
C-Sector 02		1	
FO-227144	8/16/2012	8/28/2012	classroom in basement scrub an wax.rooms are 520,364,360,235,231,221,215. 2nd floor office
C-Sector 03		1	
FO-224436	8/1/2012		Carpet Cleaning Reuther Library Room 200
<hr/>			
Engineering		929	
Emergency		18	
E - Afternoon Engineer		8	
FO-225336	8/8/2012	8/9/2012	RM 3375 ALL FUMEHOOD ALARMS WENT OFF
FO-225337	8/8/2012	8/9/2012	BSMT BURNING SMELL BY ELEVS
FO-226041	8/17/2012	8/18/2012	1ST FL VIBRATING BADLY YOU CAN HEAR PIPES SHAKING AND FLOOR IS VIBRATING
FO-226040	8/17/2012	8/18/2012	ENITRE 1ST FLR IS BEING AFFECTED NOW (Vibrant Hum coming from the floor shaking
FO-226042	8/17/2012	8/18/2012	BSMT RM 410 DUE THE VIBRATION/SHAKING IT AFFECTED THE CAGEWASHER & HOT
FO-226717	8/24/2012	8/25/2012	SMELL OF NATURAL GAS THROUGH OUT BLDG
FO-227032	8/28/2012	8/28/2012	fire alarm
FO-227038	8/28/2012	8/28/2012	DOOR # 078-11E EXTERIOR DOOR NOT CLOSING...SECURITY ISSUE
E - Area 1 Engineer		4	
FO-224437	8/1/2012	8/2/2012	RM 123.04 HAS WATER POURING THRU CLNG DAMAGING PROPERTY
FO-226695	8/24/2012		RM 242 HAS A CLNG LEAK LKNG FROM LAB 342/344
FO-226908	8/27/2012	8/27/2012	PLS MEET UP W/PUB SAFE OFCR' RE ENTRAPMENT IN NEWEST ELEV (NORTH) BTWN
FO-226973	8/28/2012	8/28/2012	CALLED SCHINDLER ELEV CO FOR NORTH SHUTDOWN ELEV NORTH ELEV (entrapmen
E - Area 2 Engineer		1	
FO-226275	8/20/2012	8/22/2012	ACTIVE FIRE IN ROOM 1220.
E - Area 3 Auxiliary Eng		1	
H-32679	8/28/2012	8/29/2012	We think we have a water leakage in the back room carpet. We have been drying it for 2 week
E - Controls Engineer		4	
FO-224577	8/3/2012		ROOF TOP HVAC UNIT IS NOT PUTTING OUT COLD AIR. (1ST FL TOO HOT)
FO-225633	8/13/2012	8/14/2012	FLAME FAILURE, BOILER NOT ONLINE.
FO-226942	8/28/2012	8/28/2012	EMERGENCY R/R RM 0100/MECH RM TROUBLESHOOT REPAIR CONTROLS ON HPLHW
FO-227081	8/29/2012	8/29/2012	AC UNIT NOT WORKING IN SERVER ROOM 3359.1.
High		268	
E - Afternoon Engineer		45	
FO-224464	8/1/2012	8/2/2012	FIRE TROUBLE ALARM.
FO-224558	8/2/2012	8/2/2012	TRIPPED CIRCUIT BREAKER. LIGHTS OUT - ROOM 0401.
FO-224557	8/2/2012	8/3/2012	FIRE TROUBLE ALARM
FO-224842	8/3/2012	8/4/2012	ELECTRICITY WENT OUT
FO-224851	8/3/2012	8/4/2012	ALARM - 1ST FLOOR - MAYBE FROM MECHANICAL ROOM.
FO-225175	8/6/2012	8/7/2012	OUTSIDE RECEIVING AREA OF SHIFFMAN LIB HANDRAIL HAS SHARP METAL STICKIN
FO-225177	8/6/2012	8/7/2012	RM# 5344 FAUCET LEAKING HEAVILY
FO-225264	8/7/2012	8/9/2012	RM# 386 LIGHT SWITCH WONT TURN OFF IN LASER LAB
FO-225269	8/7/2012	8/8/2012	RM 4092 PRESIDENTS OFFICE TOO HOT, AIR NOT WORKING
FO-225316	8/8/2012	8/9/2012	RM# 5344 FAUCET LEAKING HEAVILY
FO-225329	8/8/2012	8/9/2012	RM 26.1 HI TEMP ALARM
FO-225330	8/8/2012	8/9/2012	RM 26.21 HI TEMP ALARM

Total

FO-225331	8/8/2012	8/9/2012	RM 26.22 HI TEMP ALARM
FO-225333	8/8/2012	8/9/2012	FIRE TROUBLE ALARM
FO-225332	8/8/2012	8/9/2012	RM 27 HI TEMP ALARM
FO-225338	8/8/2012	8/9/2012	ALL 2ND FLR CLASS RMS ARE TOO HOT
FO-225416	8/9/2012	8/10/2012	the set screw holding the handle on the door for room 2359 ENG is missing, making the room
FO-225423	8/9/2012	8/10/2012	FIRE PANEL IS BEEPING. (STATING TROUBLE) 1ST FLOOR SOUTH SIDE OF BUILDIN
FO-225508	8/10/2012	8/11/2012	ALARM SOUNDING IN LOBBY...TROUBLE ACK
FO-225509	8/10/2012	8/11/2012	FIRE TROUBLE ALARM
FO-225510	8/10/2012	8/11/2012	FIRE TROUBLE ALARM
FO-225511	8/10/2012	8/11/2012	FIRE TROUBLE ALARM
FO-225684	8/13/2012	8/14/2012	STAIRWELL DOOR ALARM 2ND FL NEAR FREIGHT ELEV
FO-225763	8/14/2012	8/14/2012	DTE/GAS CO is here Ref Crew CALLED THEM IN TO CK GAS SMELL
FO-225961	8/16/2012	8/17/2012	3RD FLR ONLY AVAILABLE WOMENS RM TOILET IS OVERFLOWING (NEAR RM 308)
FO-226293	8/20/2012	8/21/2012	9th FL WOMENS RESTROOM ACROSS FROM ENGLISH DEPT SINK PLUGGED UP
FO-226412	8/21/2012	8/21/2012	RM 2037 CLNG LEAK FROM ROOF COMIGN DOWN BEAMS
FO-226413	8/21/2012	8/22/2012	SW STAIRWELL 2ND FL FLOOD
FO-226416	8/21/2012	8/22/2012	RM 1120/PATRIDGE AUD EMERG EXIT DOOR NEXT TO RM 1119 DOOR ALARM SNDNG
FO-226419	8/21/2012	8/22/2012	1ST FL MENS RM URINAL CONTINUOUSLY RUNING OVER ON FL
FO-226517	8/22/2012	8/22/2012	Room 10 Located in BASEMENT
FO-226523	8/22/2012	8/23/2012	Room 3505 EDC - The air conditioner in this lab is blowing hot air and the room is now 90 deg
FO-226529	8/22/2012	8/23/2012	RM 103 SOUTHERN IS TOO COLD (lab cultures are failing)
FO-226605	8/23/2012	8/23/2012	LOUD NOISE COMING FROM 4TH FL RACEWAY AREA PLEASE SEE DR.WHITTUM-HUD
FO-226615	8/23/2012	8/23/2012	9th FL NO WATER
FO-226709	8/24/2012	8/25/2012	BSMNT VERY LOUD NOISE MORE LIKE A VIBRATION
FO-226721	8/24/2012	8/25/2012	1ST FL WATER FOUNTAIN'S SPITTING WALL AND FL IN FRONT OF ELEV
FO-227034	8/28/2012	8/28/2012	LIGHT SMOKING WITHIN RM 52 of ART BLDG
FO-227036	8/28/2012	8/28/2012	2ND FL STAIRWELL ALARM
FO-227105	8/29/2012	8/30/2012	SMELL OF BURNT RUBBER THROUGH OUT BLDG
FO-227115	8/29/2012	8/30/2012	LAB'S 309, 324 & 325 TOO HOT COMPUTER LAB
FO-227455	8/30/2012		NW INSIDE HANDICAP DOOR NOT WORKING
FO-227460	8/30/2012	8/31/2012	RM 3375 & ALSO 2ND FLR HAVE NO WATER IN ALL SINKS (AGAIN)
FO-227554	8/31/2012		RM 310 (FREEZER RM) IS GETTING TOO HOT
FO-227565	8/31/2012	9/1/2012	CASS SIDE ENT E STRWL 1ST-4TH FLRS A HI PITCH NOISE SNDNG

E - Area 1 Engineer

88

FO-224373	8/1/2012	8/1/2012	FIRE TROUBLE ALARM
FO-224377	8/1/2012	8/2/2012	RM 8127 ONLY CHEM FH SCREECHING NEEDS TO BE SHUT OFF/DOWN. (FH no longer
FO-224382	8/1/2012	8/2/2012	RM 5332/WALK IN COLD RM BOX HI TEMP ALARM SNDNG
FO-224451	8/1/2012	8/2/2012	6TH FLR RMS 6320, 6322, 6326, 6350, 6360 ARE COMPLAINING AGAIN ARE TOO HOT
FO-224492	8/2/2012	8/3/2012	ALL 2ND FLOOR ROOM PRESSURES ARE AT ZERO.
FO-224499	8/2/2012	8/2/2012	TOO COLD. ROOM 6275. INTERFERRING WITH EXPERIMENTS.
FO-224516	8/2/2012	8/2/2012	RM#8337 HIGH TEMP ALARM
FO-224791	8/3/2012	8/3/2012	Would you please put in an emergency work order to repair the latch mechanism on Rm 3168.
FO-224795	8/3/2012	8/3/2012	HIGH HUMIDITY IN ROOMS 463, 468, 471 & 474.
FO-224810	8/3/2012	8/3/2012	FIRE TROUBLE ALARM
FO-224812	8/3/2012	8/3/2012	FIRE ALARM PANEL SOUNDING.
FO-224866	8/6/2012	8/6/2012	HIGH TEMP ALARM AHU-3
FO-224873	8/6/2012	8/7/2012	FIRE TROUBLE ALARM

Total

FO-225100	8/6/2012	8/6/2012	FIRE PANEL ALARMING. 1ST FLOOR.
FO-225147	8/6/2012	8/9/2012	ELECTRICAL OUTLET COVER IS BROKEN. ROOM 418. Finished 8/10/2012 LT
FO-225200	8/7/2012	8/10/2012	Vibration trip device tripping unit,
FO-225240	8/7/2012	8/7/2012	FIRE TROUBLE ALARM
FO-225248	8/7/2012	8/7/2012	RF #2 FAN ALARM
FO-225283	8/8/2012	8/8/2012	ALARM SOUNDING ON FAN# 2
FO-225315	8/8/2012	8/9/2012	ELECTRICIANS,
FO-225334	8/8/2012	8/9/2012	FA SNDNGN AGAIN-PLS RESET R/R BLDG PLEASE CHECK SIEMENS FIRE ALARM PAN
FO-225352	8/9/2012	8/9/2012	FIRE TROUBLE ALARM.
FO-225368	8/9/2012	8/9/2012	INSIDE FRONT ENTRANCE DOOR HANDLE IS MALFUNCTIONING. ROOM 1039.
FO-225389	8/9/2012	8/10/2012	RM 1360 TOILET CONTINUOUSLY RUNNING CONCERNED ITS GOING TO OVERFLOW
FO-225433	8/10/2012	8/10/2012	FIRE TROUBLE ALARM.
FO-225435	8/10/2012	8/10/2012	COLD ROOM IS FREEZING COLD. ROOM 7233.
FO-225474	8/10/2012	8/10/2012	Hallway OUTSIDE OF RM AF 4 CEILING LEAK NEAR LIGHT FIXTURE
FO-225603	8/13/2012	8/13/2012	FIRE ALARM PANEL IS BEEPING. (READING SYSTEM TBL) 1ST FLOOR.
FO-225641	8/13/2012	8/14/2012	RM 139 SUPER FIRE ALARM MECH FLASH ELEC RM MAIN FP TAMPER M1-134 SPRINK
FO-225695	8/14/2012	8/15/2012	HIGH HUMIDITY. DOG ROOM. ROOM 0243.
FO-225696	8/14/2012	8/14/2012	URINAL OVERFLOWING. 4TH FLOOR MEN'S RESTROOM.
FO-225707	8/14/2012		CK NEW PART ACTIVE HALF ROOF ALARM KITCHENNET EXPANSION AREA N.E.
FO-225713	8/14/2012	8/14/2012	DOOR AT THE DOCK ON BRADY WILL NOT CLOSE ALSO ALARMING
FO-225739	8/14/2012	8/15/2012	DOOR WILL NO CLOSE PROPERLY. INNER LOADING DOCK DOOR 1590.2. PROLEM W
FO-225820	8/15/2012		BSMNT RM 10 MATH LAB CEILING TILE FLAKES FALLING ON EQUIPMENR
FO-225918	8/16/2012		REGISTERING POSITIVE PRESSURE SHOULD READ NEGATIVE. ROOM 5565. SEE ERI
FO-225924	8/16/2012	8/17/2012	HIGH TEMP. ALARM. ROOM 8337.
FO-225969	8/17/2012	8/17/2012	4TH FLR RMS 461, 463, 468, 469, 471, 472 & 474 ALL HAVE HI HUMIDITY
FO-225970	8/17/2012	8/17/2012	4TH FLR RMS 461, 463, 469, 472 ALL HAVE HI TEMP *note wrkng on Chiller*
FO-226296	8/21/2012	8/21/2012	LOW TEMPS. 400 SUITES AND 200 SUITES.
FO-226350	8/21/2012	8/21/2012	TROUBLE LIGHT IS ON FIRE ALARM PANEL. 1ST FLOOR BY DOOR.
FO-226358	8/21/2012	8/22/2012	CEILING PANEL HAS FALLEN AND ALSO A CEILING LEAK. ROOM 1125.
FO-226435	8/22/2012	8/22/2012	Refill Generator
FO-226437	8/22/2012	8/22/2012	RM 8337 AN ALARM IS SNDNG WHILE THEY'RE WRKNG ON D/C (JIM BRUNER)
FO-226445	8/22/2012		RM 701/STAFF LNGE IS EXTREMELY HOT
FO-226452	8/22/2012	8/22/2012	Roomhas low temp. The room is 68 and needs to be atleast 70.
FO-226468	8/22/2012	8/22/2012	TOO COLD. SUITE 200.
FO-226483	8/22/2012	8/22/2012	FIRE TROUBLE ALARM
FO-226488	8/22/2012	8/23/2012	FIRE ALARM PANEL ALARMING
FO-226490	8/22/2012	8/23/2012	NO POWER, POSSIBLE POWER BUMP
FO-226492	8/22/2012	8/22/2012	FIRE ALARM.
FO-226491	8/22/2012	8/23/2012	NO POWER, POSSIBLE POWER BUMP
FO-226498	8/22/2012	8/23/2012	NO POWER IN WALL OUTLETS. POSSIBLE POWER SURGE. ROOM 116.
FO-226568	8/23/2012	8/23/2012	Room 3505 EDC - The air conditioner in this lab is blowing hot air and the room is now 90 deg
FO-226573	8/23/2012	8/24/2012	4TH FLR NEAR RM 475 BREEZEWAY HALLWAY PIPE VIBRATING/NOISEY
FO-226644	8/24/2012	8/24/2012	RECORDING IS STATING THAT GENERATORS ARE RUNNING & THAT FUEL NEEDS FIL
FO-226650	8/24/2012		RM 309,324,325 AIR NOT WORKING, TESTING TAKING PLACE TODAY. SEE PHIL IN RM
FO-226672	8/24/2012		CEILING LEAK. ROOM 420.
FO-226693	8/24/2012		RM 414 HAS HI TEMP
FO-226694	8/24/2012		RM 140 ONLY SINK IS PLUGGED UP

Total

FO-226740	8/27/2012		RM 100 LOW STEAM PRESSURE ALARM
FO-226776	8/27/2012	8/27/2012	RM 5463 HAS HUMIDITY
FO-226777	8/27/2012	8/27/2012	RM 5463 HAS HI TEMP
FO-226779	8/27/2012	8/27/2012	RM 5565 HAS HI TEMP
FO-226781	8/27/2012		RM 5565 HAS HI HUMIDITY
FO-226835	8/27/2012		RM 5445 HAS HI HUMIDITY
FO-226838	8/27/2012		RM 5447 HAS HI HUMIDITY
FO-226840	8/27/2012		RM 5449 HAS HI HUMIDITY
FO-226844	8/27/2012		RM 5451 HAS HI HUMIDITY
FO-226845	8/27/2012	8/27/2012	RM 5453 HAS HI HUMIDITY
FO-226847	8/27/2012		RM 5455 HAS HI HUMIDITY
FO-226860	8/27/2012		BSMT/TUNNEL ENTRANCE DOOR ISN'T OPENNING FROM OUTSIDE & INSIDE DOOR IS
FO-226873	8/27/2012		RM 027.2 HUMDITY IS REGISTERING 55% & 65% HI HUMIDITY
FO-226874	8/27/2012		HIGH TEMP. AND HIGH HUMIDITY IN ROOM 0243.
FO-226875	8/27/2012		RM 027.3 HUMDITY IS REGISTERING 55% & 65% HI HUMIDITY
FO-226877	8/27/2012		RM 027.4 HUMDITY IS REGISTERING 55% & 65% HI HUMIDITY
FO-226888	8/27/2012	8/27/2012	CEILING LEAK. ROOM 026.3
FO-226904	8/27/2012	8/30/2012	RM 220 ONLY SINK A BLACK SUBSTANCE IS COMING OUT OF FAUCET
FO-226987	8/28/2012		RM 60 FUME HOOD DOWN
FO-226988	8/28/2012		RM 40 TEMP TO HIGH COULD DAMAGE EQUIPMENT
FO-226995	8/28/2012		RM 7223 HI TEMP ALARM (WALK IN BOX)
FO-227042	8/29/2012		Office of the Dean (Rm. 441.4): Private Restroom inside Dean's office: Issue is with the drain.
FO-227088	8/29/2012	8/29/2012	HIGH HUMIDITY. ROOM 5565.
FO-227096	8/29/2012		RM 346/MECH-BLR RM WATER COMING FROM WALL/BOX
FO-227099	8/29/2012		RM 414 HAS A HI TEMP
FO-227124	8/29/2012	8/30/2012	Room 2507 - the door janes from the inside, I was not able to open it from inside the room.
FO-227161	8/30/2012		RM 3375 NO WATER IN ALL SINKS
FO-227536	8/31/2012		LOW STEAM PRESSURE. ROOM 100.

E - Area 2 Engineer

63

FO-224394	8/1/2012	8/1/2012	Room 211.2--problem opening and locking the door--
FO-224503	8/2/2012	8/2/2012	WALL OUTLETS ARE NOT WORKING. ROOM 4100.
FO-224519	8/2/2012	8/2/2012	FIRE TROUBLE ALARM
FO-224803	8/3/2012		FRONT DOOR IS NOT CLOSING PROPERLY.
FO-224863	8/6/2012	8/6/2012	FIRE TROUBLE ALARM.
FO-224949	8/6/2012	8/6/2012	WALL OUTLETS ARE NOT WORKING. ROOMS 398 & 394.
FO-224957	8/6/2012	8/6/2012	4TH FL BOARD OF GOVERNORS CEILING CAVED IN DUE TO WATER DAMAGE
FO-225098	8/6/2012	8/6/2012	WALL OUTLET IS NOT WORKING. 1ST FLOOR BEHIND COPY MACHINE. ACROSS FRO
FO-225104	8/6/2012		CEILING LEAK. ROOMS 4130 AND 4194.
FO-225111	8/6/2012	8/6/2012	POWER FAILURE/LOW BATTERY ALARM WITH RESET. 3RD FLOOR NORTH PHONE CL
FO-225144	8/6/2012	8/6/2012	WALL OUTLETS ARE NOT WORKING. ROOM 4117.
FO-225187	8/7/2012	8/7/2012	CEILING LEAK. 1ST FLOOR HALLWAY NEAR ROOM 115.
FO-225188	8/7/2012	8/7/2012	SMELL OF SMOKE. BUILDING. INCLUDING ROOM 3092. SEE PATRICE.
FO-225191	8/7/2012	8/7/2012	LIGHTS WILL NOT COME ON. ROOM 101.
FO-225239	8/7/2012	8/7/2012	BSMNT 2 RM's LIGHTS WENT OUT TOTALLY DARK IN RAQUETBALL AREA
FO-225385	8/9/2012	8/9/2012	UNKNOWN WATER LEAK. ROOM 1265.
FO-225436	8/10/2012	8/10/2012	DOOR WON'T LOCK. ROOM 10.5.
FO-225439	8/10/2012		CEILING LEAK. ROOM 4110.

Total

FO-225442	8/10/2012		RM# 4107 CEILING TILE FALLING IN, WATER POURING THROUGH
FO-225456	8/10/2012	8/10/2012	CEILING TILES ARE DAMAGED AND FALLING - POSSIBLE CEILING LEAK. ROOM 21.
FO-225467	8/10/2012	8/29/2012	4th floor north stairwell door lock core very
FO-225458	8/10/2012	8/10/2012	RM# 317 VERY COLD THERMOSTAT NOT WORKING
FO-225465	8/10/2012	8/10/2012	NO WATER - 3RD FLOOR LOUNGE.
FO-225499	8/10/2012	8/10/2012	FIRE TROUBLE ALARM.
FO-225534	8/13/2012	8/13/2012	4th FL KITCHEN ACROSS FROM RM 4100 CEILING LEAKING BADLY
FO-225599	8/13/2012	8/13/2012	DOOR LOCKED NEED ACCESS TO RM 4302
FO-225614	8/13/2012	8/13/2012	FIRE TROUBLE ALARM
FO-225624	8/13/2012	8/13/2012	ENTIRE BLDG HAS THE HEAT ON/HOT
FO-225723	8/14/2012	8/14/2012	WATER COMING UP THROUGH FLOOR. ROOM 1265.
FO-225773	8/15/2012		HANDICAP DOORS WON'T CLOSE. WARREN SIDE.
FO-225786	8/15/2012	8/15/2012	ALARM SOUNDING, NOT SURE WHAT TYPE OF ALARM SHUTS OFF THEN RESTARTS
FO-225815	8/15/2012	8/15/2012	CEILING LEAK. 2ND FLOOR HALLWAY BETWEEN ELEVATOR AND LUNCHROOM.
FO-225870	8/16/2012	8/16/2012	2ND FLR EXIT DOOR ALARM SNDNG
FO-225895	8/16/2012		CEILING TILE HAS FALLEN. HALLWAY OUTSIDE OF ROOM 150.
FO-225915	8/16/2012	8/16/2012	BEEPING NOISE FROM FIRE ALARM PANEL MSG READS FIRE PUMP RUNNING
FO-225933	8/16/2012	8/17/2012	FIRE ALARM PANEL BEEPING.
FO-225936	8/16/2012	8/16/2012	KEYS WON'T TURN IN DOOR LOCK. ROOM 2079. SEE SHERRY IN ROOM 2074.
FO-226001	8/17/2012	8/17/2012	2ND FLR AUDIBLE ALARM SNDNG BURGLAR/BURGLAR NEAR CASHIERS' OFC, GRNAD
FO-226063	8/20/2012	8/20/2012	fire trouble alarm
FO-226067	8/20/2012	8/20/2012	STRWL #1 ALL LITES ARE OUT
FO-226117	8/20/2012		RM# 1255 UNABLE TO UNLOCK DESK DRAWER. NEED ACCESS ASAP CHECK INSID D
FO-226270	8/20/2012	8/20/2012	Please repair the lock on room 3267. The occupant is having difficulty removing and inserting
FO-226257	8/20/2012		DOOR WON'T LOCK. ROOM 1606.
FO-226310	8/21/2012	8/21/2012	WATER NOT WORKING IN ENTIRE BLDG
FO-226352	8/21/2012		3rd FL COMMUNITY RM POWER OUTLETS NOT WORKING INCLUDING CEILING OUTLE
FO-226489	8/22/2012	8/22/2012	POSSIBLE POWER SURGE. LIGHTS WENT OFF AND CAME BACK ON. ROOM 4092.
FO-226493	8/22/2012	8/23/2012	NO POWER, POSSIBLE POWER BUMP
FO-226494	8/22/2012	8/22/2012	NO POWER, POSSIBLE POWER BUMP
FO-226495	8/22/2012	8/23/2012	NO POWER, POSSIBLE POWER BUMP
FO-226500	8/22/2012	8/23/2012	POWER WENT OUT CAME ON. FEW RMS ON 1ST FL STILL NO POWER RM 131 ALARM
FO-226511	8/22/2012	8/22/2012	2ND FLR WOMENS RM HANDICAP STALL TOILET IS PLUGGED & ABOUT TO OVERFLO
FO-226544	8/23/2012	8/23/2012	ENTIRE 4TH FLR ALL LITES ARE VERY DARK
FO-226661	8/24/2012		GAS SMELL. BASEMENT OFFICES.
FO-226680	8/24/2012		1ST FLR AUDITORIUM IS TOO HOT/SPECIAL EVENT FOR OISS
FO-226685	8/24/2012		FIRE TROUBLE ALARM SYSTEM FLASHING YELLOW
FO-226689	8/24/2012		1ST FLOW WATER PRESSURE 2ND FL NO WATER PRESSURE
FO-226700	8/24/2012		STE 4200 IS TOO HOT
FO-226713	8/24/2012	8/25/2012	HUGE LOUD NOISE AND DOORS RATTLING. BASEMENT ROOM 0316 AND ADJACENT
FO-226881	8/24/2012	8/27/2012	Check for leak in ceiling and replace ceiling tile in faculty office. Ceiling tile is molding.
FO-227145	8/30/2012	8/30/2012	RM 321 HAS A CLNG LEAK
FO-227493	8/31/2012	8/31/2012	EXPOSED WIRES FROM WALL OUTLET. ROOM 2226. SEE JENNIFER.
FO-227496	8/31/2012		Mens room 104 State Hall water running over flowing in urinal
FO-227522	8/31/2012		BLOWN CIRCUIT BREAKER. ROOM 347.

E - Area 3 Auxiliary Eng

60

H-31762 8/1/2012

8/1/2012 Toilet flush and kitchen sink are clogged.

Total

H-31772	8/1/2012	8/24/2012	Please check and all the wall vents next to the 03 rooms on each floor. There are all making a
H-31799	8/1/2012	8/2/2012	Kitchen exhaust fan does not work well and repeatedly causes accumulation of smoke.
H-31807	8/1/2012	8/2/2012	The shower the second bathroom will not turn off the water continues to run and is noising and
H-31809	8/1/2012		Three electric outlets are broken and hanging from the wall. The one in the kitchen next to the
H-31813	8/2/2012	8/17/2012	the sink by the bathroom has no water
H-31827	8/2/2012		Little Asia Market:
H-31840	8/3/2012	8/3/2012	the HVAC unit is not working. it is very hot in the room but it is set to cold
H-32047	8/10/2012	8/10/2012	Garbage disposal leaking under sink around neck...move-in 8/12/12
H-32065	8/13/2012		Kitchen sink needs new sprayer.
H-32081	8/13/2012		Replace smoke detector
H-32082	8/13/2012		Replaced smoke detector
H-32086	8/13/2012	8/14/2012	there is no shower head in this RA room. Please put one in. Thank you
H-32116	8/14/2012		replace whole light fixture above room 543 Ghafari
H-32241	8/14/2012	8/14/2012	Electrical outlet behind the fridge needs to be fixed/replaced.
H-32159	8/14/2012		replace smoke detector
H-32160	8/14/2012	8/24/2012	put a/c unit back together
H-32207	8/14/2012	8/14/2012	a tap in one bathroom, can not control where the water out, can not hold to let the water out from
H-32162	8/15/2012		fuse blown in room 643. central to right hand side
H-32165	8/15/2012		Bathroom shower light not working-shortage in switch. Shuts down electricity in entire apartment
H-32220	8/16/2012	8/18/2012	The living room, 1st and 2nd bedroom has no electricity the plugs are not working.
H-32221	8/16/2012	8/22/2012	RA Room - Main kitchen faucet leaks from underneath cupboard. Please repair! Thank you!
H-32200	8/17/2012	8/17/2012	The AC is not working. Please fix
H-32201	8/17/2012	8/17/2012	The AC is not working. Please fix
H-32202	8/17/2012	8/17/2012	The AC is not working. Please fix
H-32204	8/17/2012		Shower is constantly leaking.
H-32248	8/17/2012		Toilet leaks under tank when flushed.
H-32372	8/17/2012		The electrical outlet in the right corner of the room between the desk and the television does not
H-32293	8/20/2012		Mechanical check. MOVE-IN 8/25/12
H-32334	8/21/2012		Outlet in the living room is broken
H-32570	8/21/2012		2nd toilet doesn't have water in bowl and needs fixing.
H-32342	8/21/2012	8/24/2012	8/24/2012 the air is not working. Please fix
H-32357	8/21/2012	8/23/2012	8/30/2012 the air is not working. Please fix
H-32370	8/21/2012		Toilet leaks everytime it gets flushed. Move-in date 8/22/12.
H-32701	8/22/2012	8/29/2012	5th floor Kitchenette sink appears to have a slow leak.
FO-226496	8/22/2012	8/23/2012	FIRE TROUBLE ALARM
H-32815	8/23/2012		1. The Insinkerator in the Kitchen hasn't been Working since the day we moved in and then it j
H-32400	8/23/2012	8/25/2012	8/24/2012 the HVAC UNIT IS NOT WORKING.
H-32421	8/24/2012		light above door flickers whenever the door is shut - 517 Ghafari
H-32429	8/24/2012	8/24/2012	only 1 outlet is working in 211D. Maybe there is a fuse blown.
H-32434	8/25/2012	8/27/2012	electrical outlet behind dresser does not work - room 636
H-32600	8/26/2012	8/28/2012	The light on the thermostat is red, and the air is not working.
H-32599	8/26/2012	8/29/2012	The air conditioning isn't blowing out cold air!
H-32521	8/26/2012		VACANT UNIT---MECHANICAL CHECK ---MOVE IN 9/1/12
H-32598	8/26/2012	8/29/2012	AC is not working, room is at 80 degrees.
H-32562	8/27/2012	8/27/2012	The sink in the back (by the bathroom with the toilet) was backed up last night with water. An
H-32559	8/27/2012	8/28/2012	Two electrical outlets in my room are not working.
H-32628	8/27/2012		AC unit not workingauthenticated user: Ryan Mitchell - ec3980requester ip address: 141.2

Total

H-32586	8/27/2012	8/29/2012	air conditioning is not working.
H-32573	8/27/2012		Garbage disposal is not working.
H-32589	8/27/2012	8/29/2012	Air conditioner is still not working. It has been looked at a couple of times.
H-32663	8/27/2012		The living room and 1st and 2nd bedrooms don't have power in the outlets. They have already
H-32691	8/28/2012	8/29/2012	Our sink has over flown it looks like dirt or rust is coming up out of the sink and its falling onto
H-32692	8/28/2012	8/30/2012	Air condition not working. Red light is on
H-32689	8/28/2012		Kitchen sink is backing up because garbage disposal is not working.
H-32728	8/29/2012	8/30/2012	In Shower room. The shower does not drain properly, and puddles when shower is running. Al
H-32735	8/29/2012		-There is a leaking fire sprinkler (brown stain) above room 614-There is a box above room 6
H-32792	8/30/2012	8/31/2012	**URGENT** Resident has put a bucket underneath sink under the kitchen sink (yesterday's w
FO-227131	8/30/2012	8/30/2012	FIRE ALARM.
H-32845	8/31/2012		The sprinkler in the hallway has dripped red dye on the wall and carpet below it. authenticate

E - Controls Engineer

12

FO-225536	8/9/2012	8/15/2012	Boiler #3 continues to tripp on Flame Failure.
FO-225495	8/9/2012	8/29/2012	Refrigeration Crew; High
FO-225518	8/11/2012	8/15/2012	stadium boiler hot water gas valves hung open
FO-225638	8/13/2012	8/20/2012	R/R RM 154.2/MENS CO-ED TRAINING RM, DEAD SHORT IN THE WIRING OF CONDENS
FO-225711	8/14/2012		Refer Shop:
FO-226508	8/22/2012	8/22/2012	Adjust Burner
FO-226674	8/24/2012	8/24/2012	Troubleshoot unit cooling won't come on,compressors
FO-226895	8/27/2012	8/28/2012	RTU#1 will not run
FO-226923	8/27/2012		Rooftop chiller not coming on
FO-226986	8/28/2012		RTU # 1 Condenser Fan not operating but works when contactor is pushed in?
FO-227089	8/29/2012		Refrigeration Crew; High
FO-227137	8/30/2012		Boiler will not light off, coming out of OCC

Medium

389

E - Afternoon Engineer

56

FO-224458	8/1/2012	8/2/2012	RM 3638 TOO HOT..WARM AIR BLOWING
FO-224466	8/1/2012	8/1/2012	RM 6275 IS TOO COLD
FO-224563	8/2/2012	8/3/2012	RM# 2208 AIR NOT WORKING
FO-224564	8/2/2012	8/3/2012	4th FL FELT A STRONG VIBRATION IN BLDG
FO-224843	8/3/2012	8/3/2012	RM# 3016 TOO HOT
FO-224846	8/3/2012	8/4/2012	RM 107/RECORDS IS TOO HOT
FO-225171	8/6/2012	8/7/2012	The circuit breakers that the microwaves are
FO-225176	8/6/2012	8/7/2012	1ST FL FACILITIES & SUPPORT MAILBOX#11 UNABLE TO UNLOCK
FO-225183	8/6/2012	8/7/2012	BURNING RUBBER SMELL NEAR 1ST FL ELEV
FO-225328	8/8/2012	8/9/2012	Please send someone to adjust the temperature in this room. Staff just moved into this room
FO-225322	8/8/2012	8/9/2012	Room 1230 is too hot
FO-225323	8/8/2012	8/14/2012	Room 9112's fume hood has no air flow
FO-225505	8/8/2012	8/11/2012	project_description: Light Fixture is coming apart over countertop in the Undergraduate Admis
FO-225335	8/8/2012	8/9/2012	RMS 1102 & 1310 ARE TOO HOT
FO-225339	8/8/2012	8/9/2012	RM# 1313 TOO HOT...SEVERAL RM'S REPORTED TOO HOT CHECK ENTIRE BLDG
FO-225342	8/8/2012	8/9/2012	CORRIDOR DOOR NEAR 211 INSIDE DOOR KNOB FALLS OFF
FO-225422	8/9/2012	8/10/2012	A/C IS VERY NOISY. ROOM 425.
FO-225507	8/10/2012	8/11/2012	There were sparks and smoke coming from something plugged into the receptacle on wall be
FO-225675	8/13/2012	8/14/2012	RM 435 IS TOO COLD
FO-225768	8/14/2012	8/14/2012	6th FL RM 649 TOILET NOT FLUSHING PROPERLY
FO-225853	8/15/2012	8/15/2012	RM# 21 CHECK FOR LEAK TILE RECENTLY REPLACED. TILE NOW CRUMBLING DOWN

Total

FO-225861	8/15/2012	8/15/2012	1ST FL TOO COLD
FO-225958	8/16/2012	8/17/2012	CONTRACTOR NEEDS ACCESS TO ROOF
FO-225963	8/16/2012	8/17/2012	FREIGHT ELEV NEEDS TO BE UNLOCKED
FO-226287	8/20/2012	8/21/2012	TOO WARM. ROOM 4200.
FO-226403	8/21/2012	8/22/2012	Purdy 2nd Floor - East side of 2nd floor:
FO-226405	8/21/2012	8/22/2012	RM 4085 IS TOO HOT
FO-226409	8/21/2012	8/22/2012	1ST FL ATRIUM WINDOW HAS WATER COMING IN
FO-226408	8/21/2012	8/22/2012	RM 102 CLNG LEAK IN THE LAST STORAGE CLOSET NEAR BACK EXIT DOOR
FO-226411	8/21/2012	8/21/2012	RM# 403 & 603 AIR NOT WORKING TOO HOT
FO-226415	8/21/2012	8/22/2012	RM # 1016 PIPES LEAKING IN MACHINE SHOP
FO-226417	8/21/2012	8/22/2012	13TH FLR MENS RM ACROSS FROM 13001 TOILET CON'T FLUSHING
FO-226418	8/21/2012	8/22/2012	RM 13001.3 RESET CIRCUIT BREAKER
FO-226514	8/22/2012	8/22/2012	RM 201 TOO HOT
FO-226528	8/22/2012	8/23/2012	PIPE MAKING NOISE BEHIND RM 363
FO-226533	8/22/2012	8/23/2012	OUTLET RP-3SL-29 NOT WORKING WITHIN RM 311
FO-226610	8/23/2012	8/24/2012	ATTRIUM 2 AREAS ARE TOO HOT
FO-226612	8/23/2012	8/24/2012	RM#2135 CEILING LEAK IN LEFT CORNER OF OFFICE
FO-226616	8/23/2012	8/24/2012	1ST FL NEAR MAIN ENTRANCE WATER FOUNTAIN FALLING OFF WALL
FO-226710	8/24/2012	8/25/2012	RM 0100/MECH RM PLEASE TROUBLESHOOT #1 CONDENSATE RECEVIER PUMP MOT
FO-226715	8/24/2012	8/24/2012	1st FL WOMENS RESTROON SINK LEAKING
FO-227023	8/27/2012	8/29/2012	Electrical outlets not working in room 118.
FO-226928	8/27/2012	8/28/2012	RM 4141 HEAT COMING FROM CHEMICAL HOOD
FO-226935	8/27/2012	8/28/2012	RM 14001.3 TOO HOT
FO-227037	8/28/2012	8/29/2012	RM 3359.1 TOO HOT
FO-227106	8/29/2012		RM 103.4 HAS A NOISE COMING FROM AIR VENT
FO-227108	8/29/2012	8/30/2012	FAN NOT WORKING TOO HOT
FO-227112	8/29/2012	8/30/2012	2ND FL RM J TOO HOT ALSO HAS BURNING SMELL
FO-227113	8/29/2012	8/30/2012	RM 462 WET CEILING TILE FELL, CHECK FOR LEAK
FO-227114	8/29/2012	8/29/2012	2ND FL NEAR ELEV CEILING LEAK
FO-227453	8/30/2012	8/31/2012	SINK CLOGGED AND LEAKING WITHIN RM 250
FO-227456	8/30/2012	8/31/2012	RM 14001.3 IS TOO HOT (t-stat in rm 14001.2)
FO-227457	8/30/2012	8/31/2012	RM 4200 IS TOO COLD
FO-227461	8/30/2012	8/31/2012	RM 224 ELEC OUTLET NOT WORKING
FO-227552	8/31/2012	9/1/2012	RED LIGHT ON THERMOSTAT. ROOM 105.
FO-227555	8/31/2012	9/1/2012	RM 133/DISPATCH IS TOO HOT/HVAC STOPPED WRKNG

E - Area 1 Engineer

106

FO-224415	8/1/2012	8/2/2012	Heat is blasting from the registers.
FO-224417	8/1/2012	8/1/2012	ICE MACHINE 2ND FL LEAKING
FO-224424	8/1/2012	8/9/2012	Ladies room facet is continuously running; may need new washer.
FO-224423	8/1/2012	8/1/2012	TOO HOT. ROOM 1230.
FO-224425	8/1/2012	8/2/2012	RM#5463 AUTOCLAVE HAS NO STEAM
FO-224439	8/1/2012	8/8/2012	Office is to warm.
FO-224440	8/1/2012	8/8/2012	Office is to warm.
FO-224441	8/1/2012	8/10/2012	Lab is to warm.
FO-224494	8/2/2012	8/9/2012	RM 9272 IS TOO COLD AIR VENT BLOWING OUT COLD AIR
FO-224495	8/2/2012	8/2/2012	RM # 472 DOOR SCRAPES ALONG FLOOR
FO-224511	8/2/2012	8/2/2012	RESET ROLL DOWN DOOR. ROOM 101.2

Total

FO-224790	8/3/2012	8/3/2012	Room 1111it
FO-224804	8/3/2012	8/3/2012	There are broken floor tiles that need to be removed in room 0325 Main Engineering.
FO-224807	8/3/2012		Women's rest room - 0331 - Seat has broken off of toilet. Please fix ASAP.
FO-224868	8/6/2012	8/6/2012	TOO HOT. 3RD FLOOR.
FO-225127	8/6/2012		Room 1301's dimmer light switch is turning on
FO-225102	8/6/2012	8/7/2012	RM##4516 TOO COLD
FO-225114	8/6/2012	8/9/2012	TOO COLD. ROOM 2290.
FO-225117	8/6/2012	8/10/2012	VENT BLOCKED NO AIR FLOWING IN RM 5324
FO-225120	8/6/2012	8/9/2012	STRANGE NOISE IN BACK OFFICE NEAR RM 128
FO-225121	8/6/2012	8/7/2012	RM# 3330 TOO COLD CHECK ENTIRE BLDG TEMP
FO-225128	8/6/2012	8/6/2012	2nd Floor Urinals near freight elevator overflowing, old lab wing
FO-225133	8/6/2012	8/6/2012	Room 3317 our AC has been down for a week. It's quite hot for students to stay in the lab. Th
FO-225146	8/6/2012		PIPE LEAKING UNDERNEATH SINK. ROOM 409.
FO-225193	8/6/2012		Door lock to rm 356 not functioning properly.
FO-225224	8/7/2012	8/7/2012	TOILET IS PLUGGED AND BAGGED. WOMEN'S RESTROOM - ROOM 331.
FO-225274	8/8/2012	8/8/2012	LIGHT TIMER IS NOT WORKING. ROOM 200.10. Finished 8/17/2012 LT
FO-225279	8/8/2012	8/9/2012	RM# 7237 MAIN SINK DRAINING SLOWLY
FO-225284	8/8/2012	8/15/2012	CAFETERIA RESET BREAKER. The circuit breakers that the microwaves are
FO-225355	8/8/2012	8/16/2012	Can the air balance and air temperature be checked in this surrounding area? Some of the cei
FO-225312	8/8/2012	8/9/2012	A/C NOT WORKING. ROOM 2208.
FO-225373	8/9/2012	8/9/2012	LECTURE HALL LIGHTS NOT TURNING ON. HALF ON HALF OFF
FO-225390	8/9/2012		3RD FL LADIES RM SINK CLOGGED
FO-225434	8/10/2012		DOCK DOOR IS BROKEN. WILL NOT GO UP OR DOWN.
FO-225479	8/10/2012		Hallway outside room 2125 - North face of simplex clock is 3 hours slow. Please fix.
FO-225463	8/10/2012		RM# 2105 HUMIDIFIER NOT WORKING
FO-225492	8/10/2012	8/16/2012	RM# 435 TOO HOT
FO-225497	8/10/2012	8/10/2012	TOILET CONTINUOUSLY RUNNING. WOMEN'S RESTROOM 1360.
FO-225498	8/10/2012	8/10/2012	A/C MAKING LOUD NOISE. 1ST FLOOR.
FO-225502	8/10/2012	8/24/2012	RM#5324 NO AIR FLOW..VENT BLOCKED
FO-225611	8/10/2012		first floor women's restroom behind the service desk 2nd stall needs batteries to flush. can yo
FO-225622	8/13/2012	8/13/2012	LOW WATER PRESSURE IN AUTOCLAVE. 4TH FLOOR ROOM 440.
FO-225636	8/13/2012	8/13/2012	TOO COLD. 3RD FLOOR HALLWAY.
FO-225740	8/14/2012	8/14/2012	RM#103 TOO COLD
FO-225777	8/15/2012	8/15/2012	TOO COLD. ROOM 3009.
FO-225794	8/15/2012	8/16/2012	NE CORRIDOR IN BSMNT LEAK FROM CEILING
FO-225797	8/15/2012	8/15/2012	TOO COLD. ROOM 2173.
FO-225807	8/15/2012	8/21/2012	RM 154 IS TOO COLD
FO-225821	8/15/2012	8/15/2012	2 CLOGGED SINKS. ROOM 4328.
FO-225822	8/15/2012		RM 351 STEAM LEAK, LEAK CAUSING DAMAGE TO CABINETS...SEE GREG FOR ACCES
FO-225882	8/16/2012	8/16/2012	RM 2111 NORTH LAB BENCH DISTILLED WATER IS LKNG FROM UNDERNEATH
FO-225901	8/16/2012	8/24/2012	RM#5324 & 5344 NO AIR FLOW..VENT BLOCKED
FO-225919	8/16/2012	8/16/2012	FLOOR TILES ARE COMING UP. HALLWAY OUTSIDE OF ROOM 231.
FO-225935	8/16/2012		BTW RM 110 & 180 IS A STORAGE RM WITH A CABINET WONT UNLOCK WITH KEY
FO-225964	8/16/2012	8/16/2012	Basement men restroom rm. 508:
FO-225982	8/17/2012	8/17/2012	BLDG IS TOO HOT
FO-225983	8/17/2012	8/17/2012	LOW TEMP IN RM 5455
FO-225992	8/17/2012	8/17/2012	TOO HOT. ROOM 103.

Total

FO-225998	8/17/2012		RM 5324 IS STILL TOO HOT
FO-226000	8/17/2012	8/17/2012	CRACK IN WALL. ROOM 0245.1
FO-226010	8/17/2012		CHECK CAMERA ABOVE RECEIVING RM DOOR TO MAKE SURE THEIR IS A POWER SO
FO-226241	8/20/2012	8/20/2012	A/C BLOWING HOT AIR. ROOM 2100.
FO-226258	8/20/2012	8/21/2012	RM 154 TOO COLD
FO-226308	8/21/2012	8/21/2012	WINDOW SHADE STRING IS BROKEN. ROOM 435.
FO-226313	8/21/2012	8/23/2012	FLOODING IN HALLWAY AREA OF BSMNT, PUDDLES OF WATER ON FLOOR. DEVELOP
FO-226332	8/21/2012		Outside of the staff office, there are ceiling tiles that need to be replaced because of a past le
FO-226334	8/21/2012		Ceiling in teaching hospital cracking and bubbling...excess humidity??
FO-226343	8/21/2012		3rd FL MOLDING ON CEILING FALLING OFF
FO-226357	8/21/2012	8/21/2012	TOO HOT. BASEMENT ROOM 0504.
FO-226387	8/21/2012	8/21/2012	RM 103 IS TOO COLD
FO-226434	8/21/2012		There is ventilation fan that is making a loud sound; it seems broke.
FO-226438	8/21/2012	8/27/2012	Please replace missing ceiling tiles.
FO-226439	8/21/2012	8/27/2012	Please replace missing ceiling tiles in the hallway outside of 0113.
FO-226461	8/22/2012		No ventilation in the bathrooms (men's and women's) causes these rooms to smell, and in win
FO-226497	8/22/2012	8/29/2012	TOO COLD. ROOM 2101.
FO-226505	8/22/2012		RM 2106 HAS A CLNG LEAK
FO-226541	8/23/2012	8/24/2012	RM 103 SOUTHERN area need to set up a temp regulation to determine why it is too cold-col
FO-226566	8/23/2012	8/23/2012	RM 2524 ELEC OUTLETS NOT WORKING
FO-226571	8/23/2012	8/23/2012	2ND FL UNISEX RESTROOM TOILET NOT FLUSHING
FO-226657	8/24/2012	8/24/2012	TOO HOT. ROOM 1328.
FO-226664	8/24/2012		Urinals not flushing in the basement, and on the 1st,3rd,5th and 7th floors in the Science Engi
FO-226684	8/24/2012		ROOM 3520 - Plumbing problem. There is a sprout at the bottom of the sink that is leaking w
FO-226682	8/24/2012		LOUD NOISE COMING FROM THE 4TH FLOOR RACEWAY AREA. GO TO ROOM 361 OR
FO-226884	8/24/2012	8/27/2012	Study room #131 the lock is hard to use may be sticking. Could the locksmith please check thi
FO-226775	8/27/2012		JARFAR LECT HALL @ FRONT 2ND LEVEL IS TOO COLD
FO-226846	8/27/2012	8/29/2012	RM 5550 OR NEXT TO RM 5550 CIRCUIT BREAKER NOT WORKING NEEDS RESET
FO-226848	8/27/2012	8/28/2012	3RD FLR IS TOO HOT/HUMID
FO-226852	8/27/2012	8/27/2012	RM 4351 NO WATER WORKING IN SINK
FO-226854	8/27/2012	8/27/2012	RM 2119 IS TOO HOT
FO-226855	8/27/2012	8/27/2012	RM 2151 IS TOO HOT
FO-226856	8/27/2012	8/27/2012	RM 2156 IS TOO HOT
FO-226862	8/27/2012	8/28/2012	LADIES RM TOILET CONTINUOUSLY FLUSHING
FO-226868	8/27/2012	8/27/2012	TOO HOT. ROOM 8244.
FO-226902	8/27/2012		RM 219 ONLY SINK HAS NO HOW WTR
FO-226903	8/27/2012	8/30/2012	RM 219 ONLY SINK FAUCET IS DRIPPING
FO-226968	8/27/2012	8/28/2012	The key core in room 2507 needs to be replaced/fixed - it is stripped. Thanks.
FO-226997	8/27/2012	8/28/2012	Room 3528 - Core was taken out of door is in the room and needs to be re-installed.
FO-226955	8/28/2012	8/28/2012	1ST FL BOOSTER HEATER LEAKING WATER IN KITCHEN
FO-226965	8/28/2012		RM 3027 TOO HOT
FO-226974	8/28/2012	8/22/2012	PLUGGED TOILET. 3RD FLOOR MEN RESTROOM.
FO-226993	8/28/2012	8/28/2012	RM 116 NO POWER
FO-227071	8/29/2012	8/29/2012	LEAK - WATER ON FLOOR. 3RD FLOOR WOMEN'S RESTROOM.
FO-227095	8/29/2012		1ST FLR BACK ARE BY RM 134 & STRWL WOMENS RM TOILET CON'T FLUSHING
FO-227147	8/30/2012	8/30/2012	1ST FL CORRIDOR AREA'S PLUG'S NOT WORKING
FO-227150	8/30/2012		RM 14 left hand sink is plugged

Total

FO-227523	8/31/2012	8/31/2012	CEILING LEAK. ROOM 2062.
E - Area 2 Engineer		116	
FO-224388	8/1/2012	8/1/2012	SUITE 300 TOO HOT..AIR NOT WORKING
FO-224411	8/1/2012	8/1/2012	NO A/C. CARRIAGE HOUSE EAST.
FO-224434	8/1/2012	8/1/2012	SE ENTRANCE STAIRWELL B RUBBER STRIP FALLING OFF MIDDLE DOOR
FO-224485	8/1/2012	8/1/2012	Office is extremely hot; no air circulating
FO-224524	8/2/2012	8/2/2012	Room is too cold -- 66 degrees.
FO-224525	8/2/2012	8/2/2012	Lab is too cold -- 64 degrees
FO-224526	8/2/2012	8/2/2012	Lab is too cold -- 64 degrees
FO-224527	8/2/2012	8/2/2012	Lab too cold -- 70 degrees
FO-224788	8/3/2012	8/6/2012	RM#3320 TOO HOT
FO-224802	8/3/2012	8/3/2012	3RD FL BREAK RM WATER OFF ON SINK
FO-224813	8/3/2012	8/6/2012	NO AIR - CARRIAGE HOUSE.
FO-224867	8/6/2012	8/6/2012	TOO COLD. ROOM 4104.
FO-225109	8/6/2012	8/6/2012	PLUGS NOT WORKING
FO-225115	8/6/2012	8/6/2012	NO AIR - 1ST AND 2ND FLOORS.
FO-225148	8/6/2012	8/6/2012	TOO COLD. ROOM 1300 - 24 HOUR STUDY AREA.
FO-225192	8/6/2012	8/6/2012	Please replace filter in the air duct. It hasn't been replaced in some time and the air quality is
FO-225194	8/6/2012	8/7/2012	Garage door needs oil. It squeak each time its opened and closed.
FO-225211	8/7/2012	8/7/2012	PANEL HAS FALLEN FROM VENT. ROOM 242.
FO-225216	8/7/2012		FAUCET CONTINUOUSLY LEAKING. ROOM 246.
FO-225256	8/7/2012	8/8/2012	Ceiling leak on the eastern side of the north wall.
FO-225221	8/7/2012	8/7/2012	NO AIR CIRCULATION. ROOM 150.6.
FO-225241	8/7/2012	8/29/2012	TRACK LIGHTS ARE OUT. GALLERY.
FO-225245	8/7/2012	8/7/2012	TOO HOT. BUILDING.
FO-225247	8/7/2012	8/7/2012	RM 4802 VENT ABOVE DESK BLOWING OUT HOT AIR
FO-225276	8/8/2012	8/15/2012	4TH FLR NEAR & @ PROVOST OFC SIDE
FO-225280	8/8/2012	8/8/2012	My office is 85+ degrees you keep closing the work orders without fixing the temp.
FO-225311	8/8/2012	8/15/2012	Please send someone to adjust the temperature in this office suite. The staff in this location s
FO-225303	8/8/2012	8/8/2012	TOILET IN LADIES RR NOT FLUSHING RM 2234
FO-225388	8/8/2012	8/9/2012	transition strip under wood double door dislodged
FO-225346	8/9/2012		Radiator leaking in staff office 1220 located on the 1st floor suite 1200 UGL building
FO-225360	8/9/2012	8/16/2012	NO AIR. ROOM 4145.
FO-225369	8/9/2012		3RD FL STAIRWELL LEAK FROM ROOF
FO-225398	8/9/2012		RM# 9 IN BSMNT WATER COMING IN UNDER PIPING NEAR FIBER OPTIC BOX
FO-225484	8/10/2012		Blinds not working in two windows - office of AVP
FO-225466	8/10/2012	8/15/2012	It's leaking through the ceiling in my office suite - again.
FO-225488	8/10/2012	8/10/2012	MENS RR RM 326 DOOR LOCKED KEY JUST SPINS. PLEASE UNLOCK AND CHECK LOC
FO-225489	8/10/2012		CEILING LEAK WITHIN RM 4032
FO-225491	8/10/2012		CEILING LEAK WITHIN RM 4050
FO-225503	8/10/2012	8/10/2012	EXHAUST FAN BLOWERS ARE NOT ON. BASEMENT.
FO-225608	8/10/2012	8/10/2012	A smoke detector head has fallen off and is hanging by it's wires. Detector head needs to be r
FO-225524	8/13/2012	8/14/2012	Investigate water overflow problem on RTU # 1 and resolve. Water is draining through the roo
FO-225525	8/13/2012	8/22/2012	Identify up to ten locations for Honeywell remote temperature sensors. Will feed back informa
FO-225533	8/13/2012	8/13/2012	RM 317 IS TOO COLD
FO-225553	8/13/2012	8/13/2012	RM 0500/BSMT STORAGE IS HOT NO AIR CIRCULATION
FO-225559	8/13/2012		RM 154.2/CO-ED TRAINING RM ACU STOPPED WRKNG

Total

FO-225613	8/13/2012	8/13/2012	RM 100 TOO COLD
FO-225632	8/13/2012		CEILING OUTLET IS NOT WORKING. 2ND FLOOR COMPUTER LAB.
FO-225635	8/13/2012	8/13/2012	TOO COLD. 1ST FLOOR.
FO-225639	8/13/2012	8/13/2012	RM 317 IS NOW TOO HOT
FO-225649	8/13/2012	8/13/2012	RM 225 CLNG IS LKNG
FO-225742	8/14/2012	8/14/2012	PAINT IS BLISTERING. HALLWAY OUTSIDE OF ROOM 441. PLEASE CHECK FOR POSS
FO-225745	8/14/2012	8/14/2012	RM 4266 CEILING LEAK, PLEASE SEE PATRICE WITH LEAK UPDATES FOR BLDG
FO-225752	8/14/2012	8/16/2012	RM 13001.2 IS TOO COLD
FO-225753	8/14/2012	8/16/2012	RM 13001.3 IS TOO COLD
FO-225765	8/14/2012		Replace bearings and seals with our parts.Train employees on same.Not to exceed \$6,000.00
FO-225818	8/15/2012	8/29/2012	NE CARRIAGE DOOR # 510 029 KEY KEEPS GETTING STUCK IN DOOR
FO-225827	8/15/2012		BSMNT RM 015 LEAKING PIPE IN CEILING VERY CLOSE TO ART
FO-225837	8/15/2012	8/15/2012	RM 1163 2 DEAD OUTLETS UNDERNEATH WHITEBOARD NEAR SIGN SAYING DO NOT
FO-225917	8/16/2012	8/16/2012	TOO HOT IN RM's 3315, 3317 , & HALLWAY AREA WOULD LIKE AIR TURNED UP
FO-225937	8/16/2012	8/21/2012	TOO HOT IN LOBBY AND INSIDE THEATRE AN ASSEMBLY IS TAKING PLACE TODAY.
FO-225995	8/17/2012	8/17/2012	RM 12100.3 TOO HOT
FO-226014	8/17/2012		SMELLS LIKE RAW SEWAGE THROUGHOUT BLDG
FO-226015	8/17/2012	8/21/2012	FOUL ODOR. BUILDING INCLUDING ROOM 1301.
FO-226113	8/20/2012		RM# 234 TWO OUTLETS IN FRONT OF RM NOT WORKING
FO-226248	8/20/2012	8/20/2012	RM 317 IS TOO HOT
FO-226259	8/20/2012	8/20/2012	NO AIR TOO HOT
FO-226261	8/20/2012		PLEASE CHECK OUTLET WITHIN 4705 ALSO HIGH PITCH NOISE
FO-226263	8/20/2012	8/20/2012	CLASS RM 2103 IS TOO COLD
FO-226262	8/20/2012	8/20/2012	A/C NOT WORKING. ROOM 2235.
FO-226298	8/21/2012		FAUCET CONTINUOUSLY RUNNING. LADIES RESTROOM. ROOM 120.
FO-226349	8/21/2012		RM 106 MENS BATHROOM TOILET BASE LEAKING...SINK IS ALSO DRIPPING
FO-226395	8/21/2012	8/21/2012	NO AIR FLOW IN 2 ROOMS. ROOM 14110.
FO-226458	8/22/2012		The toilet in the women's bathroom delivers a very insufficient delivery of water when flushed.
FO-226460	8/22/2012		BLDG NEEDS AIR TURNED ON
FO-226472	8/22/2012		RM 102 IS TOO COLD
FO-226482	8/22/2012		TOO HOT. ROOM 326.
FO-226546	8/23/2012	8/23/2012	RM 13001.4 OUTLET NOT WORKING, RM TOO COLD
FO-226547	8/23/2012		SUITE 249 TOO HOT, PLEASE TURN ON AIR
FO-226552	8/23/2012	8/23/2012	RM 4130 CEILING LEAKING
FO-226562	8/23/2012	8/23/2012	WATER NOT WORKING IN BLDG
FO-226567	8/23/2012		1ST FLR IS TOO HOT
FO-226576	8/23/2012		Clock not working.
FO-226577	8/23/2012		BLOWER NOT WORKING
FO-226626	8/24/2012		TOO HOT. ROOM 4092.
FO-226658	8/24/2012	8/24/2012	13201.5 TOO COLD
FO-226666	8/24/2012	8/24/2012	CHECK AIR PRESSURE NEAR 3500 DOORS RATTLING DUE TO AIR PRESSURE FROM
FO-226669	8/24/2012		We have a leaking air conditioning unit. Its leaking water. Please send engineers.
FO-226678	8/24/2012	8/24/2012	E.CARRIAGE HOUSE NO AIR
FO-226681	8/24/2012		LEAK WITHIN DELILA'S CAFE SEEPING INTO RM 1505
FO-226850	8/27/2012	8/27/2012	RM# 345 LEAK
FO-226851	8/27/2012	8/27/2012	RM 4085 IS TOO HOT
FO-226876	8/27/2012		There is leaking rain water coming in on the EAST WALL of the Hilberry Theatre from the roof.

Total

FO-226879	8/27/2012		Office is to hot currently it is 98 degrees F in my office
FO-226871	8/27/2012		TOO HOT. ROOM 4200.
FO-226883	8/27/2012	8/28/2012	RM 225 & 256 TOO HOT
FO-226899	8/27/2012	8/28/2012	There is no option for "entire building" anymore. Multiple rooms have no air conditioning on th
FO-226915	8/27/2012		MEZZANINE IS TOO
FO-226918	8/27/2012	8/27/2012	ENTIRE CARRIAGE HOUSE IS TOO HOT HVAC STOPPED WORKING
FO-226919	8/27/2012	8/27/2012	RM 3198 NEED BREAKER RESET
FO-226978	8/28/2012	8/28/2012	RM 1211 UNABLE TO OPEN WINDOW
FO-226981	8/28/2012	8/28/2012	ELEVATOR BELL RINGING.
FO-226982	8/28/2012	8/28/2012	TOO HOT. ROOMS 14001.4 AND 14001.3 INSIDE SUITE 14001.
FO-226984	8/28/2012	8/30/2012	RM#163.6 WINDOW AIR CONDITIONER NOT WORKING. ENG CAME OUT BEGINNING O
FO-227017	8/28/2012		RM 1163/CLASS RM RESET BREAKER FOR OUTLET UNDERNEATH WHITEBOARD NEA
FO-227068	8/29/2012	8/29/2012	A/C NOT WORKING. ROOM 243.
FO-227070	8/29/2012	8/29/2012	TOO HOT. ROOM 8100.3.
FO-227087	8/29/2012		RM 441 SCREW MISSING ON DOOR NEAR LATCH THEY HAVE SCREW JUST NEEDS T
FO-227430	8/30/2012		Rom extremely hot -- no ventilation
FO-227431	8/30/2012		Classroom/auditorium extremely hot. Please fix temp
FO-227148	8/30/2012		Reset clock to correct time in class rooms 211 and 214 professor request State Hall
FO-227155	8/30/2012		FAN NOT WORKING TOO HOT (hvac)
FO-227444	8/30/2012	8/30/2012	TOO HOT. ROOM 4092 - PROVOST OFFICE.
FO-227478	8/31/2012		STE 4200 IS STILL TOO COLD
FO-227494	8/31/2012		TOO HOT. ROOM 128.
FO-227539	8/31/2012		Water faucet leaking in restroom 3234 - UGL 3rd floor
FO-227542	8/31/2012		Toilet stopped up 1st floor state hall mens room 109 and ladies room 110

E - Area 3 Auxiliary Eng

109

H-31770	8/1/2012		8/5/2012	Toilet tank leaks. Unit is vacant with a move-in date of 8/15/12.
H-31792	8/1/2012		8/2/2012	This is a second request in continuation of one i put on 7/25 .Kitchen sink dispenser not worki
H-31802	8/1/2012		8/2/2012	Electrical outlet on the right of the stove is broken
H-31782	8/1/2012	8/1/2012	8/16/2012	the AC in the study lounge on the 4th floor is not working.
H-31783	8/1/2012	8/1/2012	8/16/2012	the AC in the study lounge on the 4th floor is not working.
FO-224493	8/2/2012	8/3/2012		302-8 TOO HOT PLEASE SEE SUMMER AT FRONT DESK FIRST
H-32371	8/2/2012			sink is cloggedauthenticated user: Ryan Mitchell - ec3980requester ip address: 141.217.23
H-31812	8/2/2012		8/7/2012	the light switch is broken in the C bedroom
H-31825	8/2/2012		8/7/2012	Kitchen outlett off
H-31826	8/2/2012		8/7/2012	Smoke dector continues to go off.
H-31852	8/2/2012		8/7/2012	The electrical outlet is broken in the frist bedroom.
H-31853	8/3/2012		8/7/2012	Electrical outlet in the kitchen to the left of the stove is broken.
H-31866	8/5/2012			Clean ventilators in the living room. Check for bugs coming from AC
H-31868	8/5/2012		8/7/2012	Air conditioner is not working, its not cooling at all and its really hot in the apartment. Please fi
H-31869	8/6/2012		8/6/2012	change the air filter.
H-31872	8/6/2012		8/6/2012	Toilet in first bathroom on the left keeps flushing. Will not stop.
H-31905	8/6/2012		8/7/2012	The lights in this apartment do not work in any of the rooms.The fan in the bathroom does not
H-31878	8/6/2012		8/6/2012	Investigate water leak from 410.
H-31907	8/6/2012		8/7/2012	Repair broken smoke detector
FO-225217	8/7/2012			Room 251 (workroom) in the clinic, T-Stat reads 49, room hot, stat never changes.
H-31924	8/7/2012			leak coming from piping underneath sink in 330 Ghafari
H-31956	8/7/2012		8/7/2012	There is a weird sound that comes out of the AC unit sometimes when the air is turned off. Ca

Total

H-31957	8/7/2012	8/7/2012	Electrical outlet plate is cracked in the living room near the windows.
H-31960	8/7/2012	8/24/2012	Eng. Maint Chk - Vacant Unit
H-31961	8/7/2012	8/24/2012	Eng. Maint Chk - Vacant Unit
H-31962	8/7/2012	8/10/2012	Eng. Maint Chk - Vacant Unit
H-31963	8/7/2012	8/7/2012	Eng. Maint Chk - Vacant Unit
H-31964	8/7/2012	8/15/2012	Eng. Maint Chk - Vacant Unit
H-31965	8/7/2012	8/15/2012	Eng. Maint Chk - Vacant Unit
H-31966	8/7/2012	8/8/2012	Eng. Maint Chk - Vacant Unit
H-31967	8/7/2012	8/13/2012	Eng. Maint Chk - Vacant Unit
H-31968	8/7/2012	8/13/2012	Eng. Maint Chk - Vacant Unit
H-31969	8/7/2012	8/9/2012	Eng. Maint Chk - Vacant Unit
H-31970	8/7/2012	8/9/2012	Eng. Maint Chk - Vacant Unit
H-31972	8/7/2012	8/8/2012	Eng. Maint Chk - Vacant Unit
H-31973	8/7/2012	8/8/2012	Eng. Maint Chk - Vacant Unit
H-31975	8/7/2012	8/7/2012	Garbage disposal is broken.
H-31985	8/8/2012	8/8/2012	Our garbage disposal isn't working properly. Water is pooling in the right side of the sink.
H-31992	8/8/2012	8/8/2012	AC not working
H-31993	8/8/2012		Engineering: 419, light switch has loose connection at entry.
H-31994	8/8/2012	8/9/2012	Mechanical check-move in 8/13/12
H-31997	8/8/2012	8/9/2012	224. Replace plug behind the refrigerator.
H-31998	8/8/2012	8/9/2012	601, replace plug in kit.
H-32020	8/9/2012		The light fixture in the third bedroom is broken.
H-32040	8/9/2012	8/22/2012	The showerhead in bathroom #2 is leaking.
FO-225438	8/10/2012	8/16/2012	fuses blown. request ability to get fans from stockroom.
H-32044	8/10/2012	8/13/2012	UT-1101, replace duplex elec. Outlet in LR
H-32045	8/10/2012	8/10/2012	Repair: UT-502 broken light fixture in bedroom.
H-32315	8/11/2012		the faucet is leaking in the kitchen
H-32316	8/11/2012		Faucet in kitchen is leaking
H-32320	8/12/2012		The thermostat in the 3rd bedroom is not working.
H-32322	8/12/2012		To whom it may concern.
H-32327	8/13/2012		Electrical outlet near stove needs to be replaced.
H-32083	8/13/2012	8/14/2012	Toilet makes loud noise when flushed.
H-32228	8/13/2012	8/20/2012	No hot water supply in the room.
H-32112	8/14/2012		Replace smoke detector.
H-32113	8/14/2012		Replace smoke detector.
H-32114	8/14/2012		Replace smoke detector.
H-32240	8/14/2012	8/24/2012	Garbage disposal needs to be fixed.
H-32132	8/14/2012		Replace smoke detector.
H-32164	8/15/2012		Please fix the light fixture in the freight elevator. The cover is not on.
FO-225801	8/15/2012	8/16/2012	2ND FL ON BASKETBALL COURT BLOWN CIRCUIT
FO-225805	8/15/2012	8/16/2012	2ND FL ON BASKETBALL COURT BLOWN CIRCUIT
H-32175	8/15/2012		A/C not working
H-32185	8/16/2012		Light in 7th floor laundry only flickers when switch is turned on. Lights never fully come on.
H-32193	8/16/2012		Kitchen sink leaks when turned on.
H-32216	8/17/2012	8/20/2012	the tap in the kitchen keeps leaking
H-32238	8/17/2012	8/24/2012	Tub/shower combination has leaky faucet and it is also loose.
H-32246	8/17/2012		Toilet is running.

Total

H-32329	8/17/2012		I am missing a slat in the living room blinds.
H-32331	8/21/2012		The garbage disposal is broken.
H-32332	8/21/2012		The toilet is continuously running out. Needs to be repaired.
H-32333	8/21/2012	8/28/2012	The garbage disposal is broken. Needs to be repaired.
H-32335	8/21/2012		fan in bathroom is broken
H-32336	8/21/2012		Faucet is broken
H-32365	8/21/2012		replace the ballast in the 4-T-8 fixture in the Green and Gold Ghafari kit. See blue tape.
H-32843	8/22/2012	8/31/2012	Air is not working. The red light is on and air is blowing from the fan but the ac is not functionin
H-32699	8/22/2012	8/29/2012	shower has inconsistent water pressure, squirts out in all directions
H-32655	8/22/2012	8/28/2012	Flush overflowed and not working(happened today).Exhaust fan not working properly(since m
H-32467	8/24/2012		Under the sink, needs to be replaced.
H-32568	8/26/2012	8/28/2012	Air conditioning does not work. Giving off air but not dropping our temperature. Thermostat is
H-32698	8/26/2012	8/29/2012	The shower head its badly spraying in all directions. Ex: Up towards the ceiling out of the sho
H-32587	8/27/2012	8/29/2012	The thermostat is on the coldest setting but it is not blowing out very much cold air to any of th
H-32565	8/27/2012	8/27/2012	Air conditioner is not working. And it has become very hot. The thermometer is located in the
H-32567	8/27/2012	8/27/2012	Two weeks ago I got my air filter changed and it still didn't work, three days ago I put in a work
H-32564	8/27/2012	8/27/2012	Maintenance for the air condition
H-32563	8/27/2012	8/27/2012	My air conditioning was working well when I moved in, but now it is set at sixty degrees and is
H-32555	8/27/2012		replace intake grill on air conditioner.(per G. Tilson)
H-32561	8/27/2012	8/28/2012	Air conditioning does not work. It's set at 70, but it's 78-79 in the room. The red light on the bot
H-32697	8/28/2012	8/29/2012	Our air conditioner is broken it doesn't come on it doesn't work at all.
H-32694	8/28/2012	8/30/2012	Please check the shower head. Residents reported that it is not working properly.
H-32726	8/28/2012	8/9/2012	thermostat is reading 85 degrees and will not adjust. One roommate has asthma and is having
H-32810	8/29/2012		Lightbulb in bathroom with shower needs to be replaced and A/C does not work.
H-32809	8/29/2012	8/31/2012	(1) the basin is fully blocked.
H-32806	8/29/2012		Kitchen sink G/D drainage system.
H-32797	8/29/2012	8/30/2012	air-conditioning requires immediate repaires
H-32852	8/29/2012		Toilet constantly runs and water rises high
H-32794	8/30/2012	8/30/2012	My shower is weird. The water doesnt come out like a regular shower. My RA has seen it and
H-32803	8/30/2012	8/31/2012	Bathroom #2 - Toilet continually Runs after flushed. This is the second work order submitted f
H-32793	8/30/2012		Faucet in the kitchen sink is coming undone (not screwed on properly). Needs replacement.
H-32821	8/30/2012		light switch in bedroom 1 (nearest to the leaving room) is not working properly; it needs to be p
H-32823	8/30/2012		in the shower of the bathroom 1 (small one) the metal plate around the water nob was all ruste
H-32834	8/30/2012		The air condionting in the apartment needs to be fixed. There is air coming out of the vents b
H-32837	8/30/2012		The toilet seat in the restroom/bathroom has been clogged up and the line needs to be fixed.
H-32853	8/31/2012		Our garbage disposal is not working and hasnt been working since we moved in. Thank you!
FO-227502	8/31/2012		TOO HOT. A/C NOT WORKING. SOUTH SIDE OF ROOM 300.
H-32849	8/31/2012		Air Conditioning is Brokeauthenticated user: Nathan Cobb - ee9837requester ip address: 1
H-32851	8/31/2012		Air Conditioning is broke authenticated user: Nathan Cobb - ee9837requester ip address: 1
H-32875	8/31/2012		2nd bathroom (further from the entrance), toilet handle is broken...won't flush. Water keeps ru
E - Controls Engineer		2	
FO-224567	8/3/2012	8/7/2012	Please repair AC1. The condenser fan blade on AC1 broke off and went through the coil causi
FO-225453	8/8/2012	8/21/2012	AC controls

Low

246

E - Afternoon Engineer

6

FO-224852	8/3/2012	8/3/2012	YOU CAN TURN ELEVS'2 & 3 BACK ON
FO-225674	8/13/2012	8/13/2012	Sink has low water pressure
FO-225957	8/16/2012	8/17/2012	Room 3158 The roof is partially exposed and it looks ugly. The ceiling needs

Total

FO-226527	8/22/2012	8/23/2012	Ceiling and duct need painting.
FO-226716	8/24/2012	8/25/2012	Rm 077/bsmt a faint smell of particulate combustion
FO-227033	8/28/2012	8/29/2012	OLD SECTION 3RD FL MENS RM TOILET OVER FLOWING
E - Area 1 Engineer		32	
FO-224420	8/1/2012	8/1/2012	NEED ACCESS TO MECH RM
FO-224421	8/1/2012	8/1/2012	NEED ACCESS TO MECH RM
FO-224544	8/2/2012		Requests HVAC duct filter cover for 2nd Floor Men's Lockerroom
FO-225119	8/6/2012	8/17/2012	Purchase closed loop sidestream filters from HV Burton
FO-225600	8/10/2012		BUILDING AND GROUNDS (HIGH PRIORITY)
FO-225529	8/13/2012		parts and OCC of Tank
FO-225612	8/13/2012		2ND FLR ONLY WOMENS RM SINKS 3 & 5 sinks ARE IN room CONSTANTLY drips.
FO-225621	8/13/2012		Room 9112 - fume hood is not working
FO-225700	8/13/2012		Women's locker room - The ceiling is leaking
FO-225702	8/14/2012		Engineering
FO-225720	8/14/2012	8/14/2012	SEIMENS SVC MAN NEED ACCESS TO 4TH FLR MECH RM
FO-225802	8/15/2012	8/17/2012	BUILDING AND GROUNDS (HIGH PRIORITY)
FO-225848	8/15/2012	8/15/2012	Vents in room is making a "loud/weird noise".
FO-225874	8/15/2012	8/16/2012	Vibrant Hum coming from the floor shaking
FO-225892	8/15/2012		Computer labs in 309, the A/C is
FO-225875	8/16/2012		RM 240 FH IS DISCONNECTED
FO-225893	8/16/2012		Computer labs in 324 the A/C is
FO-225896	8/16/2012		Computer labs in 325 the A/C is
FO-225941	8/16/2012	8/20/2012	Room 2601
FO-225966	8/16/2012	8/17/2012	Basement men restroom rm. 114: 1st stall (No pull down handle present for the means of flus
FO-226018	8/17/2012		Bearings DJ Conley
FO-226019	8/17/2012		Blowdown timer Grainger
FO-226022	8/17/2012	8/17/2012	Vibrant Hum coming from the floor shaking
FO-226371	8/21/2012		Barrel pumps for chemical adds
FO-226453	8/22/2012	8/24/2012	DLAR. Animal Quaters. HVAC was here last week to repair the duct/fan in room 469. Are the
FO-226540	8/23/2012	8/23/2012	NEED ACCESS TO MECH RM INSPECTION OF CHILLERS
FO-226560	8/23/2012		One of the loading dock leveler ramps is stuck
FO-226592	8/23/2012	8/23/2012	Issue with restroom urinal. Was previously overflowing, someone came out and cleaned that
FO-226596	8/23/2012		There is a constant, loud vibration in the ceiling
FO-226773	8/27/2012		RM 102/ATRIUM THEY NEED THE FIRE DOOR LIFTED FOR AN EVENT TODAY @11:30A
FO-226900	8/27/2012		CELING LEAK IN RM 130 LEAKING ONTO FUME HOOD #1
FO-227149	8/30/2012		RM 453, 464, 465, 466, & 467 NEED TO CHNG FILTER
E - Area 2 Engineer		29	
FO-224773	8/1/2012	8/1/2012	Drinking fountain outside of 300 Prentis--no water coming out--please fix asap.
FO-224799	8/3/2012		RM 154.20 CLEANING OF CEILING VENTS THROUGHOUT OFFICE COMPLEX ... Please
FO-225290	8/8/2012	8/8/2012	MAIN FLR at least 2 broken t-stats on main floor.
FO-225291	8/8/2012	8/8/2012	1ST FLR broken return air grill/diffusser, at entrance to store room from sales floor.
FO-225297	8/8/2012	8/8/2012	BLDG IS TOO HOT
FO-225383	8/9/2012	8/9/2012	WOMEN'S RESTROOM 176 - SHOWERS ARE LEAKING AND SOME SHOWER HANDLES
FO-225470	8/10/2012		Engineer:
FO-225647	8/13/2012	8/14/2012	Re-direct air vent in Research Compliance Office - Rm 6306.1
FO-225718	8/14/2012	8/14/2012	NEED ASSIST. W/NETWORK OP ALL THERE DEVICES NO POWER
FO-225754	8/14/2012	8/17/2012	PLEASE TURN ON ACU FOR BLDG THIS THURSDAY 08/16/12
FO-225808	8/15/2012		Alley Door. It is extremely hard to turn keys in this door lock.Referred to Locksmith 08/15/12 Le

Total

FO-227046	8/15/2012	8/27/2012	project_description: The rubber flooring in the 1st floor West and South coordior's is badly in n
FO-225841	8/15/2012		Leak in ceiling. Cooking pot on the table
FO-225843	8/15/2012		Leak from roof into 4th floor alcove to stack
FO-225838	8/15/2012		MAIN ENTRANCE INSIDE VESTIBULE DOOR IS STICKING
FO-225909	8/16/2012	8/17/2012	Cholrine Delivery
FO-225948	8/16/2012	8/16/2012	13TH FLR ELEV LOBBY AREA MENS RM ONLY TOILET CON'T FLUSHING
FO-226029	8/17/2012		4th Floor, emergency ceiling light is making a continuous beep.
FO-226309	8/20/2012		Please close air vent over April Wolak's desk. The area is continually too cold, so she has req
FO-226396	8/21/2012	8/21/2012	DENNIS HTG/CLNG LOCKED HIS KEYS IN RM
FO-226410	8/21/2012		Cooling tower/condenser water system repair request.
FO-226467	8/22/2012		Medium
FO-226462	8/22/2012		Heating system did not work all last winter in the entire building.
FO-226459	8/22/2012	8/23/2012	JOHNSON CONTROLS NEEDS ACCESS TO MECH RM
FO-226543	8/23/2012	8/23/2012	RM 352 CLNG TILES HAVE BEEN PULLED ALSO LOOKS LIKE WATER DAMAGED CLNG
FO-227059	8/29/2012		RM 217 ACU IS DIRTY NEEDS CLEANING
FO-227146	8/30/2012		BLISTERING PAINT. STAIRWELLS BETWEEN 1ST AND 2ND, 2ND AND 3RD AND 3RD A
FO-227484	8/30/2012		Purdy Entrance Interior Handicap Door
FO-227500	8/31/2012		06/12/2012 10:59 LOWE - PRE HEAT CONTROL VALVE FOR MUAH #1 NOT MODULATIN

E - Area 3 Auxiliary Eng

140

H-31829	8/1/2012		The garbage disposal is not working
H-31831	8/2/2012	8/7/2012	Toilet is continuously running
H-31834	8/3/2012	8/17/2012	Air conditioning is not working.
H-31917	8/3/2012		Kitchen sink handle is missing.
H-31880	8/3/2012	8/8/2012	The place where the hand shower is connected to is leaking.
H-31871	8/6/2012	8/7/2012	Eng. Replace the duplex elect. receptacle near the range in 808.
H-31885	8/6/2012		Mechanical Check
H-31886	8/6/2012	8/10/2012	Mechanical Check
H-31887	8/6/2012	8/11/2012	Mechanical Check
H-31888	8/6/2012	8/11/2012	Mechanical Check
H-31889	8/6/2012	8/12/2012	Mechanical Check
H-31890	8/6/2012		Mechanical Check
H-31891	8/6/2012	8/9/2012	Mechanical Check
H-31920	8/6/2012		Mechanical Check.
H-31923	8/6/2012		Mechanical Check.
H-31927	8/6/2012		Mechanical Check.
H-31932	8/6/2012		Mechanical Check.
H-31934	8/6/2012		Mechanical Check.
H-31937	8/6/2012		Mechanical Check.
H-31940	8/6/2012		Mechanical Check.
H-31943	8/6/2012		Mechanical Check.
H-31950	8/7/2012	8/7/2012	Remove the nozzle from kitchen faucet, it splashed water too much.
H-31951	8/7/2012	8/7/2012	toilet is leaking continuously and water has come to the outside floor. Needs to be check As s
H-31971	8/7/2012	8/7/2012	Eng. Maint Chk - Vacant Unit
H-31974	8/7/2012	8/8/2012	Eng. Maint Chk - Vacant Unit
H-31977	8/7/2012	8/8/2012	Mechanical Check
H-31980	8/7/2012	8/7/2012	Garbage Disposal is not working
H-31989	8/7/2012		Mechanical check

Total

H-31983	8/7/2012	8/8/2012	Check A/C unit in rooms 263 and 161. Both rooms are part of the clinic.
H-31984	8/7/2012	8/7/2012	Leak in bathroom area
H-31999	8/8/2012	8/9/2012	the knob that turns on water in tub is disassembled.
H-32004	8/8/2012		Kitchen sink faucet is leaking water when she turns it on for cold water.
H-32006	8/8/2012		repair shower faucet
H-32008	8/9/2012		The internet outlet in the wall behind the front desk by the package board is loose and needs t
H-32036	8/10/2012		Mechanical Check.
H-32067	8/11/2012	8/14/2012	need Shut off valve handle for the bathroom hot water, the sink.
H-32068	8/11/2012	8/14/2012	The garbage disposal does not turn on. The sink is not longer draining.
H-32075	8/12/2012		The socket that connects to fridge is seems to be not working. Fridge is not turning ON. (Chat
H-32071	8/12/2012	8/14/2012	The toilet in the bath room is not flushing properly.
H-32124	8/13/2012	8/14/2012	The garbage disposal is not working in the kitchen. It does not make any noise when the switc
H-32125	8/13/2012	8/14/2012	The thermostat does not work on any setting or temperature. Needs to be fixed.
H-32224	8/13/2012	8/24/2012	In the 2nd restroom of our apartment, I did not check it when I moved in. But when I was takin
H-32108	8/13/2012	8/15/2012	Air conditioning is not working.
H-32230	8/13/2012	8/14/2012	The toilette in the first bathroom leaks when flushed. Please come fix it. Thank you.
FO-225699	8/14/2012	8/14/2012	WINDOW WASHERS NEED ACCESS TO ROOF
H-32128	8/14/2012		Thermostat in room is set on coldest temperature possible, but the temperature of the air con
H-32169	8/14/2012		Kitchen sink faucet needs to be replaced and sink needs to be resurfaced.
FO-225885	8/16/2012	8/17/2012	WINDOW CLEANERS NEED ACCESS TO ROOF
H-32188	8/16/2012		Various lights are out in the Clinic. please see Faraz and repair as needed. list all time and ma
H-32189	8/16/2012	8/17/2012	A/C is not working.
H-32831	8/17/2012	8/31/2012	Air conditioning unit is not working, need to be repaired.
H-32252	8/17/2012		Bathtub faucet is leaking.
H-32279	8/17/2012		All outlets to be changed to grounded outlets. SEND TO ELECTRICIAN.
H-32257	8/17/2012		Standing water in sink in bathroom.authenticated user: Samantha Arzola - ee8936requeste
H-32259	8/18/2012		Water damage on the shower ceiling. authenticated user: Jeremy Wells - eh6417requester
H-32264	8/18/2012		Toilet leaks when flushed. authenticated user: Justin Yemm - ef4839requester ip address:
H-32255	8/19/2012		The light outlet near the entrance in kitchen is broken, needs to be change.
H-32266	8/19/2012		Water leaking from the toilet comode and flooding the floor
H-32275	8/20/2012		The commode(Toilet) in the bathroom is over flowing and won't flush.
H-32378	8/20/2012	8/24/2012	The electrical outlet in room 313 is not working.
H-32276	8/20/2012		This is Ryan Mathew in De Roy apt 1208. The kitchen sink drain electric drainage mechanism
H-32376	8/21/2012		The thermostat is broken in lounges 400 and 324. it will not read the internal temperature of th
H-32304	8/21/2012		The light in the dining room flickers and only sometimes turns on. This may be an electrical pr
H-32649	8/22/2012	8/28/2012	The toilet closest to the door is not working! It started shooting out water so I closed the water
H-32743	8/22/2012	8/29/2012	Both fans in both bathrooms not working.
H-32397	8/23/2012		The thermostat internal temperature is broken as well as the shower headauthenticated user
H-32408	8/23/2012		Smoke detector head needs replacement.
H-32761	8/23/2012	8/30/2012	The bathroom toilet is not flushing and it continuously runs. It would be very much appreciated
H-32412	8/23/2012		There is a shortage in the Kitchen light.
H-32414	8/23/2012	8/24/2012	Garbage Disposal Work order.
H-32748	8/24/2012		The water pressure in my shower is low and the faucet does not always completely close and
H-32424	8/24/2012	8/24/2012	The shower fixture is loose and needs to be put back in place.
H-32422	8/24/2012	8/24/2012	Air conditioning is not working and air filter was just changed and red light is still on, and air is
H-32468	8/24/2012		The cable cord in the living room has a broken end. The resident was told that both the cable
H-32479	8/24/2012		Garbage disposal does not work.

Total

H-32702	8/24/2012	8/28/2012	Air Conditioner in entire suite does not work i would like for it to be fixed.
H-32490	8/25/2012		Light cover missing by room 1205
H-32750	8/25/2012		Fan knob in bathroom #1 is missing.
H-32493	8/25/2012		Smoke detector missing cover on 8th floor by stair A
H-32511	8/25/2012		Buttons on thermostat broken. Both AC and HEAT not working
H-32716	8/25/2012	8/29/2012	Electrical plug outlet in main living space needs to be replaced.
H-32723	8/26/2012		bathroom 1 fan does not work
H-32590	8/26/2012	8/28/2012	Shower head doesn't work
H-32516	8/26/2012		AC and Heat not working
H-32517	8/26/2012		Dust keeps coming out of vents
H-32675	8/26/2012		The toilet in the first bathroom is constantly running.
H-32674	8/26/2012	8/30/2012	There is a leaky pipe under the kitchen sink. The resident put a bucket under the leak to temp
H-32541	8/27/2012		Outlet (Electric plug base) on North wall of bedroom does not work (Front desk)
H-32550	8/27/2012		Thermostat is completely dead. No Air Conditioning or Heat will come on. Please fix as soon a
H-32543	8/27/2012		The living room electrical outlet on the right wall does not work, the one that the television is c
H-32710	8/27/2012		The A/C unit in my room is not working. The thermostat is set to 60 and the A/C unit is blowin
FO-226735	8/27/2012	8/28/2012	PLUMBING CO PLUMBERS ARE @ FRONT DESK TO BE ESCORTED TO APTS'
H-32544	8/27/2012		Right side of toilet is leaking a blue substance
H-32574	8/27/2012		There is a continuous leakage in the living room. Resident request that someone urgently com
H-32575	8/27/2012		Toilet tank leaking when flushed.
H-32616	8/27/2012		Living room light switch is broken.
H-32576	8/27/2012		Dining Room phone jack broken off wall.
H-32672	8/27/2012		no kitchen sink strainer
H-32673	8/27/2012		leaky faucet in bathroom
H-32551	8/27/2012		bathroom sink faucet leaks from the sidesauthenticated user: Ryan Mitchell - ec3980reque
H-32577	8/27/2012		Shower doesn't get cold.
H-32749	8/27/2012		first bathroom shower is slow.
H-32713	8/27/2012		The air conditioner is not working in this room.authenticated user: Sara Gray - el6004reque
H-32669	8/27/2012		The electrical socket of the kitchen is not working.When we insert the plug of microwave in the
H-32579	8/27/2012		living room windows are leaking water, the carpet beneath the windows is pretty saturated. Ple
H-32582	8/27/2012		Inspect light fixtures in bathroom, one of the sides does not work.
H-32632	8/27/2012		The bathtub faucet is dripping, and there is no drain stopper.
H-32633	8/27/2012		The light in the kitchen is flickering
H-32583	8/27/2012	8/28/2012	Our toilet is leaking water.
H-32606	8/27/2012		The electrical outlet on the right side of the bedroom, closest to the door, came off the wall. N
H-32591	8/27/2012	8/28/2012	Some outlets not working in the D bedroom.
H-32634	8/27/2012		Kitchen sink hot water will not turn off, so the apartment is missing cold water.
H-32622	8/28/2012	8/28/2012	The air is not working. Resident switched the unit to auto on both fan and system and raised t
H-32611	8/28/2012		ceiling is leaking near window in bedroom
H-32612	8/28/2012		toilet not flushing properly
H-32613	8/28/2012		There is a minor leak in the ceiling next to the thermostat.
H-32658	8/28/2012	8/28/2012	The garbage disposal is not working.
H-32695	8/28/2012	8/29/2012	Only a little bit of water is coming out of the shower head and there is no water pressure.
H-32688	8/28/2012		The toilet in the bathroom at the deep end of the hall way is broken and will not flush.
H-32677	8/28/2012		replaced bulb in kitchen. need light fixture in bathroom. refer to engineer
H-32678	8/28/2012		replaced bulbs. bad ballast. refer to engineer
H-32680	8/28/2012		replaced bulbs. bad ballast. refer to engineer

Total

H-32682	8/28/2012			replaced bulbs. bad ballast. refer to engineer
H-32676	8/28/2012			Toilet leaks when flushed
H-32706	8/28/2012			air conditioning not cooling apartment at all
H-32704	8/29/2012		8/29/2012	The kitchen sink is not draining the water, even when I use the disposer.
H-32727	8/29/2012	8/30/2012		The shower head shoots water through the sides instead of straight out.
H-32780	8/29/2012			Shower water is coming out different color green and yellowish discharge when turned on.
H-32754	8/29/2012			water not draining properly in kitchen
H-32765	8/29/2012	8/30/2012		Air conditioner broke haven't had air conditioner since we moved in it is very HOTTT
H-32744	8/29/2012			Replace ballast in front lobby by vending machines.
H-32764	8/29/2012	8/30/2012		Air conditoner is not turning on at all.
H-32746	8/29/2012			AC in the 3rd room is not working
H-32745	8/29/2012			Garbage Disposal
H-32830	8/30/2012	8/31/2012		The thermostat is not working in the Study/Quiet Lounge on the 5th floor. Thanks in advance
H-32832	8/30/2012			When you walk into the suite, the room on right has an unfinished power outlet. It is on the rig
H-32858	8/30/2012			In the kitchen the water is leaking under the sink in the cabinet.
H-32868	8/31/2012			The cold water is running very slow.
H-32863	8/31/2012			Shower head problems
H-32879	8/31/2012			Air conditioning stopped workingauthenticated user: Nathan Cobb - ee9837requester ip ad

E - Controls Engineer

39

FO-224396	8/1/2012			Refrig. Crew
FO-224475	8/2/2012	8/2/2012	8/2/2012	Repair or remove thermostat from wall in room 182. Follow up from original work order to after
FO-224529	8/2/2012			Refrig shop,
FO-224561	8/2/2012	8/21/2012		A/C shop
FO-225207	8/3/2012	8/23/2012		R/R BOILER RM OUTSIDE W. SIDE softener inside of boiler room needs repair on the secon
FO-225208	8/3/2012	8/31/2012		Refrigeration Crew; High
FO-225209	8/3/2012	8/15/2012		Refrigeration Crew; High
FO-225210	8/3/2012	8/6/2012		Refer Shop:
FO-225222	8/6/2012			Refrigeration section
FO-225223	8/6/2012	8/15/2012		A/C shop
FO-225254	8/7/2012	8/9/2012		Refrigeration Crew; High
FO-225305	8/8/2012			AC Controls
FO-225554	8/9/2012			A/C shop repair vortex damper on return air fan #2 in ceiling above control air compressor. Co
FO-225607	8/10/2012	8/10/2012		refrigeration crew
FO-225676	8/13/2012			Controls,
FO-225845	8/15/2012			High Priority, Refrigeration Shop, R/R room 316 a/c window unit coils icing/freezing up. (it has
FO-225852	8/15/2012	8/16/2012		Refr.crew:
FO-225905	8/16/2012	8/22/2012		Refer Shop:
FO-225908	8/16/2012	8/21/2012		Refer Shop:
FO-225913	8/16/2012			REFER SHOP/HONEYWELL:
FO-226023	8/17/2012			Refrigeration Crew; High
FO-226268	8/20/2012	8/22/2012		Refg. Crew:
FO-226269	8/20/2012	8/27/2012		Refg Crew:
FO-226274	8/20/2012	8/22/2012		Refg. Crew:
FO-226463	8/22/2012	8/27/2012		Refrigeration Crew; Medium
FO-226704	8/24/2012			REFRIGERATION (HIGH PRIORITY)
FO-226912	8/27/2012			Refrigeration Crew; High
FO-227004	8/28/2012			Refr.crew:

Total

FO-227018	8/28/2012		Refrigeration Crew; High
FO-227025	8/28/2012		R/R ROOFTOP U Please make necessary repairs to AC #1 First stage compressor will not st
FO-227072	8/29/2012		HVAC Controls Med Priority
FO-227162	8/30/2012		A/C shop
FO-227505	8/31/2012		R/R W-SIDE Number one boiler has problem with pilot at start up. Keeps going out on flame f
FO-227506	8/31/2012		R/R W-SIDE BLR #2 OFF LINE DUE Number one boiler has problem with pilot at start up. Ke
FO-227551	8/31/2012		High Pri, Controls Crew,
FO-227548	8/31/2012		High pri, Pneumatic Controls Crew, R/R RM ATTIC C/MECH RM Pre heat control valve for M
FO-227560	8/31/2012		Refg. Crew:
FO-227563	8/31/2012		Controls Crew, Medium pri,
FO-227546	8/31/2012		please service pipe shop a/c...coils are freezing up and condensate is leaking from the front

Routine**8****E - Area 3 Auxiliary Eng****8**

H-32145	8/14/2012		Mechanical Check.
H-32142	8/14/2012	8/24/2012	Mechanical Check.
H-32343	8/21/2012		Mechanical check
H-32344	8/21/2012	8/24/2012	Mechanical Check
H-32347	8/21/2012		Mechanical Check
H-32350	8/21/2012		Mechanical Check
H-32766	8/30/2012		Maintenance Check
H-32769	8/30/2012		Mechanical check-move in 9/1/12

Grounds**9****High****1****G - Physical Grounds****1**

FO-225604	8/10/2012	8/15/2012	R/R BLDG Please repair hole in ground at back entrance from broken drain tile. This is a SAF
-----------	-----------	-----------	--

Low**8****G - Moving/Storage****6**

FO-225228	8/7/2012	8/13/2012	Many items in room 179 need to be discarded.
FO-226613	8/8/2012	8/30/2012	Remove furniture from 360 Art Bldg. to properties.
FO-226938	8/14/2012		contact: Muhammad Faisal
FO-225960	8/16/2012	8/17/2012	Pick-up copier and take to property office. "Just-Do-It", index 1-20301.
FO-227128	8/20/2012		desired_date: 08/22/2012
FO-226645	8/23/2012	8/29/2012	Room 235 needs to be cleared of all items. Use standing IRB I-466020. Contact Alan Sebast

G - Physical Grounds**2**

FO-226561	8/23/2012	8/24/2012	There is a lot of trash in the loading dock area
FO-226941	8/27/2012		University dumpster located in back of the Engineering Technology Bldg @ 4855 Fourth St. ha

Trades**1068****Emergency****57****T - Carpenter****16**

FO-224535	8/2/2012	8/2/2012	EMERGENCY R/R ENTRANCE HANDICAP DOOR #036 03E STUCK IN OPEN POSITION F
FO-224796	8/3/2012	8/3/2012	REPAIR DOOR LOCK. (PRODUCTION STUDIO DOOR) DOOR WON'T LOCK. WDET-FM Fi
FO-225113	8/6/2012	8/6/2012	KEY CORE IS SPINNING AND WILL NOT UNLOCK DOOR. ROOM 211.2. Finished 8/7/201
FO-225185	8/7/2012	8/7/2012	REPAIR DOOR LOCK. DOOR WILL NOT UNLOCK. ROOM 3168. Finished 8/8/2012
FO-225441	8/10/2012	8/10/2012	REPAIR DOCK DOOR #068-01-SO DOOR STUCK CLOSED. WILL NOT GO UP OR DOWN.
FO-225728	8/14/2012	8/14/2012	SECURITY DOOR AT LOADING DOCK ON BRADY NOT CLOSING Finished 8/16/2012 LT
FO-226016	8/17/2012	8/17/2012	KEY STUCK IN DOOR LOCK. 3RD FLOOR ROOF DOOR. Finished 8/20/2012 LT
FO-226264	8/20/2012	8/20/2012	DOOR WON'T LOCK. ROOM 1606. Finished 8/21/2012 LT

Total

FO-226373	8/21/2012	8/22/2012	Please move stall partetions in mens / womens basement bathrooms in EDC new wing area
FO-226457	8/22/2012	8/22/2012	EMERGENCY R/R ROOFTOP U FAN RM NEED ACCESS KEY WILL TURN HOWEVER WIL
FO-226538	8/23/2012	8/23/2012	Please remove ceiling from projection room 2025.1 inside room 2025 See Jim Hill for lo
FO-226859	8/25/2012	8/25/2012	Emergency request. O.T. approved.
FO-227015	8/28/2012	8/29/2012	KEY BROKEN OFF IN DOOR LOCK. CLASSROOM 317. Finished 8/31/2012 LT
FO-227039	8/28/2012	8/28/2012	We are unable to secure door 078-11E. Please repair.
FO-227142	8/30/2012	8/30/2012	Room 2507 - I was not able to open it from inside the room.
FO-227474	8/31/2012		REPAIR OR REPLACE DOOR HANDLE (OFF). STAIRWELL K - 2ND FLOOR.

T - Electrician**31**

FO-224426	8/1/2012	8/1/2012	MECH RM 11 CHECK THE VARIABLE SPEED DRIVE FOR AHU # 1 Finished 8/2/2012
FO-224460	8/1/2012	8/1/2012	Light fixture fell out of ceiling. Pat the carpenter needs help. He will contact you. Finished 8/2/
FO-224801	8/3/2012	8/3/2012	COOLING TOWER #3 WILL NOT START. PENTHOUSE.Finished 8/6/2012 LT
FO-224814	8/3/2012		RESET FIRE ALARM PANEL.
FO-224861	8/6/2012	8/6/2012	FIRE ALARM CONTROL IS ALARMING AND WILL NOT SILENCE. Finished 8/7/2012
FO-225118	8/6/2012	8/6/2012	NO POWER IN WALL OUTLETS. ROOMS 398 & 394. Finished 8/7/2012
FO-225130	8/6/2012	8/6/2012	BAD BREAKERS... PLUGS NOT WORKING Finished 8/7/2012
FO-225134	8/6/2012	8/6/2012	WALL OUTLET IS NOT WORKING. 1ST FLOOR BEHIND COPY MACHINE. ACROSS FRO
FO-225229	8/6/2012		Emergency electrical receptacle is wired incorrectly, please repair.
FO-225226	8/7/2012	8/7/2012	EMERGENCY R/R ROOF ACU #1 REPLACE FUSE BLOCK & WIRING ON L2 CALL TONY
FO-225230	8/7/2012	8/7/2012	Emergency R/R RM 3112.10 electrical receptacle is wired incorrectly, please repair.
FO-225313	8/8/2012	8/9/2012	AIR CONDITIONERS ARE NOT WORKING. CHECK CIRCUIT BREAKERS. ROOMS 2202, 2
FO-225380	8/9/2012	8/9/2012	A/C NOT WORKING. PLEASE CHECK CIRCUIT BREAKERS. ROOM 2208. Finished 8/10/2
FO-225430	8/10/2012	8/14/2012	Charging station plug for E-vehicle melted while machine was charging overnight; NEED CIRC
FO-225513	8/11/2012	8/10/2012	Please repair problem with #3 air compressor located in room 100. It failed again today. It is th
FO-225515	8/11/2012	8/10/2012	Please repair DA tank controls. It keeps blowing control fuses. We are using back up pump.
FO-225741	8/14/2012	8/14/2012	WALL OUTLET IS HANGING FROM WALL. RESTROOM INSIDE ROOM 441.4.
FO-225880	8/16/2012	8/16/2012	RECONNECT WATER CIRCULATING PUMP. Finished 8/17/2012 LT
FO-226115	8/20/2012	8/30/2012	EMERGENCY R/R STRWL #1 ALL LITES ARE OUT. CK'D CIRCUIT BREAKER STILL NO L
FO-226319	8/21/2012		EMERGENCY R/R RM 010/MECH RM BOTH SUMP PUMPS OUT OF SVC. BURNING S
FO-226335	8/21/2012	8/21/2012	Check power to basement sub pumps in EDC side of building. See Mike Pummill for location
FO-226364	8/21/2012	8/22/2012	BAD BREAKERS 3rd FL COMMUNITY RM POWER OUTLETS NOT WORKING INCLUDING
FO-226402	8/21/2012	8/21/2012	Contractor dug up wires near softball field. Please verify if wires are hot, safe off or fix. Finishe
FO-226414	8/21/2012	8/22/2012	R/R RM 010/MECH RM Reuther Library
FO-226425	8/22/2012	8/22/2012	Investigate and correct cause of generator running off schedule.
FO-226503	8/22/2012	8/22/2012	Building has no power
FO-226660	8/24/2012	8/24/2012	REPAIR OR REPLACE BURNT OUT CUBE LIGHTS. CAFETERIA. SEE ENGINEER.
FO-226896	8/27/2012	8/27/2012	FIRE DOOR AT THE LECTRE HALL IS DOWN. Finished 8/28/12 LT
FO-226897	8/27/2012	8/27/2012	CHECK ELECTRICAL PROBLEM. CHILLER #1. SEE ENGINEER Finished 8/28/12 LT
FO-227125	8/30/2012	8/30/2012	BAD BREAKER #7 IS VERY HOT AND SMELLY. ROOM 1240. 24 HOUR STUDY AREA. Fi
FO-227143	8/30/2012		ROOF:COOLING TOWER FAN# WILL NOT RUN

T - Locksmith**1**

FO-226635	8/24/2012	8/24/2012	73246 21 keys
-----------	-----------	-----------	---------------

T - Pipefitter**4**

FO-225857	8/15/2012	8/17/2012	R/R 4" Domestic water Gate Valve in basement mechanical room,,,,,,,,, CB/RC 8-16-12 ,,,,,,,
FO-225869	8/16/2012	8/17/2012	PIPEFITTER/EMERGENCY R/R RM 351 BAD STM LEAK @ SHUF-OFF FOR FHS' (UNABL
FO-225877	8/16/2012	8/16/2012	PIPEFITTER/EMERGENCY R/R PH/MECH RM RELACED BLOWN GASKET ON #1 BLR MC
FO-226031	8/17/2012	8/17/2012	Fitting on side of tank blew off Finished 8/20/2012 LT

T - Plumber**4**

Total			
FO-225158	8/3/2012	8/3/2012	Men Toilet room 109. Bagged toilet. Please clear ,,,,,,,,,,,,,, MP/8-3-12 ,,,,,,,,,,,,,, Finished 8/8/2
FO-226056	8/17/2012	8/17/2012	2 8th floor slop sinks plugged ,,,,,,,,,,,,,, MP/8-17-12 ,,,,,,,,,,,,,, Finished 8/20/2012 LT
FO-226316	8/21/2012	8/21/2012	EMERGENCY: R/R BSMT/EDC AREA BOTH MENS/WOMENS RM WHEN FLUSHING FLUS
FO-226975	8/28/2012		HOT WATR HEATER LEAKING BADLY 1ST FL BOOSTER HEATER LEAKING WATER IN K
T - Roofing		1	
FO-225103	8/6/2012		4TH FL BOARD OF GOVERNORS CEILING CAVED IN DUE TO WATER DAMAGE
High		206	
T - Carpenter		54	
FO-224374	8/1/2012	8/2/2012	Locksmith
FO-224447	8/1/2012	8/2/2012	Locksmith: please repair or replace the door lock for room 211.2. Key doesn't unlock it. Finish
FO-224476	8/2/2012	8/6/2012	Please replace broken turnbuckle on fire door to new auditorium. When we did the fire test the
FO-224489	8/2/2012		Carpenter; High
FO-224789	8/3/2012	8/6/2012	Carpenters: Woodward Ave. handicapped entrance door will not close and latch on its own. Pr
FO-224830	8/3/2012	8/6/2012	Repair electronic door mechanism. Door will not open when valid card is swiped in card reade
FO-224828	8/3/2012	8/6/2012	R/R STRWL A 1ST FLR INSIDE DOOR HANDLE WILL NOT UNLOCK DOOR Finished 8/7/2
FO-224831	8/3/2012	8/3/2012	ENTRANCE DOOR #504-01-W IS NOT CLOSING PROPERLY.Finished 8/6/2012 LT
FO-224948	8/6/2012	8/7/2012	Carpenters; High
FO-224862	8/6/2012	8/6/2012	73199 Need skeleton key for window locks. Finished 8/7/2012
FO-225152	8/6/2012	8/8/2012	Room 212.01 (inside suite 206): door handle is loose and door does not close properly. Pleas
FO-225153	8/6/2012	8/7/2012	Room 212.24 (inside suite 206): door handle is loose and door does not close properly. Pleas
FO-225196	8/7/2012	8/8/2012	Scott Hall room 1309 - Mail box #11 will not open. Staff in service center have key.
FO-225237	8/7/2012	8/8/2012	ENG NEEDS LADDER TO INVESTIGATE LEAK PLEASE BRING LADDER. NOTIFY ENG
FO-225472	8/10/2012	8/10/2012	entry door lock is very difficult to open. appears to be a problem with the mortise assembly. thi
FO-225468	8/10/2012	8/13/2012	The set screw that holds the lock core in place is missing so that the lock core spins when you
FO-225530	8/13/2012		CARPENTERS: please repair entrance door near door 603-12-n. closer arm came apart
FO-225648	8/13/2012	8/14/2012	CARPENTERS: Please repair two access hatches in the Lobby area 1st floor
FO-225650	8/13/2012	8/14/2012	Carpenter; High
FO-225652	8/13/2012	8/14/2012	R/R ENTRANCE DOOR #071-02N INSIDE/OUTSIDE HANDICAP BUTTONS AREN'T OPEN
FO-225653	8/13/2012	8/16/2012	Please unlock room 309 to Pipefitters Finished 8/20/2012 LT
FO-225673	8/13/2012		FLOOR TILE IS COMING UP. 1ST FLOOR NEAR ROOM 550.
FO-225704	8/14/2012	8/16/2012	Request 73210 3-CORES 6-KEYS MIDTOWN DELI / SANTA FE CAFE. Finished 8/17/2012
FO-225767	8/14/2012	8/14/2012	Ghafari 342:
FO-225858	8/15/2012	8/20/2012	Carpenters:
FO-225856	8/15/2012	8/16/2012	R/R ENT DOOR #620 13E/Alley Door. It is extremely hard to turn keys in this door lock. Finish
FO-225888	8/15/2012	8/17/2012	R/R 3rd floor, RM 390.01 alarmed glass door is very hard to pull open, afraid glass may brake
FO-225932	8/16/2012		FLOOR TILES ARE COMING UP. HALLWAY OUTSIDE OF ROOM 231.
FO-225946	8/16/2012	8/21/2012	Carpenters: please repair loose corner moldings on steps, they are trip hazard.Priority:high. Fi
FO-226064	8/20/2012	8/20/2012	Janitor closwt #309 Key sticking in door. Having a problem getting key out of lock. Please rep
FO-226351	8/20/2012	8/21/2012	Green and Gold kitchen/Dining:
FO-226277	8/20/2012	8/21/2012	R/R RM 207 KEY CORE IS CROOKED & NEEDS STRAIGHTENING (believe screw is loose)
FO-226346	8/20/2012	8/21/2012	Green and Gold Ghafari Kit.:
FO-226377	8/21/2012	8/23/2012	1ft by 6in hole in dock area near drain needs repair.
FO-226404	8/21/2012	8/22/2012	CARPENTERS: Please repair large run of molding on ceiling(hanging down) 3rd floor hallway
FO-226424	8/22/2012	8/22/2012	Investigate and correct cause of boiler door, 498B01S, lock not functioning correctly.
FO-226455	8/22/2012	8/23/2012	Locksmith:
FO-226594	8/23/2012	8/24/2012	Carpenter:
FO-226614	8/23/2012	8/24/2012	In Front of room 1600, there are two tiles that are missing on the floor. THIS IS A SAFETY H
FO-226662	8/24/2012	8/29/2012	Remove right side lower window and install wood panel so that electricians can run power cor

Total

FO-226719	8/24/2012	8/25/2012	The following list of locksmith issues: Apt # 538door lock is tough to key into Apt # 445.D,# 82
FO-226726	8/27/2012	8/27/2012	CARPENTERS TO REPLACE WATER DAMAGED CEILING TILES 4TH FLOOR GENERAL
FO-226727	8/27/2012	8/28/2012	CARPENTERS TO CRATE UP LCN CLOSERS TO DELIVER TO IDN FOR SERVICE
FO-226887	8/27/2012	8/29/2012	Carpenters
FO-226920	8/27/2012	8/24/2012	lock not functioning correctly. need locksmith. Apt # 609.D
FO-227026	8/28/2012	8/28/2012	Univ. Towers Apt. 1109
FO-227027	8/28/2012	8/29/2012	Room 2507 of EDC the key core just spins and does not unlock the door.
FO-227014	8/28/2012	8/29/2012	Room 3528 - LATCH GUARD IS MISSING. (LATCH GUARD IS INSIDE LAB.) PLEASE REP
FO-227122	8/29/2012		Loose floor tile on main level; causing people to slip.
FO-227123	8/29/2012	8/30/2012	Main doors of Welcome Center, #082-03S, will not secure shut when building is locked/armed.
FO-227432	8/30/2012		Carpenters: please repair or replace broken handicap door opener on 1st floor door to the vest
FO-227451	8/30/2012		KEY WONT TURN IN LOCK OF RM 1344
FO-227543	8/30/2012		In office 019, which is in the basement next to
FO-227549	8/31/2012		Approx. 9 loose floor tiles in corridor at about room 235. They are completely loose from the fl

T - Electrician

85

FO-224381	8/1/2012	8/2/2012	R/R RM 0245.1 LITE TIMER CYCLE IS WRKNG Finished 8/3/2012 LT
FO-224462	8/1/2012	8/10/2012	Replace gfci covers (2) on gfci's outside between Law school and Law library. Finished 8/13/1
FO-224479	8/2/2012	8/2/2012	Investigate and correct cause for trouble alarm. Panel displays 'Card 2 power supply charger -
FO-224514	8/2/2012	8/6/2012	Electricians:
FO-224573	8/3/2012	8/3/2012	Please have extension ladder ready for scanning the roof at Arts (10 a.m.). See Dave Kuffner f
FO-224574	8/3/2012	8/3/2012	Please patch concrete in pool through area where contractor was using a hammer drill to look
FO-224575	8/3/2012	8/3/2012	Please hook up pigtail on garbage disposal Finsished 8/6/2012 LT
FO-224817	8/3/2012	8/3/2012	Please fill air in portable air tank and deliver to Phil and Robert. They have a flat tire outside L
FO-224874	8/4/2012		Please check generator. Check generator light is on. (alarm has been silenced)
FO-224855	8/5/2012		Check out why fire panel will not clear fire pump fault. Pump is not running , ack panel. Public
FO-225212	8/5/2012	8/10/2012	ELECTRICIANS,
FO-225214	8/5/2012		ELECTRICIANS,
FO-224864	8/6/2012	8/7/2012	FIRE TROUBLE WILL NOT RESET. (FIRE TROUBLE ALARM). Finished 8/8/2012
FO-225218	8/6/2012	8/7/2012	Laborer; High
FO-225197	8/7/2012	8/7/2012	LIGHTS WILL NOT COME ON. ROOM 101. Finished 8/8/2012
FO-225198	8/7/2012	8/10/2012	R/R RM 0245.1 LITE TIMER, ELEC CAME OUT 8/1... NOT WORKING Finished 8/13/12 LT
FO-225238	8/7/2012	8/9/2012	trouble shoot F/A panel trouble. Finished 8/10/2012 LT
FO-225282	8/7/2012		R/R RM 1301 electrician please troubleshoot dimmer light switch going off&on by it self,in TV r
FO-225314	8/8/2012	8/10/2012	ELECTRICIANS,
FO-225343	8/9/2012	8/10/2012	Please repair or replace air compressor motor #3. The motor won't start. Previously it's been b
FO-225455	8/9/2012	8/14/2012	Electricians
FO-225345	8/9/2012	8/15/2012	Please move coils with Pipefitters to Purdy basement mechanicl room Finished 8/16/2012 LT
FO-225379	8/9/2012	8/10/2012	Time for Fire Alarm walk thru. Friday 10 am 1st floor main lobby. Finished 8/13/12 LT
FO-225440	8/10/2012		110 W. Warren Building(South of Warren, West of John R)- Repair broken entrance bricks as
FO-225629	8/13/2012	8/23/2012	Elect. High priority
FO-225637	8/13/2012	8/16/2012	Please R&R lights under Stadium bleachers, wall packs on building and mall lights. See Jason
FO-225678	8/13/2012		electrician
FO-225687	8/14/2012	8/23/2012	Repair fire panel trouble alarm
FO-225703	8/14/2012		Electrician:
FO-225727	8/14/2012	8/17/2012	R/R Restroom 220.01 CHNG LITE FROM SENSOR MOTION LITE SWITCH TO REGULAR LI
FO-225729	8/14/2012	8/17/2012	Need Electrician-
FO-225730	8/14/2012	8/20/2012	Please hook up a permanent receptical for welder in Penthouse , See Jim Hill for location Fini

Total

FO-225757	8/14/2012		R/R RM 0245.1 light timer is still malfunctioning per Deb Ashcraft. She requests the electricia
FO-225759	8/14/2012		R/R Please MISSING/DAMAGED EXIT SIGNS IN THE FOLLOWING LOCATIONS:
FO-225781	8/15/2012		High priority
FO-225886	8/15/2012	8/24/2012	R/R BLDG 3 lights are out in the overhang outside the front (west) entrance to Scott Hall. The
FO-225899	8/16/2012	8/23/2012	R/R RM 016/MECH AREA Fire alarm horns did not work at new wing.
FO-225867	8/16/2012	8/23/2012	Repair cooling tower fan #1. Keeps blowing fuses.
FO-225988	8/17/2012	8/17/2012	R/R BLDG All exterior lights around the building are not
FO-225994	8/17/2012	8/20/2012	R/R BLDG/UNITS Southwest exterior light is burned out. Finished 8/21/2012 LT
FO-226012	8/17/2012		R/R ELEVATOR (MAIN) Four light bulbs burned out in main elevator. NOTE THAT AS SOON
FO-226066	8/20/2012	8/17/2012	Meet Roy the plumber in the main lobby. He will give you location of drinking fountain. Finishe
FO-226068	8/20/2012	8/20/2012	Check lights at ticket booth. Finished 8/21/2012 LT
FO-226069	8/20/2012	8/20/2012	R/R urinal solenoid valve 3rd floor mens room Finished 8/21/12 LT
FO-226286	8/20/2012	8/22/2012	Electricians:
FO-226255	8/20/2012	8/22/2012	See Marty (fitter) near room 51 north east corner new section basement. Please disconnect wi
FO-226256	8/20/2012	8/20/2012	Meet PM Technologies at Lande let them inside generator enclosure, assist them if needed.Fi
FO-226381	8/21/2012	8/27/2012	R/R TAGGED LIGHTS ***AREA IS DARK*** This is the little area BEFORE the door that out t
FO-226428	8/22/2012	8/22/2012	Time for training for new lights at Stadium. Wednesday 1:30 p.m. at generator behind locker r
FO-226454	8/22/2012	8/22/2012	Pick up old light fixture heads at stadium maintenance building bring back to shop upstairs.
FO-226509	8/22/2012		stock shop (BOTH FOR BLRS & COT)
FO-226479	8/22/2012		Elect.
FO-226512	8/22/2012	8/27/2012	LABORER (HIGH PRIORITY)
FO-226520	8/22/2012	8/23/2012	Install light pole near new softball field building side walk.
FO-226525	8/22/2012	8/22/2012	Turn on generator and stadium lights, provide stand by assistance if needed. When practice is
FO-226553	8/23/2012		Elect.
FO-226557	8/23/2012		Elect.
FO-226665	8/24/2012	8/28/2012	Install temp power cord from tennis courts to stadium infeild.
FO-226687	8/24/2012	8/24/2012	Time to take spare off one Transit van (Phil's) and put onto Buzz's transit van (Buzz has flat a
FO-226708	8/24/2012	8/27/2012	main floor, east side, the 8th floor outlet from the north has a prong from a power cord broken
FO-226722	8/24/2012	8/24/2012	Time for Friday night lights at the Stadium. Install generator cables, generator start up, turning
FO-226732	8/25/2012	8/27/2012	R/R RM ATTIC D/MECH RM MUAHU3 will not run in bypass or AFC. No lights on VFD or VF
FO-226723	8/25/2012	8/24/2012	Time for Saturday night lights at the Stadium. Install generator cables, generator start up, turni
FO-226733	8/26/2012	8/28/2012	R/R BSMT Public safety reports intermittent fire alarm trouble calls. Main panel zone lights for
FO-226676	8/27/2012	8/29/2012	Install temp power cords to overhang area at front entrance. Mornday morning. 3-20 amp, 120
FO-226679	8/27/2012	8/29/2012	Install temp power cords to front of main entrance. Carpenters will replace glass panel with wo
FO-226905	8/27/2012		Unhook power to both condensate pumps in penthouse , See Jim Hill for location
FO-226950	8/27/2012		Electrician:
FO-226944	8/27/2012		Electrician:
FO-227009	8/28/2012	8/30/2012	DENNIS(Handyman)
FO-227011	8/28/2012	8/30/2012	DENNIS(Handyman)
FO-227013	8/28/2012	8/30/2012	DENNIS(Handyman)
FO-227064	8/29/2012	8/30/2012	R/R RM 106 Please replace the Duct detector missing head. Location, of duct detector is MI-
FO-227097	8/29/2012		fix DCW-2
FO-227101	8/29/2012	8/30/2012	Electrician
FO-227102	8/29/2012		Electrician
FO-227119	8/30/2012		BREAKER #7 IS VERY HOT AND SMELLY. ROOM 1240. 24 HOUR STUDY AREA.
FO-227127	8/30/2012		Electricians needed to repair/replace plug for OUTLET FOR ELEC VEHICLES (E-Vehicles)IN
FO-227121	8/30/2012		Canopy and pole lighting not on fix repair adjust as needed

Total

FO-227485	8/31/2012		ELECTRIANS
FO-227480	8/31/2012		disconnect old reconnect insta hot water heater in rm. 3349
FO-227520	8/31/2012		INSIDE RM 1030 ELEC PANEL BOX IS MAKING A HUMMING SOUND AFTER RESETTNG
FO-227556	8/31/2012		R/R 1ST FLR THE FOLLOWING RMS WALL CLOCKS HAVE THE WRONG TIME:
FO-227557	8/31/2012		R/R 1ST FLR THE FOLLOWING RMS WALL CLOCKS HAVE THE WRONG TIME:
FO-227558	8/31/2012		R/R 1ST FLR THE FOLLOWING RMS WALL CLOCKS HAVE THE WRONG TIME:
T - Laborer		1	
FO-226725	8/27/2012		Time to take two tires to the Ford dealer to get them replaced. This is for Buzz's transit van.
T - Locksmith		24	
FO-225275	8/8/2012	8/9/2012	#71440 1 Key Romo 417 Finished 8/10/2012 LT
FO-225804	8/15/2012	8/21/2012	73214 4-KEYS ROOM 312 Finished 8/22/2012 LT
FO-225979	8/17/2012	8/20/2012	#73229 1 Key Room 315 Finished 8/21/2012 LT
FO-226470	8/22/2012	8/22/2012	#73237 6 Keys Room 818 and 1126 Duplicate Finished 8/22/2012LT
FO-226471	8/22/2012	8/22/2012	#73238 1 Key Room 207.3
FO-226499	8/22/2012	8/28/2012	#73240 4 Keys
FO-226501	8/22/2012	8/22/2012	#73243 3 Keys and 2 Cores Room 515
FO-226502	8/22/2012	8/22/2012	#73242 3 Keys amd 2 Cores
FO-226621	8/24/2012	8/27/2012	REQUEST 73244 4-KEYS
FO-226696	8/24/2012	8/24/2012	73247 5-keys
FO-226698	8/24/2012	8/24/2012	73250 1-core Campus move in today. Student can not unlock door. Please provide new core
FO-226706	8/24/2012	8/24/2012	73251 3-KEYS (SCHLAGE) PARKING BOOTH LOT 50
FO-226711	8/24/2012	8/24/2012	73425 20 keys - 229, 706, 707 & 912
FO-226718	8/24/2012		73249 2-keys for RA keyring
FO-226720	8/24/2012		73252 9-keys rooms 104 302 507 602 901 & 902
FO-226858	8/27/2012	8/27/2012	73255 2-CORES 3-KEYS ROOM 608
FO-226861	8/27/2012	8/27/2012	73257 2-CORES 3-KEYS ROOM 460
FO-226916	8/27/2012	8/28/2012	73248 2-cores 2-keys. Move core x9ha-2 from door on site (see louise dezure for location) a
FO-226970	8/28/2012	8/28/2012	#73258 21 Keys
FO-226983	8/28/2012	8/30/2012	#52982 3 Keys Finished 8/31/2012 LT
FO-226985	8/28/2012		#72500 3 Keys
FO-227062	8/29/2012	8/29/2012	#73261 3 Keys Finished 8/31/2012 LT
FO-227069	8/29/2012	8/30/2012	#66483 10 Keys Room 319.2 Finished 8/31/2012 LT
FO-227126	8/30/2012	8/30/2012	73263 1-key X-192 Finished 8/31/2012 LT
T - Painter		2	
FO-224545	8/2/2012	8/3/2012	Missing fire extenguisher by exit door from this mechanical room.
FO-224834	8/3/2012	8/6/2012	GRAFFITTI - 1ST FLOOR WOMEN'S RESTROOM BY ENTRANCE OF PURDY/KRESGE LI
T - Pipefitter		13	
FO-224456	8/1/2012	8/6/2012	Pipefitters
FO-224540	8/2/2012		PIPEFITTER: R/R RM 3025 HAS AN ACTIVE STEAM LEAK COMING FROM HEAT REGIST
FO-225871	8/10/2012	8/10/2012	Clear AH drain on roof ,,,,,,,,,, ME/EA 8-10-12 ,,,,,,,,,, Finished 8/16/2012 LT
FO-225487	8/10/2012	8/17/2012	FITTERS (HIGH PRIORITY)
FO-225643	8/13/2012	8/15/2012	R/R crack PVC piping on chemical feed systems,,,,,,,,,,,,, CB/8-14-12 ,,,,,,,,,, Finished
FO-225722	8/14/2012		Main steam leak in 5435 woodward basement which has not been addressed in years. Very D
FO-225791	8/15/2012	8/23/2012	PIPEFITTERS:
FO-225793	8/15/2012	8/16/2012	PIPEFITTERS:
FO-225795	8/15/2012	8/17/2012	PIPEFITTERS:
FO-225806	8/15/2012	8/21/2012	steam fitters appears to be a leak from heating coil line in north east corridor basement by roo
FO-225831	8/15/2012	8/16/2012	Fabricate 3 Strong Backs and Spool piece for 4" line in basement mechical room ,,,,,,,,,, M

Total

FO-226265	8/20/2012	8/20/2012	R/R steam trap #72 in sub basement/trap is failed closed ,,,,,,,,,, JH/RC 8-20-12 ,,,,,,,,,, Fi
FO-226556	8/23/2012		Fitters,
T - Plumber			23
FO-224454	8/1/2012		Plumbers
FO-224444	8/1/2012	8/2/2012	R/R RM 231 PLS REPLACE A DISTILLED WATER TAP/FAUCET IN ONLY SINK (WTR HAS
FO-224560	8/2/2012	8/3/2012	2ND FL WOMENS RR ALL THREE SINKS WATER GOING DOWN SLOW, BLACK STUFF I
FO-224845	8/3/2012	8/6/2012	plumber
FO-225195	8/7/2012		Repair leaking faucet. Backflow preventer is leaking. Faucet is the first on the immediate righ
FO-225364	8/7/2012	8/7/2012	R/R bagged toilet room 110 1st floor ,,,,,,,,,, MP / 8-7-12 ,,,,,,,,,, Finished 8/13/12 LT
FO-225520	8/7/2012	8/7/2012	Please snake floor drain near Boiler ,,,,,,,,,, RC/MM /8-7-12,,,,,,,,,,,,, Finished 8/13/12 LT
FO-225404	8/9/2012	8/13/2012	2ND FL MEN'S RR NEAR JANITOR'S CLOSET TOILET BAGGED ,,,,,,,,,, RC/MM 8-9-12 ,,,,
FO-225485	8/10/2012	8/16/2012	PLUMBERS (HIGH PRIORITY)
FO-225486	8/10/2012	8/16/2012	PLUMBERS (HIGH PRIORITY)
FO-225517	8/11/2012		R/R auto mens faucet 1st floor 1 faucet, 2ed floor 2 faucets ,,,,,,,,,,RC/MM 8-9-12 ,,,,,,,,,,
FO-225631	8/13/2012	8/14/2012	REPAIR/REPLACE VACUUM BREAKERS IN 4 SINKS. (LOW WATER PRESSURE IN AUT
FO-225683	8/13/2012	8/28/2012	Plumber: please repair leaking toilet sewer pipe just outside the boiler room door in student lo
FO-225872	8/15/2012		R/R pool filter return line ,,,,,,,,,, RC/MM 8-15-12 ,,,,,,,,,,
FO-225835	8/15/2012	8/16/2012	Please pump out lower basement / Evaluate sub pump problem ,,,,,,,,,, RB/8-15-12 ,,,,,,,,,,
FO-225879	8/16/2012	8/17/2012	Plumb. High Priority Fo#225815
FO-225981	8/16/2012		Plumber
FO-226337	8/21/2012	8/23/2012	R/R Leaking faucet in room 5344,,,,,,,,,,,,, DP/8-21-12 ,,,,,,,,,,
FO-226368	8/21/2012	8/24/2012	REPAIR CEILING LEAK. (CEILING PANEL HAS FALLEN) ROOM 1125. SEE ENGINEER.,,,
FO-226421	8/21/2012	8/22/2012	1st floor drinking fountain change filter ,,,,,,,,,, RC/MM 8-22-12 ,,,,,,,,,,
FO-226712	8/24/2012	8/24/2012	R/R any faucets / showers / toilets that can be found with problems ,,,,,,,,,, RC/MM 8-24-12 ,,
FO-227029	8/28/2012		Plumbers, (Medium-High)Staff Lounge, rm. 246, faucet is leaking badly and leaking undernea
FO-227492	8/31/2012		please R&R mens 4th floor stairwell bathroom...sink has bag on it.....RC....8-31-12
T - Roofing			1
FO-225105	8/6/2012		ROOF LEAKS. ROOMS 4130 AND 4194.
T - Sheetmetal			3
FO-225300	8/8/2012	8/9/2012	Michigan Mechanical to balance condenser fans
FO-226420	8/21/2012		ROOFER: R/R RM 2037 Please repair roof leak in south west corner of room 2037.
FO-227530	8/31/2012		Fan needs balanced. Michigan Mechanical
Medium			230
T - Carpenter			67
FO-224457	8/1/2012	8/7/2012	RECAULK (CAULK IS SPLITTING) AROUND WALL - SOUTH SIDE OF BASEMENT NEAR E
FO-224497	8/2/2012	8/3/2012	RM # 472 DOOR SCRAPES ALONG FLOOR Finsished 8/6/2012 LT
FO-224507	8/2/2012	8/3/2012	AF-24 DOOR NOT UNLOCKING PROPERLY Finsished 8/6/2012 LT
FO-224521	8/2/2012	8/3/2012	RM# 3304 DOOR NEEDS TO BE ADJUSTED Finsished 8/6/2012 LT
FO-224523	8/2/2012	8/6/2012	RM# 101 GLASS DOOR OUT OF ALIGNMENT. NOT CLOSING PROPERLY Finished 8/7/20
FO-224777	8/3/2012	8/6/2012	Please replace ceiling tiles in 3rd floor kitchenette . See Mike Pummell for location Finished 8/
FO-224858	8/6/2012	8/6/2012	Please mount brackets to wall in Pipe Shop , See John for location Finished 8/7/2012
FO-224859	8/6/2012		Build storage bin for Pipe Fittings in Pipe Shop , See John For location
FO-224870	8/6/2012	8/8/2012	CURB APPEAL #34, replace 2x4 eggcrate grille first floor, lobby area, center ceiling. Finished
FO-225112	8/6/2012	8/7/2012	RM 155 DOOR CLOSER BROKE OFF Finished 8/8/2012
FO-225182	8/6/2012	8/8/2012	LADIES RESTROOM DOOR FALLING OFF HINGES Finished 8/9/2012 LT
FO-225219	8/7/2012		Replace broken floor tile. These tile may be asbestos so procedure with caution.
FO-225220	8/7/2012	8/8/2012	CARPENTERS: PLEASE REPLACE MULTIPULE CEILING TILES 5th FLOOR NORTH HALL
FO-225257	8/7/2012	8/27/2012	Please repair the key cylinder on the south entrance door from the roof to the make up air fan.

Total

FO-225255	8/7/2012	8/8/2012	Please see Sandy to hang a framed item on the wall of the reception area of Design & Constr
FO-225310	8/8/2012	8/9/2012	PS #2, student parking area west exit, Pedestrian door closure broken. Door slams shut. Do
FO-225357	8/8/2012	8/13/2012	Vinyl flooring beginning to buckle at seam
FO-225405	8/9/2012	8/10/2012	locksmith/carpenter please repair entrance door handle sticks open when exiting the room. m
FO-225407	8/9/2012		The first row of tabels in Auditorium are not balanced please fix.
FO-225413	8/9/2012	8/13/2012	CARPENTERS,
FO-225452	8/10/2012	8/13/2012	Lock Smith:
FO-225469	8/10/2012	8/13/2012	Carpenters: please replace broken and damaged ceiling tiles in room 021. Priority: med.
FO-225526	8/10/2012	8/16/2012	Locksmith:
FO-225527	8/10/2012	8/14/2012	Locksmiths: please repair or replace men's room 324 door lock.key turns but doesn't unlock th
FO-225528	8/10/2012	8/30/2012	Carpenters: please replace missing and or damaged ceiling tiles in computer room 024. priorit
FO-225709	8/13/2012		R/R RM 0111/ASSEMBLY RM SECURE-ATTACHED/REPAIR the loose carpet base on the
FO-225710	8/13/2012		R/R RM 0111/ASSEMBLY RM Please repair the loose plastic laminate counter edge in the ba
FO-225651	8/13/2012	8/14/2012	Unisex Restroom - Door will not close
FO-225682	8/13/2012		Construct and Install room designation signage for Room # 4144
FO-225750	8/14/2012	8/15/2012	R/R RM/Lab in #315 RE-ATTACH broken bench. when entering the room it is the center benc
FO-225766	8/14/2012	8/15/2012	R/R 1ST FLR (ONLY WOMENS RM) Women's Restroom - Public on Purdy 1st floor
FO-225774	8/14/2012	8/16/2012	CARPENTERS,
FO-225836	8/15/2012		Modify desk in Pipe Shop for computer
FO-225860	8/15/2012		12th FL LADIES RM WINDOW COVERING TO MAKE IT UNABLE TO SEE IN IS COMING O
FO-225999	8/17/2012	8/20/2012	Door lock and bolt are sticking in room 293. Finished 8/21/2012 LT
FO-226027	8/17/2012	8/20/2012	R/R Door to Room 134: bolting mechanism does not retract completely when turning outside d
FO-226249	8/18/2012	8/20/2012	Door 2 and 3 South need repair, Doors do not secure, not sure if doors are out of alignment or
FO-226314	8/20/2012	8/22/2012	Carpenter; Medium
FO-226288	8/20/2012	8/21/2012	8/22/2012 KEY GETS STUCK HALF WAY IN LOCK Finished 8/22/2012 LT
FO-226323	8/20/2012		The roll up window drapery in office 222 of the
FO-226339	8/21/2012	8/22/2012	WINDOW SHADE STRING IS BROKEN. ROOM 435.
FO-226379	8/21/2012		Railing on back wall of service elevator loose.
FO-226390	8/21/2012	8/22/2012	Women's restroom 4th floor stall lock needs repair.
FO-226518	8/22/2012	8/23/2012	Closer is falling off door to office. Please repair/replace.
FO-226649	8/23/2012		Carpenters, Medium Priority, please replace 15 damaged ceiling tiles in Shipping/Receiving Ar
FO-226671	8/24/2012		4TH FL TILE MISSING ON FL NEAR ELEV
FO-226702	8/24/2012	8/27/2012	R/R INSIDE STE 300 ENTRANCE DOOR LEADING INTO STE OF RMS 301-314 CK/ADJUS
FO-226724	8/25/2012	8/27/2012	2nd floor Both Unisex Restrooms: The doors need to be repaired; problem with the hinges.
FO-226885	8/25/2012	8/29/2012	Please repair exterior door to mechanical room on the north side of the building near the fire d
FO-226917	8/27/2012	8/28/2012	Carpenters: please repair doors to lecture hall 134, both doors are rubbing on the floor tiles an
FO-226909	8/27/2012		Please build wood box around abanded drinking fountain , See Mike Pummill for location
FO-226913	8/27/2012		RESTROOM #8 BASEMENT DOOR OFF LINE, SCREWS NEED TO BE TIGHTEN.
FO-226949	8/27/2012	8/30/2012	Room 0610 (auditorium): Door stopper needs to be reattached to door facing Mack (south).
FO-226956	8/28/2012	8/30/2012	CARPENTERS: Please repair broken seat in auditorium 0610. Rear seat southside 5th seat.
FO-227008	8/28/2012	8/30/2012	Room 240 - Staff office
FO-227028	8/28/2012	8/29/2012	Purdy 3rd Floor Room 327 Staff office
FO-227030	8/28/2012	8/29/2012	2nd MENS LOCKER RM DOOR NOT LOCKING Finished 8/31/2012 LT
FO-227073	8/29/2012	8/30/2012	East entrance door into suite 3100 the key core needs repair, the block key will not turn the co
FO-227117	8/30/2012		Please supply key for filter room 045 to myself-Afternoon supervisor. Key number is OE59.
FO-227117	8/30/2012		Please supply key for filter room 045 to myself-Afternoon supervisor. Key number is OE59.
FO-227133	8/30/2012	8/30/2012	1st floor Gold doors in corridor (south of credit union) one door is hard to open and the screws

Total

FO-227429	8/30/2012		locksmith: please repair the door lock to mechanical room 014. the lock is stuck in locked posi
FO-227467	8/30/2012		1ST FL WOMENS HANDICAP RESTROOM LOCK IS BROKEN OFF DOOR
FO-227472	8/30/2012		Several offices within the suite are having issues with doors locking or sticking.
FO-227514	8/31/2012		Replace water damaged ceiling tiles in kitchen.
FO-227525	8/31/2012		Study room #131 the lock is hard to use may be sticking. Could the locksmith please check thi
FO-227550	8/31/2012		The office door for this room does not close. It's like the door is warped.

T - Electrician

34

FO-224376	8/1/2012	8/1/2012	R&R light fixtures, replace bad ballasts. 5th floor.
FO-224414	8/1/2012		ELECTRICIANS,
FO-224500	8/2/2012	8/6/2012	Electricalricians:
FO-224778	8/3/2012		Please Assist Plumbers with moving material , equiment on site ,clean up debris in basement
FO-225142	8/6/2012	8/6/2012	Deliver material for CPVC drain job 2ed floor lab, See Mike Pummill for location Finishe
FO-225326	8/8/2012	8/28/2012	Electrian
FO-225327	8/8/2012	8/14/2012	Electrian
FO-225309	8/8/2012	8/14/2012	R&R light fixtures in room 404, 405 and the hallway between rooms.
FO-225493	8/9/2012	8/14/2012	Electricians
FO-225494	8/9/2012	8/14/2012	Clean dirty smoke detector on 1st floor for firedoor. this detector is going into trouble on Natio
FO-225460	8/10/2012		Breaker will not reset for outside lighting . See Engineer Lapointe Breaker in mech,Rm
FO-225501	8/10/2012	8/14/2012	Please replace light bulbs in Honeywell annunciator panel first floor next to Simplex panel.
FO-225693	8/14/2012	8/22/2012	Check / repair the fire alarm system at Science Hall.
FO-225694	8/14/2012	8/17/2012	Please check fire alarm panel going in and out of trouble. Finished 8/20/2012 LT
FO-225732	8/14/2012		Electrican please correct time on north face of simplex clock it is three hours slow in hall outsi
FO-226028	8/17/2012	8/20/2012	Elect. Med. Priority
FO-226017	8/17/2012		Buzzing light on 4th floor hallway near right side exit.
FO-226118	8/17/2012		R/R Lobby of Welcome Center behind Student Service Center Desk, ceiling light is making a c
FO-226065	8/20/2012	8/17/2012	R&R light timer room 200.10. Finished 8/20/2012 LT
FO-226114	8/20/2012		R/R 4th Floor, SUPPLY emergency ceiling light is making a continuous beep.
FO-226272	8/20/2012		Laborer; Medium
FO-226587	8/23/2012		Clock not working.
FO-226707	8/24/2012		ELECTRAIN
FO-226864	8/27/2012	8/30/2012	Electricians:
FO-227060	8/28/2012		Electrician:
FO-227120	8/30/2012	8/30/2012	move genie lift to St. Andrews hall
FO-227440	8/30/2012		At the north entrance exterior, there are
FO-227446	8/30/2012		Outside the main entrance, there are several
FO-227151	8/30/2012		REPLACE OVERHANG LIGHTS. FRONT ENTRANCE TO THE BUILDING.
FO-227510	8/31/2012		R/R 24hr LOUNGE/1500 LITES ARE NOT WORKING
FO-227508	8/31/2012		Three Electrical Closets need clamps on Emergency Light Circuit Breakers. Rooms 1140, 324
FO-227516	8/31/2012		OUTSIDE RM 0247 LIGHT TIMER NOT WORKING IN ANIMAL QUARTERS
FO-227559	8/31/2012		Electricians, Med. Pri ,
FO-227567	8/31/2012		R/R AUDITORIUM & LOBBY AREA CHANDELIER NEED LITES REPLACED

T - Locksmith

8

FO-224480	8/2/2012	8/3/2012	PROVIDE AND INSTALL A LOCKBOX IN THE ENTRY TO MOTUARY SCIENCE. Finsished
FO-225437	8/10/2012	8/15/2012	#72471 4 Keys and 2 Core Finished 8/16/2012 LT
FO-225775	8/15/2012	8/20/2012	Request 73213 2-file keys Finished 8/21/2012 LT
FO-225952	8/16/2012	8/17/2012	Please provide and install a brown box for building access with a 9G master key. 3-for trades
FO-226692	8/24/2012		72828 2-KEYS
FO-226869	8/27/2012	8/28/2012	66482 4-keys room 300.01

Total

FO-227117	8/30/2012		Please supply key for filter room 045 to myself-Afternoon supervisor. Key number is OE59.
FO-227117	8/30/2012		Please supply key for filter room 045 to myself-Afternoon supervisor. Key number is OE59.
T - Painter		3	
FO-225289	8/8/2012		Paint bleachers,risers and hand rail in stadium. Finished 8/20/2012 LT
FO-225758	8/14/2012		Plaster, Medium priority,Hallway outside of room 441 and 4th floor stairwell, wall has several b
FO-226474	8/22/2012	8/30/2012	Paint entry door leading into vestibule into 4900 AAB conference room.
T - Pipefitter		24	
FO-224775	8/3/2012	8/8/2012	Pipefitters
FO-224847	8/3/2012	8/6/2012	FITTERS: PLEASE REPAIR PIPE LEAK ON DOMESTIC HOT WATER HEATER IN PENTHO
FO-225124	8/6/2012	8/27/2012	Fitters-chemical feed line for steamate,the check valve needs to be change.will not let chemic
FO-225169	8/6/2012	8/10/2012	Fitters:
FO-225170	8/6/2012		Fitters:
FO-225258	8/7/2012	8/22/2012	Railing on receiving room ramp has been damaged. Sharp metal has been removed and filed
FO-225201	8/7/2012		Fitters:
FO-225203	8/7/2012	8/13/2012	Fitters:
FO-225243	8/7/2012		fitter-Steam regulator for 5435wooder main steam line needs to be changed will not let steam
FO-225394	8/9/2012		Fitters install a jumper air line connecting the control air compressor with the lab air compress
FO-225395	8/9/2012	8/13/2012	Fitters replace the discharge check valve on the #1 lab air compressor. ,,,,,,,,,, JH/RC 8-9-12
FO-226035	8/17/2012		FITTERS: Please repair/replace blowing steam trap on steam station near fire pump
FO-226036	8/17/2012		Pipefitter
FO-226282	8/20/2012		steam fitters please replace foot valve to #3 chemical pump, ball check stuck ,,,,,,,,,, ME/
FO-226542	8/23/2012	8/24/2012	Evaluate piping / valves to isolate coil in room 3025 ,,,,,,,,,, JH/RC 8-23-12 ,,,,,,,,,,
FO-226654	8/23/2012	8/24/2012	Please check ceiling leak near room 50 in basement ,,,,,,,,,, ME/EA 8-23-12,,,,,,,,,,,,,
FO-226849	8/24/2012		R/R coil leak 147.1 in basement plenum ,,,,,,,,,, ME/EA 8-24-12 ,,,,,,,,,,
FO-226697	8/24/2012	8/30/2012	R/R leaking steam control valve in plenum #2 coil #1 ,,,,,,,,,, Me/EA 8-24-12 ,,,,,,,,,, Finished
FO-227005	8/28/2012		Pipefitter; Medium
FO-226994	8/28/2012		Please R/R coil#88.3 in sub basement #1 ,,,,,,,,,, JH/RC 8-28-12 ,,,,,,,,,,
FO-227082	8/29/2012		FITTERS: Please repair pipe leak on the Domestic Hot Water Heater(2) in lower level mech. r
FO-227118	8/30/2012		Insulate piping near Steam Reducing Station. RE: PM FO-224633
FO-227442	8/30/2012		Fitters:
FO-227443	8/30/2012		Fitters:
T - Plumber		90	
FO-224410	8/1/2012	8/2/2012	CLOGGED SINK. ROOM 1253. ,,,,,,,,,, RB/8-2-12 ,,,,,,,,,, Finished 8/3/2012
FO-224430	8/1/2012	7/30/2012	R/R bagged urnial 1st floor mens ,,,,,,,,,, RB/MM 7-30-12 ,,,,,,,,,, Finished 8/2/2012
FO-224467	8/1/2012	8/3/2012	2ST FL WOMENS RR TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,, RB/8-2-12 ,,,,,,,,,,
FO-224556	8/2/2012	8/3/2012	Plumbers: please repair automatic faucet on the right side in men's room 104.Put new batterie
FO-224565	8/2/2012	8/3/2012	RM# 6225 FAUCET LEAKING ,,,,,,,,,, RB/8-3-12 ,,,,,,,,,,Finished 8/6/2012 LT
FO-224572	8/3/2012	8/23/2012	R/R 6" backflow preventer in basement mechanical room ,,,,,,,,,, DP/RC/MM/RB 8-2-12 ,,,,,,,,,,
FO-224578	8/3/2012		Clear roof sumps ,,,,,,,,,, RC/MM 8-3-12 ,,,,,,,,,,
FO-224786	8/3/2012	8/6/2012	PLUMBERS
FO-224848	8/3/2012	8/11/2012	PLUMBERS: PLEASE REPAIR FAUCET IN WOMENS RESTROOM. FIRST SINK NEAR DO
FO-224872	8/3/2012	8/21/2012	Sink in staff lounge is clogged up. Please come and snake out ASAP.,,,,,,,,,, RC/MM 8-21-
FO-224869	8/6/2012		Men's restroom 2nd floor faucet leaking in 2nd sink. ,,,,,,,,,, RB/8-9-12 ,,,,,,,,,,
FO-225099	8/6/2012	8/14/2012	SINK WITHIN 7213 HAS LEAK ,,,,,,,,,,RB/ 8-9-12 ,,,,,,,,,,
FO-225126	8/6/2012	8/13/2012	Water leak in Basement Room 14
FO-225166	8/6/2012	8/30/2012	Urinal drain is plugged and overflowing in 2nd fl mens room in old lab wing by freight elevator.
FO-225184	8/6/2012	8/17/2012	R/R pipe leak on domestic hot water heater in penthouse ,,,,,,,,,, RB / 8-7-12 ,,,,,,,,,, Fini
FO-225186	8/7/2012	8/14/2012	1st floor Employees and Unisex restroom please tighten loose seats.,,,,,,,,,, RC/MM 8-9-12 ,

Total

FO-225225	8/7/2012	8/20/2012	Please repair shut off valve and sloan valve in basement restroom. Both valves leak.
FO-225252	8/7/2012	8/22/2012	Please replace broken toilet seat in ladies rm.(fo-225224) PLUMBERS MED. RB/
FO-225249	8/7/2012		9th floor Women's restroom across from 9408 the sink is clogged. RB/8-9-12
FO-225251	8/7/2012	8/13/2012	1ST FL LADIES RR NEAR JANITOR'S CLOSET 1ST STALL TOILET LEAKING RC/
FO-225281	8/8/2012	8/20/2012	Room 3266 - Faucet is leaking in sink - please fix. RB/8-9-12 Finished 8/2
FO-225296	8/8/2012	8/17/2012	PLUGGED SINK. 3RD FLOOR LADIES RESTROOM. RB/8-9-12 Finishe
FO-225318	8/8/2012	8/15/2012	plumber please repair leak under sink (fo-225146) med. priority RB/8-9-12
FO-225358	8/8/2012	8/29/2012	Women's restroom - One of the toilets will not
FO-225424	8/9/2012	8/20/2012	plumbers please repair 1st toilet auto flush valve it continuously runs.(fo-225389) R
FO-225426	8/9/2012		5th FL WOMENS RR, TOILET MAKING BUBBLING NOISE RB/8-9-12
FO-225483	8/10/2012	8/21/2012	Women's restroom - One of the toilets is
FO-225506	8/10/2012	8/15/2012	Room 8219's sink is constantly leaking from the
FO-225516	8/11/2012		R/R discharge check valve on #1 lab air compressor RB/8-13-12
FO-225701	8/13/2012	8/17/2012	Please Locate source of leak in Lisa"s office 2ed floor DP/8-13-12 Finished
FO-225628	8/13/2012	8/13/2012	Plumb. Med. Priority.
FO-225625	8/13/2012	8/14/2012	R/R 1ST FLR ONLY WOMENS RM 1ST STALL TOILET NOT FLUSHING AUTO FLUSHING
FO-225627	8/13/2012	8/14/2012	R/R 1ST FLR ONLY WOMENS RM (R) HAND SINK FAUCET WORKING WATER ISN'T CO
FO-225671	8/13/2012	8/14/2012	R/R RM 2103/Unisex Restroom - HANDICAP STALL Pipe leaks about toilet RB/8-
FO-225762	8/14/2012		ATTN: PLUMBERS PRIORITY MED
FO-225706	8/14/2012	8/28/2012	PLUMBERS: Please repair two middle sinks in the womens restroom 2113 both faucets have
FO-225692	8/14/2012	8/20/2012	WOMEN'S RESTROOM IN BASEMENT THE TOILET NOT FLUSHING PROPERLY
FO-225708	8/14/2012	8/16/2012	plumber please unclogg urinal drain,urinal draining very slow causing water to overflow on to fl
FO-225749	8/14/2012	8/15/2012	MEN'S RESTROOM ON 5TH FLOOR ACROSS FROM 556--THE AUTO FLUSHER NOT WO
FO-225751	8/14/2012	8/21/2012	R/R 1ST FLR OLD STOCK RM SIDE HALL WOMENS RM PLS REPLACE 2ND SINK FAUCE
FO-225779	8/14/2012		Plumbers, please repair emergency eyewash station. Very low water pressure..... RB/8-
FO-225780	8/14/2012	8/30/2012	Plumbers, please repair emergency eyewash station. Very low water pressure. RB
FO-225816	8/15/2012	8/17/2012	8th floor men's restroom across from #8308, both Urinals barely flushing. MP/8-15
FO-225817	8/15/2012	8/20/2012	7th floor men's restroom near the service elevator one of the urinal not flushing properly.
FO-225876	8/15/2012	8/28/2012	PLUMBERS: Please repair clogged sink in 3rd floor womens restroom. fo#225390 med
FO-225883	8/16/2012		please repair toilet, constantly water running. I adjusted flow rate lower. It seems to be stoppin
FO-225943	8/16/2012	8/30/2012	Plumber'
FO-225980	8/16/2012		Plumber'
FO-226005	8/17/2012	8/22/2012	SINK DRAINS SLOWLY. ROOM 7327. RB/8-20-12
FO-226046	8/17/2012	8/20/2012	UNISEX RESTROOM TOILET CONTINUOSLY FLUSHES AFTER BEING FLUSHED BUT EV
FO-226245	8/20/2012	8/20/2012	R/R 3rd floor toilet (bagged) RC/MM 8-21-12 Finished 8/21/2012 LT
FO-226283	8/20/2012		Plumber; Medium
FO-226280	8/20/2012	8/22/2012	Plumbers, please fix leaky faucet in sink behind engineers office. RB/8-21-12
FO-226284	8/20/2012	8/22/2012	Plumber; Medium
FO-226285	8/20/2012	8/30/2012	plumbers please check water pressure to auto clave, building pressure okay MP/8-2
FO-226278	8/20/2012	8/27/2012	4th FL MENS RM NEAR JANITOR'S CLOSET URINAL CONTINUOUSLY FLUSHING
FO-226281	8/20/2012	8/21/2012	WATER PRESSURE IS TOO HIGH. UNISEX RESTROOM 2103..... RB/8-21-12
FO-226320	8/20/2012	8/29/2012	Middle urinal is clogged. Bagged to prevent use..... RB/8-22-12 Finished 8/31/
FO-226326	8/21/2012	8/30/2012	sink is clogged MP/8-22-12..... Finished 8/31/2012 LT
FO-226306	8/21/2012	8/23/2012	SINKS DRAINS VERY SLOWLY. 1ST FLOOR MEN'S RESTROOM NEAR OLD STOCKROO
FO-226330	8/21/2012	8/27/2012	drain in sink on right is draining very slowly. Please clear drain..... RC/MM 8-22-12
FO-226355	8/21/2012	8/23/2012	RM 106 MENS BATHROOM TOILET BASE LEAKING...WATER COMING UP FROM FLOOR
FO-226356	8/21/2012	8/23/2012	RM 106 MENS BATHROOM LEAKING FAUCET RC/MM 8-22-12

Total

FO-226392	8/21/2012	8/24/2012	R/R 1ST FLR NEAR RM 1361 WATER FOUNTAIN HAS BAG OVER IT MP/8-22-12
FO-226436	8/21/2012		Please repair the urinal, will not flush.
FO-226464	8/22/2012		Plumber; Medium
FO-226608	8/23/2012	8/29/2012	plumber 1st floor men restroom third urnial not flushing RC/MM 8-27-12
FO-226611	8/23/2012	8/28/2012	plumber please replace bad drainline on sump pump location mech room 51 west side
FO-226598	8/23/2012	8/27/2012	R/R RM 2343/MENS RM BAG URINAL IS PLUGGED CANNOT PLUNGE W/PLUNBER PER
FO-226673	8/24/2012	8/27/2012	PLUMBERS
FO-226675	8/24/2012		Drain inside trench in room on right side moves very slow, have been plunging it 3 times per w
FO-226878	8/24/2012		PLUMBERS PLEASE REPLACE BROKEN COLD WATER FAUCET IN MENS RM.6101 MED
FO-226701	8/24/2012	8/27/2012	R/R RM 140 ONLY SINK/GARBAGE DISPOSAL IS PLUGGED UP W/FOOD. UNABLE TO R
FO-226837	8/27/2012	8/30/2012	Plumb Med. Priority
FO-226778	8/27/2012	8/28/2012	6Th floor Men's restroom across from Conference room C (westside of building) one of the uri
FO-226780	8/27/2012	8/28/2012	10th floor Men's restroom across from 10303, one of the urinal not flushing properly.
FO-226836	8/27/2012	8/30/2012	Women's restroom #3102, second stall when toilet flushed the water runs out of bowl on floor.
FO-226865	8/27/2012		Please check and repair the valves needed to isolate the controls for the system. See Rich/LI
FO-226870	8/27/2012	8/28/2012	Repair sink trap for sink in room 134. Drain may need to be cleared.,RC/MM 8-28-12
FO-226927	8/27/2012		R/R slone valve 7th floor mens, second stall from the right , west side of building MP/8-
FO-227006	8/28/2012		Plumber; Medium
FO-226976	8/28/2012		PLUGGED TOILET. 3RD FLOOR MEN RESTROOM.
FO-226989	8/28/2012		SINK ACROSS FROM FUME HOOD #7 LEAKING WATER ON FL RM 260
FO-227047	8/29/2012		R/R 3RD FLR BACK STRWL AREA (ANTHONY WAYNE RM) UNISEX BATH RM ONLY TOI
FO-227466	8/30/2012		The mechinal room on the 2nd floor near rm 216 across from this room ,open door and go up
FO-227426	8/30/2012		Plumbers please repair/replace hot water tank. It is leaking water from the bottom of the tank.
FO-227464	8/30/2012		plumber
FO-227515	8/31/2012		Water fountain is not functioning on 4th floor
FO-227517	8/31/2012		Room 212.09 (inside suite 206): sink leaks. Currently turned off. Please repair.
FO-227521	8/31/2012		Ladies room facet is continuously running; may need new washer.

T - Sheetmetal

4

FO-225778	8/14/2012		Roofer: Please make necessary repairs to leak above room #4266
FO-226526	8/22/2012		Sheetmetal. Medium priorty.
FO-226465	8/22/2012		Roofers
FO-226466	8/22/2012		ROOFERS

Low

545

T - Carpenter

129

FO-224375	8/1/2012	8/1/2012	Please replace stained ceiling tile in the 3rd floor hallway by room 3170 in the office wing.
FO-224378	8/1/2012	8/2/2012	Build a cage around the lawn sprinkler header on north side of the building to prevent damag
FO-224387	8/1/2012	8/2/2012	CURB APPEAL #21 REPLACE WATER STAINED CEILING TILES 1ST FLOOR WEST ENT
FO-224389	8/1/2012		CURB APPEAL # 22 REPLACE CEILING TILES CENTER STAIRWELL 1ST FLOOR
FO-224390	8/1/2012	8/3/2012	CARPENTERS,
FO-224392	8/1/2012	8/9/2012	CARPENTERS,
FO-225265	8/1/2012		Replace cracked glass on either side of the
FO-224491	8/1/2012	8/7/2012	carpenters
FO-224453	8/1/2012		TEAM LEADER TIME (AUGUST 2012)
FO-224455	8/1/2012		KEYS & CORES (AUGUST 2012)
FO-224486	8/2/2012	8/3/2012	Key core will not turn to call the freight elevator in the basement of the lab wing.
FO-224487	8/2/2012	8/8/2012	Door will not close and latch & lock on its own, has to be pulled closed, please repair.
FO-224488	8/2/2012	8/8/2012	Carpenters:
FO-224498	8/2/2012	8/17/2012	R/R RM 138/SVC CTR NEED TO HAVE MWRFS' & X-SHTS CUT IN HALF Finished 8/20/201

Total

FO-224501	8/2/2012	8/8/2012	Please pull out wall ac unit in Eugene's office so that bldg eng can clean it. The job is schedul
FO-224512	8/2/2012	8/6/2012	CARPENTERS,
FO-225085	8/2/2012		We would like several of the stairwell doors in PS#3 that are broken, rusted out, and failing to
FO-224579	8/3/2012	8/2/2012	SAFTEY MEETING (AUGUST 2012) Finished 8/3/2012 LT
FO-225101	8/3/2012		The Towers Residence Hall Exercise room on the 6th. flr.
FO-226044	8/3/2012	8/21/2012	Replace missing ceiling panel in room 3072 F/AB, damaged as a result of a 6/1/11 break in.
FO-225150	8/6/2012	8/7/2012	CARPENTERS,
FO-225151	8/6/2012	8/8/2012	Door stop behind entry door has come loose. Please repair. Finished 8/9/2012 LT
FO-225162	8/6/2012		14th floor unisex restroom near elevators. Take out dry wall so proper backing can be installed
FO-225261	8/7/2012	8/23/2012	PETERSON GLASS TO REPLACE WARREN ENTRANCE OVER THE DOOR TRANSOM PA
FO-225298	8/8/2012	8/9/2012	Please repair table in faculty lounge. A bolt came loose and the leg fell off. Minor repair. Finis
FO-225299	8/8/2012	8/9/2012	Carpenter
FO-225381	8/8/2012	8/10/2012	Carpenters, please replace deteriorated door bumpers. Several throughout entire building to in
FO-226487	8/8/2012		please secure mail and receiving areas 3 main entrances, high security area,mail sorter room,
FO-225317	8/8/2012	8/9/2012	CARPENTERS,
FO-225386	8/8/2012	8/14/2012	CARPENTERS,
FO-225347	8/9/2012	8/9/2012	CURB APPEAL #29 REPLACE WATER STAINED CEILING TILES 1ST FLOOR ROOM # 161
FO-225348	8/9/2012	8/9/2012	CURB APPEAL # 33 REPLACE 12X12 CEILING TILES 1ST FLOOR CENTER CEILING LOB
FO-225351	8/9/2012	8/24/2012	REQUEST 73200 4-cores 6-keys rooms 3225(2-doors) 3225.15 & 3225.01. MOVE CORE 12
FO-225349	8/9/2012	8/10/2012	INSTALL CEMENT WALKING PADS ROOF OF COHN Finished 8/13/12 LT
FO-225350	8/9/2012	8/10/2012	CARPENTERS TO INSTALL DOOR LOUVER ROOM # 130 Finished 8/13/12 LT
FO-225382	8/9/2012		Carpenters,
FO-225387	8/9/2012	8/14/2012	Carpenters replace damaged ceiling tiles in server room. Priority low. Finished 8/16/2012 LT
FO-225451	8/9/2012		Lower Level in the Staff Parking Area (southwest side) remove fencing storage area. Also re
FO-225401	8/9/2012	8/10/2012	CURB APPEAL #35 ADJUST BOTH DOORS / NOT CLOSING PROPERLY NORTH EAST S
FO-225402	8/9/2012	8/9/2012	CURB APPEAL #37 REPLACE 12X12 TILE (6)1ST SOUTH OPEN STAIRWELL Finished 8/1
FO-225403	8/9/2012	8/10/2012	CURB APPEAL # 39 INSTALL KICK PLATE LAB # 154 Finished 8/13/12 LT
FO-225411	8/9/2012	8/20/2012	carpenter please remove ac unit from window to cleanl Finished 8/21/2012 LT
FO-225412	8/9/2012		carpenter please remove a/c unit from window to be clean room 217
FO-225414	8/9/2012	8/13/2012	CARPENTERS,
FO-225962	8/9/2012		desired_date: 08/16/2012
FO-225457	8/10/2012	8/10/2012	Broken window in the Computing Center on Antoniette Street. Window is on Ground level. Th
FO-226317	8/10/2012	8/23/2012	3rd Floor, Cubicle #341.21 has a key that broke off inside the lock of the locker. Need two ne
FO-225670	8/13/2012	8/16/2012	CARPENTERS,
FO-225667	8/13/2012	8/14/2012	CARPENTERS,
FO-225668	8/13/2012	8/29/2012	CARPENTERS,
FO-225669	8/13/2012	8/30/2012	CARPENTERS,
FO-225688	8/14/2012	8/16/2012	MAKE LADDER RACK AND TOOL SHELVES FOR THE #-2 E-RIDE. Finished 8/17/2012 LT
FO-225690	8/14/2012	8/24/2012	73211 approx 20 cores, keys and padlocks to secure 1200 W. Holden.
FO-225697	8/14/2012	8/15/2012	REQUEST 71299 3-KEYS Finished 8/16/2012 LT
FO-225716	8/14/2012		R/R Room 220.5 (inside suite 206): carpet square near door loose, please re-glue.
FO-225733	8/14/2012		R/R RM (UGL Study Room) 2532 door is locked, lock will not open.
FO-225735	8/14/2012		R/R RM 2524 ADJUST door handle THAT IS stiff and difficult to open,
FO-225736	8/14/2012	8/15/2012	R/R RM 2528 ADJUST door handle THAT IS stiff and difficult to open, Finished 8/16/2012 LT
FO-225738	8/14/2012	8/15/2012	R/R RM 2540 ADJUST door handle THAT IS stiff and difficult to open, Finished 8/16/2012 LT
FO-225746	8/14/2012	8/15/2012	DOOR WILL NO CLOSE PROPERLY. INNER LOADING DOCK DOOR 1590.2. PROLEM W
FO-225769	8/14/2012		Insurance - Police Report W12-2270068 - Please board up and secure door/glass to room 598

Total

FO-225846	8/15/2012	8/16/2012	R/R UGL Study Room 3315 door handle is stiff and difficult to open Finished 8/17/2012 LT
FO-225832	8/15/2012	8/15/2012	CURB APPEAL 1 # 314 REPLACE FLOOR TILE AFTER ABATEMENT HAS TAKEN PLACE
FO-225851	8/15/2012	8/23/2012	CARPENTERS, PLEASE REPLACE CEILING TILES IN THE SOUTHEAST CORNER (TILE
FO-225849	8/15/2012	8/23/2012	CARPENTERS PLEASE REPLACE CIELING TILES IN STUDENT OFFICE #12 , TILES HAV
FO-225854	8/15/2012	8/16/2012	Please assist electricians at Law School, Damon Keith wing (1st floor main desk). Ceiling tiles
FO-225884	8/16/2012	8/16/2012	Carpenter: Please make necessary repairs to door to Room #316, door is binding and will not
FO-225923	8/16/2012	8/17/2012	replace missing ceiling tile.previous Work order No. FO-225895
FO-225947	8/16/2012	8/20/2012	CARPENTERS,
FO-227489	8/16/2012		R/R RECEIVING/STOCK AREA Request to fill holes in the receiving floor at 1200 Holden St.
FO-226365	8/16/2012		JUST DO IT.....
FO-225996	8/17/2012		Curb Appeal: Item # 375 replace missing room signs 306, 309 and 317.
FO-225997	8/17/2012		Curb Appeal: item # 358. Chiiler Room door, missing signage.Basement
FO-226008	8/17/2012	8/21/2012	CARPENTERS: Please replace multipule ceiling tiles 5th floor east hallway near room 5530 L
FO-226043	8/17/2012		DOUG, THIS IS FOR THE COST OF LABOR ONLY. Please have two doors in the Housing
FO-226121	8/20/2012		CURB APPEAL-2: ITEM #56 REMOVE EXH. FAN AND REPLACE WITH GLASS.ELECTRIC
FO-226251	8/20/2012	8/21/2012	CURB APPEAL-2: ITEM # 389 REPLACE DOOR STOPPER. WALL HAS BEEN PATCHED B
FO-226253	8/20/2012	8/21/2012	CARPENTERS TO REPAIR DOOR THAT LEADS FROM THE PRINT ROOM TO THE ATHLE
FO-226267	8/20/2012	8/21/2012	Lock Shop: sticky lock of room #2079 Ms Sherry would like her lock to operate a little more s
FO-226341	8/20/2012	8/30/2012	Green and Gold dining:
FO-226311	8/21/2012	8/21/2012	(VENDOR) BUTKI TOOL TO REPAIR PORTABLE BAND SAW. Finished 8/22/2012 LT
FO-226342	8/21/2012		DOOR WON'T OPEN WITH KEY. STORAGE CABINET DOOR. BETWEEN ROOMS 110& 1
FO-226369	8/21/2012	8/22/2012	CURB APPEAL # 2 ITEM # 24 INSTALL BASE DISPLAY CASE 1ST EAST VESTIBLE ENTR
FO-226374	8/21/2012	8/23/2012	CURB APPEAL#2 ITEM #27 INSTALL BASE DISPLAY CASE 1ST CENTER STAIRWELL N
FO-226384	8/21/2012	8/24/2012	Re-align roof hatch and catch plate - Hatch will not stay closed.
FO-226476	8/21/2012		Attention Doug: Replace frame and door at the entrance off Cass & Palmer (SE Elevator Lobb
FO-226481	8/21/2012		Attention Doug: Glass door to PS #3 Center Stairway (near vehicle entrance), seal for door gla
FO-226478	8/21/2012		Attention Doug: Door from central stairway (near vehicle entrance) to parking area needs to b
FO-226866	8/21/2012		Attention Doug: Please replace the rusted stairway door at PS #1, near Gate #1 (Cass & I-94).
FO-226545	8/22/2012	8/30/2012	R/R RM 02389 Please check window for leak at base and top of window.
FO-226456	8/22/2012	8/22/2012	CARPENTERS TO REPAIR DOOR # 082-12-N NEEDS A CLOSER & A NEW ROLLER STRI
FO-226599	8/23/2012	8/23/2012	Need door to new lower level ladies room open for public use. Currently no core in door. Dougl
FO-226570	8/23/2012	8/23/2012	CURB APPEAL 2 ITEM # 43 REPLACE 4 BROKEN TILES @ DF FIRST LEVEL NORTH / FI
FO-226569	8/23/2012	8/24/2012	The grating around the chiller needs shored up or secured, it is a trip hazard
FO-226572	8/23/2012	8/23/2012	CURB APPEAL 2 ITEM # 46 INSTALL SIGN FIRE EXTINGUISHER CAB'T 1ST LEVEL MAIN
FO-226574	8/23/2012	8/23/2012	CURB APPEAL 2 ITEM # 60ADJUST ACCESS PANEL TO CLOSE 2 ND FLOOR WEST EA
FO-226593	8/23/2012		R/R RM 3532 The core for the lock is turing on the door for room 3532,
FO-226620	8/24/2012	8/24/2012	CARPENTER TO REPAIR OR TUNE UP DOOR 060-4-N THAT LEADS TO NORTH STAIRW
FO-226622	8/24/2012	8/24/2012	CARPENTERS TO INSTALL LARGE MARQUEE SIGNAGE BOARD OUT SIDE MARIO'S OF
FO-227012	8/24/2012	8/30/2012	Carpenter's are needed to assemble and install Dogie Pot Stations on East side of University
FO-226857	8/25/2012	8/25/2012	FPM recently supplied 5-keys for University Towers apt 712 and they do not work. Key #16ej1
FO-226898	8/27/2012		Stairwell door lock on the second floor is not working properly. no further information available
FO-226943	8/27/2012		carpenters replace missing ceiling tiles as needed hallway outside and in room 0113
FO-226914	8/27/2012	8/30/2012	Please change core in 3 pad locks Finished 8/31/2012 LT
FO-226930	8/27/2012	8/29/2012	Modify charging staion shelving Finished 8/31/2012 LT
FO-226931	8/27/2012	8/28/2012	cut piece of drywall the size of average wipe board.
FO-226991	8/28/2012		Ghafari Community Room:
FO-227016	8/28/2012		Ghafari Gold and Greens Recieving Room:

Total

FO-227021	8/28/2012		CARPENTERS,
FO-227019	8/28/2012		CARPENTERS,
FO-227020	8/28/2012		CARPENTERS,
FO-227022	8/28/2012		Carpenters, please repair/replace door stop to main hallway by room 1160. Door stop is missi
FO-227024	8/28/2012		Carpenters, please repair/replace door stop. Door stop is missing rubber stopper and is scrap
FO-227055	8/29/2012		SERVICE ADA 19 CLOSERS MODEL #
FO-227479	8/29/2012		Carp. Med Priority
FO-227058	8/29/2012	8/30/2012	VENDOR (RAYNOR DOOR) TO REPAIR FIRE ROLL UP DOOR 1ST FLOOR AUDITORIUM
FO-227111	8/29/2012	8/30/2012	contact: Colleen Stone
FO-227116	8/29/2012		I need lock out tag out locks with keys for 9 engineers that don't have them. I put a work order
FO-227481	8/30/2012		R/R RM 1152 REPLACE WATER DAMAGED & STAINED (MOLD) Ceiling tileS DUE TO CLN
FO-227153	8/30/2012		CARPENTERS TO REPLACE LOCK CYLINDER TO ACCEPT 7 PIN BEST IC CORE
FO-227428	8/30/2012	8/30/2012	PLEASE MAKE A PAD LOCK FOR THE PAINTERS AND USE THE MT-9 KEY. Finished 8/31
FO-227433	8/30/2012		CARPENTER REPAIR COAT RACK ROOM #0168
FO-227458	8/30/2012		R/R RM 3028 FUMEHOOD #10 THE SASH WILL NOT OPEN
FO-227491	8/31/2012		PLEASE MAKE TWO PADLOCKS FOR THE PAINTERS MT-9
FO-227512	8/31/2012		Carpenters:
FO-227513	8/31/2012		please mount grinding wheel to table in corner of pipe shop
FO-227518	8/31/2012		R/R 2ND FLR The double doors outside of Room 2375 - The doors are held open by magnets
FO-227524	8/31/2012		project_description: The rubber flooring in the 1st floor West and South coordior's is badly in n
FO-227564	8/31/2012		contact: Sophia Dollar

T - Electrician

145

FO-224413	8/1/2012		Repair or replace RM 2319 broken clock in the hallway outside Lab 2319.
FO-224402	8/1/2012	8/24/2012	1 fixture out, 1 fixture replaced
FO-224403	8/1/2012		1 fixture out, 0 replaced
FO-224404	8/1/2012	8/23/2012	1 fixture out, 0 replaced
FO-224406	8/1/2012	8/20/2012	1 fixture out, 1 replaced
FO-224408	8/1/2012	8/30/2012	1027, 1028, 1039, 1040 dont have right screwdriver to open fixture.
FO-224433	8/1/2012	8/30/2012	light out in 1st floor hallway between rooms 123 & 126. 1 electrical problem Finished 8/31/201
FO-224443	8/1/2012	8/15/2012	Replace florescent lights in rooms 176 and 153
FO-224438	8/1/2012	8/16/2012	1 fixture out
FO-224445	8/1/2012		Move ice melter from 5743 Woodward Custodial crib to 5454 Cass 2nd. floor. 5 barrels.
FO-224463	8/1/2012	8/3/2012	Please pick up wooden pallet from bus duct and throw out. Location loading dock area Karma
FO-224469	8/1/2012	8/9/2012	3 fixtures out,
FO-224470	8/1/2012	8/14/2012	5 fixtures out, 0 replaced
FO-224471	8/1/2012	8/17/2012	1 fixtures out, 0 replaced
FO-224472	8/1/2012	8/23/2012	1 fixtures out, 0 replaced
FO-224477	8/2/2012		Time for Team Leader for month of August 2012.
FO-224478	8/2/2012	8/3/2012	Time for monthly safety meeting Finsished 8/6/2012 LT
FO-224481	8/2/2012	8/6/2012	Please check trouble on fire alarm panel. Finished 8/7/2012
FO-224483	8/2/2012		Light out in presidents office room #4200.
FO-224532	8/2/2012	8/22/2012	ELECTRICIAN
FO-224774	8/2/2012	8/20/2012	R/R Rm 324 - Simplex clock has stopped working. Please fix.Finished 8/21/2012 LT
FO-224530	8/2/2012	8/6/2012	R&R gfci boiler room. Finished 8/7/2012
FO-224531	8/2/2012	8/7/2012	Change batteries in NAC panels. Finished 8/8/2012
FO-224534	8/2/2012	8/2/2012	Install new GFCIs(2) in place of existing plugs next to new sink.
FO-224537	8/2/2012		Disconnect condensate pump in basement mechanical room. Reconnect with twist lock plug...

Total

FO-224539	8/2/2012	8/1/2012	Please look at light in 5420.05, it is the office inside of 5420, teaching hospital. The light flicke
FO-224541	8/2/2012	8/17/2012	Through the backdoor, not the loading dock entrance, hallway has an EP Finished 8/20/2012
FO-224542	8/2/2012	8/6/2012	1) Complete EP repairs on glode and ballast work in the 1st floor office. Finished 8/7/2012
FO-224546	8/2/2012	8/17/2012	Damon Keith Center
FO-224547	8/2/2012	8/16/2012	Damon Keith Center
FO-224548	8/2/2012	8/17/2012	Damon Keith Center
FO-224549	8/2/2012	8/16/2012	Damon Keith Wing
FO-224550	8/2/2012	8/17/2012	Damon Keith Wing
FO-224551	8/2/2012	8/17/2012	Damon Keith Wing
FO-224552	8/2/2012	8/17/2012	Damon Keith Wing
FO-224553	8/2/2012	8/21/2012	1 fixture out
FO-224554	8/2/2012	8/21/2012	1 fixture out
FO-224555	8/2/2012	8/21/2012	1 fixture out
FO-224772	8/3/2012	8/9/2012	Electricians
FO-224792	8/3/2012	8/14/2012	ELECTRICIANS:
FO-224793	8/3/2012	8/30/2012	ELECTRICIANS
FO-224839	8/3/2012	8/21/2012	Inside door leading to dock area - L - E.P outside stairwell 2 on the 1st floor 1-EP. Outside roo
FO-225215	8/5/2012		Fan will not go to high speed
FO-225110	8/6/2012	8/30/2012	2 fixtures out
FO-225123	8/6/2012	8/7/2012	Take bad tire to tire shop to get repaired. Finished 8/8/2012
FO-225141	8/6/2012	8/15/2012	Relocation of Parking blocks in Lot 50 for Contractor so lot can be paved. Finished 8/16/2012
FO-225165	8/6/2012	8/14/2012	1 fixture out, 0 replaced
FO-225159	8/6/2012	8/8/2012	R&R outside light above door, Hancock side of building. See Jim Stoddart. Finished 8/9/2012
FO-225167	8/6/2012	8/20/2012	2 fixture out, 0 replaced
FO-225168	8/6/2012		2 fixture out, 2 replaced
FO-225174	8/6/2012		Ceiling lights out in room #489.
FO-225204	8/7/2012		1 fixture out
FO-225253	8/7/2012	8/8/2012	Electricians:
FO-225232	8/7/2012	8/28/2012	Rm 2336
FO-225233	8/7/2012	8/17/2012	2 fixtures out
FO-225259	8/7/2012		1 fixture out, 1 fixture replaced
FO-225260	8/7/2012	8/8/2012	Time for Lock-out tag-out training class, 7:30a.m. Elena's room 3rd floor. Finished 8/9/2012 L
FO-225263	8/7/2012	8/28/2012	1 fixture out, 1 fixture replaced
FO-225321	8/8/2012	8/14/2012	Electricians
FO-225324	8/8/2012	8/22/2012	electricians
FO-225304	8/8/2012	8/27/2012	2 tagged fixtures are out in rm #448 in Purdy Library on the 4th fl to the right of the elevator. Fi
FO-225308	8/8/2012	8/9/2012	Time for trouble shooting and bench testing fire alarm panel from Prentis building. Finished 8/
FO-225557	8/9/2012		ELECTRICIANS,
FO-225415	8/9/2012	8/28/2012	1 fixture out
FO-225417	8/9/2012	8/21/2012	1 fixture out
FO-225421	8/9/2012	8/21/2012	London Luggage are 2 E.P.s Finished 8/22/2012 LT
FO-225418	8/9/2012	8/27/2012	1 fixture out
FO-225419	8/9/2012	8/24/2012	1 fixture out
FO-225420	8/9/2012	8/24/2012	1 fixture out
FO-225431	8/10/2012	8/15/2012	Time to pick up 20hp motor at Motor shop for Scott Hall job. Finished 8/16/2012 LT
FO-225432	8/10/2012	8/10/2012	Carpenters' are finished with the ceiling tile repairs in the foyer at Art. Please repair and re-inst
FO-225496	8/10/2012		Please take two rubber trash cans up to 4th floor Provost office, water is dripping from ceiling.

Total

FO-225605	8/13/2012	8/28/2012	1 fixture out
FO-225634	8/13/2012	8/14/2012	Please double check compressor motor #3 and inform bldg eng that it is available for use.
FO-225666	8/13/2012		R/R 2ND FLR OUTSIDE OF RMS 2506 & 2513 RE-ATTACH/SECURE FLR OUTLETS- Small
FO-225677	8/13/2012		Several flourescent lamps in room 6364 (Departmental Library/Conference room) is out. plea
FO-225689	8/14/2012	8/16/2012	LABORER TO PICK UP 20 BOXES OF CEILING TILE & 1 BOX OF MAINS & DELIVER TO 1
FO-225691	8/14/2012	8/23/2012	Please pick up blue lift and deliver to loading dock at Applebaum. See Pat for more info.
FO-225715	8/14/2012		R/R CENTRAL ATRIUM Two large overhead lights, above ceiling level, are out in Central Atriu
FO-225726	8/14/2012	8/17/2012	R/R RM 220.02/RESTROOM CHNG SENSOR LITE TO REGULAR LITE SWITCH
FO-225734	8/14/2012	8/16/2012	1 fixture out
FO-225737	8/14/2012	8/30/2012	2 fixture out
FO-225760	8/14/2012	8/17/2012	1 Fixture out, 1 replaced
FO-225771	8/15/2012	8/16/2012	Please check generator for fuel level and if it cranks over. Finished 8/17/2012 LT
FO-225839	8/15/2012		ELECTRICIANS,
FO-225898	8/16/2012	8/22/2012	5 fixtures out, 5 replaced
FO-225900	8/16/2012	8/27/2012	1 fixtures out, 1 replaced
FO-225911	8/16/2012		8 fixtures out
FO-225926	8/16/2012	8/23/2012	Please replace light timer in room 245.1
FO-225955	8/16/2012	8/28/2012	1 fixture out
FO-225956	8/16/2012	8/20/2012	6 fixtures out
FO-225968	8/17/2012	8/20/2012	Please construct scaffold in stairwell at Rackham. See Phil for location. Finished 8/21/2012 LT
FO-226026	8/17/2012		R/R RM 108 Light switch defective. all lights out. need repaired ASAP. This room houses the
FO-226007	8/17/2012		Restroom within Rm 441.4 has 1 bulb out
FO-226009	8/17/2012		Lights out in Education Rm 489
FO-226033	8/17/2012		Electricians
FO-226032	8/17/2012		4 fixtures out, 4 replaced
FO-226038	8/17/2012		CURB APPEAL # 1 ITEM # 315 CHANGE OUT CORRIDOR CEILING & LIGHTS ENTIRE 1S
FO-226250	8/19/2012		ELECTRICIANS:
FO-226240	8/20/2012	8/17/2012	1 fixture out
FO-226279	8/20/2012	8/24/2012	Please replace motor on unit 127-MAU-003. *See Engineer Hutting with any questions.
FO-226321	8/20/2012		Light is out in room 319 (unisex bathroom). There is no option for BLDG-Entire Building, so I p
FO-226473	8/21/2012	8/29/2012	The light in the custodial closet on the 1st floor
FO-226338	8/21/2012	8/22/2012	Please pull gas welder to manoogian... See Jim Hill
FO-226383	8/21/2012		Replace Sealite on DA tank that connects to the float controller. It looks as if someone replac
FO-226451	8/22/2012		Light bulbs need to be replaced.
FO-226447	8/22/2012	8/22/2012	Verify distress and eyewash stations for trouble alert at panel.
FO-226477	8/22/2012		Elect.
FO-226485	8/22/2012	8/28/2012	Check main fuses in clock generators. 3rd floor closets. Replace fuses if needed.
FO-226549	8/22/2012		R/R 1ST FLR The following needs electricins to complete as the lights are too high for lighting
FO-226550	8/23/2012		Election,
FO-226558	8/23/2012		Elect.
FO-226581	8/23/2012		1 fixture out.
FO-226582	8/23/2012		1 fixture out.
FO-226583	8/23/2012		2 fixture out.
FO-226584	8/23/2012		1 fixture out.
FO-226585	8/23/2012		6 fixture out.
FO-226586	8/23/2012	8/30/2012	Open area outside of room 3828 3 - EP'S Finished 8/31/2012 LT
FO-226638	8/23/2012		electrician plese verify operation of ceiling heating unit will not start see engineer

Total

FO-226655	8/24/2012		Electricians:
FO-226667	8/24/2012	8/30/2012	1 fixture out, 1 replaced
FO-226668	8/24/2012	8/30/2012	1 fixture out,
FO-226699	8/24/2012		1 fixture out, 0 replaced
FO-226703	8/24/2012		North end mens restroom field house outside restrooms Electrical problem.
FO-226867	8/27/2012		Electricians:
FO-226893	8/27/2012		Electricians
FO-226964	8/28/2012		5 fixtures out
FO-226966	8/28/2012		2 hallway lights EP
FO-226967	8/28/2012		Basement 1 EP
FO-226996	8/28/2012	8/29/2012	Please fix second light fixture in student assistant's office. Randomly the light flickers, especial
FO-227056	8/29/2012	8/30/2012	fix lighting in room 100 Finished 8/31/2012 LT
FO-227084	8/29/2012		Lights out on 3rd floor room #319
FO-227135	8/30/2012		Light out in 2nd floor study room #2401. Room 2401 has an electrical problem. The whole roo
FO-227138	8/30/2012		Lights blinking in rm #1261
FO-227139	8/30/2012		1 fixture out, 1 replaced
FO-227140	8/30/2012		2 fixtures out
FO-227141	8/30/2012		2 fixtures @ Purdy in rm #463 has electrical problems.
FO-227154	8/30/2012		Electrical problem in RR 319 on 3rds floor of MHCC / 5425
FO-227459	8/30/2012		R/R RM 3028 FUMEHOODS #S' 9 & 11 NEED LITES REPLACED
FO-227475	8/31/2012		pick up material at granger
FO-227487	8/31/2012		2 mercury bulbs in hanging ceiling lights 1st floor
FO-227561	8/31/2012		Electricians, Low pri,
FO-227533	8/31/2012		1 fixture out, 1 replaced
FO-227534	8/31/2012		1 fixture out, 1 replaced
FO-227553	8/31/2012		1 fixture out, 1 replaced
T - Laborer			5
FO-224398	8/1/2012		Time for work done in Trade Shops, cleaning, moving, etc...
FO-226034	8/17/2012	8/20/2012	Time to pick up motor from Spina Electric. Finished 8/21/2012 LT
FO-226059	8/20/2012		Pick up trash cans from 4th floor Provost office
FO-226579	8/23/2012		Time to pick up motors from Spina.
FO-227054	8/29/2012	8/30/2012	LABORER TO DROP OFF 20 ADA CLOSERS FOR SERVICE DROP OFF @ IDN DOOR & H
T - Locksmith			110
FO-224369	8/1/2012	8/6/2012	#73194 1 Key Room 328 Finished 8/7/2012
FO-224370	8/1/2012	8/6/2012	#73193 1 Key Room 302 Finished 8/7/2012
FO-224371	8/1/2012	8/6/2012	#73195 1 Key Room 606 Finished 8/7/2012
FO-224372	8/1/2012	8/8/2012	#73196 3 Keys and 2 Cores Room 345 Finished 8/8/2012
FO-224448	8/1/2012	8/6/2012	#73197 4 Keys Finished 8/7/2012
FO-224449	8/1/2012	8/6/2012	#69183 20 Keys Finished 8/7/2012
FO-224459	8/1/2012	8/6/2012	REQ # 73198 1 KEY ROOM # 3.16 Finished 8/7/2012
FO-224508	8/2/2012	8/8/2012	#72018 10 Keys and 1 Core Room 206 Finished 8/9/2012 LT
FO-224509	8/2/2012	8/8/2012	#72017 2 Cores Room 206 Finished 8/9/2012 LT
FO-224510	8/2/2012	8/8/2012	#72016 15 Keys and 2 Cores Finished 8/9/2012 LT
FO-224515	8/2/2012		#72033 2 Keys File Cabinet
FO-224517	8/2/2012	8/3/2012	#49797 3 Keys Basement Finsished 8/6/2012 LT
FO-224520	8/2/2012	8/8/2012	#72339 13 Keys Finished 8/8/2012
FO-224829	8/3/2012		#68395 10 Keys and 5 Keys Room 2312; 2316; 2316; 2320; 2321; 2324
FO-225202	8/7/2012	8/9/2012	#72015 1 Key Finished 8/10/2012 LT

Total

FO-225231	8/7/2012	8/8/2012	#72428 2 Keys Finished 8/9/2012 LT
FO-225246	8/7/2012	8/8/2012	#72752 1 Key Room B504 Finished 8/9/2012 LT
FO-225272	8/8/2012	8/9/2012	#67057 4 Keys Room 6332 Finished 8/10/2012 LT
FO-225273	8/8/2012	8/8/2012	#69183 20 Keys Room 302 Finished 8/9/2012 LT
FO-225287	8/8/2012		#72890 2 Keys
FO-225306	8/8/2012		#73200 6 Keys and 4 Cores
FO-225363	8/9/2012	8/10/2012	#72743 3 Keys Room 235.11 Finished 8/13/12 LT
FO-225365	8/9/2012	8/10/2012	#72745 3 Keys Room 3129 Finished 8/13/12 LT
FO-225366	8/9/2012	8/10/2012	#72721 3 Keys Room 2127 Finished 8/13/12 LT
FO-225370	8/9/2012	8/10/2012	#72722 3 Keys Room 1410 Finished 8/13/12 LT
FO-225372	8/9/2012	8/10/2012	#72742 3 Keys Room 2404 Finished 8/13/12 LT
FO-225374	8/9/2012	8/10/2012	#72744 3 Keys Finished 8/13/12 LT
FO-225375	8/9/2012	8/10/2012	#72724 3 Keys Room 3556A Finished 8/13/12 LT
FO-225376	8/9/2012	8/10/2012	#72719 10 Keys Room 131 Finished 8/13/12 LT
FO-225377	8/9/2012	8/10/2012	#72720 10 Keys Room 448 Finished 8/13/12 LT
FO-225378	8/9/2012	8/10/2012	#72741 3 Keys Finished 8/13/12 LT
FO-225410	8/9/2012	8/10/2012	REQ # 72723 3 KEYS DOOR # 3546A Finished 8/13/12 LT
FO-225454	8/10/2012	8/15/2012	#70389 1 Key Finished 8/16/2012 LT
FO-225490	8/10/2012	8/24/2012	#67755 3 Keys
FO-225535	8/13/2012	8/15/2012	#72034 10 Keys Room 354 Finished 8/16/2012 LT
FO-225618	8/13/2012	8/22/2012	#73208 6 Keys Room 3226
FO-225620	8/13/2012	8/10/2012	#71564 15 Keys Finished 8/13/12 LT
FO-225640	8/13/2012	8/14/2012	#73210 6 Keys and 3 Cores Finished 8/16/2012 LT
FO-225642	8/13/2012	8/16/2012	#73209 6 Keys and 2 Cores Finished 8/17/2012 LT
FO-225776	8/15/2012	8/20/2012	Request 73212 1 core room 2503 Finished 8/21/2012 LT
FO-225782	8/15/2012	8/20/2012	71298 1-CORE 5-KEYS ROOM 3114.1 Finished 8/21/2012 LT
FO-225783	8/15/2012	8/20/2012	72778 5- KEYS ROOM 3139 Finished 8/21/2012 LT
FO-225784	8/15/2012	8/20/2012	72776 3-KEYS ROOM 3134 Finished 8/21/2012 LT
FO-225787	8/15/2012	8/20/2012	72777 3-KEYS ROOM 3125 Finished 8/21/2012 LT
FO-225788	8/15/2012	8/20/2012	71441 2-KEYS CLASSROOM PODIUMS Finished 8/21/2012 LT
FO-225789	8/15/2012	8/16/2012	71439 2-KEYS ROOM 417/419 Finished 8/17/2012 LT
FO-225792	8/15/2012	8/16/2012	72725 3-KEYS ROOM 3314 Finished 8/17/2012 LT
FO-225796	8/15/2012	8/16/2012	72773 4-KEYS ROOM 054 TO 052 Finished 8/17/2012 LT
FO-225798	8/15/2012	8/16/2012	72774 2-KEYS ROOM 154 Finished 8/17/2012 LT
FO-225799	8/15/2012	8/20/2012	72775 5-KEYS FOUNDRY FRONT DOOR Finished 8/21/2012 LT
FO-225800	8/15/2012	8/20/2012	70668 4-KEYS ROOM 5215 Finished 8/21/2012 LT
FO-225842	8/15/2012	8/16/2012	62336 2-KEYS ROOM 2569 Finished 8/17/2012 LT
FO-225855	8/15/2012	8/22/2012	72962 2-KEYS SM FOR ART & ART EDUCATION
FO-225890	8/16/2012	8/22/2012	#72780 3 Keys Room 263
FO-225891	8/16/2012	8/23/2012	#72779 5 Keys Room 263.1
FO-225906	8/16/2012	8/22/2012	#73218 3 Keys and 2 Cores Room 626
FO-225907	8/16/2012	8/23/2012	#73217 3 Keys and 2 Cores ROOM 622
FO-225910	8/16/2012	8/21/2012	#73216 3 Keys and 2 Cores Room 353 Finished 8/22/2012 LT
FO-225912	8/16/2012	8/22/2012	#73215 3 Keys and 2 Cores ROOM 323
FO-225944	8/16/2012	8/28/2012	#67560 5 Keys
FO-225945	8/16/2012	8/24/2012	#51439 20 Keys
FO-225971	8/17/2012	8/24/2012	#73223 2 Keys and 1 Core room 724.3

Total

FO-225972	8/17/2012	8/22/2012	#73222 6 Keys and 2 Cores Room 546.2
FO-225973	8/17/2012	8/24/2012	#73221 2 Keys and 1 Core Room 408.3
FO-225974	8/17/2012	8/29/2012	#73220 2 Keys and 1 Core room 424.3 Finished 8/31/2012 LT
FO-225975	8/17/2012	8/29/2012	#73219 2 Keys and 1 Core Room 407.3 Finished 8/31/2012 LT
FO-225976	8/17/2012	8/23/2012	#73228 3 Keys Room 212.4
FO-225977	8/17/2012	8/23/2012	#73227 3 Keys and 1 Core Room 244.2
FO-225978	8/17/2012	8/23/2012	#73224 2 Keys and 1 Core Room 246.5
FO-226002	8/17/2012	8/28/2012	#71205 26 Keys
FO-226003	8/17/2012	8/23/2012	#73225 2 Keys Room 911.5
FO-226004	8/17/2012	8/29/2012	#73226 2 Keys Room 610.4 Finished 8/31/2012 LT
FO-226037	8/17/2012	8/22/2012	#73231 1 Keys
FO-226116	8/20/2012	8/29/2012	#72059 1 Key Finished 8/31/2012 LT
FO-226119	8/20/2012	8/29/2012	#72729 1-CORE 4-KEYS Room 3146 Finished 8/31/2012 LT
FO-226120	8/20/2012	8/24/2012	#72726 3 Keys Room 2154
FO-226297	8/21/2012	8/21/2012	#73233 9 Keys and 7 Cores Warrior Grill Finished 8/22/2012 LT
FO-226302	8/21/2012	8/30/2012	#72201 18 Keys Finished 8/31/2012 LT
FO-226303	8/21/2012		#67559 15 Keys Room 305
FO-226304	8/21/2012	8/29/2012	#72718 5 Keys Room 3114 Finished 8/31/2012 LT
FO-226305	8/21/2012	8/27/2012	#73235 5 Keys
FO-226442	8/22/2012		#73237 6 Keys Room 818 and 1126
FO-226443	8/22/2012	8/29/2012	#73236 3 Keys Finished 8/31/2012 LT
FO-226448	8/22/2012		#72432 6 Keys
FO-226449	8/22/2012	8/29/2012	#72457 1 Keys Finished 8/31/2012 LT
FO-226450	8/22/2012		#72796 10 Keys and 2 Cores
FO-226686	8/24/2012		65504 2-KEYS ROOM 6259
FO-226688	8/24/2012		72078 2-KEYS ROOM 39
FO-226691	8/24/2012		69184 10-KEYS
FO-227107	8/24/2012		#72891 1 core 15 keys
FO-226907	8/27/2012		73119 2 CORES 4-KEYS
FO-226951	8/28/2012	8/28/2012	#73100 3 Keys and 2 Cores Room 1365,1369,1371
FO-226952	8/28/2012		#73100 1 Key and 1 Core Room 1505
FO-226953	8/28/2012		#73101 1 Key and 1 Core
FO-226954	8/28/2012		#73102 1 Key and 1 Core
FO-226971	8/28/2012		#73259 36 Keys
FO-227003	8/28/2012		#72888 6 Keys Room 4402.2
FO-227065	8/29/2012		#72751 4 Keys and 2 Cores Room 236 and 215
FO-227066	8/29/2012		#70391 4 Keys 1 Core Room 376
FO-227067	8/29/2012		#70388 6 Keys Room 23552
FO-227090	8/29/2012		#72748 6 Keys Room 9306
FO-227091	8/29/2012		#72889 8 Keys Room 3315.1
FO-227092	8/29/2012		#71941 8 Keys
FO-227093	8/29/2012		#72747 6 Keys Room 2140
FO-227094	8/29/2012		#72749 8 Keys Room 10304 and 10402
FO-227116	8/29/2012		I need lock out tag out locks with keys for 9 engineers that don't have them. I put a work order
FO-227156	8/30/2012		#72709 2 cores
FO-227157	8/30/2012		#67556 5 keys
FO-227159	8/30/2012		#67557 5 keys

Total

FO-227160	8/30/2012		#72750 2 keys for upper cabinet and two lower desk drawers
T - Painter		60	
FO-224405	8/1/2012	8/6/2012	CURB APPEAL-2 PAINT THE THIRD FLOOR HALLWAY. Finished 8/7/2012
FO-224407	8/1/2012	8/20/2012	PAINT THE NORTH-WEST PENTHOUSE WALL. Finished 8/21/2012 LT
FO-224576	8/3/2012	8/3/2012	SAFETY TIME Finsished 8/6/2012 LT
FO-224833	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #189-14EB Finished 8/7/2012
FO-224835	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #189-15EB Finished 8/7/2012
FO-224836	8/3/2012	8/20/2012	Sand/Refinish Exterior Door #189-16EB
FO-224837	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #189-16EB Finished 8/7/2012
FO-224838	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #189-17EB Finished 8/7/2012
FO-224840	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #188-E Finished 8/7/2012
FO-224841	8/3/2012	8/6/2012	Sand/Refinish Exterior Door #188-W Finished 8/7/2012
FO-224860	8/6/2012	8/20/2012	Please paint storage cabinets for Pipe Shop , See John for location Finished 8/21/2012 LT
FO-225154	8/6/2012	8/8/2012	Sand/Refinish Exterior Door #156-01E Finished 8/13/12 LT
FO-225155	8/6/2012	8/7/2012	Sand/Refinish Exterior Door #156-02E Finished 8/8/2012
FO-225156	8/6/2012	8/8/2012	Sand/Refinish Exterior Door #156-03S Finished 8/13/12 LT
FO-225157	8/6/2012	8/7/2012	Sand/Refinish Exterior Door #156-04S Finished 8/8/2012
FO-225160	8/6/2012	8/7/2012	Sand/Refinish Exterior Door #064-E Finished 8/8/2012
FO-225161	8/6/2012	8/7/2012	Sand/Refinish Exterior Door EAST SIDE Finished 8/8/2012
FO-225163	8/6/2012	8/7/2012	Sand/Refinish Exterior Door WEST SIDE Finished 8/8/2012
FO-225178	8/6/2012	8/15/2012	Repaint the Wayne State Logo on Anthony Wayne Drive in front of Ghafari. Use correct paint
FO-225190	8/7/2012		PAINT THE FOURTH FLOOR HALLWAY.
FO-225292	8/8/2012	8/10/2012	Sand/Refinish Exterior Door 001-5S Finished 8/13/12 LT
FO-225293	8/8/2012	8/10/2012	Sand/Refinish Exterior Door 001-6S Finished 8/13/12 LT
FO-225294	8/8/2012	8/9/2012	Sand/Refinish Exterior Door 001-7S Finished 8/13/12 LT
FO-225295	8/8/2012	8/9/2012	Sand/Refinish Exterior Door 001-8S Finished 8/13/12 LT
FO-225428	8/10/2012	8/10/2012	Sand/Refinish Exterior Door 001-21 W Finished 8/13/12 LT
FO-225429	8/10/2012	8/10/2012	Sand/Refinish Exterior Door 001-22 W Finished 8/13/12 LT
FO-225532	8/13/2012	8/21/2012	PAINTERS TO MUD& PAINT DYRWALL PATCH 14TH FLOOR UNISEX RESTROOM
FO-225672	8/13/2012	8/15/2012	Please Paint wall in Pipe Shop before shelving is mounted Finished 8/16/12
FO-225679	8/13/2012	8/16/2012	PAINT THE LADIES ROOM ON THE FOURTH FLOOR. Finished 8/17/2012 LT
FO-225680	8/13/2012	8/16/2012	PAINT THE MEN'S ROOM ON THE FOURTH FLOOR. Finished 8/17/2012 LT
FO-225681	8/13/2012	8/21/2012	REPAIR THE PLASTER ON THE NORTH WALL IN THE BASEMENT GOING TO THE MEN'
FO-227483	8/16/2012		contact: David Wissbrun
FO-225989	8/17/2012		HANDYMAN TIME
FO-225990	8/17/2012		MTL TIME
FO-225991	8/17/2012	8/20/2012	PAINT THE WOMEN'S ROOM ON THE THIRD FLOOR. Finished 8/21/2012 LT
FO-225993	8/17/2012	8/20/2012	PAINT THE MEN'S ROOM ON THE THIRD FLOOR. Finished 8/21/2012 LT
FO-226030	8/17/2012		R/R RM 0245/DLAR requesting that a hair line crack in the wall be repaired, no evidence of w
FO-226601	8/17/2012		We would like to request that the parking attendant booth be painted at lot 22.
FO-226273	8/17/2012		Paint the south west wall to the penthouse.
FO-226061	8/20/2012	8/22/2012	REPAIR THE WALL BY THE UNI-SEX RESTROOM AND PAINT TO MATCH.
FO-226062	8/20/2012		TOUCH UP AS NEEDED DUE TO PLASTER REPAIRS. SECOND FLOOR LOUNGE.
FO-226271	8/20/2012	8/20/2012	Remove the graffiti off the trash can on the exterior of the building. Finished 8/21/2012 LT
FO-226299	8/21/2012		CURB APPEAL-2: TOUCH UP ALL WALLS ALL FLOORS AND ELEVATOR SURROUNDS.
FO-226307	8/21/2012	8/23/2012	R/R RM 138/SVC CTR & RM 150 ENGINEER SUPERVISORS' OFC NEED 2 BOXES OF PA
FO-226324	8/21/2012	8/23/2012	R/R RM 1177 FIRE EXTINGUISHER PIN HAS BEEN PULLED OUT

Total

FO-226933	8/22/2012		TOUCH UP FLACKING CEILING TILE IN ROOM 010
FO-226535	8/22/2012	8/22/2012	PAINT THE PLASTER REPAIRS IN THE BASEMENT NEAR THE MEN'S ROOM.
FO-226623	8/23/2012		Painter/ plaster repair blister on south wall of office.
FO-226555	8/23/2012		Ceiling and duct need painting.
FO-226580	8/23/2012	8/24/2012	South entrance/east side. Install railing extension to prevent access to open area/fall hazard. ,
FO-227509	8/24/2012		To cover the cost for Maintenance Painter for (30) new chairs were purchased for FAB confer
FO-226962	8/28/2012		Painter; High
FO-226990	8/28/2012		Carpenters,
FO-227045	8/29/2012		DROP OFF 5 - 10 # ABC F/E'S TO LEO FOR F/E TRAINING AT U.G.L. CUSTOMER TO REI
FO-227083	8/29/2012		R/R NEED TO PICK UP/FILL 3 FIRE EXTINGUISHER (THEY ARE IN THE GARAGE FOR A
FO-227085	8/29/2012		GRAFFITTI-POL REP #W122420039
FO-227424	8/30/2012	8/30/2012	PAINT OVER GRAFFITI ON OUR BUILDING 75 WEST FERRY AND THE FRONT OVERHA
FO-227425	8/30/2012	8/30/2012	PAINT THE DOOR SOUTH-EAST OF THE ELEVATOR ON THE FOURTH FLOOR. Finished
FO-227445	8/30/2012		PAINT EMERGENCY PUSH BUTTON COVER BOXES SAFETY RED.
FO-227482	8/31/2012		R/R RM 1152 PAINT WATER DAMAGED/PEELING WALL & STAINED WALLS DUE TO CLN
T - Pipefitter		41	
FO-224482	8/1/2012		Please Assist in pump evaluation for energy savings project ,,,,,,,,,, JH/RC 8-1-12 ,,,,,,,,,,
FO-224452	8/1/2012	8/3/2012	FITTERS,
FO-224435	8/1/2012	8/1/2012	Replace boiler chemical feed pump in boiler room upstairs at university services bldg Room 3
FO-224474	8/2/2012		R/R LMI pumps for open loop system ,,,,,,,,,, JH/RC 8-1-12 ,,,,,,,,,,
FO-224528	8/2/2012		Install isolation valve on heating loop so circulation pump can be worked on without draining th
FO-224800	8/3/2012	8/7/2012	Remove/Repair leaking HHW pipe in communications room (Basement of Schaver Music Bldg
FO-225139	8/6/2012	8/7/2012	Add Drain lines to #1,#6,#8,#9 fan units ,,,,,,,,,, CB/8-6-12 ,,,,,,,,,, Finished 8/8/2012
FO-225189	8/7/2012	8/9/2012	R/R leaking glange on 4" steam line on 1st floor mech. Room ,,,,,,,,,, ME/EA 8-9-12 ,,,,,,,,,,
FO-225262	8/7/2012		PIPEFITTER: R/R RM 0195/MECH-BOILER RM please replace leaking blow downvalve on w
FO-225356	8/8/2012	8/8/2012	Lock Out / Tag Out Training ,,,,,,,,,, ME/EA / 8-8-12 ,,,,,,,,,, Finished 8/9/2012 LT
FO-225319	8/8/2012	8/15/2012	FITTERS,
FO-225320	8/8/2012	8/15/2012	FITTERS
FO-225361	8/9/2012		FITTERS,
FO-225393	8/9/2012	8/17/2012	Fitters, install new 3/8" control air line from SCU-3 to SCU-4. See engineer. Priority low. ,,,,,,,,,,
FO-225397	8/9/2012	8/14/2012	Install drain lines for chilled water supply and return lines. Also install drain lines for vents in b
FO-225480	8/10/2012	8/10/2012	Replace broken drain pipe for fire pump.
FO-225522	8/11/2012		R/R recieving tub for Pool in basement mechanical room ,,,,,,,,,, JH/RC 8-12-12 ,,,,,,,,,,
FO-225645	8/13/2012		15' of 1 1/4" x 1 fiberglass insulation ,,,,,,,,,, ME/EA 8-14-12 ,,,,,,,,,,
FO-225646	8/13/2012		6' of 4" x 2" fiberglass insulation ,,,,,,,,,, ME/EA 8-14-12 ,,,,,,,,,,
FO-225803	8/15/2012		Suction and discharge valves need replaced, they leak thru ,,,,,,,,,, JH/RC 8-15-12 ,,,,,,,,,,
FO-225878	8/15/2012		FITTERS,
FO-226266	8/20/2012		Please check pitch on condensate header in sub basement /also install condensate air vents ,,,
FO-226340	8/21/2012	8/23/2012	Please replace trap on coil #160.2 Plenum #2 ,,,,,,,,,, JH/RC 8-22-12 ,,,,,,,,,,
FO-226344	8/21/2012	8/23/2012	Please repair coil leak coil #66.2 Plenum #1 ,,,,,,,,,, ME/EA 8-22-12 ,,,,,,,,,,
FO-226345	8/21/2012	8/23/2012	Please repair coil leak. Coil #39.2 Plenum #1 ,,,,,,,,,, ME/EA 8-22-12 ,,,,,,,,,,
FO-226347	8/21/2012	8/29/2012	Please repair coil leak. Coil #103.2 Plenum #2 ,,,,,,,,,, ME/EA 8-22-12 ,,,,,,,,,, Finished 8/
FO-226348	8/21/2012	8/30/2012	Please repair coil leak coil #2003/167.2 Plenum #2 ,,,,,,,,,, ME/EA 8-22-12 ,,,,,,,,,, Finished
FO-226354	8/21/2012		Install auto balancing valve on open loop chill watersystem ,,,,,,,,,, CB/8-22-12 ,,,,,,,,,,
FO-226446	8/22/2012		PIPEFITTER: R/R RM 410/MECH RM Condensate receiver pump that was just repaired is ag
FO-226651	8/24/2012		Pipe fitters
FO-226882	8/24/2012		Pipefitters: Repair/Replace leaking Powers hot water control valve on #3 wall unit. Priority:low

Total

FO-226901	8/27/2012	8/30/2012	R/R condensate pump #1 basement mechanical room ,,,,,,,,,, JH/RC 8-27-12 ,,,,,,,,,, Finish
FO-226992	8/28/2012		Please R/R coils #2.1 and 60.2 in sub basement #1 ,,,,,,,,,, JH/RC 8-28-12 ,,,,,,,,,,
FO-227470	8/29/2012	8/30/2012	Harness training. Finished 8/31/2012 LT
FO-227427	8/30/2012		Fitters:
FO-227437	8/30/2012		Replace bad gate valve (3/4) in plenum #2 feeding room 302.2
FO-227438	8/30/2012	8/30/2012	Repair coil leak in Plenum #2 (105.1) Finished 8/31/2012 LT
FO-227439	8/30/2012		Replace leaking gate valve (1) in plenum #2 near coil 105.1
FO-227441	8/30/2012		Repair coil leak in plenum #2 (coil 109)
FO-227486	8/31/2012		Install 2" spence valve in bypass line to DA Tank
FO-227490	8/31/2012		R&R coil #178.2 in sub basement plenum #2.....JH and RC....8-31-12
T - Plumber			48
FO-224365	8/1/2012	8/24/2012	Women Restroom 1st floor main corridor area beyond the 2nd set of doors: 1st stall as the se
FO-224367	8/1/2012		Women (Basement Restroom/Locker/Shower Room Area):
FO-224379	8/1/2012		Please repair drinking fountain in the hallway by room 2212, no water is dispensed when you
FO-224395	8/1/2012	8/15/2012	Please locate, test, inspect, and repair water backflow devices in building. Complete testing a
FO-224397	8/1/2012		Please locate, test, inspect, and repair water backflow devices in building. Complete testing a
FO-224399	8/1/2012		Please locate, test, inspect, and repair water backflow devices in building. Complete testing a
FO-224401	8/1/2012		Please locate, test, inspect, and repair water backflow devices in building. Complete testing a
FO-224570	8/2/2012	8/2/2012	Safety Meeting ,,,,,,,,,, MP/8-2-12 ,,,,,,,,,, Finished 8/3/2012
FO-224538	8/2/2012		R/R 1ST FLR WOMENS RM NEAR STE 1300 (APEX) 3RD STALL TOILET IS LEAKING @ B
FO-224854	8/4/2012		Team Leader Administrative Time
FO-225125	8/6/2012		Plumber please install drain lines to main drain for catch basens in ceiling above rooms 252 &
FO-225164	8/6/2012	8/28/2012	Men's toilet room 109 zurn auto faucet, does not work.,,,,,,,,,,MP 8-7-12 ,,,,,,,,,,
FO-225277	8/8/2012	8/30/2012	Clear and unplug floor drain in penthouse mechanical room. ,,,,,,,,,, RC/MM 8-9-12 ,,,,,,,,,,
FO-225519	8/9/2012	8/9/2012	Shop Time Finished 8/13/12 LT
FO-225384	8/9/2012		WOMEN'S RESTROOM 176 - SHOWERS ARE LEAKING AND SOME SHOWER HANDLES
FO-225464	8/10/2012	8/11/2012	Please check running toilet 2ed floor mens room ,,,,,,,,,, DP 8-10-12 ,,,,,,,,,, Finished 8/13/
FO-225523	8/11/2012		Please install Hydration Station 4th floor ,,,,,,,,,, MP/8-12-12 ,,,,,,,,,,
FO-225531	8/13/2012	8/17/2012	R/R RM 19/BSMT MENS RM ONLY TOILET IS BAGGED (TOILET CLOGGED/ALREADY PL
FO-225630	8/13/2012		Please repair or replace leaking union on a hot water heating pipe. See Rocky for location.
FO-225756	8/14/2012	8/17/2012	R/R RM 450/Men's room 4th floor, repair/replace flushing handle to urinal - urinal won't flush --
FO-225809	8/15/2012		R/R LOBBY Double water fountain on the north side of the main lobby is not draining. Same w
FO-225812	8/15/2012	8/16/2012	Water fountain on the south side shoots water beyond the basin of the fountain.Referred to Plu
FO-225847	8/15/2012		R/R A sinkhole has developed adjacent to DWSD Vault, between Law Library and Damon Ke
FO-225965	8/16/2012	8/20/2012	Basement women restroom rm. 331: Broken toilet seat (custodian has placed a bag over com
FO-226399	8/17/2012	8/30/2012	Two floor drains plugged -
FO-226400	8/17/2012	8/30/2012	Floor Drain plugged lower level near the east Parking Attendant Booth. See Parking Supervis
FO-226011	8/17/2012		INSTALL 3 NEW WATER FOUNTAINS WITH FILTERS. SEE NATHAN FOR LOCATIONS A
FO-226243	8/20/2012		Please install two gauges. One on inlet side of booster pumps and one on outlet side of boost
FO-226247	8/20/2012	8/21/2012	R/R WOMENS RM/BUS SVCS' SIDE BOTH TOILETS AREN'T FLUSHING 1ST STALL OVE
FO-226290	8/20/2012	8/27/2012	R/R RM 2345/MENS RM ONLY URINAL HAS A BAG OVER IT ,,,,,,,,,, MP/8-21-12 ,,,,,,,,,,
FO-226336	8/21/2012		Eluauate hot water on- Demand heater install ,,,,,,,,,, MP/8-22-12 ,,,,,,,,,,
FO-226394	8/21/2012	8/22/2012	R/R GRNDS DEPT AREA IN THE FOUNDRY THE UNISEX BATH RM TOILET IS STOPPED
FO-226444	8/22/2012		Plumber:
FO-226548	8/22/2012	8/27/2012	R/R BSMT Studio Theatre (basement) Mens Rest room.
FO-226607	8/23/2012		R/R RM 2139 Unisex Restroom - The only sink in the restroom
FO-226624	8/23/2012	8/29/2012	plumbers please check men restroom no heat water location shipping dept ,,,,,,,,,, RC/M

Total

FO-226625	8/23/2012	8/29/2012	plumber please check suvp office restroom no heat water see engineer for location
FO-226890	8/27/2012		R/R BSMT PLS INSTALL COVERS/SCREEN/GRATES OVER FLR DRAINS TO HELP ILLIMI
FO-226892	8/27/2012		R/R 1ST FLR PLS INSTALL COVERS/SCREEN/GRATES OVER FLR DRAINS TO HELP ILL
FO-227471	8/29/2012	8/29/2012	Trades negotiations meeting on 8/29/2012
FO-227473	8/29/2012	8/30/2012	Shop time Finished 8/31/2012 LT
FO-227449	8/30/2012		Plumber
FO-227450	8/30/2012		plumber
FO-227435	8/30/2012		Please install supports and escosions on water pipe for 5th floor mens urinals- west end
FO-227454	8/30/2012		R/R 3RD FLR WOMENS RM (ONLY) 1ST STALL TOILET FLUSH HANDLE LKNG
FO-227495	8/31/2012		check all roof drains for obstructions and or slow drainage....RC/MM....8-31-12
FO-227497	8/31/2012		check all roof drains for obstructions and slow draining.....RC/MM,,,,,8-31-12
FO-227511	8/31/2012		womens sink in bathroom has a motion sensor which is no longer working,,,,,,,,,,,,,MP.....8-3

T - Sheetmetal**7**

FO-224412	8/1/2012		SHEETMETAL: R/R RM 2335 Please insulate A/C duct work in room 2335, it is dripping cond
FO-224496	8/2/2012		ROOFER: 2ND FLR INVESTIGATION AREA/by elev tar like substance lkg from clng-pipe is h
FO-225555	8/9/2012		Roofer
FO-225556	8/9/2012		Roofers:
FO-225664	8/13/2012		Sheetmetals:
FO-225755	8/14/2012		R/R CK ROOF ABOVE Room 204 shows that there is a leak in the attic. Went upstairs and co
FO-225859	8/15/2012		Roofer:

Routine**30****T - Electrician****28**

FO-224950	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12 Finished 8/13/12 LT
FO-224951	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12 Finished 8/13/12 LT
FO-224952	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12 Finished 8/13/12 LT
FO-224953	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12
FO-224954	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12
FO-224955	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12 Finished 8/13/12 LT
FO-224956	8/6/2012	8/10/2012	ROUTINE CHECK 8/6 THRU 8/10/12
FO-225443	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225444	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225445	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225447	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225448	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225449	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-225450	8/10/2012	8/17/2012	ROUTINE CHECK 8/13/ THRU 8/17/12 Finished 8/20/2012 LT
FO-226123	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226124	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226125	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226126	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226127	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226129	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226130	8/20/2012	8/24/2012	ROUTINE CHECK 8/20 THRU 8/24
FO-226736	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
FO-226737	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
FO-226738	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
FO-226739	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
FO-226741	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT

Total			
FO-226743	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
FO-226772	8/27/2012	8/30/2012	ROUTINE CHECK 8/27 THRU 8/31/12 Finished 8/31/2012 LT
T - Plumber		2	
FO-225116	8/6/2012		Fix leaking hose bib on the west end of the north (front) of Hillberry theatre. When in use a lar
FO-227519	8/31/2012		Ladies Restroom, left sink is dripping continuously.

Scheduled Maint. (PM)

437

Engineering

410

High

25

E - Afternoon Engineer

2

FO-224884	8/13/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224885	8/13/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - Area 1 Engineer

11

FO-224220	8/3/2012		Generator Test
FO-224935	8/7/2012	8/16/2012	PM Generator
FO-224208	8/9/2012		Generator Maintenance
FO-224219	8/9/2012		Generator Test
FO-224225	8/9/2012		Generator Maintenance
FO-224215	8/10/2012		Generator Test
FO-224216	8/10/2012		Generator Test
FO-224209	8/21/2012		Generator Test
FO-224210	8/21/2012		Generator Maintenance
FO-224222	8/24/2012		Generator Test
FO-224226	8/24/2012		Generator Test

E - Area 2 Engineer

4

FO-224223	8/3/2012		Generator Test
FO-224221	8/16/2012		Generator Test
FO-224217	8/21/2012		Generator Test
FO-224207	8/22/2012		Generator Test

E - Area 3 Auxiliary Eng

8

FO-224213	8/8/2012		Generator Test
FO-224214	8/14/2012		Generator Test
FO-224218	8/15/2012		Generator Test
FO-224212	8/28/2012	8/28/2012	Generator Maintenance
FO-224230	8/28/2012		Generator Test
FO-224231	8/28/2012		Generator Test
FO-224232	8/28/2012		Generator Test
FO-224234	8/28/2012		Generator Test

Medium

3

E - Area 2 Engineer

1

FO-225593	8/21/2012	8/9/2012	PM - Harmsco Side Stream Filter
-----------	-----------	----------	---------------------------------

E - Controls Engineer

2

FO-226744	8/27/2012		State Boiler Inspection
FO-226745	8/27/2012		State Boiler Inspection

Low

71

E - Afternoon Engineer

18

FO-224667	8/1/2012	8/17/2012	PM - Fire Alarm System Test
FO-224756	8/1/2012	9/1/2012	PM - Fire Alarm System Test

Total

FO-224763	8/1/2012	8/17/2012	PM - Fire Alarm System Test
FO-224764	8/1/2012	8/17/2012	PM - Fire Alarm System Test
FO-225066	8/6/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225071	8/6/2012	8/27/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225094	8/6/2012		PM - Air Handling Unit, HV Type
FO-225075	8/10/2012		PM - Air Handling Unit, over 50 Ton
FO-225076	8/10/2012	8/31/2012	PM - Air Handling Unit, over 50 Ton
FO-225065	8/13/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225073	8/13/2012	8/27/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225095	8/13/2012		PM - Air Handling Unit, HV Type
FO-225077	8/17/2012	8/28/2012	PM - Fire Pump, Main/Jockey
FO-225064	8/20/2012	8/28/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225074	8/20/2012	8/27/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225096	8/20/2012		PM - Air Handling Unit, HV Type
FO-225590	8/27/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225591	8/27/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - Area 1 Engineer**20**

FO-224917	8/6/2012	8/9/2012	PM - Sump Pump
FO-224919	8/6/2012	8/9/2012	PM - Sump Pump
FO-224920	8/6/2012	8/9/2012	PM - Sump Pump
FO-224921	8/6/2012	8/10/2012	PM - Sump Pump
FO-224922	8/6/2012	8/10/2012	PM - Sump Pump
FO-224923	8/6/2012	8/10/2012	PM - Sump Pump
FO-224936	8/6/2012	8/8/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224937	8/6/2012	8/8/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224938	8/6/2012	8/8/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224941	8/6/2012	8/8/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224942	8/6/2012	8/8/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224943	8/6/2012	8/7/2012	PM - Sump Pump
FO-224944	8/6/2012	8/7/2012	PM - Sump Pump
FO-224945	8/6/2012	8/7/2012	PM - Sump Pump
FO-224946	8/6/2012	8/7/2012	PM - Sump Pump
FO-224915	8/15/2012		PM - Domestic Water Heater, Electric
FO-224916	8/15/2012		PM - Domestic Water Heater, Electric
FO-224929	8/15/2012		PM - Domestic Water Heater, Electric
FO-224930	8/15/2012		PM - Domestic Water Heater, Electric
FO-224211	8/21/2012		Generator Maintenance

E - Area 2 Engineer**21**

FO-224697	8/1/2012		PM - Sump Pump
FO-224745	8/1/2012		PM - Sump Pump
FO-224750	8/1/2012		PM - Sump Pump
FO-224751	8/1/2012		PM - Sump Pump
FO-224752	8/1/2012		PM - Sump Pump
FO-224753	8/1/2012		PM - Sump Pump
FO-225082	8/4/2012	8/7/2012	PM - Harmsco Side Stream Filter
FO-225083	8/4/2012	8/7/2012	PM - Harmsco Side Stream Filter
FO-225084	8/5/2012		PM - Unspecified
FO-225072	8/15/2012		PM - Outside/Fresh Air Intake Screens

Total

FO-225078	8/15/2012		PM - Chemical Feed/Metering Pump/Controller
FO-225079	8/15/2012		PM - Chemical Feed/Metering Pump/Controller
FO-225080	8/15/2012		PM - Chemical Feed/Metering Pump/Controller
FO-225081	8/15/2012		PM - Chemical Feed/Metering Pump/Controller
FO-225060	8/16/2012		PM - Domestic Water Heater, Electric
FO-225592	8/21/2012	7/25/2012	PM - Harmsco Side Stream Filter
FO-225594	8/21/2012	8/15/2012	PM - Harmsco Side Stream Filter
FO-225595	8/21/2012	8/15/2012	PM - Harmsco Side Stream Filter
FO-225596	8/21/2012	8/15/2012	PM - Harmsco Side Stream Filter
FO-225588	8/23/2012		PM - Domestic Water Heater, Electric
FO-226187	8/28/2012		PM - Domestic Water Heater, Electric
E - Area 3 Auxiliary Eng			5
FO-225092	8/6/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225093	8/6/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225090	8/13/2012	8/23/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225091	8/13/2012	8/20/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225089	8/20/2012	8/27/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - Controls Engineer			6
FO-225391	8/9/2012		Boiler - Open Clean and Close 60 inch Boilers
FO-224934	8/10/2012		Boiler - Open Clean and Close 60 inch Boilers
FO-226563	8/23/2012		Boiler - Open Clean and Close 60 inch Boilers
FO-226564	8/23/2012		Boiler - Open Clean and Close 60 inch Boilers
FO-226565	8/23/2012		Boiler - Open Clean and Close 60 inch Boilers
FO-226833	8/27/2012		Boiler - Open Clean and Close 78 inch Boilers
E - Director			1
FO-224767	8/1/2012		Vendor or Contractor Work
Routine			311
E - Afternoon Engineer			231
FO-224599	8/1/2012	8/28/2012	PM - Unit/Space Heater
FO-224600	8/1/2012	9/1/2012	PM - Unit/Space Heater
FO-224601	8/1/2012	9/1/2012	PM - Unit/Space Heater
FO-224602	8/1/2012	9/1/2012	PM - Unit/Space Heater
FO-224603	8/1/2012	9/1/2012	PM - Unit/Space Heater
FO-224604	8/1/2012	8/28/2012	PM - Unit/Space Heater
FO-224605	8/1/2012	8/28/2012	PM - Unit/Space Heater
FO-224606	8/1/2012	8/28/2012	PM - Unit/Space Heater
FO-224607	8/1/2012	8/28/2012	PM - Unit/Space Heater
FO-224608	8/1/2012	9/1/2012	PM - Unit/Space Heater
FO-224617	8/1/2012	8/9/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224618	8/1/2012	8/11/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224619	8/1/2012	8/11/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224668	8/1/2012	8/21/2012	PM - Air Handling Unit, over 50 Ton
FO-224669	8/1/2012	8/21/2012	PM - Air Handling Unit, over 50 Ton
FO-224676	8/1/2012	8/24/2012	PM - Air Handling Unit, over 50 Ton
FO-224677	8/1/2012	8/24/2012	PM - Air Handling Unit, over 50 Ton
FO-224678	8/1/2012	8/24/2012	PM - Air Handling Unit, over 50 Ton
FO-224679	8/1/2012	8/18/2012	PM - Air Handling Unit, over 50 Ton
FO-224680	8/1/2012	8/20/2012	PM - Air Handling Unit, over 50 Ton

Total

FO-224681	8/1/2012	8/24/2012	PM - Air Handling Unit, over 50 Ton
FO-224682	8/1/2012	8/20/2012	PM - Air Handling Unit, over 50 Ton
FO-224683	8/1/2012	8/16/2012	PM - Air Handling Unit, over 50 Ton
FO-224684	8/1/2012	8/22/2012	PM - Air Handling Unit, over 50 Ton
FO-224685	8/1/2012	8/20/2012	PM - Air Handling Unit, over 50 Ton
FO-224686	8/1/2012	8/21/2012	PM - Air Handling Unit, over 50 Ton
FO-224687	8/1/2012	8/22/2012	PM - Air Handling Unit, over 50 Ton
FO-224714	8/1/2012	8/24/2012	PM - Air Handling Unit, HV Type
FO-224719	8/1/2012	8/22/2012	PM - Air Handling Unit, over 50 Ton
FO-224720	8/1/2012	8/22/2012	PM - Air Handling Unit, over 50 Ton
FO-224721	8/1/2012	8/22/2012	PM - Air Handling Unit, over 50 Ton
FO-224722	8/1/2012	8/28/2012	PM - Air Handling Unit, HV Type
FO-222242	8/2/2012	7/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222243	8/2/2012	7/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222244	8/2/2012	7/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222245	8/2/2012	7/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224758	8/2/2012	8/14/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224620	8/3/2012	8/9/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224621	8/3/2012	8/9/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224622	8/3/2012	8/9/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224623	8/3/2012	8/9/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224759	8/3/2012	8/14/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224887	8/4/2012	8/21/2012	PM - Air Handling Unit, over 50 Ton
FO-224939	8/4/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224779	8/6/2012	8/18/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224780	8/6/2012	8/18/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224781	8/6/2012	8/18/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224782	8/6/2012	8/18/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224783	8/6/2012	8/18/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224996	8/6/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-225010	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225011	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225012	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225013	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225014	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225015	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225016	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225017	8/6/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225018	8/6/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-224896	8/7/2012	8/22/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224897	8/7/2012	8/22/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224898	8/7/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224899	8/7/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224940	8/7/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224966	8/7/2012	8/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224968	8/7/2012	8/24/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224975	8/7/2012	8/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Total

FO-224985	8/7/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224986	8/7/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224999	8/7/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225000	8/7/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225001	8/7/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225002	8/7/2012	8/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225003	8/8/2012	8/25/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225045	8/8/2012		PM - Fire Pump, Main/Jockey
FO-225046	8/8/2012		PM - Fire Pump, Main/Jockey
FO-225058	8/8/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-224875	8/9/2012	8/30/2012	PM - Air Handling Unit, over 50 Ton
FO-224876	8/9/2012	8/30/2012	PM - Air Handling Unit, over 50 Ton
FO-224877	8/9/2012	8/30/2012	PM - Air Handling Unit, over 50 Ton
FO-224878	8/9/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-224879	8/9/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-224880	8/9/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-224883	8/9/2012	8/14/2012	PM - Air Handling Unit, HV Type
FO-224886	8/9/2012	8/17/2012	PM - Air Handling Unit, HV Type
FO-224892	8/9/2012	8/13/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224893	8/9/2012	8/14/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224894	8/9/2012	8/14/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224895	8/9/2012	8/14/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224908	8/9/2012	8/9/2012	PM - Air Handling Unit, HV Type
FO-224909	8/9/2012	8/21/2012	PM - Air Handling Unit, HV Type
FO-224912	8/9/2012	8/22/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224931	8/9/2012	8/22/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224932	8/9/2012	8/23/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224933	8/9/2012	8/24/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224958	8/9/2012	9/1/2012	PM - Air Handling Unit, over 50 Ton
FO-224959	8/9/2012		PM - Air Handling Unit, over 50 Ton
FO-224960	8/9/2012	9/1/2012	PM - Air Handling Unit, over 50 Ton
FO-224981	8/9/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-224900	8/10/2012	8/22/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224901	8/10/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224902	8/10/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224903	8/10/2012	8/17/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224962	8/10/2012		PM - Air Handling Unit, HV Type
FO-224963	8/10/2012		PM - Air Handling Unit, HV Type
FO-224910	8/11/2012	8/28/2012	PM - Air Handling Unit, over 50 Ton
FO-224964	8/11/2012		PM - Air Handling Unit, over 50 Ton
FO-224965	8/11/2012		PM - Air Handling Unit, over 50 Ton
FO-225019	8/13/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-225026	8/13/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225027	8/13/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225028	8/13/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225029	8/13/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225030	8/13/2012	8/29/2012	PM - Fan Coil/HV/AC Unit

Total

FO-225031	8/13/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225032	8/13/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225033	8/13/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225034	8/13/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225035	8/13/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-224904	8/14/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224905	8/14/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224906	8/14/2012	8/21/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224967	8/14/2012	8/29/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224969	8/14/2012	8/30/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224997	8/14/2012		PM - Fire Pump, Main/Jockey
FO-224998	8/14/2012		PM - Fire Pump, Main/Jockey
FO-225038	8/14/2012	8/28/2012	PM - Fan Coil/HV/AC Unit
FO-225039	8/14/2012		PM - Fan Coil/HV/AC Unit
FO-225040	8/14/2012		PM - Fan Coil/HV/AC Unit
FO-224976	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224977	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224978	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224984	8/15/2012	8/30/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224987	8/15/2012	8/30/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224988	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224989	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224990	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224991	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-224992	8/15/2012	9/1/2012	PM - Unit/Space Heater
FO-225053	8/15/2012	8/30/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225054	8/15/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225055	8/15/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225056	8/15/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225057	8/15/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224888	8/16/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224889	8/16/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224890	8/16/2012	8/16/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224891	8/16/2012	8/16/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225061	8/16/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-225062	8/17/2012	9/1/2012	PM - Air Handling Unit, over 50 Ton
FO-225063	8/17/2012	9/1/2012	PM - Air Handling Unit, over 50 Ton
FO-224911	8/18/2012	8/28/2012	PM - Air Handling Unit, over 50 Ton
FO-224918	8/18/2012		PM - Air Handling Unit, over 50 Ton
FO-224924	8/18/2012		PM - Air Handling Unit, over 50 Ton
FO-224925	8/18/2012		PM - Air Handling Unit, over 50 Ton
FO-225004	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225005	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225006	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225007	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225008	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225009	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit

Total

FO-225020	8/20/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-225021	8/20/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-225022	8/20/2012	9/1/2012	PM - Fan Coil/HV/AC Unit
FO-225023	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225024	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225025	8/20/2012	8/29/2012	PM - Fan Coil/HV/AC Unit
FO-225562	8/21/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225580	8/21/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225581	8/21/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225583	8/21/2012		PM - Fan Coil/HV/AC Unit
FO-225584	8/21/2012		PM - Fan Coil/HV/AC Unit
FO-225585	8/21/2012		PM - Fan Coil/HV/AC Unit
FO-225563	8/22/2012	9/1/2012	PM - Air Handling Unit, over 50 Ton
FO-225539	8/23/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225540	8/23/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225541	8/23/2012	8/15/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225561	8/23/2012		PM - Fire Pump, Main/Jockey
FO-225538	8/25/2012		PM - Air Handling Unit, over 50 Ton
FO-225544	8/25/2012		PM - Air Handling Unit, over 50 Ton
FO-225545	8/25/2012	8/29/2012	PM - Air Handling Unit, over 50 Ton
FO-225546	8/25/2012		PM - Air Handling Unit, over 50 Ton
FO-225547	8/25/2012		PM - Air Handling Unit, over 50 Ton
FO-225548	8/25/2012		PM - Air Handling Unit, over 50 Ton
FO-225537	8/26/2012	8/16/2012	PM - Air Handling Unit, over 50 Ton
FO-225549	8/27/2012		PM - Air Handling Unit, HV Type
FO-225550	8/27/2012		PM - Air Handling Unit, HV Type
FO-225551	8/27/2012		PM - Air Handling Unit, HV Type
FO-225567	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225568	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225569	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225570	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225571	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225572	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225573	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225574	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225575	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225576	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225577	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225578	8/27/2012		PM - Fan Coil/HV/AC Unit
FO-225582	8/27/2012		PM - Air Handling Unit, over 50 Ton
FO-226070	8/28/2012		PM - Fire Pump, Main/Jockey
FO-226076	8/28/2012		PM - Air Handling Unit, over 50 Ton
FO-226077	8/28/2012		PM - Air Handling Unit, over 50 Ton
FO-226134	8/28/2012	8/31/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226135	8/28/2012	8/31/2012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226136	8/28/2012		PM - Fan Coil/HV/AC Unit
FO-226150	8/28/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Total

FO-226152	8/28/2012		PM - Fan Coil/HV/AC Unit
FO-226153	8/28/2012	8/30/2012	PM - Fan Coil/HV/AC Unit
FO-226154	8/28/2012	8/30/2012	PM - Fan Coil/HV/AC Unit
FO-226178	8/28/2012	8/31/2012	PM - Air Handling Unit, over 50 Ton
FO-226185	8/28/2012		PM - Air Handling Unit, over 50 Ton
FO-226186	8/28/2012		PM - Air Handling Unit, over 50 Ton
FO-226191	8/28/2012		Monthly Fire System Test
FO-226131	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226155	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226156	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226157	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226158	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226159	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226174	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226175	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226176	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226177	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226179	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226180	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226181	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226182	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226183	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226184	8/31/2012		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - Area 1 Engineer**14**

FO-224582	8/2/2012	8/15/2012	PM - Water Softener
FO-224926	8/8/2012	8/7/2012	Monthly AHU Inspection Clean Room Unit 2
FO-224927	8/8/2012	8/7/2012	PM - Monthly AHU Inspection Clean Room Unit 1
FO-224224	8/15/2012		Generator Maintenance
FO-224907	8/15/2012	8/28/2012	PM - Domestic Water Heater, Electric
FO-224947	8/15/2012	8/16/2012	PM - Domestic Water Heater, Electric
FO-224881	8/16/2012	8/28/2012	PM - Deaerator Tank
FO-224882	8/16/2012	8/28/2012	PM - Domestic Water Heater, Gas
FO-224913	8/16/2012		PM - Vacuum Pump
FO-224914	8/16/2012		PM - Vacuum Pump
FO-224227	8/21/2012		Generator Maintenance
FO-225542	8/22/2012		PM - Heat Exchanger and Economizer
FO-225543	8/22/2012		PM - Heat Exchanger and Economizer
FO-226079	8/28/2012		PM - Reverse Osmosis Water Softener System

E - Area 2 Engineer**49**

FO-224631	8/1/2012		PM - Centrifugal Pump, over 1 H.P.
FO-224634	8/1/2012	8/13/2012	PM - Water Softener
FO-224698	8/1/2012		PM - Sump Pump
FO-224699	8/1/2012		PM - Sump Pump
FO-224715	8/1/2012		PM - Sump Pump
FO-224716	8/1/2012		PM - Sump Pump
FO-225041	8/6/2012	8/16/2012	PM - Heat Pumps (5057 Woodward)
FO-225042	8/6/2012	8/16/2012	PM - Heat Pumps (5057 Woodward)
FO-225043	8/6/2012	8/16/2012	PM - Heat Pumps (5057 Woodward)

Total

FO-225044	8/6/2012	8/16/2012	PM - Heat Pumps (5057 Woodward)
FO-224983	8/7/2012		PM - Heat Exchanger and Economizer
FO-224993	8/7/2012		PM - Deaerator Tank
FO-224994	8/7/2012		PM - Heat Exchanger and Economizer
FO-224995	8/7/2012		PM - Heat Exchanger and Economizer
FO-224979	8/8/2012	7/30/2012	PM - Sump Pump
FO-224980	8/8/2012	7/30/2012	PM - Sump Pump
FO-225036	8/8/2012		PM - Centrifugal Pump, over 1 H.P.
FO-225087	8/8/2012		PM - Condensate Return Pump
FO-225088	8/8/2012		PM - Condensate Return Pump
FO-224972	8/14/2012		PM - Sump Pump
FO-224973	8/14/2012		PM - Sump Pump
FO-224974	8/14/2012		PM - Sump Pump
FO-224982	8/14/2012		PM - Domestic Water Heater, Steam
FO-225067	8/14/2012		PM - Sump Pump
FO-225068	8/14/2012		PM - Sump Pump
FO-225069	8/14/2012		PM - Sump Pump
FO-225037	8/15/2012		PM - Centrifugal Pump, over 1 H.P.
FO-225047	8/15/2012		PM - Heat Exchanger and Economizer
FO-225048	8/15/2012		PM - Heat Exchanger and Economizer
FO-225049	8/15/2012		PM - Heat Exchanger and Economizer
FO-225050	8/15/2012		PM - Heat Exchanger and Economizer
FO-225051	8/15/2012		PM - Heat Exchanger and Economizer
FO-225052	8/15/2012		PM - Heat Exchanger and Economizer
FO-225059	8/15/2012		PM - Domestic Water Heater, Steam
FO-225070	8/15/2012		PM - Centrifugal Pump, over 1 H.P.
FO-225086	8/15/2012		PM - Domestic Water Heater, Electric
FO-224961	8/16/2012		PM - Air Handling Unit, over 50 Ton
FO-225564	8/21/2012		PM - Unspecified
FO-225565	8/21/2012		PM - Unspecified
FO-225566	8/21/2012		PM - Domestic Water Heater, Gas
FO-224229	8/22/2012		Generator Maintenance
FO-225579	8/22/2012		PM - Centrifugal Pump, over 1 H.P.
FO-225586	8/22/2012		PM - Heat Exchanger and Economizer
FO-225587	8/22/2012		PM - Heat Exchanger and Economizer
FO-226132	8/28/2012		PM - Unspecified
FO-226133	8/28/2012		PM - Unspecified
FO-226167	8/28/2012		PM - Vacuum Pump
FO-226168	8/28/2012		PM - Domestic Water Heater, Electric
FO-226149	8/29/2012		PM - Centrifugal Pump, over 1 H.P.
E - Area 3 Auxiliary Eng		6	
FO-224757	8/1/2012		PM - Air Handling Unit, HV Type
FO-224760	8/1/2012		PM - Air Handling Unit, HV Type
FO-224761	8/1/2012		PM - Fire Alarm System Test
FO-224928	8/15/2012		Replace Chemistry PreFilters (AHU-1A/2A) North End
FO-225097	8/20/2012	8/29/2012	PM - Condensate Return Pump
FO-225598	8/23/2012	8/24/2012	PM - Fire Alarm System Test

E - Controls Engineer**6**

Total

FO-224746	8/1/2012		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-224747	8/1/2012		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-224748	8/1/2012		Boiler - Open Clean and Close 78 inch Boilers
FO-221262	8/3/2012	8/16/2012	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-225560	8/23/2012		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-225589	8/24/2012		PM - Air Dryer
E - Midnight Swing Shift		5	
FO-224633	8/1/2012	8/30/2012	PM - Unspecified
FO-224723	8/1/2012	8/30/2012	PM - Condensate Return System **Needs Task Sheet**
FO-224970	8/8/2012	8/30/2012	PM - Sewage Lift Pump
FO-224971	8/8/2012	8/30/2012	PM - Sewage Lift Pump
FO-225597	8/22/2012	8/30/2012	PM - Sewage Lift Pump

Grounds**1****Routine****1****G - Moving/Storage****1**

FO-227396 8/28/2012

Vendor or Contractor Work

Trades**26****High****23****T - Electrician****23**

FO-224220	8/3/2012		Generator Test
FO-224223	8/3/2012		Generator Test
FO-224213	8/8/2012		Generator Test
FO-224208	8/9/2012		Generator Maintenance
FO-224219	8/9/2012		Generator Test
FO-224225	8/9/2012		Generator Maintenance
FO-224215	8/10/2012		Generator Test
FO-224216	8/10/2012		Generator Test
FO-224214	8/14/2012		Generator Test
FO-224218	8/15/2012		Generator Test
FO-224221	8/16/2012		Generator Test
FO-224209	8/21/2012		Generator Test
FO-224210	8/21/2012		Generator Maintenance
FO-224217	8/21/2012		Generator Test
FO-224228	8/21/2012		Generator Test
FO-224207	8/22/2012		Generator Test
FO-224222	8/24/2012		Generator Test
FO-224226	8/24/2012		Generator Test
FO-224230	8/28/2012		Generator Test
FO-224231	8/28/2012		Generator Test
FO-224232	8/28/2012		Generator Test
FO-224233	8/28/2012	8/28/2012	Generator Test
FO-224234	8/28/2012		Generator Test

Routine**3****T - Electrician****3**

FO-224224	8/15/2012		Generator Maintenance
FO-224227	8/21/2012		Generator Maintenance
FO-224229	8/22/2012		Generator Maintenance

Total

Total: 2742