

Facilities Operations Backlog as of 6/1/16

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Maint. Work Order				46	13	11	15	6	1	0	33
Engineering				9	4	3	1	1	0	0	5
Emergency				2	1	1	0	0	0	0	1
E - MedPharm				1	1	0	0	0	0	0	
FO-348218	5/24/2016	8	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING							
E - South				1	0	1	0	0	0	0	
FO-344868	4/15/2016	47	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
High				1	0	1	0	0	0	0	1
E - Command Center				1	0	1	0	0	0	0	
FO-344878	4/15/2016	47	Hold for Funds	Refr.crew:							
Medium				2	1	0	1	0	0	0	1
E - Command Center				2	1	0	1	0	0	0	
FO-343471	3/30/2016	63	Hold for Funds	boilers 1 2 3 have trouble maintaining loop temp,below set point, reset flame failure alar							
FO-341941	9/1/2016	-92	Hold for Funds	Trade: Command Center							
Low				4	2	1	0	1	0	0	2
E - Command Center				4	2	1	0	1	0	0	
FO-337648	1/22/2016	131	Hold for Funds	REPAIR LOW WATER CUT OUT. MAKE UP TANK.							
FO-344746	4/13/2016	49	Hold for Funds	ac/burner crew-							
FO-348953	5/31/2016	1	Hold for Funds	Controls							
FO-349541	6/8/2016	-7	Hold for Funds	Controls							
Trades				37	9	8	14	5	1	0	28
Emergency				2	1	1	0	0	0	0	1
T - Electrician				2	1	1	0	0	0	0	
FO-344868	4/15/2016	47	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
FO-348218	5/24/2016	8	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING							
High				13	4	1	4	4	0	0	9
T - Carpenter				3	1	0	0	2	0	0	
FO-336514	1/8/2016	145	Hold for Funds	Follow up on work order - FO 334978 from December. I have received another request/							
FO-339303	2/10/2016	112	Hold for Funds	Replace broken floor tiles in hallway outside room							
FO-350129	6/16/2016	-15	Hold for Funds	Carpenters, High, Please seal threshold at Putnam lobby doors, rain water coming into							
T - Electrician				10	3	1	4	2	0	0	
FO-337015	1/15/2016	138	Hold for Funds	Trade: Electricians							
FO-339318	2/10/2016	112	Hold for Funds	RM 150 LIGHT SWITCH NOT WORKING PROPERLY, ALL THE LIGHTS WONT TUR							
FO-342136	3/15/2016	78	Hold for Funds	lollipop type lights around building and in front of structure #2 not working please check							
FO-342372	3/18/2016	75	Hold for Funds	**ADDING ELECTRICIAN ; Please check float switch #2 . See Gerry (Plumber)							
FO-342874	3/22/2016	71	Hold for Funds	Electricians-							
FO-343192	3/25/2016	68	Hold for Funds	trade electricians priority high							
FO-344409	4/7/2016	55	Hold for Funds	R/R RM 2301/RESTROOM Hand dryer is not functioning. there was a report of a burnin							
FO-347029	5/9/2016	23	Hold for Funds	MENS RM 2301 HAND DRYER NOT WORKING							
FO-348530	5/26/2016	6	Hold for Funds	repair trash pump. only one working.							
FO-348951	5/31/2016	1	Hold for Funds	ELECTRICIANS							
Medium				3	1	0	2	0	0	0	2
T - Carpenter				1	1	0	0	0	0	0	
FO-347481	5/17/2016	15	Hold for Funds	pls build elevated cat walk around the dearator in the bsmt of usb/fpm 2"-3" of standing							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
T - Electrician			1	0	0	1	0	0	0	
FO-341930	3/10/2016	83	Hold for Funds		Check Community Arts, and other buildings for Emergency Lighting.					
T - Plumber			1	0	0	1	0	0	0	
FO-342830	3/22/2016	71	Hold for Funds		**WILL REVISIT IN SUMMER WHEN STEAM IS OFF AND CONDENSATE ID DRY ON					
Low			18	3	6	8	1	0	0	15
T - Carpenter			7	2	4	1	0	0	0	
FO-341794	3/9/2016	84	Hold for Funds		**ADDING CARPENTER : Please replace or reset all loose tites in bathroom of office 29					
FO-344995	4/18/2016	44	Hold for Funds		REPAIR GUTTER ON SOUTHWEST CORNER.					
FO-345016	4/18/2016	44	Hold for Funds		Carpenters: please repair roof gutters on north side of the building. priority: low.					
FO-345767	4/21/2016	41	Hold for Funds		R/R BLDG The latches on the windows are broken or missing in several rooms and they					
FO-346341	4/29/2016	33	Hold for Funds		R/R all damaged and missing ceiling tiles in hallways on 1st, 2nd and 3rd floors.					
FO-346848	5/4/2016	28	Hold for Funds		Room 4235, Replace broken, loose and missing floor					
FO-346921	5/5/2016	27	Hold for Funds		please replace severely damaged floor tiles just outside the elevator on 4th floor of COE					
T - Electrician			11	1	2	7	1	0	0	
FO-340735	2/29/2016	93	Hold for Funds		pls repair rest room exh fan motor circuit not running					
FO-341792	3/9/2016	84	Hold for Funds		Light out in the Grounds' dept. I had to remove the bulb because it wouldn't stop flickerin					
FO-342004	3/11/2016	82	Hold for Funds		correct EBU system at theatre					
FO-342204	3/16/2016	77	Hold for Funds		Replace Emergency light Batteries in Auditorium.					
FO-342943	3/23/2016	70	Hold for Funds		EMERGENCY ELEC					
FO-343080	3/24/2016	69	Hold for Funds		Replacing missing shade on light fixture in second floor back hallway outside of unisex b					
FO-343295	3/28/2016	65	Hold for Funds		Extreme Air Hand Dryer is not working in Ladies Bathroom, UGL Room 2432.					
FO-343434	3/29/2016	64	Hold for Funds		the 2nd floor heating hot water pump trips off, pls repair					
FO-344767	4/13/2016	49	Hold for Funds		The hand drier in the women's bathroom does not					
FO-345765	4/21/2016	41	Hold for Funds		Out light bulbs in the building in the following rooms:					
FO-347482	5/17/2016	15	Hold for Funds		pls repair electric motor exh fan not running in the bsmt of fpm					
Routine			1	0	0	0	0	1	0	1
T - Plumber			1	0	0	0	0	1	0	
FO-332597	11/15/2015	199	Hold for Funds		(HFF) PER DK 3/30					

Total: 46