

Facilities Operations Maint. "Work Not Done" Report 4/1/16 through 4/30/16

		Total per Trade		Emergency 1 day		High 3 <= days		Medium <=14 days		Low <=30 days		Routine
Engineering		4 of 4	100%	0 of 0	#Num!	3 of 3	100%	0 of 0	#Num!	1 of 1	100%	0
E - MedPharm		1 of 1	100%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
2	FO-345865 Maint. Work Order	4/22/2016	4/22/2016	0	High	CEILING LEAK. ROOM 355.						
E - Northeast		1 of 1	100%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
2	FO-344794 Maint. Work Order	4/14/2016	4/14/2016	0	High	RM 139 TOO COLD				Building is not my zone today I think that is johnathan keys		
E - Preventative Maintenance		1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0 of 0	#Num!	1 of 1	100%	0
4	FO-343614 Maint. Work Order	3/31/2016	4/1/2016	1	Low	Wall leak in chemical storage area. Water ruining chemical boxes.						
E - South		1 of 1	100%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
2	FO-344783 Maint. Work Order	4/14/2016	4/14/2016	0	High	Please adjust the thermostat in Rm 300.02 in the Prentis Building. The room is too hot.				fo-344783 came for overheating room 300.02. I checked it out and the stat is receiving control air but the air blowing into the room is 90f at the low setting. sent in request to control section to check out overheating condition fo-283049.PS I did reduce main supply air discharge but if the reheat coil is not working with the stat it may not help.		
Total:		4 of 4	100%	0 of 0	#Num!	3 of 3	100%	0 of 0	#Num!	1 of 1	100%	0