

DRAFT Facilities Operations PM Analysis from 11/1/15 through 11/30/15

Requested										Finished	Open	WND				% Finished
Engineering			745		517		225		3							69%
E - Auxiliary			37		16		21		0							43%
FO-330178	Finished	140-HEX-002	11/1/2015	11/3/2015			False	1.00	PM - Heat Exchanger and Economizer							
FO-330426	Finished	034-HWH-001	11/1/2015	11/24/2015			False	0.25	PM - Centrifugal Pump, over 1 H.P.							
Checked and lubed pump.																
FO-330427	Finished	034-HWH-002	11/1/2015	11/24/2015			False	0.25	PM - Centrifugal Pump, over 1 H.P.							
Checked and lubed pump.																
FO-330428	Finished	034-HWP-001	11/1/2015	11/24/2015			False	0.50	PM - Centrifugal Pump, over 1 H.P.							
Checked and lubed pump.																
FO-330450	Created By PM Schedule	136-MAU-001	11/1/2015				False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan							
FO-330467	Created By PM Schedule	134-CHWP-003	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330468	Created By PM Schedule	134-CHWP-004	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330469	Created By PM Schedule	134-CWP-001	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330470	Created By PM Schedule	134-HEX-001	11/1/2015				False		PM - Heat Exchanger and Economizer							
FO-330471	Created By PM Schedule	507-HEX-001	11/1/2015				False		PM - Heat Exchanger and Economizer							
FO-330472	Created By PM Schedule	507-HEX-002	11/1/2015				False		PM - Heat Exchanger and Economizer							
FO-330473	Created By PM Schedule	507-HEX-003	11/1/2015				False		PM - Heat Exchanger and Economizer							
FO-330474	Created By PM Schedule	507-CRP-001	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330475	Created By PM Schedule	507-CRP-002	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330476	Created By PM Schedule	536-AHU-201	11/1/2015				False		PM - Air Handling Unit, HV Type							
FO-330477	Finished	992-ES-001*	11/2/2015	11/6/2015			False		PM - Emergency Shower/Eyewash Station							
FO-330478	Created By PM Schedule	536-HP-001	11/1/2015				False		PM - Air Handling Unit, HV Type							
FO-330479	Created By PM Schedule	104-CWP-001	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330480	Created By PM Schedule	104-CWP-002	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330481	Created By PM Schedule	115-GCP-001	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330482	Created By PM Schedule	115-GCP-002	11/1/2015				False		PM - Centrifugal Pump, over 1 H.P.							
FO-330489	Created By PM Schedule	134-FP-001	11/1/2015				False		PM - Monthly Fire Alarm/Fire Protection System Test							
FO-330490	Created By PM Schedule	127-FP-001	11/1/2015				False		PM - Monthly Fire Alarm/Fire Protection System Test							
FO-330491	Created By PM Schedule	115-FP-001	11/1/2015				False		PM - Monthly Fire Alarm/Fire Protection System Test							
FO-330492	Created By PM Schedule	104-FP-001	11/1/2015				False		PM - Monthly Fire Alarm/Fire Protection System Test							
FO-330493	Created By PM Schedule	507-FP-001	11/1/2015				False		PM - Monthly Fire Alarm/Fire Protection System Test							
FO-330996	Finished	501-GEN-001	11/10/2015	11/11/2015			False		Generator Maintenance, Monthly							
FO-330998	Finished	992-ES-001*	11/9/2015	11/13/2015			False		PM - Emergency Shower/Eyewash Station							
FO-331515	Finished	104-GEN-001	11/24/2015	11/25/2015			False		Generator Maintenance, Monthly							
FO-331517	Finished	127-GEN-001	11/24/2015	11/24/2015			False	0.10	Generator Maintenance, Monthly							
Test cancelled due to bldg. gas shutdown.																
FO-331519	Finished	127-GEN-002	11/24/2015	11/24/2015			False	0.10	Generator Maintenance, Monthly							
Test cancelled due to bldg. gas shutdown.																
FO-331521	Finished	127-GEN-003	11/24/2015	11/24/2015			False	0.10	Generator Maintenance, Monthly							
Test cancelled due to bldg. gas shutdown.																

Requested Finished Open WND

% Finished

FO-331523	Finished	127-GEN-004	11/24/2015	11/24/2015	False	0.10	Generator Maintenance, Monthly
Test cancelled due to bldg. gas shutdown.							
FO-331531	Finished	507-GEN-001	11/11/2015	11/12/2015	False		Generator Maintenance, Monthly
FO-331538	Finished	536-GEN-001	11/18/2015	11/18/2015	False		Generator Maintenance, Monthly
FO-331638	Finished	992-ES-001*	11/16/2015	11/20/2015	False		PM - Emergency Shower/Eyewash Station
FO-332237	Finished	992-ES-001*	11/23/2015	11/27/2015	False		PM - Emergency Shower/Eyewash Station
E - MedPharm			55	40	15	0	
FO-329986	Finished	609-HWP-001	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.
inspected							
FO-329987	Finished	609-HWP-002	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.
inspected							
FO-329988	Finished	609-HWP-003	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.
inspected							
FO-329989	Created By PM Schedule	603-AC-001	11/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-329990	Created By PM Schedule	603-HRP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-329991	Created By PM Schedule	603-HRP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-329992	Created By PM Schedule	603-HWP-001	11/1/2015		False	6.00	PM - Centrifugal Pump, over 1 H.P.
FO-329993	Created By PM Schedule	603-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-329994	Created By PM Schedule	603-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-329995	Finished	603-HWP-004	11/1/2015	11/4/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Done found broken vert. cover. checked seal. cleaned							
FO-329996	Finished	603-PCW-001	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
greased/ checked coupling cleaned							
FO-329997	Finished	603-PCW-002	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Done. checked coupling. cleaned							
FO-329998	Created By PM Schedule	511-HWP-001**	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-329999	Created By PM Schedule	511-HWP-002**	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330000	Created By PM Schedule	511-HWP-003**	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330001	Finished	629-HEX-001	11/1/2015	11/2/2015	False	1.00	PM - Heat Exchanger and Economizer
FO-330002	Finished	629-HEX-002	11/1/2015	11/2/2015	False	1.00	PM - Heat Exchanger and Economizer
FO-330003	Finished	629-HWP-001	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330004	Finished	629-HWP-002	11/1/2015	11/16/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330005	Finished	629-CRP-003	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330006	Finished	629-HWP-004	11/1/2015	11/16/2015	False	4.00	PM - Centrifugal Pump, over 1 H.P.
FO-330007	Finished	629-HWP-005	11/1/2015	11/13/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-330008	Finished	629-HWP-006	11/1/2015	11/13/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-330009	Finished	629-HWP-013	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330010	Finished	612-CRP-001	11/1/2015	11/5/2015	False	1.00	PM - Condensate Return Pump
FO-330011	Finished	612-CRP-002	11/1/2015	11/5/2015	False	0.50	PM - Condensate Return Pump
FO-330012	Finished	612-CRP-003A	11/1/2015	11/5/2015	False	0.50	PM - Condensate Return Pump
FO-330013	Finished	612-BFP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330014	Finished	612-HWP-010	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330015	Finished	612-HWP-011	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.

73%

Requested Finished Open WND

% Finished

FO-330016	Finished	612-HWP-012	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330017	Finished	612-HWP-013	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330018	Finished	612-HWP-014	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330019	Finished	612-HWP-015	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330020	Finished	612-HWP-033	11/1/2015	11/10/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330021	Finished	612-HWP-034	11/1/2015	11/10/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330022	Finished	612-HWP-035	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330023	Created By PM Schedule	611-CRP-001	11/1/2015		False		PM - Condensate Return Pump
FO-330024	Created By PM Schedule	611-CRP-002	11/1/2015		False		PM - Condensate Return Pump
FO-330025	Finished	629-CRP-001	11/1/2015	11/16/2015	False	2.00	PM - Condensate Return Pump
FO-330026	Finished	603-HWP-005	11/1/2015	11/3/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Done. ran pump cleaned. no flow check control valve							
FO-330027	Finished	603-HWP-006	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Done.							
FO-330028	Finished	603-CRP-001	11/1/2015	11/4/2015	False	0.50	PM - Condensate Return Pump
done. cleaned & ran pump/checked seal							
FO-330029	Finished	603-CRP-002	11/1/2015	11/4/2015	False	0.50	PM - Condensate Return Pump
Done. cleaned pump. checked seal							
FO-330030	Finished	612-BFP-002	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330031	Finished	612-BFP-003	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330032	Finished	612-SRG-001	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330033	Finished	612-SRG-002	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330035	Finished	629-LCP-001	11/1/2015	11/6/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330980	Created By PM Schedule	612-GEN-001	11/10/2015		False		Generator Maintenance, Monthly
FO-330981	Created By PM Schedule	612-GEN-002	11/10/2015		False		Generator Maintenance, Monthly
FO-330982	Finished	609-GEN-001	11/10/2015	11/18/2015	False		Generator Maintenance, Monthly
inspected							
FO-331511	Finished	611-GEN-001	11/24/2015	11/24/2015	False	0.50	Generator Maintenance, Monthly
Did preliminary checks of unit. Electricians did monthly generator load test.							
FO-331513	Created By PM Schedule	629-GEN-001	11/24/2015		False		Generator Maintenance, Monthly
FO-332676	Created By PM Schedule	603-ROS-001	11/28/2015		False		PM - Reverse Osmosis Water Softener System
E - North			94	87	6	1	93%
FO-330036	Finished	025-HWP-001	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330037	Finished	025-HWP-002	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330038	Finished	025-HWP-003	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330039	Finished	130-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330040	Finished	130-HWP-002	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330041	Finished	140-HRP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330042	Finished	140-HRP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330043	Finished	140-HWP-001	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330044	Finished	140-HWP-002	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-330045	Finished	140-HWP-003	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330046	Finished	140-HWP-004	11/1/2015	11/4/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330047	Finished	140-HWP-005	11/1/2015	11/4/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330048	Finished	050-RHC-001	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330049	Finished	050-RHC-002	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330050	Finished	050-RHC-003	11/1/2015	11/13/2015	False	0.50	PM - Unspecified
FO-330051	Finished	050-RHC-004	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330052	Finished	050-RHC-005	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330053	Finished	050-RHC-006	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330054	Finished	050-RHC-007	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330055	Finished	050-RHC-008	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330056	Finished	050-RHC-009	11/1/2015	11/11/2015	False	1.00	PM - Unspecified
FO-330057	Finished	050-RHC-010	11/1/2015	11/10/2015	False	1.00	PM - Unspecified
FO-330058	Finished	050-RHC-011	11/1/2015	11/20/2015	False	1.00	PM - Unspecified
FO-330059	Finished	050-RHC-012	11/1/2015	11/23/2015	False	1.00	PM - Unspecified
FO-330060	Finished	050-RHC-013	11/1/2015	11/23/2015	False	1.00	PM - Unspecified
FO-330061	Finished	050-RHC-014	11/1/2015	11/24/2015	False	1.00	PM - Unspecified
FO-330062	Finished	026-HWP-001	11/1/2015	11/20/2015	False	0.75	PM - Centrifugal Pump, over 1 H.P.
FO-330063	Finished	026-HWP-002	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330064	Finished	026-HWP-003	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330065	Finished	026-HWP-005	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330066	Finished	026-HWP-006	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330067	Finished	046-HWP-001	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330068	Finished	046-HWP-002	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330069	Finished	046-HWP-003	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330070	Finished	046-HWP-004	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330071	Finished	046-HWP-005	11/1/2015	10/23/2015	False	0.35	PM - Centrifugal Pump, over 1 H.P.
FO-330072	Finished	046-HWP-013	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330073	Finished	048-HWP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330074	Finished	048-HWP-002	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330075	Finished	048-HWP-003	11/1/2015	10/30/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330076	Finished	048-HWP-004	11/1/2015	10/30/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330077	Finished	046-CFP-002	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller
FO-330078	Finished	046-CFP-003	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller
FO-330079	Finished	048-CFP-002	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330080	Finished	048-CFP-003	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330081	Finished	048-CFP-001	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330082	Finished	022-CFP-001	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller

Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment.

FO-330083	Finished	022-CFP-002	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
-----------	----------	-------------	-----------	------------	-------	------	---

Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment.

Requested Finished Open WND

% Finished

FO-330084	Finished	022-CFP-003	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment							
FO-330085	Finished	050-HWP-001	11/1/2015	11/30/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330086	Finished	050-HWP-002	11/1/2015	11/30/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330087	Finished	050-HWP-003	11/1/2015	11/12/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330088	Finished	038-HWP-003	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Checked pump operation, PM as necessary.							
FO-330089	Created By PM Schedule	039-HWP-001	11/1/2015		True	0.25	PM - Centrifugal Pump, over 1 H.P.
Electricians waiting on part to fix switch (reference FO-325163) for this pump.							
FO-330090	Finished	042-HWP-001	11/1/2015	11/17/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Perimeter heating pump for this location is out of service and no longer used.							
FO-330091	Finished	042-HWP-002	11/1/2015	11/17/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Checked pump and motor operation, PM where necessary.							
FO-330092	Finished	043-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Greased, checked for operational problems, put back into service.							
FO-330093	Finished	043-HWP-002	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Greased bearings, checked for operational problems, placed back into service.							
FO-330094	Finished	043-HWP-005	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Checked pump operation, seals, clutch, bearings. PM as necessary.							
FO-330095	Finished	043-HWP-006	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Checked pump operation seals, clutch, bearings. PM as needed placed back into service.							
FO-330096	Finished	043-HWP-015	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Checked pump operation, seals, clutch, and bearings. No lubrication needed. PM as necessary.							
FO-330097	Finished	027-HWP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330098	Finished	027-HWP-002	11/1/2015	11/12/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330099	Finished	027-HWP-003	11/1/2015	11/12/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330100	Finished	027-HWP-004	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330101	Finished	027-HWP-005	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330102	Finished	036-HWP-001	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330103	Finished	036-HWP-002	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330104	Finished	036-HWP-003	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330105	Finished	036-HWP-004	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330106	Finished	048-SSF-001	11/1/2015	10/7/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330107	Finished	048-SSF-002	11/1/2015	10/30/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330108	Finished	046-SSF-001	11/1/2015	11/23/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330109	Finished	046-SSF-003	11/1/2015	10/14/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330110	Finished	026-SSF-001	11/1/2015	11/17/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-330111	Finished	036-SSF-001	11/1/2015	11/19/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-330112	Finished	036-CFP-001	11/1/2015	11/10/2015	False	0.25	PM - Chemical Feed/Metering Pump/Controller
FO-330113	Finished	026-HEX-001	11/1/2015	11/16/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-330114	Finished	025-DHW-001	11/1/2015	11/16/2015	False	0.50	PM - Domestic Water Heater, Steam
FO-330115	Created By PM Schedule	046-SSF-002	11/1/2015		False	0.00	PM - Harmsco Side Stream Filter
FO-330116	Finished	046-CFP-001	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller

Requested Finished Open WND

% Finished

FO-330117	Finished	046-HWP-XXX	11/1/2015	10/21/2015	False	0.65	PM - Water Booster Pump
FO-330118	Finished	038-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. Greased bearings, checked pump operation for problems, placed back into service.
FO-330119	Finished	038-HWP-002	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. Greased bearings, checked pump for operation, placed back into service.
FO-330120	Finished	025-AHU-005	11/1/2015	11/17/2015	False	1.00	Replace PRE-filters
FO-330121	Created By PM Schedule	025-AHU-004	11/1/2015		False		Replace PRE-filters
FO-330122	Created By PM Schedule	025-AHU-003	11/1/2015		False		Replace PRE-filters
FO-330123	Created By PM Schedule	025-AHU-001	11/1/2015		False		Replace PRE-filters
FO-330983	Finished	040-SAF-002	11/6/2015	11/17/2015	False	1.00	PM - Outside/Fresh Air Intake Screens Checked intake for debris removed where necessary.
FO-330984	Finished	040-SAF-003	11/6/2015	11/17/2015	False	1.00	PM - Outside/Fresh Air Intake Screens Checked for debris removed where necessary.
FO-331529	Created By PM Schedule	130-GEN-001	11/25/2015		False	0.00	Generator Maintenance, Monthly
FO-331542	Finished	048-GEN-001	11/13/2015	11/13/2015	False	0.75	Generator Maintenance, Monthly
FO-331631	Created By PM Schedule	026-ACU-004	11/15/2015		False		PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-332236	Finished	027-ACU-003	11/20/2015	11/18/2015	False	1.00	PM - Water/Air Cooled Condenser
E - Northeast			49	33	16	0	67%
FO-330124	Created By PM Schedule	062-CHWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330125	Created By PM Schedule	062-CHWP-004	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330126	Finished	193-WSS-001	11/1/2015	11/17/2015	False	1.00	PM - Water Softener
FO-330127	Finished	193-HWP-002	11/1/2015	11/24/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330128	Finished	193-HWP-003	11/1/2015	11/18/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330129	Finished	193-HWP-004	11/1/2015	11/26/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330130	Finished	193-BFP-001	11/1/2015	11/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330131	Finished	193-BFP-002	11/1/2015	11/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330132	Created By PM Schedule	195-ACU-001	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330133	Created By PM Schedule	195-ACU-002	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330134	Created By PM Schedule	195-ACU-003	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330135	Created By PM Schedule	062-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330136	Created By PM Schedule	062-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330137	Created By PM Schedule	065-CHWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330138	Finished	067-CHWP-001	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330139	Finished	067-HWP-004	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330140	Finished	067-HWP-005	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330141	Created By PM Schedule	065-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330142	Created By PM Schedule	065-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330143	Created By PM Schedule	065-HWP-005	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330144	Finished	067-HWP-001	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330145	Finished	067-HWP-002	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330146	Finished	067-HWP-003	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330147	Finished	509-HWP-001	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P. lubricated pump and motor checked for leaks and operation

Requested Finished Open WND

% Finished

FO-330148	Finished	509-HWP-002	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P. lubricated pump and motor checked operation
FO-330149	Finished	509-HWP-003	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P. lubricated pump and motor checked for leaks checked operation
FO-330150	Finished	509-HWP-005	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P. lubricated pump and motor checked operation checked coupling checked for leaks
FO-330151	Finished	509-HWP-014	11/1/2015	11/19/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P. lubricated pump and motor checked coupling checked for leaks and operation
FO-330152	Finished	511-HWP-001	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. checked for leaks lubricated pump and motor checked operation
FO-330153	Finished	511-HWP-002	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. checked for leaks lubricated pimp and motor checked operation
FO-330154	Finished	067-CRP-001	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330155	Finished	066-CRP-001	11/1/2015	11/18/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330156	Finished	066-CRP-002	11/1/2015	11/18/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330157	Finished	510-HWP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. lubricated checked coupling checked operation
FO-330158	Finished	510-HWP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P. lubricated pump checked coupling checked operation
FO-330159	Created By PM Schedule	065-CHWP-004	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330985	Finished	064-HWP-001	11/6/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330986	Finished	193-GEN-001	11/6/2015	10/2/2015	False	1.00	Generator Maintenance, Monthly
FO-330987	Finished	193-GEN-002	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-330988	Finished	193-GEN-003	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-330989	Finished	193-GEN-004	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-331508	Finished	066-GEN-001	11/25/2015	11/13/2015	False	1.00	Generator Maintenance, Monthly
FO-331533	Finished	203-GEN-001	11/17/2015	11/17/2015	False	1.00	Generator Maintenance, Monthly
FO-331540	Created By PM Schedule	527-GEN-001	11/19/2015		False		Generator Maintenance, Monthly
FO-331544	Created By PM Schedule	-GEN-001 (Towa	11/11/2015		False		Generator Maintenance, Monthly
FO-331550	Created By PM Schedule	060-GEN-001A	11/26/2015		False		Generator Maintenance, Monthly
FO-331552	Created By PM Schedule	060-GEN-001B	11/26/2015		False		Generator Maintenance, Monthly
FO-331632	Finished	064-ACU-001	11/15/2015	11/12/2015	False	0.50	PM - Water/Air Cooled Condenser
FO-331633	Finished	064-ACU-002	11/15/2015	11/12/2015	False	1.00	PM - Water/Air Cooled Condenser

E - Preventative Maintenance

177

155

20

2

88%

FO-321823		085-ACU-001	11/1/2015		True	4.00	Replace PRE-filters
FO-321823		085-ACU-001	11/1/2015		False	4.00	Replace PRE-filters
FO-325266	Finished	048-AHU-001	11/1/2015	11/6/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-325267	Finished	048-AHU-002	11/1/2015	11/6/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-325268	Finished	048-AHU-003	11/1/2015	11/10/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-326088	Finished	603-EXF-011	11/1/2015	11/2/2015	False	0.75	Replace PRE-filters
FO-326147	Finished	611-AHU-007**	11/1/2015	11/30/2015	True	0.10	Replace PRE-filters
Unit not in service							
FO-326148	Finished	611-AHU-006	11/1/2015	12/1/2015	False	2.00	Replace PRE-filters
FO-326149	Finished	611-AHU-005	11/1/2015	12/1/2015	False	1.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-326150	Finished	611-AHU-004	11/1/2015	11/25/2015	False	4.00	Replace PRE-filters
FO-326151	Created By PM Schedule	611-AHU-003	11/1/2015		False		Replace PRE-filters
FO-326152	Created By PM Schedule	611-AHU-002	11/1/2015		False		Replace PRE-filters
FO-326153	Finished	611-AHU-001	11/1/2015	11/25/2015	False	6.00	Replace PRE-filters
FO-328824	Finished	603-EXF-001	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328825	Finished	603-EXF-002	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328826	Finished	603-EXF-001-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328827	Finished	603-EXF-002-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328828	Finished	603-EXF-003	11/1/2015	11/12/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328829	Finished	603-EXF-003-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328830	Finished	603-EXF-004-A-F	11/1/2015	11/12/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328831	Finished	603-EXF-004-B-F	11/1/2015	11/12/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328832	Finished	603-EXF-005	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328833	Finished	603-EXF-006	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328834	Finished	603-EXF-007	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328835	Finished	603-EXF-008	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328836	Finished	603-EXF-009	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328837	Finished	603-EXF-010	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328838	Finished	603-EXF-012	11/1/2015	11/16/2015	False	1.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328839	Finished	603-EXF-013	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328840	Finished	603-EXF-015	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328841	Finished	603-EXF-001-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328842	Finished	603-EXF-002-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328843	Finished	603-EXF-003-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328844	Finished	603-EXF-017	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328845	Finished	603-EXF-018	11/1/2015	11/2/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328846	Finished	046-FAP-001	11/1/2015	11/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328847	Finished	048-FAP-001	11/1/2015	11/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328848	Finished	049-FAP-001	11/1/2015	11/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328849	Finished	156-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328850	Finished	499-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328851	Finished	620-FAP-001	11/1/2015	11/27/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328852	Finished	036-FP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328853	Finished	025-FP-001	11/1/2015	11/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328854	Finished	007-FP-001	11/1/2015	11/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328855	Finished	001-FP-001	11/1/2015	11/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328856	Finished	005-FAP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328857	Finished	040-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328858	Finished	038-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328859	Finished	028-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328860	Finished	026-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328861	Finished	022-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328862	Finished	017-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328863	Finished	016-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-328864	Finished	003-FAP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328865	Finished	006-FP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328866	Finished	050-FAP-001	11/1/2015	11/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328867	Finished	043-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328868	Finished	042-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328869	Finished	062-FP-001	11/1/2015	11/20/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328870	Finished	065-FP-001	11/1/2015	11/13/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328871	Finished	068-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328872	Finished	067-FP-001	11/1/2015	11/13/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328873	Finished	089-FP-001	11/1/2015	11/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328874	Finished	082-FP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328875	Finished	080-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328876	Finished	090-FP-001	11/1/2015	11/24/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328877	Finished	155-FP-001	11/1/2015	11/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328878	Finished	150-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328879	Finished	167-FAP-001	11/1/2015	11/25/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328880	Finished	166-FP-001	11/1/2015	11/24/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328881	Finished	140-FAP-001	11/1/2015	11/17/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328882	Finished	130-FP-001	11/1/2015	11/20/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328883	Finished	193-FAP-001	11/1/2015	11/16/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328884	Finished	189-FP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328885	Finished	510-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328886	Finished	509-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328887	Finished	504-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328888	Finished	629-FP-001	11/1/2015	11/4/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328889	Finished	612-FP-001	11/1/2015	11/5/2015	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-328890	Finished	611-FP-001	11/1/2015	11/3/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328891	Finished	609-FP-001	11/1/2015	11/3/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328892	Finished	603-FP-001	11/1/2015	11/5/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328893	Finished	608-FP-001	11/1/2015	11/5/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328894	Finished	603-AHU-010	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328895	Finished	603-AHU-005	11/1/2015	11/9/2015	False	3.00	Replace PRE-filters
FO-328896	Finished	603-AHU-004	11/1/2015	11/9/2015	False	3.25	Replace PRE-filters
FO-328897	Finished	603-AHU-003	11/1/2015	11/10/2015	False	1.25	Replace PRE-filters
FO-328898	Finished	603-AHU-002	11/1/2015	11/10/2015	False	2.50	Replace PRE-filters
FO-328899	Finished	603-AHU-001	11/1/2015	11/10/2015	False	2.50	Replace PRE-filters
FO-328900	Finished	629-EXF-011A	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328901	Finished	629-AHU-003	11/1/2015	12/1/2015	False	4.00	Replace PRE-filters
FO-328902	Finished	629-AHU-002	11/1/2015	12/1/2015	False	9.00	Replace PRE-filters
FO-328903	Finished	629-AHU-001	11/1/2015	12/1/2015	False	9.00	Replace PRE-filters
FO-328904	Finished	074-FAP-001	11/1/2015	11/19/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328905	Finished	629-EXF-011B	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328906	Finished	016-FCU-001	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328907	Finished	016-FCU-002	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-328908	Finished	016-FCU-003	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328909	Finished	016-FCU-004	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328910	Finished	016-FCU-005	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328911	Finished	016-FCU-006	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328912	Finished	016-HVU-001	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328913	Finished	016-HVU-002	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328914	Finished	016-HVU-003	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328915	Finished	016-HVU-004	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328916	Finished	016-HVU-005	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328917	Finished	090-HVU-004	11/1/2015	11/6/2015	False	2.50	PM - Air Handling Unit (ANNUAL)
FO-328918	Created By PM Schedule	090-HVU-003	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328919	Finished	090-HVU-002	11/1/2015	11/20/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-328920	Finished	090-HVU-001	11/1/2015	11/18/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-328921	Created By PM Schedule	090-AHU-548	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328922	Created By PM Schedule	090-AHU-547	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328923	Created By PM Schedule	090-AHU-546	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328924	Created By PM Schedule	090-AHU-545	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328925	Created By PM Schedule	090-AHU-544	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328926	Created By PM Schedule	090-AHU-543	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328927	Created By PM Schedule	090-AHU-542	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328928	Created By PM Schedule	090-AHU-541	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328929	Finished	090-AHU-003	11/1/2015	11/6/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328930	Finished	090-AHU-002	11/1/2015	11/5/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328931	Finished	090-AHU-001	11/1/2015	11/5/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328932	Finished	049-AHU-005	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328933	Finished	049-AHU-004	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328934	Finished	049-AHU-003	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328935	Finished	049-AHU-002	11/1/2015	11/18/2015	False	3.00	Replace PRE-filters
FO-328936	Finished	049-AHU-001	11/1/2015	11/18/2015	False	3.00	Replace PRE-filters
FO-328937	Finished	060-ACU-001	11/1/2015	11/21/2015	False	1.50	Replace PRE-filters
FO-328938	Finished	074-AHU-004	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328939	Finished	074-AHU-003	11/1/2015	11/21/2015	False	2.00	Replace PRE-filters
FO-328940	Finished	074-AHU-002	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328941	Finished	074-AHU-001	11/1/2015	11/21/2015	False	2.00	Replace PRE-filters
FO-328942	Created By PM Schedule	046-SAF-003	11/1/2015		False		Replace PRE-filters
FO-328943	Finished	096-FP-001	11/1/2015	11/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328945	Finished	046-AHU-001	11/1/2015	11/12/2015	False	4.00	Replace PRE-filters
FO-328946	Finished	062-AHU-004	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328947	Finished	062-AHU-003	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters
FO-328948	Finished	062-AHU-002	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters
FO-328949	Finished	062-AHU-001	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters
FO-328950	Finished	026-AHU-006	11/1/2015	12/1/2015	False	2.00	Replace PRE-filters
FO-328951	Finished	026-AHU-005	11/1/2015	12/1/2015	False	1.50	Replace PRE-filters
FO-328952	Finished	026-AHU-004	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-328953	Finished	026-AHU-003	11/1/2015	11/24/2015	False	3.00	Replace PRE-filters
FO-328954	Finished	026-AHU-002	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters
FO-328955	Finished	026-AHU-001	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters
FO-328956	Finished	027-SAF-002	11/1/2015	11/19/2015	False	3.00	Replace PRE-filters
FO-328957	Finished	027-SAF-001	11/1/2015	11/19/2015	False	6.00	Replace PRE-filters
FO-328958	Finished	028-SAF-006	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328959	Finished	028-SAF-005	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328960	Finished	028-SAF-004	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328961	Finished	028-SAF-003	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328962	Finished	028-SAF-002	11/1/2015	11/20/2015	False	1.00	Replace PRE-filters
FO-328963	Finished	028-SAF-001	11/1/2015	11/20/2015	False	1.00	Replace PRE-filters
FO-328964	Finished	016-AHU-005	11/1/2015	11/3/2015	False	3.00	Replace PRE-filters
FO-328965	Finished	016-AHU-004	11/1/2015	11/14/2015	False	6.00	Replace PRE-filters
FO-328966	Finished	016-AHU-002	11/1/2015	11/10/2015	False	3.00	Replace PRE-filters
FO-328967	Finished	016-AHU-001	11/1/2015	11/10/2015	False	3.00	Replace PRE-filters
FO-328968	Finished	023-AHU-003	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328969	Finished	023-AHU-002	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328970	Finished	023-AHU-001	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328971	Finished	022-HVU-001	11/1/2015	11/12/2015	False	3.00	Replace PRE-filters
FO-328972	Finished	022-HVU-002	11/1/2015	11/9/2015	False	1.50	Replace PRE-filters
FO-328973	Created By PM Schedule	036-SAF-001	11/1/2015		False		Replace PRE-filters
FO-328974	Created By PM Schedule	036-RTU-001	11/1/2015		False		Replace PRE-filters
FO-328975	Created By PM Schedule	036-AHU-003	11/1/2015		False		Replace PRE-filters
FO-328976	Created By PM Schedule	036-AHU-002	11/1/2015		False		Replace PRE-filters
FO-328977	Finished	082-AHU-002	11/1/2015	11/14/2015	False	3.00	Replace PRE-filters
FO-328978	Finished	082-AHU-001	11/1/2015	11/14/2015	False	3.00	Replace PRE-filters
FO-328979	Finished	016-HVU-006	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328980	Finished	016-HVU-007	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328981	Finished	016-HVU-008	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328982	Cancelled	048-AHU-003	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328983	Cancelled	048-AHU-002	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328984	Finished	022-AHU-001	11/1/2015	11/9/2015	False	3.00	Replace PRE-filters
FO-328985	Finished	169-FAP-001	11/1/2015	11/24/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328986	Created By PM Schedule	046-AHU-003	11/1/2015		False		Replace PRE-filters
FO-329081	Created By PM Schedule	046-AHU-002	11/1/2015		False		Replace PRE-filters
FO-329231	Finished	074-AHU-005	11/1/2015	11/21/2015	False	4.00	Replace PRE-filters
E - South			88	86	2	0	98%
FO-330162	Finished	090-HWP-005	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330163	Finished	090-HWP-006	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330164	Finished	090-HWP-007	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330165	Finished	090-HWP-008	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330166	Finished	090-HWP-009	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330167	Finished	090-HWP-011	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330168	Finished	090-HWP-012	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-330169	Finished	089-WSS-001	11/1/2015	11/9/2015	False	1.00	PM - Water Softener
FO-330170	Created By PM Schedule	089-AIR-001	11/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-330171	Finished	016-AIR-002	11/1/2015	11/17/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit, checked the belt. Changed oil and oil filter. checked air filter, it was good. checked operation of the pressure switch. Cleaned the unit.							
FO-330179	Finished	089-HRP-011	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330180	Finished	089-HRP-013	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330181	Finished	089-HRP-010	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330182	Finished	089-HRP-012	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330183	Finished	089-PHP-005	11/1/2015	11/24/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330184	Finished	089-PHP-005S	11/1/2015	11/24/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330185	Finished	089-PHP-006	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330186	Finished	089-PHP-006S	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330187	Finished	089-PHP-007	11/1/2015	11/6/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330188	Finished	089-PHP-008	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330189	Finished	089-PHP-008S	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330190	Finished	089-PHP-009	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330191	Finished	089-PHP-009S	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330192	Finished	089-PHP-016	11/1/2015	11/20/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330193	Finished	089-PHP-016S	11/1/2015	11/20/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330194	Finished	089-PHP-007S	11/1/2015	11/6/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330220	Finished	090-CFP-001	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330221	Finished	090-CFP-002	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330222	Finished	090-CFP-003	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330227	Finished	090-HWP-017	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330228	Finished	090-HWP-018	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330229	Finished	090-HWP-019	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330230	Finished	090-HWP-020	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330231	Created By PM Schedule	089-AIR-002	11/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-330232	Finished	089-VP-001**	11/1/2015	11/6/2015	False	1.00	PM - Vacuum Pump
FO-330233	Finished	089-VP-002**	11/1/2015	11/6/2015	False	1.00	PM - Vacuum Pump
FO-330234	Finished	006-CRP-001	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330235	Finished	006-CRP-002	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330298	Finished	005-HWP-001	11/1/2015	11/23/2015	False	2.50	PM - Centrifugal Pump, over 1 H.P.
Lubbed the motor and the bearing assembly, however the pump has a bad coupling which has to be replaced. We will order same.							
FO-330299	Finished	006-HWP-001	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330300	Finished	006-HWP-002	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330301	Finished	006-HWP-003	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330302	Finished	006-HWP-004	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330303	Finished	006-HWP-005	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330304	Finished	005-CRP-001	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							
FO-330305	Finished	005-CRP-002	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							

Requested Finished Open WND

% Finished

FO-330306 Finished 005-CRP-003 11/1/2015 11/13/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

No lub spots. Checked operation, cleaned, etc.

FO-330307 Finished 005-CRP-004 11/1/2015 11/13/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

No lub spots. Checked operation, cleaned, etc.

FO-330308 Finished 005-HEX-001 11/1/2015 11/18/2015 False 0.50 PM - Heat Exchanger and Economizer

FO-330393 Finished 096-HWP-001 11/1/2015 11/17/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330394 Finished 096-HWP-002 11/1/2015 11/17/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330395 Finished 096-HWP-003 11/1/2015 11/17/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330396 Finished 096-HWP-004 11/1/2015 11/17/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330397 Finished 096-HWP-005 11/1/2015 11/17/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330398 Finished 016-AIR-003 11/1/2015 11/18/2015 False 1.00 PM - Air Compressor, Reciprocating 5-40 H.P.

Checked operation of the unit. Checked for any excess noise and vibration, checked the belts. Checked operation of the pressure switch. install drain line for draining oil and changed it's oil, removed and cleaned air filter. cleaned the equipment.

FO-330404 Finished 007-HWP-001 11/1/2015 11/25/2015 False 0.75 PM - Centrifugal Pump, over 1 H.P.

FO-330405 Finished 007-HWP-002 11/1/2015 11/25/2015 False 0.75 PM - Centrifugal Pump, over 1 H.P.

FO-330406 Finished 007-SUP-002 11/1/2015 11/25/2015 False 0.75 PM - Centrifugal Pump, over 1 H.P.

FO-330407 Finished 089-HWP-004 11/1/2015 11/9/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

FO-330408 Finished 089-HWP-004S 11/1/2015 11/18/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330415 Finished 089-HWP-003 11/1/2015 11/18/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330416 Finished 089-HWP-003S 11/1/2015 11/25/2015 False 1.50 PM - Centrifugal Pump, over 1 H.P.

FO-330419 Finished 005-ACU-002 11/1/2015 11/18/2015 False 1.50 PM - Water/Air Cooled Condenser

FO-330461 Finished 089-CRP-001 11/1/2015 11/9/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

FO-330462 Finished 089-CRP-002 11/1/2015 11/9/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

FO-330463 Finished 005-CRP-005 11/1/2015 11/13/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

No lub spots. Checked operation, cleaned, etc. There is also a CRP-006 at this location. It was serviced also.

FO-330464 Finished 006-CRP-003 11/1/2015 11/24/2015 False 0.25 PM - Centrifugal Pump, over 1 H.P.

FO-330465 Finished 127-EXF-002 11/1/2015 11/12/2015 False 1.00 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-330466 Finished 127-EXF-001 11/1/2015 11/10/2015 False 1.00 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-330483 Finished 090-HWP-021 11/1/2015 11/2/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

FO-330484 Finished 090-HWP-022 11/1/2015 11/2/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

FO-330485 Finished 090-HWP-543 11/1/2015 11/2/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

FO-330486 Finished 090-HWP-541 11/1/2015 11/2/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

FO-330487 Finished 090-HWP-542 11/1/2015 11/2/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

FO-330488 Finished 090-ERP-542 11/1/2015 11/18/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

FO-330494 Finished 007-MAU-001 11/1/2015 11/19/2015 False 1.00 Replace PRE-filters

FO-330990 Finished 090-ACU-CR2 11/8/2015 11/3/2015 False 1.00 Monthly AHU Inspection Clean Room Unit 2

FO-330991 Finished 090-ACU-CR1 11/8/2015 11/3/2015 False 0.10 PM - Monthly AHU Inspection Clean Room Unit 1

FO-331500 Finished 007-GEN-001 11/12/2015 11/12/2015 False 0.25 Generator Maintenance, Monthly

Checked oil, battery, anti-freeze, and fuel levels. All is ok at this time.

FO-331502 Finished 007-GEN-002 11/12/2015 11/12/2015 False 0.25 Generator Maintenance, Monthly

Checked oil, battery, anti-freeze, and fuel levels. All is ok at this time.

FO-331504 Finished 090-GEN-001 11/17/2015 11/17/2015 False 1.00 Generator Maintenance, Monthly

FO-331506 Finished 089-GEN-001 11/18/2015 11/23/2015 False 1.00 Generator Maintenance, Monthly

FO-331537 Finished 090-GEN-002 11/12/2015 11/12/2015 False 0.50 Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-331546	Finished	006-GEN-001	11/19/2015	11/24/2015	False	0.50	Generator Maintenance, Monthly
FO-331634	Finished	090-HEX-001	11/15/2015	11/6/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331635	Finished	090-HEX-003	11/15/2015	11/9/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331636	Finished	090-HEX-004	11/15/2015	11/9/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331639	Finished	090-HEX-548	11/15/2015	11/13/2015	False	1.00	PM - Heat Exchanger and Economizer
E - Southeast			194	97	97	0	50%
FO-330160	Created By PM Schedule	082-DWBP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330161	Created By PM Schedule	082-CWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330172	Finished	016-HEX-001	11/1/2015	11/25/2015	False	1.00	PM - Heat Exchanger and Economizer
Checked operation of the unit, checked pressure and temp . Checked operation of steam control valve, looked for any leaks. Closed steam shut off valve and opened condensate drain valve to check for tube leaks. cleaned the unit.							
FO-330173	Finished	016-HEX-002	11/1/2015	11/25/2015	False	1.00	PM - Heat Exchanger and Economizer
Checked operation of the unit, checked pressure and temp . Checked operation of steam control valve, looked for any leaks. Closed steam shut off valve and opened condensate drain valve to check for tube leaks. cleaned the unit.							
FO-330174	Finished	016-CRS-001	11/1/2015	11/25/2015	False	0.50	PM - Condensate Return Pump
Checked operation of the unit, checked for any leaks, checked for excess vibration and noise, checked operation of the level control. cleaned the unit.							
FO-330175	Finished	016-CRS-002	11/1/2015	11/25/2015	False		PM - Condensate Return Pump
Checked operation of the unit, checked for any leaks, checked for excess vibration and noise, checked operation of the level control. cleaned the unit.							
FO-330176	Created By PM Schedule	082-CHWP-006	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330177	Created By PM Schedule	082-CHWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330195	Created By PM Schedule	001-CHWP-004	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330196	Created By PM Schedule	001-CHWP-005	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330197	Created By PM Schedule	001-CHWP-006	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330198	Created By PM Schedule	001-CHWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330199	Created By PM Schedule	001-CHWP-008	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330200	Created By PM Schedule	001-CHWP-009	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330201	Created By PM Schedule	001-CWP-010	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330202	Created By PM Schedule	001-CWP-011	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330203	Created By PM Schedule	001-CWP-012	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330204	Created By PM Schedule	001-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330205	Created By PM Schedule	001-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330206	Created By PM Schedule	001-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330207	Created By PM Schedule	001-HWP-017A	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330208	Created By PM Schedule	001-HWP-017B	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330209	Created By PM Schedule	022-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330210	Created By PM Schedule	022-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330211	Created By PM Schedule	022-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330212	Created By PM Schedule	082-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330213	Created By PM Schedule	082-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330214	Created By PM Schedule	001-CRP-001	11/1/2015		False		PM - Condensate Return Pump
FO-330215	Created By PM Schedule	001-CRP-002	11/1/2015		False		PM - Condensate Return Pump

Requested Finished Open WND

% Finished

FO-330216	Created By PM Schedule	001-CRP-003	11/1/2015		False		PM - Condensate Return Pump
FO-330217	Created By PM Schedule	001-CRP-004	11/1/2015		False		PM - Condensate Return Pump
FO-330218	Finished	022-CRP-001	11/1/2015	11/11/2015	False	0.50	PM - Condensate Return Pump
Checked operation of the unit. Checked for any leaks and excess vibration. Checked operation of the level control. no need for lubrication. Cleaned the unit.							
FO-330219	Finished	022-CRP-002	11/1/2015	11/11/2015	False	0.50	PM - Condensate Return Pump
Checked operation of the unit. Checked for any leaks and excess vibration. Checked operation of the level control. no need for lubrication. Cleaned the unit.							
FO-330223	Created By PM Schedule	001-CFP-002	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330224	Created By PM Schedule	001-CFP-003	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330225	Created By PM Schedule	001-CFP-004	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330226	Created By PM Schedule	001-CFP-005	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330236	Created By PM Schedule	001-FCU-1162-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330237	Created By PM Schedule	001-FCU-1162-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330238	Created By PM Schedule	001-FCU-1162-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330239	Created By PM Schedule	001-FCU-1163-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330240	Created By PM Schedule	001-FCU-1163-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330241	Created By PM Schedule	001-FCU-1163-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330242	Created By PM Schedule	001-FCU-1165-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330243	Created By PM Schedule	001-FCU-1165-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330244	Created By PM Schedule	001-FCU-1168-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330245	Created By PM Schedule	001-FCU-1168-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330246	Created By PM Schedule	001-FCU-1168-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330247	Created By PM Schedule	001-FCU-1168-4	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330248	Created By PM Schedule	001-FCU-1171-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330249	Created By PM Schedule	001-FCU-1171-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330250	Created By PM Schedule	001-FCU-1172-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330251	Created By PM Schedule	001-FCU-1172-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330252	Created By PM Schedule	001-FCU-1172-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330253	Created By PM Schedule	001-FCU-1202	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330254	Created By PM Schedule	001-FCU-1204	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330255	Created By PM Schedule	001-FCU-1208	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330256	Created By PM Schedule	001-FCU-1217.1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330257	Created By PM Schedule	001-FCU-1217.2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330258	Created By PM Schedule	001-FCU-1220-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330259	Created By PM Schedule	001-FCU-1220-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330260	Created By PM Schedule	001-FCU-1220-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330261	Created By PM Schedule	001-FCU-1220-4	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330262	Created By PM Schedule	001-FCU-1224-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330263	Created By PM Schedule	001-FCU-1224-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330264	Created By PM Schedule	001-FCU-1305-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330265	Created By PM Schedule	001-FCU-1305-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330266	Created By PM Schedule	001-FCU-1307-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330267	Created By PM Schedule	001-FCU-1307-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330268	Created By PM Schedule	001-FCU-1319-1	11/1/2015		False		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-330269	Created By PM Schedule	001-FCU-1319-2	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330270	Created By PM Schedule	001-FCU-1319-3	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330271	Created By PM Schedule	001-FCU-1319-4	11/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-330272	Created By PM Schedule	003-CFP-001	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330273	Created By PM Schedule	003-CFP-002	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330274	Created By PM Schedule	003-CFP-003	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330275	Created By PM Schedule	003-CFP-004	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330293	Created By PM Schedule	167-HEX-001	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330296	Created By PM Schedule	070-CRS-001*	11/1/2015		False		PM - Condensate Return Pump
FO-330297	Created By PM Schedule	070-CRS-002*	11/1/2015		False		PM - Condensate Return Pump
FO-330309	Finished	071-CRP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330310	Finished	071-HWP-003	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330311	Finished	071-HWP-004	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330312	Finished	071-HWP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330313	Finished	071-HEX-001	11/1/2015	11/2/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330314	Finished	071-HEX-002	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330315	Finished	071-HEX-003	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330316	Finished	071-HEX-004	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330317	Finished	071-HWP-027	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330318	Finished	071-HWP-028	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330319	Finished	071-HWP-029	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330320	Finished	071-HWP-030	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330321	Finished	071-HWP-031	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330322	Finished	071-HWP-032	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330323	Finished	071-HWP-033	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330324	Finished	071-HWP-034	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330325	Finished	071-HWP-035	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330326	Finished	071-HWP-036	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330327	Finished	071-HWP-037	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330328	Finished	071-HWP-038	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330329	Finished	071-HWP-039	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330330	Finished	071-HWP-040	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330331	Finished	071-HWP-041	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330332	Finished	071-HWP-042	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330333	Finished	071-HWP-043	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330334	Finished	071-HWP-044	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330335	Finished	071-HWP-045	11/1/2015	11/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330336	Finished	071-HWP-046	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330337	Finished	071-HWP-047	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330338	Finished	071-HWP-048	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330339	Finished	071-HWP-049	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330340	Finished	071-HWP-050	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330341	Finished	071-HWP-051	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330342	Finished	071-HWP-052	11/1/2015	11/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)

[illegible]

Requested Finished Open WND

% Finished

FO-330387	Finished	071-HWP-097	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330388	Finished	071-HWP-098	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330389	Finished	071-HWP-206	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330390	Finished	071-HWP-207	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330391	Finished	071-HWP-208	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330392	Finished	071-HWP-209	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330399	Finished	016-CRP-001	11/1/2015	11/18/2015	False	1.00	PM - Condensate Return Pump
Checked operation of the unit, checked for any leak, checked for any excess noise and vibration. checked float level control operation. Cleaned the equipment.							
FO-330400	Finished	016-CRP-002	11/1/2015	11/18/2015	False	1.00	PM - Condensate Return Pump
Checked operation of the unit, checked for any leak, checked for any excess noise and vibration. checked float level control operation. Cleaned the equipment.							
FO-330401	Finished	016-CFP-001	11/1/2015	11/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330402	Finished	016-CFP-002	11/1/2015	11/16/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330403	Finished	016-CFP-003	11/1/2015	11/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330409	Created By PM Schedule	028-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330410	Created By PM Schedule	028-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330411	Created By PM Schedule	189-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330412	Created By PM Schedule	499-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330413	Created By PM Schedule	499-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330414	Created By PM Schedule	499-HEX-006	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330417	Created By PM Schedule	504-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330418	Created By PM Schedule	504-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330451	Created By PM Schedule	499-CFP-001	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330452	Created By PM Schedule	499-CFP-002	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330453	Created By PM Schedule	499-CFP-003	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-330454	Created By PM Schedule	499-CFP-004	11/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-331525	Finished	637-GEN-001	11/17/2015	11/18/2015	False		Generator Maintenance, Monthly
Checked fluids							
FO-331527	Finished	637-GEN-002	11/17/2015	11/18/2015	False		Generator Maintenance, Monthly
Checked fluids							
FO-331640	Created By PM Schedule	609-ACU-002	11/15/2015		False		PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-331641	Created By PM Schedule	609-ACU-001	11/15/2015		False		PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-332821	Created By PM Schedule	001-AHU-001	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332822	Created By PM Schedule	001-AHU-001ML	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332823	Created By PM Schedule	001-AHU-001O	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332824	Created By PM Schedule	001-AHU-002	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)

FO-332825	Created By PM Schedule	I01-AHU-002ML	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332826	Created By PM Schedule	001-AHU-002O	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332827	Created By PM Schedule	I01-AHU-003ML	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332828	Created By PM Schedule	001-AHU-003O	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
FO-332829	Created By PM Schedule	001-AHU-004O	11/28/2015		False		PM - Chilled Water Coils - Drain (Old Main)
E - West			51	3	48	0	6%
FO-330276	Created By PM Schedule	003-CRP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330277	Created By PM Schedule	003-CRP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330278	Created By PM Schedule	003-BFP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330279	Created By PM Schedule	003-BFP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330280	Created By PM Schedule	003-BFP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330281	Created By PM Schedule	003-TRP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330282	Created By PM Schedule	003-HWP-014	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330283	Created By PM Schedule	003-HWP-012	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330284	Created By PM Schedule	003-HWP-013	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330285	Created By PM Schedule	003-HWP-015	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330286	Created By PM Schedule	003-HWP-016	11/1/2015		False	0.00	PM - Centrifugal Pump, over 1 H.P.
FO-330287	Created By PM Schedule	003-HWP-017	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330288	Created By PM Schedule	003-HWP-018	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330289	Created By PM Schedule	003-WSS-001	11/1/2015		False		PM - Water Softener
FO-330290	Created By PM Schedule	003-HEX-001	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330291	Created By PM Schedule	167-AHU-001	11/1/2015		False		PM - Water/Air Cooled Condenser
FO-330292	Created By PM Schedule	167-AHU-002	11/1/2015		False		PM - Water/Air Cooled Condenser
FO-330294	Created By PM Schedule	167-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330295	Created By PM Schedule	167-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330420	Finished	080-HWP-001A	11/1/2015	11/20/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
completed task list							
FO-330421	Created By PM Schedule	080-HWP-012	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330422	Created By PM Schedule	080-HWP-013	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330423	Created By PM Schedule	080-HWP-014	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330424	Created By PM Schedule	080-HWP-015	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330425	Created By PM Schedule	080-HWP-016	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330429	Created By PM Schedule	080-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330430	Created By PM Schedule	080-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330431	Created By PM Schedule	080-HWP-005	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330432	Created By PM Schedule	080-HWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330433	Created By PM Schedule	080-HWP-009	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330434	Created By PM Schedule	080-HWP-011	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330435	Created By PM Schedule	080-HWP-028	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330436	Created By PM Schedule	080-HWP-029	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330437	Created By PM Schedule	080-HWP-040	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330438	Created By PM Schedule	166-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330439	Created By PM Schedule	166-HWP-001A	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330440	Created By PM Schedule	166-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-330441	Created By PM Schedule	166-HWP-006	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330442	Created By PM Schedule	166-HWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330443	Created By PM Schedule	166-HWP-008	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330444	Created By PM Schedule	166-HEX-001	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330445	Created By PM Schedule	166-HEX-002	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330446	Created By PM Schedule	156-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330447	Created By PM Schedule	156-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330448	Created By PM Schedule	156-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330449	Created By PM Schedule	156-HWP-004	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330459	Created By PM Schedule	155-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330460	Created By PM Schedule	155-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-331000	Finished	001 SPARE from	11/10/2015	11/10/2015	False	1.00	Generator Maintenance, Monthly
FO-331548	Finished	169-GEN-001	11/26/2015	11/27/2015	False		Generator Maintenance, Monthly
FO-331637	Created By PM Schedule	156-ACU-001	11/15/2015		False		PM - Water/Air Cooled Condenser

Trades	42	33	9	0		79%
---------------	-----------	-----------	----------	----------	--	------------

T - Electrician	37	28	9	0		76%
------------------------	-----------	-----------	----------	----------	--	------------

FO-330034	Created By PM Schedule	608-GEN-001	11/3/2015		False		Generator Maintenance, Monthly
FO-330992	Finished	193-GEN-001	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-330993	Finished	612-GEN-001	11/10/2015	11/10/2015	False	2.00	Generator Test
FO-330994	Finished	612-GEN-002	11/10/2015	11/10/2015	False	2.00	Generator Test
FO-330995	Finished	501-GEN-001	11/10/2015	11/10/2015	False	4.00	Generator Test
FO-330997	Finished	608-GEN-001	11/3/2015	11/3/2015	False	4.00	Generator Test
FO-330999	Finished	001 SPARE from	11/10/2015	11/10/2015	False	4.00	Generator Test
FO-331001	Finished	193-GEN-002	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331002	Finished	193-GEN-003	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331003	Finished	193-GEN-004	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331499	Finished	609-GEN-001	11/17/2015	11/17/2015	False	4.00	Generator Test
FO-331501	Finished	007-GEN-001	11/12/2015	11/12/2015	False	2.00	Generator Test
FO-331503	Finished	007-GEN-002	11/12/2015	11/12/2015	False	2.00	Generator Test
FO-331505	Finished	090-GEN-001	11/17/2015	11/17/2015	False	4.00	Generator Test
FO-331507	Finished	089-GEN-001	11/18/2015	11/18/2015	False	4.00	Generator Test
FO-331509	Finished	066-GEN-001	11/25/2015	11/25/2015	False	4.00	Generator Test
FO-331510	Finished	611-GEN-001	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331512	Finished	629-GEN-001	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331514	Finished	104-GEN-001	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331516	Created By PM Schedule	127-GEN-001	11/24/2015		False		Generator Test
FO-331518	Created By PM Schedule	127-GEN-002	11/24/2015		False		Generator Test
FO-331520	Created By PM Schedule	127-GEN-003	11/24/2015		False		Generator Test
FO-331522	Created By PM Schedule	127-GEN-004	11/24/2015		False		Generator Test
FO-331524	Finished	637-GEN-001	11/17/2015	11/17/2015	False	2.00	Generator Test
FO-331526	Finished	637-GEN-002	11/17/2015	11/17/2015	False	2.00	Generator Test
FO-331528	Finished	130-GEN-001	11/25/2015	11/25/2015	False	4.00	Generator Test
FO-331530	Finished	507-GEN-001	11/11/2015	11/11/2015	False	4.00	Generator Test

Requested Finished Open WND

% Finished

FO-331532	Finished	203-GEN-001	11/17/2015	11/18/2015	False	6.00	Generator Test
FO-331534	Finished	536-GEN-001	11/18/2015	11/19/2015	False	4.00	Generator Test
FO-331536	Created By PM Schedule	090-GEN-002	11/12/2015		False	8.00	Generator Test
FO-331539	Finished	527-GEN-001	11/19/2015	11/19/2015	False	4.00	Generator Test
FO-331541	Finished	048-GEN-001	11/13/2015	11/13/2015	False	4.00	Generator Test
FO-331543	Finished	GEN-001 (Towa	11/11/2015	11/13/2015	False	4.00	Generator Test
FO-331545	Finished	006-GEN-001	11/19/2015	11/19/2015	False	4.00	Generator Test
FO-331547	Created By PM Schedule	169-GEN-001	11/26/2015		False		Generator Test
FO-331549	Created By PM Schedule	060-GEN-001A	11/26/2015		False		Generator Test
FO-331551	Created By PM Schedule	060-GEN-001B	11/26/2015		False		Generator Test
T - Plumber			5	5	0	0	
							100%
FO-328664	Finished	042	11/1/2015	11/6/2015	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/11-2-15 ,,,,,,,,,
FO-328665	Finished	527	11/1/2015	11/2/2015	False		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-328666	Finished	608	11/1/2015	11/2/2015	False		**CANCELLED JWT PM - Waterless Urinals
FO-328667	Finished	049	11/1/2015	11/6/2015	False	1.50	PM - Waterless Urinals ,,,,,,,,,, TT/11-2-15 ,,,,,,,,,
FO-328668	Finished	090	11/1/2015	11/6/2015	False	1.50	PM - Waterless Urinals ,,,,,,,,,, TT/11-2-15 ,,,,,,,,,

Report Total

787 550 234 3

70%