

# Facilities Operations Backlog as of 7/31/16

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
<b>Maint. Work Order</b>				<b>44</b>	<b>2</b>	<b>2</b>	<b>9</b>	<b>28</b>	<b>3</b>	<b>0</b>	<b>42</b>
<b>Engineering</b>				<b>8</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>6</b>
<b>High</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>
<b>E - Command Center</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-344878	4/15/2016	107	Hold for Funds			Refr.crew:					
<b>Medium</b>				<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>
<b>E - Command Center</b>				<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-343471	3/30/2016	123	Hold for Funds			boilers 1 2 3 have trouble maintaining loop temp,below set point, reset flame failure alar					
FO-341941	9/1/2016	-32	Hold for Funds			Trade: Command Center					
<b>Low</b>				<b>5</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>4</b>
<b>E - Command Center</b>				<b>4</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-344746	4/13/2016	109	Hold for Funds			ac/burner crew-					
FO-348953	5/31/2016	61	Hold for Funds			Controls					
FO-349541	6/8/2016	53	Hold for Funds			Controls					
FO-352270	7/14/2016	17	Hold for Funds			A/C in engineer's office has failed. Repair or replace. please advise.					
<b>E - MedPharm</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-348218	5/24/2016	68	Hold for Funds			RM 2105 UPS PANEL ALARM SOUNDING					
<b>Trades</b>				<b>36</b>	<b>0</b>	<b>1</b>	<b>7</b>	<b>25</b>	<b>3</b>	<b>0</b>	<b>36</b>
<b>High</b>				<b>12</b>	<b>0</b>	<b>1</b>	<b>3</b>	<b>6</b>	<b>2</b>	<b>0</b>	<b>12</b>
<b>T - Carpenter</b>				<b>3</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>0</b>	
FO-336514	1/8/2016	205	Hold for Funds			Follow up on work order - FO 334978 from December. I have received another request/					
FO-339303	2/10/2016	172	Hold for Funds			Replace broken floor tiles in hallway outside room					
FO-350129	6/16/2016	45	Hold for Funds			Carpenters, High, Please seal threshold at Putnam lobby doors, rain water coming into					
<b>T - Electrician</b>				<b>9</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>5</b>	<b>1</b>	<b>0</b>	
FO-337015	1/15/2016	198	Hold for Funds			Trade: Electricians					
FO-339318	2/10/2016	172	Hold for Funds			RM 150 LIGHT SWITCH NOT WORKING PROPERLY, ALL THE LIGHTS WONT TUR					
FO-342136	3/15/2016	138	Hold for Funds			lollipop type lights around building and in front of structure #2 not working please check					
FO-342874	3/22/2016	131	Hold for Funds			Electricians-					
FO-343192	3/25/2016	128	Hold for Funds			trade electricians priority high					
FO-344409	4/7/2016	115	Hold for Funds			R/R RM 2301/RESTROOM Hand dryer is not functioning. there was a report of a burnin					
FO-347029	5/9/2016	83	Hold for Funds			MENS RM 2301 HAND DRYER NOT WORKING					
FO-348530	5/26/2016	66	Hold for Funds			repair trash pump. only one working.					
FO-348951	5/31/2016	61	Hold for Funds			ELECTRICIANS					
<b>Medium</b>				<b>3</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>3</b>
<b>T - Carpenter</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-347481	5/17/2016	75	Hold for Funds			pls build elevated cat walk around the dearator in the bsmt of usb/fpm 2"-3" of standing					
<b>T - Electrician</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-341930	3/10/2016	143	Hold for Funds			Check Community Arts, and other buildings for Emergency Lighting.					
<b>T - Plumber</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-342830	3/22/2016	131	Hold for Funds			**WILL REVISIT IN SUMMER WHEN STEAM IS OFF AND CONDENSATE ID DRY ON					
<b>Low</b>				<b>20</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>17</b>	<b>0</b>	<b>0</b>	<b>20</b>
<b>T - Carpenter</b>				<b>7</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	
FO-341794	3/9/2016	144	Hold for Funds			**ADDING CARPENTER : Please replace or reset all loose tites in bathroom of office 29					
FO-344995	4/18/2016	104	Hold for Funds			REPAIR GUTTER ON SOUTHWEST CORNER.					

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-345016	4/18/2016	104	Hold for Funds	Carpenters: please repair roof gutters on north side of the building. priority: low.							
FO-345767	4/21/2016	101	Hold for Funds	R/R BLDG The latches on the windows are broken or missing in several rooms and they							
FO-346341	4/29/2016	93	Hold for Funds	R/R all damaged and missing ceiling tiles in hallways on 1st, 2nd and 3rd floors.							
FO-346848	5/4/2016	88	Hold for Funds	Room 4235, Replace broken, loose and missing floor							
FO-346921	5/5/2016	87	Hold for Funds	please replace severely damaged floor tiles just outside the elevator on 4th floor of COE							
<b>T - Electrician</b>				<b>13</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>12</b>	<b>0</b>	<b>0</b>	
FO-340735	2/29/2016	153	Hold for Funds	pls repair rest room exh fan motor circuit not running							
FO-341353	3/3/2016	150	Hold for Funds	**ADDING ELECTRICIAN: Replace condensate pump motor on pump #1 on receiver un							
FO-341792	3/9/2016	144	Hold for Funds	Light out in the Grounds' dept. I had to remove the bulb because it wouldn't stop flickerin							
FO-342004	3/11/2016	142	Hold for Funds	correct EBU system at theatre							
FO-342204	3/16/2016	137	Hold for Funds	Replace Emergency light Batteries in Auditorium.							
FO-342372	3/18/2016	135	Hold for Funds	**ADDING ELECTRICIAN ; Please check float switch #2 . See Gerry (Plumber)							
FO-342943	3/23/2016	130	Hold for Funds	EMERGENCY ELEC							
FO-343080	3/24/2016	129	Hold for Funds	Replacing missing shade on light fixture in second floor back hallway outside of unisex b							
FO-343295	3/28/2016	125	Hold for Funds	Extreme Air Hand Dryer is not working in Ladies Bathroom, UGL Room 2432.							
FO-343434	3/29/2016	124	Hold for Funds	the 2nd floor heating hot water pump trips off, pls repair							
FO-344767	4/13/2016	109	Hold for Funds	The hand drier in the women's bathroom does not							
FO-345765	4/21/2016	101	Hold for Funds	Out light bulbs in the building in the following rooms:							
FO-348218	5/24/2016	68	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING							
<b>Routine</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>
<b>T - Plumber</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	
FO-332597	11/15/2015	259	Hold for Funds	(HFF) PER DK 3/30							

**Total: 44**