

# DRAFT Facilities Operations PM Analysis from 11/1/15 through 11/30/15

Requested Finished Open WND										% Finished
Engineering		737		678	46	13				92%
E - Auxiliary		37		22	15	0				59%
FO-330178	Finished	140-HEX-002	11/1/2015	11/3/2015		False	1.00	PM - Heat Exchanger and Economizer		
FO-330426	Finished	034-HWH-001	11/1/2015	11/24/2015		False	0.25	PM - Centrifugal Pump, over 1 H.P.		
Checked and lubed pump.										
FO-330427	Finished	034-HWH-002	11/1/2015	11/24/2015		False	0.25	PM - Centrifugal Pump, over 1 H.P.		
Checked and lubed pump.										
FO-330428	Finished	034-HWP-001	11/1/2015	11/24/2015		False	0.50	PM - Centrifugal Pump, over 1 H.P.		
Checked and lubed pump.										
FO-330450	Finished	136-MAU-001	11/1/2015	12/1/2015		False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		
FO-330467	Finished	134-CHWP-003	11/1/2015	12/1/2015		False	0.25	PM - Centrifugal Pump, over 1 H.P.		
FO-330468	Finished	134-CHWP-004	11/1/2015	12/1/2015		False	0.25	PM - Centrifugal Pump, over 1 H.P.		
FO-330469	Finished	134-CWP-001	11/1/2015	12/1/2015		False	0.25	PM - Centrifugal Pump, over 1 H.P.		
FO-330470	Finished	134-HEX-001	11/1/2015	12/1/2015		False	0.25	PM - Heat Exchanger and Economizer		
FO-330471	Created By PM Schedule	507-HEX-001	11/1/2015			False		PM - Heat Exchanger and Economizer		
FO-330472	Created By PM Schedule	507-HEX-002	11/1/2015			False		PM - Heat Exchanger and Economizer		
FO-330473	Created By PM Schedule	507-HEX-003	11/1/2015			False		PM - Heat Exchanger and Economizer		
FO-330474	Created By PM Schedule	507-CRP-001	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330475	Created By PM Schedule	507-CRP-002	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330476	Created By PM Schedule	536-AHU-201	11/1/2015			False		PM - Air Handling Unit, HV Type		
FO-330477	Finished	992-ES-001*	11/2/2015	11/6/2015		False		PM - Emergency Shower/Eyewash Station		
FO-330478	Created By PM Schedule	536-HP-001	11/1/2015			False		PM - Air Handling Unit, HV Type		
FO-330479	Created By PM Schedule	104-CWP-001	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330480	Created By PM Schedule	104-CWP-002	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330481	Created By PM Schedule	115-GCP-001	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330482	Created By PM Schedule	115-GCP-002	11/1/2015			False		PM - Centrifugal Pump, over 1 H.P.		
FO-330489	Finished	134-FP-001	11/1/2015	12/1/2015		False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test		
FO-330490	Created By PM Schedule	127-FP-001	11/1/2015			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-330491	Created By PM Schedule	115-FP-001	11/1/2015			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-330492	Created By PM Schedule	104-FP-001	11/1/2015			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-330493	Created By PM Schedule	507-FP-001	11/1/2015			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-330996	Finished	501-GEN-001	11/10/2015	11/11/2015		False		Generator Maintenance, Monthly		
FO-330998	Finished	992-ES-001*	11/9/2015	11/13/2015		False		PM - Emergency Shower/Eyewash Station		
FO-331515	Finished	104-GEN-001	11/24/2015	11/25/2015		False		Generator Maintenance, Monthly		
FO-331517	Finished	127-GEN-001	11/24/2015	11/24/2015		False	0.10	Generator Maintenance, Monthly		
Test cancelled due to bldg. gas shutdown.										
FO-331519	Finished	127-GEN-002	11/24/2015	11/24/2015		False	0.10	Generator Maintenance, Monthly		
Test cancelled due to bldg. gas shutdown.										
FO-331521	Finished	127-GEN-003	11/24/2015	11/24/2015		False	0.10	Generator Maintenance, Monthly		
Test cancelled due to bldg. gas shutdown.										

**Requested Finished Open WND**

**% Finished**

FO-331523	Finished	127-GEN-004	11/24/2015	11/24/2015	False	0.10	Generator Maintenance, Monthly	
Test cancelled due to bldg. gas shutdown.								
FO-331531	Finished	507-GEN-001	11/11/2015	11/12/2015	False		Generator Maintenance, Monthly	
FO-331538	Finished	536-GEN-001	11/18/2015	11/18/2015	False		Generator Maintenance, Monthly	
FO-331638	Finished	992-ES-001*	11/16/2015	11/20/2015	False		PM - Emergency Shower/Eyewash Station	
FO-332237	Finished	992-ES-001*	11/23/2015	11/27/2015	False		PM - Emergency Shower/Eyewash Station	
<b>E - MedPharm</b>			<b>55</b>	<b>55</b>	<b>-2</b>	<b>2</b>		<b>100%</b>
FO-329986	Finished	609-HWP-001	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.	
inspected								
FO-329987	Finished	609-HWP-002	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.	
inspected								
FO-329988	Finished	609-HWP-003	11/1/2015	11/18/2015	False		PM - Centrifugal Pump, over 1 H.P.	
inspected								
FO-329989	Finished	603-AC-001	11/1/2015	12/9/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.	
checked oil and belt								
FO-329990	Finished	603-HRP-001	11/1/2015	12/9/2015	False		PM - Centrifugal Pump, over 1 H.P.	
done								
FO-329991	Finished	603-HRP-002	11/1/2015	12/9/2015	False		PM - Centrifugal Pump, over 1 H.P.	
done								
FO-329992	Finished	603-HWP-001	11/1/2015	12/9/2015	False	10.00	PM - Centrifugal Pump, over 1 H.P.	
done								
FO-329993	Finished	603-HWP-002	11/1/2015	12/9/2015	False		PM - Centrifugal Pump, over 1 H.P.	
done								
FO-329994	Finished	603-HWP-003	11/1/2015	12/9/2015	False		PM - Centrifugal Pump, over 1 H.P.	
done								
FO-329995	Finished	603-HWP-004	11/1/2015	11/4/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
Done found broken vert. cover. checked seal. cleaned								
FO-329996	Finished	603-PCW-001	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.	
greased/ checked coupling cleaned								
FO-329997	Finished	603-PCW-002	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.	
Done. checked coupling. cleaned								
FO-329998	Finished	511-HWP-001**	11/1/2015	12/1/2015	True	0.10	PM - Centrifugal Pump, over 1 H.P.	
Pump not working, needs replacing								
FO-329999	Finished	511-HWP-002**	11/1/2015	12/1/2015	True	0.10	PM - Centrifugal Pump, over 1 H.P.	
Pump not working, needs replacing								
FO-330000	Finished	511-HWP-003**	11/1/2015	12/1/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.	
Checked operation of pump. Sealed bearings.								
FO-330001	Finished	629-HEX-001	11/1/2015	11/2/2015	False	1.00	PM - Heat Exchanger and Economizer	
FO-330002	Finished	629-HEX-002	11/1/2015	11/2/2015	False	1.00	PM - Heat Exchanger and Economizer	
FO-330003	Finished	629-HWP-001	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-330004	Finished	629-HWP-002	11/1/2015	11/16/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.	
FO-330005	Finished	629-CRP-003	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-330006	Finished	629-HWP-004	11/1/2015	11/16/2015	False	4.00	PM - Centrifugal Pump, over 1 H.P.	

**Requested Finished Open WND**

**% Finished**

FO-330007	Finished	629-HWP-005	11/1/2015	11/13/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-330008	Finished	629-HWP-006	11/1/2015	11/13/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-330009	Finished	629-HWP-013	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330010	Finished	612-CRP-001	11/1/2015	11/5/2015	False	1.00	PM - Condensate Return Pump
FO-330011	Finished	612-CRP-002	11/1/2015	11/5/2015	False	0.50	PM - Condensate Return Pump
FO-330012	Finished	612-CRP-003A	11/1/2015	11/5/2015	False	0.50	PM - Condensate Return Pump
FO-330013	Finished	612-BFP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330014	Finished	612-HWP-010	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330015	Finished	612-HWP-011	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330016	Finished	612-HWP-012	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330017	Finished	612-HWP-013	11/1/2015	11/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330018	Finished	612-HWP-014	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330019	Finished	612-HWP-015	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330020	Finished	612-HWP-033	11/1/2015	11/10/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330021	Finished	612-HWP-034	11/1/2015	11/10/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330022	Finished	612-HWP-035	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330023	Finished	611-CRP-001	11/1/2015	12/1/2015	False		PM - Condensate Return Pump
Checked operation of pump. Sealed bearings. Condensate tank is overflowing. Pumps may not be large enough or pressure from Scott Hall system may be causing condensate to not drain properly.							
FO-330024	Finished	611-CRP-002	11/1/2015	12/1/2015	False	0.50	PM - Condensate Return Pump
Checked operation of pump. Sealed bearings. Condensate tank is overflowing. Pumps may not be large enough or pressure from Scott Hall system may be causing condensate to not drain properly.							
FO-330025	Finished	629-CRP-001	11/1/2015	11/16/2015	False	2.00	PM - Condensate Return Pump
FO-330026	Finished	603-HWP-005	11/1/2015	11/3/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
Done. ran pump cleaned. no flow check control valve							
FO-330027	Finished	603-HWP-006	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Done.							
FO-330028	Finished	603-CRP-001	11/1/2015	11/4/2015	False	0.50	PM - Condensate Return Pump
done. cleaned & ran pump/checked seal							
FO-330029	Finished	603-CRP-002	11/1/2015	11/4/2015	False	0.50	PM - Condensate Return Pump
Done. cleaned pump. checked seal							
FO-330030	Finished	612-BFP-002	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330031	Finished	612-BFP-003	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330032	Finished	612-SRG-001	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330033	Finished	612-SRG-002	11/1/2015	11/11/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330035	Finished	629-LCP-001	11/1/2015	11/6/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330980	Finished	612-GEN-001	11/10/2015	1/11/2016	False		Generator Maintenance, Monthly
FO-330981	Finished	612-GEN-002	11/10/2015	1/11/2016	False		Generator Maintenance, Monthly
FO-330982	Finished	609-GEN-001	11/10/2015	11/18/2015	False		Generator Maintenance, Monthly
inspected							
FO-331511	Finished	611-GEN-001	11/24/2015	11/24/2015	False	0.50	Generator Maintenance, Monthly
Did preliminary checks of unit. Electricians did monthly generator load test.							

## Requested Finished Open WND

% Finished

FO-331513	Finished	629-GEN-001x	11/24/2015	12/7/2015	False		Generator Maintenance, Monthly
FO-332676	Finished	603-ROS-001	11/28/2015	12/1/2015	False	2.00	PM - Reverse Osmosis Water Softener System

done. running @98% rejection

**E - North** **94** **92** **1** **1** **98%**

FO-330036	Finished	025-HWP-001	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330037	Finished	025-HWP-002	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330038	Finished	025-HWP-003	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330039	Finished	130-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330040	Finished	130-HWP-002	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330041	Finished	140-HRP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330042	Finished	140-HRP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330043	Finished	140-HWP-001	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330044	Finished	140-HWP-002	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330045	Finished	140-HWP-003	11/1/2015	11/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330046	Finished	140-HWP-004	11/1/2015	11/4/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330047	Finished	140-HWP-005	11/1/2015	11/4/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330048	Finished	050-RHC-001	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330049	Finished	050-RHC-002	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330050	Finished	050-RHC-003	11/1/2015	11/13/2015	False	0.50	PM - Unspecified
FO-330051	Finished	050-RHC-004	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330052	Finished	050-RHC-005	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330053	Finished	050-RHC-006	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330054	Finished	050-RHC-007	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330055	Finished	050-RHC-008	11/1/2015	11/13/2015	False	1.00	PM - Unspecified
FO-330056	Finished	050-RHC-009	11/1/2015	11/11/2015	False	1.00	PM - Unspecified
FO-330057	Finished	050-RHC-010	11/1/2015	11/10/2015	False	1.00	PM - Unspecified
FO-330058	Finished	050-RHC-011	11/1/2015	11/20/2015	False	1.00	PM - Unspecified
FO-330059	Finished	050-RHC-012	11/1/2015	11/23/2015	False	1.00	PM - Unspecified
FO-330060	Finished	050-RHC-013	11/1/2015	11/23/2015	False	1.00	PM - Unspecified
FO-330061	Finished	050-RHC-014	11/1/2015	11/24/2015	False	1.00	PM - Unspecified
FO-330062	Finished	026-HWP-001	11/1/2015	11/20/2015	False	0.75	PM - Centrifugal Pump, over 1 H.P.
FO-330063	Finished	026-HWP-002	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330064	Finished	026-HWP-003	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330065	Finished	026-HWP-005	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330066	Finished	026-HWP-006	11/1/2015	11/10/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330067	Finished	046-HWP-001	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330068	Finished	046-HWP-002	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330069	Finished	046-HWP-003	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330070	Finished	046-HWP-004	11/1/2015	10/19/2015	False	0.65	PM - Centrifugal Pump, over 1 H.P.
FO-330071	Finished	046-HWP-005	11/1/2015	10/23/2015	False	0.35	PM - Centrifugal Pump, over 1 H.P.
FO-330072	Finished	046-HWP-013	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330073	Finished	048-HWP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330074	Finished	048-HWP-002	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330075	Finished	048-HWP-003	11/1/2015	10/30/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

## Requested Finished Open WND

% Finished

FO-330076	Finished	048-HWP-004	11/1/2015	10/30/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330077	Finished	046-CFP-002	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller
FO-330078	Finished	046-CFP-003	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller
FO-330079	Finished	048-CFP-002	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330080	Finished	048-CFP-003	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330081	Finished	048-CFP-001	11/1/2015	10/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330082	Finished	022-CFP-001	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller

Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment.

FO-330083	Finished	022-CFP-002	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
-----------	----------	-------------	-----------	------------	-------	------	---

Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment.

FO-330084	Finished	022-CFP-003	11/1/2015	11/20/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
-----------	----------	-------------	-----------	------------	-------	------	---

Checked operation of the pumps, put suction lines of all 3 pumps in a bucket of clean water and increased the seed and stroke of the pumps and ran the pumps for 15 minutes to flush the pumps and lines. cleaned the equipment

FO-330085	Finished	050-HWP-001	11/1/2015	11/30/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330086	Finished	050-HWP-002	11/1/2015	11/30/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330087	Finished	050-HWP-003	11/1/2015	11/12/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330088	Finished	038-HWP-003	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

Checked pump operation, PM as necessary.

FO-330089	Created By PM Schedule	039-HWP-001	11/1/2015		True	0.25	PM - Centrifugal Pump, over 1 H.P.
-----------	------------------------	-------------	-----------	--	------	------	------------------------------------

Electricians waiting on part to fix switch (reference FO-325163) for this pump.

FO-330090	Finished	042-HWP-001	11/1/2015	11/17/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Perimeter heating pump for this location is out of service and no longer used.

FO-330091	Finished	042-HWP-002	11/1/2015	11/17/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Checked pump and motor operation, PM where necessary.

FO-330092	Finished	043-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Greased, checked for operational problems, put back into service.

FO-330093	Finished	043-HWP-002	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Greased bearings, checked for operational problems, placed back into service.

FO-330094	Finished	043-HWP-005	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Checked pump operation, seals, clutch, bearings. PM as necessary.

FO-330095	Finished	043-HWP-006	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Checked pump operation seals, clutch, bearings. PM as needed placed back into service.

FO-330096	Finished	043-HWP-015	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	-----------	------------	-------	------	------------------------------------

Checked pump operation, seals, clutch, and bearings. No lubrication needed. PM as necessary.

FO-330097	Finished	027-HWP-001	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330098	Finished	027-HWP-002	11/1/2015	11/12/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330099	Finished	027-HWP-003	11/1/2015	11/12/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330100	Finished	027-HWP-004	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330101	Finished	027-HWP-005	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330102	Finished	036-HWP-001	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330103	Finished	036-HWP-002	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

**Requested Finished Open WND**

**% Finished**

FO-330104	Finished	036-HWP-003	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330105	Finished	036-HWP-004	11/1/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330106	Finished	048-SSF-001	11/1/2015	10/7/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330107	Finished	048-SSF-002	11/1/2015	10/30/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330108	Finished	046-SSF-001	11/1/2015	11/23/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330109	Finished	046-SSF-003	11/1/2015	10/14/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330110	Finished	026-SSF-001	11/1/2015	11/17/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-330111	Finished	036-SSF-001	11/1/2015	11/19/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-330112	Finished	036-CFP-001	11/1/2015	11/10/2015	False	0.25	PM - Chemical Feed/Metering Pump/Controller
FO-330113	Finished	026-HEX-001	11/1/2015	11/16/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-330114	Finished	025-DHW-001	11/1/2015	11/16/2015	False	0.50	PM - Domestic Water Heater, Steam
FO-330115	Finished	046-SSF-002	11/1/2015	11/24/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-330116	Finished	046-CFP-001	11/1/2015	10/27/2015	False	0.35	PM - Chemical Feed/Metering Pump/Controller
FO-330117	Finished	046-HWP-XXX	11/1/2015	10/21/2015	False	0.65	PM - Water Booster Pump
FO-330118	Finished	038-HWP-001	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Greased bearings, checked pump operation for problems, placed back into service.							
FO-330119	Finished	038-HWP-002	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Greased bearings, checked pump for operation, placed back into service.							
FO-330120	Finished	025-AHU-005	11/1/2015	11/17/2015	False	1.00	Replace PRE-filters
FO-330121	Finished	025-AHU-004	11/1/2015	12/22/2015	False	1.00	Replace PRE-filters
FO-330122	Finished	025-AHU-003	11/1/2015	12/22/2015	False	1.50	Replace PRE-filters
FO-330123	Finished	025-AHU-001	11/1/2015	12/22/2015	False	1.00	Replace PRE-filters
FO-330983	Finished	040-SAF-002	11/6/2015	11/17/2015	False	1.00	PM - Outside/Fresh Air Intake Screens
Checked intake for debris removed where necessary.							
FO-330984	Finished	040-SAF-003	11/6/2015	11/17/2015	False	1.00	PM - Outside/Fresh Air Intake Screens
Checked for debris removed where necessary.							
FO-331529	Finished	130-GEN-001	11/25/2015	11/30/2015	False	1.00	Generator Maintenance, Monthly
FO-331542	Finished	048-GEN-001	11/13/2015	11/13/2015	False	0.75	Generator Maintenance, Monthly
FO-331631	Created By PM Schedule	026-ACU-004	11/15/2015		False		PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-332236	Finished	027-ACU-003	11/20/2015	11/18/2015	False	1.00	PM - Water/Air Cooled Condenser
<b>E - Northeast</b>			<b>49</b>	<b>49</b>	<b>-2</b>	<b>2</b>	<b>100%</b>
FO-330124	Finished	062-CHWP-003	11/1/2015	12/1/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330125	Finished	062-CHWP-004	11/1/2015	12/1/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330126	Finished	193-WSS-001	11/1/2015	11/17/2015	False	1.00	PM - Water Softener
FO-330127	Finished	193-HWP-002	11/1/2015	11/24/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330128	Finished	193-HWP-003	11/1/2015	11/18/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330129	Finished	193-HWP-004	11/1/2015	11/26/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330130	Finished	193-BFP-001	11/1/2015	11/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330131	Finished	193-BFP-002	11/1/2015	11/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330132	Finished	195-ACU-001	11/1/2015	11/3/2015	False		PM - Fan Coil/HV/AC Unit
FO-330133	Finished	195-ACU-002	11/1/2015	11/3/2015	False		PM - Fan Coil/HV/AC Unit
FO-330134	Finished	195-ACU-003	11/1/2015	11/3/2015	False		PM - Fan Coil/HV/AC Unit
FO-330135	Finished	062-HWP-001	11/1/2015	12/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330136	Finished	062-HWP-002	11/1/2015	12/1/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

**Requested Finished Open WND**

**% Finished**

FO-330137	Finished	065-CHWP-003	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330138	Finished	067-CHWP-001	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330139	Finished	067-HWP-004	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330140	Finished	067-HWP-005	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330141	Finished	065-HWP-001	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330142	Finished	065-HWP-002	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330143	Finished	065-HWP-005	11/1/2015	12/23/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330144	Finished	067-HWP-001	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330145	Finished	067-HWP-002	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330146	Finished	067-HWP-003	11/1/2015	11/19/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330147	Finished	509-HWP-001	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
lubricated pump and motor checked for leaks and operation							
FO-330148	Finished	509-HWP-002	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
lubricated pump and motor checked operation							
FO-330149	Finished	509-HWP-003	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
lubricated pump and motor checked for leaks checked operation							
FO-330150	Finished	509-HWP-005	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
lubricated pump and motor checked operation checked coupling checked for leaks							
FO-330151	Finished	509-HWP-014	11/1/2015	11/19/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
lubricated pump and motor checked coupling checked for leaks and operation							
FO-330152	Finished	511-HWP-001	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
checked for leaks lubricated pump and motor checked operation							
FO-330153	Finished	511-HWP-002	11/1/2015	11/16/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
checked for leaks lubricated pimp and motor checked operation							
FO-330154	Finished	067-CRP-001	11/1/2015	11/20/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330155	Finished	066-CRP-001	11/1/2015	11/18/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330156	Finished	066-CRP-002	11/1/2015	11/18/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330157	Finished	510-HWP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
lubricated checked coupling checked operation							
FO-330158	Finished	510-HWP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
lubricated pump checked coupling checked operation							
FO-330159	Finished	065-CHWP-004	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330985	Finished	064-HWP-001	11/6/2015	11/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330986	Finished	193-GEN-001	11/6/2015	10/2/2015	False	1.00	Generator Maintenance, Monthly
FO-330987	Finished	193-GEN-002	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-330988	Finished	193-GEN-003	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-330989	Finished	193-GEN-004	11/6/2015	11/6/2015	False	1.00	Generator Maintenance, Monthly
FO-331508	Finished	066-GEN-001	11/25/2015	11/13/2015	False	1.00	Generator Maintenance, Monthly
FO-331533	Finished	203-GEN-001	11/17/2015	11/17/2015	False	1.00	Generator Maintenance, Monthly
FO-331540	Finished	527-GEN-001	11/19/2015	11/19/2015	False	3.00	Generator Maintenance, Monthly
pre formed load test							
FO-331544	Finished	GEN-001 (Towa	11/11/2015	12/22/2015	False	1.00	Generator Maintenance, Monthly
FO-331550	Finished	060-GEN-001A	11/26/2015	12/22/2015	True		Generator Maintenance, Monthly
FO-331552	Finished	060-GEN-001B	11/26/2015	12/22/2015	True		Generator Maintenance, Monthly
FO-331632	Finished	064-ACU-001	11/15/2015	11/12/2015	False	0.50	PM - Water/Air Cooled Condenser

FO-331633	Finished	064-ACU-002	11/15/2015	11/12/2015	False	1.00	PM - Water/Air Cooled Condenser
<b>E - Preventative Maintenance</b>			<b>169</b>	<b>161</b>	<b>0</b>	<b>8</b>	<b>95%</b>
FO-321823	Finished	085-ACU-001	11/1/2015	11/20/2015	True	4.00	Replace PRE-filters
FO-321823	Finished	085-ACU-001	11/1/2015	11/20/2015	False	4.00	Replace PRE-filters
FO-325266	Finished	048-AHU-001	11/1/2015	11/6/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-325267	Finished	048-AHU-002	11/1/2015	11/6/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-325268	Finished	048-AHU-003	11/1/2015	11/10/2015	False	4.00	Final Filter Replacement (18 MONTH FIXED INTERVAL)
FO-326088	Finished	603-EXF-011	11/1/2015	11/2/2015	False	0.75	Replace PRE-filters
FO-326147	Finished	611-AHU-007**	11/1/2015	11/30/2015	True	0.10	Replace PRE-filters
Unit not in service							
FO-326148	Finished	611-AHU-006	11/1/2015	12/1/2015	False	2.00	Replace PRE-filters
FO-326149	Finished	611-AHU-005	11/1/2015	12/1/2015	False	1.00	Replace PRE-filters
FO-326150	Finished	611-AHU-004	11/1/2015	11/25/2015	False	4.00	Replace PRE-filters
FO-326151	Completed	611-AHU-003	11/1/2015		True		Replace PRE-filters
FO-326152	Completed	611-AHU-002	11/1/2015		True		Replace PRE-filters
FO-326153	Finished	611-AHU-001	11/1/2015	11/25/2015	False	6.00	Replace PRE-filters
FO-328824	Finished	603-EXF-001	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328825	Finished	603-EXF-002	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328826	Finished	603-EXF-001-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328827	Finished	603-EXF-002-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328828	Finished	603-EXF-003	11/1/2015	11/12/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328829	Finished	603-EXF-003-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328830	Finished	603-EXF-004-A-F	11/1/2015	11/12/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328831	Finished	603-EXF-004-B-F	11/1/2015	11/12/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328832	Finished	603-EXF-005	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328833	Finished	603-EXF-006	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328834	Finished	603-EXF-007	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328835	Finished	603-EXF-008	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328836	Finished	603-EXF-009	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328837	Finished	603-EXF-010	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328838	Finished	603-EXF-012	11/1/2015	11/16/2015	False	1.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328839	Finished	603-EXF-013	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328840	Finished	603-EXF-015	11/1/2015	11/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328841	Finished	603-EXF-001-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328842	Finished	603-EXF-002-A-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328843	Finished	603-EXF-003-B-F	11/1/2015	11/4/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328844	Finished	603-EXF-017	11/1/2015	11/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328845	Finished	603-EXF-018	11/1/2015	11/2/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-328846	Finished	046-FAP-001	11/1/2015	11/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328847	Finished	048-FAP-001	11/1/2015	11/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328848	Finished	049-FAP-001	11/1/2015	11/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328849	Finished	156-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328850	Finished	499-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328851	Finished	620-FAP-001	11/1/2015	11/27/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test



## Requested Finished Open WND

% Finished

FO-328852	Finished	036-FP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328853	Finished	025-FP-001	11/1/2015	11/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328854	Finished	007-FP-001	11/1/2015	11/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328855	Finished	001-FP-001	11/1/2015	11/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328856	Finished	005-FAP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328857	Finished	040-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328858	Finished	038-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328859	Finished	028-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328860	Finished	026-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328861	Finished	022-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328862	Finished	017-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328863	Finished	016-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328864	Finished	003-FAP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328865	Finished	006-FP-001	11/1/2015	11/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328866	Finished	050-FAP-001	11/1/2015	11/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328867	Finished	043-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328868	Finished	042-FAP-001	11/1/2015	11/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328869	Finished	062-FP-001	11/1/2015	11/20/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328870	Finished	065-FP-001	11/1/2015	11/13/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328871	Finished	068-FAP-001	11/1/2015	11/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328872	Finished	067-FP-001	11/1/2015	11/13/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328873	Finished	089-FP-001	11/1/2015	11/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328874	Finished	082-FP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328875	Finished	080-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328876	Finished	090-FP-001	11/1/2015	11/24/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328877	Finished	155-FP-001	11/1/2015	11/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328878	Finished	150-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328879	Finished	167-FAP-001	11/1/2015	11/25/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328880	Finished	166-FP-001	11/1/2015	11/24/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328881	Finished	140-FAP-001	11/1/2015	11/17/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328882	Finished	130-FP-001	11/1/2015	11/20/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328883	Finished	193-FAP-001	11/1/2015	11/16/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328884	Finished	189-FP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328885	Finished	510-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328886	Finished	509-FAP-001	11/1/2015	11/11/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328887	Finished	504-FAP-001	11/1/2015	11/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328888	Finished	629-FP-001	11/1/2015	11/4/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328889	Finished	612-FP-001	11/1/2015	11/5/2015	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-328890	Finished	611-FP-001	11/1/2015	11/3/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328891	Finished	609-FP-001	11/1/2015	11/3/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328892	Finished	603-FP-001	11/1/2015	11/5/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328893	Finished	608-FP-001	11/1/2015	11/5/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328894	Finished	603-AHU-010	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328895	Finished	603-AHU-005	11/1/2015	11/9/2015	False	3.00	Replace PRE-filters

**Requested Finished Open WND**

**% Finished**

FO-328896	Finished	603-AHU-004	11/1/2015	11/9/2015	False	3.25	Replace PRE-filters
FO-328897	Finished	603-AHU-003	11/1/2015	11/10/2015	False	1.25	Replace PRE-filters
FO-328898	Finished	603-AHU-002	11/1/2015	11/10/2015	False	2.50	Replace PRE-filters
FO-328899	Finished	603-AHU-001	11/1/2015	11/10/2015	False	2.50	Replace PRE-filters
FO-328900	Finished	629-EXF-011A	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328901	Finished	629-AHU-003	11/1/2015	12/1/2015	False	4.00	Replace PRE-filters
FO-328902	Finished	629-AHU-002	11/1/2015	12/1/2015	False	9.00	Replace PRE-filters
FO-328903	Finished	629-AHU-001	11/1/2015	12/1/2015	False	9.00	Replace PRE-filters
FO-328904	Finished	074-FAP-001	11/1/2015	11/19/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328905	Finished	629-EXF-011B	11/1/2015	11/16/2015	False	1.25	Replace PRE-filters
FO-328906	Finished	016-FCU-001	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328907	Finished	016-FCU-002	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328908	Finished	016-FCU-003	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328909	Finished	016-FCU-004	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328910	Finished	016-FCU-005	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328911	Finished	016-FCU-006	11/1/2015	11/3/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-328912	Finished	016-HVU-001	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328913	Finished	016-HVU-002	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328914	Finished	016-HVU-003	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328915	Finished	016-HVU-004	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328916	Finished	016-HVU-005	11/1/2015	11/14/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328917	Finished	090-HVU-004	11/1/2015	11/6/2015	False	2.50	PM - Air Handling Unit (ANNUAL)
FO-328918	Finished	090-HVU-003	11/1/2015	12/2/2015	False	7.00	PM - Air Handling Unit (ANNUAL)
FO-328919	Finished	090-HVU-002	11/1/2015	11/20/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-328920	Finished	090-HVU-001	11/1/2015	11/18/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-328929	Finished	090-AHU-003	11/1/2015	11/6/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328930	Finished	090-AHU-002	11/1/2015	11/5/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328931	Finished	090-AHU-001	11/1/2015	11/5/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-328932	Finished	049-AHU-005	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328933	Finished	049-AHU-004	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328934	Finished	049-AHU-003	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328935	Finished	049-AHU-002	11/1/2015	11/18/2015	False	3.00	Replace PRE-filters
FO-328936	Finished	049-AHU-001	11/1/2015	11/18/2015	False	3.00	Replace PRE-filters
FO-328937	Finished	060-ACU-001	11/1/2015	11/21/2015	False	1.50	Replace PRE-filters
FO-328938	Finished	074-AHU-004	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328939	Finished	074-AHU-003	11/1/2015	11/21/2015	False	2.00	Replace PRE-filters
FO-328940	Finished	074-AHU-002	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328941	Finished	074-AHU-001	11/1/2015	11/21/2015	False	2.00	Replace PRE-filters
FO-328942	Completed	046-SAF-003	11/1/2015		True		Replace PRE-filters
FO-328943	Finished	096-FP-001	11/1/2015	11/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328945	Finished	046-AHU-001	11/1/2015	11/12/2015	False	4.00	Replace PRE-filters
FO-328946	Finished	062-AHU-004	11/1/2015	11/20/2015	False	2.00	Replace PRE-filters
FO-328947	Finished	062-AHU-003	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters
FO-328948	Finished	062-AHU-002	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters

**Requested Finished Open WND**

**% Finished**

FO-328949	Finished	062-AHU-001	11/1/2015	11/17/2015	False	2.00	Replace PRE-filters
FO-328950	Finished	026-AHU-006	11/1/2015	12/1/2015	False	2.00	Replace PRE-filters
FO-328951	Finished	026-AHU-005	11/1/2015	12/1/2015	False	1.50	Replace PRE-filters
FO-328952	Finished	026-AHU-004	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters
FO-328953	Finished	026-AHU-003	11/1/2015	11/24/2015	False	3.00	Replace PRE-filters
FO-328954	Finished	026-AHU-002	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters
FO-328955	Finished	026-AHU-001	11/1/2015	11/24/2015	False	2.00	Replace PRE-filters
FO-328956	Finished	027-SAF-002	11/1/2015	11/19/2015	False	3.00	Replace PRE-filters
FO-328957	Finished	027-SAF-001	11/1/2015	11/19/2015	False	6.00	Replace PRE-filters
FO-328958	Finished	028-SAF-006	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328959	Finished	028-SAF-005	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328960	Finished	028-SAF-004	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328961	Finished	028-SAF-003	11/1/2015	11/17/2015	False	0.50	Replace PRE-filters
FO-328962	Finished	028-SAF-002	11/1/2015	11/20/2015	False	1.00	Replace PRE-filters
FO-328963	Finished	028-SAF-001	11/1/2015	11/20/2015	False	1.00	Replace PRE-filters
FO-328964	Finished	016-AHU-005	11/1/2015	11/3/2015	False	3.00	Replace PRE-filters
FO-328965	Finished	016-AHU-004	11/1/2015	11/14/2015	False	6.00	Replace PRE-filters
FO-328966	Finished	016-AHU-002	11/1/2015	11/10/2015	False	3.00	Replace PRE-filters
FO-328967	Finished	016-AHU-001	11/1/2015	11/10/2015	False	3.00	Replace PRE-filters
FO-328968	Finished	023-AHU-003	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328969	Finished	023-AHU-002	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328970	Finished	023-AHU-001	11/1/2015	11/6/2015	False	2.00	Replace PRE-filters
FO-328971	Finished	022-HVU-001	11/1/2015	11/12/2015	False	3.00	Replace PRE-filters
FO-328972	Finished	022-HVU-002	11/1/2015	11/9/2015	False	1.50	Replace PRE-filters
FO-328973	Finished	036-SAF-001	11/1/2015	12/3/2015	False	3.00	Replace PRE-filters
FO-328974	Completed	036-RTU-001	11/1/2015		True		Replace PRE-filters
FO-328975	Finished	036-AHU-003	11/1/2015	12/2/2015	False	3.00	Replace PRE-filters
FO-328976	Finished	036-AHU-002	11/1/2015	12/3/2015	False	2.00	Replace PRE-filters
FO-328977	Finished	082-AHU-002	11/1/2015	11/14/2015	False	3.00	Replace PRE-filters
FO-328978	Finished	082-AHU-001	11/1/2015	11/14/2015	False	3.00	Replace PRE-filters
FO-328979	Finished	016-HVU-006	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328980	Finished	016-HVU-007	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328981	Finished	016-HVU-008	11/1/2015	11/7/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-328982	Cancelled	048-AHU-003	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328983	Cancelled	048-AHU-002	11/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-328984	Finished	022-AHU-001	11/1/2015	11/9/2015	False	3.00	Replace PRE-filters
FO-328985	Finished	169-FAP-001	11/1/2015	11/24/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328986	Completed	046-AHU-003	11/1/2015		True		Replace PRE-filters
FO-329081	Completed	046-AHU-002	11/1/2015		True		Replace PRE-filters
FO-329231	Finished	074-AHU-005	11/1/2015	11/21/2015	False	4.00	Replace PRE-filters
<b>E - South</b>			<b>88</b>	<b>86</b>	<b>2</b>	<b>0</b>	<b>98%</b>
FO-330162	Finished	090-HWP-005	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330163	Finished	090-HWP-006	11/1/2015	11/6/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330164	Finished	090-HWP-007	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.

# Requested Finished Open WND

% Finished

FO-330165	Finished	090-HWP-008	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330166	Finished	090-HWP-009	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330167	Finished	090-HWP-011	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330168	Finished	090-HWP-012	11/1/2015	11/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330169	Finished	089-WSS-001	11/1/2015	11/9/2015	False	1.00	PM - Water Softener
FO-330170	Created By PM Schedule	089-AIR-001	11/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-330171	Finished	016-AIR-002	11/1/2015	11/17/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit, checked the belt. Changed oil and oil filter. checked air filter, it was good. checked operation of the pressure switch. Cleaned the unit.							
FO-330179	Finished	089-HRP-011	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330180	Finished	089-HRP-013	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330181	Finished	089-HRP-010	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330182	Finished	089-HRP-012	11/1/2015	11/11/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330183	Finished	089-PHP-005	11/1/2015	11/24/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330184	Finished	089-PHP-005S	11/1/2015	11/24/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330185	Finished	089-PHP-006	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330186	Finished	089-PHP-006S	11/1/2015	11/19/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330187	Finished	089-PHP-007	11/1/2015	11/6/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330188	Finished	089-PHP-008	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330189	Finished	089-PHP-008S	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330190	Finished	089-PHP-009	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330191	Finished	089-PHP-009S	11/1/2015	11/16/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330192	Finished	089-PHP-016	11/1/2015	11/20/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330193	Finished	089-PHP-016S	11/1/2015	11/20/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330194	Finished	089-PHP-007S	11/1/2015	11/6/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330220	Finished	090-CFP-001	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330221	Finished	090-CFP-002	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330222	Finished	090-CFP-003	11/1/2015	11/11/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-330227	Finished	090-HWP-017	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330228	Finished	090-HWP-018	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330229	Finished	090-HWP-019	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330230	Finished	090-HWP-020	11/1/2015	11/4/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330231	Created By PM Schedule	089-AIR-002	11/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-330232	Finished	089-VP-001**	11/1/2015	11/6/2015	False	1.00	PM - Vacuum Pump
FO-330233	Finished	089-VP-002**	11/1/2015	11/6/2015	False	1.00	PM - Vacuum Pump
FO-330234	Finished	006-CRP-001	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330235	Finished	006-CRP-002	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330298	Finished	005-HWP-001	11/1/2015	11/23/2015	False	2.50	PM - Centrifugal Pump, over 1 H.P.
Lubbed the motor and the bearing assembly, however the pump has a bad coupling which has to be replaced. We will order same.							
FO-330299	Finished	006-HWP-001	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330300	Finished	006-HWP-002	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330301	Finished	006-HWP-003	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330302	Finished	006-HWP-004	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330303	Finished	006-HWP-005	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.

# Requested Finished Open WND

% Finished

FO-330304	Finished	005-CRP-001	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							
FO-330305	Finished	005-CRP-002	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							
FO-330306	Finished	005-CRP-003	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							
FO-330307	Finished	005-CRP-004	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc.							
FO-330308	Finished	005-HEX-001	11/1/2015	11/18/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-330393	Finished	096-HWP-001	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330394	Finished	096-HWP-002	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330395	Finished	096-HWP-003	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330396	Finished	096-HWP-004	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330397	Finished	096-HWP-005	11/1/2015	11/17/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330398	Finished	016-AIR-003	11/1/2015	11/18/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit. Checked for any excess noise and vibration, checked the belts. Checked operation of the pressure switch. install drain line for draining oil and changed it's oil, removed and cleaned air filter. cleaned the equipment.							
FO-330404	Finished	007-HWP-001	11/1/2015	11/25/2015	False	0.75	PM - Centrifugal Pump, over 1 H.P.
FO-330405	Finished	007-HWP-002	11/1/2015	11/25/2015	False	0.75	PM - Centrifugal Pump, over 1 H.P.
FO-330406	Finished	007-SUP-002	11/1/2015	11/25/2015	False	0.75	PM - Centrifugal Pump, over 1 H.P.
FO-330407	Finished	089-HWP-004	11/1/2015	11/9/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330408	Finished	089-HWP-004S	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330415	Finished	089-HWP-003	11/1/2015	11/18/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330416	Finished	089-HWP-003S	11/1/2015	11/25/2015	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-330419	Finished	005-ACU-002	11/1/2015	11/18/2015	False	1.50	PM - Water/Air Cooled Condenser
FO-330461	Finished	089-CRP-001	11/1/2015	11/9/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330462	Finished	089-CRP-002	11/1/2015	11/9/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330463	Finished	005-CRP-005	11/1/2015	11/13/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
No lub spots. Checked operation, cleaned, etc. There is also a CRP-006 at this location. It was serviced also.							
FO-330464	Finished	006-CRP-003	11/1/2015	11/24/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-330465	Finished	127-EXF-002	11/1/2015	11/12/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-330466	Finished	127-EXF-001	11/1/2015	11/10/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-330483	Finished	090-HWP-021	11/1/2015	11/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330484	Finished	090-HWP-022	11/1/2015	11/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330485	Finished	090-HWP-543	11/1/2015	11/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330486	Finished	090-HWP-541	11/1/2015	11/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330487	Finished	090-HWP-542	11/1/2015	11/2/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-330488	Finished	090-ERP-542	11/1/2015	11/18/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330494	Finished	007-MAU-001	11/1/2015	11/19/2015	False	1.00	Replace PRE-filters
FO-330990	Finished	090-ACU-CR2	11/8/2015	11/3/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-330991	Finished	090-ACU-CR1	11/8/2015	11/3/2015	False	0.10	PM - Monthly AHU Inspection Clean Room Unit 1
FO-331500	Finished	007-GEN-001	11/12/2015	11/12/2015	False	0.25	Generator Maintenance, Monthly
Checked oil, battery, anti-freeze, and fuel levels. All is ok at this time.							

**Requested Finished Open WND**

**% Finished**

FO-331502	Finished	007-GEN-002	11/12/2015	11/12/2015	False	0.25	Generator Maintenance, Monthly
Checked oil, battery, anti-freeze, and fuel levels. All is ok at this time.							
FO-331504	Finished	090-GEN-001	11/17/2015	11/17/2015	False	1.00	Generator Maintenance, Monthly
FO-331506	Finished	089-GEN-001	11/18/2015	11/23/2015	False	1.00	Generator Maintenance, Monthly
FO-331537	Finished	090-GEN-002	11/12/2015	11/12/2015	False	0.50	Generator Maintenance, Monthly
FO-331546	Finished	006-GEN-001	11/19/2015	11/24/2015	False	0.50	Generator Maintenance, Monthly
FO-331634	Finished	090-HEX-001	11/15/2015	11/6/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331635	Finished	090-HEX-003	11/15/2015	11/9/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331636	Finished	090-HEX-004	11/15/2015	11/9/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-331639	Finished	090-HEX-548	11/15/2015	11/13/2015	False	1.00	PM - Heat Exchanger and Economizer
<b>E - Southeast</b>			<b>194</b>	<b>194</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-330160	Finished	082-DWBP-001	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330161	Finished	082-CWP-001	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330172	Finished	016-HEX-001	11/1/2015	11/25/2015	False	1.00	PM - Heat Exchanger and Economizer
Checked operation of the unit, checked pressure and temp . Checked operation of steam control valve, looked for any leaks. Closed steam shut off valve and opened condensate drain valve to check for tube leaks. cleaned the unit.							
FO-330173	Finished	016-HEX-002	11/1/2015	11/25/2015	False	1.00	PM - Heat Exchanger and Economizer
Checked operation of the unit, checked pressure and temp . Checked operation of steam control valve, looked for any leaks. Closed steam shut off valve and opened condensate drain valve to check for tube leaks. cleaned the unit.							
FO-330174	Finished	016-CRS-001	11/1/2015	11/25/2015	False	0.50	PM - Condensate Return Pump
Checked operation of the unit, checked for any leaks, checked for excess vibration and noise, checked operation of the level control. cleaned the unit.							
FO-330175	Finished	016-CRS-002	11/1/2015	11/25/2015	False		PM - Condensate Return Pump
Checked operation of the unit, checked for any leaks, checked for excess vibration and noise, checked operation of the level control. cleaned the unit.							
FO-330176	Finished	082-CHWP-006	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330177	Finished	082-CHWP-007	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330195	Finished	001-CHWP-004	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330196	Finished	001-CHWP-005	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330197	Finished	001-CHWP-006	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330198	Finished	001-CHWP-007	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330199	Finished	001-CHWP-008	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330200	Finished	001-CHWP-009	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330201	Finished	001-CWP-010	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330202	Finished	001-CWP-011	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330203	Finished	001-CWP-012	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330204	Finished	001-HWP-001	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330205	Finished	001-HWP-002	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330206	Finished	001-HWP-003	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330207	Finished	001-HWP-017A	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-330208	Finished	001-HWP-017B	11/1/2015	12/2/2015	False		PM - Centrifugal Pump, over 1 H.P.

# Requested Finished Open WND

% Finished

FO-330209 Finished 022-HWP-001 11/1/2015 12/1/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

Checked operation of the unit. Checked for any unusual noise and vibration, checked the coupling. Lubricated pump and motor bearings. Cleaned the unit.

FO-330210 Finished 022-HWP-002 11/1/2015 12/1/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

Checked operation of the unit. Checked for any unusual noise and vibration, checked the coupling. Lubricated pump and motor bearings. Cleaned the unit.

FO-330211 Finished 022-HWP-003 11/1/2015 12/1/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

This is a fractional H.P. pump. It is a sealed pump. Checked operation of the pump, checked for any unusual noise and vibration, checked for any leaks. cleaned the unit.

FO-330212 Finished 082-HWP-001 11/1/2015 12/2/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330213 Finished 082-HWP-002 11/1/2015 12/2/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330214 Finished 001-CRP-001 11/1/2015 12/2/2015 False PM - Condensate Return Pump

FO-330215 Finished 001-CRP-002 11/1/2015 12/2/2015 False PM - Condensate Return Pump

FO-330216 Finished 001-CRP-003 11/1/2015 12/2/2015 False PM - Condensate Return Pump

FO-330217 Finished 001-CRP-004 11/1/2015 12/2/2015 False PM - Condensate Return Pump

FO-330218 Finished 022-CRP-001 11/1/2015 11/11/2015 False 0.50 PM - Condensate Return Pump

Checked operation of the unit. Checked for any leaks and excess vibration. Checked operation of the level control. no need for lubrication. Cleaned the unit.

FO-330219 Finished 022-CRP-002 11/1/2015 11/11/2015 False 0.50 PM - Condensate Return Pump

Checked operation of the unit. Checked for any leaks and excess vibration. Checked operation of the level control. no need for lubrication. Cleaned the unit.

FO-330223 Finished 001-CFP-002 11/1/2015 12/2/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330224 Finished 001-CFP-003 11/1/2015 12/2/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330225 Finished 001-CFP-004 11/1/2015 12/2/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330226 Finished 001-CFP-005 11/1/2015 12/2/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330236 Finished 001-FCU-1162-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330237 Finished 001-FCU-1162-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330238 Finished 001-FCU-1162-3 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330239 Finished 001-FCU-1163-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330240 Finished 001-FCU-1163-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330241 Finished 001-FCU-1163-3 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330242 Finished 001-FCU-1165-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330243 Finished 001-FCU-1165-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330244 Finished 001-FCU-1168-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330245 Finished 001-FCU-1168-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330246 Finished 001-FCU-1168-3 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330247 Finished 001-FCU-1168-4 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330248 Finished 001-FCU-1171-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330249 Finished 001-FCU-1171-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330250 Finished 001-FCU-1172-1 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330251 Finished 001-FCU-1172-2 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330252 Finished 001-FCU-1172-3 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330253 Finished 001-FCU-1202 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330254 Finished 001-FCU-1204 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

FO-330255 Finished 001-FCU-1208 11/1/2015 12/2/2015 False PM - Fan Coil/HV/AC Unit

**Requested Finished Open WND**

**% Finished**

FO-330256	Finished	001-FCU-1217.1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330257	Finished	001-FCU-1217.2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330258	Finished	001-FCU-1220-1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330259	Finished	001-FCU-1220-2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330260	Finished	001-FCU-1220-3	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330261	Finished	001-FCU-1220-4	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330262	Finished	001-FCU-1224-1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330263	Finished	001-FCU-1224-2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330264	Finished	001-FCU-1305-1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330265	Finished	001-FCU-1305-2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330266	Finished	001-FCU-1307-1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330267	Finished	001-FCU-1307-2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330268	Finished	001-FCU-1319-1	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330269	Finished	001-FCU-1319-2	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330270	Finished	001-FCU-1319-3	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330271	Finished	001-FCU-1319-4	11/1/2015	12/2/2015	False		PM - Fan Coil/HV/AC Unit
FO-330272	Finished	003-CFP-001	11/1/2015	11/30/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
winterized							
FO-330273	Finished	003-CFP-002	11/1/2015	11/15/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
winterized							
FO-330274	Finished	003-CFP-003	11/1/2015	11/15/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
winterized							
FO-330275	Finished	003-CFP-004	11/1/2015	11/1/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
completed prior to 11/30/15							
FO-330293	Finished	167-HEX-001	11/1/2015	12/2/2015	False		PM - Heat Exchanger and Economizer
FO-330296	Finished	070-CRS-001*	11/1/2015	12/1/2015	False		PM - Condensate Return Pump
FO-330297	Finished	070-CRS-002*	11/1/2015	12/1/2015	False		PM - Condensate Return Pump
FO-330309	Finished	071-CRP-001	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330310	Finished	071-HWP-003	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330311	Finished	071-HWP-004	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330312	Finished	071-HWP-002	11/1/2015	11/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330313	Finished	071-HEX-001	11/1/2015	11/2/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330314	Finished	071-HEX-002	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330315	Finished	071-HEX-003	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330316	Finished	071-HEX-004	11/1/2015	11/3/2015	False	2.00	PM - Heat Exchanger and Economizer
FO-330317	Finished	071-HWP-027	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330318	Finished	071-HWP-028	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330319	Finished	071-HWP-029	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330320	Finished	071-HWP-030	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330321	Finished	071-HWP-031	11/1/2015	11/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330322	Finished	071-HWP-032	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330323	Finished	071-HWP-033	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330324	Finished	071-HWP-034	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330325	Finished	071-HWP-035	11/1/2015	11/9/2015	False	1.00	PM - Heat Pumps (5057 Woodward)



[illegible]

**Requested Finished Open WND**

**% Finished**

FO-330370	Finished	071-HWP-080	11/1/2015	11/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330371	Finished	071-HWP-081	11/1/2015	11/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330372	Finished	071-HWP-082	11/1/2015	11/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330373	Finished	071-HWP-083	11/1/2015	11/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330374	Finished	071-HWP-084	11/1/2015	11/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330375	Finished	071-HWP-085	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330376	Finished	071-HWP-086	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330377	Finished	071-HWP-087	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330378	Finished	071-HWP-088	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330379	Finished	071-HWP-089	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330380	Finished	071-HWP-090	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330381	Finished	071-HWP-091	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330382	Finished	071-HWP-092	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330383	Finished	071-HWP-093	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330384	Finished	071-HWP-094	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330385	Finished	071-HWP-095	11/1/2015	11/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330386	Finished	071-HWP-096	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330387	Finished	071-HWP-097	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330388	Finished	071-HWP-098	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330389	Finished	071-HWP-206	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330390	Finished	071-HWP-207	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330391	Finished	071-HWP-208	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330392	Finished	071-HWP-209	11/1/2015	11/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-330399	Finished	016-CRP-001	11/1/2015	11/18/2015	False	1.00	PM - Condensate Return Pump
Checked operation of the unit, checked for any leak, checked for any excess noise and vibration. checked float level control operation. Cleaned the equipment.							
FO-330400	Finished	016-CRP-002	11/1/2015	11/18/2015	False	1.00	PM - Condensate Return Pump
Checked operation of the unit, checked for any leak, checked for any excess noise and vibration. checked float level control operation. Cleaned the equipment.							
FO-330401	Finished	016-CFP-001	11/1/2015	11/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330402	Finished	016-CFP-002	11/1/2015	11/16/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330403	Finished	016-CFP-003	11/1/2015	11/16/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
the pump is installed and on line, but it is not in operation because we still have chemicals from previous company and using an old chemical pump. I checked the pump operation, checked for ant leaks, checked controller operation.							
FO-330409	Finished	028-HWP-001	11/1/2015	12/2/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
Checked operation of the unit. Checked the pump coupling. checked for any unusual noise and vibration. Greased motor and pump bearings. checked for any leaks. Cleaned the unit.							

**Requested Finished Open WND**

**% Finished**

FO-330410 Finished 028-HWP-002 11/1/2015 12/2/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

Checked operation of the unit. Checked the pump coupling. checked for any unusual noise and vibration.  
Greased motor and pump bearings. checked for any leaks. Cleaned the unit.

FO-330411 Finished 189-HWP-001 11/1/2015 12/1/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330412 Finished 499-HWP-001 11/1/2015 12/1/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330413 Finished 499-HWP-002 11/1/2015 12/1/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330414 Finished 499-HEX-006 11/1/2015 12/1/2015 False PM - Heat Exchanger and Economizer

FO-330417 Finished 504-HWP-001 11/1/2015 12/1/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330418 Finished 504-HWP-002 11/1/2015 12/1/2015 False PM - Centrifugal Pump, over 1 H.P.

FO-330451 Finished 499-CFP-001 11/1/2015 12/1/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330452 Finished 499-CFP-002 11/1/2015 12/1/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330453 Finished 499-CFP-003 11/1/2015 12/1/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-330454 Finished 499-CFP-004 11/1/2015 12/1/2015 False PM - Chemical Feed/Metering Pump/Controller

FO-331525 Finished 637-GEN-001 11/17/2015 11/18/2015 False Generator Maintenance, Monthly

Checked fluids

FO-331527 Finished 637-GEN-002 11/17/2015 11/18/2015 False Generator Maintenance, Monthly

Checked fluids

FO-331640 Finished 609-ACU-002 11/15/2015 12/15/2015 False PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers

FO-331641 Finished 609-ACU-001 11/15/2015 12/16/2015 False PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers

FO-332821 Finished 001-AHU-001 11/28/2015 12/3/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILL WATER COILS.

FO-332822 Finished 001-AHU-001ML 11/28/2015 12/15/2015 False 0.75 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332823 Finished 001-AHU-001O 11/28/2015 12/2/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332824 Finished 001-AHU-002 11/28/2015 12/3/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332825 Finished 001-AHU-002ML 11/28/2015 12/15/2015 False 0.75 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332826 Finished 001-AHU-002O 11/28/2015 12/2/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332827 Finished 001-AHU-003ML 11/28/2015 12/15/2015 False 0.75 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332828 Finished 001-AHU-003O 11/28/2015 12/2/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING CHILLED WATER COILS.

FO-332829 Finished 001-AHU-004O 11/28/2015 12/2/2015 False 0.50 PM - Chilled Water Coils - Drain (Old Main)

DRAINING COILS

**E - West 51 19 32 0 37%**

FO-330276 Finished 003-CRP-001 11/1/2015 11/30/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

completed during summer maint

FO-330277 Finished 003-CRP-002 11/1/2015 11/1/2015 False 0.50 PM - Centrifugal Pump, over 1 H.P.

work done as part of summer maint.

FO-330278 Finished 003-BFP-001 11/1/2015 11/1/2015 False 1.00 PM - Centrifugal Pump, over 1 H.P.

work done during summer maint

# Requested Finished Open WND

% Finished

FO-330279	Finished	003-BFP-002	11/1/2015	1/20/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
serviced pump set							
FO-330280	Finished	003-BFP-003	11/1/2015	11/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
done during summer maint							
FO-330281	Finished	003-TRP-002	11/1/2015	11/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
work done during summer maint. Pump loud but ok							
FO-330282	Finished	003-HWP-014	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
completed							
FO-330283	Finished	003-HWP-012	11/1/2015	1/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
cleand and serviced pump set							
FO-330284	Finished	003-HWP-013	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
done							
FO-330285	Finished	003-HWP-015	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-330286	Finished	003-HWP-016	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
due to death in family did not get done will complete first week of dec.							
FO-330287	Finished	003-HWP-017	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
death in family will get first wk. of dec.							
FO-330288	Finished	003-HWP-018	11/1/2015	12/1/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
death in family will get first wk of december							
FO-330289	Finished	003-WSS-001	11/1/2015	11/23/2015	False	1.00	PM - Water Softener
Per Eldon they found bad valve for tank 1 N.O.P. will write WO for new valve or new head							
FO-330290	Finished	003-HEX-001	11/1/2015	11/15/2015	False	2.00	PM - Heat Exchanger and Economizer
prob with Siemens control set up in reverse...Fixed							
FO-330291	Created By PM Schedule	167-AHU-001	11/1/2015		False		PM - Water/Air Cooled Condenser
FO-330292	Created By PM Schedule	167-AHU-002	11/1/2015		False		PM - Water/Air Cooled Condenser
FO-330294	Created By PM Schedule	167-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330295	Created By PM Schedule	167-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330420	Finished	080-HWP-001A	11/1/2015	11/20/2015	False	2.00	PM - Centrifugal Pump, over 1 H.P.
completed task list							
FO-330421	Created By PM Schedule	080-HWP-012	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330422	Created By PM Schedule	080-HWP-013	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330423	Created By PM Schedule	080-HWP-014	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330424	Created By PM Schedule	080-HWP-015	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330425	Created By PM Schedule	080-HWP-016	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330429	Created By PM Schedule	080-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330430	Created By PM Schedule	080-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330431	Created By PM Schedule	080-HWP-005	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330432	Created By PM Schedule	080-HWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330433	Created By PM Schedule	080-HWP-009	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330434	Created By PM Schedule	080-HWP-011	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330435	Created By PM Schedule	080-HWP-028	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330436	Created By PM Schedule	080-HWP-029	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330437	Created By PM Schedule	080-HWP-040	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330438	Created By PM Schedule	166-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330439	Created By PM Schedule	166-HWP-001A	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.

**Requested Finished Open WND**

**% Finished**

FO-330440	Created By PM Schedule	166-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330441	Created By PM Schedule	166-HWP-006	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330442	Created By PM Schedule	166-HWP-007	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330443	Created By PM Schedule	166-HWP-008	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330444	Created By PM Schedule	166-HEX-001	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330445	Created By PM Schedule	166-HEX-002	11/1/2015		False		PM - Heat Exchanger and Economizer
FO-330446	Created By PM Schedule	156-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330447	Created By PM Schedule	156-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330448	Created By PM Schedule	156-HWP-003	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330449	Created By PM Schedule	156-HWP-004	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330459	Created By PM Schedule	155-HWP-001	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-330460	Created By PM Schedule	155-HWP-002	11/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-331000	Finished	001 SPARE from	11/10/2015	11/10/2015	False	1.00	Generator Maintenance, Monthly
FO-331548	Finished	169-GEN-001	11/26/2015	11/27/2015	False		Generator Maintenance, Monthly
FO-331637	Finished	156-ACU-001	11/15/2015	1/14/2016	False		PM - Water/Air Cooled Condenser

<b>Trades</b>	<b>42</b>	<b>34</b>	<b>7</b>	<b>1</b>			<b>81%</b>
<b>T - Electrician</b>	<b>37</b>	<b>29</b>	<b>7</b>	<b>1</b>			<b>78%</b>

FO-330034	Created By PM Schedule	608-GEN-001	11/3/2015		False		Generator Maintenance, Monthly
FO-330992	Finished	193-GEN-001	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-330993	Finished	612-GEN-001	11/10/2015	11/10/2015	False	2.00	Generator Test
FO-330994	Finished	612-GEN-002	11/10/2015	11/10/2015	False	2.00	Generator Test
FO-330995	Finished	501-GEN-001	11/10/2015	11/10/2015	False	4.00	Generator Test
FO-330997	Finished	608-GEN-001	11/3/2015	11/3/2015	False	4.00	Generator Test
FO-330999	Finished	001 SPARE from	11/10/2015	11/10/2015	False	4.00	Generator Test
FO-331001	Finished	193-GEN-002	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331002	Finished	193-GEN-003	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331003	Finished	193-GEN-004	11/6/2015	11/6/2015	False	1.00	Generator Test
FO-331499	Finished	609-GEN-001	11/17/2015	11/17/2015	False	4.00	Generator Test
FO-331501	Finished	007-GEN-001	11/12/2015	11/12/2015	False	2.00	Generator Test
FO-331503	Finished	007-GEN-002	11/12/2015	11/12/2015	False	2.00	Generator Test
FO-331505	Finished	090-GEN-001	11/17/2015	11/17/2015	False	4.00	Generator Test
FO-331507	Finished	089-GEN-001	11/18/2015	11/18/2015	False	4.00	Generator Test
FO-331509	Finished	066-GEN-001	11/25/2015	11/25/2015	False	4.00	Generator Test
FO-331510	Finished	611-GEN-001	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331512	Finished	629-GEN-001x	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331514	Finished	104-GEN-001	11/24/2015	11/24/2015	False	4.00	Generator Test
FO-331516	Created By PM Schedule	127-GEN-001	11/24/2015		False		Generator Test
FO-331518	Created By PM Schedule	127-GEN-002	11/24/2015		False		Generator Test
FO-331520	Created By PM Schedule	127-GEN-003	11/24/2015		False		Generator Test
FO-331522	Created By PM Schedule	127-GEN-004	11/24/2015		False		Generator Test
FO-331524	Finished	637-GEN-001	11/17/2015	11/17/2015	False	2.00	Generator Test
FO-331526	Finished	637-GEN-002	11/17/2015	11/17/2015	False	2.00	Generator Test
FO-331528	Finished	130-GEN-001	11/25/2015	11/25/2015	False	4.00	Generator Test

**Requested Finished Open WND**

**% Finished**

FO-331530	Finished	507-GEN-001	11/11/2015	11/11/2015	False	4.00	Generator Test
FO-331532	Finished	203-GEN-001	11/17/2015	11/18/2015	False	6.00	Generator Test
FO-331534	Finished	536-GEN-001	11/18/2015	11/19/2015	False	4.00	Generator Test
FO-331536	Created By PM Schedule	090-GEN-002	11/12/2015		False	8.00	Generator Test
FO-331539	Finished	527-GEN-001	11/19/2015	11/19/2015	False	4.00	Generator Test
FO-331541	Finished	048-GEN-001	11/13/2015	11/13/2015	False	4.00	Generator Test
FO-331543	Finished	GEN-001 (Towa	11/11/2015	11/13/2015	False	4.00	Generator Test
FO-331545	Finished	006-GEN-001	11/19/2015	11/19/2015	False	4.00	Generator Test
FO-331547	Created By PM Schedule	169-GEN-001	11/26/2015		False		Generator Test
FO-331549	Created By PM Schedule	060-GEN-001A	11/26/2015		False		Generator Test
FO-331551	Finished	060-GEN-001B	11/26/2015	12/22/2015	True		Generator Test
<b>T - Plumber</b>			<b>5</b>	<b>5</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-328664	Finished	042	11/1/2015	11/6/2015	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/11-2-15 ,,,,,,,,,,
FO-328665	Finished	527	11/1/2015	11/2/2015	False		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-328666	Finished	608	11/1/2015	11/2/2015	False		**CANCELLED JWT PM - Waterless Urinals
FO-328667	Finished	049	11/1/2015	11/6/2015	False	1.50	PM - Waterless Urinals ,,,,,,,,,, TT/11-2-15 ,,,,,,,,,,
FO-328668	Finished	090	11/1/2015	11/6/2015	False	1.50	PM - Waterless Urinals ,,,,,,,,,, TT/11-2-15 ,,,,,,,,,,
<b>Report Total</b>			<b>779</b>	<b>712</b>	<b>53</b>	<b>14</b>	<b>91%</b>