

# Facilities Operations Work Orders Received 2/1/16 through 2/29/16

WO	Received	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1628</b>	
<b>Custodial</b>			<b>171</b>	
<b>High</b>			<b>4</b>	
<b>C-Lighting</b>			<b>2</b>	
FO-338624	2/2/2016	2/5/2016		The Ladies restroom light bulb is out on the first floor
FO-339868	2/17/2016	2/18/2016		Check lights at St. Andrews Hall for Event on Saturday.
<b>C-Sector 02</b>			<b>1</b>	
FO-338768	2/3/2016	2/4/2016	2/4/2016	need soap in the dispensers.
<b>Pest Controller</b>			<b>1</b>	
FO-339544	2/15/2016	2/17/2016	2/17/2016	RM 226 PLEASE SET TRAPS FOR SPIDERS
<b>Medium</b>			<b>5</b>	
<b>C-Sector 02</b>			<b>1</b>	
FO-339741	2/16/2016			Rooms 5324 and 5344 (connected rooms). Please strip and wax lab floors - Please note: Must be done during evening hours. Please contact Krista Mitchell at 577-9028 to schedule time and date.
<b>Pest Controller</b>			<b>4</b>	
FO-338613	2/2/2016			It appears we have mice. Please lay new traps throughout the Chemical Engineering wing.
FO-339418	2/12/2016	2/15/2016	2/15/2016	PEST CONTROL-GLUE PEST STRIPS NEED CHANGING AGAIN, STRIPS ARE FULL, PRIORITY MED
FO-339936	2/18/2016	2/19/2016	2/19/2016	4016.1 PLEASE MOUSE TRAPS
FO-340253	2/23/2016	2/24/2016	2/24/2016	Need bug traps in the audiology clinic room 002 in the basement.
<b>Low</b>			<b>161</b>	
<b>C-Director</b>			<b>1</b>	
FO-339313	2/10/2016			1st floor public ladies room lights over the counter are out.
<b>C-Lighting</b>			<b>88</b>	
FO-338275	2/1/2016	2/1/2016		Wayne State Police - several hallway lights burned out on the 1st and 2nd floors.
FO-338277	2/1/2016	2/1/2016		Wayne State Police - 2nd floor main stairwell lobby - lights around the molding at the ceiling are burned out - also requires carpenters for scaffolding for access per Paul Prouty.
FO-338276	2/1/2016	2/1/2016		Wayne State Police - 2nd floor by the main lobby stairwell - showcase lights are burned out.
FO-338278	2/1/2016	2/1/2016		Lighting crew- please replace lights (48" fluorescent) in room 7406. Three fixtures out
FO-338300	2/1/2016	2/1/2016		1st fl - 2 LO in the POD area of FAB. It was the switch at the bottom the staff did not turn on.
FO-338324	2/1/2016	2/1/2016		lite out in living room.
FO-338328	2/1/2016	2/1/2016		lite in Ms Wilson's office and on the 1st floor - dining room
FO-338345	2/1/2016	2/4/2016		Repair burnt out light in storage area inside of M. Locker Room. Please see Bob Ostrowski on specs. Thank You
FO-338357	2/1/2016	2/9/2016		Replace burned out incandescent bulbs in first fixture and flickering lights in second fixture (may require electrical repair). Three or 4 bulbs in each fixture. Room 385 (388) Manooogian.
FO-338674	2/2/2016	2/3/2016		Re-lamp fixtures in room 101.
FO-338682	2/2/2016	2/3/2016		The Elaine L. Jacob Gallery (room 0402, Old Main) needs approximately 40 light bulbs for our next exhibition. The light bulbs needed are Sylvania flood 90W 130V. Thank you!
FO-338744	2/3/2016	2/4/2016		Light is out in the hallway in front of office 3004
FO-338760	2/3/2016	2/4/2016		1st Floor, Lobby - 2 Candelabra lights out.
FO-338764	2/3/2016	2/3/2016		1 LO - Storage room in the basement. Henrietta says you can come through the back door.

WO	Recieved	Finished	Total	Request
FO-338791	2/3/2016	2/4/2016		In rear hallway- between Engineer's office & mechanical room- please replace burned out fluorescent lights. Major government event next Monday.
FO-338795	2/3/2016	2/8/2016		Rm. 3134 has 4 fluorescent light bulbs out that need replacing.
FO-338824	2/4/2016	2/4/2016		6th floor, 1st unisex restroom, replace light bulb.
FO-338825	2/4/2016	2/8/2016		Purdy Library 1st Floor, Check Out Desk  Lamp Replacement Requested: 2 lights out behind Check Out Desk  Thank you.
FO-338894	2/4/2016	2/9/2016		rm 1162 3 fluorescents out
FO-338912	2/4/2016	2/16/2016		Lab 2116 - Relamp 1 Light Fixture Inner lab 2116- relamp 1 light fixture Lab 2136 - Relamp 2 light fixtures Lab 2106 - Relamp Light 4 -LLight fiixtures Inner lab -light fixture Lab 2248 -Relamp 2-light fixtures Lab 2258 - Relamp - 2 Light fixtu
FO-338917	2/4/2016	2/22/2016		RM 325 LIGHTS OUT
FO-338991	2/5/2016	2/8/2016		Lab 160 - 7 LO
FO-338993	2/5/2016	2/8/2016		Lab 154 - 8 LO
FO-338994	2/5/2016	2/8/2016		Lab 152 - 1 LO
FO-339025	2/5/2016	2/8/2016		Lab 150 - 3 LO
FO-339028	2/5/2016	2/8/2016		Office 156 - 1 LO
FO-339043	2/5/2016	2/8/2016		Scott Hall room 114 mens locker room the locker area has two lights out. Contact Dave Barnett 313577-3233.
FO-339065	2/5/2016	2/8/2016		Room 113 and 114 inside room 115 each have burnt out bulbs. The fixtures closest to the window in each area have bulbs that are burnt out. Contact Tracy Schuck 7-1277 or Sheryl MacGillis 7-1446 for access to the room.
FO-339074	2/6/2016	2/10/2016		in study room 122 the lights are dim. thanks Michelle
FO-339083	2/8/2016	2/9/2016		*The online form would not allow me to select BLDG-Entire Building - At Manoogian Hall the lights are not working in many of the network equipment closets. These rooms are:  Room 006 Room 056 Room 083 Room 156 Room 254 Room 278 Room 306 Ro
FO-339125	2/8/2016	2/9/2016		Room 118 - 1 LO
FO-339127	2/8/2016	2/10/2016		Room 220 - 3 LO
FO-339175	2/9/2016	2/9/2016		Rooms 5625 and 5530 have lights out. Please replace.
FO-339187	2/9/2016	2/10/2016		4th floor- Replace light bulb in sitting area north of elevators near telephone equipment room 4332.
FO-339189	2/9/2016	2/9/2016		Law school, 2nd floor stairwell near Partrich Auditorium, replace light bulb. It was not the bulbs it was the switch that was off.
FO-339192	2/9/2016	2/9/2016		Law school, 1st floor stairwell near Partrich Auditorium, replace light bulb. It was not light bulb the switch was off.
FO-339193	2/9/2016	2/10/2016		On Cohn side, replace 3 light bulbs in hallway.
FO-339195	2/9/2016	2/11/2016		Stairwell A 4th 1, 3rd, 1 2nd 1, Landing 1, basement landing 1, basement 5, stairwell B 5th 1, 3rd 1, 1st 1, basement 1, Stair C 5th 1, D 5th 1, 4th 1, 3rd landing 1, 2nd floor landing 1, 2nd 1, basement 4.
FO-339214	2/9/2016	2/10/2016		File room very dark rm 2701
FO-339237	2/9/2016	2/10/2016		rm 3301 2 out 9:30-5pm union office

WO	Recieved	Finished	Total	Request
FO-339321	2/11/2016	2/11/2016		Please replace the burned light bulbs in the Bonstelle Room and the in the north west stairwell with 15watt medium base light bulbs. Thanks
FO-339322	2/11/2016	2/12/2016		Please replace burned out lights in the elevator.
FO-339323	2/11/2016	2/12/2016		Please replace burned out lights in the elevator.
FO-339324	2/11/2016	2/12/2016		Please replace burned out lights in the hall by the elevators.
FO-339339	2/11/2016	2/12/2016		Light fixture in room 150 are beeping. Please repair so that beeping stops.
FO-339353	2/11/2016	2/12/2016		Lighting Department-please replace burned out - 4' fluorescent tubes 2nd floor IDF room.
FO-339359	2/11/2016	2/12/2016		staircase 5 out inner lobby 5-6 sconces out and outer lobby 2 sconces out
FO-339376	2/11/2016	2/11/2016		The Damon J Keith elevator light went out. There is a bad fuse inside of the elevator since last summer. The elevator company has not responded in a timely manner to handle this situation. At least 5 phone calls have been placed to the company.
FO-339419	2/12/2016	2/12/2016		please have electricians replace light bulb in room contractor has no light in room high priority
FO-339461	2/12/2016	2/15/2016		The lights kept clicking off & on in computer lab 325. Can someone take a look at the sensors to make sure they are functioning correctly.
FO-339469	2/12/2016			need ceiling lights replaced.
FO-339480	2/12/2016	2/15/2016		room 114 copier room has a light panel which is not working. thanks Michelle
FO-339763	2/16/2016	2/18/2016		replace out light in ladies r/r 401 thx
FO-339765	2/16/2016	2/18/2016		plz replace out light -3d flr ladies r/r - first stall -thx
FO-339778	2/16/2016	2/17/2016		Relamp light ixture
FO-339779	2/16/2016	2/17/2016		Lighting Fixture located betwee3n Security Desk and Room 1102 has debris laying on lens. Vestibule relamp recessed fixture.
FO-339780	2/16/2016	2/17/2016		Relamp recessed light fixture over vending machines
FO-339781	2/16/2016	2/17/2016		Women's Locker Rooom - Reramp two light fixtures that are out.
FO-339791	2/16/2016	2/17/2016		Please replace burned out lights in the lab.
FO-339792	2/16/2016	2/17/2016		Please replace burned out lights in the office.
FO-339794	2/16/2016	2/17/2016		Please replace burned out lights in the lab.
FO-339821	2/17/2016	2/17/2016		replace light bulb in fixture outside room 136 in stairwell to the 2nd floor. Inside South East Carriage House black door. Replace bulbs in basement stairwell outside mechanical door in Basement of East Carriage House
FO-339824	2/17/2016	2/17/2016		Need a new light bulb in the living room.
FO-339832	2/17/2016	2/17/2016		Light crew: Please replace burned out light bulbs in the middle stairway by vending machines bulbs are burned out in the high ceiling and also in basement next to vending machines. This is the second request It is too dark at nights and early in mornings.
FO-339859	2/17/2016	2/25/2016		Lighting department-please replace 4' tubes in 3 fixtures
FO-339906	2/18/2016	2/19/2016		Relamp two exterior recessed lights at building entry.
FO-339917	2/18/2016	2/18/2016		Lite out in hallway leading to men's rr - Studio Theater
FO-339987	2/19/2016	2/19/2016		Room 225 - 2 LO
FO-340019	2/19/2016	2/19/2016		4 lights out
FO-340076	2/22/2016	2/23/2016		Lights out on UGL Third Floor: 27 tubes in need of replacement.
FO-340083	2/22/2016	2/23/2016		Re-lamp fixture in room 120.
FO-340084	2/22/2016	2/23/2016		Re-lamp fixtures in room 101.
FO-340139	2/22/2016	2/29/2016		broken glass cover over light fixture needs replacing
FO-340151	2/22/2016	2/24/2016		1st floor - Women's R/R - 1 LO over.
FO-340152	2/22/2016	2/24/2016		2nd fl - Outside Unisex R/R - 1 LO
FO-340278	2/23/2016	2/24/2016		2nd floor, Room #246, Office ceiling light keeps flickering, bulb may need replaced.
FO-340329	2/24/2016	2/25/2016		Lighting Department-please replace several burned out 4' fluorescent tubes in storage room, inside control room, within the tv studio. Contact engineer if necessary
FO-340336	2/24/2016	2/25/2016		Relamp light fixture.

WO	Recieved	Finished	Total	Request
FO-340363	2/24/2016	2/25/2016		3rd floor - Stairwell B - 3 LO
FO-340364	2/24/2016	2/25/2016		3rd Floor - Stairwell C - 1 LO
FO-340366	2/24/2016	2/26/2016		Room 143 - 8 LO
FO-340382	2/24/2016	2/26/2016		8 lights out in this area. Please replace. Thank you.
FO-340384	2/24/2016	2/26/2016		Loading dock area. Two lights are out and it makes the loading dock rather dark. Please replace. Thank you.
FO-340390	2/24/2016	2/26/2016		Light changers please change lights in room 154.
FO-340437	2/24/2016	2/25/2016		Request to have light bulbs replaced in room 2542 in the Engineering Development Center.
FO-340453	2/25/2016	2/29/2016		Light is out in the hallway in front of room 3105
FO-340513	2/25/2016	2/29/2016		basement men's restroom-please fix light out in entry area. thank you
FO-340538	2/26/2016	2/26/2016		lites out in elevators in DJ Keith Center. The elevator company has been notified 5 times since last summer. They are waiting on a part to repair the fuse.
<b>C-Materials</b>			<b>9</b>	
FO-338296	2/1/2016	2/2/2016	2/2/2016	Recycling bin on the 4th floor of Hudson Webber @ Karmanos needs to be emptied and replaced.
FO-339050	2/5/2016	2/12/2016	2/12/2016	R/R RM 150/CMD/AD/SVC CTR OFC NEED PAPER SHREDDING BIN EMPTIED/OR REPLACED W/EMPTY ONE
FO-339505	2/15/2016			Room 4374 - Pick up and replace recycling bin.
FO-339529	2/15/2016			Room 1158 - Request for 1 recycling bin to be dropped off.
FO-339550	2/15/2016			Room 270 Recycling bin - pick up and replace.
FO-340089	2/22/2016			Medium Priority: Empty and R/R RM 1215 replace large gray recycle bin in Admissions suite.
FO-340153	2/22/2016			Recycling bins on the 1st, 2nd, and 3rd floors are full and need to be picked up and replaced. Requester needs an additional recycling bin placed on the 2nd floor.
FO-340324	2/24/2016			4th floor of the Hudson Webber Building - pick up recycling bin.
FO-340546	2/26/2016			3rd Floor - Room 3108 (Work Room) - Recycling bin - pick up and replace.
<b>C-Projects</b>			<b>1</b>	
FO-338820	2/4/2016			We need the vents cleaned for the entire first and second floors of the Law Library. See Mary Bonk for details. 7 6177
<b>C-Relief</b>			<b>1</b>	
FO-339719	2/16/2016			Women's bathroom beside elevator on 4th floor, toilet is plugged.
<b>C-Repair</b>			<b>19</b>	
FO-338712	2/3/2016			stand on auto scrubber serial# 3510151308196, Model# sc 1600 x2OD. Plastic cap cover that catches water that flows into machine is broken(cracked). on first floor room 1203.
FO-338823	2/4/2016	2/4/2016		6th floor east side women's restroom roll towel dispenser is broken. (1st restroom off the elevator).
FO-338833	2/4/2016	1/26/2016		Transfer Supplies from (FPM/STOCKROOM), to basement stock closet of (APPLEBAUM).
FO-338939	2/5/2016			repair hose that connect to the squeegee also the wire cable to the squeegee
FO-339066	2/6/2016	2/17/2016		Please repair upright vacuum handle . Also, the back pack vacuum is not picking up.
FO-339067	2/6/2016	2/17/2016		Please repair upright vacuum handle. Also, repair backpack vacuum.
FO-339079	2/7/2016	2/23/2016		There is no toilet paper dispenser in one of the stalls in this room. Please repair.  Thanks
FO-339154	2/9/2016	2/10/2016		R/R RM 00128/MENS RR TOILET STALL TOILET PAPER DISPENSER HAS BROKEN NEEDS REPLACING
FO-339254	2/10/2016			Embalming lab need white paper towel roll in the dispenser or the dispenser needs to be replace so that the brown paper towel roll will fit in a dispenser.
FO-339396	2/11/2016	2/12/2016		One of the soap dispensers is missing in the Men's room on the 2nd floor of FAB.
FO-339728	2/16/2016	2/17/2016		The advance walk-behind ser:DQCT240649048087 just got a new squeeze for it now it won't pick-up water can we check this machine out.

WO	Recieved	Finished	Total	Request
FO-339902	2/18/2016	2/19/2016		NEW EQUIPMENT: A REQUEST FROM (A.D./DAVID, H.) TO LABEL AND INSTALL A MAGNET BAR TO NEW VACUUM CLEANER UP RIGHT. (Sanitaire/SC887/Ser.314290008747)
FO-339907	2/18/2016	2/18/2016		EQUIPMENT TRANSFER: Back to building from main office stockroom. Advance/Adfinity Auto, Scrubber
FO-340054	2/22/2016	2/22/2016		Vacuum brush needs replaced.
FO-340130	2/22/2016	2/26/2016		Carp med. Priority Replace hand towel dispenser in Boiler rm. NOP
FO-340231	2/23/2016	2/24/2016		4th floor Men's room soap dispenser is broken and needs repairing
FO-340372	2/24/2016	2/25/2016		349.3 men's restroom broken soap dispenser.
FO-340397	2/24/2016	2/25/2016		9th floor - Unisex restroom, near the water fountains, the toilet dispenser is broken.
FO-340565	2/26/2016	2/29/2016		Wayne State Police - 2nd floor men's restroom - towel dispenser broken.
<b>C-Sector 01</b>			<b>8</b>	
FO-338948	2/5/2016			2 cases of dial soap.
FO-338949	2/5/2016			2 cases of dial soap.
FO-338950	2/5/2016			2 cases of dial soap.
FO-338951	2/5/2016			2 cases of dial soap.
FO-338952	2/5/2016			2 cases of dial soap.
FO-338953	2/5/2016			2 cases of dial soap.
FO-339078	2/7/2016	2/22/2016		The gojo soap dispenser in the handicapped restroom is empty. Please replace. Thanks
FO-340337	2/24/2016			2 cases of gojo soap.
<b>C-Sector 02</b>			<b>5</b>	
FO-339128	2/8/2016	2/18/2016		Please clean the floor to lab 4254. An inspector indicated that the floors in this room are dirty and should be cleaned for proper BSL2 compliance.
FO-339132	2/8/2016			Research lab and inner rooms all need to be wiped down. Floors need to be stripped & waxed. Rooms are currently empty but have been assigned to a new faculty member that is due to be here 3/1/16. Work needs to be completed before rooms are occupie
FO-339798	2/16/2016	2/25/2016		Lab 2305 located in the Occupational-Physical therapy suite 2290, needs floor cleaned and mopped.
FO-340528	2/26/2016			I was wondering if I could get some rooms cleaned up for an event on March 12th. We would need to have the commons area cleaned and the tables wiped down. The floor mopped in 540 and the garbage emptied. The atrium upstairs the windows cleaned and the floo
FO-340537	2/26/2016			Please have custodians strip and wax first floor corridors. Please note: Must be done by March 9. Would prefer to have the work done on Saturday, March 5. All charges for overtime work should be direct billed to index 133121. Please contact Kris
<b>C-Sector 03</b>			<b>3</b>	
FO-338696	2/2/2016	2/12/2016		The ladies public restrooms need to have mold growing under the hand dryers cleaned away please.
FO-339468	2/12/2016	2/20/2016		Please shampoo carpet and apply stain remover for both of these faculty's offices. Room 3133, and Room 3145. Thank
FO-340392	2/24/2016	2/25/2016		The roof at the north end of the Prentis Building is leaking water into the building. Please send someone to clean and stop the leak.
<b>C-Sector 04</b>			<b>1</b>	
FO-339502	2/15/2016	2/17/2016		1 case of dial soap.
<b>C-Sector 05</b>			<b>3</b>	
FO-338940	2/3/2016	2/8/2016		Requesting custodial attention. Please make sure the back hallway behind GL 100 is swept and mopped and the burned out light bulb are replaced by Monday morning. Especially to back hallway, for outside group event Monday evening, Feb. 8. event time 3-6:30
FO-339448	2/12/2016			Floor of lab 2330 needs to be cleaned and mopped. Left sign on door last Friday 2/5/2016 for this request but floor has still not been addressed. Can we get the floor in lab 2330 cleaned/mopped?
FO-340094	2/22/2016			Per discussion with Steve Johnson, Hall of Fame room 1200 reserved for carpet cleaning on Monday, May 2, 2016. Thank you.

WO	Recieved	Finished	Total	Request
<b>C-Sector 06</b>			<b>5</b>	
FO-338810	2/3/2016			Carpet needs to be cleaned on the 2nd floor of the Law Library, including the RBK Room 2392. No spot cleaning! Do not clean study rooms. Requested RUSH OPERATION. Contact Mary Bonk for specifics. 7-6177
FO-338944	2/5/2016	2/11/2016		4 cases of gojo soap.
FO-338946	2/5/2016	2/11/2016		2 cases of gojo soap.
FO-340470	2/25/2016			plz have carpet stain cleaned in rm 425(Conference Room) large cup of coffee spilled this morning. some clean-up was done at best. still a large spot on carpet. (Very important meetings are scheduled in room 425 today from 1130am - 330pm). thank you
FO-340512	2/25/2016			still require cleaning of carpet stain in room 425 (Conference Room) earlier efforts to clean stain resulted in re-appearance of stain after area dried. thank you
<b>C-Sector 07</b>			<b>2</b>	
FO-339509	2/15/2016	2/16/2016		Purdy Library 1st Floor Staff Women's Restroom is out of paper towel. Please refill. Thank you.
FO-339916	2/18/2016	2/19/2016		OFFICE NEED CLEANING AFTER EXPERIENCING LEAK YESTERDAY. ROOM 0224. Task is complete.
<b>C-Sector 09</b>			<b>6</b>	
FO-339315	2/10/2016			please thoroughly vacuum office# 221 as soon as possible. thank you
FO-340409	2/24/2016			2 cases of dial soap.
FO-340410	2/24/2016			2 cases of dial soap.
FO-340411	2/24/2016			2 cases of dial soap.
FO-340413	2/24/2016			2 cases of dial soap.
FO-340416	2/24/2016			4 cases of dial soap.
<b>C-Sector 10</b>			<b>1</b>	
FO-339262	2/10/2016			Stock Issue Request: Back Brace size large
<b>Pest Controller</b>			<b>8</b>	
FO-338818	2/4/2016	2/5/2016	2/5/2016	At about 7:57 pm I got a report from Public Safety of a rodent running around somewhere on the westside of the building. Could you look in to this Sir? Thanks..
FO-339093	2/8/2016	2/12/2016	2/12/2016	Bedbugs have been seen around front desk reception area.
FO-339157	2/9/2016	2/22/2016	2/22/2016	Purdy Library 1st Floor Reference Area  Cockroaches (2) reported in reference area. Please set traps.  Thank you.
FO-339169	2/9/2016	2/9/2016	2/9/2016	EXTERMINATION FOR MICE. ROOM 5300.
FO-339485	2/15/2016	2/15/2016	2/15/2016	A mouse is still in the lab. They previously put down some catchmaster but the mouse is still in lab 1305. Thank you.
FO-339842	2/17/2016	2/17/2016	2/17/2016	We have been seeing roaches in the basement by lecture room and both restroom
FO-340385	2/24/2016	2/25/2016	2/25/2016	Pest control: R/R RM 00050/MECH RM Please apply pest control for roaches in mechanical room 50. priority: low.
FO-340448	2/25/2016	2/29/2016	2/29/2016	Treat Ground Supervisor vehicle for bed bugs.
<b>Routine</b>			<b>1</b>	
<b>Pest Controller</b>			<b>1</b>	
FO-339225	2/9/2016	2/10/2016	2/10/2016	Inspect and treat Custodial Break room in Basement of 5057 Woodward Ave.
<b>Engineering</b>			<b>652</b>	
<b>Emergency</b>			<b>20</b>	
<b>E - Auxiliary</b>			<b>1</b>	
FO-340124	2/22/2016	2/26/2016		TRANSMITTER BLDG LOST AIR COND
<b>E - Command Center</b>			<b>1</b>	
FO-340091	2/22/2016	2/24/2016		BOILER DOWN TO IGNITION FAILURE.
<b>E - MedPharm</b>			<b>2</b>	
FO-339282	2/10/2016	2/10/2016		RM 411 LOW HUMIDITY, ANIMAL RM

WO	Recieved	Finished	Total	Request
FO-339438	2/12/2016	2/12/2016		STRWL D FROM 3RD - 1ST FLR SMELL SMOKE
<b>E - North</b>			<b>1</b>	
FO-338773	2/3/2016	2/3/2016		FIRE ALARM.
<b>E - Preventative Maintenance</b>			<b>6</b>	
FO-338918	2/4/2016	2/4/2016		5TH FL LADIES RM SINKS PLUGGED, WATER ON FLOOR
FO-339062	2/5/2016	2/5/2016		RM 3359 TOO HOT, CRITICAL EQUIPMENT WITHIN RM
FO-339579	2/15/2016	2/17/2016		RM 109 RADIATOR LEAKING, FLOODING IN AREA
FO-339961	2/18/2016	2/19/2016		HANDICAP ENTRY DOOR #071 08E DOOR CLOSURE HAS SNAPPED/BROKEN PLS CK & SECURE DOOR (note: schedule wo for Carp 2/19/16)
FO-340427	2/24/2016	2/26/2016		RM 302 CLNG LEAKING DOWN WALL INTO ELECTRICAL BOX ON WALL
FO-340515	2/25/2016	2/25/2016		BAD LEAK AT STRUCTURE 4 PLEASE UPDATE SERVICE CENTER
<b>E - South</b>			<b>8</b>	
FO-338960	2/5/2016	2/5/2016		LAB 30 TOO HOT
FO-339264	2/10/2016	2/10/2016		FAP ALARM IS SNDNG
FO-339298	2/10/2016	2/10/2016		FAP FIRE ALARM IS SNDNG SEE RESULTS
FO-339385	2/11/2016	2/12/2016		1ST FLR MAIN ENTRANCE BURNING SMELL(NOTE ENG SENT ELEC) R/R RM 6152 AIR COMPRESSOR #1 CONTACTORS ARE STICKING UNIT ISN'T SHUTTING OFF CAUSING BURNNING SMELL
FO-339446	2/12/2016	2/12/2016		CALLED SCHINDLER ELEV CO FOR ONLY HAS AN ENTRAPMENT REF #51815337
FO-339747	2/16/2016	2/16/2016		GAS SMELL. 2ND FLOOR INCLUDING ROOM 2100.
FO-340381	2/24/2016	2/29/2016		RM 4121 ONLY WINDOW IS LKNG CAUSING CARPET IN & AROUND WINDOW LEAKAGE TO BE SATURATED W/WTR ALSO SHORTING OUT POWER STRIPPED CONNECTED TO WALL OUTLET
FO-340391	2/24/2016	2/24/2016		RM 4324 CEILING FELL IN
<b>E - West</b>			<b>1</b>	
FO-339447	2/12/2016	2/12/2016		CALLED SCHINDLER ELEV CO FOR ONLY ELEV ENTRAPMENT? FLR REF #51816464
<b>High</b>			<b>332</b>	
<b>E - Auxiliary</b>			<b>23</b>	
FO-338617	2/2/2016	2/4/2016		MID CITY GRILL HEAT NOT WORKING
H-57124	2/4/2016	2/6/2016		URGENT (resident just moved in): bathroom sink is leaking
H-57154	2/5/2016			Water shoots out of kitchen faucet when turned on.authenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.200
H-57190	2/5/2016	2/10/2016		The Garbage Disposal STILL broke. Someone came to fix it when we were outside and he did not fix it. It is still broke. It's urgent. authenticated user: Ahmad Aburaideh - fs3668 requester ip address: 35.16.67.209
H-57182	2/7/2016			cold water tap in kitchen is not working moderate leakage of water continuously.  authenticated user: Manaswini Remidi - fs2524requester ip address: 141.217.23.175
FO-339240	2/10/2016	2/10/2016		FIRE ALARM. PANEL IN ROOM 401.
FO-339355	2/11/2016	2/11/2016		RM 00413 HAS A LOW HUMDITY
H-57258	2/11/2016	2/12/2016		URGENT: The fire alarm system needs to be reset ASAP. There's an active fire alarm for 1005 which is incorrect and is causing the fire alarm to set off every few hours. We tried to reset it on the front desk fire alarm panel but it aborts every time we tr
H-57312	2/12/2016	2/17/2016		The apt temperature is cold. If heat is working than it could be that the windows need plastic put on them. If so, please put in a work order at the front desk. authenticated user: Afnan Abduljaber - ft6597 requester ip address: 66.87.115.109
H-57303	2/12/2016	2/17/2016		The heater shut down. Need help asap. authenticated user: Pawan Vedanti - fr6588 requester ip address: 35.16.67.28

WO	Recieved	Finished	Total	Request
H-57314	2/14/2016	2/17/2016		Fire alarm at the front desk goes off sporadically. Notifications need to be tended to, adjusted, or cleared. If you cannot do so than please elevate this issue to proper personnel so that it can be resolved. RA Vivien Okechukwu authenticated user: Vivi
H-57309	2/15/2016	2/17/2016		Is leaking water from my sink authenticated user: Guilherme Henrique Domingos De Franco - fy6492 requester ip address: 35.16.38.172
FO-339803	2/16/2016	2/18/2016		RM 207 IS TOO COLD
FO-339818	2/17/2016	2/18/2016		MOTOR CITY GRILL FRONT ENTRANCE DOOR WILL NOT UNLOCK.
FO-339857	2/17/2016	2/26/2016		MOTOR CITY GRILL FRONT ENTRANCE DOOR WILL NOT UNLOCK.
H-57390	2/20/2016	2/23/2016		The water faucet has sprung a leak near the end of the faucet where the water comes out. It may be able to be caulked, but it is on the metal and caused by rust. authenticated user: Tian Jin - fd5133 requester ip address: 35.16.66.53
H-57393	2/22/2016	2/23/2016		Bathroom toilet will not refill with water, which will keep making noise. authenticated user: Michael Chang-Songlue - fa2941 requester ip address: 35.16.66.42
FO-340235	2/23/2016	2/23/2016		HIGH TEMP ALARM. ROOM MDF.
FO-340236	2/23/2016	2/23/2016		POWER FAILURE ALARM. ROOM 133.1.
H-57436	2/23/2016	2/25/2016		The tap in the kitchen sink has been leaking from last 6 months and nothing has been done after around a dozen complaints yet, apart from a few visits and words in return like 'this is 100 years old building, what else can you expect'.  The tap immedia
FO-340370	2/24/2016	2/24/2016		FIRE TROUBLE ALARM
H-57474	2/25/2016	2/26/2016		My garbage disposal has a crack in it, and leaks whenever I do dishes. I think it needs to be replaced, unless there is a way to clog the leak. authenticated user: Joshua Loukotka - fi6490 requester ip address: 141.217.232.144
H-57484	2/27/2016			The smoke detector in apartment 1005 continuously went off this weekend. An engineer was called to the building and was unable to get the alarm to reset since the request reset was aborted. The engineer determined that the smoke director is very dirty and
<b>E - Command Center</b>			<b>10</b>	
FO-338743	2/3/2016	2/17/2016		Pumps will not start on condensate transfer tank in basement
FO-338811	2/3/2016			Please repair actuator and pilot positioners.
FO-338839	2/4/2016	2/5/2016		Carrier RTU's 1-4: Please set up trends for the following for EACH rooftop unit:  Supply Fan CFM, Static Pressure, & Speed Return Fan CFM, Static Pressure, & Speed  No duration was specified.  Once trending has been set-up, please plan to forward
FO-338879	2/4/2016	2/8/2016		CONTROLS (HIGH) R/R BSMT AHU #3 DISCHARGE TEMP SETTING OUT OF CONTROL OVER HEATING BUILDING IN AUTO. OUT IN MANUAL 72F. REPAIR,REPLACE, REPROGRAM CONTROLS
FO-338904	2/4/2016	2/18/2016		Controls -- High Priority R/R RM 00045/MECH RM Found inside of #2 Boiler Control panel wet and the bottom of panel still containing water. Smelled of electrical fire. Shut power off to boiler controls.
FO-338943	2/5/2016	2/8/2016		Trade: Command Center Priority: VERY HIGH R/R RM 00030/LAB Please make needed repairs to the exh. controller for the ICPMS machine in Lab 30. The plasma temp increased yesterday at 11:10am, and again at 11:10pm. The only reason this would happen is a lo
FO-338954	2/5/2016	2/9/2016		SF-4 keeps tripping on freezestat.  Please investigate.  Also, can OA intake be reduced temporarily to prevent unit from shutting down until investigation has been completed.



WO	Recieved	Finished	Total	Request
FO-339496	2/15/2016	2/26/2016		CONTROLS GROUP-PLEASE REPAIR #1 BOILER, BOILER DOWN LOOKS LIKE CONTROLLER BURNED HIGH PRIORITY
FO-339497	2/15/2016	2/15/2016		Siemens controls for heating loop not maintaining proper temperature. See Greg Ray for details.
FO-340526	2/26/2016	2/26/2016		Repair Cam on combustibile air on Boiler #1
<b>E - MedPharm</b>			<b>100</b>	
FO-338292	2/1/2016			RM 00225/DLAR HAS POSITIVE AIR PRESSURE SHOULD BE NEGATIVE
FO-338293	2/1/2016	2/1/2016		RM 00514/DLAR HAS POSITIVE AIR PRESSURE SHOULD BE NEGATIVE
FO-338295	2/1/2016	2/2/2016		RM 00522/DLAR HAS POSITIVE AIR PRESSURE SHOULD BE NEGATIVE
FO-338303	2/1/2016			FAP FIRE TROUBLE ALARM
FO-338304	2/1/2016			RM 5229 TOO HOT
FO-338315	2/1/2016	2/3/2016		#2 & #5 ELEVATORS ARE NOT WORKING. PLEASE VERIFY.
FO-338330	2/1/2016	2/1/2016		RM 0243 HIGH TEMP AND HIGH HUMIDITY
FO-338353	2/1/2016			RM 2248/CLASS RM HAS A LITE COVER HANGING DOWN-SAFETY ISSUE
FO-338354	2/1/2016	2/3/2016		BODY COOLER IS WARM. ROOM 521.
FO-338371	2/1/2016	2/2/2016		Rooms 218-234 are too warm
FO-338599	2/2/2016	2/8/2016		2ND ELEV LEAK FROM PENTHOUSE DOWN TO THE BSMNT
FO-338614	2/2/2016	2/3/2016		CEILING METAL COVER HAS FALLEN. ROOM 3141.
FO-338685	2/2/2016	2/2/2016		RM 1233 THERE IS A LEAK COMING FROM THE WASHER
FO-338723	2/3/2016	2/8/2016		FIRE TROUBLE ALARM.
FO-338750	2/3/2016			RM 6321 TOO HOT
FO-338759	2/3/2016	2/10/2016		HIGH TEMPS. 4TH FLOOR ANIMAL QUARTERS ESPECIALLY ROOM 414.
FO-338761	2/3/2016			RM 4321 TEMP ALARM HI/LOW?
FO-338771	2/3/2016	2/3/2016		RM 354 BURNING SMELL WHEN AIR BLOWS
FO-338780	2/3/2016	2/23/2016		FIRE ALARM PANEL REPORTING TROUBLE
FO-338781	2/3/2016	2/3/2016		RM 4465 WALK IN HAS A TEMP ALARM ?HI/LOW
FO-338782	2/3/2016			RM 5258 IS TOO HOT
FO-338783	2/3/2016			RM 5258 AIR HANDLING IS TOO LOUD
FO-338812	2/3/2016	2/3/2016		RM 419 & 423 LOW TEMP ALARM
FO-338831	2/4/2016			RM 5552 WALK IN COLD RM BOX ISN'T WRKNG TOO WARM
FO-338876	2/4/2016	2/23/2016		LEAK COMING FROM VACUUM BREAKER. ROOM 4126.
FO-338942	2/5/2016	2/23/2016		3RD FL NO HOT WATER 3108
FO-338980	2/5/2016			RM 1200 TOO HOT
FO-339063	2/5/2016			PLEASE CALL SONYA 577-1576 MONDAY MORNING
FO-339095	2/8/2016			GREEN LECT HALL IS TOO COLD
FO-339096	2/8/2016			RM 1328 IS TOO HOT
FO-339108	2/8/2016			RM 6321 IS TOO HOT
FO-339213	2/9/2016			RM 5213 IS TOO COLD
FO-339287	2/10/2016			RM 108 TOO COLD, RM IS WITHIN RM 103
FO-339295	2/10/2016			rm 5236 IS TOO HOT
FO-339332	2/11/2016			GREEN LECT HALL IS TOO COLD
FO-339337	2/11/2016			RM 5550 HAS A NEGASTIVE PRESSURE SHOULD BE POSITIVE
FO-339342	2/11/2016	2/11/2016		RM 00229 HAS LOW HUMIDITY
FO-339348	2/11/2016			RM 411 LOW HUMIDITY
FO-339349	2/11/2016	2/11/2016		Heater not working on the dock area.
FO-339362	2/11/2016	2/25/2016		RM 3117 LEAK FROM CEILING
FO-339373	2/11/2016			Please repair the light of Hood No 6 (Room No-3341). The light takes 40-45 minutes to work properly after switching it on.
FO-339379	2/11/2016	2/11/2016		RM 00522 HAS LOW TEMP

WO	Recieved	Finished	Total	Request
FO-339399	2/12/2016	2/12/2016		LOW TEMP. ROOM 0413.
FO-339420	2/12/2016	2/26/2016		VENT OVER GRILL IS NOT WORKING. KITCHEN.
FO-339421	2/12/2016	2/26/2016		LOW HUMIDITY. ROOM 412.
FO-339449	2/12/2016	2/12/2016		LOW HUMIDITY. ROOM 0507.
FO-339459	2/12/2016			The fire alarm panel in the hallway next to the stage door. shows normal, but there a 6 or 8 blinking lights in the lower right corner of the panel. They are continuously blinking. Is this normal? Please check. Thanks.
FO-339501	2/15/2016			5TH FL NO HOT WATER
FO-339510	2/15/2016	2/16/2016		HALLWAY NEAR 5600 TOO COLD
FO-339521	2/15/2016	2/16/2016		4600 TOO COLD
FO-339524	2/15/2016			Dean's office 2625, there is a constant squeaking sound in the NW corner of the room.
FO-339528	2/15/2016	2/26/2016		KITCHEN FOOD COOLER NOT WORKING
FO-339539	2/15/2016			WALL OUTLETS ARE NOT WORKING. ROOM 3138.
FO-339545	2/15/2016	2/26/2016		RM 3359 AND 3369 TOO HOT, SENSITIVE EQUIPMENT IN RM
FO-339549	2/15/2016			Electrical sockets not working
FO-339740	2/16/2016	2/16/2016		LOUD BANGING NOISE IN CEILING. 2ND FLOOR WOMEN'S RESTROOM.
FO-339749	2/16/2016	2/16/2016		3105 TOO HOT
FO-339750	2/16/2016	2/16/2016		3RD, 4th,& 5TH FL SOUTH SIDE TOO HOT, PLEASE SEE DAISY 577-5409 WITH STATUS
FO-339754	2/16/2016	2/16/2016		TEMPERATURE ALARM. ROOM 4321.
FO-339757	2/16/2016	2/16/2016		RM 4314 ALARM SOUNDING
FO-339776	2/16/2016			GREEN LECT HALL IS TOO HOT
FO-339810	2/17/2016	2/17/2016		TEMPERATURE ALARM. ROOM 4321.
FO-339870	2/17/2016			AIR PRESSURE CAUSING DOORS TO SLAM CLOSED. ROOMS 4263, 4273 & 4259.
FO-339897	2/18/2016	2/18/2016		TEMPERATURE ALARM. ROOM 4321.
FO-339903	2/18/2016	2/22/2016		SHOWER HAS NO HOT WATER. LADIES LOCKER ROOM 0120.
FO-339913	2/18/2016	2/22/2016		SHIFFMAN LIBRARY TOO COLD
FO-339977	2/19/2016			LOW STEAM PRESSURE ALARM.
FO-339998	2/19/2016	2/19/2016		0130 WATER DETECTION ALARM
FO-340001	2/19/2016			LAB 6321 TOO HOT, PLEASE ADJUST TEMP ASAP
FO-340010	2/19/2016			R/R R 8229 SINK @ YOUR RIGHT AS YOU COME INTO RM HOT WATRED FAUCET WILL NOT TURN OFF-WTR IS FLOWING GETTING HOTTER
FO-340017	2/19/2016			RM 9232 IS EXTREMELY HOT
FO-340020	2/19/2016			RM 6111 ODORS NOT LEAVING THE ROOM, CHECK VENTILATION
FO-340066	2/22/2016			HIGH TEMP. ROOM 4252.
FO-340085	2/22/2016	2/22/2016		ALARM SOUNDING IN INCUBATOR ROOM. ROOM 4321.
FO-340087	2/22/2016			RM 9228 AUTOCLAVE IS LKNG
FO-340088	2/22/2016	2/22/2016		DTE REQUESTING ENG TO MEET AT THE GENERATOR
FO-340093	2/22/2016			9TH FL TOO COLD
FO-340100	2/22/2016			LOW TEMP. ALARM. ROOMS 419 & 423 (ANIMAL QUARTERS)
FO-340254	2/23/2016			RM 325 BODY COOLER RM TEMP TOO HIGH 72 SHOULD BE 65 PLEASE FIX ASAP
FO-340304	2/24/2016			WATER HAMMERING SOUND COMING FROM CEILING AND WALL. ROOMS 410 AND 406.
FO-340325	2/24/2016			HIGH TEMP. ROOM 521.
FO-340328	2/24/2016			RM 3325 TOO HOT
FO-340327	2/24/2016			HIGH HUMIDITY. ROOMS 200.09 AND 200.04.
FO-340331	2/24/2016			NO HOT WATER IN THE DEAN'S RESTROOM. ROOM 1229.
FO-340332	2/24/2016			1ST FL RESTROOM'S LOW WATER PRESSURE
FO-340334	2/24/2016			PIPE LEAK. PIPE SCRUBBER IS BROKEN. ROOM 516.

WO	Recieved	Finished	Total	Request
FO-340335	2/24/2016	2/24/2016		RM 324 IS TOO HOT (tkng exams)
FO-340349	2/24/2016			RM 324 TOO HOT
FO-340353	2/24/2016			RM 00034 IS TO HOT
FO-340354	2/24/2016			RM 00036 IS TO HOT
FO-340373	2/24/2016			RM 521 TOO HOT
FO-340464	2/25/2016			RM 200.02 HAS A HI TEMP ALARM
FO-340473	2/25/2016			TOO WARM. ROOM 412.
FO-340474	2/25/2016			TOO HOT. 400 SUITE ESPECIALLY ROOM 419.
FO-340475	2/25/2016			HIGH TEMP. ALARM. ROOM 416.
FO-340489	2/25/2016			REQUESTING ENG INVESTIGATE LOADING DOCK DOOR NOT CLOSING PROPERLY
FO-340494	2/25/2016	2/25/2016		RM 354 LOST POWER TO BACK AREA OF RM
FO-340529	2/26/2016			RM 1200 TOO HOT
FO-340532	2/26/2016	2/26/2016		LOW HUMIDITY. ROOM 0249.
FO-340583	2/26/2016	2/26/2016		PLEASE MEET DTE NEAR NEW GENERATOR
<b>E - North</b>			<b>26</b>	
FO-338299	2/1/2016	2/1/2016		CTR OF BLDG CLASS RMS ALL FLRS ARE TOO HOT
FO-338317	2/1/2016	2/1/2016		FOUL SMELL THROUGHOUT BLDG VERY STRONG ON LEFT SIDE OF OFFICES
FO-338597	2/2/2016	2/2/2016		WALL OUTLETS ARE NOT WORKING. ROOM 1215.
FO-338616	2/2/2016	2/2/2016		The vent in my office has been on for several months. It is very loud and consequently, it is hard to hold conversations with my students. It also throws out quite a bit of dust.
FO-338732	2/3/2016	2/3/2016		RM 4101 NEED BREAKER RESET
FO-338738	2/3/2016	2/3/2016		RM 4101 BLOWN FUSE, ALSO RM IS TOO COLD
FO-338745	2/3/2016	2/3/2016		3RD FL TOO HOT
FO-338755	2/3/2016	2/3/2016		RM 3094 TOO COLD, AIR IS ON
FO-338763	2/3/2016	2/3/2016		Purdy Library 4th Floor Room 450
				Staff reported that area is rather warm. Please adjust the temperature.
				Thank you.
FO-339112	2/8/2016	2/8/2016		RM 134 IS TOO HOT
FO-339259	2/10/2016	2/10/2016		VERY LOUD HUMMING NOISE ON THE 3RD FLOOR.
FO-339270	2/10/2016	2/10/2016		RM 331 OUTLETS NOT WORKING
FO-339334	2/11/2016	2/11/2016		RM 4057 IS TOO COLD
FO-339335	2/11/2016	2/11/2016		RM 2226 IS TOO COLD
FO-339341	2/11/2016	2/11/2016		2ND FLR JANITOR'S CLOSET HAS A HOT WTR TK LEAK
FO-339364	2/11/2016	2/11/2016		RM 4110 TOO COLD
FO-339371	2/11/2016	2/11/2016		RM 4339 TOO COLD
FO-339774	2/16/2016	2/16/2016		RM 134 IS TOO HOT
FO-339775	2/16/2016	2/16/2016		3RD FLR WOMENS RR 1ST SINK WATER WILL NOT SHUT-OFF
FO-339878	2/17/2016	2/17/2016		STE 4200 KITCHEN, NO HOT WATER
FO-340098	2/22/2016	2/22/2016		SUMP PUMP FOR E ELEV IS IN ALARM
FO-340122	2/22/2016	2/22/2016		RM 2311 IS TOO HOT
FO-340359	2/24/2016	2/24/2016		RM 50 EXHAUST FANS NOT WORKING
FO-340378	2/24/2016	2/24/2016		FAP IS RINGING STATING ALARM IS IN TROUBLE
FO-340531	2/26/2016			RM 4032 CEILING LEAK TILE COLLAPSED ,,,,,,,,,, ME/2-26-16 ,,,,,,,,,,
FO-340586	2/26/2016			FIRE TROUBLE ALARM. DUE TO POWER BUMP.
<b>E - Northeast</b>			<b>25</b>	
FO-338891	2/4/2016	2/4/2016		FIRE SMOKE ALARM
FO-338899	2/4/2016	2/4/2016		RM 3367/MECH RM HAS A VERY LOUD NOISE COMING FROM IT

WO	Recieved	Finished	Total	Request
FO-339159	2/9/2016	2/10/2016		Air intake vent in the office 0101.1 in the basement is hanging dangerously from the ceiling.
FO-339174	2/9/2016	2/9/2016		WALL OUTLETS ARE NOT WORKING. ROOM 2822.
FO-339383	2/11/2016	2/11/2016		RM 155 IS TOO COLD
FO-339433	2/12/2016	2/12/2016		GRNDS OFC ALL LITES WENT OUT
FO-339531	2/15/2016	2/16/2016		WALL OUTLET IS NOT WORKING. ROOM 261 FRONT RIGHT SIDE OF OFFICE.
FO-339532	2/15/2016	2/16/2016		WALL OUTLET IS NOT WORKING. ROOM 253 REAR LEFT SIDE OF OFFICE.
FO-339764	2/16/2016	2/16/2016		RM 261WALL OUTLET IS NOT WORKING AGAIN 2/15/16. ROOM 261 FRONT RIGHT SIDE OF OFFICE.
FO-339766	2/16/2016	2/16/2016		RM 253 WALL OUTLET IS NOT WORKING AGAIN. ROOM 253 REAR LEFT SIDE OF OFFICE.
FO-339844	2/17/2016	2/17/2016		RM 214 LOW TEMP ALARM
FO-339934	2/18/2016	2/18/2016		LOW TEMP. ALARM. COOLER ROOM 214.
FO-339979	2/19/2016	2/19/2016		HUMMING NOISE COMING FROM CEILING IN ROOMS 1800, 1811, & 1814.
FO-340082	2/22/2016	2/23/2016		DEANS OFFICE 277 TOO COLD
FO-340314	2/24/2016	2/26/2016		DOOR BELL IS NOT WORKING. EARLY CHILD CARE CENTER.
FO-340367	2/24/2016	2/24/2016		1ST FL VESTIBULE AREA CEILING LEAK, POSSIBLY FROM BROKEN GUTTER
FO-340368	2/24/2016	2/24/2016		FIRE TROUBLE ALARM
FO-340371	2/24/2016	2/24/2016		RM'S 2918/2924 OUTLETS NOT WORKING
FO-340443	2/25/2016	2/25/2016		LOW TEMP. ALARM. ROOM 214.
FO-340467	2/25/2016	2/25/2016		RM 2918 NEED BREAKER RESET
FO-340469	2/25/2016	2/25/2016		RM 2924 NEED BREAKER RESET
FO-340485	2/25/2016	2/25/2016		WATER COMING IN THRU WINDOW. 3RD FLOOR.
FO-340573	2/26/2016	2/26/2016		RM 261 FRONT & 253 BACK, RM 263 AREA'S HAVE BLOWN CIRCUIT
FO-340575	2/26/2016	2/26/2016		LOW TEMP. ALARM. ROOM 214.
FO-340578	2/26/2016	2/26/2016		CEILING LEAK. ROOM 287.
<b>E - Preventative Maintenance</b>			<b>77</b>	
FO-338366	2/1/2016	2/1/2016		RM 214 LOW TEMP ALARM
FO-338372	2/1/2016	2/3/2016		9TH FL PLEASE OPEN CABLE RM FOR COMCAST
FO-338373	2/1/2016	2/5/2016		3RD FL RM 333 LEAK FROM LINE ON ICE MACHINE. PLEASE ISOLATE
FO-338374	2/1/2016	2/1/2016		High Priority: Tripped circuit in Admissions. Several computers do not have power. Please reset ASAP.
FO-338699	2/2/2016	2/3/2016		RM 6000 ? WHETHER IT IS TOO HOT OR TOO COLD
FO-338700	2/2/2016	2/2/2016		RM 527 IS TOO COLD
FO-338705	2/2/2016	2/3/2016		Outlet is not receiving power on the back wall under the window as well as the wall on the right hand side. The orange outlets are working on this wall, but the white outlets are not.
FO-338706	2/2/2016	2/3/2016		Outlet is not receiving power on the back wall under the window.
FO-338709	2/2/2016	2/3/2016		Outlet is not receiving power on the back wall under the window.
FO-338710	2/2/2016	2/2/2016		Been too cold since last week. Also Room's 3120A, 3122, 3126, and 3128. Thank you.
FO-338798	2/3/2016	2/4/2016		RM 150 TOO HOT
FO-338807	2/3/2016	2/3/2016		STRWL D HAS NAT GAS SMELL
FO-338813	2/3/2016	2/3/2016		RM 1081 NEEDS TO BE UNLOCKED, CHAIR KIM MORGAN IS IN RM 1143
FO-338816	2/3/2016	2/4/2016		The window on the south east side of the second floor in room 201 is open (from the top down). It should probably be shut. Don't want the possum getting in.
FO-338865	2/4/2016			CONTRACTORS NEED TO GET INTO RM 4373
FO-338910	2/4/2016			NORTH EXIT DOOR DOESN'T CLOSE PROPERLY, SECURITY ISSUE
FO-338913	2/4/2016	2/4/2016		Rm. 364 - Reports that the electrical outlets do not work. Please repair.

WO	Recieved	Finished	Total	Request
FO-338920	2/4/2016	2/5/2016		TANKS TO BOILER ARE EMPTY SAM FROM ELDON WATER CALLED TO HAVE SOMEONE CHECK BOILER AND LARGE TANKS
FO-338925	2/4/2016	2/5/2016		Room still getting cold after 1:00 p.m. and black stuff coming out of ceiling in far left hand corner. Filter probably needs to be replaced.
FO-339053	2/5/2016			GREEN LECTURE HALL RM 2322, LEAK FROM CEILING THROUGH DOOR JAM
FO-339056	2/5/2016	2/6/2016		RM 278/OFC KITCHEN AREA GARBAGE DISPOSAL ISN'T WRKNG PLS CK RESET
FO-339060	2/5/2016	2/5/2016		Room 1243 is too cold
FO-339061	2/5/2016	2/6/2016		Room is very cold. There is no heat coming into the classroom
FO-339123	2/8/2016	2/9/2016		BLDG TOO HOT
FO-339130	2/8/2016	2/8/2016		Faculty member's office is very warm. He cannot sit comfortably in his office without the windows open. Please adjust temp. Thanks.
FO-339131	2/8/2016	2/29/2016		RM 2822 NO POWER TO OUTLET POWERING FRIDGE
FO-339229	2/9/2016	2/10/2016		LAB 4167 TOO HOT
FO-339233	2/9/2016			RM 3455 TEMP PROBLEM
FO-339234	2/9/2016	2/10/2016		2123 & LAB 2156 TOO HOT
FO-339235	2/9/2016	2/10/2016		RM 4115 & 4117 TOO HOT
FO-339236	2/9/2016	2/10/2016		2157 & 2168 TOO HOT
FO-339308	2/10/2016			FIRE TROUBLE ALARM
FO-339314	2/10/2016	2/10/2016		1ST FLR FREE LEGAL AID NEED BREAKER RESET
FO-339316	2/10/2016	2/11/2016		LAB 8327 TOO HOT, ANIMAL RM PLEASE ADJUST TEMP ASAP
FO-339395	2/11/2016	2/12/2016		2ND/3RD FLRS/AUDITORIUM NO HEAT
FO-339417	2/12/2016	2/13/2016		2ND/3RD FLRS/AUDITORIUM NO HEAT 02/11/2016 20:04 Frank Vaught- Adjust boiler PSI for building.
FO-339470	2/12/2016	2/13/2016		RM 103 IS EXTREMELY HOT
FO-339471	2/12/2016	2/17/2016		PAD LOCK LEADING INTO ALLEY ON SOUTH SIDE OF BLDG CAN'T OPEN W/KEY NEED TO OPEN SAFETY/SECURITY PROBLEM FOR EASY ACCESS FROM BLDG
FO-339564	2/15/2016	2/15/2016		There is no power at the receptacles under the counter top in this control booth. We are currently running extension cords to power the equipment. Please check and repair. Thanks
FO-339567	2/15/2016	2/17/2016		RM 0367 NO HEAT, TOO COLD
FO-339576	2/15/2016	2/15/2016		RM 2420,2146,2134 TOO COLD
FO-339577	2/15/2016	2/16/2016		IAB 60 VENTILATION SYSTEM IS OFF
FO-339581	2/15/2016	2/16/2016		RM 307 & 308 TOO HOT
FO-339797	2/16/2016	2/16/2016		RN 4321 (WALK IN COLD RM BOX) TEMP ALARM ? WHETHER HI/LOW
FO-339799	2/16/2016	2/17/2016		1ST FLR NEAR RM 169 ALARM PANEL IS BEEPING
FO-339802	2/16/2016	2/16/2016		RN 4321 (WALK IN COLD RM BOX) TEMP ALARM ? WHETHER HI/LOW **AGAIN**
FO-339804	2/16/2016	2/17/2016		RM 224/OFC SINK IN DEPT KITCHEN IS BACKING UP
FO-339886	2/17/2016			LAB 6321 TOO HOT
FO-339891	2/17/2016			LAB 3108 TOO HOT
FO-339893	2/17/2016	2/18/2016		SOUTHWEST ENTRANCE 1ST FL CLOSEST TO WARREN, PLEASE UNLOCK TEMP DOOR
FO-339951	2/18/2016	2/19/2016		GARAGE AREA LEAKING PIPE
FO-339959	2/18/2016	2/19/2016		HIGH TEMP. ALARM. COLD ROOM 4252.
FO-339963	2/18/2016	2/19/2016		RM 2009 ACTIVE CEILING LEAK IN FRONT ROW 2 AREAS
FO-339964	2/18/2016	2/19/2016		RM 10202.2 TOO COLD
FO-340022	2/19/2016	2/20/2016		RM 1241 DEANS OFC TOILET IS BUBBLING COULD OVERFLOW
FO-340023	2/19/2016	2/20/2016		LAB AREAS 3130 & 3270 TOO HOT
FO-340024	2/19/2016	2/20/2016		RM 5236 IS TOO HOT
FO-340156	2/22/2016	2/23/2016		RM 103 TOO HOT

WO	Recieved	Finished	Total	Request
FO-340162	2/22/2016			RM 0300 BSMNT LOCKER RM, NO HOT WATER
FO-340298	2/23/2016	2/24/2016		FIRE TROUBLE ALARM.
FO-340299	2/23/2016	2/24/2016		FIRE TROUBLE ALARM
FO-340303	2/23/2016			Hood W6 (or EF31/3028/06), water supply on left side of the hood leaks when it is turned on. Which one is obvious because the students have wrapped a lot of Parafilm around the leaky joint in an attempt to stop the leak.
FO-340301	2/23/2016	2/23/2016		RM 213 LIGHTS WILL NOT TURN ON, POSSIBLE BLOWN FUSE
FO-340408	2/24/2016	2/25/2016		APT 1206 WATER LEAKING IN THROUGH WINDOW
FO-340421	2/24/2016	2/24/2016		2ND FLR & MAIN STRWL HAS A STRONG SEWAGE SMELL
FO-340424	2/24/2016	2/24/2016		RM 1339 WATER LEAKING IN THROUGH WINDOW
FO-340425	2/24/2016	2/25/2016		RM 3360 HAS A CLNG LEAK
FO-340426	2/24/2016	2/25/2016		3RD FLR NEAR EAST STRWL CEILING LEAK COMING THRU LITE FIXTURE
FO-340431	2/24/2016	2/25/2016		RM 3316 HAS A CLNG LEAK
FO-340432	2/24/2016	2/24/2016		STE 1800 HUMMING NOISE
FO-340434	2/24/2016	2/25/2016		6TH FL 687 CEILING LEAK
FO-340507	2/25/2016	2/27/2016		RM 3350 CEILING LEAK NEAR ENTRANCE OF RM
FO-340508	2/25/2016	2/25/2016		RM 3315 AND SURROUNDING AREA, BURNING SMELL
FO-340509	2/25/2016			RM 3610 IS TOO HOT
FO-340510	2/25/2016	2/25/2016		CEILING LEAK. ROOM 271.
FO-340598	2/26/2016	2/26/2016		ALARMS SOUNDING IN RECEPTION AREA
FO-340603	2/26/2016			RM 6353 ALL LIGHTS WENT OUT
<b>E - South</b>			<b>27</b>	
FO-338619	2/2/2016	2/2/2016		RM 410 BURNING SMELL
FO-338679	2/2/2016	2/2/2016		On the 2nd floor in the old wing there is a pipe that is making a hissing sound. The pipe is labeled chilled water return. The purge valve is leaking in the ceiling. This is across from room 2325. Thank you.
FO-338678	2/2/2016	2/2/2016		RM 1137 TAMPER ALARM
FO-338747	2/3/2016	2/2/2016		BLDG THE FUMEHOODS W/IN BLDG ARE GOING IN/OUT OF ALARM
FO-338748	2/3/2016	2/2/2016		BLDG FANS STOPPED WORKING
FO-339111	2/8/2016	2/8/2016		ENGINEER TO SHUT ELEV OFF-CALLED SCHINDLER ELEV CO FOR #2/NORTH ELEV HAD AN ENTRAPMENT THEY'RE OFF NOW-HOWEVER ELEV JERKS VERY HARD WHEN IN MOTION\ REF #51773073
FO-339119	2/8/2016	2/10/2016		2ND FLR CTR OPEN STUDY AREA ADJACENT TO STACKS CK BREAKER FOR A 2 ROLLS OF LIGHTS ARE OUT
FO-339191	2/9/2016	2/9/2016		There is a leak and mold in the wall on the second floor right outside the elevator entering into the Rands House on the second floor.
FO-339356	2/11/2016	2/12/2016		CIRCULATION DESK AREA IS TOO COLD
FO-339400	2/12/2016	2/12/2016		FIRE ALARM SOUNDING. 1ST FLOOR NEAR CIRCULATION DESK.
FO-339437	2/12/2016	2/12/2016		RM 50.2/LAB IS TOO HOT 82degrees SHOULD BE 72degrees
FO-339455	2/12/2016	2/16/2016		Low humidity in this room only. Currently at 29% Would like it increased to 40%
FO-339457	2/12/2016	2/12/2016		STRONG EXHAUST FUMES. ROOM 1360.
FO-339542	2/15/2016	2/16/2016		The exhaust system for the engine in lab 1360 is not working at all, and the technician came this morning to fix the circulating fan for the ventilation system, which is a different case. Please have the building engineering take a look at this issue.
FO-339547	2/15/2016	2/22/2016		The right sash of Fume Hood EF31/3028/06 does not work properly. Students cannot raise or lower it to proper levels during class.
FO-339739	2/16/2016	2/16/2016		PLEASE CONTACT SERVICE CENTER REGARDING LOCK ON FREIGHT ELEV
FO-339777	2/16/2016	2/17/2016		ALARM SOUNDING AND LIGHT BLINKING. BASEMENT ROOM 0154.
FO-339838	2/17/2016	2/29/2016		**NOT A PIPE LEAK / EXSAUST VENT FROM AUTO CLAVE CONDENSING ON VENT PER RC . JWT 2/10
				LAB 231 ACTIVE CEILING LEAK ,,,,,,,,,,,,,,,,,, JH/2-9-16 ,,,,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-340081	2/22/2016	2/22/2016		BEEPING SOUND COMING FROM THE 1ST FLOOR EMERGENCY RESPONSE ROOM.
FO-340121	2/22/2016	2/22/2016		PLEASE REMOVE FRONT DOOR MULLION
FO-340340	2/24/2016	2/24/2016		2ND FL POST LEADING TO EDC NEEDS TO BE REMOVED PLEASE BRING KEY
FO-340356	2/24/2016	2/29/2016		**THIS IS NOT A PIPE SHOP REPAIR / ENGINEERING DEPT TO FOLLOW UP ON EXHAUST DUCT WORK FROM AUTO CLAVE THAT IS LEAKING. SEE MARK BOBICK JWT 2/24
				It is raining from a vent in the ceiling again in my lab. I have put several requests in to fix this and it
FO-340491	2/25/2016	2/25/2016		NO POWER IN WALL OUTLETS. ROOM 3360.
FO-340551	2/26/2016	2/26/2016		RM 2131 EMERGENCY EYEWASH MACHINE, NOT GETTING ANY WATER TO MACHINE
FO-340582	2/26/2016	2/26/2016		POWER BUMP APPX 12:45
FO-340587	2/26/2016	2/26/2016		FIRE TROUBLE ALARM. DUE TO POWER BUMP.
FO-340591	2/26/2016	2/26/2016		4th FLOOR COLD ROOM IS HEATING UP.
<b>E - Southeast</b>			<b>25</b>	
FO-338352	2/1/2016			RM 2222 NEED BREAKER RESET
FO-338355	2/1/2016	2/1/2016		RM 0360 NEED BREAKER RESET
FO-338585	2/2/2016	2/2/2016		BOILER IS DOWN.
FO-338681	2/2/2016			INSIDE STE 2317 RM 2321 HAS BLACK SOOT COMING OUT OF AIR VENTS
FO-338724	2/3/2016	2/3/2016		FIRE TROUBLE ALARM.
FO-338878	2/4/2016	2/4/2016		RM 0134 NEEDS TO BE UNLOCKED
FO-339274	2/10/2016			TOILET NOT FLUSHING. ROOM 3301. (AAUP OFFICE)
FO-339346	2/11/2016			CONTRACTOR NEEDS ACCESS TO TELCOM RM
FO-339451	2/12/2016			2ND FLR T-STAT IS ON THE WRONG DAY SO ITS NOT HEATING AREA
FO-339548	2/15/2016			PLEASE TURN HEAT ON IN BLDG, IF UNABLE TO TURN HEAT ON SEE MICHAEL IN THE BOX OFFICE 7-2972
FO-339560	2/15/2016			Engineer replace coupling insert on heating hot water pump #1
FO-339742	2/16/2016			RM 109 LEAKING RADIATOR
FO-339755	2/16/2016			PLEASE GIVE JIM HEART ACCESS TO THE ROOF AT 12 NOON 734-709-5307
FO-339801	2/16/2016	2/17/2016		RM 109 LEAKING RADIATOR ALSO TOO HOT
FO-339831	2/17/2016	2/17/2016		RM 2155 ACTIVE CEILING LEAK
FO-339841	2/17/2016	2/17/2016		DOOR IS LOCKED. ROOM 1145.
FO-339976	2/19/2016			TOO HOT. BUILDING.
FO-339980	2/19/2016			FIRE TROUBLE ALARM
FO-340106	2/22/2016			JIM HART FROM 123 NET WILL BE ARRIVING AT 12PM PLEASE MEET BEHIND BLDG
FO-340256	2/23/2016			GREEN RM BACKSTAGE, PLEASE TURN HEAT ON
FO-340261	2/23/2016			FIRE TROUBLE ALARM
FO-340369	2/24/2016			FIRE TROUBLE ALARM
FO-340444	2/25/2016			WATER LEAKING FROM OUTSIDE INTO BASEMENT THRU WALL.
FO-340454	2/25/2016			FIRE TROUBLE ALARM.
FO-340559	2/26/2016			FIRE TROUBLE ALARM
<b>E - West</b>			<b>19</b>	
FO-338306	2/1/2016	2/1/2016		FIRE SUPERVISOR ALARM.
FO-338628	2/2/2016	2/4/2016		NO POWER IN WALL OUTLET. (VENDING MACHINES) 2ND FLOOR.
FO-338629	2/2/2016	2/4/2016		RM 226 CENTER LIGHTS NOT TURNING ON, NEED BREAKER RESET
FO-338630	2/2/2016	2/2/2016		WALL OUTLET IS NOT WORKING. ROOM 153.
FO-338774	2/3/2016	2/5/2016		RM 100 TOO HOT
FO-339340	2/11/2016	2/12/2016		RM 266 HAS A NATURAL GAS SMELL
FO-339375	2/11/2016	2/12/2016		BLDG TOO COLD
FO-339523	2/15/2016	2/15/2016		ENG PLEASE CALL MAIN OFFICE 577-6187

WO	Recieved	Finished	Total	Request
FO-339543	2/15/2016	2/15/2016		Office is extremely cold.
FO-339812	2/17/2016	2/19/2016		RM 150 POOL LEVEL DROPPED 1/2 in
FO-339837	2/17/2016	2/17/2016		BAD ODOR COMING FROM POOL. ROOM 150.
FO-339911	2/18/2016	2/19/2016		RM 137 IS TOO COLD
FO-339915	2/18/2016	2/18/2016		RM 103.2 AC IS ON, TOO COLD
FO-339999	2/19/2016	2/19/2016		FIRE ALARM.
FO-340092	2/22/2016	2/24/2016		RM 128 COLD AIR IS BLOWING IN THRU VENTS
FO-340129	2/22/2016	2/22/2016		1ST FLR IS TOO COLD
FO-340374	2/24/2016	2/24/2016		NORTH END NEW ADDITION WOMEN'S BASKETBALL OFFICE, CEILING LEAK
FO-340393	2/24/2016	2/25/2016		HALLWAY OUTSIDE 020 ACTIVE CEILING LEAK
FO-340585	2/26/2016	2/26/2016		FIRE TROUBLE ALARM. DUE TO POWER BUMP.
<b>Medium</b>			<b>106</b>	
<b>E - Auxiliary</b>			<b>8</b>	
H-57118	2/3/2016	2/4/2016		The power source (plug points) in the kitchen counter is not working. There are 2 three pin plug points that has not been working since move-in. Also the CFL bulb over the kitchen sink has been fused out. And one bulb on the chandelier has also been fuse
H-57114	2/3/2016	2/6/2016		Garbage disposal is broke. please come ASAP. authenticated user: Ahmad Aburaideh - fs3668 requester ip address: 35.16.67.81
H-57120	2/4/2016	2/4/2016		The handle in the shower for cold water has fallen off and broken. It needs to be replaced. authenticated user: Justine Valka - fg9623 requester ip address: 141.217.233.182
H-57249	2/10/2016	2/11/2016		Fix shower head; it has been dripping constantly with no way to stop it. Thank you! authenticated user: Chelsea Kornago - fv0795 requester ip address: 35.16.232.140
H-57305	2/15/2016	2/17/2016	2/17/2016	Heat is not working the room authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.176
H-57310	2/15/2016	2/17/2016		Kitchen sink garbage disposal is not working. When turned on, food comes up on the other side of the sink. authenticated user: Megan Moncion - fh1128 requester ip address: 35.16.68.199
FO-339984	2/19/2016	2/26/2016		TOO WARM. STUDIO - ROOMS 127, 110, 118, 126, 128 & 117.
H-57481	2/27/2016	2/29/2016	2/29/2016	The heat from the air conditiong system is not working. When i turn it up the vent emits cold air and no heat. authenticated user: Lincoln Yaldoo - fx6281 requester ip address: 35.16.98.97
<b>E - Command Center</b>			<b>33</b>	
FO-338297	2/1/2016	2/1/2016		Three (3) fans serving the gymnasium area are locked out.
FO-338361	2/1/2016			pls repair boiler 1 will not start
FO-338749	2/3/2016			Supply fans for HVAC are blowing too hard causing doors to open in the building. Schedule needs to be re-set also.
FO-338869	2/4/2016	2/4/2016		Boiler will not run in lead.
FO-338871	2/4/2016	2/4/2016		Boiler will not come off low fire.
FO-338903	2/4/2016	2/19/2016		Replace bad signal converter.
FO-338930	2/5/2016	2/9/2016		BAS-med priority- Please run a room temperature trend chart on this lab for the next week or so. Tenant gets uncomfortable around 1PM every day. We need more data to see whats going on. Afternoon shift keeps finding the work station at 73 degree
FO-338947	2/5/2016	2/5/2016		Fix boiler!
FO-338978	2/5/2016	2/15/2016		control air compressor twin unit. unit on right leaks oil badly, please replace compressor on right



WO	Recieved	Finished	Total	Request
FO-338981	2/5/2016			//update on scope of work// Building requires two airstations and an automatic means of switching between them to function properly.  //orig request//Purdy induction units have dual pressure thermostats. 25 lbs heat, 18 lbs cooling season. I need an ai
FO-339019	2/5/2016	2/10/2016		trade controls priority medium please service lab 3170 has no heat check actuator valve no air pressure to open the valve removed air line still no heat
FO-339070	2/6/2016	2/18/2016		Please send Tony Antoszewski to Music Annex to repair the temperature control system serving the building. The building was 96 degrees on Saturday February 6.
FO-339072	2/6/2016	2/8/2016		AHU-1 at Cohn is running on Saturdays, even though it is programmed off on Siemen's scheduling.  AHU-2 & 3 are off.  AHU-1 does shut off on Sunday.  Good luck figuring this one out!
FO-339106	2/8/2016			Trade: Controls/Siemens Priority: Medium R/R ROOF EDC cooling tower bypass valve controller is rapidly opening and exhausting control air to this valve.
FO-339186	2/9/2016		2/15/2016	Trade: Command Center Priority: Medium Please repair AC unit for IT closet in room 43. The compressor located in the sub-basement and appears to be shorted to ground.
FO-339190	2/9/2016	2/11/2016		AC Shop-Please replace damaged room sensor.
FO-339242	2/10/2016	2/19/2016		Adjust burner, flame too rich.
FO-339552	2/15/2016	2/15/2016		Controls inspect and repair programing for AH-2 preheat.
FO-339555	2/15/2016	2/16/2016		B.A.S. please check FCU-1 unit for women's restroom. this is a 100% out air unit and it keeps tripping on freeze stat when O.A. temp is low. Priority: med.
FO-339556	2/15/2016	2/22/2016		BAS: Please troubleshoot ahu 1 MA dampers. Dampers are not regulating properly. Also, HV does not appear to be responding.
FO-339814	2/17/2016			HVAC-- Priority Medium Heat Pump blows cool air
FO-339815	2/17/2016	2/19/2016		Controls, repair failed temp indication for animal facility Rm. 205. The alarm has the wrong ID CSM.16.A01.205. It should be 21.A03B
FO-339853	2/17/2016			CONTROLS/HONEYWELL  HEAT EXCHANGERS 1 AND 2 AT MORT SCI. DO NOT HAVE A RESET SCHEDULE. THE SET POINT IS AT 180F ALL THE TIME. PLEASE ADD IN A RESET SCHEDULE.
FO-340101	2/22/2016	2/24/2016		Refridge shop. R/R RM 1195/MECH BLR RM Boiler No. 2 still fills up with water when off. Bypass valve has been replaced. Water is leaking by feed water regulator. medium priority.
FO-340104	2/22/2016	2/24/2016		Refridge shop.R/R RM 1195/MECH BLR RM Boiler No. 3 fills with water when not in use. Water is leaking by feed water regulator. Medium priority.
FO-340114	2/22/2016	2/23/2016		Controls remove old room numbers for animal rooms on graphics.
FO-340117	2/22/2016			Controls add exhaust TEC to graphic display for all animal rooms.
FO-340238	2/23/2016	2/23/2016		A/C Controls please troubleshoot face & by-pass dampers on AHU-4. Dampers to pre-heat coils are closed but outside air dampers are also closed.
FO-340272	2/23/2016			controls replace motor to unit heater in main entrance vestibule (attn: Gordon and Maureen)
FO-340360	2/24/2016		2/24/2016	To refrig. crew. Please repair. Unable to bring up Insight system on my computer. Error message- "impossible to locate federated database." 00_FD_BOOT.
FO-340484	2/25/2016			CONTRACTOR/HONEYWELL:R/R RM 2224 Please replace VAV in room 2224MED.
FO-340493	2/25/2016			Controls change primary chilled water pump #2 and condenser water pump #2 to lead pumps for chiller #2.
FO-340592	2/26/2016			Converter overheating
<b>E - MedPharm</b>			<b>20</b>	
FO-338742	2/3/2016	2/8/2016		TOO HOT. ROOM 7320.
FO-338757	2/3/2016	2/3/2016		TOO HOT. ROOM 315.
FO-338775	2/3/2016	2/23/2016		TOO HOT. ROOM 9320

WO	Recieved	Finished	Total	Request
FO-338776	2/3/2016	2/23/2016		TOO HOT. ROOM 9326 AND VERY LOUD NOISE COMING FROM HEATER.
FO-338829	2/4/2016	2/23/2016		TOO COLD. ALL ANIMAL ROOMS ESPECIALLY ROOM 416.
FO-338834	2/4/2016	2/23/2016		TOO COLD. ROOM 3125.
FO-338907	2/4/2016	2/23/2016		TOO COLD. ROOMS 3240, 3280 & 3130.
FO-339021	2/5/2016	2/25/2016		TOO COLD. ROOMS 5234 AND 5236.
FO-339177	2/9/2016			TOO COLD. ROOM 2224.
FO-339184	2/9/2016	2/25/2016		TOO COLD. ROOM 5236.
FO-339257	2/10/2016	2/11/2016		TOO COLD IN ROOMS 5603, 5601, 5605, 5611, 5613 & 5617.
FO-339495	2/15/2016	2/16/2016		TOO COLD. 5TH FLOOR INCLUDING ROOM 5305.
FO-339511	2/15/2016			TOO COLD. ROOM 170.
FO-339512	2/15/2016	2/16/2016		TOO COLD. ROOM 3128.
FO-339538	2/15/2016	2/26/2016		TOO HOT. ROOM 4131.
FO-339730	2/16/2016	2/16/2016		TOO HOT. ROOM 4131.
FO-340119	2/22/2016			TOO HOT. ROOM 103.
FO-340446	2/25/2016	2/26/2016		TOO HOT. ROOM 324.
FO-340466	2/25/2016			WATER IS NOT COMING INTO WASHING MACHINE. ROOM 1306.
FO-340595	2/26/2016			TOO COLD. ROOMS 5213 & 5215.
<b>E - North</b>			<b>9</b>	
FO-338625	2/2/2016	2/2/2016		TOO COLD. ROOM 1279.
FO-338627	2/2/2016	2/2/2016		TOO STUFFY. ROOM 1270.
FO-338676	2/2/2016	2/3/2016		TOO HOT. ROOM 314.
FO-338766	2/3/2016	2/3/2016		Purdy Library 4th Floor Room 448 Staff report that are is rather warm. Please adjust the temperature.  Thank you.
FO-338880	2/4/2016	2/4/2016		TOO COLD. ROOM 221.
FO-339517	2/15/2016	2/15/2016		TOO HOT. ROOM 1515.
FO-339534	2/15/2016	2/15/2016		TOO COLD. ROOM 4104.
FO-340274	2/23/2016	2/23/2016		1ST FL STAIRWELL DOOR NEAREST ANTHONY WAYNE, DOOR HAS GREASE OR OIL FROM DOOR CLOSURE
FO-340339	2/24/2016	2/24/2016		COLD AIR BLOWING. ROOM 2095.
<b>E - Northeast</b>			<b>9</b>	
FO-339042	2/5/2016	2/5/2016		TOO COLD. 1ST FLOOR.
FO-339499	2/15/2016	2/15/2016		TOO COLD. 1ST FLOOR ESPECIALLY ROOM 110.
FO-339536	2/15/2016	2/23/2016		NO HEAT. ROOM 247.
FO-339758	2/16/2016	2/17/2016		Cold Classrooms-60 degrees (also rooms 235,240,245), reported yesterday
FO-339759	2/16/2016	2/17/2016		Cold Classrooms-60 degrees (also rooms 235,239,245), reported yesterday
FO-339974	2/19/2016	2/19/2016		NO HEAT IN SOUTHWEST STAIRWELL.
FO-340286	2/23/2016	2/25/2016		TOO COLD. 1ST FLOOR SUITE.
FO-340399	2/24/2016	2/24/2016		TOO COLD. 1ST FLOOR SUITE.
FO-340471	2/25/2016	2/25/2016		TOO COLD. ROOM 313.
<b>E - Preventative Maintenance</b>			<b>9</b>	
FO-338364	2/1/2016	2/2/2016		FANS ARE OFF. WOMEN'S RESTROOM. ROOM 380.
FO-338367	2/1/2016	2/2/2016		RM 3438/MENS RR ONLY TOILET ISN'T WRKNG AGAIN Sloan valve malfunction and toilet plugged.,,,,,,,,,,,,,, TT/1-26-16 ,,,,,,,,,,,,,,
FO-338368	2/1/2016	2/1/2016		R/R RM 3438/MENS RR ONLY TOILET ISN'T WRKNG AGAIN Sloan valve malfunction and toilet plugged.,,,,,,,,,,,,,, (SEE OLD WO FO-337889)
FO-339223	2/9/2016	2/10/2016		The heat in staff office is extremely hot. Temperature is currently on 77. Please check as soon as possible.
FO-339306	2/10/2016	2/11/2016		COLD AIR BLOWING THRU VENTS. TOO COLD. ROOM 313.

WO	Recieved	Finished	Total	Request
FO-339753	2/16/2016	2/16/2016		RM 3201 IS STILL TOO HOT (pls see results) The heat in staff office is extremely hot. Temperature is currently on 77. Please check as soon as possible.
FO-339888	2/17/2016	2/18/2016		TOO HOT. ROOM 8321 (INSIDE OF ROOM 8319)
FO-339890	2/17/2016	2/18/2016		GARBAGE DISPOSAL IS BROKEN. CAFETERIA.
FO-340418	2/24/2016	2/25/2016		TOO HOT. ROOM 34.
<b>E - South</b>			<b>4</b>	
FO-338323	2/1/2016	2/2/2016		TOO HOT. ROOMS 361 AND 359.
FO-338756	2/3/2016	2/9/2016		AIR FAN FROM VENTS ARE VERY LOUD. ROOM 333.
FO-339506	2/15/2016	2/15/2016		VERY LOUD CLICKING NOISE COMING FROM CEILING ON THE RIGHT FRONT SIDE OF BUILDING. ROOM 106.
FO-340438	2/24/2016			There is excessive dust and debris that is coming out of the heat register vents that is causing a problem with research. The researcher mentioned that someone taped filters over the registers but they are not doing a good job and are the tape is falling
<b>E - Southeast</b>			<b>7</b>	
FO-338335	2/1/2016	2/1/2016		TOO COLD. ROOM 2155.
FO-338736	2/3/2016			DOOR ALARM. EAST STAIRWELL. CANCEL WORK ORDER REQUEST PER JODY.
FO-339100	2/8/2016			The heater does not work again in office 14200.10. Please help to check it since the inclement weather will come this week. Thanks so much for your help!
FO-339101	2/8/2016	2/8/2016		TOO HOT. BUILDING.
FO-339525	2/15/2016			Hi, Thanks for the staff's working on the heater last week. I am not sure have they completed it? Unfortunately, it is not working today.Thanks!
FO-339863	2/17/2016			EXTREMELY COLD. ROOM 8202.3.
FO-340105	2/19/2016			COLD AIR BLOWING. ROOMS 13400.2 AND 13400.1.
<b>E - West</b>			<b>7</b>	
FO-338772	2/3/2016	2/12/2016		It is 80 degrees in the auditorium. Please lower the heat.
FO-339423	2/12/2016	2/19/2016		TOO COLD. ROOM 137.
FO-339428	2/12/2016	2/12/2016		NO HEAT. MEN'S LOCKER ROOM. ROOM 154.
FO-339488	2/15/2016	2/15/2016		NO HEAT. BUILDING.
FO-339507	2/15/2016	2/26/2016		TOO COLD. ROOM 342.
FO-339869	2/17/2016	2/23/2016		TOO COLD. ROOM 342.
FO-339948	2/18/2016	2/18/2016		TOO HOT. ROOM 100.
<b>Low</b>			<b>194</b>	
<b>E - Auxiliary</b>			<b>72</b>	
H-57089	2/1/2016	2/2/2016	2/2/2016	Need circuits to be reset because a few stopped working authenticated user: Shae-lyn Grubb - fw2534 requester ip address: 35.16.96.31
H-57075	2/1/2016	2/2/2016	2/2/2016	The vent (or something else) in the women's restroom is making a really loud buzzing sound. I'm not sure if it's been reported already but I've heard it for at least 2 weeks now. authenticated user: Dominique Witherspoon - ev6822 requester ip address: 3
H-57076	2/1/2016	2/3/2016	2/3/2016	For the second time this year, our air conditioning has not been functioning properly. We would appreciate if someone was sent up to fix it. authenticated user: Kareem Elhage - cq7219 requester ip address: 35.16.107.190
H-57079	2/1/2016	2/3/2016	2/3/2016	Fifth floor sink clogged kitchenette authenticated user: Sabbir Ahmed - fo9519 requester ip address: 141.217.23.229
H-57060	2/1/2016			Faucet and garbage disposal are leaking.
H-57061	2/1/2016			Broken outlet between 306 and 308
H-57093	2/2/2016			KITCHEN SINK PIPELINE WATER LEAKING WHEN TAP IS TURNED ON. URGENT REPAIR NEEDED. authenticated user: Dharani Dhar Narra - fj6814 requester ip address: 12.47.84.135
H-57087	2/2/2016	2/2/2016		Our heat is out once again. This is the 5th time it has stopped working and every time we put in a request, they take forever to come and fix it. It is very cold outside and I refuse to live in a dorm where the heat doesn't work. authenticated user: A'Z

WO	Recieved	Finished	Total	Request
H-57100	2/2/2016	2/4/2016		The motor is running when turned on and making a loud noise but nothing is coming out while on. The room is cold please fix.
H-57095	2/2/2016	2/3/2016		shower leaking hot water - room 441
H-57099	2/2/2016			Shower with the tub the hot water and cold water isn't working right. Either it is boiling hot to where your skin is burning or so cold you freeze. There is not in between temperature, you can here a click when turning to warm and it becomes boiling hot.
H-57101	2/2/2016	2/4/2016		I have a concern about the air filter in my room. It is filled with dust and needs to be changed. Thank you authenticated user: Oludamilola Akinfenwa - fw3193 requester ip address: 35.16.43.148
H-57106	2/2/2016			Hello,We need the erator to be replaced by an engineering operator due to its leak Thank youauthenticated user: Varun Kandukuri - fl9707requester ip address: 35.16.230.149
H-57104	2/2/2016			Second Bathroom's shower lever handle is inoperative. Thus, there is a water wastage. Kindly, fix it immediately.Thank youauthenticated user: Jayant Sakhardande - fj6255requester ip address: 141.217.220.208
H-57131	2/3/2016			Very hot in apartment. No temperature control.authenticated user: Sean Blackburn - em7421requester ip address: 35.16.75.12
H-57123	2/3/2016			In apartment 416, their fan in their bathroom is out. Please fix as soon as possible. Thank you.authenticated user: Chevonne Abrams - eh3331requester ip address: 141.217.59.20
H-57139	2/4/2016	2/5/2016	2/5/2016	For the third time I have to file a service request for for the air conditioning. I filed one about a week ago and its status was changed to complete even though no one ever came to fix it. Please send someone to room 811 in the towers residence hall to
H-57137	2/4/2016			engineering checkauthenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.200
H-57169	2/4/2016	2/8/2016		The heat went out again. authenticated user: Amber Epperson - fw6276 requester ip address: 35.16.102.164
H-57143	2/4/2016	2/6/2016		Resident says that the water in the bathroom and kitchen is too hot. Resident says that she does not have warm water. authenticated user: Tamika Davis - eq2532 requester ip address: 141.217.23.175
H-57141	2/5/2016	2/9/2016	2/9/2016	The heat is not working in the lounge. No matter what the temperature is, air blows out. authenticated user: Alexandra D'Abreu-Hines - fp0908 requester ip address: 35.16.96.234
H-57157	2/5/2016	2/10/2016		Mechanical Check authenticated user: Jasmine Kendrick - eu6470 requester ip address: 141.217.23.173
H-57179	2/6/2016	2/6/2016		Half of my apartment has no power (had to connect my fridge into another room via 2 extension chords) and my toilet is not flushing. I would very much prefer both of those things to work. authenticated user: Cody Thompson - fh8965 requester ip address:
H-57170	2/6/2016	2/8/2016		The shower in the bathroom needs to be fixed because it drips water constantly, which is creating a huge amount of black mold. authenticated user: Rachel Hackett - ft9800 requester ip address: 35.16.97.79
H-57177	2/7/2016			Shower head only has half the water coming out of the head, and the other half comes out of the spout.authenticated user: Juhee Prakash - fi1213requester ip address: 35.16.65.44
H-57180	2/7/2016			lights in bathroom and kitchen went off.authenticated user: Manaswini Remidi - fs2524requester ip address: 141.217.23.175
H-57191	2/7/2016			ENGINEERING: Please replace light fixture in hallway if it is not working. Water leaked into fixture from apt. above on Sunday, 02/07. Ensure wires are dry before testing or attempting to repair.authenticated user: Prentis Gipson - bq7019requester ip
H-57192	2/7/2016			ENGINEERING: Please inspect smoke detector and base for proper operation. Water leaked into detector on Sunday, 02/07. Ensure all wires are dry before testing or replacement.authenticated user: Prentis Gipson - bq7019requester ip address: 141.217.23.
H-57199	2/8/2016			Sink gasket is leaking and probably needs to be replaced.authenticated user: Anthony Kurcz - ez7811requester ip address: 141.217.23.177
H-57195	2/8/2016	2/10/2016		Sink garbage disposable - When turned on, all the debris comes up on the opposite side of the sink. authenticated user: Hannah Smith - fb8842 requester ip address: 35.16.224.139

WO	Recieved	Finished	Total	Request
H-57212	2/8/2016			Broken garbage disposal. Need engineer to come in and fix. authenticated user: Rizwan Ahmed - ey8281 requester ip address: 141.217.221.182
H-57209	2/9/2016	2/9/2016	2/24/2016	Ashley Hepp 02/24/2016 16:04 - Toilet water will not stop running and the toilet has started to leak water onto the bathroom floor. authenticated user: Victoria Bellamy - fh2437 requester ip address: 35.16.73.33
H-57216	2/9/2016			Water leakage from tap when shower is used in the second (tub) bathroom. authenticated user: Karan Patil - ft6156 requester ip address: 198.208.251.22
H-57234	2/9/2016			Shower in 1st bathroom is not working properly. Water is falling out from gap. authenticated user: Naman Chhaya - ft6817 requester ip address: 141.217.220.232
H-57230	2/9/2016	2/10/2016	2/10/2016	The thermostat does not work in this study lounge. As of now, it is cold, and the heat does not work. authenticated user: Brian Echols - fh3449 requester ip address: 141.217.23.177
H-57233	2/9/2016			New air filter. authenticated user: Tanneh Nagbe - eu7026 requester ip address: 35.16.101.35
H-57227	2/10/2016	2/10/2016	2/10/2016	Heater is broken. This is our third work order. It's very cold at night. authenticated user: Jessica Rabban - fx2476 requester ip address: 35.16.103.248
H-57242	2/10/2016			Light in the men's restroom is out. authenticated user: Amari McGee - ev1977 requester ip address: 141.217.23.176
FO-339266	2/10/2016	2/18/2016		CK ENTRY DOOR TO EINSTEIN SHOP NOT VERY HARD TO OPEN
FO-339267	2/10/2016	2/18/2016		CK ENTRY DOOR TO JIMMY JOHN'S SHOP NOT VERY HARD TO OPEN
H-57254	2/10/2016			Third room heat vent (the one in the corner between the Windows) stopped working again. The room was extremely cold last night even with the heat turned all the way up. authenticated user: Sanjana Shahreen - eu7659 requester ip address: 172.56.11.153
H-57251	2/10/2016	2/11/2016		Heater is blowing out cold air authenticated user: Antoinette Taylor - fo0835 requester ip address: 35.16.102.173
H-57257	2/11/2016			In the 9th Floor Kitchenette, two of the ceiling lights have bad ballasts that need to be replaced. Contact Rick from maintenance. authenticated user: Philip Trela - eu7977 requester ip address: 141.217.23.172
H-57264	2/11/2016			The vent keeps blowing cold air on and off now. When someone from maintenance came this morning, it was fine, but half an hour later, it's back to blowing out little to no air and only cold air. Please come figure out what's wrong...the room gets so cold
H-57263	2/11/2016	2/12/2016		Shower head is leaking, has been for about a week authenticated user: Cameron Smielewski - fv1140 requester ip address: 35.16.233.205
H-57280	2/12/2016	2/15/2016	2/15/2016	The batteries in the thermostat are dead so it doesn't work. authenticated user: Keontae Ware - fg9660 requester ip address: 141.217.23.171
H-57278	2/13/2016	2/15/2016	2/15/2016	The heat in the lounge does not work at all. authenticated user: Alexandra D'Abreu-Hines - fp0908 requester ip address: 35.16.103.208
H-57282	2/13/2016	2/15/2016	2/15/2016	The heater doesn't seems to be heating. I put the temperature up to 72-75, but it always remains at 64-66. My room is getting really cold, and it starting to bother me sometimes. authenticated user: Marcio Targino Correia - fy7191 requester ip address
H-57283	2/14/2016	2/16/2016	2/16/2016	The air conditioner doesn't work on heat mode. The temperature inside is 66 degrees and it's almost impossible to stay inside the room too long. Thank you. authenticated user: Rafael Aguiar de Santana - fy2236 requester ip address: 141.217.225.42
H-57295	2/15/2016	2/16/2016	2/16/2016	The heat in our room is not working. The current temperature of the room is 67 degrees but it is set for 78 degrees. authenticated user: Zachary Owczarzak - fv6129 requester ip address: 70.210.70.87
H-57301	2/15/2016	2/16/2016	2/16/2016	The heat in the room does not work. It is currently set to the highest heat setting (78 Degrees) and it is currently 70 degrees in the room. I believe we need our air filter replaced, but I am not entirely sure. authenticated user: Mark Dorsey - fi5623

WO	Recieved	Finished	Total	Request
H-57323	2/15/2016	2/17/2016	2/17/2016	The thermostat is clearly broken. The heat doesn't work. I put a work order in a couple weeks ago and still nothing has been done to fix it. authenticated user: Ashleigh Anderson - fo1351 requester ip address: 35.16.108.94
H-57330	2/16/2016	2/18/2016	2/18/2016	The shower head continuously drip. The shower head was changed but the drip is still occurring. authenticated user: JaNel Stephens-Dantzler - eo2346 requester ip address: 141.217.23.179
H-57331	2/16/2016	2/18/2016	2/18/2016	The bathroom sink will not stop running. Something is wrong with the faucet. authenticated user: Wanza Mason - fi1610 requester ip address: 35.16.104.228
H-57338	2/16/2016	2/17/2016		The garbage disposal is not allowing the sink to drain properly. authenticated user: Jessica Weaver - fi2693 requester ip address: 146.9.59.15
H-57357	2/16/2016			SECOND BATHROOM FLUSH TANK NOT REFILLING AFTER FIRST FLUSH. PLEASE VISIT AS SOON AS POSSIBLE. authenticated user: Dharani Dhar Narra - fj6814 requester ip address: 141.217.220.118
H-57332	2/17/2016	2/17/2016	2/17/2016	At some point in time my thermostat stopped working properly. When ever I would turn up the heat, the cold would also go up and vise versa. This caused the red light to turn on and the vents to blow only cold air out. I tried to "fix" it by resetting it a
H-57350	2/17/2016			Toilet is not working. Water is continually flushing. Temporarily blocked water flow but toilet is currently unusable. authenticated user: Bhavana Tetali - fh2409 requester ip address: 146.9.59.15
H-57387	2/18/2016	2/24/2016		Heat in the kitchen does not work. authenticated user: Deja Moore-Grant - eo2406 requester ip address: 216.143.116.8
H-57377	2/18/2016	2/19/2016	2/19/2016	Our heating system is broken. Nothing is appearing on the screen to change it or turn it on. It's just blank and no air is coming out of any vents. authenticated user: Abigail Landskroener - fk9925 requester ip address: 35.16.229.164
H-57380	2/18/2016	2/22/2016	2/22/2016	Thermostat. Even when turned to 80 or 90 degrees, cool air comes out and the thermostat never reads above 70 degrees. Please fix because it gets really cold. authenticated user: - requester ip address: 35.16.227.219
H-57389	2/19/2016			Fire alarm keeps going off. authenticated user: Jasmine Kendrick - eu6470 requester ip address: 141.217.23.173
H-57385	2/20/2016	2/22/2016	2/22/2016	I think that I blew a fuse or threw a breaker. Three of the outlets in my room aren't working after I plugged in an old extension cord. When I plugged it in I heard a pop and then some of my lights went out. There are still some working outlets on the oth
H-57427	2/23/2016	2/24/2016		Toilet is broken! The water does not fill in the back of the toilet. Therefore I cannot flush. authenticated user: Amyra Woods - eh3128 requester ip address: 35.16.71.45
H-57435	2/23/2016			Smoke alarm went off for DeRoy #1005 indicating that it is dirty and needs to be cleaned.  authenticated user: Peter Dolnicek - eo7549 requester ip address: 141.217.23.173
H-57441	2/24/2016	2/24/2016		Thermostat not cutting on authenticated user: Tyffany Smith - fl9947 requester ip address: 35.16.96.90
H-57460	2/24/2016			Our kitchen ceiling had an access panel put in recently and it's currently pouring down rain on our floor. It ruined a few boxes and the carpet. It's obvious that the access panel was put up very quickly, and is not fully attached to the ceiling so the w
H-57447	2/25/2016	2/25/2016		Red light goes on and off and cool air works occasionally. authenticated user: Monica Norton - fp4498 requester ip address: 35.16.98.78
H-57478	2/26/2016			Bathroom(infront of first apartment) Exhaust Fan making too much noise. authenticated user: Rahul Gujar - ft6709 requester ip address: 141.217.221.103
H-57479	2/26/2016	2/29/2016	2/29/2016	The heat in my room is not coming out hot. Even at its highest temperature it's still freezing.! authenticated user: N'Dea Colter - fv1269 requester ip address: 35.16.99.82
H-57508	2/27/2016			Both the outlets in my room under my bed are not working and I used these for all my devices. I live in 1024B. authenticated user: Ashi Arora - fi4557 requester ip address: 35.16.238.234
H-57500	2/27/2016			the shower pressue is low and fully switching to show mode authenticated user: Ahila Manivannan - fj0752 requester ip address: 108.168.227.47

WO	Recieved	Finished	Total	Request
<b>E - Command Center</b>			<b>27</b>	
FO-338280	2/1/2016	2/17/2016		AC Shop-please R/R 6TH FLR check heat pump 1-69. Compressor will not start. No heat in offices..
FO-338819	2/4/2016	2/8/2016		BAS Controls- Medium priority- Please update graphic screens and access on control computer in Chief's office. Make it work like the one at the BAS station.
FO-338874	2/4/2016	2/9/2016		These two fans share a common fresh air inlet trunk but split and have their own dampers each fan has it's own discharge. They are induction unit fans. They run at 7 " water. The units they serve are thru out the building. The water is either chilled in
FO-339037	2/5/2016			Tempered water controller is not working, original equipment 60 plus years old, please replace
FO-339081	2/8/2016	2/11/2016		BAS Section: R/R BLDG please create graphics page for multi purpose courtyard rtu. RTU is now on system. Attach page to Matthai graphics.
FO-339181	2/9/2016			Control air compressor regulating station is circa @ 1950's. Having issues with control air pressure. Please install new modern regulator with bypass.
FO-339198	2/9/2016			Boiler Crew- R/R RM 00195/MECH BLR RM please repair panel door to boiler #1. Will not latch properly.
FO-339325	2/11/2016			Trade: Controls Priority: High Please modify controls so that fan#5 won't trip on F-stat. Also check co2 sensor.
FO-339382	2/11/2016	2/18/2016		A/C Controls, R/R RM 111 please troubleshoot cold temps in 1st floor lab 111.
FO-339425	2/12/2016			Perform tune-up on Boiler "C".
FO-339453	2/12/2016	2/17/2016		To refrig. crew. R/R RM 201/MECH RM Please replace the following defective transducers on AHU-2. AHU-2 C/V transducer not responding to auto or manual signal.
FO-339454	2/12/2016	2/17/2016		To refrig. crew. R/R RM 201/MECH RM Please replace the following defective transducers on AHU-3. AHU-3 transducers for H/V and for M/A not responding to auto or manual signal.
FO-339486	2/15/2016	2/18/2016		A/C Controls, please replace stat that controls 1st floor SE area (F611..11.VAV.1.8). Stat is not controlling properly. Also if possible move stat inside lab.
FO-339546	2/15/2016	2/15/2016		For Rich. Please modify graphics to show freeze stat status on AHU-3, 4, 5 & 6 at I-bio.
FO-339725	2/16/2016	2/17/2016		For Rich: Please modify graphics for I-bio to show "Points in Alarm" link.
FO-339746	2/16/2016	2/16/2016		BAS: please investigate point 003.08.g01.prf. Point is going in and out of alarm and making noise on pager.
FO-339938	2/18/2016			HONEYWELL R/R RM 00108/1st floor lounge reheat valve.
FO-340108	2/22/2016			Need 4 thermostats Siemens Powers 192-209 product # 05131213 Pneumatic stats to repair room 134 and others
FO-340237	2/23/2016			BAS Section: Please repair/replace wall stats for rms. 205 and 206. These are specialized stats and are no longer functioning.
FO-340258	2/23/2016	2/25/2016		BAS - Please work with controls (Lloyd) and investigate efficacy of putting tempered water controller on seimens panel.
FO-340323	2/24/2016			Controls R/R RM 211 replace two failed stats in animal cage wash room 211.
FO-340351	2/24/2016	2/24/2016		BAS section: R/R RM 0002/MECH RM please troubleshoot and correct power issue with field panel 9 and auxiliary devices. Panel is not communicating and powers the AEM for the bldg. network.
FO-340352	2/24/2016			BAS section: R/R RM 00012/MECH RM please replace 1400 VA UPS for field panel 9. UPS has failed.
FO-340462	2/25/2016	2/26/2016		controls groupR/R ROOF--AHU 001 not heating please correct condition
FO-340525	2/26/2016	2/26/2016		BAS Section: Please check rm 149, uninvent 1. ma temp alarms.
FO-340589	2/26/2016			Adjust time schedule for MA units and heat pumps so that they run this weekend.

WO	Recieved	Finished	Total	Request
FO-340590	2/26/2016			Cleaver Brooks Boiler Parts - CAMPUSWIDE
				DJ Conley Order:
				Item # 82-111/CB Part #082-00111 Modulating Cam Spring Qty: 12
				Item # 36-25/CB Part #036-00025 Cam Spring Guide Qty: 12
<b>E - MedPharm</b>			<b>19</b>	
FO-338301	2/1/2016	2/1/2016		Need ceiling vent covered due to dust falling onto desk
FO-338697	2/2/2016	2/4/2016		The conference room in suite 1130 has a ceiling leak near the front and needs repair.
FO-338722	2/3/2016	2/4/2016		animal quarters need ceiling filters changed in all animal rooms
FO-338725	2/3/2016			too hot in rooms 218-234
FO-338740	2/3/2016	2/4/2016		In Rm. 1306.1 the washing machine is leaking and needs repair.
FO-338746	2/3/2016	2/3/2016		RM 2290 HAS A HI PITCH NOISE
FO-338765	2/3/2016			ALARM READING INCUBATOR FAILURE. ROOM 4312.
FO-338786	2/3/2016			please deliver 15 bags of salt for Reverse Osmosis system in the penthouse Scott Hall building #612.FO-327323
FO-338789	2/3/2016			please deliver 1 pallet of nikrocleanse to room 100 Scott Hall.FO-327323
FO-338790	2/3/2016			please deliver 15 bags of salt to 3rd floor mechanical area for reverse osmosis system at Hudson webberFO-327692
FO-338931	2/5/2016			Elliman Day Engineer- med priority- please install filter material in Supply vents (5) of room 3109.
FO-339032	2/5/2016			Rm. 3530 has a Laminar Hood with a UV lamp out and needs replacing.
FO-339167	2/9/2016			No hot water.
FO-339290	2/10/2016	2/10/2016		RM 522 IS TOO COLD
FO-339439	2/12/2016			Office is cold.
FO-339783	2/16/2016			HIGH TEMP. ALARM. ROOM 4252.
FO-340458	2/25/2016			RM 414 HASW A HI TEMP
FO-340459	2/25/2016			RM 200.06 HAS A LOW TEMP
FO-340460	2/25/2016			RM 200.07 HAS A LOW TEMP
<b>E - North</b>			<b>16</b>	
FO-338356	2/1/2016	2/1/2016		High Priority: Tripped circuit in Admissions. Several computers do not have power. Please reset ASAP.
FO-338622	2/2/2016	2/2/2016		Room is extremely cold. Please adjust temp.
FO-338793	2/3/2016	2/3/2016		RM 1198 IS TOO COLD
FO-338872	2/4/2016	2/4/2016		Classroom too hot - over 78 degrees in room.
FO-338873	2/4/2016	2/4/2016		rooms 150 & 150.3 too hot. it is 79 degrees in room 150.
FO-338941	2/5/2016	2/5/2016		NEED ASSISTANCE W/4TH FLR
FO-339168	2/9/2016	2/9/2016		RM 00011 REPLACE BLOWN FUSES ON CRP #1 & 2
FO-339200	2/9/2016	2/24/2016		R/R 1ST FLR SOUTHEND NEAR ELEVS ALL 3 STALLS Replace 3 flush valves in the public restroom on the 1st floor Women's restroom ***SEE RESULTS***
FO-339201	2/9/2016	2/24/2016		R/R SOUTHEND NEAR ELEVS' Basement floor public men's restroom need three black toilet seats replaced
FO-339203	2/9/2016			1ST FLR Replace 2 sink faucets in the 1st floor womens public restroom- south end of the building **SEE RESULTS**
FO-339204	2/9/2016	2/24/2016		1st floor mens public restroom - south end of the building need 4 faucets replaced **SEE RESULTS**
FO-339345	2/11/2016	2/11/2016		Purdy Library 2nd Floor, Room 231 Staff reported that area is cold. Please adjust the temperature. Thank you.



WO	Recieved	Finished	Total	Request
FO-339914	2/18/2016	2/18/2016		Wood shop spray booth needs more heat=up the heat only in the spray booth. It's reading in the low 60's and it needs to be lower 70's.
FO-339989	2/19/2016	2/19/2016		Room is too cold. Cold air blowing from vents.
FO-340013	2/19/2016			The air-conditioning in room 1243 is very noisy- the exhaust fan in the ceiling is very loud.
FO-340128	2/22/2016	2/22/2016		Room is too cold. Cold air coming from vents. Please adjust temp.
<b>E - Northeast</b>			<b>9</b>	
FO-338684	2/2/2016			BSMT RM 00036 IS TOO COLD
FO-338762	2/3/2016			The South West office lights and furnace is not working and the breaker is triped in the electrical panel. Need an electrician to investigate.
FO-338827	2/4/2016	2/4/2016		Cass door IS STANDING OPEN.
FO-338828	2/4/2016	2/19/2016		Hot water in ladies bathroom (Shower/sinks) on the will not heat up properly.
FO-339089	2/8/2016	2/18/2016		Exhaust vents in DLAR area 128.1 & 128.2 are not functioning at all and need to be checked out
FO-339094	2/8/2016			Several offices on the second floor are cold. Radiators are somewhat warm, but not hot. Please investigate and increase temperature.
FO-339344	2/11/2016	2/11/2016		Room is extremely cold. Please adjust temp.
FO-339537	2/15/2016	2/15/2016		Classrooms are cold about 55 degrees especially rooms 235,238,239,241,245,234,218,
FO-339756	2/16/2016	2/16/2016		Cold Classrooms-60 degrees (also rooms 238,239,240,245), reported yesterday
<b>E - Preventative Maintenance</b>			<b>25</b>	
FO-338370	2/1/2016	2/2/2016		1ST FLR WEST STRWL FIRE EXIT DOOR IS IN ALARM NEAR LAB 1305/JANITORS CL 1308
FO-338698	2/2/2016	2/3/2016		The conference room in suite 1130 has a ceiling leak near the front and needs repair.
FO-338707	2/2/2016	2/3/2016		Too hot. High temperatures makes it uncomfortable for the instructor and students.
FO-338809	2/3/2016	2/3/2016		We need the vents cleaned for the entire first and second floors of the Law Library. See Mary Bonk for details. 7 6177
FO-338846	2/4/2016	2/5/2016		Life Science Filters for DLAR 16x20x2 Qty: 24
FO-338897	2/4/2016	2/9/2016		Driveway Air Filters 18x18x2 Qty: 12
FO-338908	2/4/2016	2/5/2016		Please replace cafeteria filters 16x20x2 Qty: 15 20x20x2 Qty: 6
FO-338909	2/4/2016	2/9/2016		14x14x1 Qty: 6
FO-338914	2/4/2016	2/5/2016		Hallway on way to Deliliah's Café has smell of gas (sewer gas?). (Last time this was reported about a week ago, pouring of water into basement drain seemed to help alleviate the smell.)
FO-339059	2/5/2016	2/5/2016		Room 1545 is too cold
FO-339103	2/8/2016	2/29/2016		PM Shift Tools  6" Stepladder (Qty: 2) Hand Carts (Qty: 2) Nut Drivers (Qty: 4)
FO-339129	2/8/2016	2/8/2016		Air intake vent in the office 0101.1 in the basement is hanging dangerously from the ceiling.
FO-339227	2/9/2016	2/10/2016		Electrical outlets on lab bench have no in lab 2310. The first bench next to the shelves.
FO-339300	2/10/2016	2/11/2016		Belt Order A-46 Qty: 1
FO-339312	2/10/2016	2/16/2016		two outlets on the left side as you enter lab are not working
FO-339788	2/16/2016	2/16/2016		There is no hot water in the first floor men's restrooms and the employee lounge. This has been the case for about the last ten days.

WO	Recieved	Finished	Total	Request
FO-339793	2/16/2016	2/17/2016		The room is Extremely COLD
FO-339829	2/17/2016	2/18/2016		Belt Order B-64 Qty: 2
FO-339830	2/17/2016			Belt Order 4L350 Qty: 1
FO-339887	2/17/2016	2/18/2016		Water is dripping from ceiling and tile is getting wet causing it to drip. It looks like it's ready to fall down.
FO-339950	2/18/2016	2/19/2016		Friday 2/19th around 6:30 pm Need the lights in the HIGH BAY area turn off for an event (IIE Regional Conference Dance) there will be speakers and you can't hear over the noise.
FO-339956	2/18/2016			Please repair the DI water faucet, it will not turn off.
FO-340282	2/23/2016	2/26/2016		Belt Order: B-60 Qty: 1
FO-340296	2/23/2016	2/23/2016		FIRE TROUBLE ALARM.
FO-340429	2/24/2016	2/25/2016		Storage room, located near the elevator, is leaking water.
<b>E - South</b>			<b>15</b>	
FO-338316	2/1/2016	2/1/2016		It is raining from a vent in the ceiling again in my lab. I have put several requests in to fix this and it keeps happening. This NEEDS to be fixed, there is brown corrosive-looking water/fluid all over my work benches!!!
FO-338342	2/1/2016	2/9/2016		There is a filter that was installed over the heat/air duct that supplies the room. Instead of being installed into a "holder" it ended up just getting taped onto the wall and it has since fallen off. This room has dust sensitive lasers and equipment th
FO-338612	2/2/2016	2/2/2016		DOOR CHIMES WON'T STOP. ROOM 0504.09. (CANCEL WORK ORDER PER JAN GOMILINSKI)
FO-338716	2/2/2016	2/3/2016		Heat is always on and will not go down
FO-338731	2/3/2016	2/4/2016		Leak from ceiling tiles in Dean's Office, Suite 3100, closest to Room 3112. Reported last night to Engineer per note from Lori Rinaldi, Library Clerk Senior. This is in general vicinity of previous leaks. We don't know if any work was done to determin
FO-338858	2/4/2016	2/4/2016		NEED ACCESS TO KEY OPERATED ELEV FOR METER READINGS (313-300-3422)
FO-338859	2/4/2016	2/4/2016		NEED TO READ METER. PLEASE CALL THE SERVICE CENTER
FO-338877	2/4/2016	2/4/2016		NEED TO DELIVER TKS TO BLDG 248-798-9375
FO-338977	2/5/2016	2/10/2016		In Honors Suite of UGL, Suite 2100, Second Floor, there is clear water stain and what appears to be accumulated water in rug of floor nearest to the left wall between men's room and kitchen, not coming from ceiling. Honors is wondering if a pipe in th
FO-339047	2/5/2016	2/6/2016		Light covers in lab space need to be replaced 2310 D10 & D14 fell out of the fixtures and are laying on lab benches.
FO-339158	2/9/2016	2/9/2016		Research lab is very hot.
FO-339215	2/9/2016	2/9/2016		MEET W/DWSD OUT IN FRONT OF STATE HALL
FO-339443	2/12/2016	2/16/2016		It is 78 degrees F in our research lab, and has been so ever since the heat was turned on. The high room temperature has been interfering with some of our experiments, so we request if this could please be looked into. Thank you!
FO-339995	2/19/2016	2/19/2016		the engine exhaust system in lab 1360 is not working. Please send work order to building engineer, Rocky.
FO-340394	2/24/2016	2/24/2016		The roof at the north end of the Prentis Building is leaking water into the building. Please send someone to clean and stop the leak.
<b>E - Southeast</b>			<b>8</b>	
FO-338302	2/1/2016			There is a leak in the ceiling in the audiology clinic room in the basement in their office room 002.1.
FO-338933	2/5/2016			Engineer replace seal on heating hot water pump #1
FO-338956	2/5/2016			R/R BLDG Purchase 2 ASCO solenoid valve repair kits from Grainger.
FO-338957	2/5/2016			engineerR/R RM 333 replace leaking water filter pressure gauge on filter for ice machine.
FO-339088	2/8/2016			CONTACT JIM B FOR THOMPSON HME 313-220-2637

WO	Recieved	Finished	Total	Request
FO-339519	2/15/2016			The heat in rooms 114, 116, 120, and the first floor hall ways is again not working.
FO-339566	2/15/2016			#2 GAS VALVE WILL NOT LIGHT.  (The heat in rooms 114, 116, 120, and the first floor hall ways is again not working).
FO-339982	2/19/2016			Thermostat in main room is leaking. Have inspection soon. Needs to be adjusted please. Thank you, Susan
<b>E - West</b>			<b>3</b>	
FO-338934	2/5/2016	2/12/2016		NEED ACCESS TO JANITOR'S CLOSET (Expert Svcs (Red Folder) HERE TO DO REPAIRS FROM FLOODING
FO-338935	2/5/2016	2/12/2016		NEED ACCESS TO JANITOR'S CLOSET (Expert Svcs (Red Folder) HERE TO DO REPAIRS FROM FLOODING
FO-339721	2/15/2016	2/23/2016		The room is extremely cold
<b>Grounds</b>			<b>4</b>	
<b>High</b>			<b>1</b>	
<b>G - Physical Grounds</b>			<b>1</b>	
FO-339912	2/18/2016			the driveway behind Reuther heading to Jacob House has a huge oil slick or spill needs cleaned up
<b>Low</b>			<b>3</b>	
<b>G - Moving/Storage</b>			<b>1</b>	
FO-339023	2/5/2016	2/5/2016		Outside of Room 3103 - display case is broken and needs to be thrown away.
<b>G - Physical Grounds</b>			<b>2</b>	
FO-339082	2/6/2016			I would like to request for our courtyards to be cleaned. Thank you.
FO-339745	2/16/2016			Request salt to be placed on Cass side of the building due to icy conditions. Employee slipped and fell upon entering the building.
<b>Trades</b>			<b>801</b>	
<b>Emergency</b>			<b>44</b>	
<b>T - Carpenter</b>			<b>10</b>	
FO-338360	2/1/2016	2/1/2016		DOOR WON'T UNLOCK. ROOM 153.1.
FO-338870	2/4/2016	2/8/2016		EMERGENCY CARP R/R ENTRANCE DOOR #211 08W ADJUST DOOR CLOSURE - CAUSING DOOR NOT TO CLOSE PROPERLY THIS MORN IT WAS WIDE OPEN. (see Mark B if necessary)
FO-339216	2/9/2016	2/9/2016		KEY STUCK IN DOOR LOCK. ROOM 378.
FO-339456	2/12/2016	2/12/2016		LOCKED KEYS INSIDE OF 2ND FLOOR JANITOR'S CLOSET.
FO-339784	2/16/2016	2/17/2016		MAIN ENTRANCE HANDICAP PUSH BUTTON NOT OPENING DOORS
FO-339894	2/18/2016	2/18/2016		**ADDING CARPENTER: Remove cabinet and section of wall to access drain near room 0224. See Don Bear for detail  REPAIR SUMP PUMP. GAS ODOR SMELL COMING FROM KITCHEN SINK. ROOM 0224. DB/2-17-16
FO-339937	2/18/2016	2/18/2016		Provide access in wall near greenhouse to access plumbing vent line for repair. See Gerry (Plumber)for location
FO-340099	2/22/2016	2/22/2016		EMERGENCY CARP R/R RM 2375 KEY IS STUCK IN DOOR LOCK NEED ACCESS
FO-340137	2/22/2016	2/22/2016		DOOR IS JAMMED LOCKED AND NO ONE CAN GET OUT OR COME IN. EARLY CHILD CARE CENTER.
FO-340386	2/24/2016	2/25/2016		R/R RM 4121 ONLY WINDOW IS LKNG CAUSING CARPET IN & AROUND WINDOW LEAKAGE TO BE SATURATED W/WTR ALSO SHORTING OUT POWER STRIPPED CONNECTED TO WALL OUTLET
<b>T - Electrician</b>			<b>20</b>	
FO-338340	2/1/2016	2/1/2016		BSMNT BARRS LOUNGE LIGHT FLICKERING, SMELLS LIKE SMOKE
FO-338362	2/1/2016	2/1/2016		R/R RM 311 Overhead light flickering and sparking. Looks like there is some small flame and smoke when light is turned on. Please look into right away.

WO	Recieved	Finished	Total	Request
FO-338769	2/3/2016	2/4/2016		FIRE SYSTEM WILL NOT RESET.
FO-338770	2/3/2016	2/3/2016		SPARKS COMING FROM LIGHT SWITH AND LIGHT FLICKERED. 1ST FLOOR DINING AREA.
FO-338927	2/5/2016	2/9/2016		MAIN COMPRESSOR WON'T START. CONTACT ENGINEER FOR DETAILS.
FO-339030	2/5/2016	2/5/2016		POSSIBLE MALFUNCTION IN PRIMARY ROOM. (SOMETHING BLEW) ROOM 32. CONTACT ENGINEER FOR DETAILS.
FO-339152	2/9/2016	2/9/2016		EMERGENCY ELEC R/R RM 6152/MECH RM AIR #1 WILL NOT RUN FUSES ARE GOOD
FO-339384	2/11/2016	2/11/2016		EMERGENCY ELEC R/R RM 6152 AIR COMPRESSOR #1 CONTACTORS ARE STICKING UNIT ISN'T SHUTTING OFF CAUSING BURNNING SMELL
FO-339430	2/12/2016	2/12/2016		**VERIFY power to condensate pump that is still in service located on condensate receiver in basement. See Jim Hill
				EMERGENCY PIPE R/R RM 00045/MECH RM BSMT COND RET PUMP STOPPED WORKING NEED REPIPING ,,,,,,,,,, JH/2-12-16 ,,,,,,,,,
FO-339481	2/15/2016	2/15/2016		AIR HANDLER #5 SUPPLY FAN DOWN.
FO-339516	2/15/2016	2/16/2016		ELECTRICIANS: AIR COMPRESSOR DOWN
FO-339752	2/16/2016	2/16/2016		AIR HANDLER #4 IS DOWN ON FREEZE STAT. PENTHOUSE
FO-339786	2/16/2016			BSMNT MECH RM 154 SUMP ON AND OFF
FO-340070	2/22/2016	2/19/2016		Pole was blown down by high Winds, make safe, and remove pole.
FO-340086	2/22/2016	2/23/2016		1st floor - stacks area (across from the computer lab) - whole bank of lights are out.
FO-340103	2/22/2016	2/23/2016		There is a broken fluorescent light fixture. (EXPOSED WIRES HANGING)
FO-340310	2/24/2016	2/26/2016		RESET FIRE ALARM. SMOKE DETECTOR 2B.
FO-340407	2/24/2016	2/25/2016		CEILING LEAKING FROM LIGHT FIXTURE. 3RD FLOOR BY EAST STAIRCASE.
FO-340580	2/26/2016	2/26/2016		TROUBLESHOOT AIR HANDLER #8 SOUTH VFD.
FO-340588	2/26/2016	2/26/2016		BOILERS WILL NOT START DUE TO POWER BUMP. ROOM 51.
<b>T - Pipefitter</b>			<b>5</b>	
FO-339045	2/5/2016	2/9/2016		EMERGENCY PIPE R/R RM 3320/MECH RM PREHEAT STEAM COIL IS LEAKING AGAIN (STM HAS BEEN ISOLATED) ,,,,,,,,,, EA/2-5-16 ,,,,,,,,,
FO-339116	2/8/2016	2/8/2016		RM 251 CEILING PIPE SPEWING STEAM ,,,,,,,,,, RC/2-8-16 ,,,,,,,,,
FO-339773	2/16/2016	2/19/2016		EMERGENCY PIPEFITTERS R/R RM 00100/MECH RM - REPLACE PVC LINE OF TOWER MAKE UP TK IS SWELLING & ABOUT TO BURST ,,,,,,,,,, ME/2-16-16 ,,,,,,,,,
FO-340257	2/23/2016			Steam leak in Stairwell 1 (west stairwell 1st floor). Loud hissing noise and the "smell" of steam in the stairwell. ,,,,,,,,,, EA/2-23-16 ,,,,,,,,,
FO-340403	2/24/2016	2/24/2016		CEILING LEAK. ROOM 2105.,,,,,,,,,, JH/2-24-16 ,,,,,,,,,
<b>T - Plumber</b>			<b>7</b>	
FO-339113	2/8/2016	2/8/2016		Garbage disposal in Apartment leaking please investigate ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-339568	2/15/2016	2/15/2016		FLOOR DRAIN IS PLUGGED. 2 INCHES OF WATER. BASEMENT MECHANICAL ROOM.,,,,,,,,,, GS/2-15-16 ,,,,,,,,,
FO-339825	2/17/2016	2/22/2016		**REFER TO GUARDIAN PLUMBING REQUEST FO#340725 JWT  **ADDING PLUMBERS: Sump pumps not working correctly . See Don and Pat for detail ,,,,,,,,, DB/2-17-16 ,,,,,,,,,
				BSMNT MECH RM 154 SUMP ON AND OFF
FO-339826	2/17/2016			REPAIR SUMP PUMP. GAS ODOR SMELL COMING FROM KITCHEN SINK. ROOM 0224. ,,,,,,,,, DB/2-17-16 ,,,,,,,,,
FO-339826	2/17/2016			REPAIR SUMP PUMP. GAS ODOR SMELL COMING FROM KITCHEN SINK. ROOM 0224. ,,,,,,,,, DB/2-17-16 ,,,,,,,,,
FO-339985	2/19/2016	2/19/2016		Mens rooms north hallway repair bagged sink ,,,,,,,,,, TT/2-19-16 ,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-340338	2/24/2016	2/24/2016		REPLACE 2 INCH NIPPLE ON SCRUBBER. PIPE LEAK. PIPE SCRUBBER IS BROKEN. ROOM 516 CREAMATORY. ,,,,,,,,,,,,,,,,,,,,,, MM/2-24-16 ,,,,,,,,,,,,,,,,,,,,,,
<b>T - Roofing</b>			<b>2</b>	
FO-340419	2/24/2016			EMERGENFCY ROOFER R/R RM 4324 REPAIR ROOF LEAK CEILING FELL IN
FO-340420	2/24/2016			EMERGENFCY ROOFER R/R RM 4256 REPAIR ROOF LEAK
<b>High</b>			<b>262</b>	
<b>T - Carpenter</b>			<b>72</b>	
FO-338290	2/1/2016	2/2/2016		DOOR WILL NOT UNLOCK - KEY WILL NOT GO INTO DOOR LOCK. LOUNGE DOOR COMING FROM MCGREGOR.
FO-338307	2/1/2016	2/2/2016		Front door latch does not open fully when swipe card used.
FO-338309	2/1/2016	2/2/2016		RM 1136 DOOR DOESN'T LOCK, SECURITY ISSUE
FO-338311	2/1/2016	2/2/2016		Trade: Carpenter Priority: High Location: Lecture Hall Entrance Please raise the roll-up fire door at the entrance to the Lecture Hall.
FO-338320	2/1/2016	2/15/2016		OVERHEAD GATE FOR EXECUTIVE GARAGE NEEDS SERVICE FROM RAYNOR DOOR
FO-338598	2/1/2016	2/2/2016		R/R RM 121 Two interior doors in need of repair. The doors have settled and no longer close automatically. This is in violation of fire safety codes and as a child care facility we must have them fixed. One door is an entrance to room 185, the other is th
FO-338333	2/1/2016	2/2/2016		Men room - Door lock needs repair, will not stay locked.
FO-338351	2/1/2016	2/2/2016		R/R 2ND FLR SOUTH SIDE (by elevator) UNISEX RR HANDICAP STALL IS LOCKED FROM WITHIN
FO-338610	2/2/2016	2/3/2016		RM 327 DOOR HANDLE NOT WORKING, CURRENTLY TABLE IS KEEPING DOOR OPEN. SAFETY ISSUE
FO-338621	2/2/2016	2/3/2016		The outside door of the South Stairwell that exits to Woodward does not close properly. It needs to be adjusted. It is often not closed all the way and this is a security risk.
FO-338683	2/2/2016	2/3/2016		R/R 4TH FLR STRWL (A) DOOR HANDLE FELL OFF (handle is inside rm 4374)
FO-338695	2/2/2016	2/3/2016		Steel double doors leading into room 1142 (Receiving/Storage) won't secure unless forced. Alignment issue causing security issues.
FO-338779	2/3/2016	2/4/2016		Womens 1st fl restroom the locking latch on the 3rd stall has fallen off and it can no longer be locked.
FO-338805	2/3/2016	2/4/2016		Urgent- R/R Rm.# 309, please repair loose door handle - secure room for important files. thank you
FO-338808	2/3/2016	2/4/2016		Re-Glue carpet tiles throughout the 2nd floor of the Law Library. Several areas are a trip hazard. See Mary Bonk for specifics. 7-6177
FO-338862	2/4/2016	2/5/2016		R/R INTERIOR DOOR #2 TO ENT DOOR #612-02S DOOR IS DRAGGING NEED TO ADJUST DOOR CLOSURE
FO-338863	2/4/2016	2/5/2016		R/R INTERIOR DOOR #3 TO ENT DOOR #612-03S DOOR SCREW TO TOP PLATE IS COMING OUT
FO-338893	2/4/2016	2/26/2016		Our roll up garage door doesn't stop when it reaches the ground when it is closing. It continues trying to go further and seems like it is coming off the drive gear slightly. This causes a loud popping noise when we go to open and we are worried that the
FO-338923	2/4/2016	2/23/2016		Repair door leading into the storage/mechanical area on the lower level as you walk the east corridor back from the kitchen (and left). Door will not close and lock.
FO-338921	2/4/2016			RM 2137 MISSING/BROKEN FLOOR TILE
FO-338929	2/5/2016	2/9/2016		Carpenters- High priority (security)- Please repair or replace malfunctioning door latch and adjust door closer for softer closing. DOOR #611-03-N.
FO-339160	2/9/2016	2/9/2016		GATE NOT WORKING
FO-339162	2/9/2016	2/9/2016		SLIDING GARAGE DOOR NOT CLOSING PROPERLY
FO-339188	2/9/2016	2/10/2016		The door knob/lock is just about ready to fall off. We are now using a padlock to lock the door. The door knob needs to be repaired/replaced. Thank you.

WO	Recieved	Finished	Total	Request
FO-339220	2/9/2016	2/10/2016		DOOR HANDLE STAYS DOWN AND WON'T GO UP. DOOR WILL NOT LOCK. SUITE 202.
FO-339268	2/10/2016	2/12/2016		R/R Handicap door 082-07W has broken mounting screw for spring assembly on upper door channel. Spring assembly is lying on top of door and not preventing it from opening too far.
FO-339303	2/10/2016			Replace broken floor tiles in hallway outside room 110 Scott Hall. This is a trip hazard and needs to be done as soon as possible.
FO-339309	2/10/2016	2/11/2016		R/R 2ND FLR STRWL C DOOR WILL NOT OPEN
FO-339351	2/11/2016	2/26/2016		Overhead door will not open all the way and goes into alarm. This is impeding deliveries.
FO-339370	2/11/2016	2/12/2016		Carpenter to affix covers to underside of roof top elevator hoist way exhaust dog house on roof of building. Snow blowing into hoist way and landing on top of elevator. North east corner for front passenger elevator. See Kuffner.
FO-339378	2/11/2016	2/11/2016		Fabricate to prevent snow from entering elevator raceway. Steve And Jeff knows the job.
FO-339483	2/14/2016	2/16/2016		Room 112 Computer lab , Door handle is locked but the latch is not catching door can be pulled open. thanks Michelle
FO-339493	2/15/2016	2/15/2016		DOOR HANDLE IS BROKEN. WOMEN'S RESTROOM IN LOBBY. (DOOR IS LOCKED)
FO-339514	2/15/2016	2/15/2016		EXECUTIVE GARAGE DOOR IS UP AND WONT CLOSE
FO-339522	2/15/2016	2/16/2016		LOADING DOCK GATE WILL NOT CLOSE.
FO-339575	2/15/2016	2/16/2016		RM 327 SHADES NOT PROPERLY WORKING, SHADES WONT LET UP OR DOWN, ONE SHADE JUST HANGING ON WINDOW
FO-339770	2/16/2016	2/18/2016		R/R RM 335 RESECURE LOOSE & ABOUT TO FALL CLNG TILES, & ALSO REPLACE DAMAGED CEILING TILES
FO-339835	2/17/2016	2/18/2016		LEED plaque needs to be hung in the lobby, across from the main doors. To be hung at 5'6". The plaque is stored in my office.
FO-339843	2/17/2016	2/18/2016		9TH FL STORAGE RM DOOR NOT LOCKING, RM HAS NO NUMBER PLEASE GO TO RM 9408 FOR EXACT LOCATION
FO-339855	2/17/2016	2/22/2016		RM 6111 REPAIR BROKEN FLOOR TILE
FO-339923	2/18/2016	2/18/2016		1ST FL STAIRWELL DOOR, UNABLE TO GET INTO STAIRWELL KNOB JUST TURNS. DOOR IS PROPPED OPEN
FO-339949	2/18/2016	2/22/2016		Area 3510 door next to the service elevator on the third floor has been twisted and does not close therefore there is no security at that point.
FO-339952	2/18/2016	2/22/2016		RM 0113 BROKEN PROJECTOR SCREEN. (2) PROJECTORS WITHIN RM ONE WAS TAKEN FROM ANOTHER RM CONTACT PROF SANDRA @577-5225
FO-339962	2/18/2016	2/22/2016		CARP (2/19/16) ENG CANCELLED REQUEST PER SHAH R/R HANDICAP ENTRY DOOR #071 08E DOOR CLOSURE HAS SNAPPED/BROKEN (NOTE ENG WILL TRY & SECURE DOOR 2/18/16)
FO-339973	2/19/2016			**ADDING CARPENTER: Erect Scaffold in lecture hall 2009 to access plumbing leak. See Gerry for detail **ALSO provide access in wall to repair plumbing issue
				PLUMBERS Repair leaking water line in ceiling.
				High priority
				Related to FO; 339
FO-339991	2/19/2016	2/22/2016		Classroom 1545 has a desk hanging on by a lone bolt, in danger of breaking and potentially taking a student's work with it.  The desk is D 11-12, again, in room 1545--I think it needs 4 bolts with washers.
FO-340000	2/19/2016	2/22/2016		Stairwell #2 door on second floor has stuck door handle.

WO	Recieved	Finished	Total	Request
FO-340057	2/20/2016	2/22/2016		Trade: Carpenter Priority: High Door handle broken. Handle at engineer desk at state hall.
FO-340062	2/22/2016	2/22/2016		Carpenters. Please repair exterior door 166 02E, will not close on its own. Priority: High. Security item.
FO-340053	2/22/2016	2/22/2016		**ADDING CARPENTER: Replace missing ceiling tiles in 2009, Please do 1st thing Monday prior 9:00am if possible. See Gerry if needed  Investigate ceiling leak in 3225-a thought to be coming from Greenhouse ,,,,,,,,,,,,,, GS/2-17-16 ,,,,,,,,,,,,,, *
FO-340078	2/22/2016	2/22/2016		Closure on front entrance door 166-02E ias not working.
FO-340109	2/22/2016	2/23/2016		RM 178 LOCK NOT WORKING PROPERLY
FO-340113	2/22/2016	2/23/2016		Door lock on the last stall is broken. We had a student that got locked in the stall.
FO-340150	2/22/2016	2/23/2016		1ST FL ATRIUM LADIES RM DOOR LOCK NOT WORKING PROPERLY
FO-340228	2/23/2016	2/26/2016		Purdy Library 1st Floor Reference Area Two holes in floor in front of Public Computer #56. Safety Concern: Student might fall when rolling chair away from work station.  Please see Richard at the Check Out desk if more detailed information is needed.
FO-340229	2/23/2016			CARPENTRY DEPT-PLEASE REPAIR ROOFTOP LATCH TO ROOF ACSESS DOOR,LATCH WONT CATCH, SECURITY CONCERNS, PRIORITY HIGH
FO-340252	2/23/2016	2/24/2016		UGL Ladies Room, Room 3232, has main door handle to room in need of repair, it is loose and is pulled away from door.
FO-340300	2/23/2016	2/25/2016		Room 259 door frame is broken.
FO-340375	2/24/2016	2/25/2016		R/R RM 1154 THE ONLY WINDOW HAS A LEAK COMIN FROM AROUND PANE PLEASE SEAL AREAS AROUND FRAME/WINDOW
FO-340387	2/24/2016	2/25/2016		CARP R/R 1ST FL VESTIBULE AREA CEILING LEAK, DUE TO BUSTED GUTTER ABOVE AREA
FO-340400	2/24/2016	2/25/2016		NORTH END NEW ADDITION WOMEN'S BASKETBALL OFFICE, CEILING LEAK coming through window, needs to sealed.
FO-340439	2/25/2016	2/26/2016		Trade: Carpenter Priority: Medium to high Window seal leaking inside the staff office and out the office facing eastside. wall damaged.
FO-340456	2/25/2016	2/26/2016		DOOR SLAMS. 4TH FLOOR DOOR LEADING TO OFFICES. NEAR MEN'S RESTROOM.
FO-340478	2/25/2016	2/25/2016		R/R 4TH FLR GOING TOWARDS STE 4000 The entrance door from the atrium into the hallway near the stairs is slamming shut. It appears that the door spring is not working.
FO-340480	2/25/2016	2/26/2016		room 110 lav counter top about to come off wall DB
FO-340505	2/25/2016			Carpenters--Priority HighFoundation Leak --Southwest corner of bldg by drive.Concrete has broken loose allowing water into basement
FO-340533	2/26/2016	2/29/2016		DOOR HARD TO OPEN, PROBLEM WITH DOOR LOCK. ROOM 0249.
FO-340534	2/26/2016	2/29/2016		DOOR WON'T CLOSE PROPERLY. ROOM 0247.
FO-340555	2/26/2016			STORAGE RM CORE LOOSE ON LOCK CONTACT SGT. SAUNDERS FOR ENTRY 577-6063
FO-340564	2/26/2016			2ND FL MENS RM STALL DOOR HINGE IS BROKEN
FO-340572	2/26/2016			GARAGE DOOR IS NOT CLOSING
FO-340604	2/26/2016			The double doors to the storage closet, in Prentis suite 200, is ajar and will not stay closed. It actually blocks the hallway leading to the back advising offices. Please see front desk personnel for direction to the issue.
<b>T - Electrician</b>			<b>60</b>	
FO-338327	2/1/2016	2/1/2016		6TH FL W.WING CORRIDOR, RED EXIT SIGN HANGING BY THE WIRE ALSO FIRE ALARM PANEL HANGING OFF THE WALL BELOW EXIT SIGN
FO-338369	2/1/2016	2/1/2016		Install globe on Blue Light on NW corner of building where the globe is missing.
FO-338620	2/2/2016	2/2/2016		Power outlet on floor immediately to left of entrance is pulled out and wires are exposed. Please repair.

WO	Recieved	Finished	Total	Request
FO-338629	2/2/2016	2/4/2016		RM 226 CENTER LIGHTS NOT TURNING ON, NEED BREAKER RESET
FO-338721	2/3/2016	2/5/2016		Check all the pole lights, a lot of them seem to be out.
FO-338735	2/3/2016	2/4/2016		Disconnect heater over welding bench near pipe machine.
FO-338753	2/3/2016	2/3/2016		Conference room 2216 has 3 lights out, that have been tagged for electricians since July 2015. This is 1/4 of the lights in this teaching conference room. Please fix ASAP.
FO-338989	2/5/2016	2/5/2016		Meet Simplex Technician to install bad card in Fire Panel.
FO-338990	2/5/2016	2/5/2016		Fire Panel need to be put in by pass, so sprinkler head can be replaced.
FO-339046	2/5/2016	2/6/2016		R/R 2ND FLR STRWL K LITE NEEDS CHANGING (OVER 6ft)
FO-339185	2/9/2016	2/10/2016		Electricians, R/R RM 00011/MECH RM please repair/replace condensate pump 2. Pump works but has to be constantly turned off and reset to continue to operate properly.
FO-339318	2/10/2016			RM 150 LIGHT SWITCH NOT WORKING PROPERLY, ALL THE LIGHTS WONT TURN OFF
FO-339374	2/11/2016			In 3250 (lab), one of the Bio Hood UV lights is broken and needs replacing.
FO-339409	2/12/2016	2/12/2016		Repair/Replace light pole knock down by playground in rear of building.
FO-339435	2/12/2016	2/16/2016		R/R RM 1301 Please check the electrical plug under the time clock outside my office. I had two time clocks installed and both are losing time. See Mary with questions.
FO-339442	2/12/2016			R/R RM 2218 REPLACED EP 4-4-16 TAGGED LITE (Note: there is only 1 lite out of 2 wrkng)
FO-339462	2/12/2016			trade electrical priority high service exhaust fan unit has bad bearings and rotation of the exhaust fan is backwards rotation needs to be reverse
FO-339475	2/13/2016	2/15/2016		**ADDING ELECTRICIAN: Verify Voltage and phase of sanitary pump room 00021 . See Gerry or Ken for location if needed *Report findings to John Towle  PLUMBERS, PLEASE REPLACE BAD SANITARY SUMP PUMP & FLOAT ASSEMBLY. PRIORITY-HIGH. ,,,,,,,,,,,,,,
FO-339491	2/15/2016	2/15/2016		The light switch when you walk in the door off of the main hallway snapped off. This is in conference room 1145. Thank you.
FO-339498	2/15/2016	2/17/2016		**ADDING ELECTRICIAN: Disconnect condensate pump #1 in mechanical room #11. Reconnect when repairs are complete. See Ron Clark  Fitters, please repair/replace condensate return pump #1 in room 11. Motor runs, but not pumping.,,,,,,,,,,,,,,,,,, RC/2-11
FO-339513	2/15/2016	2/16/2016		One of the security lights has a light bulb that has broken at the base and can't be removed. Could an electrician come and remove the light bulb base from the fixture?
FO-339533	2/15/2016	2/26/2016		LOUD NOISE COMING FROM CEILING NOW THE LIGHTS ARE NOT ON. ROOM 0174.
FO-339553	2/15/2016	2/19/2016		Electrician repair several fire alarm dirty smoke heads throughout the building.
FO-339558	2/15/2016	2/15/2016		3rd floor right off the Elevator there's only one light fixture working, Please repair lighting in area so all fixtures are working.
FO-339743	2/16/2016	2/16/2016		**ADDING ELECTRICIAN ;Rewire domestic hot water recirculation pump in plumber lockup, See Gerry if needed  (**) PO REQ DK 2/1 RM 125/KITCHEN AREA ACROSS FROM WOMENS RR IN BUS SVCS SECTION HAS NO HOT WATER ,,,,,,,,,,,,,, GS/1-25-16,,,,,,,,,,,,,
FO-339748	2/16/2016	2/17/2016		**VERIFY Volts and phase on condensate receiver pumps in basement *Report findings to John Towle  **PRIORITY LOWERED/WORK IN PROGRESS JWT **FEED WATER SUPPLY CLEARED 2/13 JWT  EMERGENCY PIPE R/R RM 00045/MECH RM BSMT COND RET PUMP STOPPED WORKI



WO	Recieved	Finished	Total	Request
FO-339768	2/16/2016	2/17/2016		**ADDING ELECTRICIAN: Disconnect domestic hot water tank in janitors closet room 2358. See Troy Taylor if needed  R/R 2ND FLR JANITOR'S CLOSET REPAIR LEAK INHOT WTR TK ,,,,,,,,,,,,,, TT/2-11-16 ,,,,,,,,,,,,,
FO-339813	2/17/2016	2/19/2016		elect. determine cause and correct condition causing several wall duplex recepticals to not function. priority medium. ROSE REQUESTED HIGH PRIORITY CA
FO-339851	2/17/2016	2/18/2016		W. ENTRANCE BLUE LIGHT PHONE, LIGHT IS NOT WORKING
FO-339852	2/17/2016	2/18/2016		EAST ENTRANCE BLUE LIGHT PHONE, LIGHT IS NOT WORKING
FO-339866	2/17/2016	2/18/2016		REPLACE BLUE PHONE LIGHTS. NORTH SIDE OF BLDG.
FO-339867	2/17/2016	2/18/2016		REPLACE BLUE PHONE LIGHTS. SOUTH SIDE OF BLDG.
FO-339892	2/17/2016	2/22/2016		RM 1165 CLOCK MAKING A LOUD NOISE
FO-339905	2/18/2016	2/19/2016		Repair lights in St. Andrews Hall.
FO-339942	2/18/2016	2/19/2016		Trade: Electrician Priority: High R/R RM 00000.62/MECH BLR RM Please disconnect electricity from feedwater pump #2.
FO-339975	2/19/2016	2/19/2016		Trade: Electricians Priority: High R/R RM 00101.10-FAP LOCATION Please repair Fire Alarm System "Configuration Process Failure" trouble alarm.
FO-339990	2/19/2016	2/22/2016		Please clean light fixture and test light. There was a water leak on the floor just above it and the fixture collected water. The water is dry, but the office occupants are afraid to turn on the light. The dried water mark is unsightly and need
FO-339994	2/19/2016			R/R 1ST FLR (HEAD COACHES LOCKER/OFC RM A) Repair exhaust fan at football stadium building head coaches office. Thank You. Bob Ostrowski
FO-340005	2/19/2016			R/R RM 110 Repair the exhaust fan at the football stadium building... Room 110
FO-340008	2/19/2016	2/22/2016		Trade: Electrician Priority: High R/R RM 00000.62/MECH BLR RM Please reconnect electricity to boiler feed pump #2 and standby for rotation test.
FO-340006	2/19/2016	2/23/2016		R/R RM 120 Repair the exhaust fan at the football stadium building... Room 110
FO-340060	2/20/2016			please have electricianscheck north supply fan on ahu-8 tripping on overload. reset breaker and the fan keeps tripping. high priority
FO-340061	2/20/2016	2/24/2016		ELECTRICIANS: PLEASE CHECK LIGHTS IN BOILER ROOM RESET BREAKER OK STILL NO LIGHTS PRIORITY( HIGH)
FO-340063	2/22/2016	2/22/2016		Trade: Electrician Priority: High National Time fire panel has a trouble and will not reset.
FO-340096	2/22/2016	2/22/2016		Trade: Electrician Priority: High R/R RM 00000.62/MECH BLR RM Please disconnect the electrical connections from boiler feed pump #3.
FO-340138	2/22/2016	2/23/2016		Trade: Electrician Priority: High R/R RM 00000.62/MECH BLR RM Please reconnect feedwater pump #3 and standby during rotation test.
FO-340144	2/22/2016	2/26/2016		Move one man lift to Prentis building for Fitters to use.
FO-340245	2/23/2016			Purdy Library Exterior All "Lollipop" lights are out from the Purdy entrance to Cass Avenue. Area is rather dark after the sun sets. Safety concern for staff and students. Please repair.  Thank you.
FO-340267	2/23/2016	2/24/2016		RM 307 (3) OUTLETS HANGING OFF THE WALL. rp-2e-6 307-201 307-D01

WO	Recieved	Finished	Total	Request
FO-340306	2/24/2016			Electricians- Fire Panel High Priority- Fire Trouble light on Simplex Fire Panel for Scott Hall.
FO-340346	2/24/2016	2/24/2016		Exterior Lights on all day, find reason why, and correct.
FO-340348	2/24/2016			Exterior lights are on all day, trouble-shoot, and correct.
FO-340355	2/24/2016	2/25/2016		Electricians- R/R BSMT/MECH RM (FAP) Please replace card in Fire Alarm Panel 9th floor electrical room
FO-340357	2/24/2016	2/26/2016		LIGHT FIXTURES ARE BEEPING. ROOM 150.
FO-340376	2/24/2016	2/25/2016		Trade: Electricians Priority: High R/R RM 00000.62/MECH BLR RM Please reconnect feed water pump #1 in the Chemistry boiler room.
FO-340383	2/24/2016	2/26/2016		wet conditions panel in trouble NAC PNL M1-90 Earth ground
FO-340417	2/24/2016	2/25/2016		There is an issue with the incandescent lighting located over the conference table. None of it is workingg. I talked to Eugene Owens regarding this matter. Please direct this work order to his attention.
FO-340523	2/26/2016			High Priority Need Electricians to replace light bulbs on 2 outdoor lollipop lights on Cass Ave. 1 at entrance under awning. 1 at stage door entrance. 2 of the 4 need replacement bulbs. Because there are no city lights on Cass Ave. the theatre looks d
FO-340581	2/26/2016			Check Low Voltage Lighting System, and get information off Dimming Pack.
FO-340601	2/26/2016			There are 5 troubles on the Fire Panel, 2 belong to Bayview Electricians, but the other 3 are related to a water flow alarm, 1st floor near room 1239; NAC Panel 8th floor, and NAC Panel 9th floor.
<b>T - Locksmith</b>			<b>7</b>	
FO-338626	2/2/2016	2/9/2016		Please provide 6-keys for room 205. Core# 30AAB-15 key # 105987
FO-339489	2/15/2016	2/15/2016		Need replacement padlock for mail room @ 1200 Holden to replace padlock cut off.
FO-339515	2/15/2016			Make a key ring for the new Electrician. He need a Block key, MB, X192, X287, 25789-49, XOE22, OE22, X292 25296-269.
FO-339857	2/17/2016	2/26/2016		MOTOR CITY GRILL FRONT ENTRANCE DOOR WILL NOT UNLOCK.
FO-340067	2/19/2016	2/25/2016		New Key New Space Assignment Key #: 110863 Key Holder ID: Juanitta Hill Qty: 2  action: copy of 3 Master keys
FO-339993	2/19/2016	2/22/2016		Call-in by Public Safety for Mrs. Wilson. Please rekey the 3 entry doors (Master Keyed)  Dorothy Carter 02/19/2016 11:00 - Ok per Bobby Smith to create work order for this job under maintenance.
FO-340259	2/23/2016	2/23/2016		New Key New Staff Member Key #: See Set left in keyshop Key Holder ID: FP&M Qty: 4  action: 25296, xoe22, oe22, 14772
<b>T - Painter</b>			<b>6</b>	
FO-338886	2/4/2016	2/10/2016		please have painters seal the wall and floor near elevator back wall behind heat exchanger and pumps the floor is leaking to the 9th floor causing a slip hazard. high priority.
FO-339207	2/9/2016	2/10/2016		Please paint 3 ladders with Wayne State University Engineering. Ladders located in the stockroom.
FO-339518	2/15/2016	2/23/2016		Please paint WSU logo and engineering on ladder for FAB

WO	Recieved	Finished	Total	Request
FO-339988	2/19/2016	2/22/2016		**ADDING HANDY MAN: Please pick up will call Friday 2/19. See John Towle for direction  PLUMBERS Repair leaking water line in ceiling.  High priority  Related to FO; 339963 & 339887 ,,,,,,,,,,,,,, GS/2-18-16 ,,,,,,,,,,,,,,
FO-340294	2/23/2016	2/25/2016		RM 2115 DENT IN WALL ABOVE ELECTRICAL OUTLET
FO-340570	2/26/2016			HALLWAY NEAR 2091 DENT IN WALL TO THE RIGHT PLEASE REPAIR ALSO PAINT WAS LEFT INSIDE RM 2115
<b>T - Pipefitter</b>			<b>35</b>	
FO-338310	2/1/2016	2/2/2016		Fitters, please repair leak in steam coil on AHU-1 ,,,,,,,,,,,,,, ME/2-1-16 ,,,,,,,,,,,,,,
FO-338326	2/1/2016			In the dean's suite, Rm. 2627 there is a leak coming from the ceiling; the drip is constant. Please repair right away. ,,,,,,,,,,,,,, EA/2-1-16 ,,,,,,,,,,,,,,
FO-338331	2/1/2016	2/1/2016		LAB 450 ACTIVE CEILING LEAK ,,,,,,,,,,,,,,*ME/ GS/2-1-16 ,,,,,,,,,,,,,,
FO-338611	2/2/2016	2/4/2016		Steamfitter,please repair leaking Hydronic piping in PH,causing ceiling leak on 9th floor,outside elevators.FO-338599,PRIORITY HIGH ,,,,,,,,,,,,,, EA/2-2-16 ,,,,,,,,,,,,,,
FO-338737	2/3/2016	2/3/2016		Fitters, please repair leak in steam coil on AHU-1,,,,,,,,,,,,, ME/2-3-16 ,,,,,,,,,,,,,,
FO-338778	2/3/2016			Steam coil leak on #1 air handler. It needs to be repaired.,,,,,,,,,,,,,, ME/2-3-16 ,,,,,,,,,,,,,,
FO-338800	2/3/2016	2/8/2016		Celing leak. The researcher tried to move a ceiling tile and found that the tile is wet from above.,,,,,,,,,,,,,,ME/2-4-16 ,,,,,,,,,,,,,,
FO-338801	2/3/2016	2/4/2016		Steam fitters- high- repair glycol leak in ceiling of conference room.,,,,,,,,,,,,,, JH/2-3-16 ,,,,,,,,,,,,,,
FO-338898	2/4/2016			Purdy Library 1st Floor Open area outside of Staff Women's Restroom Water leaking from ceiling. Tile soaked with water, crumbled and fell to the floor.  Recurring problem. Please fix.  Thank you. ,,,,,,,,,,,,,, ME/2-4-16 ,,,,,,,,,,,,,,
FO-339034	2/5/2016	2/5/2016		REPAIRS TO DRAIN TRUUGH IN CEILING BEING CONTRACTED FOR REPAIRS.SEE TIMM HERR 577-4359 FOR DETAIL ON REPAIRS JWT 2/8/16  Rm. 4545 - Repair ceiling leak in the middle of room. Reports of chairs and tables getting wet.,,,,,,,,,,,,,, ME/2-5-16 ,,,,,,,,,,,,,,
FO-339161	2/9/2016	2/10/2016		fitters, repair leaks in the sensing line from the PRV on the south wall ,,,,,,,,,,,,,, JH/2-9-16 ,,,,,,,,,,,,,
FO-339166	2/9/2016	2/9/2016		**NOT A PIPE LEAK / EXSAUST VENT FROM AUTO CLAVE CONDENSING ON VENT PER RC . JWT 2/10  LAB 231 ACTIVE CEILING LEAK ,,,,,,,,,,,,,, JH/2-9-16 ,,,,,,,,,,,,,,
FO-339172	2/9/2016	2/10/2016		please have pipefitters replace air vent on hydronics penthouse high priority. ,,,,,,,,,,,,,, JH/2-9-16 ,,,,,,,,,,,,,,
FO-339256	2/10/2016			**PRIORITY LOWERED / WARMER OUTSIDE TEMPS NEEDED TO COMPLETE JWT 2/13/16  Scott hall basement room 356 and 529 (cage area) we have two severe pipe leaks. One in each area. Garbage cans have been filling up twice a day. Also cause damage to custodial equ
FO-339285	2/10/2016	2/11/2016		Please install the new head on the boiler softener at Cohn building ,,,,,,,,,,,,,, JH/2-10-16 ,,,,,,,,,,,,,
FO-339304	2/10/2016	2/18/2016		Trade: Pipefitter Priority: High Please repair leaking steam coil in AHU #3.,,,,,,,,,,,,,, ME/2-11-16 ,,,,,,,,,,,,,,
FO-339354	2/11/2016			Fitter replace leaking safety valve on boiler #2 ,,,,,,,,,,,,,, JH/2-11-16 ,,,,,,,,,,,,,,
FO-339416	2/12/2016			**PRIORITY LOWERED/WORK IN PROGRESS JWT **FEED WATER SUPPLY CLEARED 2/13 JWT  EMERGENCY PIPE R/R RM 00045/MECH RM BSMT COND RET PUMP STOPPED WORKING NEED REPIPING ,,,,,,,,,,,,,, JH/2-12-16 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-339508	2/15/2016	2/17/2016		MENS RM PIPE LEAKING NEAR SINK ..... JH/2-15-16 .....
FO-339557	2/15/2016	2/17/2016		please have pipe fitters repair leaking pre heat coils on ahu-13 bad steam leak from coils. high priority. .... EA/2-15-16 .....
FO-339561	2/15/2016			(**) PO REQ DK 2/23 Replace Danfoss radiator control valve with manual shutoff radiator steam valve. For Steven Pecic's office. .... JH/2-15-16 .....
FO-339751	2/16/2016	2/17/2016		please have pipefitters remove heat exchanger bundle on hydronics ac-8 to check the heat exchanger for leaks ..... EA/2-17-16 ..... high priority.
FO-339806	2/17/2016			Trade: Steam fitter Priority: High Radiator leak.
FO-339828	2/17/2016	2/17/2016		RM 2155 ACTIVE CEILING LEAK ..... JH/2-17-16 .....
FO-339858	2/17/2016	2/20/2016		Pipefitters-Please repair or replace fin tube radiator in office 109. Bad leak. Steam off at control valve. High Priority ..... EA/2-18-16 .....
FO-339910	2/18/2016			There is a leak in the ceiling in room 101.2 on the first floor. We hold therapy sessions in that room starting at 3:30pm today we need it fixed before then.  Thank You ..... EA/2-18-16 .....
FO-339932	2/18/2016	2/22/2016		RADIATOR LEAK. 2ND FLOOR WOMEN'S DRESSING ROOM. .... JH/2-18-16 .....
FO-339972	2/19/2016	2/22/2016		WSU Fitter:  Please replace reheat control valve for Rm 00108 - 1st floor lounge VAV ..... JH/2-19-16 .....
FO-340107	2/22/2016	2/22/2016		Water leaking from the ceiling into the lab area. The room had the same problem previously and the room tiles are belting from the previous and current leaks. .... JH/2-22-16 .....
FO-340260	2/23/2016	2/23/2016		There are four leaks currently in 2028 from the ceiling - 3 above the aisle ways and one above a lab bench. One of the leaks is going at a pretty good rate. The custodian found them and went upstairs to check. We've got buckets under all of them and Richa
FO-340295	2/23/2016	2/24/2016		LAB 3177 CEILING LEAK INSIDE DOORWAY ..... JH/2-24-16 .....
FO-340452	2/25/2016			Pipe fitters: Please repair or replace leaking reheat valve for room 200, it is leaking through and causing the room to be hot. the reheat valve is located in north east corner of fishbowl ceiling. priority: high. .... ME/2-25-16 .....
FO-340472	2/25/2016	2/25/2016		CEILING LEAK. ROOM 4001..... JH/2-25-16 .....
FO-340495	2/25/2016			please have pipefitters repair condensate tempering tank check repair or replace high priority ..... ME/2-25-16 .....
FO-340531	2/26/2016			RM 4032 CEILING LEAK TILE COLLAPSED ..... ME/2-26-16 .....
<b>T - Plumber</b>			<b>73</b>	
FO-338312	2/1/2016	2/2/2016		R/R RM 423 KITCHEN AREA HOT WATER FAUCET KNOB IS BROKEN ..... TT/2-1-16 .....
FO-338313	2/1/2016	2/2/2016		R/R RM 456 MENS RR (RIGHT) URINAL ISN'T FLUSHING ..... TT/2-1-16 .....
FO-338363	2/1/2016	2/2/2016		*REFER TO FO#338788 JWT  Purdy Library, R/R 1st Floor, Teaching Commons Inside entrance to Teaching Commons: water leaking from ceiling - running down wall and ceiling tiles are wet.  Outside entrance to Teaching Commons: ceiling tile hanging loose,
FO-338675	2/2/2016	2/3/2016		2ND FL WOMENS RM 1ST STALL TOILET HANDLE LEAKS ..... DB/2-3-16 .....
FO-338680	2/2/2016	2/3/2016		R/R 4TH FLR WOMENS RR NEAR RM 4100 ONE OF THE SINKS IS PLUGGED (CUSTODIAN PLUNGED SINK HOWEVER BLACK DEBRIS CAME UP) ..... TT/2-3-16 .....
FO-338701	2/2/2016	2/5/2016		R/R RM 1233 ONLY SINK FAUCET IS LKNG FROM WASHER ..... MM/2-3-16 .....
FO-338711	2/2/2016	2/9/2016		Mens room on both 1st and 2nd floor are plugged and backed up. .... GS/2-3-16 .....

WO	Recieved	Finished	Total	Request
FO-338717	2/3/2016			Trade: Plumber Priority: High Ceiling leak through drain pipe at south-west side of 2nd floor. GS/2-3-16 *****
FO-338767	2/3/2016	2/5/2016		Women's restroom 5th floor--all 5 sinks have about 1-2 inches of water in them. Looks like water is coming up from the drain. MM/2-3-16 *****
FO-338777	2/3/2016	2/4/2016		Womans rest room 1st floor. The handicap toilet is loose and now there is water leaking from it. TT/2-3-16 *****
FO-338803	2/3/2016	2/4/2016		Leak in sink plumbing. Bathroom located in Central Receiving. GS/2-4-16 *****
FO-338843	2/4/2016	2/4/2016		1ST FL MENS TOILET CONTINUOUSLY FLUSHING GS/2-4-16 *****
FO-338885	2/4/2016	2/9/2016		please have plumbers repair three leaking vacuum breakers in lab in room 4126. wasting water and leaking high priority. MM/2-5-16 *****
FO-338922	2/4/2016	2/10/2016		Low Level - Ladies restroom on the Brady side has possible leak from last toilet with water constantly on the floor. MM/2-5-16 *****
FO-338926	2/4/2016			(**) PO REQ DK 2/23 Sink underneath cabinet is leaking, wet floor in front of cabinet. Could be leaking from pipe or sink. Sink is on the left side of the lab. Thank you. MM/2-5-16 *****
FO-338932	2/5/2016	2/9/2016		Plumbers- high priority- Women's Lavatory 5th floor. Wash basins(5) are plugged up and need to be snaked. MM/2-5-16 *****
FO-338974	2/5/2016	2/16/2016		PLUMBERS please restore hot water flow to sink faucet,also there is redish/brown water coming from many hot water faucets.I suspect it came from Low Pressure Lab cold water Tank after last weeks water shut down.FO-338942 priority HIGH. *****
FO-338970	2/5/2016	2/8/2016		R/R 3RD FLR MENS RR (Only Mens RR on flr) THE ONLY URINAL IS CON'T FLUSHING TT/2-8-16 *****
FO-339024	2/5/2016	2/5/2016		*Per GS this was completed on 2/5/16 on another w.o. JWT  MENS RM 3277 MIDDLE STALL TOILET CONTINUOUSLY RUNNING GS/2-5-16 *****
FO-339171	2/9/2016	2/10/2016		PLUMBING DEPT-PLEASE REPAIR HANDICAP TOILET MENS REST ROOM 5TH FLOOR ACROSS FROM CONFERENCE ROOM 595 PRIORTY HIGH TT/2-9-16 *****
FO-339230	2/9/2016			Faucet is dripping and hard to turn off. MM/2-10-16 *****
FO-339231	2/9/2016			Faucet is dripping and hard to turn off. MM/2-10-16 *****
FO-339228	2/9/2016	2/10/2016		RM 331 SINK HAS STEADY STREAM OF WATER THAT WONT TURN OFF TT/2-10-16 *****
FO-339252	2/10/2016	2/10/2016		1st floor handicap water fountain has low water pressure. TT/2-10-16 *****
FO-339276	2/10/2016	2/16/2016		Small ceiling leak. There is a bucket in the place where it is dripping. *TT/JH/2-11-16 *****
FO-339284	2/10/2016	2/11/2016		Women's restroom: Stall toilet constantly running. GS/2-10-16 *****
FO-339320	2/10/2016	2/11/2016		Plumbers  Clear broken glass from garbage disposal.  High priority TT/2-11-13 *****
FO-339343	2/11/2016	2/16/2016		CEILING LEAK. ROOM 3117 (INSIDE OF ROOM 3108). *MM/EA/2-11-16 *****
FO-339347	2/11/2016	2/18/2016		R/R 2ND FLR JANITOR'S CLOSET REPAIR LEAK INHOT WTR TK TT/2-11-16 *****
FO-339358	2/11/2016	2/12/2016		2nd floor ladies room, the 2nd sink has a constant drip that needs repair. MM/2-11-16 *****
FO-339381	2/11/2016			*WATER RESTORED 2/11 JWT  RM 214/215 SUPPLY LINE IS FROZEN EMBAULMING LAB HAS NO WATER FLOW-PIPES COULD BE FROZEN POTENTIAL FLOODING PROBLEM TT/2-11-16 *****
FO-339381	2/11/2016			*WATER RESTORED 2/11 JWT  RM 214/215 SUPPLY LINE IS FROZEN EMBAULMING LAB HAS NO WATER FLOW-PIPES COULD BE FROZEN POTENTIAL FLOODING PROBLEM TT/2-11-16 *****

WO	Recieved	Finished	Total	Request
FO-339408	2/12/2016			Trade: Plumber Priority: High Please repair the leaking acid waste line above AHU #4 in the Life Science basement mechanical room. .... TT/2-13-16 .....
FO-339494	2/15/2016	2/16/2016		URINAL LEAKING AT BOTTOM. MEN'S RESTROOM IN LOBBY. .... DB/2-15-16 .....
FO-339520	2/15/2016	2/15/2016		**REFER TO FO#339347 / WORK IN PROGRESS / REPLACEMENT HOT WATER HEATER JWT 2/15  Since Friday, the water in the women's bathroom, 2nd floor has had low pressure and is FREEZING COLD. There does not seem to be any hot water.
FO-339535	2/15/2016	2/19/2016		RADIATOR LEAK. ROOM 109.1. .... EA/2-19-16 .....
FO-339582	2/15/2016	2/16/2016		3 stalls have brownish colored sludge in the toilet boils, flushed the toilets and the stain is still there .... TT/2-16-16
FO-339809	2/17/2016	2/19/2016		Please have plumbers repair leaking back flow preventer in the penthouse near hydronics. near elevator, high priority .... DB/2-18-16 .....
FO-339817	2/17/2016	2/20/2016		Investigate ceiling leak in 3225-a thought to be coming from Greenhouse .... GS/2-17-16 .....
				**FOLLOW UP WITH SLYVIA 2/17/16
FO-339823	2/17/2016	2/17/2016		**DUPLICATE/REFER TO FO#339826 JWT  RM 0224 SINK BACKING UP
FO-339846	2/17/2016	2/22/2016		TOILET WON'T FLUSH. WOMEN'S RESTROOM. 1ST STALL. ROOM 1374.2..... MM/2-18-16 .....
FO-339848	2/17/2016	2/18/2016		2ND FL MENS RM SINK IS PLUGGED .... TT/2-17-16 .....
FO-339860	2/17/2016	2/19/2016		LAB 4230 CONSTANT LEAK, WATER HAS BEEN MOPPED AWAY AND RETURNS SHORTLY AFTER. PLEASE INVESTIGATE LEAK .... TT/2-17-16 .....
FO-339862	2/17/2016	2/18/2016		Repair 3 steam leaks in room 3325. See Gerry for locations .... JH/2-17-16 .....
FO-339872	2/17/2016	2/19/2016		1st floor children bathroom in the early childhood center. Leaks everytime it is flushed..... DB/2-18-16 .....
FO-339904	2/18/2016	2/19/2016		BSMNT WATER DISPENSER NOT WORKING, WATER FILTER ISSUE .... TT/2-18-16 .....
FO-339922	2/18/2016	2/18/2016		R/R RM 128/MENS RR (BUS SVCS SIDE) ONLY SINK IS DRAINING VERY SLOW .... TT/2-18-16 .....
FO-339940	2/18/2016	2/19/2016		URINALS ARE NOT WORKING. MEN'S RESTROOMS 3238 AND 3438. .... DB/2-18-16 .....
FO-339941	2/18/2016	2/18/2016		6TH FL UNISEX RESTROOM STALL TO THE RIGHT, TOILET IS PLUGGED .... TT/2-18-16 .....
FO-339955	2/18/2016	2/19/2016		R/R 3RD FLR LADIES RR NEAR STE 3638 ONE OF THE SINKS IS PLUGGED .... DB/2-19-16 .....
FO-339958	2/18/2016			(**) PO REQ DK 2/29 PR#1  R/R RM 2122 Please repair the DI water faucet, it will not turn off. (Note: AA Shift Bldg Eng will turn off wtr) .... GS/2-19-16 .....
FO-339966	2/19/2016	2/20/2016		PLUMBERS  Repair leaking water line in ceiling.  High priority  Related to FO; 339963 & 339887 .... *DB/GS/2-18-16 .....
FO-339983	2/19/2016			Plumbers: MED High Follow-up from WO FO-337560  The showers in the first floor women's restroom does not have hot water. Please determine if the balancing valves is in-need of adj., cleaning or repair. If repair is needed the installing contractor w
FO-340007	2/19/2016	2/22/2016		EMERGENCY PLUM R/R NEAR FOOTBALL STADIUM/CLOSER TO I-94 FREEWAY DWSD SAYS THEY HAVE A WATER MAIN BREAK NEED SOMEONE ASAP .... DB/2-19-16 .....
FO-340012	2/19/2016	2/22/2016		R/R R 8229 SINK @ YOUR RIGHT AS YOU COME INTO RM HOT WATRER FAUCET WILL NOT TURN OFF-WTR IS FLOWING GETTING HOTTER .... MM/2-19-16 .....

WO	Recieved	Finished	Total	Request
FO-340097	2/22/2016	2/22/2016		MENS RM 1362 SINK TURN ON AND OFF BY ITSELF ..... DB/2-22-16 .....
FO-340110	2/22/2016			Plumber clear floor drain in penthouse next to air compressor ..... GS/2-22-16 .....
FO-340123	2/22/2016	2/23/2016		R/R RM 1340 Private women's bathroom on the first floor has a sink that is clogged. ..... DB/2-22-16 .....
FO-340149	2/22/2016	2/23/2016		1ST FL ATRIUM DRINKING FOUNTAIN IS CLOGGED ..... DB/2-23-16 .....
FO-340234	2/23/2016			PLUGGED SINK. 4TH FLOOR MEN'S RESTROOM. ROOM 4101..... MM/2-23-16 .....
FO-340266	2/23/2016	2/23/2016		RM 1241 DEANS OFC TOILET IS BUBBLING COULD OVERFLOW ..... DB/2-23-16 .....
FO-340270	2/23/2016	2/23/2016		LADIES RM 502 NO HOT WATER ..... DB/2-23-16 .....
FO-340283	2/23/2016	2/25/2016		TOILET CONTINUOUSLY FLUSHING. 1ST FLOOR LADIES RESTROOM. ROOM 110..... DB/2-24-16 .....
FO-340305	2/24/2016			Plumbers- High Priority- Plugged toilet in the dean's office. Please clear and restore to service.
FO-340341	2/24/2016	2/25/2016		4TH FL 2ND STALL WONT FLUSH ALSO 1ST STALL TOILET SEAT LOOSE ..... TT/2-24-16 .....
FO-340377	2/24/2016	2/25/2016		R/R 7TH FLR ONLY MENS RR THE ONLY SINK IS PLUGGED & FILLED TO THE BRIM ..... TT/2-24-16 .....
FO-340530	2/26/2016	2/26/2016		**CANNOT PUMP DOWN ICE / REQUESTED GROUNDS TO SALT THIS MORNING 2/26 / WILL TRY TO PUMP DOWN MONDAY 2/29 / **NO WORK ORDERS NEED TO BE WRITTEN ON THIS / REFER TO FO#337091 / THIS IS BEING CHECKED DAILY JWT 2/26
				The loading dock has water and ice bui
FO-340635	2/26/2016			Pump sump down for Guardian Plumbing to evaluate rail hardware ..... TT/ 2-26-16 .....
FO-340549	2/26/2016			Room 215 at the 3rd table the plastic elbow joint under sink has leak. Per instructor please repair as soon as possible we have standing water on the floor from the leak. .... TT/2-26-16 .....
FO-340571	2/26/2016	2/26/2016		**DUPLICATE WORK ORDER / REFER TO FO#338604DB / MATERIAL ON ORDER JWT 2/29
				2ND FL DRINKING FOUNTAIN IS NOT COLD, WOULD LIKE NEW COOLING UNITS ..... DB/2-26-16 .....
FO-340579	2/26/2016			2ND FL UNISEX RESTROOM NEAR RECEPTION DESK. TOILET CLOGGED ..... DB/2-26-16 .....
FO-340594	2/26/2016			FLOOR DRAIN IS PLUGGED. ROOM 410..... MM/2-26-16 .....
FO-340600	2/26/2016			2ND FL MENS RM TOILET CONTINUOUSLY RUNNING ..... DB/2-26-16 .....
<b>T - Roofing</b>			<b>9</b>	
FO-338718	2/3/2016			Trade: RooferPriority: HighCeiling leak at Dean office at the center of the hallway.
FO-338924	2/4/2016			From Jason (Aramark)... "One of the two leaks occurs in heavy rain out of the sky lights in the lobby. Almost in the middle of the building to the left side if looking at the pond.The second leak is in the wall of room C to the pond end of the buil
FO-339212	2/9/2016			There is a leak and mold in the wall on the second floor right outside the elevator entering into the Rands House on the second floor.
FO-340388	2/24/2016			ROOFER: R/R 1ST FL VESTIBULE AREA CEILING LEAK, DUE TO BUSTED GUTTER ABOVE AREA REPAIR ROOF AFTER GUTTER HAS BEEN REPAIRED
FO-340395	2/24/2016			ROOFER R/R 3RD FLR NEAR RESTROOM 3238 CEILING IS LEAKING
FO-340412	2/24/2016			Roofers: Please repair roof leak around skylight on top of the north stairway. priority: high.
FO-340414	2/24/2016			Roofers: please repair roof leak from top of windows in room 200.2. Priority: high
FO-340423	2/24/2016			ROOF LEAK ABOVE WEST ENTRANCE. CONTANT NATHAN CRIST FOR DETAILS.
FO-340524	2/25/2016			Room 271 water dripping form roof on to ceiling light fixture.This is for the roofing Department.
<b>Medium</b>			<b>135</b>	
<b>T - Carpenter</b>			<b>28</b>	

WO	Recieved	Finished	Total	Request
FO-338792	2/3/2016	2/4/2016		R/R RM 153.1 AFTER REPLACING DOOR LOCK KEYS ARE NOW VERY HARD TO MANEUVER IN DOOR LOCK
FO-338969	2/5/2016			**ADDING CARPENTER: Install 30"x24" wood panel to cover hole in wall located in custodial closet across from elevator 2nd floor. See Gerry (Plumber ) if needed  Plumbers, please replace mop sink faucet that is beyond repair,,,,,,,,,GS/2-3-16 ,,,,,,
FO-338973	2/5/2016	2/16/2016		**ADDING CARPENTER: Replace stained ceiling tiles in conference room 1130.5 JH  Steam fitters- high- repair glycol leak in ceiling of conference room,,,,,,,,,,,,, JH/2-3-16 ,,,,,,,,,,
FO-338979	2/5/2016	2/8/2016		WINDOW BLINDS WILL NOT GO DOWN. ROOM 3315.
FO-339041	2/5/2016	2/11/2016		CARPENTERS: Please replace several floor tiles in room 1306 due to pipe leak. MED.
FO-339218	2/9/2016	2/11/2016		**ADDING CARPENTER: Replace ceiling tile in room #2 inside room 133 on the west end of 1st floor. See Marty Elwart if needed  Celng leak. The researcher tried to move a ceiling tile and found that the tile is wet from above,,,,,,,,,,,,,ME/2-4-16
FO-339265	2/10/2016	2/15/2016		CARPENTERS: Please repair seat in auditorium. South side, 3rd row from top. MED.
FO-339283	2/10/2016	2/24/2016		**ADDING CARPENTER:Drinking fountain outside 3342 please add wall studs and backing board added for new fountain install. See Troy Taylor for detail  (**) PO REQ DK 1/4 R/R 3RD FLR HALLWAY Water is leaking from UNDERNEATH @ WALL NEXT TO the water fou
FO-339401	2/12/2016	2/15/2016		CARPENTERS, WARREN SIDE HANDICAP VESTIBULE DOOR NOT OPENING FULLY ALSO HANDICAP PUSH PAD AT STAIRS NOT FUNCTIONING, PLEASE REPAIR. PRIORITY-MEDIUM
FO-339569	2/15/2016	2/16/2016		CARPENTERS: Please repair security door on 3rd floor at freight elevator. MED
FO-339571	2/15/2016	2/18/2016		Carpenters: please repair several loose floor tiles on 4th floor in front of elevators, some of them are trip hazard. priority: med.
FO-339769	2/16/2016	2/24/2016		R/R RM 333 REPLACE CLNG TILES THAT ARE DAMAGED, FALLEN & MISSING
FO-339782	2/16/2016	2/17/2016		CARPENTERS, PLEASE REPAIR LOOSE HALLWAY FLOORING NEAR ROOM 3338. PRIORITY-MEDIUM
FO-339834	2/17/2016	2/17/2016		Faculty office door 1324 is sticking. Difficult to open and close.
FO-339833	2/17/2016	2/25/2016		Ceiling tile outside of 1321 needs to be replaced. Rusted water stain on tile.
FO-339875	2/17/2016	2/18/2016		RE-ATTACH SIGN 206.1, STAIRWELL SIGN 2ND FLOOR WEST WING, 109 1ST FLOOR LOBBY. SEE DR. GREENWALD IN ROOM 206 IF NEEDED. MUST BE DONE PRIOR TO 2/26/16.
FO-339927	2/18/2016			Carpenters:Please replace two bad ceiling tiles in room 3339. Medium priority.
FO-340131	2/22/2016			Carp Med PriorityReplace or repair ceiling tile 1st fl. hallways
FO-340132	2/22/2016			Carp Med PriorityReplace or repair ceiling tile 2nd fl. hallways
FO-340133	2/22/2016			Carp Med PriorityReplace or repair ceiling tile 3rd fl. hallways
FO-340146	2/22/2016	2/23/2016		R/R Interior LOBBY DOOR FOR ENTRANCE DOOR #629 01S inside east front door is catching and difficult to open. Please repair.
FO-340415	2/24/2016			WATER COMING IN THRU WINDOW (EVERY TIME IT RAINS). ROOM 1150.
FO-340422	2/24/2016	2/25/2016		This adds to previous request (#280963) for assistance with squeaking door: A second door is noticeably squeaking: UGL 096 inner door, corresponding to outer door UGL 096 04E.
FO-340517	2/25/2016	2/26/2016		Please re-hang the bulletin board at the 3rd floor reception area. It was taken down to repair a leak, now needs one drywall anchor to re-hang it.



WO	Recieved	Finished	Total	Request
FO-340519	2/26/2016			*ADDING CARPENTER : Replace stained ceiling tiles in room 3177 and 3171 JH  LAB 3177 CEILING LEAK INSIDE DOORWAY ,,,,,,,,,,,,,, JH/2-24-16 ,,,,,,,,,,,,,,
FO-340521	2/26/2016			Request from Safety Committee:  Build stairs/steps to entrance of Generator Enclosure.
FO-340522	2/26/2016			Request from Safety Committee:  Build stairs/steps to entrance of Generator Enclosure.
FO-340542	2/26/2016			1ST FL STAIRWELL DOOR NEAREST ANTHONY WAYNE, DOOR HAS GREASE OR OIL FROM DOOR CLOSURE
<b>T - Electrician</b>			<b>26</b>	
FO-338314	2/1/2016	2/10/2016		Check all lights, and receptacles to make sure all is working, need to be done by Friday.
FO-338719	2/3/2016			Trade: ElectricalPriority: MediumPlease install blank plate cover to cover hollow space at lounge area or hall.
FO-338794	2/3/2016	2/9/2016		Trade: Electrician Priority: Medium Location: R/R Basement hall outside Lab 30 Please make needed repairs to the in ceiling lights around the Lumigen Instrument Center. Only a few are still lit.
FO-338830	2/4/2016	2/4/2016		Time for Electricians to have Safety Meeting for month of February, 2016.
FO-338992	2/5/2016	2/10/2016		We have a few lights over pool out, and need them lamped as soon as possible.
FO-339022	2/5/2016	2/11/2016		Check, and repair Exit signs on 1st floor, and basement.
FO-339048	2/5/2016	2/12/2016		ELECTRICIANS: Please replace UV Light in Fume Hood in room 3530.MED.
FO-339068	2/6/2016	2/8/2016		Replace 9 burnt out lights in room 100 and 6 burnt out lights in room 115 Lande. Rooms are currently unoccupied and locked. Contact Sheryl MacGillis at 577-1446 or Krista Mitchell at 577-9028 for access to the rooms.  Turned over to Electricia
FO-339097	2/8/2016	2/10/2016		Combustion Damper Safety interlock wiring jumpered out.  Dampers not working. A. Waller found electric damper actuator wires cut.  Please run new control wiring from boiler control panel to damper actuator. Contact Aubrey Waller for more details.
FO-339164	2/9/2016	2/10/2016		trade electricians priority medium R/R 3RD FLR please replace over head lights coming off third floor elevator right above pop machians theirs two just hanging
FO-339165	2/9/2016	2/10/2016		electricians R/R 5TH FLR please replace bad lighting switch across from lab 5155 and theirs lights out on this floor due to the switch priority medium
FO-339210	2/9/2016	2/10/2016		Verify volts/phase required to complete hook up on Gorman Rupp sewage ejector located near elevator in sub-basement. This is the pump that is not piped in or wired *Provide findings to John Towle
FO-339279	2/10/2016	2/12/2016		trade electrical priority medium R/R 2ND FLR please service smoke detectors on second floor that is off base and leaning they are not fully connected see smiley engineer for locations
FO-339280	2/10/2016	2/11/2016		trade electrical priority medium R/R 2ND FLR please service second floor bank of lights that's out check all breakers and they are set lighting still out
FO-339301	2/10/2016	2/11/2016		trade electrical priority medium R/R 1ST FLR please service fire alarm panel its showing game well trouble in the clean room area
FO-339464	2/12/2016	2/15/2016		Trade: Electricians Priority: Medium R/R 4TH FLR Please repair stairwell light in stairway going to the 4th floor off the Warren stairway.

WO	Recieved	Finished	Total	Request
FO-339474	2/13/2016	2/26/2016		***ADDING ELECTRICIAN: Electrical outlet needed for drinking fountain in hall near room3342. See Troy Taylor when completed  (**) PO REQ DK 1/4 R/R 3RD FLR HALLWAY Water is leaking from UNDERNEATH @ WALL NEXT TO the water fountain outside of the rest
FO-339477	2/14/2016	2/19/2016		Repair fire panel is experiencing intermittent nuisance alarms going off and at UGL. One time he panel read, "Pull station, second floor", and then reset itself.
FO-339478	2/14/2016	2/16/2016		Repair trouble in fire alarm panel at Welcome Center. Fire trouble reads, "Pull Station, 2nd floor".
FO-339737	2/16/2016	2/26/2016		CLOCK IS NOT WORKING. ROOM 1165.
FO-340016	2/19/2016			Please provide power to, 1)Relay box and 2)Spence Solenoid in basement.
FO-340126	2/22/2016	2/23/2016		trade electricians priority medium R/R RM 2130 please replace bad light switch in room 2130 and theirs no lights in this room
FO-340262	2/23/2016			ELECTRICIANS,PLEASE CORRECT FAULT ON AUX FIRE PANEL.PRIORITY-MEDIUM
FO-340344	2/24/2016	2/26/2016		Trade: Electrician Priority: Medium R/R RM 1360 The engine exhaust fan indicating light is not working in lab 1360, it is located inside the lab just above the entrance door, please fix.
FO-340461	2/25/2016	2/26/2016		**ADDING ELECTRICIAN: Disconnect sump pump #2 located in fan room #2. See Gerry for detail  Replace Sump pump #2 located in fan room #2 new pump replacement is not pumping ,,,,,,,,, GS/1-11-16,,,,,,,,,
FO-340574	2/26/2016			LOT 15 & MALL NEAR COHN BLDG (2) BLUE LIGHTS OUT
<b>T - Locksmith</b>				<b>2</b>
FO-338832	2/4/2016	2/4/2016		Please make 7 keys for the generator door at Student Center.
FO-338861	2/4/2016	2/23/2016		Cut 3 keys for One-Man Lift.
<b>T - Painter</b>				<b>5</b>
FO-339422	2/12/2016	2/26/2016		Please stencil Engineering Convertible Handtrucks.
FO-339876	2/17/2016	2/25/2016		PAINT WALL IN WEST WING STAIRWELL BASEMENT LEVEL CORNER TO CORNER WHERE PATCH IS. PAINT PEELING WALL IN ROOM 202 CORNER TO CORNER. MUST BE DONE PRIOR TO 2/26/16.
FO-340004	2/19/2016	2/25/2016		Touch up the ceiling before the glass door leading to the 100 suite and touch up the ceiling in the north west lobby. Must be done prior to 2/26/16
FO-340011	2/19/2016	2/23/2016		Please stencil Engineer 6' Ladders Qty: 2
FO-340518	2/26/2016			**ADDING PAINTERS : Please patch and paint drywall that was repaired by Carpenters so Plumber can mount new drinking fountain. 3rd floor hall near 3342 *See Troy (Plumber) when complete  (**) PO REQ DK 1/4 R/R 3RD FLR HALLWAY Water is leaking from
<b>T - Pipefitter</b>				<b>25</b>
FO-338319	2/1/2016	2/4/2016		PIPEFITTER REPLACE BROKEN BLOWDOWN VALVE AIR COMPRESSOR ,,,,,,,,,, JH/2-1-16 ,,,,,,,,,,  MEDIUM PR
FO-338594	2/2/2016	2/3/2016		trade pipe fitters priority medium please secure leaking flange coming off heating pump hwp-2 in basement small leak theirs water on floor from leak ,,,,,,,,,, RC/2-2-16 ,,,,,,,,,,
FO-338741	2/3/2016			Trade: Pipe Fitters Priority: Medium Location: Receiving mech. rm ,,,,,,,,,, JH/2-3-16 ,,,,,,,,,,  Please repair and/or replace AHU-3's pre-heat steam valve. The valve is letting steam leak by causing overheating.
FO-338822	2/4/2016	2/9/2016		Fitters, R/R PENTHOUSE please repair leak in steam coil on AHU-1. Priority: Medium ,,,,,,,,,, JH/2-5-16 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-338866	2/4/2016			(**) PO REQ DK 2/22 FITTERS, PLEASE REPAIR STEAM LEAK ON OAHU#3 HUMIDIFER UNIT. PRIORITY-MEDIUM ,,,,,,,,,, JH/2-5-16 ,,,,,,,,,
FO-338881	2/4/2016	2/10/2016		To pipe fitters. Please repair or replace leaking flange gasket on PRV in room 23 above air tanks.,,,,,,,,,, ME/2-5-16 ,,,,,,,,,
FO-338882	2/4/2016	2/9/2016		To pipe fitters. Please replace broken 3/8" black pipe drain line that snapped off of bottom of tank #2. ,,,,,,,,,, ME/2-5-16 ,,,,,,,,,
FO-338911	2/4/2016			(**) PO REQ DK 2/22 FITTERS: Please repair/ replace leaking Pilot Valve on domestic hot water tank#1 MED. ,,,,,,,,, JH/2-5-16 ,,,,,,,,,
FO-339173	2/9/2016	2/25/2016		Trade: Pipe Fitter Priority: Medium Please replace failed steam trap on H&V units #11 & 12 reheat coils in lab wing basement. ,,,,,,,,, JH/2-9-16 ,,,,,,,,,
FO-339253	2/10/2016			To pipe fitters. Please replace both OS&Y isolation valves for PRV on McGregor steam line in this room.,,,,,,,,,, ME/2-11-16 ,,,,,,,,,
FO-339255	2/10/2016			Trade: Pipefitter Priority: Medium Repair or replace failed steam trap on east basement fresh air steam coil. ,,,,,,,,,, JH/2-11-16 ,,,,,,,,,
FO-339302	2/10/2016	2/15/2016		To pipe fitters. Please replace defective and broken strainer on SF-8 for steam coil and clear drip leg of debris.,,,,,,,,,, ME/2-11-16 ,,,,,,,,,
FO-339329	2/11/2016	2/18/2016		Fitters, please repair/replace condensate return pump #1 in room 11. Motor runs, but not pumping.,,,,,,,,,, RC/2-11-16 ,,,,,,,,,
FO-339410	2/12/2016	2/18/2016		J Hill pls test check troubleshoot repair condensate leaking on floor from condensate receiver in store room cage slip n fall hazard ,,,,,,,,,, JH/2-12-16 ,,,,,,,,,
FO-339411	2/12/2016	2/17/2016		r/r steam trap in the2nd floor mens room near electrical shop office and the trap below in the hall way 1st floor near main stair way ,,,,,,,,,, JH/2-12-16 ,,,,,,,,,
FO-339541	2/15/2016			(**) PO REQ DK 2/23 To pipe fitters. Please replace steam valve and actuator on SF-10 rm. 25. ,,,,,,,,,, ME/2-15--16 ,,,,,,,,,
FO-339551	2/15/2016	2/19/2016		Fitter repair leaking flange at steam reducing station.,,,,,,,,,, ME/2-15-16 ,,,,,,,,,
FO-339822	2/17/2016			FITTERS: Please repair 4th floor HEAT EXCHANGER in room 4115. MED.,,,,,,,,,, ME/2-18-16 ,,,,,,,,,
FO-339836	2/17/2016			(**) PO REQ TH 2/19 Refabricate header supplying hydronic heat over pumps in mechanical room 100. Header has numerous leaks Tis needs to be completed to finish installing new hydronic circulation pumps ,,,,,,,,,, EA/2-17-16 ,,,,,,,,,
FO-339854	2/17/2016	2/22/2016		To pipe fitters. Repair or replace leaking flange on Circulating pump #1 on inlet side of pump. ,,,,,,,,, ME/2-18-16 ,,,,,,,,,
FO-339953	2/18/2016	2/20/2016		Radiator problems, Leaking and wet rug in at least 4 different rooms: 102.8, 102.7, 109.1, 244 ,,,,,,,,,, EA/2-19-16 ,,,,,,,,,
FO-340095	2/22/2016	2/24/2016		To pipe fitters. Please install new coalescing filter for air station on SW wall of rm. 25. See building engineer for part. ,,,,,,,,,, ME/2-22-16 ,,,,,,,,,
FO-340269	2/23/2016	2/24/2016		Pf Med Priority Remove and re install condenser piping. Assist Engineer ,,,,,,,,,, EA/2-23-16 ,,,,,,,,,
FO-340396	2/24/2016			PLEASE REPAIR OR REPLACE STEAM TRAP ON AC-8 STEAM COIL, VENT LINE OVERFLOWING PRIORITY MED ,,,,,,,,,, JH/ 2-24-16,,,,,,,,,
FO-340566	2/26/2016			Fitters, repair a small leak in the recently installed pro-press pipe to the side stream filter. priority medium.,,,,,,,,,, ME/2-26-16 ,,,,,,,,,
<b>T - Plumber</b>			<b>46</b>	
FO-338318	2/1/2016			(**) PO REQ DK 2/22 Trade: Plumbers Priority: Medium Please replace the leaking relief valve in the discharge line of the Domestic Hot Water Tank. The valve tag looks like its a 45 or 55 psig at 210 degrees. The tag is hard to see, however per the pres

WO	Recieved	Finished	Total	Request
FO-338329	2/1/2016	2/1/2016		*DUPLICATE/ REFER TO FO#338329 JWT  Trade: Plumbers Priority: Medium Location: #2 Fan Room The newly installed sump pump is NOT pumping. GS/2-1-16
FO-338332	2/1/2016			(**) PO REQ DK 2/22 trade plumbers priority medium please service leaking pipe in ceiling in lab 5131 TT/2-1-16
FO-338588	2/2/2016	2/5/2016		Plumbers: Please repair women's rest room toilet on the third floor. Toilet is leaking at the spud connection. Toilet is bagged. Medium Priority. GS/2-2-16
FO-338595	2/2/2016			PLUMBERS: Please check bypass line between the two Sumps in Boiler room. MED. Attn. MIKE MM/2-2-16
FO-338596	2/2/2016	2/2/2016		PM all bathrooms for any fixture repairs needed. All repairs to be completed by Friday 2/5 for an event being held Monday 2/8 in room 100 TT/2-2-16
FO-338602	2/2/2016			Plumb Med PriorityPlease re anchor several yr.old temp catch basin behind AHU # 1. Support is busted and basin is hanging and not doing the job. Also provider fitting and drain line to sewer to prevent water from flowing on floor creating a slip hazard
FO-338604	2/2/2016			(**) PO REQ DK 2/22 R/R 2ND FLR BTWN MENS/WOMENS RR LOUNGE AREA HIGHER DRINK FOUNT IS BAGGED (also note same fountain when in use wtr spouts over fountain & water is warm) DB/2-2-16
FO-338785	2/3/2016	2/11/2016		R/R RM 5258 THE LARGEST SINK HAS A DRIPPING FAUCET MM/2-3-16
FO-338806	2/3/2016			2nd floor drinking fountain-water tastes horrible GS/2-4-16
FO-338975	2/5/2016	2/15/2016		plumber replace ball valve for water bottle rack. It's leaking. MM/2-8-16
FO-339036	2/5/2016	2/8/2016		trade plumbers priority medium please service men's toilet in bath room2130 leaking spud and crack seal behind toilet is causing water to filtrate out into hall area TT/2-8-16
FO-339092	2/8/2016	2/12/2016		Plumbers (Medium)  Floor drain between the rear of the boilers is plugged. Please snake out. MM/2-8-16
FO-339117	2/8/2016			(**) PO REQ DK 2/23 R/R RM 515 ONLY SINK IS LKNG @ THE FAUCET TT/2-9-16
FO-339182	2/9/2016			Plumbers, please repair leaky hot water valve and low water flow for cold and hot water in basement women's restroom. MM/2-9-16
FO-339196	2/9/2016			Replace 3 flush valves in the Public restroom basement floor near room 014 GS/2-25-16
FO-339251	2/10/2016	2/10/2016		*DUPLICATE /REFER TO FO#339252  1st floor handicap water fountain has low water pressure.
FO-339367	2/11/2016	2/15/2016		Toilet is leaking water in the back when flushed, near handle. TT/2-11-16
FO-339450	2/12/2016	2/17/2016		LEAKY FAUCET. ROOM 0519. TT/2-12-16
FO-339466	2/12/2016	2/15/2016		R/R RM 3337/MENS RR TOILET STALL HAS A BAG OVER IT TT/2-12-16
FO-339467	2/12/2016			R/R RM 3337/MENS RR ONE OF THE URINALS HAS BEEN BAGGED MM/2-12-16
FO-339479	2/14/2016	2/23/2016		Repair drinking fountain located in basement of Cohn nearest 010.1. The cooling compressor is humming and not running. Circuit breaker #20 in nearby closet opened to disconnect power to fountain. TT/2-15-16
FO-339490	2/15/2016	2/22/2016		CLOGGED TOILET. ROOM 9101. MM/2-15-16
FO-339492	2/15/2016	2/22/2016		PLUMBERS: Please repair leaking backflow preventer. Northwest wall of room 0130. MED. DB/2-15-16
FO-339726	2/16/2016			PLUMBERS DEPT-PLEASE REPLACE MISSING WATER FOUNTAIN OR COVER HOLE IN WALL UNTIL FOUNTAIN IS REPLACED ACROSS THE HALL FROM SEMINAR ROOM 553 PRIORITY MED TT/2-16-16
FO-339805	2/17/2016			Trade: Plumber Priority: Medium Garbage disposal sometime pushing up. Unclogged and O.K Still need to be check. TT/2-29-16

WO	Recieved	Finished	Total	Request
FO-339807	2/17/2016			Trade: Plumber Priority: Medium No hub connector leaking through roof conductor. Droplets outside R150. .... TT/2-29-16 .....
FO-339847	2/17/2016	2/19/2016		Single Men's Room #13128.00, nearest the freight elevator. Sink faucet is very hard to turn on and off and is dripping. It only has one handle. Thank you! .... TT/2-18-16 .....
FO-339881	2/17/2016	2/17/2016		**REFER TO FO#340356 / ENGINEERING DEPARTMENT TO FOLLOW UP ON REPAIR. THIS IS NOT A PIPE SHOP REPAIR JWT 2/24  cage washer vent pipe is causing condensation to travel and leak into lab 231 in basement animal quarters trade plumbers priority medium
FO-339968	2/19/2016	2/22/2016		Trade: Plumber Priority: Medium Across R 0129, 1st stall toilet is not flushing. .... TT/2-19-16 .....
FO-339969	2/19/2016	2/22/2016		Trade: Plumber Priority: Medium Urinal not flushing AND 1ST STALL TOILET LEAKING AT TAIL PIPE. .... TT/2-19-16 .....
FO-339970	2/19/2016	2/22/2016		Trade: Plumber Priority: Medium 1st stall toilet won't flush. .... TT/2-19-16 .....
FO-339971	2/19/2016	2/23/2016		Trade: Plumber Priority: Medium Toilet leaking at Tail pipe. .... TT/2-19-16 .....
FO-340056	2/20/2016	2/22/2016		Trade: Plumber Priority: Medium Sink clogged. Need to be snake. .... TT/2-22-16 .....
FO-340058	2/20/2016	2/22/2016		Trade: Plumber Priority: Medium Toilet plugged. R420,332,330,232 & 230. .... TT/2-22-16 .....
FO-340090	2/22/2016			To pipe fitters. Please replace the Accutemp aquastat control for the domestic hot water heat exchanger. Is defective, no hot water at sinks in building. .... GS/2-22-16 .....
FO-340127	2/22/2016	2/23/2016		trade plumbers priority medium please remove ice machine so that sun glow can re-tile the floor in this area .... TT/2-22-16 .....
FO-340134	2/22/2016			Plumber repair leaking trap in ceiling of shipping and receiving Rm. 106 .... GS/2-22-16 .....
FO-340136	2/22/2016			Plumber replace back flow on lab sink faucet Rm. #004 .... GS/2-22-16 .....
FO-340239	2/23/2016	2/23/2016		*DUPLICATE/REFER TO FO#340251 JWT  Clean sink traps out in rooms 256, 258, 259 & 263.
FO-340243	2/23/2016	2/23/2016		*DUPLICATE/REFER TO FO#340251 JWT  Clean sink traps out in rooms 256, 258, 259 & 263.
FO-340250	2/23/2016	2/23/2016		**DUPLICATE/REFER TO FO#340251 JWT  Clean sink traps out in rooms 256, 258, 259 & 263.
FO-340251	2/23/2016	2/25/2016		Clean sink traps out in rooms 256, 258, 259 & 263. .... TT/2-23-16 .....
FO-340242	2/23/2016	2/24/2016		pls repair replace leaking sink drain trap in the engineers office room 162.1 .... DB/2-23-16 .....
FO-340455	2/25/2016			Trade: Plumbers - Attn Gerry Priority: Medium Please repair faucet in the 4th floor mens bathroom. Water will not come on. .... GS/2-25-16 .....
FO-340487	2/25/2016			R/R RM 3146/MENS RR 2ND SINK (on the right as you face both sinks) IS LEAKING FROM FAUCET HANDLE .... DB/2-25-16 .....
<b>T - Roofing</b>			<b>3</b>	
FO-340441	2/25/2016			Roof repair- medium priority- repair roof leaks on the south east corner of the building.
FO-340602	2/26/2016			ROOF LEAK  RM 302 LEAKING DOWN WALL INTO ELECTRICAL BOX MOUNTED ON WALL

WO	Recieved	Finished	Total	Request
FO-340605	2/27/2016			Please repair rook leak at Public Safety. Water is leaking in from the roof line around a 2 inch conduit that penetrates the concrete roof and is located in the corner of the 2nd floor Multi-purpose room storage room. Relatively minor leakage at this time
<b>Low</b>			<b>353</b>	
<b>T - Carpenter</b>			<b>78</b>	
FO-338274	2/1/2016	2/11/2016		Carpenter repair floor tiles in storage room 313.
FO-338322	2/1/2016	2/3/2016		R/R Keys/TENNIS COURT STORAGE RM will no longer work in the storage room door, located inside the main tennis court area. For some reason the key will not enter the lock all the way. We are unable to unlock the door for entry.
FO-338336	2/1/2016			TEAM LEADER TIME ( FEBRUARY 2016 )
FO-338586	2/2/2016	2/2/2016		CARPENTER TO TAKE ED STANCZAK'S TRUCK TO REPLACE TIRE & HAVE PAT COAKLEY'S TRUCK TO THE REPAIR SHOP
FO-338615	2/2/2016	2/2/2016		Need ceiling tile replaced- seems it was moved moved to the side yesterday- Please replace
FO-338733	2/3/2016	2/4/2016		Purdy Library R/R INTERIOR/ENTRANCE DOOR #026 01S ADJUST DOOR CLOSURE TO TNE INTERIOR slams shut: hinge needs adjustment. Since the door is mostly glass, we are concerned about the door breaking and injuring someone.  Thank you.
FO-338734	2/3/2016	2/4/2016		RIGHT SIDE OF THE DOUBLE DOORS ARE NOT CLOSING PROPERLY. ROOM 1030 (SIM LAB.).
FO-338796	2/3/2016	2/4/2016		R/R 2ND FLR REPLACE MISSING CLNG TILES IN THE FOLLOWING AREAS: Ceiling panel missing in study room 2401. An additional panel is missing on the second floor outside the Law Library elevator. See Mary Bonk for specifics. 7-6177
FO-338802	2/3/2016	2/4/2016		rm# 306, please replace missing ceiling tile. preparing rooms for accreditation visit. thank you
FO-338804	2/3/2016	2/4/2016		Please refer to Request # 279979. Just discovered another ceiling panel missing on first floor near range 169. See Mary Bonk for specifics. 7 6177
FO-338837	2/4/2016	2/5/2016		R/R Rm. 2436 - The door plate/handle needs to be tightened.
FO-338884	2/4/2016	2/5/2016		Carpenters- Please replace door sweep on outside entrance to Mechanical room 00010.00.
FO-338902	2/4/2016	2/24/2016		Per Tim Herr- R/R ELEVATOR request re-tiling elevator floor
FO-338959	2/5/2016	2/8/2016		***CANCEL/LPS*** IF NECESSARY SEE RESULTSR/R RM 1234/UGL Women's Bath Room on 1st floor nearest to Extended Study Center (?) STALL Door to bathroom has been locked and will not be opened until sink is fixed.
FO-338972	2/5/2016	2/26/2016		Replace missing ceiling tiles in study room 322. Repairs are complete. See Jim Hill if needed
FO-339033	2/5/2016			CARPENTERS TO GIVE ACCESS TO AN OUTSIDE VENDOR TO REPAIR A BUILDING
FO-339035	2/5/2016			CARPENTERS TO RELEASE DETEK DOOR ALARMS FOR VENDOR TO MEASURE CEMENT GRIND
FO-339044	2/5/2016			Carpenter replace floor tiles that lifted from water leak. Rm #333
FO-339052	2/5/2016	2/8/2016		Trade: Carpenters Priority: Low Location: Lecture Hall Entrance  Please cut and install an access hatch or door in the Roll Up door motor area. This will allow much better access to the turnbuckle, locking lever, and motor.
FO-339107	2/8/2016	2/17/2016		CARPENTERS TO MAKE UP FIRE EXTINGUISHER MOUNTING BOARDS
FO-339114	2/8/2016	2/9/2016		R/R Room 3325. The plate that holds the lock in is falling off of the door.
FO-339142	2/9/2016	2/9/2016		Outside door O2 E electronic latch does not work
FO-339153	2/9/2016	2/11/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES ON 3RD FLOOR HALLWAY NEAR STAIRWELL-F . PRIORITY-LOW
FO-339156	2/9/2016	2/11/2016		Carpenters: please repair swivel tablet arm on the row M, seat # 6. the tablet arm is in Prentis mechanical room. Priority: low.
FO-339217	2/9/2016	2/12/2016		Replace missing ceiling tiles and grid where needed in DLAR room 0410 JT
FO-339239	2/9/2016	2/15/2016		The blinds in this room are damaged with the chains used for rotation broken or no longer attached. No rush to fix, just making the university aware.

WO	Recieved	Finished	Total	Request
FO-339271	2/10/2016	2/12/2016		CARPENTERS TO REPAIR 2 HOLES IN DRYWALL WALL BETWEEN ROOM # 159 & 169 SQUARE HOLE & ROUND HOLE
FO-339273	2/10/2016	2/12/2016		R/R Floor 1 south stairwell door 128B will not lock via key. Door leads from stairwell to interior hallway.
FO-339281	2/10/2016	2/11/2016		Please repair lock to regular toilet stall in the 1st floor Men's - old restroom. Lock is not locking.
FO-339296	2/10/2016	2/22/2016		In the early childhood center, Knapp Building. Room 170 has 1 light out. The light switch wont stay up in the bathroom between 170 and 176. The light over the stairs by room 163 is out. Room 170 has 1 electrical problem; the restroom between room
FO-339305	2/10/2016	2/22/2016		Replace stained ceiling tiles.
FO-339360	2/11/2016	2/15/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-339389	2/11/2016	2/12/2016		R/R 1ST FLR/Men's Bathroom, directly across from Margherio Conference Room (141), has a defective door on the first stall.
FO-339403	2/12/2016	2/15/2016		CARPENTERS, HALLWAY FLOORING TRANSITION STRIP MISSING NEAR ROOM 0137, PLEASE REPAIR. PRIORITY-LOW
FO-339405	2/12/2016	2/15/2016		CARPENTERS, MISSING COVE BASE IN HALLWAY NEAR ROOM 0129, PLEASE REPAIR. PRIORITY-LOW
FO-339427	2/12/2016	2/15/2016		Install replacement card reader head on AD display lock.
FO-339458	2/12/2016	2/15/2016		Lock cylinder on loading dock door 082-14N needs to be lubricated.
FO-339465	2/12/2016	2/12/2016		CARPENTERS TO CLEAN OUT LABORS LOCKERS & FLOOR TILE IN THE STORAGE AREA
FO-339559	2/15/2016	2/16/2016		CARPENTERS TO REINSTALL SHADE THAT IS LAYING ON THE WINDOW SILL ROOM # 327
FO-339573	2/15/2016	2/16/2016		The LEED certificate, which is located next to the elevator in the lobby, needs to be replaced with the LEED plaque that was ordered. The plaque is currently being storied in my office (University Services AVP office). Once replaced, please give
FO-339562	2/15/2016	2/15/2016		CARPENTER TO PUT ATTIC STOCK OF CEILING TILE INTO THE STOCK ROOM
FO-339563	2/15/2016	2/16/2016		CARPENTERS TO BUILD & INSTALL A VCT TILE RACK IN STORAGE GARAGE
FO-339720	2/15/2016	2/16/2016		Location is conference room #3. Need LEED and AIA plaques hung. The plaques are currently being stored in my office (University Services AVP office). I also have a drawing showing the needed alignments. Please see me for instructions.
FO-339738	2/16/2016	2/16/2016		CARPENTERS  Please install door stop on office door of room 065 (basement floor)
FO-339761	2/16/2016	2/17/2016		R/R RM 273 please fix door rm. 273 - lock jamming -thank you
FO-339789	2/16/2016	2/16/2016		CARPENTER TO REPAIR MENS ROOM ENTRANCE DOOR NAER ROOM #209 DOOR NOT LATCHING
FO-339790	2/16/2016	2/22/2016		CARPENTER TO REPAIR LOCKSET ROOM # 319 DOOR NOT SECURING
FO-339819	2/17/2016	2/18/2016		CARPENTERS, PLEASE SECURE #3 FFC UNIT TO WALL. PRIORITY-LOW
FO-339820	2/17/2016	2/25/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-339884	2/17/2016	2/22/2016		CARPENTERS, PLEASE REPAIR FLOORING @ WINDOWS. PRIORITY-LOW
FO-339885	2/17/2016	2/22/2016		CARPENTERS, PLEASE REPAIR FLOORING @ WINDOWS. PRIORITY-LOW

WO	Recieved	Finished	Total	Request
FO-339880	2/17/2016	2/17/2016		ROOM # 217 REPLACE CLOSER & REPAIR LOCKSET
FO-339882	2/17/2016	2/22/2016		CARPENTER TO REPAIR CLOSER DOOR 16-17-W & ADJUST DOOR 16-22-N CLOSER
FO-339883	2/17/2016	2/24/2016		CARPENTER TO REPALCE DAMAGED CEILING TILE ROOM # 215
FO-339929	2/18/2016	2/22/2016		Carpenters: Please replaced three, possibly four stained ceiling tiles by the windows and near the office copier in suite 1215. Medium Priority.
FO-339960	2/18/2016	2/18/2016		CARPENTER TO REPAIR WOMENS RESTROOM DOOR LOCK 1ST FLOOR
FO-339965	2/19/2016	2/24/2016		In the Studio Theatre(downstairs) in the lobby there are several ceiling tiles that have loosedned and are ver close to fallingfalling. Can this be addressed in the morning by carpenter? Can the tiles be leveled/nailed to the ceiling , not warping/bowin
FO-339992	2/19/2016	2/22/2016		CARPENTER TO REPAIR CLOSER 2ND FLOOR STAIRWELL EAST SIDE
FO-340009	2/19/2016	2/23/2016		Trip Hazard. R/R BLDG BOTH STRWLS Several of the stair treads are loose or have fallen off on both sets of stairs in the lecture hall. I just showed the engineer told him I am putting this in as a emergency because of the hazard.
FO-340018	2/19/2016	2/22/2016		CARPENTRY please r/r broken window on the 2nd floor of Music Annex. The room in the SE corner of the 2nd floor has a window that is broken in the open position letting weather and possibly rodents in the building. Please address asap.
FO-340490	2/23/2016	2/26/2016		3rd fl study room #3320 - wall kicked-in. Incident Police Report #W16-0540043 Dorothy Carter 02/24/2016 10:15 - Spoke to Leon Massey on 2-23-16 to let him know that the whiteboard is departmental property and would be removed from the action requested.
FO-340264	2/23/2016			CARPENTERS, PLEASE REPAIR COVE BASE IN BSMT @ EXTERIOR DOORS IN STAIRWELL- G.PRIORITY-LOW
FO-340280	2/23/2016	2/24/2016		Purdy Library 2nd Floor, room 231 Door latch sticks open. Difficult to close at times. Please repair.  Thank you.
FO-340284	2/23/2016	2/24/2016		The key pad is not working, although it lights up when you put the code in, but it will not open the door. I tried to change the code, but that didn't work
FO-340291	2/23/2016	2/24/2016		3rd floor, Office 332, door to office will not close tightly. You have to pull on the handle of the door really hard to get the door to close or the door will just push right open even if its locked.
FO-340342	2/24/2016	2/25/2016		Trade: Carpenter Priority: Low The door to the main 1st floor electrical room (1135) is not latching and locking, please make adjustments.
FO-340379	2/24/2016	2/25/2016		R/R UGL inner door TO ENTRANCE DOOR #096-01E is squeaking the door that corresponds to outside door, 096 01E. Please check all the doors, inside and out for squeaking.
FO-340405	2/24/2016			Carpenters: Please replace damaged window blind on south window, it has a large cut in the middle of it. Priority: low.
FO-340406	2/24/2016			Carpenters: Please repair or replace roller clutch for the blind on 2nd window from north, the blind can not be rolled up or down. Priority: low.
FO-340428	2/24/2016	2/25/2016		R/R RM 200 SEAL WINDOW LEAK IN office in suite 200 is leaking water from the ceiling/window. Please see front desk person to direct to office with issue.
FO-340430	2/24/2016			R/R RM 4674 water is currently dripping alot in the window from the rain/sleet and is pooling on the window ledge.
FO-340463	2/25/2016	2/26/2016		Carpenters: Please repair door jamb stop on door # 02213W to fishbowl, the stop is bend. Priority: low.
FO-340477	2/25/2016			I need some plywood placed on the floor, under the hanging drawings. Water is seeping under the drywall, and ruining the drawings that I store on the floor. Thank you!
FO-340516	2/25/2016			Ceiling tiles that were destroyed by water leaks need to be replaced in the 4th floor training room and the conference room (409)
FO-340535	2/26/2016			Carpenters: please repair broken tablet arm of the chair in row D and seat # 111. the tablet arm is in Prentis mechanical room. Priority: low.
FO-340543	2/26/2016			Please remove two ceiling tiles and screen tile from ceiling in print room.
FO-340562	2/26/2016			Provide appropriate cover over exposed copper heating pipe on the finished wall of the 3rd floor bridge between Law School and Law Library.



WO	Recieved	Finished	Total	Request
FO-340596	2/26/2016	2/26/2016		CARPENTERS TO ASSEMBLE A FILE CABINET FOR THE FIRST LADY IN THE PRESIDENTS APARTMENT.
<b>T - Electrician</b>			<b>83</b>	
FO-338267	2/1/2016			COMPRESSORS WILL NOT START.  Electricians ordered new starter/contactator.
FO-338291	2/1/2016			The men's restroom next to room 1360 has 1 electrical problem.
FO-338294	2/1/2016	2/23/2016		The EXIT sign between room 140 and the men's restroom has an electrical problem.
FO-338298	2/1/2016	2/18/2016		The EXIT sign between rooms 037 and 045 has an electrical problem.
FO-338325	2/1/2016	2/17/2016		2nd floor, long corridor outside of academic advising, 20 Lights, partially out. Tagged in August. Please check before sending to Electricians.
FO-338349	2/1/2016	2/24/2016		There is 1 electrical problem in the passenger elevator.
FO-338609	2/2/2016			Light bulbs have blown out in office area and need replacing.....there is 1 EP in this room, causing the area to be very dim..
FO-338618	2/2/2016	2/23/2016		rm 479 - 9 Out, 477 - 6 out. There is 1 EP in office 477 and @ EP's in office 479 directly over Professor's desk..
FO-338694	2/2/2016			ELECTRICIANS,R/R BLDG PLEASE REPAIR EXTERIOR LIGHTS @ DOCK BAYS & EXTERIOR LIGHT @ DOOR 001-12W.PRIORITY-LOW
FO-338752	2/3/2016			Kresge Library 2nd Floor  Unable to shut off lights.  Momentary Contactor (located in Kresge 1st floor light panels) is not working.  Please repair.  Thank you.
FO-338797	2/3/2016			Please return one pallet of trash cans to the local Grainger office. Double shipment.Se Lynda Kinder , trash cans in the FP&M Stockroom.
FO-338845	2/4/2016	2/19/2016		In the early childhood center, Knapp Building. Room 170 has 1 light out. The light switch wont stay up in the bathroom between 170 and 176. The light over the stairs by room 163 is out. Room 170 has 1 electrical problem; the restroom between room
FO-338847	2/4/2016	2/24/2016		Matthaei Building Room 154.2 - change light in trainers office. Please see Bob Ostrowski on specifics. Thank You. Bob Ostrowski
FO-338887	2/4/2016			FOUL ODOR COMING IN THROUGH MECHANICAL ROOM WALL THRU ELECTRICAL CONDUIT. CONTACT ENGINEER FOR DETAILS.
FO-338901	2/4/2016	2/15/2016		The light above door 067 13N is inoperative. Please I&R.
FO-338917	2/4/2016	2/22/2016		RM 325 LIGHTS OUT
FO-338937	2/5/2016	2/16/2016		Electricians- R/R RM 00195/MECH BLR RM Please replace burned out light bulb in outdoor security light on boiler room wall/Putnam street side.
FO-339027	2/5/2016			There is 1 EP directly infront of Pool area...across from display case.
FO-339026	2/5/2016	2/19/2016		Storage room 130.1 - 5 lights out. there is 1 EP directly in front of this storage room.
FO-339075	2/7/2016	2/11/2016		The exit6 illuminated sign at the south east side of the auditorium is not lit. Please repair. This could be a safety issue.
FO-339076	2/7/2016	2/12/2016		About 1/2 of the sconce lights in the inner lobby are burned out. Also please check for burned out lights in main auditorium. All sconce lights should be 60watt. We will open a new performance on Friday  Thanks
FO-339077	2/7/2016	2/9/2016		About 1/2 of the sconce lights in the inner lobby are burned out. Also please check for burned out lights in main auditorium. All sconce lights should be 60watt. We will open a new performance on Friday  Thanks
FO-339087	2/8/2016			The hallway outside of the elevators has 1 electrical problem. (3rd floor)

WO	Recieved	Finished	Total	Request
FO-339110	2/8/2016	2/12/2016		1 EP - Outside room 140, behind the purdy help desk.
FO-339118	2/8/2016	2/24/2016		Room # 113-114 - 2 EPs. Taped.
FO-339121	2/8/2016	2/8/2016		Take truck to shop, and have tire repaired.
FO-339126	2/8/2016			The fixture outside room 4047 causes the bulbs to rattle from time to time.
FO-339151	2/9/2016			The Donor Gallery has 8 electrical problems. (1st floor)
FO-339176	2/9/2016			Assist plumbers/fitters with domestic water pumps replacement.
FO-339226	2/9/2016	2/9/2016		Check wire on roof to be sure it isn't hot, Roofer working, and don't want to get electrocuted.
FO-339246	2/10/2016			exterior electrical outlet East side GFI, reported when carpenter plugs in utility vehicle to charge it trips, not sure if it's an overload , or faulty GFI
FO-339288	2/10/2016			The light fixture over the northwest lobby entrance door, at the top of the ramp is missing. Please repair. This light fixture would allow a safer entry to the theatre.  Thanks  Install LED Fixture over Entrance Door.
FO-339307	2/10/2016	2/23/2016		Purdy Library 4th Floor, Room 450  Clock in room 450 has stopped working. Please repair or replace. Room 450 is a closed area with restricted access. Please Richard at the Check Out desk for access. Thank you.
FO-339330	2/11/2016			Range 165 has 1 electrical problem. (1st floor)
FO-339331	2/11/2016			Range 338 has 1 electrical problem. (2nd floor)
FO-339338	2/11/2016			The men's restroom has 1 electrical problem. (3rd floor)
FO-339387	2/11/2016			ELECTRICIANS,R/R RM 205/CLASS RM PLEASE REPLACE MISSING TIME CLOCK.PRIORITY-LOW
FO-339391	2/11/2016	2/23/2016		R/R 2ND FLR NEXT TO MAIN ELEV Clock needs to be fixed, showing the wrong time, 2nd floor of the Mazurek building right next to the Main Elevator
FO-339429	2/12/2016			Please check the electrical plug under the time clock outside my office. I had two time clocks installed and both are losing time. See Mary with questions.
FO-339432	2/12/2016	2/15/2016		Grounds Office - All lights are out. There is either a bad switch and/or a bad circuit that caused all the lights to go out.
FO-339434	2/12/2016	2/16/2016		ELECTRICIANS TO REMOVE CEILING MOUNTED BOSE SPEAKER TO REPLACED WATER DAMAGED CEILING TILE
FO-339460	2/12/2016	2/15/2016		R/R PH please have electricians replace our broken electrical clock with same in the office penthouse.
FO-339463	2/12/2016			Trade: ElectriciansPriority: LowR/R 3RD FLR HALLWAY Please repair hallway clock near room 361.
FO-339484	2/15/2016	2/15/2016		A light switch is room 1305 and the light cannot be turned off. Thank you.
FO-339503	2/15/2016	2/17/2016		The hallway across from the passenger elevator has 1 electrical problem. (2nd floor) As I attempted to remove the bulb the tombstone came loose.
FO-339570	2/15/2016	2/25/2016		The Light in the main stairwell between the 1st. and 2nd Floor stairwell, this is a safety issue for...This will be forwarded to the electricians individuals in the building, the stairwell is very dark.
FO-339723	2/16/2016			The hallway outside of room 212 has 1 electrical problem.
FO-339771	2/16/2016			The hallway just past room 4360 has 1 electrical problem.
FO-339795	2/16/2016	2/26/2016		R/R Stair well - A - Light out entering stairs. Also light is still out at entry to stairs going down to basement benn on electricians list for several months. At Stairwell J Basement outside room 0359 Two light fixtures each have a lamp burned out.
FO-339796	2/16/2016			Lab 2305 has several fluorescent lights out. It is in the Occupational-Physical Therapy suite, 2290. There is a keypad for entry; check with secretary to gain entry into the lab. Also, there is a light across from room 2247. The hallway across from room
FO-339811	2/17/2016	2/19/2016		REPLACE LIGHTS ON BLUE LIGHT PHONES. EXTERIOR SIDE OF NORTH AND SOUTH BUILDINGS.
FO-339816	2/17/2016	2/22/2016		Lightning -- Priority Medium Please replace blown light bulbs in main hallway. There are 3electrical problems.
FO-339850	2/17/2016			EP - North and South Stairwells, lower auditorium. 2 fixtures each in these stairwells have safety locks on them. Please remove locks so bulbs can be changed.

WO	Recieved	Finished	Total	Request
FO-339864	2/17/2016			2 EPs - Outside of 487 - fixtures are side by side. Hallway is dark.
FO-339865	2/17/2016	2/26/2016		REPLACE BLUE PHONE LIGHTS. NORTH SIDE OF BLDG.
FO-339873	2/17/2016	2/24/2016		In Lab 220 - 9 LO  Fume Head (FH)-2--1 FH-5--1 FH-6--1 FH-7--3 FH-11--1 FH-12--1 FH-13--1 To be completed by Electricians...
FO-339874	2/17/2016	2/24/2016		Lab 210 - 2 LO  FH- 4--1 FH-3--1 to be completed by electricians
FO-339918	2/18/2016			Room 1302 has 1 electrical problem.
FO-339919	2/18/2016			Range 282 has 1 electrical problem.(2nd floor)
FO-339943	2/18/2016			ELECTRICIANS,R/R 3RD FLR HALLWAY PLEASE REPLACE DEFECTIVE EXIT SIGNS IN HALLWAYS.PRIORITY-LOW
FO-339944	2/18/2016			ELECTRICIANS,R/R 3RD FLR HALLWAY PLEASE REPLACE DEFECTIVE EBU'S IN HALLWAYS.PRIORITY-LOW
FO-339945	2/18/2016			R/R BLDG Repair dusk to dawn lights on exterior of building, North side, behind London Luggage. Lights are not on at night in early morning hours, ie. midnight to 06:00.
FO-340021	2/19/2016			R/R RM 3330 Dr. Firestine's Lab Room 3330, replace fume hood lights. The hood is a Fischer Hamilton SAFEAIRE.
FO-340059	2/20/2016			please have electricianscheck north supply fan on ahu-8 tripping on overload. reset breaker and the fan keeps tripping.
FO-340077	2/22/2016	2/25/2016		UGL main elevators in need of light replacements (small and recessed). First elevator, one out; second elevator, three out. (Not able to report on third elevator at the time of this report.)
FO-340155	2/22/2016	2/26/2016		Room 335 - 1 LO
FO-340247	2/23/2016			UGL Freight Elevator has two ceiling lights out, small and recessed.
FO-340249	2/23/2016			Replace lamp bulbs at security desk in the 5057 Woodward Lobby.
FO-340273	2/23/2016	2/23/2016		Repair bad clock located in the library, near the bathrooms. (1st Floor)
FO-340292	2/23/2016	2/24/2016		Trade: Electrician Priority: High Please disconnect feed water pump #1.
FO-340293	2/23/2016	2/23/2016		Need PO for PM Technologies to make repairs on generator.
FO-340297	2/23/2016	2/26/2016		Truck need to go to shop for repairs.
FO-340326	2/24/2016			Trade: Lighting Priority: Low Please repair lighting in 7 1/2 fixtures in the first floor lobby of the Science and Engineering Library.
FO-340333	2/24/2016			The stairwell landing across from room 206 has an electrical problem. The tombstone caused the bulb to spark in the fixture.
FO-340343	2/24/2016			1 EP - 4th FI Stairwell - Woodcock Stacks side of the building. Please see Brandon Carter for directions!
FO-340345	2/24/2016			1 EP - This is an 8 foot bulb to the right of the main elevator upon exiting the 3rd floor. Tagged.
FO-340457	2/25/2016			RM 5453 HAS A FLASHING/BLINKING LITE NEEDS REPLACING. There is 1 electrical problem.
FO-340492	2/25/2016			The hall light across from the reference desk has 1 electrical problem.
FO-340553	2/26/2016			Light burnt out in hallway outside of office #13203.1 - Thank you!
FO-340569	2/26/2016			Three of the light covers are missing. A light needs to be replaced. There is plastic covering the camera  Install lens, lens came in 2/26/2015 in the back corner of the room.

WO	Recieved	Finished	Total	Request
FO-340577	2/26/2016			Replace burned - out light ceiling light at Matthaehi in gym 111. Burned out light is above the main basket on the south side. A lift will be necessary. Please rush. Post Season Game on Thursday, March 3rd. Please replace light (or repair if necessary) pri
FO-340584	2/26/2016			LIGHTS OUT - BLUE LIGHT PHONE. NORTH SIDE OF BUILDING FACING CVS.
FO-340599	2/26/2016	2/26/2016		Electrician need FR rated clothing
<b>T - Locksmith</b>			<b>81</b>	
FO-338334	2/1/2016	2/9/2016		New Key New Space Assignment Key #: 30439 Core A-60 Key Holder ID: College of Engineering Dean's Office Qty: 2  action: To fill Key Requests
FO-338338	2/1/2016	2/9/2016		New Key New Staff Member Key #: 65009 Key Holder ID: Rosemary Foster Qty: 1  action: New master key for labs in the basement of Knapp Building
FO-338337	2/1/2016			KEYS & CORES ( FEBRUARY 2016 )
FO-338687	2/2/2016	2/9/2016		Replacement New Staff Member Key #: 820 Key Holder ID: Division of Engineering Technology, Main Office Qty: 2  action: Request two master keys for the entire building. One key will be for the main office key cabinet and the other for a Connect Se
FO-338688	2/2/2016	2/9/2016		New Key Lost / Stolen Key #: 401 Key Holder ID: Allen Saliganan Qty: 2  action: To access our mice housed at Elliman Bldg., Rm. 0413
FO-338728	2/2/2016	2/12/2016		Replacement New Staff Member Key #: Steelcase desk - lock #fr 419 Key Holder ID: Bob Ostrowski for Athletics Qty: 2  action: Model # of steel case desk is 9087SML
FO-338727	2/2/2016	2/12/2016		New Key New Staff Member Key #: B-59 Key Holder ID: College of Engineering, Dean's Office Qty: 2  action: **This is for room 2519** Thank you.
FO-338726	2/2/2016	2/12/2016		New Key New Staff Member Key #: D-1 Key Holder ID: College of Engineering, Dean's Office Qty: 2  action: New staff member. Thank you.

WO	Recieved	Finished	Total	Request
FO-338821	2/3/2016	2/9/2016		<p>New Key Lost / Stolen Key #: 35009 Key Holder ID: Chris McHugh Qty: 1</p> <p>action: Graduate Student at WSU, need access to the animal facilities.</p>
FO-338945	2/4/2016	2/17/2016		<p>New Key New Staff Member Key #: 23066 Key Holder ID: Paul Bishop Qty: 5</p> <p>action: Keys for room 2413, Music Library.</p>
FO-338962	2/5/2016	2/16/2016		<p>Replacement Damaged Key #: Hon 122E Key Holder ID: Ramona Washington Qty: 3</p> <p>action: To have three keys made for a file cabinet marked: HON. Core marked: 122E</p>
FO-339150	2/5/2016			<p>New Key New Staff Member Key #: 109814 Key Holder ID: Theresa Y. Hill Qty: 8 action: Please duplicate 8 keys from the number listed above. Contact Theresa Y. Hill if you require any additional information. This is the general lab keys for HFHS Bone</p>
FO-339148	2/8/2016	2/17/2016		<p>New Key Damaged Key #: Best Key Holder ID: 11181-3 Qty: 2</p> <p>action: Key replacement, broken key.</p>
FO-339147	2/8/2016	2/16/2016		<p>New Key Lost / Stolen Key #: 27764 Key Holder ID: Maureen Okasinski Qty: 1</p> <p>action: Need to replaced lost key Account #: 113231</p>
FO-339146	2/8/2016	2/16/2016		<p>New Key Lost / Stolen Key #: 27711 Key Holder ID: Maureen Okansinski Qty: 1</p> <p>action: New to replace lost key Account #: 113231</p>
FO-339145	2/8/2016	2/17/2016		<p>New Key New Staff Member Key #: D-27/30791 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: Key needed for new student. Thank you.</p>

WO	Recieved	Finished	Total	Request
FO-339144	2/8/2016	2/16/2016		New Key New Space Assignment Key #: 37.4 (7AA) Key Holder ID: Michelle Matthews Qty: 4  action: Key #32477 Account #: 126911
FO-339143	2/8/2016	2/16/2016		Replacement New Space Assignment Key #: C125A & 107E Key Holder ID: Michelle Matthews Qty: 2 Keys each  action: 2 #C125A 2 #107E (Hon file cabinet)
FO-339199	2/9/2016	2/17/2016		New Key Lost / Stolen Key #: Please see below Key Holder ID: Dr. Heydari Qty: Please see below  action: Keys for Dr. Heydari and they are as follows:  Key #   Core #   Room #   Qty  11727   A9CB10   429   1 11729   A9CB13   430   1 1096
FO-339197	2/9/2016	2/17/2016		New Key Lost / Stolen Key #: 109628-1 Key Holder ID: Paul Burghardt Qty: 5  action: Need 5 keys for Lab Account #: 771929
FO-339261	2/10/2016	2/11/2016		New Key New Space Assignment Key #: UTC Key Holder ID: Brittany Thompson-Johnson Qty: 5  action: THe key core was changed on the elevator for the 3rd floor. Please provide 5 keys marked "UTC" for access to the 3rd floor.
FO-339260	2/10/2016	2/11/2016		New Key New Staff Member Key #: 3867, C390A and 108099-1 Key Holder ID: Jon Barth Qty: 1 each  action: The AAB pod core identification numbers are 3867, C390A and 108099-1  Account #: 227960
FO-339326	2/11/2016			Room 129 - 2 EPs - These fixtures are ceiling lights behind a locked display area.  OPEN TO CARPENTERS:  Open display case, and make 2 keys for Electricians.
FO-339328	2/11/2016	2/17/2016		Room 121 - 1 LO  OPEN TO CARPENTERS:  Open display case, and make 2 keys for the Electricians.

WO	Recieved	Finished	Total	Request
FO-339363	2/11/2016	2/22/2016		<p>New Key New Staff Member Key #: B52, 105972, 108033, MM, 30791, X292, 25699 Key Holder ID: Student Center Administration Qty: 1 of each</p> <p>action: We frequently have two managers of the facility but currently only have one set of keys. We would</p>
FO-339366	2/11/2016	2/18/2016		<p>New Key New Space Assignment Key #: 31826.12 Key Holder ID: Dorothea Smith Qty: 1</p> <p>action: Please provide one key for entrance to suite. Staff member received promotion and needs access for daily entry. Thank you.</p>
FO-339368	2/11/2016	2/17/2016		<p>New Key New Staff Member Key #: 13186-132 Key Holder ID: kathleen maheras Qty: 1</p> <p>action: We are moving part of our mouse colony over to the Lande vivarium and need a key</p>
FO-339369	2/11/2016			<p>New Key New Space Assignment Key #: ? Key Holder ID: kathleen maheras Qty: 1</p> <p>action: Part of our mouse colony is moving over to Lande to avoid the ELLiman construction. room 51.1 will serve as our temporary lab space. Will I need a separate key f</p>
FO-339377	2/11/2016	2/22/2016		<p>Core Change Lost / Stolen Key #: core # - 17AAC34, key # - 33966 Key Holder ID: Donnella Johnson Qty: 2 cores and 3 keys</p> <p>action: 1 mailbox core, 1 room core, 3 keys Account #: 228200</p>
FO-339407	2/11/2016	2/12/2016		<p>Core Change Damaged Key #: Need new pad lock - 15KA1X Key Holder ID: leo lieberman Qty: 2</p> <p>action: See Mike Pines for details.</p>
FO-339404	2/11/2016	2/18/2016		<p>New Key New Staff Member Key #: 10AA.2.41 Key Holder ID: Chacko George Qty: two</p> <p>action: Please issue two keys to Room 6111 Scott Hall. Account #: 133601</p>
FO-339402	2/11/2016	2/23/2016		<p>New Key Lost / Stolen Key #: core AB24, key 037052 Key Holder ID: Angelica Reyna Qty: 2 cores and 3 keys</p> <p>action: 1 room core, 1 mailbox core, and 3 keys ****Emergency Core 11 is currently installed, please return the core to the front desk****</p>

WO	Recieved	Finished	Total	Request
FO-339445	2/12/2016	2/23/2016		<p>New Key New Staff Member Key #: 31291/G-12 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: New staff members. Thank you.</p>
FO-339444	2/12/2016	2/22/2016		<p>New Key New Staff Member Key #: 31337/G-58x Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: New staff member, inventory. Thank you.</p>
FO-339487	2/12/2016	2/23/2016		<p>Replacement Lost / Stolen Key #: HW 162 Key Holder ID: Juanitta Hill Qty: 3</p> <p>action: I would like a copy of a file cabinet key #HW 162. Thank you.</p>
FO-339735	2/15/2016	2/24/2016		<p>New Key New Staff Member Key #: 18757 Key Holder ID: Kristine Sholty and Kelli Jurich Qty: 3</p> <p>action: Requesting 3 to replace the backup keys I've given to new staff.</p>
FO-339734	2/15/2016	2/24/2016		<p>New Key Lost / Stolen Key #: X3171 Key Holder ID: Kristine Sholty and Kelli Jurich Qty: 3</p> <p>action: Requesting 3 keys to replace backups I've given to new staff.</p>
FO-339785	2/15/2016	2/24/2016		<p>New Key New Space Assignment Key #: I don't know this. Key Holder ID: Sarah Brownlee Qty: 3</p> <p>action: My research group needs to be able to access my lab in 251 Life Sciences during nights and weekends when the building is locked. I am requesting 3</p>
FO-339733	2/15/2016	2/23/2016		<p>New Key Lost / Stolen Key #: 41400-07 Key Holder ID: Tia Finney Qty: 2</p> <p>action: We need 2 super keys for new administrators. Account #: 127951</p>



WO	Recieved	Finished	Total	Request
FO-339732	2/15/2016	2/23/2016		<p>New Key Lost / Stolen Key #: 40689 Key Holder ID: Office Staff Qty: 2</p> <p>action: We need 2 replacement keys Account #: 127951</p>
FO-339731	2/15/2016	2/23/2016		<p>New Key New Staff Member Key #: 874 Key Holder ID: Division of Engineering Technology, Main Office Qty: 3</p> <p>action: Need additional keys for new staffing and division key box Account #: 121921</p>
FO-339772	2/16/2016	2/16/2016		<p>New Key Lost / Stolen Key #: 76857 Key Holder ID: Deshaun Harris Qty: 1</p> <p>action: to be picked up by med school courier</p>
FO-339787	2/16/2016	2/24/2016		<p>New Key New Staff Member Key #: 20336 Key Holder ID: Amy Hays Qty: 5</p> <p>action: 5 keys for room 357 Art Building</p>
FO-339808	2/16/2016	2/24/2016		<p>New Key New Space Assignment Key #: 22434 Key Holder ID: Joseph Rasak Qty: 2</p> <p>action: This key is for the door that leads from the elevator lobby on the 2nd floor at 5425 Woodward to the office corridor on the 2nd floor. We are currently</p>
FO-339827	2/17/2016	2/24/2016		<p>New Key New Staff Member Key #: B498 Key Holder ID: Various Qty: 5</p> <p>action: Please make 5 additional keys for the front and back door of Beecher House (B498) for new divisional employees. Account #: 168231</p>
FO-340064	2/19/2016	2/22/2016		<p>New Key New Space Assignment Key #: 110968 Key Holder ID: Juanitta Hill Qty: 5</p> <p>action: More people assigned access to room</p>

WO	Recieved	Finished	Total	Request
FO-340065	2/19/2016	2/24/2016		New Key New Space Assignment Key #: 111106 Key Holder ID: Juanitta Hill Qty: 3  action: 3 keys for Admissions Sub-Master
FO-340068	2/19/2016	2/25/2016		New Key New Space Assignment Key #: 110972 Key Holder ID: Juanitta Hill Qty: 2  action: copies of 2 keys to Room 159
FO-340069	2/19/2016	2/25/2016		New Key New Space Assignment Key #: 110987 Key Holder ID: Juanitta Hill Qty: 3  action: copies of 3 keys to Room 081
FO-340071	2/19/2016	2/25/2016		New Key New Space Assignment Key #: 110968 Key Holder ID: Juanitta Hill Qty: 5  action: Copies of 5 keys to Room 079
FO-340361	2/19/2016			New KeyLost / StolenKey #: ?Key Holder ID: Chelsea RichardsonQty: 1action: using space temporarily for mouse procedures
FO-340362	2/19/2016			New KeyLost / StolenKey #: ?Key Holder ID: Chelsea RichardsonQty: 1action: using space temporarily for mouse procedures
FO-340365	2/20/2016			New KeyLost / StolenKey #: 13186-132Key Holder ID: Chelsea RichardsonQty: 1action: access to animal housing where colony will be housed
FO-340116	2/22/2016	2/25/2016		New Key New Space Assignment Key #: 22360 Key Holder ID: Leo T./ Mike Hawthorne Qty: 2  action: Key to let building staff operate the freight elevator.
FO-340225	2/22/2016			New KeyNew Space AssignmentKey #: 90069Key Holder ID: Lisa PolinQty: 1action: need entry into Room 0408 on a daily basis to take care of animals housed within. Account #: 225126
FO-340226	2/22/2016			New KeyNew Staff MemberKey #: 401-112Key Holder ID: Lisa PolinQty: 1action: need entry into Room 0413 on a daily basis to take care of animals housed within. Account #: 225126
FO-340227	2/22/2016			New KeyLost / StolenKey #: 35009Key Holder ID: Lisa PolinQty: 1action: need entry into DLAR animal rooms AF26 and AF28 on a daily basis to take care of animals housed within. Account #: 225126
FO-340141	2/22/2016	2/25/2016		New Key Lost / Stolen Key #: 121E Key Holder ID: Hilary Marusak Qty: 3  action: This is a file cabinet key. Let me know if it can be replaced.
FO-340140	2/22/2016			New KeyNew Staff MemberKey #: 109880Key Holder ID: Theresa Y. Hill Qty: 3action: Please duplicate 3 keys for office #1415 in IBio. This is for an office in the Bio & Systems Engineering group. I need these ASAP. Please give to Mike Pines. Than
FO-340322	2/23/2016			ReplacementLost / StolenKey #: UM316Key Holder ID: Beth MadiganQty: 2action: Can I get 2 replacement keys?

WO	Recieved	Finished	Total	Request
FO-340321	2/23/2016	2/26/2016		<p>Replacement Lost / Stolen Key #: UM251 Key Holder ID: Beth Madigan Qty: 2</p> <p>action: Can I get 2 replacement keys?</p>
FO-340320	2/23/2016	2/26/2016		<p>Replacement Lost / Stolen Key #: SL285 Key Holder ID: Beth Madigan Qty: 2</p> <p>action: Can I get 2 replacement keys?</p>
FO-340319	2/23/2016	2/26/2016		<p>Replacement Lost / Stolen Key #: SL280 Key Holder ID: Beth Madigan Qty: 2</p> <p>action: Can I get 2 replacement keys?</p>
FO-340318	2/23/2016	2/26/2016		<p>Replacement Lost / Stolen Key #: SL222 Key Holder ID: Beth Madigan Qty: 2</p> <p>action: Can I get 2 replacement keys?</p>
FO-340317	2/23/2016			<p>ReplacementLost / StolenKey #: L002Key Holder ID: Beth MadiganQty: 2action: Can I get 2 replacement keys?</p>
FO-340315	2/23/2016	2/26/2016		<p>New Key Damaged Key #: 7073-4 Key Holder ID: Beth Madigan Qty: 2</p> <p>action: Can I get 2 replacement keys?</p>
FO-340313	2/23/2016	2/26/2016		<p>New Key Lost / Stolen Key #: 20 BEST TA23 and 20 BEST TA24 Key Holder ID: Dr. Bruce Russell Qty: 1 each</p> <p>action: Philosophy Dept Replacement for lost key: 12212 - Hall Corridor 12212.1 - Seminar Room</p>
FO-340312	2/23/2016	2/26/2016		<p>New Key Lost / Stolen Key #: 20934 Key Holder ID: Qin Lai Qty: 4</p> <p>action: need 4 keys made students who use the lab for research. Account #: 122371</p>
FO-340311	2/23/2016	2/26/2016		<p>New Key Lost / Stolen Key #: 109168 Key Holder ID: Carol Salisbury Qty: 6</p> <p>action: Need 6 keys for Grad Research students who use this room. Account #: 122371</p>

WO	Recieved	Finished	Total	Request
FO-340729	2/24/2016			<p>New Key Lost / Stolen Key #: C390A (Non-BEST Core) Key Holder ID: Carol Dargin/Bldg Engineer/PM Engineer Qty: 3</p> <p>action: Please make a duplicate key for Siemens Smoke Evacuation System Control Panel located in the lobby of Elliman.</p> <p>Panel</p>
FO-340622	2/24/2016			<p>New KeyDamagedKey #: core AD25, key 037183Key Holder ID: Angelica ReynaQty: 1 keyaction: Cut 1 key - this is for Professor DuncanAccount #: 228156</p>
FO-340380	2/24/2016			<p>2- KEYS FOR TIERNEY CUSTODIAL CLOSET. KEY # 26326.6 - .7</p>
FO-340624	2/24/2016			<p>Core Change Lost / Stolen Key #: 16EB28 Key Holder ID: Eric Johnson Qty: 2 cores and 5 keys</p> <p>action: 1 room core, 1 mailbox core and 5 keys Account #: 228184</p>
FO-340626	2/24/2016			<p>Core Change Lost / Stolen Key #: 16ED56 Key Holder ID: Eric Johnson Qty: 2 cores, 7 keys</p> <p>action: 1 room core, 1 mailbox core, and 7 keys Account #: 228184</p>
FO-340630	2/24/2016			<p>Core Change Lost / Stolen Key #: 16ED4 Key Holder ID: Eric Johnson Qty: 2 cores and 7 keys</p> <p>action: 1 mailbox core, 1 room core, and 7 keys Account #: 228184</p>
FO-340631	2/24/2016			<p>Core Change Lost / Stolen Key #: 16EG11 Key Holder ID: Eric Johnson Qty: 2 cores and 5 keys</p> <p>action: 1 room core, 1 mailbox core, and 5 keys Account #: 228184</p>
FO-340633	2/24/2016			<p>Core Change Lost / Stolen Key #: 16EK38 Key Holder ID: Eric Johnson Qty: 2 cores and 5 keys</p> <p>action: 1 room core, 1 mailbox core, and 5 keys Account #: 228184</p>
FO-340445	2/25/2016			<p>LOCKSHOP TRAINING ( FEBRUARY 2016 )</p>
FO-340634	2/25/2016			<p>New KeyNew Space AssignmentKey #: 22354Key Holder ID: Leo T./ Tim GrittenQty: 2 action: Key to office for new Associate Dean.</p>
FO-340642	2/26/2016			<p>New KeyNew Staff MemberKey #: MJ 1. 9, 11, 13, 14Key Holder ID: G. TilsonQty: 4 MJ 1 2 of each of the othersaction: 4) MJ 12) MJ 92) MJ112) MJ132) MJ14all new keys for staff from housing who will have temporary offices in our suite, dur</p>

WO	Recieved	Finished	Total	Request
FO-340644	2/26/2016			New KeyNew Staff MemberKey #: 20030-5Key Holder ID: Aaron SwiftQty: 1action: Doing a walkthrough with C&IT for a wireless survey soon, and need master key for the MEB building.Account #: 121981
<b>T - Painter</b>			<b>26</b>	
FO-338344	2/1/2016	2/10/2016		PAINTERS TO MUD & PAINT REPAIRED HOLE IN THE WALL AT THE WATER PIPE LEADING TO THE HEATER IN THE LOBBY ( SEE STEPHEN FOR LOCATION )
FO-338347	2/1/2016	2/12/2016		PAINTERS TO MUD & PAINT 20" X 20" PATCH BASEMENT NEXT TO ROOM #18
FO-338365	2/1/2016			CLEAN & PAINT OVER GRAFITTI ENTIRE CAMPUS, FOR THE MONTH OF FEB.
FO-338587	2/2/2016			HANDYMAN TIME ( FEBRUARY 2016 )
FO-338713	2/3/2016	2/10/2016		3rd floor window columns, scrape, patch, prime & paint to finish entire 3rd floor.
FO-338714	2/3/2016	2/10/2016		Repaint existing east wall, currently green. shelving unites have been moved.
FO-338715	2/3/2016	2/8/2016		PAINTERS TO PAINT 8 SHEETS OF T-1-11 PLYWOOD TO MATCH THE SOFTBALL DUGOUT BACK OUTSIDE WALL
FO-339141	2/9/2016	2/9/2016		PAINTERS TO PAINT INSTALLED WOODEN PANEL THAT COVERS HOLE IN WALL LOCATED IN COUSTODIAL CLOSET ACROSS FROM THE ELEVATOR 2ND FLOOR
FO-339241	2/10/2016			2nd Floor, Scrape Prime & Paint Window Pockets, columns, & walls
FO-339272	2/10/2016	2/17/2016		PAINTERS TO PAINT THE WINDOW WALL & REGISTERS 3 OF THEM ROOM # 2134.00
FO-339319	2/11/2016	2/22/2016		PAINTERS TO MUD & PAINT 2 WALL REPAIRS BASEMENT BETWEEN ROOMS 159 & 169
FO-339398	2/12/2016			Repair, Prime & Paint, Buckling Patches in west stairwell between 1st thru 4th floors.
FO-339565	2/15/2016			PATCH, SAND, PRIME & PAINT TO FINISH ALL WALLS IN HALLWAY, BETWEEN ROOMS 1035 TRU 1155.
FO-339898	2/18/2016			SCRAPE, PRIME & PAINT... EXTERIOR HANDRAILS, OVERHEAD DOORS, MAN DOORS, BENCHES, TRASH DISPOSAL LIDS, CAMPUS WIDE.
FO-339946	2/18/2016	2/23/2016		PAINTERS TO PAINT FIRE EXTINGUISHER HANGER BOARDS
FO-339954	2/18/2016	2/25/2016		In the basement, RM.49 Repair Plaster, Prime & Paint to finish.
FO-339986	2/19/2016			PAINTERS TO MUD & PAINT WINDOW COVES REPAIRED BY THE CARPENTERS ROOMS # 1163 & 1151
FO-340015	2/19/2016			R/R LOBBY AREA Please paint doors and jambs in lobby area.2/19/16 lps: I spoke w/Tim Herr re: req. he spoke w/W Pociask for him to Cancel the estimate 280715, replace it with this request above req (280751).
FO-340288	2/23/2016			#1130 Men's bathroom writing on stall door - Incident # W16-0540043
FO-340289	2/23/2016			# 2238 Men's bathroom writing on stall door- Incident # W16-0540043
FO-340290	2/23/2016			#3238 Men's bathroom writing on toilet paper dispenser. Incident # W16-0540043
FO-340263	2/23/2016			Please paint 2 ladders with WSU logo and Engineering on them. They are for the engineer at the 5447 building.
FO-340265	2/23/2016			PAINTERS,PLEASE PATCH/PAINT WATER DAMAGED WINDOW AREA.PRIORITY-LOW
FO-340483	2/25/2016			PAINTERS TO MUD & PAINT DRINKING FOUNTAIN OUTSIDE ROOM # 3342 REPAIRED BY THE CARPENTERS
FO-340506	2/25/2016			Prime & Paint, Patch above wall outlet in room 2115
FO-340607	2/26/2016			Paint walls in main hall on the 1st floor. Include Emergency Exit door in painting.
<b>T - Pipefitter</b>			<b>25</b>	
FO-338720	2/2/2016	2/2/2016		processing time for paperwork, e-mails, phone calls, etc....CB....2-2-16
FO-338799	2/3/2016	2/3/2016		processing time for paperwork, e-mails, phone calls, etc....CB....2-3-16
FO-339055	2/5/2016	2/5/2016		processing time for paperwork, e-mails, phone calls, etc....CB....2-5-16
FO-339057	2/5/2016	2/5/2016		take contractor to look at insulation jobs.....CB....2-5-16
FO-339224	2/9/2016	2/9/2016		processing time for paperwork, e-mails, phone calls ,etc...CB...2-9-16
FO-339243	2/10/2016	2/17/2016		Pipe fitters: please install new valve body for ahu 8 heating valve. See BAS/ Rich H. for part and details. ,,,,,,,,,,,,,, ME/2-11-16 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-339249	2/10/2016	2/12/2016		2015/2016 STEAM TRAP TESTING, REPLACEMENT PROGRAM ,,,,,,,,,, JH/ 2-10-16 ,,,,,,,,,,  **SEE ATTACHED EMAIL FOR ROOMS WITHOUT HEAT
FO-339297	2/10/2016			Setup for removal of chill water valves mechanical room 25 ,,,,,,,,,, JT/EA/2-10-16 ,,,,,,,,,
FO-339397	2/11/2016	2/11/2016		take contractor to look at some insulation jobs....CB....2-11-16
FO-339392	2/11/2016			FITTERS, PLEASE REPLACE BAD HWH SUPPLY VALVE & HWH CONTROL VALVE ON #1 FFC UNIT. PRIORITY-LOW ,,,,,,,,,, EA/2-12-16 ,,,,,,,,,,
FO-339388	2/11/2016	2/11/2016		processing time for paperwork, e-mails, phone calls, etc....CB....2-11-16
FO-339482	2/12/2016	2/12/2016		set up contractor and supervise insulation job.....CB....2-12-16
FO-339476	2/13/2016			Replacement of 2 impact guns ,,,,,,,,,, JH/2-13-16 ,,,,,,,,,,
FO-339879	2/17/2016	2/25/2016		FITTER, PLEASE REPLACE LEAKING HWH VALVE ON #1 FFC. PRIORITY-LOW. ,,,,,,,,,, JH/2-18-16 ,,,,,,,,,,
FO-339957	2/18/2016	2/18/2016		processing time for paperwork,(impact report for Mott), phone calls, e-mails, etc....CB...2-18-16
FO-339967	2/19/2016	2/18/2016		**DUPLICATE WORK ORDER/ REFER TO FO#339256 JWT  Steam Fitters- High priority- Repair leaking hydronic line in receiving dock area. Caged storage rm 0359.
FO-340026	2/19/2016			Steven Pecic 10/23/2014 11:20 - Plant Fund Request Number ONLY: Scott Hall Mechanical Upgrades. Deferred Maintenance Budget: \$500,000.00 Brazen 10/24/2014 11:36 - Ops project didn't require a PM-fee FO.  BLS 04.28.15 - Project transferred to DCS, origi
FO-340125	2/22/2016	2/24/2016		PF Med Priority R/R RM 00035/MECH RM Repair steam leaks ahu #7 ,,,,,,,,,, EA/2-22-16 ,,,,,,,,,,
FO-340142	2/22/2016	2/22/2016		ECM meeting.....CB...2-22-16
FO-340308	2/23/2016	2/23/2016		processing time for [paperwork, e-mails, phone calls, etc....CB.....2-23-16
FO-340309	2/23/2016	2/23/2016		spoke to building coordinator about several building issues and chk prior radiator repairs in multiple rooms.....CB.....2-23-16
FO-340268	2/23/2016	2/24/2016		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON FFC UNIT. PRIORITY-LOW ,,,,,,,,,, JH/2-23-16 ,,,,,,,,,,
FO-340610	2/26/2016			processing time for paperwork, e-mails, phone calls, etc...CB.....2-26-16
FO-340612	2/26/2016			escort sheet metal contractor to several buildings for quotes.....CB.....2-26-16
FO-340608	2/26/2016			Leak from ceiling in com arts bldg in hallway outside room 136. I also called into public safety..... ME/2-29-16 ,,,,,,,,,,
<b>T - Plumber</b>			<b>56</b>	
FO-338343	2/1/2016	2/10/2016		R/R RM 130/MENS RR Repair urinal in M. Restroom #130 @ Matthaei.  See Bob Ostrowski on specifications..... GS/ 2-1-16 ,,,,,,,,,,
FO-338358	2/1/2016			The toilet in the stall in 2438 is leaking water on the handle/pipe. The floor is wet now..... TT/2-1-16 ,,,,,,,,,,
FO-338751	2/3/2016			(**) PO REQ DK 2/22  Remove stainless molded sink/counter top from rusted steel cabinets in DLAR Basement Wing rooms : 0411, 0413, 0415, 0417, 0419,0412, 0414, 0416 0418 Replace cabinets with stainless frames, then replace original sink back into new f
FO-338784	2/3/2016	2/11/2016		Plumbers replace damaged 4" center faucet for lav. sink in coaches locker room ,,,,,,,,,, GS/2-3-16 ,,,,,,,,,,
FO-338787	2/3/2016	2/23/2016		Plumbers repair leaking faucets in room 2246..... GS/2-3-16 ,,,,,,,,,,
FO-338788	2/3/2016	2/24/2016		Plumbers, please replace mop sink faucet that is beyond repair.....GS/2-3-16 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-338900	2/4/2016	2/5/2016		*PER GS THIS WAS COMPLETED 2/5/16 ON DIFFERENT FO JWT  Purdy Library, R/R RM 235/JANITORS' CLOSET SLOP SINK DRAIN HAS A LEAK CAUSING WTR TO GO TO 1ST FLR Teaching Commons Inside entrance to Teaching Commons: water leaking from ceiling - running down w
FO-339051	2/4/2016	2/4/2016		SAFETY MEETING ,,,,,,,,,, MM/ 2-4-16 ,,,,,,,,,,
FO-338915	2/4/2016	2/10/2016		R/R LOWER LEVEL Ladies restroom on Low Level (Mack side), has 2nd and 5th toilet that needs repair. Also, file odor emitting from same toilets.,,,,,,,,,, MM/2-5-16 ,,,,,,,,,,
FO-338928	2/4/2016	2/5/2016		(Men's bathroom): First sink faucet handle has fallen off. ,,,,,,,,,, TT/2-5-16 ,,,,,,,,,,
FO-338936	2/5/2016	2/10/2016		4th floor janitor closet water leaking very bad from fauct ,,,,,,,,,, MM/2-5-16 ,,,,,,,,,,
FO-338938	2/5/2016			(**) PO REQ DK 2/23 1st floor janitor faucet is not working. No water is coming out ,,,,,,,,,, MM/2-5-16 ,,,,,,,,,,
FO-338958	2/5/2016	2/5/2016		R/R RM 1234/UGL Women's Bath Room on 1st floor nearest to Extended Study Center has sink which needs attention ... sink is covered with plastic bag and has black sludge accumulated. (?) Door to bathroom has been locked and will not be opened until sink i
FO-338968	2/5/2016	2/10/2016		R/R RM 140/WOMENS RR 1st floor Purdy Women's Public restroom: First sink, left faucet handle has a leak draining from bottom. ,,,,,,,,,, TT/2-8-16 ,,,,,,,,,,
FO-338961	2/5/2016	2/8/2016		Drinking fountain near restrooms 2ed floor are plugged ,,,,,,,,,, TT/2-5-16 ,,,,,,,,,,
FO-339038	2/5/2016	2/5/2016		Clear urinal drains in hockey area ,,,,,,,,,, DB/2-5-16 ,,,,,,,,,,
FO-339049	2/5/2016	2/9/2016		R/R RM 1362/Mens RR second sink from left, not operating.,,,,,,,,,, MM/2-8-16 ,,,,,,,,,,
FO-339071	2/6/2016			Please install a cold water line up to the rooftop decking so that the air conditioning system can be serviced. There is a relatively convenient hole located in the roof that is over the 4th floor pump room, (near the elevator). Appropriate isolation and
FO-339073	2/6/2016	2/12/2016		Repair small drip from galvanized nipple located near the outlet of the backflow preventer serving the chilled water system at Education. Pipe is located above the sump pump in the basement mechanical room. ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,
FO-339105	2/8/2016	2/10/2016		R/R drain on Carpenters wash sink outside Doug's office ,,,,,,,,,, GS/2-8-16 ,,,,,,,,,,
FO-339149	2/9/2016	2/8/2016		**PER TIM HERR CONTRACTOR HAS DONE THIS JWT  Please repair the sprinkler head that blew on 2/8/2016.  It is in the loading dock area at the building entrance.
FO-339170	2/9/2016	2/10/2016		Repair two Delta faucets on hand washing sinks located in Men's lavatory of FAB near room 1360, (behind elevators). Seats & springs, cam packing and aerators need R/R. Water is skeeting out. ,,,,,,,,,, TT/2-9-16 ,,,,,,,,,,
FO-339202	2/9/2016			R/R Basement floor SOUTHEND NEAR ELEVS' women's public bathroom 1ST stall TOILET NOT FLUSHING FILLED UP W/TOILET PAPER
FO-339206	2/9/2016	2/12/2016		R/R RM 111/Bathroom needs faucet tightened or replaced- continuously drips.,,,,,,,,,, GS/2-9-16 ,,,,,,,,,,
FO-339208	2/9/2016	2/12/2016		R/R SOUTHEND NEAR ELEVS' Basement floor public men's restroom need TO CHNG three black toilet TO WHITE ,,,,,,,,,, GS/2-10-16 ,,,,,,,,,,
FO-339209	2/9/2016	2/12/2016		R/R 1ST FLR Replace 2 MALFUNCTIONING sink faucets in the 1st floor womens public restroom- south end of the building ,,,,,,,,,, GS/2-9-16 ,,,,,,,,,,
FO-339211	2/9/2016			R/R 1st floor SOUTHEND mens public restroom - south end of the building need 4 OUTDATED faucets replaced
FO-339221	2/9/2016	2/15/2016		R/R RM 051/BSMT Clear mop sink drain in basement janitors room 051 ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,
FO-339222	2/9/2016	2/9/2016		OPEN TO PIPEFITTER..CHK ON ABATEMENT AMOUNT AND ACCESS...2-9-16...CB*****Replace isolation valves and necessary piping to water meter Valves will not hold/ No way to isolate building in an Emergency ,,,,,,,,,, DB/1-29-16  *****  *
FO-339244	2/10/2016			Plumbers-please replace defective watts regulator on #1 domestic water booster pump Watts Model 263AP / 20-175 PSI/ 1/2" ,,,,,,,,,, TT/2-10-16 ,,,,,,,,,,
FO-339275	2/10/2016	2/10/2016		Clear drains for master bedroom bathroom sinks ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,
FO-339336	2/11/2016	2/12/2016		R/R Room 5204 - Ladies Restroom. Large sink drain is clogged. ,,,,,,,,,, MM/2-11-16 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-339372	2/11/2016	2/22/2016		R/R leaking floor flange 1st floor mens room ,,,,,, TT/2-11-16 ,,,,,,
FO-339380	2/11/2016	2/15/2016		Need new Water Filter for Drinking Fountain in Paint Shop.,,,,,, TT/2-13-16 ,,,,,,
FO-339390	2/11/2016	2/22/2016		R/R 1ST FLR/Men's Bathroom, directly across from Margherio Conference Room (141), the toilet in the second stall is malfunctioning, currently there is a plastic bag over it. ,,,,,, MM/2-15-16 ,,,,,,
FO-339414	2/12/2016	2/16/2016		R/R RM 205/Ladies restroom on second (2) floor, the 3rd bathroom stall has very low water flow and having problems flushing completely. You have flush 4 or 5 times just to clear any waste. ,,,,,, TT/2-12-16 ,,,,,,
FO-339415	2/12/2016			Plumber repair leaking faucet in kitchen #314.,,,,,, MM/2-15-16 ,,,,,,
FO-339473	2/13/2016	2/15/2016		R/R drinking fountain on 1st floor near elevators ,,,,,, TT/2-15-16 ,,,,,,
FO-339727	2/16/2016	2/16/2016		*DUPLICATE WORK ORDER JWT  PLUMBERS TO UNPLUG FLOOR DRAIN BASEMENT FERRY STREET ENTRANCE STANDING WATER ,,,,,, GS/2-16-16 ,,,,,,
FO-339744	2/16/2016	2/17/2016		Plumbers to Meet with Delta Rep at 9:00am 2/17 ,,,,,, GS/2-16-16 ,,,,,,
FO-339839	2/17/2016	2/19/2016		Toilet seat in first floor bathroom on east side of main stair is very loose. Tighten or replace.,,,,,, TT/2-18-16 ,,,,,,
FO-339861	2/17/2016	2/19/2016		First floor toilet runs continuously. Please fix. JUST DO IT. Charge Index: 113231.,,,,,, DB/2-18-16 ,,,,,,
FO-340079	2/22/2016	2/22/2016		R/R RM 2301/Men's restroom - 1st stall has a clogged toilet (custodians cannot unclog). ,,,,,, DB/2-22-16 ,,,,,,
FO-340080	2/22/2016	2/22/2016		R/R RM 2301/Men's restroom - Last urinal is not flushing. ,,,,,, DB/2-22-16 ,,,,,,
FO-340233	2/23/2016	2/23/2016		*DUPLICATE /REFER TO FO#340234 JWT  4th floor Men's room sink is clogged up. Needs to be un stopped.
FO-340281	2/23/2016	2/24/2016		On 3rd floor in Kitchen, faucet has a constant drip.,,,,,, DB/2-24-16 ,,,,,,
FO-340285	2/23/2016	2/23/2016		R/R water supply line to ice maker in training room ,,,,,, DB/2-23-16 ,,,,,,
FO-340307	2/24/2016			Trade: PlumberPriority: Medium2nd stall on left has leaking tail pipe and need Sloan valve kit.
FO-340402	2/24/2016	2/25/2016		R/R RM 250/CLASS LAB Main sink backed up not draining. ,,,,,, DB/2-24-16 ,,,,,,
FO-340442	2/25/2016			Sanitary waste pipe is leaking at ceiling, and at floor elbow.,,,,,, TT/2-25-16 ,,,,,,
FO-340481	2/25/2016			Investigate water on floor near wall rooms 502, 503 No access from 205, 201 *Sheryl would like to open wall if needed to see if source of water coming from plenum ,,,,, MM/2-25-16 ,,,,,,
FO-340482	2/25/2016			R/R 2 faucets in 2nd floor mens room not working ,,,,,, TT/2-25-16 ,,,,,,
FO-340497	2/25/2016	2/25/2016		Janitors sink needs to be snaked out room 251 ,,,,,, TT/2-25-16 ,,,,,,
FO-340544	2/26/2016			Garbage disposal needs service. When someone turns the machine on, it makes a lot of noise. ,,,,,, TT/2-26-16 ,,,,,,
FO-340563	2/26/2016			Repair flush valve assembly on the 1st toilet to the left in Men's lavitory, near 338 Cohn. Sloan valve long flushing. Vacuum breaker bad. Likely disc and diaphragm needed also. ,,,,, TT/2-26-16 ,,,,,,
FO-340576	2/26/2016			Could not find men's room on here. The toilet seat in the first stall in the second floor men's bathroom has been broken for several weeks ,,,,,, DB/2-26-16 ,,,,,,
<b>T - Roofing</b>			<b>4</b>	
FO-340389	2/24/2016			R/R RM 00316 3rd floor, Office #316, window is leaking water, do have a waste basket placed to try and collect the water.
FO-340401	2/24/2016			Community ArtsR/R RM 131/mens bathroom ceiling is leaking.
FO-340440	2/25/2016			Roofing- medium priority- Repair roof leaks on the South East corner of the building.
FO-340468	2/25/2016			2/25 PREVIOUS WORK ORDER 337093 is a ROOFING REQUEST / THIS REQUEST HAS BEEN CHANGE TO ROOFING. SEE TIM HERR FOR REPAIR SCHEDULE JWT 2/25  Purdy Library 4th Floor near Room 439. Water leaking from ceiling in same place as reported in FO-337093.

**Routine**

**7**



WO	Recieved	Finished	Total	Request
<b>T - Electrician</b>			<b>7</b>	
FO-338600	2/1/2016			PS#1 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338601	2/1/2016			PS#2 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338603	2/1/2016			PS#3 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338605	2/1/2016			PS#4 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338606	2/1/2016			PS#5 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338607	2/1/2016			PS#6 ROUTINE CHECK - 2/1 THRU 2/29/16
FO-338608	2/1/2016			VARIOUS CAMPUS LOTS ROUTINE CHECK - 2/1 THRU 2/29/16
<b>Scheduled Maint. (PM)</b>			<b>524</b>	
<b>Engineering</b>			<b>386</b>	
<b>Routine</b>			<b>386</b>	
<b>E - Auxiliary</b>			<b>28</b>	
FO-337229	2/1/2016	2/29/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337230	2/1/2016	2/29/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337231	2/1/2016	2/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337232	2/1/2016	2/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337233	2/1/2016	2/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337240	2/1/2016			PM - Air Handling Unit
FO-337241	2/1/2016			PM - Air Handling Unit
FO-337242	2/1/2016	2/29/2016		PM - Water/Air Cooled Condenser
FO-337243	2/1/2016	2/29/2016		PM - Air Handling Unit, HV Type
FO-337244	2/1/2016	2/5/2016		PM - Emergency Shower/Eyewash Station
FO-337245	2/1/2016	2/29/2016		PM - Air Handling Unit, HV Type
FO-337255	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-337256	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-337257	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-337258	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-337259	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-337858	2/4/2016	2/4/2016		Generator Maintenance, Monthly
FO-337849	2/8/2016	2/12/2016		PM - Emergency Shower/Eyewash Station
FO-337848	2/9/2016	2/10/2016		Generator Maintenance, Monthly
FO-338395	2/10/2016	2/11/2016		Generator Maintenance, Monthly
FO-338399	2/15/2016	2/19/2016		PM - Emergency Shower/Eyewash Station
FO-338657	2/17/2016	2/17/2016		Generator Maintenance, Monthly
FO-339134	2/22/2016	2/26/2016		PM - Emergency Shower/Eyewash Station
FO-338643	2/23/2016	2/26/2016		Generator Maintenance, Monthly
FO-338645	2/23/2016	2/26/2016		Generator Maintenance, Monthly
FO-338647	2/23/2016	2/24/2016		Generator Maintenance, Monthly
FO-338649	2/23/2016	2/24/2016		Generator Maintenance, Monthly
FO-338651	2/23/2016	2/24/2016		Generator Maintenance, Monthly
<b>E - MedPharm</b>			<b>39</b>	
FO-337099	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337100	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337101	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337102	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337103	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-337104	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337105	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337106	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337107	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337108	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337109	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337110	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337111	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337112	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337113	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337114	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337115	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337116	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337117	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337118	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337119	2/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337120	2/1/2016			PM - Emergency Shower/Eyewash Station
FO-337121	2/1/2016			PM - Emergency Shower/Eyewash Station
FO-337122	2/1/2016			PM - Emergency Shower/Eyewash Station
FO-337123	2/1/2016			PM - Domestic Water Heater, Electric
FO-337124	2/1/2016			PM - Domestic Water Heater, Electric
FO-337125	2/2/2016			Generator Maintenance, Monthly
FO-337126	2/2/2016			Generator Maintenance, Monthly
FO-337830	2/9/2016			Generator Maintenance, Monthly
FO-337831	2/9/2016			Generator Maintenance, Monthly
FO-338375	2/14/2016			PM - Chemical Feed/Metering Pump/Controller
FO-338376	2/14/2016			PM - Chemical Feed/Metering Pump/Controller
FO-338377	2/14/2016			PM - Chemical Feed/Metering Pump/Controller
FO-338378	2/14/2016			PM - Chemical Feed/Metering Pump/Controller
FO-338379	2/14/2016			PM - Chemical Feed/Metering Pump/Controller
FO-338380	2/16/2016			Generator Maintenance, Monthly
FO-338641	2/23/2016			Generator Maintenance, Monthly
FO-338673	2/23/2016			Generator Maintenance, Monthly
FO-339584	2/28/2016			PM - Reverse Osmosis Water Softener System
<b>E - North</b>			<b>19</b>	
FO-336294	2/1/2016	2/3/2016		Replace PRE-filters
FO-336295	2/1/2016	2/5/2016		Replace PRE-filters
FO-336296	2/1/2016	2/4/2016		Replace PRE-filters
FO-336297	2/1/2016	2/3/2016		Replace PRE-filters
FO-336301	2/1/2016	2/4/2016		Replace PRE-filters
FO-337127	2/1/2016	2/16/2016		PM - Sump Pump
FO-337128	2/1/2016	2/16/2016		PM - Sump Pump
FO-337129	2/1/2016	2/16/2016		PM - Sump Pump
FO-337130	2/1/2016	2/18/2016		PM - Sump Pump
FO-337131	2/1/2016	2/18/2016		PM - Sump Pump
FO-337132	2/1/2016	2/5/2016		PM - Harmsco Side Stream Filter
FO-337133	2/1/2016	2/9/2016		PM - Harmsco Side Stream Filter

WO	Recieved	Finished	Total	Request
FO-337134	2/1/2016	2/4/2016		PM - Harmsco Side Stream Filter
FO-337135	2/1/2016	2/4/2016		PM - Harmsco Side Stream Filter
FO-337136	2/1/2016	2/16/2016		PM - Sump Pump
FO-337137	2/1/2016	2/24/2016		PM - Unspecified
FO-337138	2/1/2016	2/3/2016		PM - Harmsco Side Stream Filter
FO-337832	2/9/2016	2/9/2016		Generator Maintenance, Monthly
FO-338653	2/24/2016			Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>28</b>	
FO-336277	2/1/2016	2/22/2016		Replace PRE-filters
FO-336278	2/1/2016	2/22/2016		Replace PRE-filters
FO-336279	2/1/2016	2/22/2016		Replace PRE-filters
FO-336280	2/1/2016	2/22/2016		Replace PRE-filters
FO-337139	2/1/2016	2/24/2016		PM - Deaerator Tank
FO-337140	2/1/2016	2/24/2016		PM - Water Softener
FO-337141	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337142	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337143	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337144	2/1/2016			PM - Domestic Water Heater, Steam
FO-337145	2/1/2016	2/1/2016		PM - Vacuum Pump
FO-337146	2/1/2016	2/16/2016		PM - Domestic Water Heater, Electric
FO-337837	2/4/2016	2/4/2016		Generator Maintenance, Monthly
FO-337838	2/4/2016	2/4/2016		Generator Maintenance, Monthly
FO-337839	2/4/2016	2/4/2016		Generator Maintenance, Monthly
FO-337887	2/4/2016	2/4/2016		Generator Maintenance, Thursday 2/4/2016 @ 7:30 AM.
FO-337833	2/5/2016	2/5/2016		Generator Maintenance, Monthly
FO-337834	2/5/2016	2/5/2016		Generator Maintenance, Monthly
FO-337835	2/5/2016	2/5/2016		Generator Maintenance, Monthly
FO-337836	2/5/2016	2/5/2016		Generator Maintenance, Monthly
FO-337840	2/5/2016	2/11/2016		Generator Maintenance, Monthly
FO-337841	2/5/2016	2/4/2016		Generator Maintenance, Monthly
FO-338381	2/16/2016	2/10/2016		Generator Maintenance, Monthly
FO-338659	2/18/2016	2/18/2016		Generator Maintenance, Monthly
FO-339133	2/21/2016			PM - Domestic Water Heater, Gas
FO-338638	2/24/2016			Generator Maintenance, Monthly
FO-338665	2/25/2016	2/25/2016		Generator Maintenance, Monthly
FO-338667	2/25/2016	2/25/2016		Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>157</b>	
FO-335938	2/1/2016		2/1/2016	HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335939	2/1/2016		2/1/2016	HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335940	2/1/2016		2/1/2016	HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335941	2/1/2016	2/27/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335942	2/1/2016	2/16/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335943	2/1/2016	2/27/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335944	2/1/2016	2/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335945	2/1/2016	2/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335946	2/1/2016	2/27/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335947	2/1/2016	2/3/2016		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-335948	2/1/2016	2/17/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335949	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335950	2/1/2016	2/10/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335951	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335952	2/1/2016	2/3/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335953	2/1/2016	2/3/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335954	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335955	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335956	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335957	2/1/2016	2/11/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335958	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335959	2/1/2016	2/24/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335960	2/1/2016	2/24/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335961	2/1/2016	2/16/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335962	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335963	2/1/2016	2/2/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335964	2/1/2016	2/16/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335965	2/1/2016	2/10/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335966	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335967	2/1/2016	2/17/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335968	2/1/2016	2/24/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335969	2/1/2016	2/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335970	2/1/2016	2/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335971	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335972	2/1/2016	2/3/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335973	2/1/2016	2/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335974	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335975	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335976	2/1/2016	2/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335977	2/1/2016	2/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335978	2/1/2016	2/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335979	2/1/2016	2/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335980	2/1/2016	2/11/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335981	2/1/2016	2/11/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335982	2/1/2016	2/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335983	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335984	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335985	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335986	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335987	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335988	2/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335989	2/1/2016	2/17/2016		PM - Air Handling Unit (ANNUAL)
FO-335990	2/1/2016	2/12/2016		PM - Air Handling Unit (ANNUAL)
FO-335991	2/1/2016	2/10/2016		PM - Air Handling Unit (ANNUAL)
FO-335992	2/1/2016	2/5/2016		PM - Air Handling Unit (ANNUAL)
FO-335993	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
FO-335994	2/1/2016	2/13/2016		PM - Air Handling Unit (ANNUAL)

WO	Recieved	Finished	Total	Request
FO-335995	2/1/2016	2/16/2016		PM - Air Handling Unit (ANNUAL)
FO-335996	2/1/2016	2/4/2016		PM - Air Handling Unit (ANNUAL)
FO-335997	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
FO-335998	2/1/2016	2/4/2016		PM - Air Handling Unit (ANNUAL)
FO-335999	2/1/2016	2/23/2016		Replace PRE-filters
FO-336000	2/1/2016	2/23/2016		PM - Air Handling Unit (ANNUAL)
FO-336001	2/1/2016	2/20/2016		PM - Air Handling Unit (ANNUAL)
FO-336002	2/1/2016	2/20/2016		PM - Air Handling Unit (ANNUAL)
FO-336003	2/1/2016	2/17/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-336004	2/1/2016			Replace PRE-filters
FO-336005	2/1/2016	2/5/2016		PM - Fan Coil/HV/AC Unit
FO-336006	2/1/2016	2/5/2016		PM - Fan Coil/HV/AC Unit
FO-336007	2/1/2016	2/10/2016		PM - Fan Coil/HV/AC Unit
FO-336008	2/1/2016	2/10/2016		PM - Fan Coil/HV/AC Unit
FO-336009	2/1/2016	2/5/2016		PM - Fan Coil/HV/AC Unit
FO-336010	2/1/2016	2/5/2016		PM - Fan Coil/HV/AC Unit
FO-336011	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336012	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336013	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336014	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336015	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336016	2/1/2016		2/1/2016	Replace PRE-filters
FO-336017	2/1/2016		2/1/2016	Replace PRE-filters
FO-336018	2/1/2016		2/1/2016	Replace PRE-filters
FO-336019	2/1/2016		2/1/2016	Replace PRE-filters
FO-336020	2/1/2016		2/1/2016	Replace PRE-filters
FO-336021	2/1/2016		2/1/2016	Replace PRE-filters
FO-336022	2/1/2016		2/1/2016	Replace PRE-filters
FO-336023	2/1/2016		2/1/2016	Replace PRE-filters
FO-336024	2/1/2016	2/16/2016		Replace PRE-filters
FO-336025	2/1/2016	2/16/2016		Replace PRE-filters
FO-336026	2/1/2016	2/17/2016		Replace PRE-filters
FO-336027	2/1/2016	2/17/2016		Replace PRE-filters
FO-336028	2/1/2016	2/18/2016		Replace PRE-filters
FO-336029	2/1/2016	2/18/2016		Replace PRE-filters
FO-336030	2/1/2016	2/19/2016		Replace PRE-filters
FO-336031	2/1/2016	2/20/2016		PM - Air Handling Unit (ANNUAL)
FO-336032	2/1/2016	2/19/2016		PM - Air Handling Unit (ANNUAL)
FO-336033	2/1/2016	2/19/2016		PM - Air Handling Unit (ANNUAL)
FO-336034	2/1/2016	2/20/2016		PM - Air Handling Unit (ANNUAL)
FO-336035	2/1/2016	2/18/2016		PM - Air Handling Unit (ANNUAL)
FO-336036	2/1/2016	2/13/2016		PM - Air Handling Unit (ANNUAL)
FO-336037	2/1/2016	2/17/2016		PM - Air Handling Unit (ANNUAL)
FO-336038	2/1/2016	2/6/2016		Replace PRE-filters
FO-336039	2/1/2016	2/3/2016		Replace PRE-filters
FO-336040	2/1/2016	2/6/2016		Replace PRE-filters
FO-336041	2/1/2016	2/6/2016		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-336042	2/1/2016	2/3/2016		Replace PRE-filters
FO-336043	2/1/2016	2/10/2016		PM - Air Handling Unit (ANNUAL)
FO-336044	2/1/2016	2/13/2016		PM - Air Handling Unit (ANNUAL)
FO-336045	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
FO-336046	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
FO-336047	2/1/2016	2/10/2016		Replace PRE-filters
FO-336048	2/1/2016	1/29/2016		PM - Air Handling Unit (ANNUAL)
FO-336049	2/1/2016	2/16/2016		PM - Air Handling Unit (ANNUAL)
FO-336050	2/1/2016	2/10/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-336051	2/1/2016	2/24/2016		Replace PRE-filters
FO-336052	2/1/2016	2/11/2016		Replace PRE-filters
FO-336053	2/1/2016	2/11/2016		Replace PRE-filters
FO-336054	2/1/2016	2/10/2016		Replace PRE-filters
FO-336055	2/1/2016	2/10/2016		Replace PRE-filters
FO-336056	2/1/2016	2/11/2016		Replace PRE-filters
FO-336057	2/1/2016	2/11/2016		Replace PRE-filters
FO-336058	2/1/2016	2/16/2016		Replace PRE-filters
FO-336059	2/1/2016	2/17/2016		Replace PRE-filters
FO-336060	2/1/2016	2/16/2016		Replace PRE-filters
FO-336061	2/1/2016	2/16/2016		Replace PRE-filters
FO-336062	2/1/2016	2/13/2016		Replace PRE-filters
FO-336063	2/1/2016	2/13/2016		Replace PRE-filters
FO-336064	2/1/2016	2/13/2016		Replace PRE-filters
FO-336065	2/1/2016	2/13/2016		Replace PRE-filters
FO-336066	2/1/2016	2/9/2016		Replace PRE-filters
FO-336067	2/1/2016	2/9/2016		Replace PRE-filters
FO-336068	2/1/2016	2/6/2016		Replace PRE-filters
FO-336069	2/1/2016	2/5/2016		Replace PRE-filters
FO-336070	2/1/2016	2/12/2016		Replace PRE-filters
FO-336071	2/1/2016	2/16/2016		Replace PRE-filters
FO-336072	2/1/2016	2/13/2016		Replace PRE-filters
FO-336073	2/1/2016	2/17/2016		Replace PRE-filters
FO-336074	2/1/2016	2/18/2016		Replace PRE-filters
FO-336075	2/1/2016	2/20/2016		Replace PRE-filters
FO-336076	2/1/2016	2/23/2016		Replace PRE-filters
FO-336077	2/1/2016	2/19/2016		Replace PRE-filters
FO-336078	2/1/2016	2/19/2016		Replace PRE-filters
FO-336079	2/1/2016	2/26/2016		Replace PRE-filters
FO-336080	2/1/2016	2/25/2016		Replace PRE-filters
FO-336081	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336082	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336083	2/1/2016	2/12/2016		PM - Fan Coil/HV/AC Unit
FO-336084	2/1/2016	2/18/2016		Replace PRE-filters
FO-336085	2/1/2016	3/1/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-336086	2/1/2016	2/6/2016		Replace PRE-filters
FO-328928	2/1/2016	2/12/2016		PM - Air Handling Unit (ANNUAL)
FO-328927	2/1/2016	2/12/2016		PM - Air Handling Unit (ANNUAL)

WO	Recieved	Finished	Total	Request
FO-328926	2/1/2016	2/11/2016		PM - Air Handling Unit (ANNUAL)
FO-328925	2/1/2016	2/11/2016		PM - Air Handling Unit (ANNUAL)
FO-328924	2/1/2016	2/10/2016		PM - Air Handling Unit (ANNUAL)
FO-328923	2/1/2016	2/10/2016		PM - Air Handling Unit (ANNUAL)
FO-328921	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
FO-328922	2/1/2016	2/9/2016		PM - Air Handling Unit (ANNUAL)
<b>E - South</b>			<b>33</b>	
FO-337147	2/1/2016	2/4/2016		PM - Water Softener
FO-337148	2/1/2016	2/4/2016		PM - Deaerator Tank
FO-337153	2/1/2016	2/2/2016		PM - Domestic Water Heater, Electric
FO-337155	2/1/2016	2/1/2016		PM - Vacuum Pump
FO-337156	2/1/2016	2/1/2016		PM - Vacuum Pump
FO-337213	2/1/2016	2/15/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337214	2/1/2016	2/15/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337236	2/1/2016	2/15/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337237	2/1/2016	2/11/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337238	2/1/2016	2/10/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337246	2/1/2016	2/2/2016		PM - Domestic Water Heater, Electric
FO-337247	2/1/2016	12/12/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337248	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337249	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337250	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337251	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337252	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337253	2/1/2016	2/18/2016		PM - Water Booster Pump
FO-337254	2/1/2016	2/9/2016		PM - Water Booster Pump
FO-337260	2/1/2016	12/12/2015		Replace PRE-filters
FO-337862	2/3/2016	2/3/2016		Generator Maintenance, Monthly
FO-337850	2/4/2016	2/18/2016		PM - Water Booster Pump
FO-337842	2/8/2016	2/3/2016		Monthly AHU Inspection Clean Room Unit 2
FO-337843	2/8/2016	2/3/2016		PM - Monthly AHU Inspection Clean Room Unit 1
FO-338384	2/11/2016	2/11/2016		Generator Maintenance, Monthly
FO-338386	2/11/2016	2/11/2016		Generator Maintenance, Monthly
FO-338398	2/11/2016	2/11/2016		Generator Maintenance, Monthly
FO-338419	2/11/2016	2/11/2016		Generator Maintenance, Monthly
FO-338382	2/16/2016	2/23/2016		PM - Domestic Water Heater, Gas
FO-338388	2/16/2016	2/16/2016		Generator Maintenance, Monthly
FO-338636	2/17/2016	2/17/2016		Generator Maintenance, Monthly
FO-338671	2/17/2016	2/17/2016		Generator Maintenance, Monthly
FO-338661	2/18/2016	2/18/2016		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>73</b>	
FO-337149	2/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337150	2/1/2016			PM - Sump Pump
FO-337151	2/1/2016			PM - Sump Pump
FO-337152	2/1/2016			PM - Sump Pump
FO-337157	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337158	2/1/2016			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-337159	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337160	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337161	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337162	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337163	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337164	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337165	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337166	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337167	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337168	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337169	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337170	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337171	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337172	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337173	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337174	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337175	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337176	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337177	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337178	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337179	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337180	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337181	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337182	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337183	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337184	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337185	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337186	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337187	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337188	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337189	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337190	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337191	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337192	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337193	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337194	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337195	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337196	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337197	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337198	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337199	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337200	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337201	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337202	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337203	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337204	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337205	2/1/2016			PM - Fan Coil/HV/AC Unit



WO	Recieved	Finished	Total	Request
FO-337206	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337207	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337208	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337209	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337210	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337215	2/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337216	2/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337217	2/1/2016			PM - Heat Pumps (5057 Woodward)
FO-337218	2/1/2016			PM - Heat Pumps (5057 Woodward)
FO-337219	2/1/2016			PM - Heat Pumps (5057 Woodward)
FO-337220	2/1/2016			PM - Heat Pumps (5057 Woodward)
FO-337221	2/1/2016			PM - Air Intake Dampers (Old Main)
FO-337222	2/1/2016			PM - Air Intake Dampers (Old Main)
FO-337223	2/1/2016			PM - Air Intake Dampers (Old Main)
FO-337224	2/1/2016			PM - Fan Coil/HV/AC Unit
FO-337225	2/1/2016			PM - Sump Pump
FO-337226	2/1/2016			PM - Sump Pump
FO-337227	2/1/2016			PM - Sump Pump
FO-338391	2/16/2016			Generator Maintenance, Monthly
FO-338393	2/16/2016			Generator Maintenance, Monthly
<b>E - West</b>			<b>9</b>	
FO-337154	2/1/2016			PM - Domestic Water Heater, Steam
FO-337211	2/1/2016			PM - Domestic Water Heater, Electric
FO-337212	2/1/2016			PM - Water Softener
FO-337228	2/1/2016			PM - Domestic Water Heater, Electric
FO-337234	2/1/2016			PM - Domestic Water Heater, Electric
FO-337235	2/1/2016			PM - Domestic Water Heater, Electric
FO-337860	2/3/2016	2/3/2016		Generator Maintenance, Monthly
FO-337853	2/9/2016	2/10/2016		Generator Maintenance, Monthly
FO-338663	2/25/2016			Generator Maintenance, Monthly
<b>Trades</b>			<b>138</b>	
<b>Routine</b>			<b>138</b>	
<b>T - Electrician</b>			<b>119</b>	
FO-337262	2/1/2016	2/1/2016		PM - Sump Pump
FO-337263	2/1/2016	2/1/2016		PM - Sump Pump
FO-337264	2/1/2016	2/1/2016		PM - Sump Pump
FO-337265	2/1/2016	2/1/2016		PM - Sump Pump
FO-337266	2/1/2016	2/1/2016		PM - Sump Pump
FO-337267	2/1/2016	2/12/2016		PM - Sump Pump
FO-337239	2/2/2016	2/2/2016		Generator Test Tuesday 2/2/2016 @ 7:15 AM.
FO-337261	2/2/2016	1/29/2016		Generator Test
FO-337859	2/3/2016	2/3/2016		Generator Test Wednesday 2/3/2016 @ 7:30 AM.
FO-337861	2/3/2016	2/3/2016		Generator Test Wednesday 2/3/2016 @ 7:30 AM.
FO-337865	2/3/2016	2/3/2016		PM - Sump Pump
FO-337868	2/3/2016	2/3/2016		PM - Sump Pump
FO-337871	2/3/2016	2/3/2016		PM - Sump Pump
FO-337874	2/3/2016	2/3/2016		PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-337877	2/3/2016	2/3/2016		PM - Sump Pump
FO-337880	2/3/2016	2/3/2016		PM - Sump Pump
FO-337857	2/4/2016	2/4/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337881	2/4/2016	2/4/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337882	2/4/2016	2/4/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337883	2/4/2016	2/4/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337884	2/4/2016	2/4/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337844	2/5/2016	2/5/2016		Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337854	2/5/2016	2/5/2016		Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337855	2/5/2016	2/5/2016		Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337856	2/5/2016	2/5/2016		Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337863	2/5/2016	2/5/2016		PM - Sump Pump
FO-337866	2/5/2016	2/5/2016		PM - Sump Pump
FO-337869	2/5/2016	2/5/2016		PM - Sump Pump
FO-337872	2/5/2016	2/5/2016		PM - Sump Pump
FO-337875	2/5/2016	2/5/2016		PM - Sump Pump
FO-337878	2/5/2016	2/5/2016		PM - Sump Pump
FO-337885	2/5/2016	2/5/2016		Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337886	2/5/2016	2/5/2016		Generator Test Friday 2/5/2016 @ 7:15 AM.
FO-337864	2/8/2016	2/8/2016		PM - Sump Pump
FO-337867	2/8/2016	2/8/2016		PM - Sump Pump
FO-337870	2/8/2016	2/8/2016		PM - Sump Pump
FO-337873	2/8/2016	2/8/2016		PM - Sump Pump
FO-337876	2/8/2016	2/8/2016		PM - Sump Pump
FO-337879	2/8/2016	2/8/2016		PM - Sump Pump
FO-337845	2/9/2016	2/9/2016		Generator Test Tuesday 2/9/2016 @ 7:15 AM.  ****PER EUGEAN NO TEST****
FO-337846	2/9/2016	2/9/2016		Generator Test Tuesday 2/9/2016 @ 7:15 AM.  ****PER EUGEAN NO TEST****
FO-337847	2/9/2016	2/9/2016		Generator Test Tuesday 2/9/2016 @ 7:15 AM.
FO-337851	2/9/2016	2/9/2016		Generator Test Tuesday 2/9/2019 @ 7:15 AM.
FO-337852	2/9/2016	2/9/2016		Generator Test Tuesday 2/9/2016 @ 1PM.
FO-338394	2/10/2016	2/10/2016		Generator Test Thursday 2/11/2016 @ 1PM.
FO-338402	2/10/2016	2/10/2016		PM - Sump Pump
FO-338405	2/10/2016	2/10/2016		PM - Sump Pump
FO-338408	2/10/2016	2/10/2016		PM - Sump Pump
FO-338411	2/10/2016	2/10/2016		PM - Sump Pump
FO-338414	2/10/2016	2/10/2016		PM - Sump Pump
FO-338417	2/10/2016	2/10/2016		PM - Sump Pump
FO-338385	2/11/2016	2/11/2016		Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338387	2/11/2016	2/11/2016		Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338397	2/11/2016	2/11/2016		Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338418	2/11/2016	2/11/2016		Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338400	2/12/2016	2/12/2016		PM - Sump Pump
FO-338403	2/12/2016	2/12/2016		PM - Sump Pump
FO-338406	2/12/2016	2/12/2016		PM - Sump Pump
FO-338409	2/12/2016	2/12/2016		PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-338412	2/12/2016	2/12/2016		PM - Sump Pump
FO-338415	2/12/2016	2/12/2016		PM - Sump Pump
FO-338401	2/15/2016	2/15/2016		PM - Sump Pump
FO-338404	2/15/2016	2/15/2016		PM - Sump Pump
FO-338407	2/15/2016	2/15/2016		PM - Sump Pump
FO-338410	2/15/2016	2/15/2016		PM - Sump Pump
FO-338413	2/15/2016	2/15/2016		PM - Sump Pump
FO-338416	2/15/2016	2/15/2016		PM - Sump Pump
FO-338383	2/16/2016	2/16/2016		Generator Test, Tuesday 2/16/2016 @ 7:15 AM.
FO-338389	2/16/2016	2/16/2016		Generator Test, Tuesday 2/16/2016 @ 9:30 AM.
FO-338390	2/16/2016	2/16/2016		Generator Test, Tuesday 2/16/2016 @ 8:15
FO-338392	2/16/2016	2/16/2016		Generator Test, Tuesday 2/16/2016 @ 8:15 AM.
FO-338396	2/16/2016	2/16/2016		Generator Test, Tuesday 2/16/2016 @ 9:15 AM.
FO-338637	2/17/2016	2/17/2016		Generator Test, Wednesday 2/17/2016 @ 10:00.
FO-338654	2/17/2016	2/17/2016		Generator Test, Wednesday 2/17/2016 @ 7:15 AM.
FO-338670	2/17/2016	2/15/2016		Generator Test, Wednesday 2/17/2016 @ 10 AM.
FO-339005	2/17/2016	2/17/2016		PM - Sump Pump
FO-339007	2/17/2016	2/17/2016		PM - Sump Pump
FO-339009	2/17/2016	2/17/2016		PM - Sump Pump
FO-339011	2/17/2016	2/17/2016		PM - Sump Pump
FO-339013	2/17/2016	2/17/2016		PM - Sump Pump
FO-339015	2/17/2016	2/17/2016		PM - Sump Pump
FO-338658	2/18/2016	2/18/2016		Generator Test, Thursday 2/18/2016 @ 7:15 AM.
FO-338660	2/18/2016	2/18/2016		Generator Test, Thursday 2/18/2016 @ 7:15 AM.
FO-339004	2/19/2016	2/19/2016		PM - Sump Pump
FO-339006	2/19/2016	2/19/2016		PM - Sump Pump
FO-339008	2/19/2016	2/19/2016		PM - Sump Pump
FO-339010	2/19/2016	2/19/2016		PM - Sump Pump
FO-339012	2/19/2016	2/19/2016		PM - Sump Pump
FO-339014	2/19/2016	2/19/2016		PM - Sump Pump
FO-339135	2/22/2016	2/22/2016		PM - Sump Pump
FO-339136	2/22/2016	2/22/2016		PM - Sump Pump
FO-339137	2/22/2016	2/22/2016		PM - Sump Pump
FO-339138	2/22/2016	2/22/2016		PM - Sump Pump
FO-339139	2/22/2016	2/22/2016		PM - Sump Pump
FO-339140	2/22/2016	2/22/2016		PM - Sump Pump
FO-338640	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 7:15 AM.
FO-338642	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 10AM.
FO-338644	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338646	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338648	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338650	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338672	2/23/2016	2/23/2016		Generator Test, Tuesday 2/23/2016 @ 2PM.
FO-338639	2/24/2016	2/24/2016		Generator Test, Wednesday 2/24/2016 @ 7:15 AM.
FO-338652	2/24/2016	2/24/2016		Generator Test, Wednesday 2/24/2016 @ 7:15 AM.
FO-339703	2/24/2016	2/24/2016		PM - Sump Pump
FO-339706	2/24/2016	2/24/2016		PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-339709	2/24/2016	2/24/2016		PM - Sump Pump
FO-339712	2/24/2016	2/24/2016		PM - Sump Pump
FO-339715	2/24/2016	2/24/2016		PM - Sump Pump
FO-339718	2/24/2016	2/24/2016		PM - Sump Pump
FO-338662	2/25/2016			Generator Test, Thursday 2/25/2016 @ 7:15 AM.
FO-338664	2/25/2016			Generator Test, Thursday 2/25/2015 @ 1PM.
FO-338666	2/25/2016			Generator Test, Thursday 2/25/2016 @ 1PM.
FO-339701	2/26/2016			PM - Sump Pump
FO-339704	2/26/2016			PM - Sump Pump
FO-339707	2/26/2016			PM - Sump Pump
FO-339710	2/26/2016			PM - Sump Pump
FO-339713	2/26/2016			PM - Sump Pump
FO-339716	2/26/2016			PM - Sump Pump
<b>T - Plumber</b>			<b>19</b>	
FO-336281	2/1/2016	2/1/2016		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-336531	2/1/2016			PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/2-1-16 ,,,,,,,,,
FO-336532	2/1/2016			PM - Waterless Urinals ,,,,,,,,,, MM/2-1-16 ,,,,,,,,,
FO-336533	2/1/2016	2/3/2016		PM - Waterless Urinals ,,,,,,,,,, TT/2-1-16 ,,,,,,,,,
FO-336534	2/1/2016	2/3/2016		PM - Waterless Urinals ,,,,,,,,,, TT/2-1-16 ,,,,,,,,,
FO-338963	2/1/2016	2/10/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338964	2/1/2016			2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338965	2/1/2016	2/10/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338966	2/1/2016	2/10/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338967	2/1/2016	2/9/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338982	2/1/2016	2/11/2016		PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,
FO-338983	2/1/2016	2/11/2016		PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,
FO-338984	2/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,
FO-338985	2/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,
FO-338986	2/1/2016	2/10/2016		PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,
FO-338987	2/1/2016	2/9/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-338988	2/1/2016	2/9/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-339016	2/1/2016	2/9/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,
FO-339017	2/1/2016	2/9/2016		2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,

---

**Total: 2152**