

Facilities Operations Work Orders Received 11/1/2014 through 11/30/2014

WO	Received	Finished	Total	Request
Maint. Work Order			1915	
Custodial			199	
Emergency			1	
C-Sector 09			1	
FO-301158	11/10/2014	11/11/2014		Two class rooms need to be cleaned ASAP. room 370 and room 357. room 357 has a class until 8pm.
High			3	
C-Repair			2	
FO-300978	11/7/2014	11/6/2014		Install a hand sanitizer wall mount on the 6th floor outside public restroom and also place a hand sanitizer stand in hallway by room 6203
FO-300981	11/7/2014	11/14/2014		List the part numbers for 10 auto scrubber batteries for quote and purchase through Harris battery . Submit information to Marvin Darby by November 17, 2014
C-Sector 04			1	
FO-301245	11/11/2014	11/11/2014		SPILL FRONT STAIRWELL LEADING TO THE 2ND FLOOR.
Medium			2	
C-Director			1	
FO-301832	11/17/2014			Custodial and Grounds to support Thanksgiving Day Parade and Turkey Trott. Buildings: Welcome Center (Warming Center), Freer House (VIP), Rackham (Outside Only), Green Space (Warren/Woodward). Event will be serviced from 5am - 12Noon
C-Repair			1	
FO-301469	11/13/2014	11/13/2014		WOMENS RESTROOM NEXT TO KITCHEN, SOAP DISPENSOR NOT WORKING
Low			193	
C-Director			1	
FO-301499	11/13/2014			Custodial to cover Scholar's Day.
C-Lighting			69	
FO-300345	11/3/2014			Relamp Round light fixture at the south end of the west 3rd floor corridor.(Entry to lectures Hall Corridor)
FO-300348	11/3/2014	11/3/2014		Light Cover Hanging in room 358. please fix ASAP. any questions please call Terri at 7-3003.Task complete.
FO-300404	11/3/2014	11/6/2014		Stairwell J basement level. Each ligt in the stairwell on the basement level has a bulb burnt out
FO-300409	11/3/2014	11/5/2014		The light intensity is too great for the animals. Two light bulbs must be taken out of each light fixture in rooms 0243, 0245, 0245.1, and 0246. ASAP per site visitors.
FO-300770	11/4/2014	11/6/2014		Mens Locker Room - Relamp light fixture.
FO-300781	11/4/2014	11/5/2014		Please replace lights-rm 306.4 COE Thankyou This task is complete.
FO-300790	11/4/2014	11/6/2014		344 Scott Hall - ladies locker room has lights out in the 2 shower stalls. Please repair as soon as possible.
FO-300826	11/5/2014	11/5/2014		Please replace lights-out-1st flr men's restroom-COE. Thank you
FO-300828	11/5/2014	11/5/2014		Please replace lights-out-basement men's restroom, COE. Thank you
FO-300839	11/5/2014	11/5/2014		Re-lamp fixtures in 2nd floor Men's restroom.
FO-300910	11/6/2014	11/7/2014		ROOM #0307.1 NEEDS LIGHT BULBS REPLACED AS SOON AS POSSIBLE. ONLY ONE LIGHT ON IN THIS OFFICE.
FO-300911	11/6/2014	11/12/2014		Relamp corridor light fixture on 3rd fl. Corridor opposite entry to Green Lecture Hall.
FO-300913	11/6/2014	11/7/2014		Overhead light above desk on right hand side is burned out.
FO-300944	11/6/2014	11/7/2014		Note from DALNET, Kristy Eklund: "There are several lights out in 2210 and out in hallways by the bathrooms. It looks like they are all the emergency lights." Please see Kristy Eklund or Steven Bowers. This Suite of Offices is card entry only. Circ De
FO-300950	11/6/2014	11/7/2014		Light above sink in men's bathroom is burned out. Please replace.
FO-301023	11/7/2014	11/10/2014		5 of the 11 lights on the first floor hallway are not working. 2 of the lamp fixtures have yellow tape from the lighting crew from back in 2013. Also the fluorescent fixture at the door of 125 is not lit.

WO	Recieved	Finished	Total	Request
FO-301137	11/10/2014	11/13/2014		Replace light in restroom located in lunchroom area - NOTE: Door number is 6100.0.
FO-301163	11/10/2014	11/11/2014		Overhead lights dim due to burned out bulbs. Looking into the classroom three tubes on the right and 2 tubes on the left side of the room are burned out.
FO-301164	11/10/2014	11/11/2014		This is a classroom. Overhead lights dim due to burned out bulbs. Looking into the classroom three tubes on the left side of the room are burned out.
FO-301165	11/10/2014	11/13/2014		Overhead lights dim due to burned out bulbs. Looking into the classroom 5 tubes on the right and 6 tubes on the left side of the room are burned out.
FO-301166	11/10/2014	11/11/2014		Overhead lights dim due to burned out bulbs. Looking into the classroom 7 tubes on the right and 6 tubes on the left side of the room are burned out.
FO-301167	11/10/2014	11/11/2014		Overhead lights dim due to burned out bulbs. 3 tubes on the right and 2 tubes on the left side of the room are burned out.
FO-301168	11/10/2014	11/11/2014		Overhead lights dim due to burned out bulbs. 5 tubes on the right and 7 tubes on the left side of the room are burned out.
FO-301169	11/10/2014	11/14/2014		Room 307. This is a classroom not on the drop down list. Overhead lights dim due to burned out bulbs. 1 tubes on the right and 3 tubes on the left side of the room are burned out.
FO-301170	11/10/2014	11/14/2014		Room 308. This is a classroom not on the drop down list. Overhead lights dim due to burned out bulbs. 1 tube on the right and 1 tube on the left side of the room are burned out.
FO-301171	11/10/2014	11/14/2014		Room 325 is a Computer Lab which also functions as a testing room for students. The overhead lighting left side 3rd row ceiling panel light is burned out.
FO-301225	11/11/2014	11/11/2014		There is a light bulb out in 27 Prentis. Task complete.
FO-301254	11/11/2014	11/14/2014		One spot light out in SW corner of lobby.
FO-301255	11/11/2014	11/14/2014		Light out in north stairwell between 1st & 2nd floor.
FO-301256	11/11/2014	11/14/2014		Light out in south stairwell between 3rd & 4th floors.
FO-301269	11/11/2014	11/12/2014		There are 2-3 lights out in suit 2701. please see receptionist for exact location. ok to close...
FO-301292	11/11/2014	11/13/2014		the cover of light is broken, please take it off or replace it as soon as possible, otherwise I'm afraid it may fall down anytime, thanks
FO-301294	11/11/2014	11/13/2014		dead light bulb.
FO-301295	11/11/2014	11/13/2014		dead light bulb.
FO-301335	11/12/2014	11/13/2014		light out on third floor room 306.4. this light was out recently. This request was answered before. The light was replaced all is still working. This was witnessed by lighting techs Michael Seldon and David Glenn.
FO-301388	11/12/2014	11/13/2014		on the second floor in the honors college. one light out in hallway leading to the men's room in the back of the honors college. office opens at 8:30am
FO-301399	11/12/2014	11/14/2014		Room 475 has one panel with two lights out. Task complete.
FO-301402	11/12/2014	11/17/2014		Light out in room 345. This task is complete.
FO-301405	11/12/2014	11/14/2014		Kresge Library, 1st Floor, Open Study Area Flickering light in display case (University Press) along west wall. This task is complete no problems. Please see Richard at the Purdy Check Out desk if additional information or access is needed. Tha
FO-301482	11/13/2014	11/13/2014		(closest to) rm 3638 - Women's R/R, the entrance area has three lights out. ok to close.
FO-301486	11/13/2014			MD Lab 2106 -Relamp ceiling panel , back right corner of room.
FO-301587	11/14/2014	11/14/2014		4 lights out in the house 7 lights out in the lobby
FO-301657	11/14/2014	11/20/2014		Relamp light fixture in south west corridor to cafeteria.
FO-301760	11/17/2014	11/17/2014		Four Lights out in room 5001. Please call Doris Davis at 73556 if there are any questions.

WO	Recieved	Finished	Total	Request
FO-301844	11/17/2014	11/17/2014		rm. 190.11, 5 lights out in hallway to freight elevator.
FO-302026	11/17/2014	11/20/2014		Need light replaced in Women's Second Floor Bathroom near paper towel holder.
FO-302048	11/18/2014	11/19/2014		REPLACE BLOWN LIGHTS. 3RD FLOOR UNISEX RESTROOM. close out..
FO-302103	11/18/2014	11/20/2014		Relamp corridor Lightfixture across from Blue Lecture Hall
FO-302104	11/18/2014	11/20/2014		Relamp light fixture in secon floor corridor acroos from room2200
FO-302162	11/18/2014	11/20/2014		a whole panel of lights out in room 2117.
FO-302240	11/19/2014	11/20/2014		There are a few lights out in room 1520, there is a blood drive going on, so finish ASAP. lights are on order, by Eugene Owens...
FO-302305	11/19/2014	11/20/2014		Overhead lights. Two bulbs are still burned out, one on the left and one on the right, in the light fixtures closest to the front of the classroom.
FO-302376	11/20/2014	11/20/2014		hanging lite fixture in hall near 487
FO-302447	11/21/2014	11/21/2014		stairway basement to up to balcony (sconces) cell 313 617 1380. This request was canceled by requester.
FO-302456	11/21/2014	11/21/2014		women's restroom 2nd floor - 4 out in inner restroom
FO-302469	11/21/2014	11/24/2014		2 lights in the ceiling of the freezer are burned out. Will need replacements. Thank you, Susan
FO-302496	11/21/2014	11/24/2014		This is the computer lab which also functions as a testing room for students. Second request for this one, on the row of light closest to the clock wall the third light panel is burned out. Also, another light has burned out, third light on the row of l
FO-302506	11/21/2014	11/25/2014		Relamp the following 3rd Fl. South west corridor (2 fixtures) 2nd. Fl. East Corridor between rm.s 2248 and 2238 relamp corridor Fixture.
FO-302756	11/24/2014			there are two lights out in lab 1305. please call 313-974-8716 for lab to be opened.
FO-302776	11/24/2014	11/24/2014		There are three candle lobster lights out on the main floor. please call Raynell for additional information at 72275
FO-302781	11/24/2014	11/24/2014		light flickering heavily in room 169.
FO-302849	11/24/2014			Please replace burned out florescent bulbs in the lab.
FO-302850	11/24/2014			Please replace burned out florescent bulbs in the lab.
FO-302852	11/24/2014			Please replace burned out florescent bulbs in the lab.
FO-302853	11/24/2014			Please replace burned out florescent bulbs in the lab.
FO-302857	11/24/2014			Change 7 burnt out lights in ceiling of pool...Left will be needed. Please see Bob Ostrowski on specs... Please rush. Thank You.
FO-302967	11/25/2014	11/26/2014		Purdy Library, 1st Floor, Reference Area Light lens hanging down: potential safety concern. This task has been taken care of. No problems. Please see Richard at the Check Out desk if additional information is needed. Thank you.
FO-302993	11/25/2014	11/25/2014		Rm. 3144 -Replace 6 burned out light bulbs.
FO-303077	11/26/2014			Relamp two fixtures by vending area
C-Materials			11	
FO-300332	11/3/2014	11/7/2014		Need a large recycle bin on the fifth floor in lab room 508. please call him on his cell at 734-679-8589
FO-300718	11/4/2014	11/4/2014		I'm a lab monitor and we've been missing our large recycling can for about a week now. It was brought to the end of the hall for emptying I assume but is now missing. Thanks
FO-300783	11/4/2014	11/7/2014		Recycle bin pickup and replace in suit 3100.
FO-300919	11/6/2014	11/7/2014		3 large recycling bins on each stairwell need to be picked up/replaced.
FO-300920	11/6/2014	11/7/2014		2nd fl - 2 recycling bins need to be picked up/replaced.
FO-301572	11/14/2014	11/14/2014		Room 1328/1st floor FAB - Large bin is full. Please pick up and replace.
FO-301838	11/17/2014	11/24/2014		Need Two full recycle bins picked up and replaced in room 357.

WO	Recieved	Finished	Total	Request
FO-302165	11/18/2014	11/24/2014		Need two recycle bins in room 357.
FO-302252	11/19/2014	11/24/2014		Need a couple of boxes of D-battery for Hand Santizier for Hand machine
FO-302768	11/24/2014	11/24/2014		Need two recycle bins picked up and replaced in room 3104.
FO-303012	11/25/2014			Please replace the recycling bin in room 711 of the Hudson Webber Cancer Research Center. It is now full.
C-Projects			2	
FO-302946	11/25/2014			Scrub and wax kitchen floor and bathroom floor
FO-303030	11/26/2014			Main corridors, buff and wax main corridor
C-Repair			32	
FO-300324	11/3/2014	11/4/2014		SOAP DISPENSER IS BROKEN. 1ST FLOOR MEN'S RESTROOM NEAR OLD STOCKROOM.
FO-300684	11/4/2014	11/5/2014		paper towel dispenser not working properly- 1st floor unisex restroom located on north/east side of lobby
FO-300711	11/4/2014	11/4/2014		3rd floor ladies room last stall toilet paper dispenser is broken.
FO-300768	11/4/2014	11/5/2014		Paper towel dispenser broke - not rolling out -2cnd floor ladies on southeast corner of the building
FO-300795	11/5/2014	11/5/2014		ADVANCE MICROMAX 20DX FLOOR SCRUBBER SERIAL #O70806144, NO WATER COME OUT. PLEASE REPAIR.
FO-300847	11/5/2014			ADVANCE AUTO SCRUBBER, SERIAL #E254286 THERE A SHORTAGE IN THE SWITCH. PLEASE REPAIR ASAP. SCRUBBER LOCATED IN BASEMENT.
FO-300860	11/5/2014			The sweeper in Law has a damaged on/off switch.
FO-300862	11/5/2014			The sanitaire vacuum in Law has a missing screw to the handle.
FO-300872	11/6/2014	11/6/2014		Please remove & replace the toilet paper dispenser in the men's # 2 stall.
FO-300964	11/6/2014	11/6/2014		Unisex restroom on 2nd floor The soap dispenser is broken.
FO-300979	11/7/2014			Order parts and repair two auto scrubbers for Sec 1 and for Sec 5 by November 17, 2014
FO-301061	11/10/2014	11/10/2014		1ST FLOOR WOMEN'S RESTROOM THE SOAP DISPENSER IS BROKEN. PLEASE REPAIR/REPLACE.
FO-301083	11/10/2014	11/10/2014		There is a broken Towel dispenser on the only 4th floor woman's restroom.
FO-301280	11/11/2014	11/13/2014		Please replace the squeegee & squeegee strap on the Advance convertamatic auto scrubber (s/n 1955713). Located near the NE stairwell in the basement.
FO-301281	11/11/2014			Please replace the damaged power cord on the sector 9 project team Advance Pacesetter 20ts (s/n 3000132216) located in the sector 9 store room.
FO-301282	11/11/2014	11/13/2014		Please replace the pole on the sector 9 project team advance pacesetter 20ts scrubber (s/n 3000132217). located in the sector 9 store room.
FO-301283	11/11/2014	11/13/2014		Please replace the leaking return hose to the squeegee on the sector 9 (student center)advance adfinity AXP 20D auto scrubber (s/n 083023184). located in the sector 9 store room.
FO-301303	11/12/2014			Restroom #105 a small 1 needs a toilet paper dispenser. Also women's restroom on 1st floor needs a paper towel dispenser there 2 women's restroom on the 1st floor.
FO-301313	11/12/2014			There is broken towel dispenser on the first floor men's restroom across from room 169. call Jackie at 72057.
FO-301370	11/12/2014			NEED INK FOR PINTER FROM (FPM/STOCKROOM) (hp15) BLACK INK.
FO-301383	11/12/2014	11/13/2014		Paper towel dispenser is broken.
FO-301527	11/13/2014	11/14/2014		Both soap dispensers at 5454 Cass (Ladies room and kitchen/sink area by Business Services) are not working correctly. Please have someone address.
FO-301592	11/14/2014	11/18/2014		1st floor ladies room 110 soap dispenser attached to the partition is broke
FO-301728	11/15/2014	11/18/2014		Paper towel dispenser is broken in the men restroom on the 3rd floor.
FO-301822	11/17/2014			2cnd floor men's room paper towel dispenser broke
FO-302164	11/18/2014	11/21/2014		soap dispenser is not dispensing in suit 3100.
FO-302314	11/19/2014	11/14/2014		The Vacuum at the field house. The handle is broken and needs to be repaired. Vacuum is a Hoover Commercial Insight 100.
FO-302320	11/20/2014			Sanitaire Vacuum model:sc882,ser#1351000925 needs the body repair and bolt nuts are loose.

WO	Recieved	Finished	Total	Request
FO-302387	11/20/2014			NEEDS TO ORDER SOME AUTO SCRUBBER PARTS FROM (ALLIED-EAGLE SUPPLY CO.) This is part of (FO-300979) AUTHORIZED BY: Marvin, Darby and Sheryl, Lloyd
FO-302389	11/20/2014			NEED TO ORDER SOME PARTS FROM (ALLIED-EAGLE SUPPLY CO.) This is part of (FO-300979) SECTOR # 1 Authorized By: Marvin, Darby and Sheryl, Llody
FO-302490	11/21/2014			The real wheel on the custodial cart in Community Arts is broken and needs to be replaced.
FO-302941	11/25/2014			Please check and repair the sector 9 project team Kent 20" side by side scrubber (011604C1). The unit stopped working while scrubbing a carpet. Also replace the splash skirt.
C-Sector 01			11	
FO-300804	11/5/2014	11/26/2014		lockers dirty in the basement. click on linked documents for picture.
FO-300806	11/5/2014	11/26/2014		Men's room urinals stained, worn and smells bad.click on linked documents for picture.
FO-300809	11/5/2014	11/26/2014		Men's rest roomwall tile and grout stained in basement.
FO-302245	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302246	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302250	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302251	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302253	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302255	11/19/2014	11/24/2014		2 cases of Dial soap
FO-302256	11/19/2014	11/24/2014		6 cases of rags
FO-303058	11/26/2014			Clean carpet in Room 1652 University Advising Center in the Academic Success Center
C-Sector 02			7	
FO-300836	11/5/2014	11/5/2014		Scrub and waxed room 8275 Scott Hall.
FO-300915	11/6/2014	11/6/2014		Scrub and wax labs 8248 and 8252 Scott Hall
FO-300989	11/7/2014	11/7/2014		Scrub and wax lab 8245 in Scott Hall
FO-301116	11/10/2014	11/10/2014		Scrub and wax lab 8214 in Scott Hall
FO-301498	11/13/2014	11/13/2014		Scrub and wax labs 9200,9207 in Scott Hall
FO-302383	11/20/2014	11/19/2014		Scrub and wax office and lab 8271 Scott Hall
FO-302384	11/20/2014	11/19/2014		Scrub and wax lab 9312 Scott Hall
C-Sector 03			13	
FO-300734	11/4/2014	11/5/2014		2 cases of dial soap
FO-300735	11/4/2014	11/5/2014		2 cases of dial soap
FO-300736	11/4/2014	11/5/2014		2 cases of dial soap
FO-300737	11/4/2014	11/5/2014		2 cases of dial soap
FO-300738	11/4/2014	11/5/2014		2 cases of dial soap
FO-300801	11/5/2014	11/6/2014		clean wire mold behind copiers. first floor room 117. click on linked documents for picture.
FO-301081	11/10/2014	11/12/2014		scrape off old stickers at switches. first floor near room 222. look at linked documents for picture.
FO-301270	11/11/2014	11/12/2014		Please clean room 10 in basement for this Thursday, Nov 13th event. Thank you
FO-301271	11/11/2014	11/12/2014		Please clean space at rm 116 (Information Station) for the WSU open house this Thurs, Nov 13th. Thank you
FO-301272	11/11/2014	11/12/2014		Please clean lobby area on 1st flr for the WUS open house on Thurs, Nov 13th. Thank you
FO-301525	11/13/2014	11/14/2014		5 boxes of Gojo soap
FO-301779	11/17/2014	11/20/2014		Clean and Polish concrete floor in basement west side area near room 080. click on linked documents for picture.
FO-302791	11/24/2014	11/26/2014		mold on window sill; multiple locations along window wall. on third floor north exterior wall.
C-Sector 04			4	
FO-300726	11/4/2014	11/5/2014		2 cases of dial soap
FO-300728	11/4/2014	11/5/2014		2 cases of dial soap

WO	Recieved	Finished	Total	Request
FO-300729	11/4/2014	11/5/2014		1 case of dial soap
FO-300732	11/4/2014	11/5/2014		2 cases of dial soap
C-Sector 05			9	
FO-301353	11/12/2014	11/24/2014		3 cases of dial soap
FO-301354	11/12/2014	11/24/2014		3 cases of dial soap
FO-301355	11/12/2014	11/24/2014		3 cases of dial soap
FO-301356	11/12/2014	11/24/2014		2 cases of dial soap
FO-301359	11/12/2014	11/24/2014		3 cases of gojo soap
FO-301360	11/12/2014	11/24/2014		3 cases of dial soap
FO-301361	11/12/2014	11/24/2014		2 boxes of white rags
FO-302257	11/19/2014	11/24/2014		4 cases of Gojo soap
FO-302258	11/19/2014	11/24/2014		2 cases of hand sanitizer
C-Sector 06			6	
FO-300344	11/3/2014	11/11/2014		Stained glass window in North stairwell - underneath the stained glass ON THE OUTSIDE OF THE BUILDING the windows need to be power-washed.
FO-301209	11/11/2014	11/24/2014		The fabric on the benches at the back of room 013 have some large liquid-looking stains. Please have custodial determine if the fabric can be cleaned and share findings with Ruth Jensen, Suite 100, Cohn. Task is complete.
FO-302109	11/18/2014			Carpets in rooms BC and room LM need to be professionally cleaned.
FO-302128	11/18/2014	11/25/2014		Please vacuum Conference Room floor, especially under the table and chairs. Thank you -rm 425, COE task is complete
FO-302130	11/18/2014			Request front entry hallway/foyer and stairwell and on the 1st Floor, Engineering Technology Building to be cleaned, mop and waxed.
FO-302189	11/19/2014			NEED CLEAN UP ON 5TH FLOOR OUTSIDE OF ROOM 586. (LEAK)
C-Sector 07			9	
FO-300803	11/5/2014	11/6/2014		clean door on first floor east side near room 115. click on linked documents for picture.
FO-301782	11/17/2014			Remove gum from terrazzo floor in first floor room 190.14 circulation desk. click on linked documents for picture.
FO-301786	11/17/2014			clan rusty water fountain on second floor. click on linked documents for picture.
FO-301790	11/17/2014			Remove yellow glue on book stacks on second floor outside 240. click on linked documents for picture.
FO-301792	11/17/2014			clean window sills along north wall on second floor. click on linked documents for picture.
FO-301797	11/17/2014	10/6/2014		Remove 2 sided tape between elevators on second floor. click on linked documents to see picture
FO-302788	11/24/2014			clean or replace old faucets. click on linked documents for picture.
FO-302790	11/24/2014			clean terrazzo at bases and around toilets.click on linked documents for picture.
FO-303029	11/25/2014			Wax and seal floor in Room 3103 Old Main.
C-Sector 08			5	
FO-300341	11/3/2014	11/4/2014		Please vacuum grounds office ASAP. Hello Carla I will have my custodian come in and take care this matter 11/04/2014 after that it will be done two times out the week. Ted Williams
FO-300746	11/4/2014	11/4/2014		2 cases of Dial Soap
FO-300747	11/4/2014	11/4/2014		8 cases of Dial Soap
FO-300750	11/4/2014	11/4/2014		8 cases of Gojo soap
FO-301522	11/13/2014	11/13/2014		2 cases of dial soap
C-Sector 09			13	
FO-302207	11/19/2014	11/19/2014		2 cases of dial soap
FO-302209	11/19/2014	11/19/2014		2 cases of dial soap
FO-302210	11/19/2014	11/19/2014		2 cases of dial soap
FO-302211	11/19/2014	11/19/2014		2 cases of dial soap

WO	Recieved	Finished	Total	Request
FO-302212	11/19/2014	11/19/2014		2 cases of dial soap
FO-302213	11/19/2014	11/19/2014		2 cases of dial soap
FO-302214	11/19/2014	11/19/2014		2 cases of dial soap
FO-302215	11/19/2014	11/19/2014		2 cases of dial soap
FO-302216	11/19/2014	11/19/2014		2 cases of dial soap
FO-302217	11/19/2014	11/19/2014		2 cases of dial soap
FO-302218	11/19/2014	11/19/2014		2 cases of dial soap
FO-302219	11/19/2014	11/19/2014		2 cases of dial soap
FO-302220	11/19/2014	11/19/2014		2 cases of dial soap
C-Sector 10			1	
FO-302413	11/20/2014			one case of dial soap
Engineering			803	
Emergency			22	
E - MedPharm			5	
FO-301022	11/7/2014			EMERGENCY ELEC R/R RM 2330.10 ENG HAS CK'D BREAKER BREAKER HAS NO PROBLEM PLS HAVE ELECS' CK WHY R/R CK ALL lights are out in cold room. Please fix as soon as possible.
FO-302075	11/18/2014	11/18/2014		MECH RM 11 WATER LEAKING UNDER DOOR
FO-302114	11/18/2014			RM 9360 CEILING LEAK, AHU# 9 AHU#13 LEAK ,,,,,,,,,, JH/11-18-14 ,,,,,,,,,,
FO-302734	11/24/2014			EMERGENCY ELEC R/R FAP HAS A CODE STATING CARD #19 HAS LOW BASTTERY CASUSING TROUBLE ALARM ACTIVE W/RESET & REPEATING CONSTANTLY
FO-303045	11/26/2014			EMERGENCY KROPF R/R RM 7123/WALK IN COLD RM BOX KEE[S LOOSING POWER AFTER RESETTNG WILL WORK FOR ONLY A COUPLE OF SECONDS
E - North			3	
FO-301317	11/12/2014	11/12/2014		ESS SET FAP ALARM OFF BY ACCIDENT NEED TO RESET IS SNDNG IN PRES' APT
FO-302783	11/24/2014	11/25/2014		EMERGENCY/CARP R/R ENT Handicap DOOR #026 01S PUSH BUTTON/openers are not working on the Purdy side near the Cass entrance.
FO-303027	11/26/2014			EMERGENCY ELEC R/R BLDG FAP FIRE ALARM WILL NOT RESET Completed 11-26-2014 SRP
E - Northeast			2	
FO-302823	11/24/2014	11/24/2014		GENERATOR DOOR HAS BLOWN OPEN & NOW STANDING OPEN AFRAID GENERATOR WILL GET WET DUE TO RAIN
FO-302833	11/24/2014			EMERGENCY ELEC R/R BLDG LOST POWER PLS TROUBLESHOOT
E - Preventative Maintenance			3	
FO-301846	11/17/2014	11/18/2014		STEAM COMING FROM WALL. ROOM 1125.1. Engineer found steam leak before isolation valve inside rm 1125.1. WO transferred to fitters as emergency. Fitters called in. No isolation valves found for leaking steam line. Boilers turned off for repair. ,,,,,,
FO-302308	11/19/2014			UPGRADING TO EMERGENCY DUE TO FOLLOWING 2nd floor men's restroom stall near windows not flushing properly. 11/21/14 LPS: PLEASE NOT TOILET IS NOW STOPPED UP & OVERFLOWING Engineer checked Men's room toilet, flushing valve not working properly, refer
FO-302401	11/20/2014	11/21/2014		FAP FIRE TROUBLE ALARM ACTIVE
E - South			6	
FO-301419	11/13/2014	11/13/2014		FAP FIRE TROUBLE ALARM SNDNG
FO-302045	11/18/2014	11/18/2014		RM 242/246 MELTED PLASTIC SMELL
FO-302744	11/24/2014	11/24/2014		RM 102/AUDITORIUM FIRE DOUR HAS LOCKED DOWN

WO	Recieved	Finished	Total	Request
FO-302746	11/24/2014	11/24/2014		RM 203/BRIDGE DOOR FIRE DOOR HAS LOCKED DOWN
FO-303028	11/26/2014	11/26/2014		FAP FIRE TROUBLE ALARM
FO-303034	11/26/2014	11/26/2014		RM 102/AUDITORIUM FIRE DOOR HAS LOCKED DOWN
E - Southeast			2	
FO-300759	11/4/2014	11/4/2014		RM 2111 OUTLETS NOT WORKING NEAR WINDOW
FO-302738	11/24/2014			FAP FIRE TROUBLE ALARM ACTIVE
E - West			1	
FO-302837	11/24/2014			CALLED SCHINDLER ELEV CO FOR #2 ELEV ENTRAPMENT 4TH FLR REF #45703659
High			221	
E - Auxiliary			38	
FO-300319	11/3/2014	11/4/2014		NO HOT WATER THROUGHOUT BUILDING AND CAFETERIA.
H-48849	11/3/2014	11/20/2014	11/4/2014	Please check the heat in the apartment. The resident reports that heat is not coming out of them. Thanks! Audrey authenticated user: Audrey Cloum - el0476 requester ip address: 141.217.23.191
H-48846	11/3/2014	11/13/2014	11/13/2014	The ceiling right up the kitchen sink is leaking . authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.218
H-48871	11/5/2014	11/5/2014	11/6/2014	Shower doesn't have hot water without the faucet shuddering really noisily. authenticated user: Qamile Qoshja - ez8365 requester ip address: 35.16.193.131
FO-300819	11/5/2014	11/6/2014		HANDICAP DOORS ENTRANCE ARE NOT OPENING. UNIVERSITY PHARMACY - 5254 ANTHONY WAYNE DRIVE.
H-48880	11/5/2014	11/10/2014	11/10/2014	URGENT:The carpet in one of the bedroom is getting wet due to a leak underneath the flooring. Need immediate attention. authenticated user: Lakshmi Mohanadas - fk2967 requester ip address: 141.217.232.156
H-48884	11/5/2014	11/7/2014	11/6/2014	The disposer in the sink, in the kitchen, is clogged. Is leaking under the cabinet. authenticated user: Joice Da Costa Resende - fs4008 requester ip address: 35.16.193.199
H-48901	11/6/2014	11/6/2014	11/6/2014	All of the power in my dining room and kitchen is not working. This has been since last evening around 8pm. It would be wonderful if this could be fixed as soon as possible! Thank you! authenticated user: Rachel Deluca - fq2843 requester ip address: 14
H-48941	11/8/2014	11/10/2014	11/10/2014	the garbage disposal is broken and also leaking from the bottom. authenticated user: Qiuyun Xu - fj2616 requester ip address: 35.16.69.67
H-48948	11/10/2014			URGENT-The heater is not working from friday, the day when the engineers came to check the leak in the flooring due to which the carpet got wet. The wetness in the carpet got dried from the time the heater is not working.authenticated user: Sai Vishnu AI
H-48967	11/10/2014	11/11/2014	11/11/2014	Garbage disposal, sounds like something may be stuck inside. authenticated user: Naijamah Allah - ej2633 requester ip address: 141.217.23.218
H-48984	11/10/2014			Toilet in the first bathroom on right hand continues to not work. This is the FOURTH work order I have placed on the toilet within the last one week. No one was able to fix it. There needs to be a permanent solution. Water level rises way to high and suct
H-48971	11/10/2014	11/12/2014	11/12/2014	toilet water pressure is low, toilet will not flush-URGENT authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.218
H-48987	11/11/2014			I need urgent maintenance for the bathroom ceiling because there is a leaking since four weeks ago.Maintenance guy came and he took off the old ceiling and put a nylon cover as a temporary solution but no one show up since that time (around two weeks ag
FO-301188	11/11/2014	11/11/2014		FIRE TROUBLE ALARM.
H-49006	11/12/2014	11/13/2014	11/17/2014	Leak coming from ceiling (not near the window) in the larger bedroom. authenticated user: Celia Staniak - ev6281 requester ip address: 141.217.23.218

WO	Recieved	Finished	Total	Request
FO-301444	11/13/2014	11/13/2014		fire alarm testing 248-981-9544
H-49022	11/13/2014	11/13/2014	11/17/2014	Stall #1 in the men's bathroom in the lobby is leaking water from somewhere. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.218
H-49027	11/13/2014	11/13/2014	11/13/2014	Garbage disposal is leaking authenticated user: - requester ip address: 141.217.23.218
H-49058	11/16/2014	11/18/2014		Ken Scott (resident) called and said the heat in the room is not working at all. authenticated user: Nailah Hall - ff4867 requester ip address: 141.217.23.241
H-49096	11/18/2014	11/18/2014		The heat in this resident apartment isn't working. It hasn't been working for three weeks now. authenticated user: Danielle Henry - ew4467 requester ip address: 141.217.23.241
H-49128	11/19/2014			Heating unit is not working. authenticated user: Cydney McChesney - em8294 requester ip address: 141.217.23.240
H-49144	11/19/2014	11/20/2014	11/20/2014	Hi, Apartment no. 302 is constantly facing problem of heater which turn on and off according to policy but unable to provide heat to room specially in the hall and sometimes in the bedrooms as well as bathroom. authenticated user: Apurav Patil - fl4162
H-49159	11/20/2014	11/20/2014	11/20/2014	continuous Water leaking from the latrine flushing pipe - Please check it - Thank you !!!! authenticated user: Magesh Muthu - fg6627 requester ip address: 141.217.233.32
H-49166	11/20/2014	11/23/2014		Mechanical check (please rush-room needed for new RA) Thank you! authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.241
H-49167	11/20/2014	11/20/2014	11/20/2014	Please check the heat in the apartment ASAP. The resident reports that it is very cold. Thanks! authenticated user: Audrey Cloum - el0476 requester ip address: 141.217.83.64
H-49185	11/20/2014	11/20/2014	11/24/2014	Thermostat does not work in room 263 (health center connected to DeRoy apartments)- no heat
H-49182	11/20/2014	11/21/2014	11/24/2014	Outlet on south wall in living room is loose. authenticated user: Nailah Hall - ff4867 requester ip address: 141.217.23.241
FO-302400	11/20/2014	11/20/2014		wrong room number was previously entered for FO-302351 office 262 thermostat - digital read is not working, unable to control heat, office is cool.
FO-302438	11/21/2014	11/21/2014		FIRE TROUBLE ALARM.
H-49205	11/21/2014	11/24/2014		Heat not working authenticated user: Navjot Batra - eq5486 requester ip address: 141.217.23.241
H-49206	11/21/2014	11/21/2014		Experiencing hot water problems authenticated user: Navjot Batra - eq5486 requester ip address: 141.217.23.241
H-49210	11/21/2014			Shower and sink are overflowing. Cannot use shower or sink. authenticated user: Justin Yemm - ef4839 requester ip address: 141.217.23.240
H-49218	11/24/2014			The shower head in our bathroom has been leaking constantly for the past week or so. We came back to campus Sunday night and noticed that the floor around the shower was wet, as well as the bath mats, when nobody had showered prior. There is also a pink r
FO-302753	11/24/2014	11/24/2014		CHECK ON POWER, C& IT EQIP IS OUT ALSO PUBLIC SAFETY IS NOT GETTING A READ ON BLDG
H-49260	11/24/2014	11/25/2014		Toilet started flushing by itself and it won't stop authenticated user: Navjot Batra - eq5486 requester ip address: 141.217.232.228
FO-302819	11/24/2014			COG RETAIL SPACE NECT TO SUBWAY BACK DOOR WON'T CLOSE PROPERLY ALARM SOUNDING
H-49262	11/24/2014	11/24/2014		garbage disposal is not working. authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
FO-300328	11/3/2014	11/5/2014		Honeywell: R/R 3RD FLR Please investigate and repair why alarm points 214, 215, 309,310,311, 312,313,314,315,316,317,318,319, and 320 keep going into alarm (Excel 10 online/offline) and is creating thousand's of critical alarms in the Honeywell computer
FO-300743	11/4/2014	11/4/2014		Trade: Controls/Siemens Priority: EMERGENCY R/R Lab 5168 CONTROL INSIDE VAV FOR RM NOT WORKING WILL NOT SHUT-OFF HEATING VALVE CAUSING RM TO OVER HEATING-OR TOO COLD DISTURBING EXPERIMENTS
FO-300748	11/4/2014	11/4/2014		Trade: Controls/Siemens Priority: EMERGENCY R/R Lab 5178 CONTROL INSIDE VAV FOR RM NOT WORKING WILL NOT SHUT-OFF HEATING VALVE CAUSING RM TO OVER HEATING-OR TOO COLD DISTURBING EXPERIMENTS
FO-301226	11/11/2014	11/13/2014		CONTROLS- please r/r FVW and/or actuator. Operation is unreliable. Valve leaks by and causes high water, but valve also does not fully open when calling. found low water condition and valve only partially open. Boiler #2 University Services. BOILER is OOS
FO-301724	11/14/2014	11/18/2014		Controls High:Boiler no.2 has short circuit trips breaker when trying to fire.
FO-301743	11/17/2014	11/18/2014		Adjust sensitivity of level master on Boiler "A". Boiler repeatedly floods.
FO-301754	11/17/2014			R/R RM 1301 REPAIR CONTROL VLV FOR HOT COIL THATS NOT WORKING CAUSING COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-301755	11/17/2014			R/R 1ST FLR CIRC DESK REPLACE T-STAT THATS NOT WORKINGH CAUSING COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-302169	11/18/2014			RM 10303.30 IS TOO COLD PM Engineer investigated. Heat pump 2-64 not communicating with TEC. Work order transferred to Controls on 11/19/14.
FO-302175	11/18/2014			RM 8405.7 TOO COLD PM Engineer attempted to reset heat pump 1-105. Unit did not respond. Transferred to Controls on 11/19.
FO-302424	11/21/2014			HVAC Unit serving auditorium lighting booth is making loud noise. Please check & repair. For access, Please contact, Michael Donahue @ 313-577-0853 There is an even scheduled in auditorium on Friday 11-21-14.
E - MedPharm			71	
FO-300342	11/3/2014	11/3/2014		COLD RM 5520 & 5530 TOO COLD
FO-300399	11/3/2014	11/5/2014		RM 6355 TOO HOT
FO-300401	11/3/2014	11/3/2014		THE SOUND OF RUNNING WATER IS COMING THROUGH WALL. ROOM 2620.
FO-300691	11/4/2014	11/5/2014		LOW TEMP. ALARM. ROOM 200.01.
FO-300714	11/4/2014			BSMNT 411 LOW TEMP
FO-300762	11/4/2014	11/4/2014		Room needs to be warmer. Yucatan pigs housed in this room. Temperature should be between 75-80 degrees. Thank you, Susan
FO-300807	11/5/2014			LAB 200.08 LOW TEMP
FO-300858	11/5/2014			CEILING LEAK. HALLWAY OUTSIDE OF ROOMS 5530 AND 5450.01.
FO-300884	11/6/2014	11/17/2014		LOW TEMP. ROOM 200.08
FO-300890	11/6/2014			RM 200.01/DLAR HAS HI TEMP
FO-300895	11/6/2014	11/17/2014		LOW TEMP. ROOM 400.
FO-300904	11/6/2014	11/17/2014		STRONG RUBBER BURNING SMELL. BASEMENT NEAR ELEVATORS.
FO-301010	11/7/2014	11/7/2014		RM 200.01/DLAR HAS HI TEMP
FO-301011	11/7/2014			RM 200.07/DLAR HAS LOW HUMIDITY
FO-301012	11/7/2014	11/7/2014		RM 7119/DLAR HAS LOW HUMIDITY
FO-301028	11/7/2014	11/17/2014		HIGH TEMP. ALARM. ROOM 4215.
FO-301090	11/10/2014	11/17/2014		HIGH TEMP. ROOM 200.01.
FO-301205	11/11/2014	11/11/2014		RM 3430 CHEMICAL SMELL
FO-301223	11/11/2014	11/11/2014		COLD RM 3212 TOO HOT, EXPERIMENTS GOING ON

WO	Recieved	Finished	Total	Request
FO-301227	11/11/2014			SHIFFMAN 139 FIRE TROUBLE ALARM
FO-301247	11/11/2014	11/25/2014		Whistling sound coming from somewhere in ceiling.
FO-301293	11/11/2014	11/12/2014		Please turn down the air conditioner. The temperature is too high for our chemicals. Need fix ASAP. Thank you!
FO-301311	11/12/2014	11/12/2014		LAB 200.01 HIGH TEMP
FO-301312	11/12/2014	11/14/2014		RM 417 LOW TEMP
FO-301314	11/12/2014	11/20/2014		RM 200.12 & 7119
FO-301315	11/12/2014	11/12/2014		RM 200.08 LOW TEMP
FO-301341	11/12/2014	11/12/2014		RM 229 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301342	11/12/2014	11/12/2014		RM 231 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301344	11/12/2014	11/12/2014		RM 235 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301345	11/12/2014	11/12/2014		RM 236 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301346	11/12/2014	11/12/2014		RM 243 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301347	11/12/2014	11/12/2014		RM 247 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301349	11/12/2014	11/12/2014		RM 249 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANIMALS TO BE AGITATED
FO-301376	11/12/2014			PIPEFITTER: R/R BSMT @ ENTRY WAY OF 400 STE REPAIR/REPLACE 1inch LEAKING HYDRONIC LINE JH/11-13-14
FO-301424	11/13/2014	11/13/2014		RM 0100 STM PRESSURE ALARM
FO-301433	11/13/2014	11/13/2014		RM 4132 & 4134 BLOWN FUSE
FO-301493	11/13/2014	11/17/2014		RM's 200.07 & 200.12 LOW HUMIDITY
FO-301494	11/13/2014	11/17/2014		RM 200.08 LOW TEMP
FO-301495	11/13/2014	11/17/2014		RM 200.01 HIGH TEMP
FO-301563	11/14/2014	11/14/2014		RM 200.01/DLAR HAS A LOW TEMP ALARM
FO-301603	11/14/2014			CEILING LEAK. HALLWAY OUTSIDE OF ROOM 5530.
FO-301813	11/17/2014	11/20/2014		LOW HUMIDITY IN ROOMS 200.05, 7119, & 412.
FO-301814	11/17/2014	11/20/2014		HIGH HUMIDITY IN ROOM 200.01.
FO-301827	11/17/2014	11/17/2014		BSMT N.W. QUADRANT HAS A BURNING RUBBER SMELL
FO-302030	11/18/2014	11/18/2014		AIR HANDLER #3 HIGH TEMP. DISCHARGE ALARM.
FO-302033	11/18/2014	11/18/2014		LOW HUMIDITY IN ROOM 5341.
FO-302038	11/18/2014	11/20/2014		FIRE PANEL BUZZING. GUARD'S DESK.
FO-302058	11/18/2014	11/20/2014		ANIMAL RM'S 200 & 400 STE's LOW HUMIDITY RM 7119 LOW HUMIDITY
FO-302059	11/18/2014	11/20/2014		RM 200.01 HIGH TEMP
FO-302062	11/18/2014			LOUD BUZZING NOISE COMING FROM ROOM 212.07.
FO-302068	11/18/2014			1ST FL CIRCULATION AREA/ 2ND FL 232 TOO COLD
FO-302106	11/18/2014	11/18/2014		RM 464 BLOWN FUSE
FO-302119	11/18/2014	11/18/2014		1ST FL/ LAB 100 TOO COLD
FO-302142	11/18/2014	11/18/2014		RM 200.01/DLAR HAS HI TEMP ALARM
FO-302146	11/18/2014	11/20/2014		HIGH TEMP. ALARM. ROOM 200.01.
FO-302228	11/19/2014	11/19/2014		BLOWN FUSE. ROOM 464.
FO-302282	11/19/2014	11/19/2014		RM 239 TOO COLD, AIR PRESSURE IS POSITIVE SHOULD BE NEGATIVE
FO-302289	11/19/2014	11/19/2014		RM 0305 THE GAS STERILIZER IS IN ERROR STATING THAT THE COMPRESSED AIR IS IN SOMETHING OF A EVAC
FO-302323	11/20/2014	11/20/2014		TOO COLD. ROOMS 231, 235, 239, 241 & 247. (ALL ANIMAL ROOMS)
FO-302378	11/20/2014	11/20/2014		LOW HUMIDITY RM 200.06, 200.12, 200.07 ,7119, 200.03

WO	Recieved	Finished	Total	Request
FO-302379	11/20/2014			RM 200.01 & 7119 HIGH TEMP
FO-302428	11/21/2014			TEMPERATURE ALARM. ROOM 4465.
FO-302459	11/21/2014	11/21/2014		RM 4445 HAS LOW HUMIDTY
FO-302460	11/21/2014	11/21/2014		RM 5449 HAS LOW HUMIDTY
FO-302462	11/21/2014	11/21/2014		RM 5451 HAS LOW HUMIDTY
FO-302463	11/21/2014	11/21/2014		RM 5453 HAS LOW HUMIDTY
FO-302464	11/21/2014	11/21/2014		RM 5455 HAS LOW HUMIDTY
FO-302489	11/21/2014			Fume hood is not drawing enough air.
FO-302785	11/24/2014			TOO COLD AND DOOR MAKES WHISTLING SOUND WHEN CLOSING (AIR PRESSURE. ROOM 0239.
FO-302818	11/24/2014			HIGH TEMP. ALARM. ROOM 6353.
FO-302953	11/25/2014			ALARM SOUNDING. ROOM 2602.
E - North			15	
FO-300362	11/3/2014	11/3/2014		BSMT CHEMICAL RM SEWAGE PUMP IS IN ALARM
FO-300815	11/5/2014	11/5/2014		LOW BATTERY ALARM/POWER FAIL. ROOM 4221.
FO-301025	11/7/2014	11/7/2014		RM 214? COOLER RM HAS A HI TEMP ALARM
FO-301319	11/12/2014	11/12/2014		FIRE TROUBLE ALARM (COMMUNITY ARTS AND PRESIDENT'S APT.)
FO-301322	11/12/2014	11/12/2014		FIRE TROUBLE ALARM (COMMUNITY ARTS AND PRESIDENT'S APT.)
FO-301617	11/14/2014	11/14/2014		FAP FIRE TROUBLE ALARM ACTIVE
FO-301754	11/17/2014			R/R RM 1301 REPAIR CONTROL VLV FOR HOT COIL THATS NOT WORKING CAUSING COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-301755	11/17/2014			R/R 1ST FLR CIRC DESK REPLACE T-STAT THATS NOT WORKINGH CAUSING COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-301801	11/17/2014	11/18/2014		1ST FLR STUDY RMS HAS COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-301802	11/17/2014	11/17/2014		2ND FLR STUDY RMS HAS COLD DAMP AIR BLOWING OVER OCCUPANTS DESK
FO-302066	11/18/2014	11/18/2014		RM 171 TOO COLD, AIR BLOWING PLEASE SEE DONNA
FO-302121	11/18/2014	11/18/2014		STRONG BURNING SMELL ON THE 3RD FLOOR WEST SIDE OF BUILDING.
FO-302479	11/21/2014			EINSTEIN BRO EXPRESS CART, BREAKER TRIPPED
FO-302749	11/24/2014	11/24/2014		NEAR ADMISSIONS OFF EINSTEIN EXPRESS CART OUTLET NOT WORKING
FO-303044	11/26/2014	11/26/2014		KITCHEN STEAMER NOT WORKING, EVENT TOMORROW FOR THE PRESIDENT
E - Northeast			6	
FO-301343	11/12/2014			REPAIR SMOKE DETECTOR 1ST FLOOR (PUBLIC SAFETY CALLED IN FIRE ALARM) Completed 11-14-2014 SRP
FO-301768	11/17/2014	11/17/2014		RM 4305 WALL OUTLETS HAVE NO POWER
FO-301769	11/17/2014	11/17/2014		WALL OUTLET IS NOT WORKING. ROOM 4303. (ENTER THROUGH ROOM 4300)
FO-301817	11/17/2014	11/17/2014		NO POWER IN ROOM 404.
FO-302102	11/18/2014	11/18/2014		1ST FL COPPER PIPE NEEDS REPAIR, FROZEN PIPE 1ST FL RADIATOR BUSTED, WATER SHOOTING OUT ,,,,,,,,,,,,,, EA/11-18-14 ,,,,,,,,,,,,,,
FO-302191	11/19/2014	11/19/2014		TEMPERATURE ALARMS IN DISPATCH ROOM.
E - Preventative Maintenance			48	
FO-300411	11/3/2014	11/4/2014		LAB 417 & 7119 LOW HUMIDITY
FO-300413	11/3/2014	11/4/2014		RM 1200 TOO HOT
FO-300414	11/3/2014	11/3/2014		FIRE TROUBLE ALARM
FO-300957	11/6/2014	11/7/2014		NEED AIR TURNED ON EVENT TODAY
FO-300958	11/6/2014	11/7/2014		1ST FL LADIES RM HANDICAP STALL PLUGGED EVENT TODAY
FO-300959	11/6/2014			Active ceiling leak - Drywall damaged . Water is not pouring in but you can hear a steady dripping above ceiling. I may be a steam leak on second floor 2009 Science Hall causing it ,,,,,,,,,,,,,,,,, ME/11-7-14 ,,,,,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-300967	11/6/2014			RM 1631 LEAK COMING THROUGH LIGHT FIXTURE. Engineer investigated. Found leaking heating control valve. Transferred to Fitters for replacement.,,,,,,,,,,,,,, JH/11-7-14 ,,,,,,,,,,,,,,
FO-301040	11/7/2014	11/8/2014		NO POWER IN WALL OUTLETS. ROOM 1107.
FO-301041	11/7/2014	11/8/2014		ALARM SOUNDING IN MECHANICAL ROOM.
FO-301045	11/7/2014	11/7/2014		FAP FIRE TROUBLE ALARM W/RESET
FO-301106	11/10/2014	11/11/2014		LAB 3530 TOO HOT
FO-301155	11/10/2014	11/11/2014		BSMNT STUDIO O LEAK FROM VENTILATION SYSTEM
FO-301157	11/10/2014	11/12/2014		FIRE TROUBLE ALARM Engineer found same fire alarm trouble related to gas detection system-ongoing problem for last month. Work order transferred to electricians. Completed 11-11-2014 SRP
FO-301159	11/10/2014	11/13/2014		FIRE TROUBLE ALARM. Engineer found ground fault. Trouble acknowledged. Work order transferred to electricians. Completed 11-12-2014 SRP
FO-301160	11/10/2014	11/10/2014		FIRE TROUBLE ALARM
FO-301172	11/10/2014	11/11/2014		RM 3234 GAS SMELL
FO-301267	11/11/2014	11/12/2014		WEST STAIRWELL DOOR ALARM. 5TH FLOOR.
FO-301389	11/12/2014	11/13/2014		RM 229 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANINALS TO BE AGITATED
FO-301390	11/12/2014	11/13/2014		RM 231 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANINALS TO BE AGITATED
FO-301391	11/12/2014	11/13/2014		RM 235 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANINALS TO BE AGITATED
FO-301392	11/12/2014	11/13/2014		RM 243 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANINALS TO BE AGITATED
FO-301393	11/12/2014	11/13/2014		RM 249 HAS POSITIVE/NEGATIVE AIR PRESSURE IN RM CAUSING DOOR NOT TO CLOSE & IF PRESSED TO CLOSE IT WHISTLES CAUSING ANINALS TO BE AGITATED
FO-301394	11/12/2014	11/13/2014		RM 239 IS TOO COLD POST OP OCCUPANTS ARE BEING PUT INTO RM NOW
FO-301404	11/12/2014		11/13/2014	HALLWAY OUTSIDE 6306 LOSS POWER
FO-301406	11/12/2014	11/13/2014		LAB 435 TOO COLD
FO-301530	11/13/2014			Shower is leaking onto the floor in the NE corner hallway. There is a trashcan collecting the water. ,,,,,,,,,,,,,, MM/11-17-14 ,,,,,,,,,,,,,,
FO-301722	11/14/2014	11/15/2014		IN THE TELEVISION STUDIO AREA (BEHIND GOLD DOORS) THE HTG UNIT WHEN IS ON MAKES A HORRIBLE SQUEELING NOISE
FO-301839	11/17/2014	11/17/2014		Low Humidity
FO-301840	11/17/2014	11/17/2014		Low humidity
FO-301836	11/17/2014		11/18/2014	IN BSMT LOWER LEVEL MENS RR HALLWAY LEADING TO RR WATER COMING FROM UNDERNEATH MECH RM DOOR
FO-301837	11/17/2014	11/18/2014		SOFTBALL FIELD BLDG LOST POWER IN THE FRONT
FO-301842	11/17/2014		11/18/2014	RM 200.01/DLAR HI TEMP ALARM
FO-301849	11/17/2014	11/18/2014		FAUCET IS CONTINUOUSLY RUNNING. BASEMENT WOMEN'S RESTROOM. ,,,,,,,,,,,,,, MM/11-18-14 ,,,,,,,,,,,,,,
FO-301854	11/17/2014			IN BSMT LOWER LEVEL MENS RR HALLWAY LEADING TO RR WATER COMING FROM UNDERNEATH MECH RM DOOR
FO-301856	11/17/2014	11/18/2014		FIRE TROUBLE ALARM.
FO-302169	11/18/2014			RM 10303.30 IS TOO COLD PM Engineer investigated. Heat pump 2-64 not communicating with TEC. Work order transferred to Controls on 11/19/14.

WO	Recieved	Finished	Total	Request
FO-302175	11/18/2014			RM 8405.7 TOO COLD PM Engineer attempted to reset heat pump 1-105. Unit did not respond. Transferred to Controls on 11/19.
FO-302299	11/19/2014	11/20/2014		RM 0235 HAS LOW TEMP
FO-302301	11/19/2014	11/20/2014		RM 0239 HAS LOW TEMP
FO-302302	11/19/2014	11/20/2014		RM 0243 HAS LOW TEMP
FO-302304	11/19/2014	11/20/2014		RM 0247 HAS LOW TEMP
FO-302316	11/19/2014	11/20/2014		1ST FL RADIATOR BURST IN ATRIUM, WATER SHOOTING OUT Engineer reported vestibule HW finned tube at main entry froze & split. Finned tube supply isolated. Doors left open to allow building air to provide some heat to vestibule. The 2nd finned tube hea
FO-302400	11/20/2014	11/20/2014		wrong room number was previously entered for FO-302351 office 262 thermostat - digital read is not working, unable to control heat, office is cool.
FO-302404	11/20/2014	11/20/2014		DISPATCH RM HIGH TEMP ALARM, TOO HOT
FO-302417	11/20/2014	11/21/2014		BSMNT AUDITORIUM GAS SMELL
FO-302499	11/21/2014	11/22/2014		SHIFFMAN LIBRARY FIRE TROUBLE ALARM
FO-302862	11/24/2014	11/25/2014		RM 6353 HAS A HI TEMP ALARM (WALK IN COLD RM BOX)
FO-302866	11/24/2014	11/25/2014		ALARM SOUNDING
E - South			17	
FO-300384	11/3/2014	11/3/2014		BSMT TUNNEL LEADING TO CHEM BLDG DOOR IS IN ALARM
FO-300400	11/3/2014	11/5/2014		room 0231 is running hot. room should be kept around 60-70 degrees
FO-300821	11/5/2014	11/5/2014		SOUTH ENTRANCE SLIDING DOORS ARE NOT OPERATING.
FO-300838	11/5/2014	11/6/2014		RM 0070/LAB SUPPLEMENTAL ACU STOPPED WORKING
FO-300852	11/5/2014	11/6/2014		strong sewer gas smell in basement
FO-301192	11/11/2014	11/11/2014		Room 0231 is running very hot at 83 degrees. This room should be kept at 70 degrees or lower to store food and bedding.
FO-301350	11/12/2014	11/12/2014		BSMNT TUNNEL DOOR ALARM SOUNDING LEADING TO CHEMISTRY
FO-301451	11/13/2014	11/19/2014		RM 125 IS TOO COLD ALSO THE HIGHER T-STAT IS WATER FLOWS OUT OF IT
FO-302131	11/18/2014	11/19/2014		RM 1109 HAS A CLNG LEAK
FO-302380	11/20/2014	11/20/2014		RM 169 TOO COLD
FO-302477	11/21/2014	11/21/2014		DISTILLED WATER COMING OUT LIKE TAP WATER
FO-302478	11/21/2014	11/21/2014		DISTILLED WATER COMING OUT LIKE TAP WATER
FO-302480	11/21/2014	11/21/2014		GAS SMELL 1ST FL NEAR ELEV
FO-302731	11/24/2014	11/24/2014		PLEASE REPAIR DOOR LOCK. DOOR WON'T OPEN WITH KEY. ROOM 1242.
FO-302945	11/24/2014			Just outside of the doors to 3210 are three ceiling tiles that are wet/sagging on two. One of them has a smoke detector in its center. Would like the cause checked and the tiles replaced.
FO-303048	11/26/2014	11/26/2014		RECEIVING RM PLEASE CHECK COMPRESSOR, MAKING A STRANGE NOISE. SEE LOUISE
FO-303065	11/26/2014			MOTOR NEEDS REPLACING ON UNIT HEATER RM 1355 HEATING FAN NOT WORKING
E - Southeast			11	
FO-300371	11/3/2014	11/3/2014		2ND FLR LADIES RR HAS A SEWER GAS SMELL
FO-301200	11/11/2014	11/11/2014		WALL OUTLETS ARE NOT WORKING. ROOM 3207.
FO-301243	11/11/2014	11/11/2014		FIRE ALARM
FO-301348	11/12/2014			FIRE TROUBLE ALARM, CLEAN SMOKE DETECTOR Completed 11-14-2014 SRP
FO-301759	11/17/2014	11/17/2014		7TH FLR OUTSIDE OF RM 7206 CLNG IS LKNG
FO-302221	11/19/2014			RM 101.2 HAS A CLNG LEAK (believe its from the radiator above)
FO-302284	11/19/2014	11/19/2014		12TH FL DOOR ALARM NEAR ELEV IS SOUNDING
FO-302453	11/21/2014	11/21/2014		NO POWER RM 2155 OFFICES WITHIN AFFECTED 255.1 & 255.2

WO	Recieved	Finished	Total	Request
FO-302487	11/21/2014	11/21/2014		STANDING WATER INSIDE AND OUTSIDE OF THE 1ST FLOOR CUSTODIAL CLOSET. LOBBY.
FO-302732	11/24/2014			CEILING LEAK. 3RD FLOOR STAIRWELL F.
FO-302808	11/24/2014			FIRE TROUBLE ALARM.
E - West			4	
FO-300829	11/5/2014	11/5/2014		SEWAR GAS SMELL. 2ND FLOOR WOMEN'S RESTROOM.
FO-301573	11/14/2014	11/17/2014		1ST FLR HOT WTR TK THAT'S LOCATED IN THE TRAINNING RM WENT OUT
FO-301608	11/14/2014	11/14/2014		PRESS BOX @ STADIUM LOST HOT WATER
FO-301806	11/17/2014	11/20/2014		NO POWER IN WALL OUTLETS. ROOM 461.
Medium			261	
E - Auxiliary			27	
H-48845	11/3/2014	11/5/2014	11/5/2014	Vent in room is blowing out cold air instead of hot air. authenticated user: Erica Vanhook - eh4498 requester ip address: 35.16.73.206
H-48879	11/4/2014	11/5/2014	11/12/2014	Kitchen sink handle broken.
H-48861	11/4/2014			Faucet in bathroom is continuously running. It's not a full force run, but not just a drip either. authenticated user: Cydney McChesney - em8294 requester ip address: 141.217.23.203
H-48882	11/5/2014	11/5/2014	11/5/2014	No heat in the clinic waiting room. authenticated user: Celia Staniak - ev6281 requester ip address: 141.217.23.218
FO-300901	11/6/2014	11/10/2014		TOO HOT. ROOMS 120, 127 & 129
FO-300903	11/6/2014	11/7/2014		TOO COLD. ROOM 157.
H-48909	11/7/2014	11/7/2014	11/7/2014	The light switch that should turn on the light in my kitchen stopped working. I tried replacing the light bulb, but this did not work. The switch feels different than it did when it worked. authenticated user: Daniel Warren - fk4713 requester ip address
H-48944	11/10/2014	11/10/2014	11/10/2014	The shower handle fell down. authenticated user: Sai Vishnu Aluru - fl8666 requester ip address: 141.217.23.218
H-48969	11/10/2014	11/11/2014	11/11/2014	All power outlets in the kitchen do not work any more. Oven and refrigerator work OK. authenticated user: Hao Song - ei9668 requester ip address: 141.217.233.141
H-48985	11/10/2014			problem with sink grinder, heater is not working properly. authenticated user: Naveen Rajkumar - fs1514 requester ip address: 141.217.177.211
H-48981	11/11/2014	11/12/2014	11/12/2014	The faucet in our bathroom constantly runs. It is annoying and I think that it is causing lowered pressure in our toilet. authenticated user: Tiara Jackson - eg9008 requester ip address: 141.217.233.200
FO-301210	11/11/2014			FREIGHT ELEVATOR 8492 IS NOT WORKING. BELIEVED TO BE STUCK ON THE 6TH FLOOR. SCHINDLER ELEVATOR REFERENCE #45509478.
H-49023	11/13/2014	11/13/2014	11/13/2014	Garbage disposal is not working. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.218
FO-301610	11/14/2014	11/14/2014		5TH FL TOO COLD
FO-301761	11/17/2014	11/17/2014		RM 470 IS EXTREMELY COLD
H-49084	11/17/2014	11/27/2014		Please look at the shower the residents/RA reports having difficulty turning it on. Thanks! authenticated user: Audrey Cloum - el0476 requester ip address: 141.217.23.215
FO-302060	11/18/2014	11/20/2014		ENTIRE 5TH FLR IS EXTREMELY COLD
H-49129	11/19/2014			Heater is not working at all. Room is fridgid. authenticated user: Carly Malburg - fh1228 requester ip address: 141.217.23.203
H-49187	11/20/2014			Heating unit is not working. Unit is blowing out cold air. authenticated user: Yang Liu - fk1379 requester ip address: 35.16.105.85
H-49200	11/21/2014			heat not getting hot enough in Ghafari CD apartment

WO	Recieved	Finished	Total	Request
H-49208	11/21/2014			The shower is leaking and getting water on the bathroom floor. authenticated user: Justin Yemm - ef4839 requester ip address: 141.217.23.240
H-49204	11/21/2014	11/21/2014	11/21/2014	The kitchen is out of power. authenticated user: Ruoyun Pang - fk1751 requester ip address: 35.16.70.61
H-49209	11/21/2014	11/26/2014		The heat in the room is not working. Residents shut the heat off for a few minutes and turned it back on, but it was still not working. authenticated user: Justin Yemm - ef4839 requester ip address: 35.16.193.5
H-49214	11/21/2014	11/24/2014		Resident states that the heat is working fine in the living room and kitchen area, but the individual rooms have little or no heat going to them. authenticated user: Christina Wong - el0587 requester ip address: 141.217.23.193
H-49268	11/25/2014	11/25/2014		Toilet is not flushing. authenticated user: Joseph Gerow - fb1093 requester ip address: 141.217.233.129
H-49282	11/25/2014	11/29/2014		Thermostat only blows cold air; no heat. authenticated user: Shon Johnson - eq9546 requester ip address: 35.16.196.39
H-49288	11/26/2014	11/27/2014		The water is dripping from the faucet. authenticated user: Renee Brown - ez9158 requester ip address: 141.217.23.210
E - Command Center			27	
FO-300396	11/3/2014	11/7/2014		The boiler water level sensors on #1 and #3 boilers are not working properly. #1 boiler is especially a problem. #3 boiler is troublesome but will start if you blow down the water column or hit it
FO-300698	11/4/2014	11/10/2014		The face/bypass dampers for AHU-2 are open to the coil and not moving. They should move to help maintain the discharge air set-point which is 68 degrees. Siemens is showing them as "NONE & 0.00 pct" and we have a discharge temp of 87.28 degrees.
FO-300905	11/6/2014	11/21/2014		Command Center-Please repair #1 rooftop; No heat. It appears relay or safety holding out.
FO-300906	11/6/2014	11/19/2014		Command Center-Please repair #4 rooftop. No heat.
FO-301005	11/7/2014	11/24/2014		RTU # 2 will not run gas valve is not opening to unit. Please inspect., EA/11-24-14
FO-301231	11/11/2014	11/13/2014		CONTROLS- please investigate vibration when boiler fires. Purge sounds OK. so I don't believe it's the blower. When gas valve opens there seems to be excessive vibration.
FO-301483	11/13/2014	11/19/2014		Please have the refrigeration crew change the schedule on all fans and pumps to start them one hour earlier in the morning. Customers complaining too cold.
FO-301488	11/13/2014			Trade: Controls Priority: High Please repair AHU 1. Fan tripping on low temperature. Steam valve not responding properly. See graph sent via email.
FO-301517	11/13/2014			RM 10303.3 IS TOO COLD Engineer checked. Heat pump #2-64 has no communication from thermostat to the TEC controller. Possibly bad stat. Engineer unable to access stat due to locked stat cover. Work Order transferred to Command Center.
FO-301548	11/14/2014	11/17/2014		Honeywell: This morning the computer showed 2443 critical alarms, all Excel ON/OFF line. Please repair. High Priority.
FO-301564	11/14/2014	11/14/2014		SLEDGE/ REFER: R/R PENTHOUSE Please replace SCANNER TUBE on penthouse boiler. HIGH
FO-301574	11/14/2014	11/18/2014		PENTHOUSE: AHU# 4 DAMPERS WON'T CLOSE, UNIT IS OFF
FO-302355	11/17/2014	11/20/2014		Boiler #1 will not light off - Sensor not found error on levelmaster
FO-301757	11/17/2014	11/18/2014		tempered water pumps, #5 and # 6 supply chilled water in summer, heating hot water in winter, a frequency drive normally maintains system pressure, when in "auto" will not ramp pump speed up, running in "bypass" located in Purdy machine room
FO-301777	11/17/2014			R/R RM 235 REPAIR HTG/CLNG UNIT FOR RM 235 WILL ONLY WORK ON CLNG NOT HTG CAUSING RM TP BE TOO COLD
FO-301781	11/17/2014			AIR HANDLER UNIT #1 FREEZE STAT KEEPS TRIPPING OUT. SEE ENGINEER FOR DETAILS.

WO	Recieved	Finished	Total	Request
FO-301795	11/17/2014			Rm#150 - Conf Rm- supplemental furnace not firing. Please investigate.
FO-301809	11/17/2014	11/20/2014		Adjust air flow switch on Boiler "D". Will not fire.
FO-301819	11/17/2014			TOO COLD. ROOM 189.
FO-301833	11/17/2014	11/18/2014		R/R BLDG AHU #3 WILL NOT START SUSPECT FREEZE STAT
FO-301850	11/17/2014			TOO HOT. ROOM 2337.
				PM Engineer found room temp 80°F. Stat is set at 72°F. When changed to day mode, setpoint changed by 1°F. Transferred to Controls to check TEC programming.
FO-302202	11/19/2014			Trade: Command Center Priority: High R/R RM 00018/MECH RM AHU 4 (Animal Quarters) fan is tripping on freeze stat. Please repair/adjust controls. F/B dampers appear to be hunting. Graph sent by email.
FO-302237	11/19/2014	11/21/2014		Command Center-Please repair #2 rooftop. Intermittent heat - going out on limits?
FO-302283	11/19/2014	11/20/2014		Please move T-Stat back into AD's office.
FO-302352	11/20/2014			Command Center-Please repair #3 rooftop. Found off @ disconnect 11/19?
FO-302416	11/20/2014			071-RM 8405.5 TOO COLD
				Transferred to Command Center. Please reference FO-312175 in which PM Engineer attempted to reset heat pump 1-105. Unit did not respond.
FO-302990	11/25/2014			CONTROLS please troubleshoot control related issues with operation of Boiler #2. Boiler in auto/remote and does not appear to acknowledge preferred instrument. preferred instr. not calling for boiler and boiler remains on, etc.
E - MedPharm			40	
FO-300333	11/3/2014	11/3/2014		TOO HOT. ROOM 1328.
FO-300343	11/3/2014	11/5/2014		TOO WARM. ROOMS 2258, 2228, 2106, 2116, 2136, 2135, 2125 & 2115.
FO-300360	11/3/2014	11/5/2014		RM 1328 IS EXTREMELY TOO HOT. HEAT IS POURING OUT OF PERIMETER VENTS
FO-300696	11/4/2014	11/5/2014		Replace oil in air compressors
FO-300708	11/4/2014			RM 1230 TOO COLD
FO-300918	11/6/2014	11/6/2014		RM 2136 IS TOO COLD
FO-301129	11/10/2014	11/10/2014		STRANGE SMELL. ROOM 3430.
FO-301203	11/11/2014			Please inspect the fume hood located in this room. It is running at 147 FPM so it is likely not a clogged filter since that would restrict airflow. Researcher would like to begin using it again.
FO-301291	11/11/2014	11/12/2014		please turn off the heat or turn on air conditioner, the room is too hot
FO-301330	11/12/2014	11/20/2014		NO HEAT. ROOM 1281.
FO-301358	11/12/2014	11/12/2014		DOOR ALARM. ROOM 2490.
FO-301443	11/13/2014	11/13/2014		RM 324 IS TOO COLD
FO-301474	11/13/2014			RM 520 TOO COLD
FO-301500	11/13/2014			RM 4263 IS TOO COLD (not the cold rm)
FO-301501	11/13/2014			INSIDE RM 4263 - RM 4265 IS TOO COLD (not the cold rm)
FO-301502	11/13/2014			INSIDE RM 4263 - RM 4267 IS TOO COLD (not the cold rm)
FO-301568	11/14/2014	11/14/2014		TOO HOT. ROOM 4545.
FO-301586	11/14/2014			TOO COLD. ROOMS 102 AND 108.
FO-301620	11/14/2014	11/14/2014		RM 4545 IS TOO COLD NOW
FO-301641	11/14/2014	11/14/2014		DOCK BAY AREA ENTRY DOOR TO HALLWAY HAS A CLNG LEAK
FO-301646	11/14/2014			RM 0225 HAS A CLNG LEAK
FO-301778	11/17/2014	11/17/2014		BLUE LECT HALL IS TOO HOT
FO-301787	11/17/2014	11/18/2014		TOO HOT. ROOM 0540.
FO-302061	11/18/2014			Please repair brackets Ceiling tile is bulging and about to fall.
FO-302100	11/18/2014	11/18/2014		RM 2105 IS STILL TOO COLD
FO-302115	11/18/2014	11/19/2014		Kitchen/copy Rm. 2614. Please check for possible low power in wall outlet. Microwave works off and on.

WO	Recieved	Finished	Total	Request
FO-302150	11/18/2014	11/18/2014		TOO COLD. 4TH FLOOR ANIMAL ROOMS.
FO-302226	11/19/2014	11/19/2014		TOO COLD. ROOM 2190.
FO-302234	11/19/2014	11/19/2014		TOO COLD. ROOM 520.
FO-302235	11/19/2014	11/19/2014		LOW HUMIDITY. ROOM 520.
FO-302269	11/19/2014	11/19/2014		TOO HOT. ROOM 521.
FO-302347	11/20/2014			SINK LEAKING ROOMS 5324 AND 5344. SEE ENGINEER FOR MORE DETAILS. (MULTI-TASK),,,,,,,,,,,,, MM/11-24-14 ,,,,,,,,,,,,,,
FO-302349	11/20/2014			TOO HOT. ROOM 8252.
FO-302364	11/20/2014			INNER & OUTER LOBBY IS TOO COLD PLS TURN ON HEAT
FO-302465	11/21/2014			RM 5245 TOO COLD
FO-302474	11/21/2014			RM 109 COLD AIR IS BLOWING DOWN ON OCCUPANT
FO-302772	11/24/2014	11/25/2014		RM 313 TOO HOT
FO-302780	11/24/2014			RM 315 TOO HOT
FO-302789	11/24/2014			RM 6111 TOO HOT
FO-302998	11/25/2014	11/26/2014		RM 2190 IS TOO COLD
E - North			25	
FO-300357	11/3/2014	11/3/2014		<p>Purdy Library, 2nd Floor, Room 231</p> <p>Staff in office suite reported area being rather cold.</p> <p>Please adjust the temperature.</p> <p>Thank you.</p>
FO-300392	11/3/2014	11/3/2014		<p>For the past two weeks or so, my office has been very warm.</p> <p>The thermostat does not seem to be responding like it used to.</p> <p>Please fix or at least stop the warm air from pumping into my office.</p> <p>Thanks,</p>
FO-300752	11/4/2014	11/4/2014		<p>Office is really warm again.</p> <p>After I submitted a WO yesterday, my office was back to normal and blowing cold air (good!).</p> <p>Since I got back into the office this morning, my office has reverted back to pumping in hot air (bad).</p> <p>Thank you for</p>
FO-300845	11/5/2014	11/5/2014		<p>Purdy Library, 4th Floor, Room 446</p> <p>Staff reported area being too warm.</p> <p>Please adjust the temperature.</p> <p>Thank you.</p>
FO-300851	11/5/2014	11/5/2014		several outlets are out in the following rooms: 1247, 1248, and 1251. Please inspect and repair.
FO-300945	11/6/2014	11/6/2014		RM 421 IS TOO HOT
FO-301001	11/7/2014	11/7/2014		RM 10 IS EXTREMELY HOT
FO-301002	11/7/2014	11/7/2014		RM 30 IS EXTREMELY HOT
FO-301310	11/12/2014	11/12/2014		RM 321 IS TOO COLD
FO-301479	11/13/2014			BLDG TOO COLD
FO-301497	11/13/2014	11/13/2014		RM 315 TOO COLD
FO-301613	11/14/2014	11/14/2014		<p>There is a faculty training session going on in this room. They are saying the air went on and it's getting cold in the room. They would like the temperature adjusted.</p> <p>Thank you.</p>
FO-301819	11/17/2014			TOO COLD. ROOM 189.

WO	Recieved	Finished	Total	Request
FO-302065	11/18/2014	11/18/2014		RM 105 IS TOO COLD
FO-302110	11/18/2014	11/18/2014		Office 321 Cohn has been extremely cold - 66 degrees. Only warms slightly when door to hallway is opened. Please report findings to Ruth Jensen in the Dean's suite.
FO-302135	11/18/2014	11/18/2014		Please adjust temperature. It is cold in this office suite. The air conditioners are running constantly. Thank you.
FO-302148	11/18/2014	11/18/2014		RM 2119 IS TOO COLD
FO-302208	11/19/2014	11/19/2014		ENTIRE BLDG NO HEAT
FO-302248	11/19/2014	11/19/2014		RM 2074 IS STILL TOO COLD
FO-302249	11/19/2014	11/19/2014		AUDITORIUM TOO COLD
FO-302310	11/19/2014	11/20/2014		RM 2074 IS STILL TOO COLD (AGAIN)
FO-302332	11/20/2014	11/20/2014		TOO COLD. ROOM 1001.
FO-302374	11/20/2014	11/20/2014		TOO COLD. ROOM 1179.
FO-302415	11/20/2014	11/20/2014		FAB RM 2074 TOO COLD
FO-302475	11/21/2014	11/21/2014		BSMNT EMPLOYEE LOCKER RM STRONG SEWAGE SMELL
E - Northeast			26	
FO-300350	11/3/2014	11/3/2014		Our building is cold today. Please warm it up for us.
FO-300721	11/4/2014	11/4/2014		RM 100/SEC OFC IS TOO HOT
FO-300837	11/5/2014			MAIL RM AREA SURROUNDING BASEBOARD HTG UNITS AREN'T ON COLD
FO-300841	11/5/2014	11/5/2014		RM 100 IS TOO COLD FEELS LIKE AC IS STILL ON
FO-300921	11/6/2014	11/10/2014		Went to Holden, spoke with workers in affected area both overhead heaters working at this time. Also checked with the dock DOCK AREA WEST HEATER ISN'T WORKING (PLZ SEE LEO) heaters both were working, however it was reported that the west heater takes seve
FO-301071	11/10/2014	11/10/2014		TOO COLD. BUILDING
FO-301110	11/10/2014	11/19/2014		Building is very cold on the 1st floor. Please warm up.
FO-301431	11/13/2014	11/13/2014		BLDG FREEZING COLD,EXTREMELY COLD RM's 132,134 251,252,
FO-301440	11/13/2014	11/13/2014		RM 103 IS TOO COLD
FO-301457	11/13/2014	11/14/2014		STE 100 FREE LEGAL AID CLINIC TOO COLD PLEASE ASK FOR BOARD MEMBER
FO-301468	11/13/2014	11/14/2014		1ST FLR FREE LEGAL AID CLINIC CONF RM TOO COLD
FO-301584	11/14/2014	11/13/2014		RM 103 IS TILL TOO COLD
FO-301785	11/17/2014	11/17/2014		TOO HOT. SHERYL LLOYD'S OFFICE IN THE CUSTODIAL DEPARTMENT.
FO-302037	11/18/2014	11/18/2014		RM 103 NO HEAT, TOO COLD
FO-302073	11/18/2014	11/18/2014		Ceiling unit space heater is not blowing out heated air. Please check all units in storage area along Antoinette street.
FO-302088	11/18/2014	11/18/2014		R/R ENT HANDICAP DOOR #193-02E Repair handicap door closure on interior main entrance door. It makes a thump/bang when it opens or closes. Also re-install the latch on the interior Exit door. Latch is at the Reception desk.
FO-302125	11/18/2014	11/19/2014		RM 122 IS TOO COLD
FO-302126	11/18/2014	11/18/2014		TOO WARM. ROOM 313.
FO-302242	11/19/2014	11/19/2014		1ST FL AHU MAKING A LOUD NOISE, CAN BE HEARD IN RM 109
FO-302243	11/19/2014	11/19/2014		TOO COLD. 2ND FLOOR. SEE ALEX FOR MORE DETAILS.
FO-302294	11/19/2014	11/20/2014		TOO COLD. ROOMS 2902, 1202 & 1203.
FO-302426	11/21/2014	11/13/2014		Need HVAC System looked at. Way too hot in dispatch (79 degrees). Using emergency backup a/c unit to cool room down. Thermostat does not appear to be working either.
FO-302774	11/24/2014	11/24/2014		TOO WARM. DISPATCH OFFICE.
FO-302775	11/24/2014	11/24/2014		RM 313 IS TOO HOT
FO-302972	11/25/2014	11/13/2014		TOO HOT. CUSTODIAL OFFICE. SEE THERESA.
FO-303054	11/26/2014			CONTRACTOR REQUESTING ENG TO GO OVER BLDG
E - Preventative Maintenance			50	
FO-300412	11/3/2014			1ST FLR MENS RR 3RD STALL TOILET NOT FLUSHING

WO	Recieved	Finished	Total	Request
FO-300779	11/4/2014	11/7/2014		Purdy Library, 1st Floor, Office Suite 122 (Home of HR Region B) Two electrical outlets stopped working. I checked the breaker panels: all on. Please correct problem for Human Resources staff. Engineer investigated. Was able to reset breaker for
FO-300786	11/4/2014			R/R RM 5344 ONLY SINK HAS A STEADY LEAK COMING FROM FAUCET (ENGINEER HAS ISOLATED LEAK)
FO-300961	11/6/2014	11/7/2014		1ST FL NEAR COMPUTER CTR TOILET OVERFLOWING
FO-300962	11/6/2014	11/7/2014		STE 1600 MENS & WOMENS RM TOILET CONTINUOUSLY FLUSHING
FO-301151	11/10/2014	11/11/2014		Electrical outlets in room 315, drop down outlets: ISRP 3IN CR.3, are not working.
FO-301156	11/10/2014	11/11/2014		RM 1510 DELILAH'S CAFE TOO HOT, AIR NOT CIRCULATING
FO-301250	11/11/2014			WHOLE IS CEILING POSSIBLE LEAK. ROOM 3129.
FO-301261	11/11/2014	11/12/2014		PLEASE CALL JEFF BUMPUS 7-0077
FO-301274	11/11/2014	11/12/2014		RM 3116 NO VENTILATION
FO-301278	11/11/2014	11/12/2014		NEEDS ASSISTANCE LIGHTING A PILOT ON GRILL
FO-301400	11/12/2014	11/13/2014		RM 313 TOO HOT
FO-301401	11/12/2014	11/13/2014		Room is very warm @ 80 degrees....
FO-301407	11/12/2014	11/12/2014		RM 169 TOO COLD
FO-301517	11/13/2014			RM 10303.3 IS TOO COLD Engineer checked. Heat pump #2-64 has no communication from thermostat to the TEC controller. Possibly bad stat. Engineer unable to access stat due to locked stat cover. Work Order transferred to Command Center.
FO-301519	11/13/2014	11/14/2014		1ST - 3RD FLRS SOUTH SIDE OF BLDG IS EXTREMELY HOT
FO-301528	11/13/2014	11/14/2014		RM 101 COVER TO THE AC UNIT NEEDS TO BE PUT ON PLEASE CHECK AC UNIT TO MAKE SURE IT IS OPERATING UPDATE THERESA 7-0039
FO-301533	11/13/2014	11/19/2014		There are 3 radiators and not one is working in Room 60.5 at Art Bldg. Previously submitted on FO-301396.***This was an Engineering FO#/ First Request to the PipeFitters JWT 11-15-14 Engineer investigated. Found one radiator working and two (2) not
FO-301534	11/13/2014	11/19/2014		Two out of three radiators not working in Room 162 Art Bldg. Previously submitted on FO-301397 ***This was an Engineering FO#/ First Request to the Pipefitters JWT 11-15-14 Engineer checked and found 2 out of 4 radiators not working. Radiators appear
FO-301723	11/14/2014	11/15/2014		Ceiling unit space heater is not blowing out heated air. Please check all units in storage area along Antoinette street.
FO-301845	11/17/2014	11/18/2014		RM 171 IS TOO COLD
FO-301851	11/17/2014	11/18/2014		Purdy Library, 1st Floor, Office Suite 134 Occupants of office suite report area to be rather warm. Please adjust the temperature. Thank you.
FO-301852	11/17/2014		11/18/2014	Room 134 is unbelievably hot. (per Librarian) Can the heat be reduced??
FO-301847	11/17/2014	11/18/2014		TOO COLD. ROOM 2105.
FO-301848	11/17/2014	11/18/2014		TOO COLD. 1ST, 2ND AND 3RD FLOORS.
FO-301853	11/17/2014	11/18/2014		Received notice this room has been too cold since Friday. Presently registering 65 degrees
FO-301850	11/17/2014			TOO HOT. ROOM 2337. PM Engineer found room temp 80°F. Stat is set at 72°F. When changed to day mode, setpoint changed by 1°F. Transferred to Controls to check TEC programming.
FO-301857	11/17/2014	11/18/2014		TOO HOT. ROOM 219.
FO-301858	11/17/2014	11/18/2014		POSSIBLE CEILING LEAK (HEAR WATER RUNNING) ROOM 219.
FO-301859	11/17/2014	11/18/2014		NEED HEAT TURNED ON TO 1ST FLOOR GREEN ROOM.
FO-301860	11/17/2014	11/18/2014		TOO COLD. ROOM 117.

WO	Recieved	Finished	Total	Request
FO-302156	11/18/2014	11/18/2014		RM 361 LOST POWER IN WALL OUTLETS
FO-302159	11/18/2014	11/19/2014		RM 363 LOST POWER IN WALL OUTLETS
FO-302166	11/18/2014	11/18/2014		EDUCATION 189 TOO COLD,STUDENT WITH DISABILITY UNABLE TO TAKE THE TEMP
FO-302167	11/18/2014	11/19/2014		OLD MAIN 151 TOO COLD,STUDENT WITH DISABILITY UNABLE TO TAKE THE TEMP
FO-302173	11/18/2014	11/19/2014		Lab is too cold -- 66 degrees. Space is within room 385.
FO-302174	11/18/2014	11/18/2014		RM 2074 TOO COLD
FO-302176	11/18/2014	11/19/2014		RM 405 NO HEAT
FO-302306	11/19/2014	11/20/2014		AIR COMING THRU WINDOWS. 1ST FLOOR FREE LEGAL AID.
FO-302309	11/19/2014	11/20/2014		RM 723 ALARM SOUNDING
FO-302311	11/19/2014	11/20/2014		RM 149 IS TOO HOT
FO-302317	11/19/2014	11/20/2014		EDUCATION RM 169 TOO COLD, COLD AIR BLOWING
FO-302399	11/20/2014	11/21/2014		2ND FL WOMENS DRESSING RM RADIATOR'S LEAKING
FO-302402	11/20/2014	11/20/2014		TOO COLD. ROOM 171.
FO-302416	11/20/2014			071-RM 8405.5 TOO COLD
				Transferred to Command Center. Please reference FO-312175 in which PM Engineer attempted to reset heat pump 1-105. Unit did not respond.
FO-302864	11/24/2014	11/24/2014		RM 1115/CLASS LECT HALL HAS A CLNG LEAK
FO-303009	11/25/2014			RM 1111 CEILING LEAK
				This work order is being submitted to trades for follow-up. Engineering has been informed that repair work will be scheduled for completion between Thanksgiving and Christmas Closure.
				Prior work order references: FO-301543,
FO-303011	11/25/2014	11/26/2014		RM 2074 IS EXTREMELY COLD
FO-303014	11/25/2014	11/26/2014		BSMNT SOUTHEAST CORNER, STORAGE CLOSET DOOR JAMMED
FO-303019	11/25/2014			PLEASE CHECK GENERATOR, MAKING A STRANGE NOISE. SEE LOUISE
E - South			20	
FO-300390	11/3/2014	11/3/2014		Room is very warm - 77 degrees and rising.....
FO-300751	11/4/2014	11/4/2014		LAB 050 IS EXTREMELY HOT
FO-300816	11/5/2014	11/5/2014		RM 106 TOO HOT
FO-301329	11/12/2014	11/12/2014		RM 315 IS EXTREMELY COLD
FO-301454	11/13/2014	11/14/2014		We believe there is a steam leak in the room. Water is condensing on the windows, room is very humid and the researcher also said whatever it is it "smells" bad too....
FO-301455	11/13/2014	11/13/2014		Entire Building too hot - I am getting phone calls from all floors complaining about the high temperatures.
FO-301582	11/14/2014	11/19/2014		TOO HOT. LAB. 60.
FO-301794	11/17/2014	11/17/2014		TOO COLD. ROOM 131 (TEACHES ON SATURDAY AND REPORTS TO PUBLIC SAFETY HOW COLD IT IS THE ROOM)
FO-301810	11/17/2014	11/17/2014		Could you have an engineer come to Rands Rm.100 and turn down the heat.
FO-301815	11/17/2014	11/17/2014		Recheck room temperature of Rands Rm. 207. It is still cold.
FO-302077	11/18/2014	11/18/2014		Office 1160 (Janie Williams-White 7 -2978 has the overhead vent blowing on her. Needs it to be adjusted so it does not blow. Thank you.
FO-302083	11/18/2014	11/18/2014		Lab 2316 is having problems with the heating radiator. Last year they didn't work because the line was cut for renovations. The got them working last year but now they are not working again. Thank you.
FO-302091	11/18/2014	11/19/2014		RM 137 TOO COLD ONGOING CONCERN, PLEASE CHECK TEMP
FO-302232	11/19/2014	11/20/2014		TOO COLD. ROOM 311.
FO-302777	11/24/2014	11/24/2014		RM 4115 IS TOO HOT
FO-302778	11/24/2014	11/24/2014		RM 4121 IS TOO HOT
FO-302779	11/24/2014	11/24/2014		RM 4123 IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-302787	11/24/2014	11/24/2014		RM 218 TOO COLD, TURN AIR OFF
FO-302984	11/25/2014	11/25/2014		CHECK BLDG WATER PRESSURE
FO-303035	11/26/2014	11/26/2014		RM 060/LAB IS TOO COLD
E - Southeast			31	
FO-300719	11/4/2014	11/4/2014		1ST FLL LOBBY LEAK COMING FROM UPPER 2ND FL LOBBY RADIATOR, SEE MIKE IN THE BOX OFFICE FOR MORE INFO
FO-300922	11/6/2014	11/6/2014		TOO COLD. ROOMS 13201.7, 13201.5, & 13201.4.
FO-301118	11/10/2014	11/10/2014		No air coming out of HVAC duct. No air circulation.
FO-301222	11/11/2014			No heat in Room 203 Rackham, in particular 203.3.
FO-301302	11/12/2014			WINDOW STUCK OPEN. ROOM 1137. (Multi-Task)
FO-301362	11/12/2014			RM 109 TOO COLD
FO-301364	11/12/2014			RM 201.4 TOO HOT
FO-301375	11/12/2014			BLDG IS TOO COLD
FO-301434	11/13/2014	11/13/2014		RM 8306.3 TOO COLD
FO-301458	11/13/2014	11/13/2014		RM 120 TOO COLD, PLEASE CALL CURT WITH STATUS 7-4438
FO-301777	11/17/2014			R/R RM 235 REPAIR HTG/CLNG UNIT FOR RM 235 WILL ONLY WORK ON CLNG NOT HTG CAUSING RM TP BE TOO COLD
FO-301805	11/17/2014	11/17/2014		TOO COLD. ROOM 231.
FO-302049	11/18/2014	11/18/2014		RM 5016 TOO COLD, PLEASE CHECK HEAT TIMER YESTERDAY THE HEAT TURNED OFF AT 3:00 by 4 IT WAS FREEZING
FO-302055	11/18/2014	11/18/2014		RM 7208 TOO COLD
FO-302093	11/18/2014	11/18/2014		RM 00428 IS TOO COLD FOR INSTRUMENTS
FO-302094	11/18/2014	11/18/2014		RM 00429 IS TOO COLD
FO-302105	11/18/2014	11/18/2014		RM 10503.1 NO HEAT, TOO COLD
FO-302111	11/18/2014			TOO COLD. ROOM 416.
FO-302140	11/18/2014	11/18/2014		DOOR ALARM. 12TH FLOOR NEAR FREIGHT ELEVATOR.
FO-302266	11/19/2014	11/19/2014		NO HEAT. ROOM 2390.
FO-302342	11/20/2014	11/20/2014		RM 329 HAS NO HEAT
FO-302381	11/20/2014			RM 340 WINDOW UNIT NEEDS FILTER REPLACED
FO-302382	11/20/2014	11/20/2014		RM 337 TOO COLD, RED LIGHT ON THERMOSTAT IS ON
FO-302448	11/21/2014	11/21/2014		RM 8307.2 IS TOO COLD
FO-302750	11/24/2014			It is very hot in suite 207. Can the heat be turned off just for today since it is warm out side? It is 87 degrees in my co-workers (Ms. Williams) office and 82 degrees in mine.
FO-302751	11/24/2014			BLDG TOO HOT.
FO-302752	11/24/2014			STE 5000 TOO HOT
FO-302827	11/24/2014			RM 2218 IS TOO HOT
FO-302845	11/24/2014			STE 5000 TOO COLD
FO-302988	11/25/2014			9th FL 9310 BURNNING RUBBER SMELL
FO-302991	11/25/2014			2ND FL RM 228 CREEK IN CEILING
E - West			15	
FO-300397	11/3/2014	11/3/2014		RM 150 TOO COLD
FO-300942	11/6/2014	11/7/2014		MIKE NEEDS ENG ASSISTANCE WITH DELIVERY AT MATTHAEI
FO-301099	11/10/2014	11/12/2014		TOO HOT. ROOM 125.
FO-301230	11/11/2014	11/13/2014		BLDG TOO HOT
FO-301241	11/11/2014	11/18/2014		TOO WARM. ROOM 100.
FO-301323	11/12/2014	11/18/2014		EAST SIDE OF BLDG HAS NO HEAT
FO-301588	11/14/2014	11/19/2014		TOO COLD. BUILDING.
FO-301770	11/17/2014	11/21/2014		RM 307 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-301771	11/17/2014	11/21/2014		RM 313 IS TOO COLD
FO-301774	11/17/2014	11/21/2014		2ND FLR ENTIRE WEST WNG IS EXTREMELY COLD
FO-301775	11/17/2014	11/21/2014		RM 169 IS TOO COLD
FO-302028	11/17/2014	11/21/2014		Second Floor - south side of bldg. additonal rooms too cold 2031 - 66, 2011 -64, 2015,2017,2025,2033 - all 67 degrees. Previous request was for 2037 - 65 degrees
FO-302063	11/18/2014	11/18/2014		Room is too cold--62 degrees. Tried turning thermostat in room up to 70 and nothing happens. Please fix ASAP.
FO-302288	11/19/2014	11/24/2014		POOL AREA IS TOO COLD
FO-302814	11/24/2014	11/24/2014		Room is too hot! Over 100 degrees!
Low			299	
E - Area 1 Engineer			1	
FO-302051	11/18/2014			Water is coming from under the door of locked mechanical room/custodial dept has no access/ (no room number). This room is located inside the basement men's restroom/front of the building by auditorium
E - Auxiliary			121	
H-48829	11/1/2014	11/5/2014	11/6/2014	Please take care of leaking under a kitchen sink (in the bottom cabinet). I see dripping when water runs in the sink. authenticated user: Miwa Ito - fj6636 requester ip address: 35.16.70.152
H-48810	11/1/2014	11/3/2014	11/19/2014	Toilet in First bathroom on Right-hand side is not working still. Initial work order was fulfilled on Monday earlier this week and my toilet was supposedly fixed. However, toilet still tends to overflow and does not flush properly. authenticated user: N
H-48811	11/1/2014	11/19/2014	11/19/2014	Bathroom fan in the first bathroom on the right side is dysfunctional and needs replacement. Thank you. authenticated user: Nishanth Alluri - ep9136 requester ip address: 35.16.69.139
H-48830	11/1/2014			Please take care of 2 problems at DeRoy #812:1. Leaking under the kitchen sink (in the bottom cabinet). We see dripping when water runs in the sink.2. Loud noise when we raise water temperature of the shower. We cannot have water hot enough because th
H-48833	11/1/2014	11/4/2014	11/4/2014	the bedroom window located away from the closet is blowing in air. Also the heat isn't working in this unit. authenticated user: Isabell Groves - fb2096 requester ip address: 141.217.23.205
H-48825	11/1/2014			The AC's temperature sensor to control the temperature of the apartment doesn't work well. Would you please fix it as soon as possible?authenticated user: Mohammad Aminisharifabad - fb3016requester ip address: 141.217.232.241
H-48816	11/2/2014	11/4/2014	11/4/2014	1st. Heating doesn't work although only the blower work and after waiting an hour there is still no warm air at all. 2nd. there is bad odor from the HVAC system when it works on cool, auto and heat. authenticated user: Antowan Zyada - fo5804 requeste
H-48813	11/2/2014	11/7/2014	11/19/2014	sink water leak authenticated user: Sohrab Mahendra Surana - fl6143 requester ip address: 35.16.197.130
H-48814	11/2/2014	11/7/2014		A piece holding the kitchen faucet in place from underneath broke. Also, the seal around the base of the faucet broke so water easily leaks into the cabinets below. authenticated user: Scott Ginebaugh - ez4739 requester ip address: 141.217.220.109
H-48850	11/2/2014	11/4/2014	11/19/2014	The second bathroom is broken. Water comes in but does not suck water out. TOILET IS NOT CLOGGED. This is the sixth time submitting a request. Maintenance said that this time a plumber should fix the toilet. It is a plumbing issue. authenticated user: E
H-48817	11/3/2014	11/3/2014	11/19/2014	Garbage disposal is not working again. This is the third complaint in a month. Would highly recommend replacing the motor or come up with a permanent fix as once it gets clogged, its stinks very badly. authenticated user: Sankaranarayanan Viswanathan - f
H-48802	11/3/2014	11/3/2014		Outlet near refrigerator has blown. Needs reset or replacement. authenticated user: Arielle Armstrong-Martin - ez3255 requester ip address: 35.16.107.166

WO	Recieved	Finished	Total	Request
H-48822	11/3/2014	11/4/2014	11/19/2014	There is a big problem with the hot water supply in my apartment recently. The hot water stops constantly. It happens day and night. Sometimes I bathe my baby during the daytime, suddently there is only cold water running. During the night, about bed tim
H-48821	11/3/2014	11/4/2014	11/4/2014	My heat is broken and keeps going in and out. The huge problem with this is since we are experiencing the ridiculous frozen tundra in our shower systems, I'm going to need my heat fixed. authenticated user: Sara Gray - el6004 requester ip address: 141.
H-48851	11/3/2014	11/4/2014	11/19/2014	Need maintains for the disposal machine as soon as possible. authenticated user: Bakri Alamri - ex6986 requester ip address: 141.217.220.63
H-48836	11/3/2014	11/4/2014	11/4/2014	AC Unit isn't working. System has been reset multiple times and it never lasts very long. authenticated user: Chelsea Antilla - ee8903 requester ip address: 141.217.224.97
H-48852	11/3/2014	11/4/2014	11/19/2014	Drain disposal has stopped working. authenticated user: Sunpreet Singh - ev6179 requester ip address: 141.217.221.149
H-48856	11/4/2014	11/7/2014	11/19/2014	Toilet in the first bathroom on the right-hand side continued to malfunction. The water level rises too high. This is the third work order within the last seven days. Prominent issue that needs a permanent fix, please. authenticated user: Nishanth Allur
H-48866	11/5/2014	11/6/2014	11/19/2014	Toilet started overflowing and piece fell out of the top part, got it to stop thought authenticated user: Shelby Bensinger - eo7490 requester ip address: 70.210.66.184
H-48875	11/5/2014	11/5/2014	11/5/2014	My air conditioning is only putting out hot air. I set the air as cold as it will go, but it is still 73 degrees in my room (which is way too hot). Please fix this. It has been like this for a couple days now. authenticated user: Zachary Rich - eu7441 r
H-48867	11/5/2014			Leak in the ceiling near the office
H-48869	11/5/2014			ballasts marked by blue tape in the multipurpose room need to be replaced.
H-48883	11/5/2014	11/5/2014	11/5/2014	Exam room 4 in the clinic- inspect fan unit for possible leaks. authenticated user: Celia Staniak - ev6281 requester ip address: 141.217.23.218
H-48891	11/5/2014	11/7/2014	11/7/2014	AC not working again. Little red light underneath is on. authenticated user: Chelsea Antilla - ee8903 requester ip address: 141.217.224.246
H-48893	11/5/2014	11/6/2014	11/6/2014	Filter needs to be replaced authenticated user: Chelsea Antilla - ee8903 requester ip address: 141.217.224.97
H-48894	11/5/2014	11/6/2014	11/6/2014	Heat broke always air authenticated user: Lauren Coats - ep5240 requester ip address: 35.16.32.111
H-48888	11/5/2014	11/7/2014	11/19/2014	Garbage disposal broken authenticated user: Griffin Harms - fb5208 requester ip address: 35.16.67.169
H-48881	11/5/2014	11/5/2014	11/12/2014	ENGINEERING: Replace handle on kitchen faucet and replace washer in tub valve (work completed by Gipson and Broadnax on 11/05 @ 1:40P, 0.5H) authenticated user: Prentis Gipson - bq7019 requester ip address: 141.217.23.228
H-48878	11/5/2014	11/6/2014		Toilet keeps draining its water so there is very little left in the bowl. We've avoided using it to prevent further issues. *EMERGENCY* authenticated user: Mary Whitney - fh2810 requester ip address: 35.16.96.217
H-48896	11/6/2014	11/12/2014		When you turn on the faucet in the kitchen, the pipes below the sink are leaking. Needs to be fixed asap. authenticated user: Shravani Mandalaparty - ev4976 requester ip address: 141.217.59.49
H-48897	11/6/2014	11/14/2014		Faucet is leaking in second bathroom.
H-48898	11/6/2014	11/8/2014		Toilet is slowly running.
H-48914	11/7/2014	11/7/2014	11/7/2014	Air conditioner will still not go below 70 degrees. This is still too warm for me to sleep well. authenticated user: Zachary Rich - eu7441 requester ip address: 141.217.225.149

WO	Recieved	Finished	Total	Request
H-48933	11/7/2014	11/13/2014		The sink in the kitchen started to leak again as it was repaired already once and now it has the same problem and the light in the room is not working authenticated user: Abinaya Mohan - fr4931 requester ip address: 35.16.196.191
FO-301029	11/7/2014	11/10/2014		BLDG CK NO HOT WATER
H-48934	11/7/2014	11/12/2014		in sink dispenser not working, bathroom 1 flush problem authenticated user: Arnab Samanta - fs3005 requester ip address: 35.16.197.172
H-48935	11/7/2014	11/12/2014		The garbage disposal is broken and won't let water pass and the window in the living room can open but can't close authenticated user: Devin Rose - fn9755 requester ip address: 35.16.198.217
H-48947	11/8/2014	11/11/2014	11/11/2014	Heating apparatus rattling problem After about 15 min or more of the heating system working a strange rattling noise come out form the main conditioning apparatus. authenticated user: Antowan Zyada - fo5804 requester ip address: 141.217.224.115
H-48953	11/9/2014	11/11/2014	11/11/2014	Heater is not working. Thermostat is set at 78 but room stays on 68. Freezing! authenticated user: Jazzmine Miley - eq8631 requester ip address: 141.217.23.186
H-48954	11/9/2014	11/11/2014	11/11/2014	hot water is out and has been come and go all week during mornings and nights. authenticated user: Theodore Maximiuk - fb4567 requester ip address: 141.217.225.199
H-48937	11/9/2014	11/11/2014		My kitchen sink is not draining and that garbage disposal stopped working please try come and help asap authenticated user: Chethan Kumar Hanumanthappa Tembad - fn7821 requester ip address: 141.217.59.59
H-48955	11/9/2014	11/14/2014	11/14/2014	The heat is not working in the 1127 unit. Only cold air comes out of the vents. authenticated user: Christopher Binno - eg8502 requester ip address: 141.217.225.152
H-48975	11/10/2014	11/13/2014	11/13/2014	Room stays cold, regardless of when heat is on. Vents not working properly. authenticated user: Jasmine Kendrick - eu6470 requester ip address: 141.217.224.114
H-48972	11/10/2014	11/12/2014	11/12/2014	Activity room:the plug on the side closet to tv needs to be fixed and the light bulb is burnt out needs to be replaced authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.218
H-48970	11/10/2014	11/11/2014	11/11/2014	Towers room 650 temperature is stuck at 75 degrees and the thermostat is turned down to 60 degrees.
H-48991	11/11/2014	11/28/2014		Mechanical Check. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.218
H-48996	11/12/2014	11/12/2014	11/19/2014	bath room sink for washing hands is very slow. authenticated user: Tengjiao Qi - fk3241 requester ip address: 141.217.220.129
H-48997	11/12/2014	11/14/2014		NEED MAINTENANCE FOR THE DISPOSAL MACHINE. IT DOES NOT WORK AT ALL. authenticated user: Bakri Alamri - ex6986 requester ip address: 141.217.220.63
H-49010	11/12/2014	11/14/2014		Toilet in bathroom 2nd bathroom (one with bathtub) does not flush, white piece inside toilet detached from handle authenticated user: Carolyn Chan - dt9641 requester ip address: 141.217.220.157
H-49007	11/12/2014	11/13/2014	11/13/2014	The water faucet in the kitchen is broken. Could you fix it? Thank you so much. authenticated user: Xueting He - fm5477 requester ip address: 35.16.199.204
H-49017	11/12/2014	11/14/2014	11/14/2014	Our A/C unit isn't working and hasn't been for the past few days. authenticated user: Maxwell Johnston - fl7127 requester ip address: 35.16.107.226
H-49013	11/13/2014	11/14/2014		Kitchen sink erator not working. authenticated user: Rahul Patil - fg1066 requester ip address: 141.217.220.159

WO	Recieved	Finished	Total	Request
H-49018	11/13/2014	11/14/2014	11/14/2014	My air conditioning makes a loud noise every 5-10 minutes and has been going on for a while now. authenticated user: Monica Miller - fo5828 requester ip address: 141.217.225.128
H-49015	11/13/2014			The fire alarm red light is flashing - potential low battery issue. authenticated user: Perani Chander - fm3607 requester ip address: 141.217.220.241
H-49019	11/13/2014	11/15/2014	11/15/2014	Heat not working authenticated user: Marlecia Primuse - fm5189 requester ip address: 35.16.194.107
H-49021	11/13/2014	11/13/2014	11/13/2014	Light above sink doesn't work, even with a new light bulb. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.218
H-49029	11/13/2014	11/15/2014	11/15/2014	Dish washer is not working properly. Water is not hot enough and is not washing dishes well. Nick from the Towers Cafe came to the front desk to request a work order. authenticated user: Jazzmine Milety - eq8631 requester ip address: 141.217.23.186
H-49039	11/13/2014		11/17/2014	Garbage disposal is not working properly. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.218
H-49036	11/14/2014	11/14/2014		Hello, The garbage disposal is broken. the left-side sink is also clogged. could you please take care of it? Thanks authenticated user: Ramin Sakhtemani - fq3924 requester ip address: 141.217.220.72
H-49045	11/14/2014	11/14/2014		the ceiling is dripping badly in deroy's lobby infront of the front desk needs to fixed as soon as possible authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.218
H-49046	11/14/2014		11/17/2014	the laundry area on the 12th floor is flooded with water due to which the 11th floor is dripping badly, the lobby area infront front desk is dripping too ...needs to be fixed immediately. authenticated user: Manaswini Remidi - fs2524 requester ip address
H-49030	11/14/2014	11/15/2014		I believe the thermostat in our room isn't working properly. The room temperature is at 70 degrees usually and sometimes at 71 degrees, but it won't go any higher than that. I set it heater at 76 but it won't heat up to that temperature. Also the room I'm
FO-301629	11/14/2014	11/14/2014		ELEV THAT SVCS BSMT TO 7TH FLR IS IN FIRE MODE 1ST FLR DOORS CLOSED
H-49055	11/14/2014			The heating unit in room 326 is out. authenticated user: Cydney McChesney - em8294 requester ip address: 141.217.23.240
H-49064	11/15/2014	11/18/2014	11/18/2014	The heat is out. authenticated user: Devan Simmons - ev6163 requester ip address: 108.223.192.114
H-49071	11/16/2014	11/19/2014		The last room in the apartment , is not heated properly, even though the heater is on high. authenticated user: Kiran Sunil Deshmukh - fp3374 requester ip address: 35.16.79.152
H-49060	11/16/2014			room is only blowing cold air. authenticated user: Shon Johnson - eq9546 requester ip address: 141.217.23.232
H-49061	11/16/2014			room is only blowing cold air. authenticated user: Shon Johnson - eq9546 requester ip address: 141.217.23.232
H-49062	11/16/2014			Our shower started dripping water a few days ago.Last night that drip increased to a full leak, and my roommate and I were wondering what the cause was, and what could be done to stop the leaking. authenticated user: Thomas Zielke - es0554 requester ip
H-49063	11/16/2014			Resident's heat is not working authenticated user: Emily Moran - ez9649 requester ip address: 141.217.23.203
H-49076	11/17/2014	11/18/2014	11/18/2014	The heating unit is broken. It is constantly blowing out cold air. authenticated user: Sara Gray - el6004 requester ip address: 141.217.225.139

WO	Recieved	Finished	Total	Request
H-49077	11/17/2014	11/18/2014	11/18/2014	The heating in our room is not working even after we have reset our system twice. Also, the light bulb in room 347C is flickering and will not stay on. authenticated user: Nivea Brown - fp8045 requester ip address: 35.16.103.43
H-49078	11/17/2014	11/20/2014	11/20/2014	The shower head is leaking and the heating unit is not working. authenticated user: Sara Gray - el6004 requester ip address: 141.217.225.139
H-49079	11/17/2014	11/20/2014	11/20/2014	The heating unit does not work. authenticated user: Sara Gray - el6004 requester ip address: 141.217.225.139
H-49081	11/17/2014	11/22/2014	11/22/2014	The study lounge temperature/ thermostat is broken. authenticated user: Sara Gray - el6004 requester ip address: 141.217.225.139
H-49111	11/17/2014	11/19/2014		The fridge we have is too small for three people. The maintenance person also agrees with us. Could you please provide us with a bigger fridge? Also, the heating in the first two rooms are not working properly. The first room is too warm, and the second
H-49101	11/17/2014	11/20/2014	11/20/2014	Our air conditioner is broken. I find that our room is always REALLY warm, which admittedly isn't too bad as it gets colder but it can still be a little to hot. If you could send someone to look at our AC I'd really appreciate it. authenticated user: B
H-49113	11/18/2014	11/21/2014		Toilet flush handle loose/broken. authenticated user: Brian Chun - ft0995 requester ip address: 141.217.221.228
H-49114	11/18/2014	11/20/2014		The kitchen sink erator is blocked because of which water is clogged in the sink. Please consider this as a priority. authenticated user: Prachi Vesikar - fq8356 requester ip address: 35.16.71.116
H-49116	11/18/2014	11/20/2014		the insincorator is not working authenticated user: Harshavardhana Galla - fr0259 requester ip address: 35.16.79.48
H-49108	11/18/2014	11/20/2014	11/20/2014	My heat does not work. When I put the system on heat, it sounds like it's coming on, but nothing comes out of the vent. authenticated user: Dominique Witherspoon - ev6822 requester ip address: 35.16.197.205
H-49123	11/18/2014			we have problem with the heat it keeps giving cold air and the light in the bathroom doesn't work anymore also the chain that's next to the blinder is broken. authenticated user: Ghada Sadoon - eq1555 requester ip address: 141.217.174.162
H-49127	11/18/2014			The A/C is not working. It is only circulating cold air. authenticated user: Chiara Woods - eb8378 requester ip address: 141.217.23.203
H-49132	11/18/2014	11/21/2014	11/21/2014	The thermostat won't go above about sixty-eight degrees. The heat doesn't seem to be working at all, even though I have it on. There is a little red light on on the thermostat. authenticated user: Megan Mather - fh1350 requester ip address: 141.217.224.
H-49133	11/19/2014	11/22/2014	11/22/2014	Heat isn't working. It only blows out cold air. authenticated user: Mark Teague - eg3572 requester ip address: 141.217.23.186
H-49134	11/19/2014	11/19/2014	11/19/2014	Heat isn't working. It only blows out cold air. authenticated user: Mark Teague - eg3572 requester ip address: 141.217.23.186
H-49140	11/19/2014	11/19/2014		broken garage disposal authenticated user: Kevin White - ep9465 requester ip address: 35.16.73.124
H-49136	11/19/2014	11/26/2014	11/26/2014	A/c does not heat up enough. It is set on the hottest setting, and the rooms are still super cold. Also, the windows are filled with condensation. authenticated user: Muhammad Ismail - fh0281 requester ip address: 141.217.224.183
H-49141	11/19/2014	11/22/2014	11/22/2014	Need to fix thermostat because heat wont go passed 78 degree. authenticated user: An Do - em7676 requester ip address: 141.217.224.113
H-49150	11/19/2014	11/20/2014		1) Sink dispenser is not working. authenticated user: Kaushik Innamuri - fr6209 requester ip address: 24.209.70.159
FO-302312	11/19/2014	11/20/2014		PLS CALL DONNELLA REGARDING NO HEAT

WO	Recieved	Finished	Total	Request
H-49170	11/19/2014			The blinds and heater are both not functioning. Please fix them as soon as possible. authenticated user: Resma Gadde - fp1331 requester ip address: 35.16.111.228
H-49155	11/19/2014	11/21/2014	11/21/2014	SUBWAY's ice machine isn't making ice authenticated user: Veronica Gonzales - fh3793 requester ip address: 141.217.23.186
H-49171	11/19/2014			Heat not working authenticated user: Kayla Wood - ez6729 requester ip address: 35.16.105.238
H-49156	11/20/2014	11/26/2014	11/26/2014	heat is not working. when you turn it on it just blows out cold air and its colder in my bedroom than the rest of the room. i think there is a draft coming from my window. i stay in the 2nd to last room near the thermostat. thermostat has been reset but e
H-49172	11/20/2014			Heat not working in room 437. Unit is blowing out cold air. authenticated user: Cydney McChesney - em8294 requester ip address: 35.16.96.221
H-49186	11/20/2014			The heat in our room is not working at all! We are sleeping in a freezer!authenticated user: Gerald Palmer - em8475requester ip address: 35.16.192.131
H-49160	11/20/2014			Replace all faucets: bathrooms and kitchen
H-49161	11/20/2014	11/25/2014		Fix water in bathroom 1 - Currently it is manually shut off because it won't turn off at the faucet
FO-302350	11/20/2014	11/20/2014		We have no heat in a few of our patient rooms at Campus Health Center - DEROY APARTMENTS ROOM 115.
FO-302351	11/20/2014	11/20/2014		Room 263 at Campus Health Center - thermostat does not work and room has no heat.
H-49198	11/20/2014	11/26/2014	11/26/2014	I don't know if the air condicionator is working correct because we put in the Heal, but we need to keep the temperature in 77/78 F to have our apartment warm(it is making a lot of noise). In my friends apartment, they use to leave the temperature like 7
H-49176	11/20/2014			Shower leaks. authenticated user: Justin Yemm - ef4839 requester ip address: 35.16.197.126
H-49178	11/20/2014			The shower leaks. authenticated user: Justin Yemm - ef4839 requester ip address: 35.16.197.126
H-49179	11/20/2014	11/29/2014		The heat in the lounge is still broken. authenticated user: Justin Yemm - ef4839 requester ip address: 35.16.197.126
H-49180	11/20/2014			The heat in the lounge is broken. authenticated user: Justin Yemm - ef4839 requester ip address: 35.16.197.126
H-49168	11/20/2014	11/24/2014	11/24/2014	Towers Cafe - no heat in dishwasher room.
H-49197	11/21/2014	11/21/2014		Kitchen disposal is not working for the past several days...Please help.. Thanks..! authenticated user: Ayse Karaca - ek6995 requester ip address: 141.217.221.196
H-49203	11/21/2014	11/25/2014		electrical outlet by the stove is broken.
H-49224	11/21/2014			Thermostat is not working in the room. Blows air, but doesn't get hot or cold. authenticated user: Eric Carter - fp0519requester ip address: 141.217.23.234
H-49227	11/21/2014			The heater inside the room can not be adjusted. authenticated user: Christopher Cross - fa6775requester ip address: 141.217.23.234
H-49220	11/22/2014	11/24/2014		One of the wall sockets does not work. authenticated user: Keontae Ware - fg9660 requester ip address: 141.217.23.241
H-49221	11/22/2014	11/24/2014		Garbage Disposal has stopped working. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.240
H-49216	11/23/2014	11/24/2014		in-sink erater not working authenticated user: Sukhesh Sudan - ff7947 requester ip address: 141.217.220.155
H-49217	11/23/2014	11/25/2014		1)Flush in one of the washroom needs repair.Float valve malfunction. 2) Refrigerator door liner has got cut. Need to be replaced. authenticated user: Rahuldev Gurudev - fl6922 requester ip address: 141.217.220.243

WO	Recieved	Finished	Total	Request
H-49219	11/23/2014	11/24/2014		Toilet is leaking from basin on the top when I flush. This is an emergency I need it fixed because I cannot use bathroom authenticated user: Monica Shah - eh9074 requester ip address: 166.170.22.198
H-49222	11/24/2014	11/24/2014		the drainpipe will leak when I am trying to open the switch in the kitchen and the water doesn't flow well through the pipes. thank you. authenticated user: Bin Bai - fk8427 requester ip address: 141.217.220.102
H-49273	11/25/2014	11/28/2014		Replace kitchen faucet. The faucet leaks at the base and cannot be shut off in normal position. It was repaired in the past, but this time it needs to be replaced. authenticated user: Carl Ballou - da5860 requester ip address: 141.217.59.35
H-49274	11/25/2014	11/25/2014		Bathroom/ Washroom-1 leakage from Top floor. Urgent authenticated user: Siddharth Waichal - fk0395 requester ip address: 141.217.220.127
H-49285	11/25/2014			Ceiling leaking. authenticated user: Ashley Hepp - fa9366 requester ip address: 35.16.199.143
H-49283	11/25/2014			The vents need to be cleaned. authenticated user: Chiara Woods - eb8378 requester ip address: 141.217.23.203
E - Command Center			76	
FO-300347	11/3/2014			controls crew R/R RM 100/MECH RM please troubleshoot AC-1 humidifier,model #94 ham-d 7# 3/4 15 psi/60 Armstrong.priority-High
FO-300358	11/3/2014			BAS Section: R/R RM 401/MECH RM please repair failed FLN network for VAV boxes on 2nd floor lab areas.
FO-300363	11/3/2014	11/27/2014		Controls group, R/R RM 113 recently installed thermostat does not operate in the auto/heat mode. Fan runs cold air only in the manual mode. Priority high
FO-300375	11/3/2014	11/17/2014		CONTROLS CREW, R/R RM 495/NEW BLR RM PLEASE TROUBLESHOOT NO POWER TO SOFTNER CONTROL, REPLACED TRANSFORMER BUT FAILED IMMEDIATELY. PRIORITY-HIGH
FO-300391	11/3/2014			Steven is experiencing wide temp/air volume swings. There is also the issue of the VAV box self-calibration; this thing seems to self-calibrate all day. Please investigate.
FO-300727	11/4/2014	11/4/2014		Boiler not starting.
FO-300707	11/4/2014			Controls group/SIEMENS R/R 3RD FLR replace repair outside air temperature sensor. Priority high.
FO-300760	11/4/2014	11/5/2014		Please repair MUA #1 for the Science building. Unit trips on high limit. Filters and belts are good. Gas modulating valve does not appear to be working.
FO-300769	11/4/2014	11/7/2014		Please re-evaluate Simons boiler; DTE has determined outside regulators ok; meter will be replaced. Possible relay issue.
FO-300822	11/5/2014			Please investigate Rm#VAV's #1200 Scott Hall. NTE \$1500.00. Refer PO#696055.
FO-300885	11/6/2014	11/10/2014		Controls R/R RM 1139/MECH RM Boiler rm med priority #2 boiler will not start, Please determine root cause and repair
FO-300940	11/6/2014			Trade: Controls/Siemens Priority: HighR/R BLDG EDC Engine lab 1551 is in a negative pressure because supply damper is not opening. Siemens command is 100% for this damper but there is no air flow. I checked the air handler #8 and it is running and making
FO-300943	11/6/2014			Needed diaphragm for A. Kotal
FO-301008	11/7/2014			CONTROLS CREW, R/R RM 2111/CLASS LAB CAV BOXES NOT FUNCTIONING, TWO ARE FAILED. PRIORITY-LOW
FO-301119	11/10/2014			BAS crew: Please troubleshoot ahu 2 mixed air dampers,: responding slow, possible leak by.
FO-301199	11/11/2014			R/R MAIN ENTRANCE A BUZZING NOISE ELECS' TO CK LIGHT BALLAST CHANGED TO LOW, bad EP on unit, ordered it, and is waiting for part. Open to Control Shop, please replace Ep. on the heater in the vestibule off Canfield.

WO	Recieved	Finished	Total	Request
FO-301212	11/11/2014	11/12/2014		HONEYWELL: Please repair/ replace POWER PACK on third floor. Multipule VAVs down. ZONE IS HOT. HIGH
FO-301334	11/12/2014			trade controls priority high R/R BSMT please replace powers thermostat in basement animal quarters over heating this room with animals inside and food
FO-301373	11/12/2014			Controls -- Priority Medium R/R RM 115 Thermostat in room 115 not working correctly.
FO-301408	11/13/2014			Face & Bypass Dampers not working
FO-301512	11/13/2014			HONEYWELL- R/R RM 112/RECEIVING please r/r heat in main office. control valve for reheat was leaking. damper has been disconnected. reheat is isolated. Room is 60 degrees when occupant comes to work. please address asap.
FO-301560	11/14/2014	11/14/2014		Please investigate/repair AC-1 diaphragm issue.Scott Hall. NTE \$750.00. Refer PO#696055.
FO-301569	11/14/2014	11/26/2014		Controls Med PriorityR/R RM 1108/MECH RM #2 boiler will not restart after LWCO. must raise level above normal operating level using FW bypass due to the electric valve being closed at normal level.
FO-301593	11/14/2014			HONEYWELL- R/R RM 313 please r/r control valve type M6410A1029 9938 located in room 313 that services the 3rd floor hallway reheat. (valve is disconnected, hanging and inoperable). east side hall is very cold w/ no reheat.
FO-301747	11/17/2014			Trade: Command Center Priority: High Lab 60 ctl stpt (F007.09.A01.301:CTL STPT) is changing. Laser equipment in this room requires it to remain constant at 72 deg 24/7. Please remove any night setback for this area. Graph will be sent by email.
FO-301748	11/17/2014	11/20/2014		CONTROLS CREW, R/R RM 00495/NEW BLR RM MAKEUP WATER SOLENOID TO D.A TANK FAILED, PLEASE REPLACE. PRIORITY-HIGH
FO-301765	11/17/2014	11/19/2014		Control Engineer; High R/R RM 2210 Please check the refrigerant pressure in the heat pump 2-15 for Suite 2210. The compressor is not cycling on and the suite is extremely cold.
FO-301766	11/17/2014			Control Engineer; High R/R 7TH FLR Water leak was reported w/ FO-301759 water leaking from ceiling. The water was leaking from the TRX control water valve around the diaphragm. I have isolated heat pump #1-96-071-HWP-054 electrically and water so
FO-301767	11/17/2014	11/19/2014		Control Engineer; High R/R RM 8306.30 Please repair/replace the blower motor on heat pump 1-120-071-HWP-078, the unit is not running. I have the unit isolated electrically.
FO-301825	11/17/2014			Controls-- Priority MediumR/R RM 201 Heating/Cooling unit (part# 26) not getting hot. Blowing cool air
FO-301830	11/17/2014			Refg. Crew:R/R RM 316/MECH RM Please check stroke on new 3-way control valve on the perimeter heating system and adjust. New valve is not the same as old, and fitters had to install a longer shaft rod on valve. High priority.
FO-302042	11/18/2014			R/R RM 00025/MECH RM Supply fan 1 serving the auditorium has a defective controller for the discharge air temperature. Please have refrigeration crew repair or replace.
FO-302047	11/18/2014	11/19/2014		Control Engineer; Medium R/R RM 2312 Please repair the bad thermostat/steam control valve diaphragm in the Suite. There is no control of the radiators and the suite is over heating.
FO-302124	11/18/2014			Controls, R/R 6TH FLR MECH RM please replace failed freeze stat on AHU-4. I bypassed it to get fan to run.
FO-302138	11/18/2014			BAS crew: R/R RM 3211/MECH RM Install averaging temp sensor for heat recovery coil on AHU 3, set up PPCL control programming.
FO-302149	11/18/2014			R/R RM 00032/MECH RM Supply fan 13 for Alumni house has hot deck programmed to not go over 100F. Please have Refrigeration crew correct this in program.
FO-302160	11/18/2014			Repair/replace controller on AHU # 5.
FO-302193	11/19/2014			CONTROLS- R/R BLDG please r/r AHU#3 at 5447 Woodward unit is currently not operating. the area is getting heat from other supply, but serviced rooms are under 50F.

WO	Recieved	Finished	Total	Request
FO-302196	11/19/2014			CONTROLS- R/R BLDG please r/r AHU#5. unit is currently not operating. the area is getting heat from other supply, but serviced rooms are under 50F.
FO-302204	11/19/2014			Controls: MED PriorityR/R 2ND FLR Please repair/replace Trane thermostat located 2nd floor S. W. lunchroom.Stat controls RTU for all offices on 2nd floor west side.Stat flashes all icons periodically and indicates cooling failure in heat mode.Please p
FO-302223	11/19/2014			Control Engineer; High R/R RM 8405.6 Please check the refrigerant pressures in the system for heat pump #1-105-071-HWP-063. The refrigerant compressor is not cycling on, the suites are cold.
FO-302224	11/19/2014			Control Engineer; High R/R RM 9406.4 Please check the refrigerant pressures in the system for heat pump #1-128-071-HWP-086. The refrigerant compressor is not cycling on, the suites are cold.
FO-302231	11/19/2014	11/26/2014		Siemens: R/R Room 321 room temperature (67) is below set point (73) and damper command and positioner is at 100 %. However air flow is slightly below 50% air flow. possible damper or damper drive issue. Please repair.
FO-302254	11/19/2014			Controls, R/R RM 400.10/MECH BLR RM repair/replace alarm horn on boiler #3.
FO-302324	11/20/2014			HONEYWELL please r/r control valve that is stuck in closed position for south half of room 121/122 at Mort Sci. The discharge is 60 degrees w/ no reheat. valve type M6410A1029 9938.
FO-302325	11/20/2014	11/21/2014		Please re-locate T-Stat from general AD offices back into AD main office.
FO-302340	11/20/2014			R/R RM 4087.01 EF-35 is only showing 13 cfm and is showing as an 'AO' point, it should be an 'AI' point. this is the point info. F005.04.E35.ECF
FO-302353	11/20/2014			Control Engineer; HighR/R RM 8307.20 Please check the refrigerant pressures in heat pump #1-116-071-HWP-074. The compressor is not cycling on.
FO-302354	11/20/2014			Control Engineer; HighR/R RM 9305.20 Please check the refrigerant pressures in heat pump #1-135-071-HWP-093. The compressor is not cycling on.
FO-302356	11/20/2014			Control Engineer; HighR/R RM 9204.10 Please check the refrigerant pressures in heat pump #1-132-071-HWP-090. The compressor is not cycling on.
FO-302357	11/20/2014			Control Engineer; HighR/R RM 9311 Please check the refrigerant pressures in heat pump #1-137-071-HWP-095. The compressor is not cycling on.
FO-302358	11/20/2014			Control Engineer; HighR/R RM 10410.00 Please check the refrigerant pressures in heat pump #2-53-071-HWP-101. The compressor is not cycling on.
FO-302363	11/20/2014			Control Engineer; HighR/R RM 10202 Please check the refrigerant pressures in heat pump #2-58-071-HWP-106. The compressor is not cycling on.
FO-302359	11/20/2014			Control Engineer; HighR/R RM 10303 Please check the refrigerant pressures in heat pump #2-64-071-HWP-112. The compressor is not cycling on.
FO-302360	11/20/2014			Control Engineer; HighR/R RM 10304.40 Please check the refrigerant pressures in heat pump #2-68-071-HWP-116. The compressor is not cycling on.
FO-302388	11/20/2014			Controls Med. to High PriorityR/R 1ST FLR HALLWAY NEAR RM 1108 replace small plastic control line and spring on unit heater 1 st floor stairwell SE side of bldg. No heat in area.
FO-302397	11/20/2014			Trade: Controls/Siemens Priority: HighR/R EDC Engine test cell lab 1539 room temperature is 56 and the set point is 72. The Siemens system is not commanding the heating valve to open. Please trouble shoot.
FO-302436	11/21/2014			Control Engineer; HighR/R MEZZANINE Please repair heat pumps #142 & #143(Master & Slave). The units are going out on the lock out relay. The studio staff are also complaining about excessive resonance coming from the units. The units ID Numbers are;
FO-302437	11/21/2014			Control Engineer; High R/R MEZZANINE Please repair heat pumps #142 & #143(Master & Slave). The units are going out on the lock out relay. The studio staff are also complaining about excessive resonance coming from the units. The units ID Numbers

WO	Recieved	Finished	Total	Request
FO-302441	11/21/2014			Controls: High Priority. R/R RM 00027/MECH RM (FOR RM 367) Please reset/open Fire Damper on cold deck side of supply air duct to room/lab 367. Room is over heating.
FO-302452	11/21/2014			Controls: Med High R/R Room/Lab 169 overheating Repair or replace pneumatic thermostat. MD# T-4002 Johnson Controls. At present stat is removed and a jumper air line has been put in place to relieve the over heating.
FO-302457	11/21/2014			Trade controls priority medium R/R RM 530.10 please check air handler #2 at ugl pint house area static speed control is to high and needs loop tuning as well thank you
FO-302503	11/21/2014	11/25/2014		Please confirm operation or failure of 3-way valve supplying coil #13 adjacent to store on level #1 of SCB.
FO-302741	11/24/2014	11/24/2014		Trade: Command Center Priority: High R/R RM 00022/MECH RM Insight is not starting at Science Hall. Please repair.
FO-302742	11/24/2014			Trade: Command CenterPriority: MediumR/R RM 0231/LAB Please repair VAV box. The space is cold!
FO-302963	11/25/2014			trade controls priority high R/R RM 1147 please service air dryer here at bio-science fan motor is going bad and is about to stop ultra air dryer going bad.
FO-302966	11/25/2014			Controls -- Priority HighR/R RM 337.10 Heat Pump constantly kicks off and needs resetting.
FO-302994	11/25/2014			Investigate AHU#4 F&BP dampers & coil> no airflow.
FO-302995	11/25/2014			BAS group: R/R PENTHOUSE Please replace ahu 4 steam valve actuator diaphragm Honeywell MP 953c 1083 2 4-11psi
FO-302996	11/25/2014			BAS group: R/R PENTHOUSE please replace ahu 4 preheat damper controls to work of AOP/Siemens.
FO-302999	11/25/2014	11/25/2014		Swap mod motor from boiler "B", install on "A" "A" Boiler repeatedly floods. Get specs from motor to Massa; will need to order replacement.
FO-303047	11/26/2014			Refg. Crew:R/R RM 410/MECH RM The PRV that controls the domestic hot water will not allow temperatures greater than 100 degrees no matter what the set point is. Please repair. Medium Proirity.
FO-303049	11/26/2014			Honeywell/Refg. Crew.R/R 3133/MECH RM The outside air sensor for Law School BAS is showing 10 degrees higher than actual temperature. Please repair. Medium Priority.
FO-303055	11/26/2014			Replace needed damper motors for combustion air.
FO-303056	11/26/2014			Investigate Boiler #3, fail to ignite> see Gregg Ray.
FO-303069	11/26/2014			Controls: R/R RM 239 please correct air flow/temp control issues for 0239. Room very negative, room cold (set point 74).
E - MedPharm			14	
FO-300322	11/2/2014	11/2/2014		Just outside Room 0171A, ceiling tiles have fallen down due to moisture. Possible pipe leaking. Thank you, Susan
FO-300763	11/4/2014	11/4/2014		Room needs to be warmer. Yucatan pigs housed in this room. Temperature should be between 75-80 degrees. Thank you, Susan
FO-300764	11/4/2014	11/4/2014		Room needs to be warmer. Yucatan pigs housed in this room. Temperature should be between 75-80 degrees. Thank you, Susan
FO-300835	11/5/2014	11/5/2014		Room 0513 too cold it needs to be at least 72 degrees.
FO-300896	11/6/2014			BSMT NEED ACCESS TO RM NEAR DOCK AREA CHANGINE OUT METER PH #313-408-5413
FO-301196	11/11/2014			Low humidity
FO-301197	11/11/2014			Low humidity
FO-301198	11/11/2014			Low humidity
FO-301328	11/12/2014	11/12/2014		Odor coming from the pump room. Needs to be checked for the sump pumps working properly. Thank you, Susan
FO-301336	11/12/2014	11/12/2014		DTE NEED ACCESS TO MECH RM TO INSTALL NEW ELEC METER ETC
FO-302046	11/18/2014	11/18/2014		DOCK AREA PLS TURN OFF ALL 3 UNIT HEATERS ABOVE DOCK DOOR AREA
FO-302414	11/20/2014			Have engineer pick up ladder that was loaned to Pharmacology department. Thank you.

WO	Recieved	Finished	Total	Request
FO-303032	11/25/2014	11/26/2014		The temperature in this room is too high for chemical storage and experiment. Please set the temperature down to 70 or lower. Thanks
FO-303061	11/26/2014			The outlets in 232B, 232D, and the open suite area of 232 are not working.
E - North			18	
FO-300753	11/4/2014	11/4/2014		Purdy Library, 1st Floor, Office Suite 134 Staff in area report that area is too warm. Please adjust the temperature. Thank you.
FO-301014	11/7/2014	11/7/2014		Please tighten ALL toilet seats in the Cohn Building. Basement, 1st floor, 2nd floor and 3rd floor, per housekeeping reporting that many are loose need to be secured.
FO-301027	11/7/2014	11/7/2014		Air conditioning unit over door of office 156 is dripping water. We currently have a waste basket by the door to catch water. Also is it possible to adjust the temp of the one unit. It's very cold in that area of the department.
FO-301103	11/10/2014	11/20/2014		repair pump coupling Grainger # 4RD26
FO-301121	11/10/2014	11/12/2014		Please check for the cause to the bubbling/peeling paint above the interior door (door between offices). This was repaired and painted earlier this semester but is bubbling again. Possible water leak??? ,,,,,,,,,,,,,, JH/11-12-14 ,,,,,,,,,,,,,,
FO-301378	11/12/2014	11/26/2014		Our building is very cold. Please warm it up. Thank you.
FO-301466	11/13/2014	11/13/2014		2nd Floor: Temperature needs to be adjusted. Mornings about 60 degrees, afternoons about 74 degrees. (3rd floor seems to be fine.)
FO-301503	11/13/2014	11/13/2014		The temperature on the 3rd floor needs adjustments (as well as the 2nd floor-order already submitted for the 2nd floor); Both 2nd and 3rd floor offices are cold!
FO-301547	11/13/2014			Hallway corridor outside room 352- need lights replaced- 50% of the lights stopped functioning all at once- may be a power issue
FO-301752	11/17/2014	11/17/2014		Purdy Library, 3rd Floor, Room 350 Occupants of staff office report that area is rather warm. Please adjust the temperature. Thank you.
FO-301807	11/17/2014	11/17/2014		4 logbooks from stockroom
FO-302057	11/18/2014	11/18/2014		Fuse blown. Please reset.
FO-302064	11/18/2014	11/18/2014		need more heat in room 241. has gotten chilly again. thank you
FO-302071	11/18/2014	11/18/2014		Room 114, 115, and 3rd floor hallway are very cold. Please warm up.
FO-302144	11/18/2014	11/18/2014		Too cold throughout building.
FO-302432	11/21/2014	11/21/2014		The entire first floor is very cold.
FO-302786	11/24/2014	11/24/2014		Rm. 134 The office is too hot.
FO-302969	11/25/2014	11/25/2014		Purdy Library, 1st Floor, Office Suite 134 Staff report area rather warm. Please turn down the heat. Thank you.
E - Northeast			6	
FO-300368	11/3/2014	11/3/2014		RM 2701 IS TOO COLD - COLD AIR BLOWING INTO RM
FO-300712	11/4/2014	11/4/2014		CK EQ REC'D INFO THE ELEC POWER HAD FLUCTUATED
FO-301325	11/12/2014			Clean gutters of leaves and debris for the Winter
FO-301577	11/14/2014	11/14/2014		3rd floor back hallway and 1st floor classroom 121 are cold. Please warm up.
FO-301585	11/14/2014	11/18/2014		Exterior server room fan not functional. Call 7-3368 for additional details.

WO	Recieved	Finished	Total	Request
FO-303041	11/26/2014	11/26/2014		Radiator in office is leaking from the vent. This is the same problem as reported in FO-302267 (I mistakenly said valve in that request, however), which is listed as finished. I have closed both valves on the radiator and put a trash can under it to cat
E - Preventative Maintenance			27	
FO-300679	11/4/2014			<p>Fan Sheave: 18-3/8" 2A Sheave 2-7/16" Q1 Bushing</p> <p>Drive Sheave: 5" 2A Sheave 1-1/8" Q1 Bushing</p> <p>Belts: A158 Qty: 2</p>
FO-300680	11/4/2014	11/4/2014		Clean Coils
FO-300794	11/5/2014	11/11/2014		<p>EF Belts (For Day Shift)</p> <p>B255 Belts Qty: 6</p>
FO-300955	11/6/2014	11/7/2014		Teaching lab is very hot.
FO-300971	11/7/2014	11/20/2014		Order for Filter Clips for Chemistry Bldg AHU's
FO-301043	11/7/2014	11/13/2014		R/R 4TH FLR The women's bathroom 4TH STALL TOILET NEEDS FLUSH VLV REPLACED DUE IT is constantly flushing..... MP/11-13-14
FO-301275	11/11/2014	11/12/2014		Room too hot
FO-301395	11/12/2014	11/13/2014		Electrical outlet on south side of wall no longer works.
FO-301396	11/12/2014	11/13/2014		No heat in Room 60.1. There are 3 radiators and not one is working.
FO-301397	11/12/2014	11/13/2014		Two out of 3 radiators not working in room 152 Art Bldg.
FO-301410	11/13/2014	11/20/2014		<p>Please replace belts On Communit Arts RAF-2</p> <p>B158 Qty: 3</p>
FO-301516	11/13/2014	11/14/2014		Outlet in kitchen area is not working.
FO-301841	11/17/2014	11/17/2014		low humidity
FO-301843	11/17/2014	11/18/2014		rm 190.11, hallway near freight elevator has water all over it. Coming under wall from mechanical room 346.
FO-302155	11/18/2014	11/19/2014		TOO COLD. ROOM 169.
FO-302161	11/18/2014	11/19/2014		APT 314 LOST POWER
FO-302171	11/18/2014	11/19/2014		fuse blew out only in one portion of the office - 2147.08
FO-302172	11/18/2014	11/19/2014		Office is extremely cold
FO-302303	11/19/2014	11/20/2014		Room temperature of Prentis Rm. 309 is too cold. Please send engineer to fix.
FO-302307	11/19/2014	11/20/2014		PLS PUT CAUTION TAPE AROUND A HOLE IN SIDE WALK OFF FRONT OF THOMPSON HME OFF OF HANCOCK SIDE (ORANGE CONE OVER IT)
FO-302318	11/19/2014	11/20/2014		Room temperature of Prentis Rm. 311 is too cold. Please send engineer to fix.
FO-302421	11/21/2014	11/27/2014		<p>Belt order</p> <p>B61 Qty:8</p>
FO-302422	11/21/2014	11/27/2014		<p>Basement Ceiling Unit</p> <p>Belt order</p> <p>B65 Qty:2</p>
FO-302728	11/22/2014			January Filter Order for Matthaehi OA Intakes
FO-302938	11/25/2014			<p>Please purchase 6 qts oil for fans with oil bearings. Grainger Part # 1UBX8</p> <p>Oil not stocked in stockrm.</p>
FO-302939	11/25/2014			<p>Belt order</p> <p>B47 Qty:1</p>

WO	Recieved	Finished	Total	Request
FO-302940	11/25/2014			Belt order B50 Qty:1
E - South			18	
FO-300331	11/3/2014	11/4/2014		Suite 300 in the Prentis Building is too cold. Need engineer to fix heating issue.
FO-300378	11/3/2014	11/3/2014		Strong sewer gas smell in basement and also the 1st floor. I have not checked other floors but have had several complaints about the smell!
FO-300380	11/3/2014	11/4/2014		Students are complaining about the "natural gas" smell on the second floor coming out of the vents. I went up there and we believe that it is just the same sewer gas smell that we are getting on the other floors.
FO-300723	11/4/2014	11/4/2014		Strong sewer gas smell in entire building. Complaints from students that it smells terrible in the building. This was also turned in yesterday.
FO-300932	11/6/2014	11/11/2014		MICROWAVE COMM CO WILL NEED ACCESS TO ROOF TO SERVICE SATELITE DISH
FO-301253	11/11/2014	11/11/2014		Teaching lab is very hot and the students are complaining since their safety goggles are fogging up from the heat. It's over 85 degrees and rising.
FO-301438	11/13/2014	11/13/2014		SCOTT WILL NEED ACCESS TO MECH RM PLS CALL HIN @313-282-9520
FO-301442	11/13/2014			The fume hood in this room is running too high (approx. 181 FPM). In mid-December, researchers from science hall will be moving into this lab so they would like it fixed.
FO-301445	11/13/2014			The fume hood in this room is running too low (approx. 60 FPM). In mid-December, researchers from science hall will be moving into this lab so they would like it fixed.
FO-301446	11/13/2014			The fume hood in this room is running too high (approx. 140 FPM). In mid-December, researchers from science hall will be moving into this lab so they would like it fixed.
FO-301450	11/13/2014	11/13/2014		Office is very hot. @ 80 degrees and rising.
FO-301831	11/17/2014			**Steam Traps Leaking By Are The suspected cause. Replacement Steam Traps on Order under FO#301018 JWT R/R 00022/MECH RM Entire Building - Hot Water too hot. I just checked at taps on 3rd floor and it's coming out @ 155 degrees. Had complaint from
FO-302078	11/18/2014	11/18/2014		Lab 3330 on the third floor is really cold. They need this to be checked. Thank you.
FO-302079	11/18/2014	11/25/2014		Lab 1355 dos not appear to have the heating system on in it. It is very cold. Can building Engineer please check. Contact number is Abhishek at 313-463-0894. Thank you.
FO-302344	11/20/2014	11/21/2014		Can you please have Rocky come and check in the Dean's Suite in the main Engineering building the main conference room and the Dean's conference room. They both are extremely cold. Not the usual. Thanks.
FO-302829	11/24/2014	11/24/2014		MEET W/SIEMENS
FO-302831	11/24/2014	11/25/2014		MEET W/SIEMENS
FO-302980	11/25/2014	11/25/2014		Could you have an engineer come to Rands Rm.102 and turn down the heat.
E - Southeast			15	
FO-300321	11/2/2014	11/3/2014		The office is very cold. It seems like the heater does not work for this the room 2210.
FO-301776	11/4/2014	11/4/2014		RM 201 I would like to request for the filters in the floor heat/cooling unit be replaced (due to allergy flare ups). Thank you.
FO-301252	11/11/2014	11/11/2014		Breaker is blown in Room 3110 & 3108.1 Old Main.
FO-301382	11/12/2014	11/12/2014		ONLY cold air coming out of heat register
FO-301437	11/13/2014			WILL NEED ACCESS TO MECH RM PH #313-220-2637
FO-301556	11/14/2014	11/14/2014		PLEASE CALL CAROL TALBOTT AT 664-2630. REGARDING QUESTIONS REGARDING BUILDING.
FO-301688	11/14/2014	11/17/2014		The office is very cold. It seems like the heater does not work for this the room 2210.

WO	Recieved	Finished	Total	Request
FO-301803	11/17/2014	11/17/2014		The following rooms are extremely cold: 2202, 2204, and 2206
FO-302067	11/18/2014	11/19/2014		Please turn on heat at Hilberry Thetare in Ladies and Mens dressing rooms 2nd floor. Also can the heat be turned up on radiator in Green room (backstage 1st floor)? Please see Michael in the box office if you have any questions/problems. Thanks,
FO-302385	11/20/2014			Ms. Faith Williams says it is too hot in her office she is in room 207.3.
FO-302458	11/21/2014			Room 101.2 ceiling is still leaking water. It was fixed twice this week but it is still leaking. We are using 2 buckets at the same time to catch the water. That room belongs to Mrs. O'Leary she said she can be reached by email today at ad2250@wayne.ed
FO-302830	11/24/2014			HVAC not circulating air in this office.Needs to be reset.
FO-302978	11/25/2014	11/25/2014		2155.2 - heater has very loud ticking noise
FO-302979	11/25/2014	11/25/2014		2155.5 - heater has very loud ticking noise
FO-302981	11/25/2014	11/25/2014		2155.6 heater has very loud ticking noise
E - West			3	
FO-300716	11/4/2014	11/24/2014		BSMT HAS SEWER GAS SMELL
FO-301351	11/12/2014	11/19/2014		Room 367 is too warm, 84', for experiments in that lab. Please lower to nearer 70-72.
FO-302072	11/18/2014	11/18/2014		The 131 suite of offices is very cold. Need heat.
Grounds			3	
Low			3	
G - Moving/Storage			2	
FO-300948	11/6/2014			Grounds to support Friday Night 11/7/2014 HS Football Game
FO-301758	11/17/2014			Grounds:R/R BSMT Please remove old valves and other debris in mechanical rooms 0316, and 0410. See Engineer. Medium Priority.
G - Physical Grounds			1	
FO-302815	11/24/2014			need 3 bangs of oil absorbent, 2 boxes of dust masks, and 6 clear safety glasses.
Trades			910	
Emergency			71	
T - Carpenter			18	
FO-300775	11/4/2014	11/4/2014		EMERGENCY/CARP R/R SOUTH LOBBY DOOR GLASS IS SHATTERED NEED BOARD UP
FO-300864	11/5/2014	11/5/2014		"Emergency Repair" - R/R RM 102/OFC Door leading from room 102 to hallway is broken and will not close. It appears the door closing mechanism may have been damaged in conjunction with the Presidential visit to WSU over the weekend. Because the door
FO-301206	11/11/2014	11/11/2014		DOOR WON'T OPEN. KEY TURNS IN DOOR LOCK. 2ND FLOOR LADIES RESTROOM.
FO-301307	11/12/2014	11/11/2014		EMERGENCY CARP R/R RM 2140 DOOR LOCK IS SPINNING (STEWART MAY'S OFC)
FO-301412	11/13/2014	11/13/2014		R/R ENT DOOR #003-01S does not latch properly, doors comes ajar causing it to be unsecure after hours
FO-301449	11/13/2014	11/14/2014		EMERGENCY/CARP R/R ENT HANDICAP DOOR #071-02N DOOR ACTUATOR WILL NOT OPEN DOOR
FO-301590	11/14/2014	11/17/2014		EMERGENCY CARP R/R RM 1253 CANNOT UNLOCK DOOR W/KEY NOR SUB MASTER KEY
FO-301591	11/14/2014	11/14/2014		ERMERGENCY CARP R/R ENT HANDICAP (AD) DOOR CLOSURE ARM FELL OFF
FO-302113	11/18/2014	11/18/2014		DOOR HANDLE IS HANGING. ENTRANCE DOOR TO LAW LIBRARY.
FO-302141	11/18/2014	11/18/2014		DOOR WON'T CLOSE PROPERLY. DOOR 062-01-WEST
FO-302143	11/18/2014	11/18/2014		DOOR 062-03-WEST PANIC BAR IS FALLING OFF.

WO	Recieved	Finished	Total	Request
FO-302278	11/19/2014			ADDING CARPENTER: Please remove ceiling in closet located in basement north east stairwell to access steam leak. See Eric or Corey for location. **Need to complete steam repair before Friday 11-21-14
				BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH
FO-302327	11/20/2014	11/20/2014		REPAIR OR REPLACE PUSH BAR ON DOOR 090-12-N. DOOR NOT LATCHING OR LOCKING. CONTACT ENGINEER FOR DETAILS.
FO-302451	11/21/2014	11/21/2014		EMERGENCY CARP INSURANCE POL REP #W14-3250042 R/R DUE TO B & E FRONT ENTRANCE DOOR GLASS ROCK THROWN THRU WINDOW TO GAIN ENTRANCE NEED BOARD UP
FO-302783	11/24/2014	11/25/2014		EMERGENCY/CARP R/R ENT Handicap DOOR #026 01S PUSH BUTTON/openers are not working on the Purdy side near the Cass entrance.
FO-302839	11/24/2014	11/24/2014		Tonya Jones 11/24/2014 14:16 - POLICE REPORT# W43080064 Window in attic facing Gullen Mall is broken. Broken glass outside. Part of window still intact, but unstable. Customer is afraid glass will blow out due to high winds.
FO-303007	11/25/2014	11/25/2014		KEY BROKEN OFF, TO OVERHEAD GARAGE DOOR VEHICLE PARKED INSIDE.
FO-303031	11/26/2014			EMERGENCY CARP R/R RM 4047 CANNOT OPEN DOOR W/KEY
T - Electrician			25	
FO-300325	11/3/2014	11/24/2014		#1 EXHAUST FAN IS NOT RUNNING. SEE ENGINEER.
FO-301003	11/7/2014	11/7/2014		#2 BOILER WILL NOT START. BOILER ROOM.
FO-301022	11/7/2014			EMERGENCY ELEC R/R RM 2330.10 ENG HAS CK'D BREAKER BREAKER HAS NO PROBLEM PLS HAVE ELECS' CK WHY R/R CK ALL lights are out in cold room. Please fix as soon as possible.
FO-301048	11/7/2014	11/7/2014		Sewage ejector pump keeps tripping out. Reason unknown. Can't wait due to possibility of overflowing.
FO-301194	11/11/2014	11/21/2014		SUPPLY FAN 1 WILL NOT START. SEE ENGINEER.
FO-301224	11/11/2014	11/11/2014		Disconnect and re-connect electrical wiring serving low water alarm float on feed water heater tank. Pipe fitters relocating the float assembly up 4 inches.
FO-301316	11/12/2014	11/13/2014		EMERGENCY/ELEC R/R RM 9309/PIPECHASE NEED TO HAVE LITES REPLACED ASAP
FO-301462	11/13/2014	11/13/2014		PENTHOUSE RETURN AIR FAN #2 NOT WORKING
FO-301481	11/13/2014	11/14/2014		1 EP, Rm 103 - Lt. Smith office has no light.
FO-301549	11/14/2014	11/14/2014		AIR HANDLER #4 DOWN ON FREEZE STAT AND WON'T START. PENTHOUSE.
FO-301834	11/17/2014	11/17/2014		EMERGENCY/ELEC R/R BLDG AHU #3 WILL NOT START SUSPECT FREEZE STAT
FO-302039	11/18/2014	11/19/2014		HEATER #2 OUT. VESTIBULE.
FO-302069	11/18/2014	11/18/2014		PRONGS STUCK IN FLOOR OUTLETS. ROOM 2101.
FO-302118	11/18/2014	11/19/2014		AHU # 1,3,4 DOWN ON FREEZE STAT
FO-302206	11/19/2014	11/19/2014		SUPPLY FAN #2 IS DOWN. SUSPECT BLOWN FUSES. PENTHOUSE MECHANICAL ROOM 502.
FO-302262	11/19/2014	11/19/2014		EMERGENCY ELEC R/R RM 201/203 MECH RM SAF #4 WILL NOT START UP APPEARS TO BE BLOWN FUSE
FO-302260	11/19/2014	11/19/2014		RM 1200 NO POWER TO OUTLETS
FO-302431	11/21/2014	11/21/2014		NO POWER IN ELECTRICAL HEATER. ROOM 1145. SEE ROCKY FOR LOCATION.
FO-302734	11/24/2014			EMERGENCY ELEC R/R FAP HAS A CODE STATING CARD #19 HAS LOW BASTTERY CASUSING TROUBLE ALARM ACTIVE W/RESET & REPEATING CONSTANTLY
FO-302735	11/24/2014			EMERGENCY ELEC R/R BSMT/MECH RM RAF-2 IS DOWN WILL NOT START

WO	Recieved	Finished	Total	Request
FO-302769	11/24/2014	11/24/2014		Electricians; High: R/R RM 0008.11/MECH RM Reset trouble alarm fire alarm system. Located Emergency Response Room across from front stairwell entering basement.
FO-302833	11/24/2014			EMERGENCY ELEC R/R BLDG LOST POWER PLS TROUBLESHOOT
FO-303027	11/26/2014			EMERGENCY ELEC R/R BLDG FAP FIRE ALARM WILL NOT RESET Completed 11-26-2014 SRP
FO-303036	11/26/2014	11/26/2014		Electricians; High: R/R RM 0008.11/MECH RM Reset trouble alarm fire alarm system. Located Emergency Response Room across from front stairwell entering basement. Completed 11-26-2014 SRP
FO-303064	11/26/2014			Electrician; Emergency R/R RM 0195/MECH RM No. 1 Boiler down due to blown fuse in control, burner motor starter. Fuse is RNQ-R-15 other fuses on starter are LP-CC-15.
T - Locksmith			1	
FO-302420	11/21/2014	11/20/2014		Please provide access to Rm 4163. Researcher locked their keys, coat & phone inside. Carpenters called in by Afternoon Shift Engineering Associate Director.
T - Pipefitter			13	
FO-300326	11/3/2014	11/4/2014		AIR HANDLER UNIT #1 STEAM COIL LEAK. PENTHOUSE..... ME/11-3-14
FO-301013	11/7/2014	11/7/2014		**Duplicate / Refer to FO#300949 JWT EMERGENCY PIPE R/R RM 0100 REMOVE 1/2 IN REG VLV & PIPING INSTALL STRAIGHT PIPE W/GLOBE VLV FOR AHU #2. (TEMPORARY FOR ANOTHER JOB FOR SAME FAN) SEE RESULTS
FO-301139	11/10/2014	11/10/2014		HIGH PRESSURE GASKET BLOWING FOR STEAMLINE IN RM 10 STEAM RUCHING OUT JH/11-10-14
FO-301193	11/11/2014	11/11/2014		REPAIR LEAKING STEAM COIL AC2. ROOM 100..... ME/11-11-14
FO-301750	11/17/2014	11/17/2014		EMERGENCY/PIPE R/R PH REPAIR AHU #1 LEAKING COIL ME/11-17-14
FO-301846	11/17/2014	11/18/2014		STEAM COMING FROM WALL. ROOM 1125.1. Engineer found steam leak before isolation valve inside rm 1125.1. WO transferred to fitters as emergency. Fitters called in. No isolation valves found for leaking steam line. Boilers turned off for repair.
FO-302034	11/18/2014	11/18/2014		EMERGENCY PIPE R/R PH/MECH RM HAVE FITTER TACK WELL A SHIVE COLLAR ON MOTOR FOR AHU #11 JH/11-18-14 (SEE ENGINEER)
FO-302076	11/18/2014	11/19/2014		**Refer to Roofer FO#302203 JWT RM 3027.1 RAINING INSIDE RM ME/11-18-14
FO-302114	11/18/2014			RM 9360 CEILING LEAK, AHU# 9 AHU#13 LEAK JH/11-18-14
FO-302322	11/20/2014	11/20/2014		VERY BAD CEILING LEAK. ROOM 231 ME/11-20-14
FO-302763	11/24/2014	11/24/2014		AC6 HOT DECK COIL LEAKING. NEED REPAIR. ROOM 3320..... JH/11-24-14
FO-302947	11/25/2014	11/25/2014		UPPER AC1 TOP COIL LEAKING BADLY AT FLANGE. ROOM 100..... ME/11-25-14
FO-303082	11/28/2014			chk condensate flowing out of mechanical room 11.....
T - Plumber			13	
FO-301080	11/10/2014	11/10/2014		ALL TOILETS NOT FLUSHING, SINKS WATER CONTINUOUSLY RUNNING GS/11-10-14
FO-301105	11/10/2014	11/10/2014		CONTINUOUSLY RUNNING WATER COMING FROM WATER FOUNTAIN SPILLING OVER TO CARPET. 4TH FLOOR NEAR ROOM 4200. GS/11-10-14
FO-301439	11/13/2014	11/13/2014		*David Kuffner Forwarding information to Parking JWT R/R DRIVEWAY LEADING INTO PARKING LOT THE MAN HOLE COVER IS CAVING IN (SAFETY ISSUE DUE TO CHILDREN ARE WALKING IN THE VICINITY)

WO	Recieved	Finished	Total	Request
FO-301808	11/17/2014	11/17/2014		NO RUNNING WATER IN SINKS. 5TH FLOOR MEN'S RESTROOM..... DB/11-17-14
FO-302099	11/18/2014	11/18/2014		Basement Sanitary drain backup at floor drain in south/east area of Building under Restaurant. See Bill Willard GS/11-18-14
FO-302278	11/19/2014			ADDING CARPENTER: Please remove ceiling in closet located in basement north east stairwell to access steam leak. See Eric or Corey for location. **Need to complete steam repair before Friday 11-21-14
				BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH
FO-302308	11/19/2014			UPGRADING TO EMERGENCY DUE TO FOLLOWING 2nd floor men's restroom stall near windows not flushing properly. 11/21/14 LPS: PLEASE NOT TOILET IS NOW STOPPED UP & OVERFLOWING Engineer checked Men's room toilet, flushing valve not working properly, refer
FO-302471	11/21/2014	11/21/2014		EMERGENCY PIPE R/R SUB BSMT MECH RM REPAIR COUPLING ON #2 ACID SUMP PUMP MP/11-21-14
FO-302472	11/21/2014	11/21/2014		EMERGENCY PLUM R/R RM 110/WOMENS RR THE 3RD SINK FAUCET WILL NOT SHUT OFF WTR IS FLOWING FULL FORCE (however note wtr is going down the drain) DB/11-21-14
FO-302748	11/24/2014			EMERGENCY ELEC R/R SUB BSMT MECH RM REPAIR SOLENOID VLV ON #1 ACID SUMP PUMP Electricians disconnected Solenoid (480V Coil), and is waiting for Plumbers to replace Solenoid to connect it back up. OPEN TO PLUMBERS: GS/11-24-14
FO-302836	11/24/2014	11/24/2014		EMERGENCY PLUM R/R BSMT MENS RR TOILET IS PLUGGED & OVERFLOWING GS/11-24-14
FO-302838	11/24/2014	11/25/2014		LEAK OVER WEST OVERHANG DB/11-24-14
FO-303002	11/25/2014	11/25/2014		EMERGENCY PLUM R/R 1ST FLR MENS RR ONLY TOILET IS PLUGGED UP & READY TO OVERFLOW MM/11-25-14
			1	
T - Roofing				
FO-302203	11/19/2014			**ADDING ROOFER: Roof leak 3027.1 See John Covert Sisung for location or Marty Elwart RM 3027.1 RAINING INSIDE RM ME/11-18-14
			209	
High				
T - Carpenter			47	
FO-300398	11/3/2014	11/4/2014		ENTRANCE DOOR HARD TO OPEN. 3RD FLOOR MEN'S RESTROOM.
FO-300741	11/4/2014	11/5/2014		First Name: Kelly Last Name: Loftis Email: fp2365@wayne.edu Phone: 313-577-4637 Type of Issue: Automatic Door Openers Affiliation: Staff Comments: The automatic button on the handicap entrance of Rands House has not been working for several months,
FO-300766	11/4/2014	11/5/2014		R/R Door 090-11N scrapes threshold, doesn't close flush, intermittently fails to latch/secure
FO-300767	11/4/2014	11/4/2014		The handle to the stairway door has come apart. This needs to be fixed ASAP for safety reasons.
FO-300789	11/4/2014			Repair trap door in ceiling over sink that is stuck half open. Very low ceiling and poses a hazard for people using the sink. This women's locker room is used every day by the students who need it for Gross lab.
FO-300792	11/5/2014	11/5/2014		During the PM shift on 11-4-14, Public Safety reported that the overhead door was not securing. Engineering investigated. Found keypad lock mechanism needs to be repaired/replaced.
FO-300840	11/5/2014	11/6/2014		WEST SIDE OF BLDG INNER DOOR PIN AT TOP OF HINGE IS STICKING OUT. SAFETY ISSUE CUSTOMER STATED NO DOOR NUMBER PLEASE CONTACT MARTHA FOR MORE INFO 7-1621

WO	Recieved	Finished	Total	Request
FO-300963	11/6/2014	11/14/2014		Dorothy Carter 11/06/2014 16:05 - Carpenter's portion of this move job. To take apart & reassemble several desk with Grounds crew. EACPHS Move: We are moving a number of people around in the building (1) three people are moving from the 1st floor to th
FO-300999	11/7/2014	11/10/2014		R/R 1ST FLR (PEDESTRIAN DOOR) The garage door on the northeast side that connects the garage and sled area (rm. 1200) is not closing properly.
FO-301030	11/7/2014	11/10/2014		Door 203-05S doesn't close flush; causes failure to latch/secure.
FO-301132	11/10/2014			WSU carpenters to construct weather enclosure protecting the west, north, and east exterior plaza elevation from freezing weather. Use more permanent cement board exterior material. Install doors for egress. Need work started immediately prior to freezing
FO-301133	11/10/2014	11/18/2014		IT door is slamming shut upon entrance and exit; concerned that the glass will break if not addressed soon. NOTE: Door is part of the IT Suite #6304, however the door was not in use until recently and does not have a room number on it.
FO-301221	11/11/2014	11/14/2014		Stairwell J - Door leading down to basement - Handles broken off door (note: handles currently being used to prop door open)
FO-301246	11/11/2014	11/11/2014		Key is stuck in the lock, possibly superglue was used. Need to have a locksmith come out ASAP please. Thanks
FO-301229	11/11/2014	11/14/2014		CARPENTRY/GLAZIERS- please r/r window on 2nd floor. window over looking courtyard. South west side. Green room w/ long couch. Window will not close securely. It is open to the elements. High priority.
FO-301249	11/11/2014	11/13/2014		DOOR KNOB IS BROKEN. CLOSET ROOM 2360.
FO-301259	11/11/2014	11/25/2014		In the hallway outside rooms 220 and between rooms 212-214 the ceiling trim is falling down causing a hazard. Please repair.
FO-301284	11/11/2014	11/17/2014		**ADDING CARPENTER: Install one 12"x12" vinyl tile for new eye wash location in front of room 3437. See Gerry (Plumber) when done (**) PO Req TH PLUMBERS: Please replace eye wash station sink. Found missing. HIGH ,,,,,,,,,,,,,, JS/7-29-14 ,,,,,,,,,
FO-301309	11/12/2014	11/14/2014		Door is 3310 is jammed. Students get locked inside the room. It appears that the lock needs to be replaced. Thank you.
FO-301326	11/12/2014	11/14/2014		RM 2140 INSIDE STE 2100 CORE IS SPINNING UNABLE TO LOCK AND UNLOCK DOOR
FO-301604	11/13/2014	11/17/2014		Front door lock is not working correctly, please send the locksmith out tomorrow morning. Work order was written H-48974 Thanks
FO-301542	11/14/2014	11/18/2014		Manoogian bldg Janitor's Closet (Rm 172) Janitor's closet door lock not working. Key cannot be inserted in cylinder. May have something jammed in cylinder. Unable to open door. Please investigate and repair.
FO-301558	11/14/2014	11/14/2014		NEED FRONT ENTRANCE DOORS OPENED.
FO-302334	11/17/2014			Repair of M. Basketball Team Room Code that is NOT functioning....Please rush...Mike Pines is aware of this situation..Specs. - Bob OstrowskiThank You.Dorothy Carter 11/20/2014 08:33 - E-mail dated 11/19/14 received to charge account index 1-22521 fro
FO-302029	11/17/2014	11/19/2014		Please fix door handle. Door handle falls off every time someone touches it.
FO-302053	11/18/2014	11/19/2014		trade carpenter priority high down in basement area theirs a set of louvers that's bring cold air through them and also my concern is theirs a sprinkler heads right by this area it may burst if to much air comes in is it possible to put a tarp over the lo
FO-302229	11/19/2014	11/20/2014		1ST FL STAFF OFFICE DOOR BEHIND CIRC DESK SCREWS MISSING ON DOOR LOCK SEE LERONIA FOR LOCATION DETAILS
FO-302233	11/19/2014	11/24/2014		2ND FL BRIDGE LEADING TO MAZUREK LEAKING, MAKE OR REPAIR SEAL CONNECTING BLDG 612 & 608
FO-302259	11/19/2014	11/19/2014		Lock broken on apartment door, student can not get out of their room. Dorothy Carter 11/19/2014 11:23 - This was a call-in at 5 am in the morning per e-mail dated 11/19/14 from Patrick Erne.

WO	Recieved	Finished	Total	Request
FO-302273	11/19/2014	11/20/2014		Please repair damage to door, damage door hardware, wood door jam is damaged also. Located at the Woodward entrance at 5035 Woodward, damage due to a B&E. The building is vacant. Police Report Number W14-3230036 Dorothy Carter 11/19/2014 12:18 - Per Bill
FO-302268	11/19/2014			GARAGE DOOR NOT CLOSING PROPERLY PLEASE CONTACT RAYNOR DOOR
FO-302319	11/20/2014	11/21/2014		Please install door sweep on West Doors (Main entrance doors). Background: 1ST FL RADIATOR BURST IN ATRIUM, WATER SHOOTING OUT. Engineer reported vestibule HW finned tube at main entry froze & split. Finned tube supply isolated. Doors left open t
FO-302394	11/20/2014	11/20/2014		The left, main front door will not open. This is NOT an alarm issue. Something with the arm on the top of the door is keeping it shut. Need to have this taken care of ASAP.
FO-302373	11/20/2014	11/21/2014		NORTHWEST INNER AND OUTER HANDICAP DOORS NOT OPENING PROPERLY.
FO-302425	11/20/2014			Electronic handicap door at Purdy (south) entrance not functioning
FO-302508	11/21/2014	11/24/2014		contact: Dawn Waltzcontact_email: dwaltz@wayne.educontact_ph: 7-1090desired_date: 11/24/2014funding_source: 147771funding_year: 2015preferred_billing_method: Directproject_description: Need to have key core fixed, key will not go in. This office
FO-302500	11/21/2014			White floor tiles are lifting and need to be replaced. The problem is considered highly urgent because disabled people in wheelchairs frequent this Neuro Lab.
FO-302731	11/24/2014	11/24/2014		PLEASE REPAIR DOOR LOCK. DOOR WON'T OPEN WITH KEY. ROOM 1242.
FO-302771	11/24/2014	11/24/2014		The inner main handicap door to the front of the building needs to have the control arm reattached. Student went out the door hitting it so hard that it dislodged the rolling wheel on the top arm. This is a secured door so it needs to be repaired asap.
FO-302761	11/24/2014			Request section of ceiling grid to be removed Rm# 8307.1; heat pump will need to be taken down. Please contact Andy McAlpine.
FO-302847	11/24/2014	11/24/2014		Second floor lounge, the door will not open and needs to have someone gain access the this room.2nd floor study lounge...unable to gain entrance. Door lock batteries are dead. Not able to charge lock to open door to change batteries. Advised FP&M w
FO-302848	11/24/2014	11/24/2014		Door is not closing properly. The actual location is at the COG Retail Store next to subway. Please call if you have any questions.
FO-302844	11/24/2014			Install backer board and replace cinder blocks on 2ed floor mens urinal that has been removed for wall mount replacement near Dean's office. Please let John Towle Know when completed so Tile work can be started. ***Tile work to be started Monday Dec 1st
FO-302861	11/24/2014	11/25/2014		R/R Panic bar door outside Room 171 in the first floor of Knapp in the Child Care Center. The bar is falling off it is missing a pin. Please repair.
FO-302987	11/25/2014			2ND FL WINDOWS NEED TO BE STABILIZED BY DEC 11
FO-303026	11/26/2014			Door 016-03E will not secure.
FO-303042	11/26/2014			Student locked out of room. The key will go into the lock but the lock will not turn.
T - Electrician			65	
FO-300370	11/3/2014	11/4/2014		Disable Gas Monitor, clear trouble on Fire Alarm system, and disconnect batteries. Completed 11-4-2014 SRP
FO-300410	11/3/2014	11/4/2014		South multi-purpose room light switch needs to be replaced, switch works intermittently.
FO-300709	11/4/2014	11/4/2014		R/R RM 0190 FAP PANEL IN TROUBLE Completed 11-4-2014 SRP
FO-300755	11/4/2014	11/6/2014		plug broke off in wall socket in room 208 on window wall, lower left corner Completed 11-6-2014 SRP
FO-300800	11/5/2014			LIGHTS ARE NOT COMING ON WHEN LIGHT SWITCH IS TURNED ON. GYM 111.
FO-300802	11/5/2014	11/7/2014		Please disconnect power from motor on make up air unit 2 on roof.
FO-300813	11/5/2014			Repair lights on second level of ramp, 2 fixtures outside of Carpenters Shop.
FO-300899	11/5/2014	11/7/2014		Just Do It, WSU Electricians to turn on lights at Tom Adams field for the Warren De La Salle v East English Village football game on Friday, November 7, 2014. Report to 5454 Cass Avenue at 5:00 p.m., lights on at 5:30 p.m., lights off at 9:30 p.m., out b

WO	Recieved	Finished	Total	Request
FO-300878	11/6/2014	11/6/2014		**ADDING ELECTRICIAN: Disconnect storm water sump on #2 sump in subbasement mechanical room . See Mike Pummill for location
				Replace storm water pumps in sumps #1 and #2 ,,,,,,,,,,,,,, MP/11-6-14 ,,,,,,,,,,,,,,
FO-300916	11/6/2014	11/6/2014		R/R room number 125. The metal frame surrounding a set of light fixtures between Cubicle #2 and Cubicle #3 is not securely attached to the ceiling. We are afraid that it is going to fall on one of us. Please fix. Thank you - Dawn C.
FO-300952	11/6/2014	11/7/2014		ELECTRICAL DEPT R/R -PLEASE CHECK BLOWN CIRCUIT #4 RTU IN PANEL PP-2,CAN'T RESET CIRCUIT BREAKER ,NEEDED TO RUN AC UNIT TO ELEVATOR CONTROLS ROOM,ROOM TO HOT HIGH PRIORITY
FO-300976	11/7/2014	11/7/2014		Parking Lot #60 (Behind Hillberry) Please adjust timers in lot so that light come on at dusk.
FO-301064	11/10/2014			please have electricians wire in new air compressor to power source for animal quarters room 100. this air compressor is located near water heaters in room 100high priority.
FO-301065	11/10/2014	11/10/2014		please have electricians change lights in cold box. daily experiments being stored in this cold box. no light, high priority.
FO-301066	11/10/2014	11/12/2014		ELECTRICIANS, CONDENSATE RECEIVER PUMP(A) WILL NOT OPERATE, PLEASE REPAIR. PRIORITY-HIGH
FO-301079	11/10/2014	11/14/2014		RM 2156 LIGHTS FLICKERING, LIGHTING CREW STATED IT IS AN ELECTRICAL PROBLEM
FO-301114	11/10/2014			Electricians, please repair/replace condensate pump in room 12. Priority: high
FO-301149	11/10/2014	11/12/2014		One of the outdoor Porch LIGHTS above handicap entrance doors (alongside Hancock St) is out. This has required an electrician in the past. Please let me know if you need more information. Michael Donohue 577-0853
FO-301157	11/10/2014	11/12/2014		FIRE TROUBLE ALARM Engineer found same fire alarm trouble related to gas detection system-ongoing problem for last month. Work order transferred to electricians. Completed 11-11-2014 SRP
FO-301159	11/10/2014	11/13/2014		FIRE TROUBLE ALARM. Engineer found ground fault. Trouble acknowledged. Work order transferred to electricians. Completed 11-12-2014 SRP
FO-301185	11/11/2014			PS #1 – Public Safety reported lights out on east side of structure. Engineer found 1st and last light on. However all lights in between were off. Engineer checked breakers. All breakers ok. These lights were recently installed as part of recent
FO-301191	11/11/2014	11/11/2014		Room 0242 light timer is malfunctioning and will need to be replaced or fixed asap. Lights are not turning on and off by timer. This is a reverse light cycle room and the timer is ver very important! Completed 11-11-2014 SRP
FO-301215	11/11/2014	11/13/2014		RM 179 LIGHT SENSOR NOT WORKING, LIGHTS ARE ON AND OFF AT ODD HOURS
FO-301217	11/11/2014	11/17/2014		ELECTRICIANS: Please repair bad ballast (shorts) in room 2156. HIGH
FO-301232	11/11/2014			Trade: ElectriciansPriority: HighExhaust fan 32 is not running. Fan is for multiple fume hoods in lab 3040. New motor was installed 9/17/14. 2 fuses are blown. Motor appears to have overheated. Fan is on roof. Starter is located in the penthouse
FO-301237	11/11/2014	11/11/2014		**ADDING ELECTRICIAN: Please verify voltage on domestic hot water recirculation pump #2 in room 257. Relay info to John Towle ASAP Please R/R RM 257/MECH RM B&G pump for DHWH #2, in basement mechanical room ,,,,,,,,,,,,,, MM/11-10-14 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-301279	11/11/2014	11/17/2014		<p>**Need set up by 11-14-14 9:00am</p> <p>*ADDING Laborer: Set up baker scaffold with wheels in janitor closet off lobby ASAP. See Gerry (Plumber) for detail</p> <p>*Abatement Complete</p> <p>(**) PO REQ DK</p> <p>*Lowered Priority / Work in Progress JWT</p> <p>TRAP DRIED OUT, EVENT T</p>
FO-301286	11/12/2014			<p>**ADDING LABORER: Remove pipe / pumps and tanks in both fan rooms in basement. See Mike Pummill for location</p> <p>Replace storm water pumps in sumps #1 and #2 ,,,,,,,,,,,,,, MP/11-6-14 ,,,,,,,,,,,,,,</p>
FO-301288	11/12/2014	11/14/2014		<p>Work order to electricians to investigate why boiler feed water Pumps 2 & 3 are blowing fuses.</p> <p>Engineer reported that feed water pumps 2 & 3 have been blowing fuses. Engineer indicated that pump #2 blew two that were replaced on 11-11-14. He also not</p>
FO-301289	11/12/2014	11/13/2014		<p>In main Gym there are 5 lights out, repair as needed. There's a Basketball game Friday, and they need to be completed before the game.</p>
FO-301290	11/12/2014			<p>Move lift to Matthaei for Electricians, and return it to UGL when job is complete.</p>
FO-301306	11/12/2014	11/12/2014		<p>R/R ELEV Please fix elevator light. The O-ring has come loose from around one of the lights and the light bulb is dangling from its wires.</p> <p>Completed 11-12-2014 SRP</p>
FO-301343	11/12/2014			<p>REPAIR SMOKE DETECTOR 1ST FLOOR (PUBLIC SAFETY CALLED IN FIRE ALARM)</p> <p>Completed 11-14-2014 SRP</p>
FO-301348	11/12/2014			<p>FIRE TROUBLE ALARM, CLEAN SMOKE DETECTOR</p> <p>Completed 11-14-2014 SRP</p>
FO-301417	11/13/2014	11/18/2014		<p>Remove cement pedestal at location of new clear water pumps in plenum #1</p>
FO-301460	11/13/2014	11/21/2014		<p>ADDING LABORER: Move material from stockroom to location at Hilberry.</p> <p>Also clean up debris from 2ed floor women's bathroom above box officeand 1st floor janitors room.</p> <p>*Bring gondola. See Gerry the plumber for location</p> <p>(**) PO REQ DK</p> <p>*Lowered Piori</p>
FO-301463	11/13/2014	11/13/2014		<p>**ADDING ELECTRICIAN: Hook up welder pigtail for 220 volt welder.located in mechanical room 15</p> <p>See Eric or Corey for location</p> <p>Repair leaking economizer located in mechanical room 15 ,,,,,,,,,,,,,, EA/11-13-14 ,,,,,,,,,,,,,,</p>
FO-301489	11/13/2014	11/14/2014		<p>Trade: Laborer</p> <p>Priority: High</p> <p>Please deliver 1 drum (or keg) of Neutramine for boiler water treatment. Standing FO297705</p>
FO-301531	11/13/2014	11/14/2014		<p>Emergency light fixture is hanging by the wires located behind the elevators on the 1st floor.</p>
FO-301575	11/14/2014	11/14/2014		<p>3RD FL ALARM HANGING FROM CEILING</p> <p>Completed 11-14-2014 SRP</p>
FO-301619	11/14/2014	11/14/2014		<p>Please wire up temporary electric heaters in tent city at Life Science.</p>
FO-301725	11/14/2014	11/17/2014		<p>Light switch in restroom located in lunchroom area seems to have a shortage. Light bulbs were replaced on request that was entered on 11-10-14, however light still flickers on and off, and at times will not come on at all. Door number is 6100.01.</p>
FO-301746	11/17/2014	11/18/2014		<p>**ADDING LABORER: Transport 10' extension ladder that will extend to 20' to the Football Stadium Press box by 12:15pm Monday 11-17-14 so Plumbers can Winterize water system. Then return ladder. See Mike Pummill for Location</p> <p>Winterize Football Stadium</p>
FO-301799	11/17/2014	11/17/2014		<p>Check circuit to the Under the Shingles Ice Melting System to assure proper installation, if there's a visible Fire Risk, and there is Thermal Sensors in place.</p>
FO-302032	11/18/2014			<p>please correct oil leak on transformer that is located between Rands house and Purdy Library...This has been brought up in our safety meeting and Mark Allen would like it addressed, This is not PLD's responsibility anymore and we were asked to handle it..</p>

WO	Recieved	Finished	Total	Request
FO-302090	11/18/2014	11/19/2014		The re-heat units on the 4th floor are not working. Please investigate and advise.
FO-302098	11/18/2014	11/18/2014		R/R RM 0004.10/MECH RM Supply fan 1 has a defective electrical coil and will not run. This is a high priority to electricians. Please repair or replace.
FO-302177	11/18/2014	11/20/2014		Need a Voltage verification to replace DHW recirc pump. See John Towle for location. Need ASAP
FO-302265	11/19/2014	11/19/2014		Take the Lighting stands over to room 1520, and set them up for the Blood Drive. Completed 11-19-2014 SRP
FO-302290	11/19/2014	11/21/2014		**ADDING LABORER: Remove scaffold in 1st floor janitor closet ASAP and clean up floor of any debris left from drain repair, **This needs to be removed and cleaned of debris by Thursday 3:30pm(**) PO REQ DK *Lowered Priority / Work in Progress JWT TRA
FO-302408	11/20/2014	11/21/2014		Electrician, High Priority, R/R RM 195/MECH BLR RM Replace fuse type LP-CC-15 on boiler number 2, burner motor starter/relay. Boiler down.
FO-302425	11/20/2014			Electronic handicap door at Purdy (south) entrance not functioning
FO-302492	11/21/2014	11/24/2014		JUST DO IT ASAP, breaker which supplies power to convection oven in kitchen in basement keeps tripping. This is a vital piece of equipment for President Wilson's holiday dinners. index # 227703 see Chef Jason.
FO-302479	11/21/2014			EINSTEIN BRO EXPRESS CART, BREAKER TRIPPED
FO-302491	11/21/2014	11/22/2014		Please repair Chandelier in Presidents Dining Rm.
FO-302507	11/21/2014	11/25/2014		Trade: Electricians Priority: High Clocks are not running. Please repair. Completed 11-25-2014 SRP
FO-302740	11/24/2014			R/R RM 2337 CFCU MOTOR WILL NOT START UP
FO-302766	11/24/2014			R/R ROOF AREA EXH FAN 14 (NEAR FAN #4) MOTOR HAS BURNT OUT *PLS NOTE FAN #4 COULD HAVE TAKEN #14'S PLACE*
FO-302767	11/24/2014	11/25/2014		Trade: Electricians Priority: High R/R 1ST FLR Fire alarm system indicates trouble. Please repair and reset. Completed 11-25-2014 SRP
FO-302948	11/25/2014	11/25/2014		Trade: Electrician Priority: High Tag#090-GEN-001 R/R LAB/ROOF Rooftop generator is still in alarm " Low Jacket Temp" please repair.
FO-302950	11/25/2014			Trade: Electrician Priority: High Tag#096-HWP-001 R/R RM 530/MECH RM Speed drive for heating pump #1 does not work, have to run in hand. Ron Weiss was out this past summer and said it needed a new board, need to get this drive working to get the heat in
FO-302951	11/25/2014			Trade: Electrician Priority: HighTag#096-HWP-002R/R RM 530/MECH RM Speed drive for heating pump #2 does not work, have to run in hand. Ron Weiss was out this past summer and said it needed a new board, need to get this drive working to get the heat into
FO-302973	11/25/2014	11/25/2014		Electrician R/R 1ST FLR repair fire panel trouble alarm. Priority high. Completed 11-25-2014 SRP
FO-303005	11/25/2014			Repair plug strip in room 9245.
FO-303065	11/26/2014			MOTOR NEEDS REPLACING ON UNIT HEATER RM 1355 HEATING FAN NOT WORKING
T - Locksmith			2	
FO-300817	11/5/2014	11/5/2014		612-110514 - To cover the cost of 1 core change and 2 keys. Key fits door 1322 Scott Hall "NTE \$100.00"
FO-301422	11/13/2014			janitors storeroom/office key broke off/or some type of obstruction can not lock door Door # 13, basement
T - Pipefitter			44	
FO-300327	11/3/2014	11/4/2014		Fitters, please repair steam leak on AHU-2. Priority: high ,,,,,,,,,,,,,,,,,, ME/11-3-14 ,,,,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-300329	11/3/2014	11/3/2014		fitters please repair leaking condensate pipe behind AC-3.priority high..... JH/11-3-14
FO-300377	11/3/2014	11/3/2014		Repair nipple leak on steam coil in hallway near room 3218 EA/11-3-14
FO-300695	11/4/2014	11/5/2014		trade pipe fitters priority high please R/R 6149/MECH RM replace or repair relief valve on #2hydronic boiler they just put a new one on last week and now the new one is leaking pretty bad thank you EA/11-5-14
FO-300730	11/4/2014	11/5/2014		Pipefitters -- Priority High 2nd Radiator from entrance leaks (no part #), onto 1st floor entrance ME/11-5-14
FO-300731	11/4/2014	11/5/2014		Pipefitters -- Priority High Radiator vent leaks in 2nd floor ladies restroom..... ME/11-5-14
FO-300861	11/5/2014	11/6/2014		There is a heater in the vestibule off Canfield with a loud EP switch in it, please have plumbers change it out. JH/11-6-14
FO-300949	11/6/2014	11/7/2014		steamfitter please install bypass and new regulating valve onAC-2,also verify if steam is flowing through Coils.priority High !! ME/11-7-14
FO-300959	11/6/2014			Active ceiling leak - Drywall damaged . Water is not pouring in but you can hear a steady dripping above ceiling. I may be a steam leak on second floor 2009 Science Hall causing it ME/11-7-14
FO-300967	11/6/2014			RM 1631 LEAK COMING THROUGH LIGHT FIXTURE. Engineer investigated. Found leaking heating control valve. Transferred to Fitters for replacement..... JH/11-7-14
FO-301084	11/10/2014	11/12/2014		RM 3012 CEILING LEAK ME/11-10-14
FO-301113	11/10/2014			Fitters, please repair leaky seal on condensate pump in room 11. Priority: high RC/11-11-14
FO-301135	11/10/2014	11/12/2014		Fitters: Please replace bad hot water v.a.v. box coil control valve. Both hot water supply and return valves are closed until valve is replaced. FO-301121. high priority..... JH/11-11-14
FO-301236	11/11/2014	11/12/2014		LAB 3159 CEILING LEAK EA/11-11-14
FO-301300	11/12/2014	11/13/2014		Fitters, please repair leak in steam coil on AHU-1. Priority: high..... ME/11-13-14
FO-301376	11/12/2014			PIPEFITTER: R/R BSMT @ ENTRY WAY OF 400 STE REPAIR/REPLACE 1inch LEAKING HYDRONIC LINE JH/11-13-14
FO-301386	11/12/2014	11/13/2014		Steamfitter, High; Please cracked nipple at pressure gauge on steam main in fan room at fan AHU-3..... ME/11-13-14
FO-301441	11/13/2014	11/17/2014		steamfitter R/R PH please repair leaking 2nd preheat coil in AC-10,priority High..... JH/11-14-14
FO-301526	11/13/2014			BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH RM. Engineer found drip coming from 3" trap. Unable to do anything further due to Theater Performance. Work order transferred to plumbers for trap repair/replacement. EA/11-17-14 ,,,
FO-301537	11/13/2014	11/14/2014		4th floor kitchen has a ceiling leak. Did place a garbage can under the leak..... ME/11-14-14
FO-301578	11/14/2014	11/14/2014		**Duplicate / Refer to FO#301579 JWT please have pipe fitters repair a overhead leaking condensate line in room 0341 It is leaking over the condensate pumps and tank. 3/4 inch line. high priority due to flat floor in mechanical space that may leak in
FO-301579	11/14/2014	11/18/2014		please have pipe fitters repair a overhead leaking condensate line in room 0341 It is leaking over the condensate pumps and tank. 3/4 inch line. high priority due to flat floor in mechanical space that may leak in hallway. EA/11-17-14
FO-301580	11/14/2014	11/19/2014		please have pipe=fitters add 4 1/2 inch drain lines from chill water coil. when opened drains in to hall way. high priority EA/11-15-14

WO	Recieved	Finished	Total	Request
FO-301594	11/14/2014	11/14/2014		SteamFitters Priority high R/R RM 000.01/MECH RM Please r/r #5 AHU THATS leaking dripleg on steam line for ahu-5- water is leaking on hallway floor. Slip and fall hazard. Please r/r leaking dripleg on steam line for ahu-5.....EA.....11-14-14
FO-301611	11/14/2014	11/18/2014		Trade: Pipefitters Priority: High Faculty office 3027.1 complains of high temperature, high humidity and odors. Coils are leaking in plenum and condensate is being delivered to the office. Follow up to FO 301454. JH/11-15-14 ,,,,,,
FO-301609	11/14/2014	11/17/2014		RM 101.2 CELING LEAK ,,,,,,,,,, ME/11-15-14 ,,,,,,,,,,
FO-301693	11/14/2014	11/17/2014		steamfitters R/R RM 355 please repair/replace leaking unit heater trap in bay area,priority High ,,,,,,,,,, JH/11-17-14 ,,,,,,,,,,
FO-301745	11/16/2014	11/17/2014		(**) PO REQ DK FITTERS: R/R RM 1195/MECH-BLR RM PLEASE REPLACE GASKET TO #2 BOILER MAIN STEAM LINE FLANGE TO NONRETURN VALVE. LEAKING (HIGH PRIORITY) ,,,,,,,,,, EA/11- 17-14 ,,,,,,,,,,
FO-301751	11/17/2014	11/17/2014		R/R PH REPAIR AHU #2 LEAKING COIL ,,,,,,,,,, ME/11-17-14 ,,,,,,,,,,
FO-302043	11/18/2014	11/18/2014		Trade: Pipefitter Priority: High Please repair leaking steam coil in AHU 1. ,,,,,,,,,, ME/11-18-14 ,,,,,,,,,,
FO-302102	11/18/2014	11/18/2014		1ST FL COPPER PIPE NEEDS REPAIR, FROZEN PIPE 1ST FL RADIATOR BUSTED, WATER SHOOTING OUT ,,,,,,,,,, EA/11-18-14 ,,,,,,,,,,
FO-302134	11/18/2014	11/18/2014		*Duplicate / Refer to FO#301534 Steam radiator leaking very badly in room 162. Need this replaced right away high priority.
FO-302136	11/18/2014	11/18/2014		*Duplicate / Refer to FO#301533 Bad steam leak on radiator elbow against wall. Very high priority. Have pipe fitters repair or replace
FO-302197	11/19/2014			Pipefitters: MED High Priority. R/R RM 00011/MECH RM Please repair (5) steam leaks in AHU-7 fin-tube heating coils. These are not relief caps, they are in the tube, 2 of 5 are major leaks.,,,,,,,,,, EA/11-24-14 ,,,,,,,,,
FO-302198	11/19/2014	11/25/2014		Insulation: MED High Priority. R/R RM 00011/MECH RM Please insulate area between heating coils approximately 11ft x 3ft and 11ft x 1ft in AHU-1 to prevent false shut down of AHU-1,2,3, and 4 due to cold spots in air handler.,,,,,,,,,, CB/11-24-14 ,,
FO-302199	11/19/2014	11/25/2014		Insulation: MED High Priority. R/R RM 00011/MECH RM Please insulate area between heating coils approximately 11ft x 2ft and 11ft x 1ft in AHU-7 to prevent false shut down of AHU-7, 6, 5 due to cold spots in air handler.,,,,,,,,,, CB/11-24-14 ,,,,,,
FO-302316	11/19/2014	11/20/2014		1ST FL RADIATOR BURST IN ATRIUM, WATER SHOOTING OUT Engineer reported vestibule HW finned tube at main entry froze & split. Finned tube supply isolated. Doors left open to allow building air to provide some heat to vestibule. The 2nd finned tube hea
FO-302423	11/21/2014	11/21/2014		Leaking air vent on radiator on east wall of auditorium. There is an event on 11-21-14 and vent is noisy. Please check & repair ,,,,,,,,,, EA/11-21-14 ,,,,,,,,,,
FO-302743	11/24/2014	11/25/2014		CEILING LEAK. 1ST FLOOR NEAR FRONT DOOR. ,,,,,,,,,, JH/11-24-14 ,,,,,,,,,,
FO-302755	11/24/2014			Dr. Frade's office ceiling is leaking again. Please repair the ceiling. I have already contacted custodial services for the carpet clean up. suite# 330 ,,,,,,,,,, EA/11-24-14 ,,,,,,,,,,
FO-302764	11/24/2014	11/25/2014		CEILING LEAK. BASEMENT WOMEN'S RESTROOM 0106.,,,,,,,,,, ME/11-24-14 ,,,,,,,,,,
FO-302784	11/24/2014			1ST FL TO THE RIGHT OF ENTRANCE CEILING LEAK, LEAKING ON PROPERTY ,,,,,,,,, EA/11-24-14 ,,,,,,,,,,
FO-302968	11/25/2014			Trade: Pipefitters Priority: High Please repair steam leak in AHU #3 heating coils. ,,,,,,,,,, ME/11-25-14 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-303087	11/28/2014			please investigate large steam leak in mech room in basement, room 11
T - Plumber			49	
FO-300366	11/3/2014	11/3/2014		PLUGGED TOILET. 4TH FLOOR MEN'S RESTROOM. HANDICAP STALL..... MM/11-3-14
FO-300369	11/3/2014	11/4/2014		1ST FL HALLWAY NEWLY INSTALLED WATER FOUNTAIN, WATER TASTE SALTY AND LIKE RUST GS/11-3-14
FO-300374	11/3/2014	11/4/2014		BSMT WOMENS RR NEAR KITCHEN 00012 ONLY TOILET IS OVERFLOWING BELIEVE ITS CAUSING SEWER PUMP TO ALARM MP/11-3-14
FO-300379	11/3/2014	11/4/2014		repair toilet separating from wall 2ed floor mens in the animal quarters MM/11-3-14
FO-300832	11/5/2014	11/5/2014		1sT FL WOMENS RM, FAR RIGHT STALL LEAKING BADLY MP/11-5-14
FO-300833	11/5/2014	11/21/2014		4TH FL MENS RM FAR RIGHT SINK NOT WORKING MM/11-5-14
FO-300834	11/5/2014	11/5/2014		*Duplicate/ Refer to FO#300123 JWT Plumbers -- Priority High Floor trap in 2nd floor ladies restroom does not prevent the smell of sewer gas entering restroom..... GS/11-5-14
FO-300863	11/5/2014	11/7/2014		TOILET IS CONTINUOUSLY FLUSHING. LADIES RESTROOM. ROOM 1600..... GS/11-7-14
FO-300871	11/5/2014			R/R RM 5324 ONLY SINK HAS A LEAKY FAUCET (wtr comes out when faucet is on disrupting experiments)
FO-300900	11/6/2014			CEILING LEAK. ROOM 3202..... GS/11-6-14
FO-300968	11/6/2014	11/12/2014		In the Ladies restroom on the 1st floor, the 5th sink's faucet runs constantly. GS/11-7-14
FO-300990	11/7/2014	11/20/2014		WATER IS RUSTY - 2ND FLOOR WOMEN'S RESTROOM. (TOILETS AND FAUCET) GS/11-15-14
FO-301062	11/9/2014	11/11/2014		*Duplicate/Refer to FO#301062 JWT *Negative for Asbestos in ceiling Material In the lower level men's room water is leaking onto the floor. It appears to be coming from the closet near the men's room. The theatre has performances beginning this comin
FO-301089	11/10/2014	11/10/2014		RM 1348 SINK LEAKING BADLY MM/11-10-14
FO-301108	11/10/2014			2ND FL WATER FOUNTAIN OUTSIDE 226 NOT WORKING MP/11-13-14
FO-301115	11/10/2014			LOCKER RM DRINKING FOUNTAIN COMING AWAY FROM WALL MP/11-11-14
FO-301233	11/11/2014	11/11/2014		The 4th floor women's bathroom handicap stall. The toilet is stopped up..... MM/11-11- 14
FO-301285	11/11/2014	11/12/2014		Replace seats springs and stem for delta bar sink faucet in room 4011 GS/11-11- 14
FO-301377	11/12/2014	11/13/2014		R/R RM 5545 ONLY SINK HAS A STEADY STREAM OF WATER COMING FROM FAUCET MM/11-13-14
FO-301379	11/12/2014	11/13/2014		PLUGGED SINK. 1ST FLOOR WOMEN'S RESTROOM..... MP/11-13-14
FO-301385	11/12/2014	11/13/2014		R/R RM 1324 (ONLY URINAL) Men's urinal is not flushing. MM/11-13-14
FO-301496	11/13/2014	11/13/2014		*Moister sensor detected water on floor and shut down booster pump. Sensor Reset / Water Restored NO WATER PRESSURE IN THE BLDG
FO-301508	11/13/2014	11/19/2014		Plumbers - Floor Drain in the Exterior Boiler Room under the South End of the DA Tank is plugged up. Call Lee at 734-417-6192. MM/11-15-14
FO-301526	11/13/2014			BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH RM. Engineer found drip coming from 3" trap. Unable to do anything further due to Theater Performance. Work order transferred to plumbers for trap repair/replacement. EA/11-17-14 ,,,
FO-301530	11/13/2014			Shower is leaking onto the floor in the NE corner hallway. There is a trashcan collecting the water. MM/11-17-14
FO-301546	11/13/2014	11/17/2014		The janitors' closet on the low level/common level has a leak coming from it. The floor was wet outside the door which is next to the ATM MM/11-17-14

WO	Recieved	Finished	Total	Request
FO-301543	11/14/2014	11/13/2014		**Duplicate / Refer to FO#300204 Engineer Found drain pan leak in rm 2111 that is leaking into the ceiling of rm 1111. Please repair leaking drain pan.
FO-301599	11/14/2014	11/26/2014		Plumb Med. to High Priority Please repair leak on glass drain line above door in mechanical rm 0257. Com plaints of bad smell in area. GS/11-17-14
FO-301689	11/14/2014	11/20/2014		6204 WOMENS RM CLOGGED TOILET MM/11-17-14
FO-301744	11/17/2014	11/17/2014		Winterize Football Stadium / Press Box MP/11-17-14
FO-301756	11/17/2014	11/25/2014		R/R 1ST FLR WOMENS RR ONLY SINK WILL NOT DRAIN MP/11-24-14
FO-301849	11/17/2014	11/18/2014		FAUCET IS CONTINUOUSLY RUNNING. BASEMENT WOMEN'S RESTROOM. MM/11-18-14
FO-302086	11/18/2014			4TH FL DRINKING FOUNTAIN HAS LEAK, WATER LEAKING ON FL MP/11-18-14
FO-302123	11/18/2014			Three compartment sinks leaking from faucets in cold kitchen. Repair needed by Tuesday, November 25 per health department inspection. GS/11-24-14
FO-302151	11/18/2014	11/25/2014		TOILET COVERED WITH BAG AND HAVE VERY BAD SMELL. 2ND FLOOR LADIES RESTROOM. INSIDE MIDDLE OFFICES. MP/11-24-14
FO-302222	11/19/2014			PLUMBERS please r/r p-trap that's leaking onto switchgear in primary room. Drain located and custodian asked not to use until cracked trap is replaced. already spoke to JT and Mike the plumber. High priority. MM/11-19-14
FO-302286	11/19/2014	11/21/2014		R/R 3RD FLR HALLWAY ACROSS FROM RM 325 DRINK FOUNT ON/PUSH BUTTON IS STUCK IN AN ON POSITION CAUSING WATER TO FLOW NON-STOP DOWN DRAIN MM/11-21-14
FO-302367	11/20/2014			**ADDING CONTRACTOR: Macomb Mechanical for Sheet Metal Support: Please remove and replace exhaust fan near basement mens room to access steam pipe repair. See Eric or Corey for location Pipefitters: BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH R
FO-302377	11/20/2014	11/20/2014		1ST FL MENS RM TO THE RIGHT OF BLDG ENTRANCE OUT OF ORDER FOR 2DAYS PLEASE FIX GS/11-20-14
FO-302419	11/20/2014	11/24/2014		Men's restroom, handicapped stall on the first floor is not working, did put an out of order sign on door for customers to not use until toilet is fixed. GS/11-24-14
FO-302435	11/21/2014	11/25/2014		FAUCET LEAK. ROOM 8314. MM/11-14-14
FO-302484	11/21/2014	11/24/2014		R/R RM 1200 S.W. WALL PIPE HAS SHUT OFF VLV THAT IS LKNG (CANNOT SHUT OFF WTR) Water dripping continuously on floor from handle in south west corner of room. GS/11-21-14
FO-302493	11/21/2014	11/25/2014		URINALS CONTINUOUSLY FLUSHING. MEN'S RESTROOM 5101. MM/11-24-14
FO-302511	11/21/2014	11/21/2014		MENS RESTROOM SINK NOT DRAINING PROPERLY MP/11-24-14
FO-302759	11/24/2014	11/24/2014		RM 1348 FL DRAIN BACKING UP, BAD ODOR MM/11-24-14
FO-303043	11/26/2014			R/R RM/STE 1600 IN THE BACK OF THE STE JANITORS CLOSET SLOP SINK FAUCET HAS A STEADY FLOW UNABLE TO SHUT OFF WTR
FO-303051	11/26/2014			R/R RM 225/ONLY SINK - FAUCET SPIGOT IS LKNG IN 3 AREAS....MM.....11-26-14
FO-303051	11/26/2014			R/R RM 225/ONLY SINK - FAUCET SPIGOT IS LKNG IN 3 AREAS....MM.....11-26-14
FO-303067	11/26/2014			Only sink in the room has a garbage disposal. The disposal does not work and the sink now has about 2-3 inches of standing water in it. Next week, the undergraduate biology labs will be having their practical exams on Tuesday, Wednesday and Thursday. C
T - Roofing			2	
FO-302732	11/24/2014			CEILING LEAK. 3RD FLOOR STAIRWELL F.
FO-302945	11/24/2014			Just outside of the doors to 3210 are three ceiling tiles that are wet/sagging on two. One of them has a smoke detector in its center. Would like the cause checked and the tiles replaced.
Medium			152	
T - Carpenter			35	

WO	Recieved	Finished	Total	Request
FO-300340	11/3/2014			Please remove ceiling grid for heat pump installations on 1st. floor. See Andy or Gordon for more information if needed.
FO-300346	11/3/2014	11/4/2014		Carpenter Med priority Re anchor opening arm on door latch to roof
FO-300361	11/3/2014	11/3/2014		RM 311 NEEDS DOOR STOP
FO-300373	11/3/2014	11/4/2014		R/R RM 241 ENT DOOR TO Restroom door needs to be fixed. The door is sticking, locking students and staff inside.
FO-300917	11/6/2014	11/7/2014		R/R RM 143 RE-ATTACH The threshold under the door leading from the hallway into Room 143 is loose. Please fix. Thank you. Dawn C.
FO-300924	11/6/2014	11/7/2014		Card swipe works fine but when the door unlocks it is jammed and have to hit it to open. Can you please have Building Engineer look at it. Thanks.
FO-301161	11/10/2014			Drywall around outside window needs to be fixed since it was damaged during the installation of the replacement glass. Also the ceiling tile needs to be put back in place.
FO-301162	11/10/2014	11/14/2014		Entrance door to Room 2111 (on south end) is hard to open. Because of that, it is hard to tell if door is locked or unlocked.
FO-301211	11/11/2014			FRONT ENTRANCE DOOR INTERIOR DOOR CLOSER IS MAKING A POPING SOUND WHEN DOOR OPENS.
FO-301228	11/11/2014	11/14/2014		The door to 24 Prentis is sticking and does not shut on its own.
FO-301250	11/11/2014			WHOLE IS CEILING POSSIBLE LEAK. ROOM 3129.
FO-301302	11/12/2014			WINDOW STUCK OPEN. ROOM 1137. (Multi-Task)
FO-301338	11/12/2014	11/25/2014		Carpenter Med Priority Replace ceiling tiles in following areas, Rm 1232, 2134, 3129 hall by 3217, 3134
FO-301339	11/12/2014	11/19/2014		Carpenter Med Priority Replace ceiling tiles in following areas, Rm 1232, 2134, 3129 hall by 3217, 3134
FO-301340	11/12/2014			Carp. Med. priority/Repair ceiling and trap door in hall leading to boiler rm. NW corner of bldg, Repair drywall above drinking fountain by 2134
FO-301459	11/13/2014	11/25/2014		**ADDING CARPENTER: Remove ceiling tile 3rd floor N/E corner for repair on emergency shower. See Mike McAlinden for location **Try to do on Monday Morning 11-17-14 NE corner of 3rd floor hallway, emergency shower is dripping. Garbage can is under i
FO-301480	11/13/2014	11/17/2014		Two ceiling panels are out of alignment, in front center of the room.
FO-301487	11/13/2014	11/14/2014		Stairwell J second floor into stairwell. Door handle is broken.
FO-301541	11/14/2014			**ADDING CARPENTER: Cut access in hard ceiling in janitor closet. See Don Bear for location PLUMBERS, PLEASE REPAIR LEAKING BACKFLOW PREVENTER ABOVE CEILING. (IN HALLWAY @ ROOM 4411). PRIORITY-LOW ,,,,,,,,,,,,,, DB/10-30-14 ,,,,,,,,,,,,,,
FO-301605	11/14/2014	11/19/2014		RM 035 PROJECTION SCREEN NEEDS ADJUSTING, PLEASE CALL HELP DESK 7-1154
FO-301612	11/14/2014	11/17/2014		Door is sticking on the inside area, latch is not aligned properly. When you turn the knob door does not open easily.
FO-302061	11/18/2014			Please repair brackets Ceiling tile is bulging and about to fall.
FO-302082	11/18/2014			Several tiles are pulling up of floor on 3rd floor hallway in front of elevator.
FO-302097	11/18/2014	11/19/2014		Room 2118 is missing a screw in the lock plate. Sometimes the door does not lock when you close it. Thank you.
FO-302096	11/18/2014			RM 137 TRIP HAZARD NEAR FRONT RIGHT OF BOARD SIDE 2 FL TILES LIFTING
FO-302241	11/19/2014	11/24/2014		Carpenter; Medium Please replace the two damage ceiling tiles in the office.
FO-302247	11/19/2014	11/20/2014		carpenter repair auto door closer 1st floor north. (609 06 N)

WO	Recieved	Finished	Total	Request
FO-302370	11/20/2014	11/24/2014		Trade: CarpentersPriority: MediumPlease caulk and seal overhangs underneath the 231 suite. Cold air is entering and causing the rooms to be cold.
FO-302371	11/20/2014			Trade: CarpentersPriority: MediumPlease repair terrazzo floor. Floor has dropped causing a uneven surface between sections. Trip and fall hazard.
FO-302486	11/21/2014			Need access panels in ceiling in basement of Thompson> we are running comm cable. Please see Andy or Gordy for specific locations.
FO-302510	11/21/2014			6350 WINDOW LEAKING
FO-302770	11/24/2014			Trade: CarpentersPriority: MediumWest auditorium door interferes with the roll down fire door to the lobby. Please move closer and/or add stops to prevent door from interfering with the fire roll down door.
FO-302773	11/24/2014			Carp. med priorityCut access hole and install panel to facilitate engineer working on controls
FO-302792	11/24/2014	11/25/2014		Door handles to Barris Lounge are malfunctioning. Please inspect and repair.
FO-302952	11/25/2014			Trade: CarpentersPriority: MediumPlease repair the basement door to the west stairway. The panic bar/latch is sticking causing difficult operation.
T - Electrician			42	
FO-300336	11/3/2014	11/22/2014		Have Electricians install controller to the middle pump for the lift pump in the basement pump room.
FO-300353	11/3/2014	11/4/2014		CLOCK IS NOT WORKING PROPERLY. (KEEPS WRONG TIME) ROOM 120. Completed 11-4-2014 SRP
FO-300405	11/3/2014	11/5/2014		Laborer please deliver two barrels of glycol to EDC penthouse.
FO-300722	11/4/2014	11/6/2014		R/R RM CUST OFC PLS RESET CLOCKS Completed 11-6-2014 SRP
FO-300779	11/4/2014	11/7/2014		Purdy Library, 1st Floor, Office Suite 122 (Home of HR Region B) Two electrical outlets stopped working. I checked the breaker panels: all on. Please correct problem for Human Resources staff. Engineer investigated. Was able to reset breaker for
FO-300793	11/5/2014			Vestibule unit heater blower motor not working. Unit Heater Motor not working. Please replace blower motor. Unit is located in the NE stairwell under the fire hose connection.
FO-300805	11/5/2014	11/12/2014		RESET CLOCKS. 1ST FLOOR NORTH AND SOUTH LOBBIES. Completed 11-12-2014 SRP
FO-300818	11/5/2014	11/6/2014		ELECTRICIANS R/R OUTSIDE-PLEASE CHECK EXTERIOR LIGHTING ON WEST SIDE OF BUILDING,GETTING COMPLAINTS ABOUT IT BEING DARK AT NIGHT PRIORITY MED
FO-300844	11/5/2014			trade labor priority medium please deliver 20 bags of salt pallets for the water softner here at bio-science thank you
FO-300953	11/6/2014			Electricians:R/R RM 00024/MECH RM please repair or replace light fixture just inside the mechanical room 024 main door. priority: med.
FO-301019	11/7/2014	11/8/2014		Replace 120 LED lamps in Auditorium due to recall.
FO-301036	11/7/2014	11/19/2014		electrician R/R RM 201/MECH RM #5 supply fan won't run contactor don't pull in ASAP
FO-301037	11/7/2014			R/R RM 253/MECH RM fan unit #11 won't run repair ASAP
FO-301058	11/8/2014	11/10/2014		Replace pump control circuit serving the condensate transfer pump set located in Mechanical room 10. The pumps will not run on hand, test or auto.
FO-301074	11/10/2014	11/11/2014		please deliver 5 pails of neutramine to scott hall room 100. steam fo-297762
FO-301075	11/10/2014	11/11/2014		please deliver 5 pails of neutramine to scott hall room 100. steam fo-297762
FO-301076	11/10/2014	11/11/2014		please deliver 5 pails of nitrite to room 100 scott hall fo297762
FO-301077	11/10/2014	11/11/2014		please deliver 5 pails of nitrite to scott hall penthouse fo-297762
FO-301082	11/10/2014	11/11/2014		please deliver 5 pails of halochlor to penthouse scott hall fo-297763

WO	Recieved	Finished	Total	Request
FO-301141	11/10/2014	11/17/2014		Install Heat to overhang on East, and northeast side of building.
FO-301214	11/11/2014			RESTROOM 2432 HAND DRYER NOT WORKING
FO-301260	11/11/2014	11/21/2014		Electricians fixed two lights in lab and the next day they went out again. This is an electrical issue not a bulb issue. Please repair.
FO-301429	11/13/2014			ELECTRICIANR/R RM 00010/MECH RM PLEASE RECONNECT SOLENOID VALVE FOR COOLING TOWER BLOW DOWN LINEMEDIUM PR
FO-301435	11/13/2014			Electricians; Medium:R/R RM 195/MECH BLR RM Please repair Unit Heater No. 2 in boiler room. Suspect bad motor.
FO-301538	11/13/2014	11/20/2014		**ADDING ELECTRICIAN: Replace light cover in room 5545. See Mike McAlinden if needed R/R RM 5545 ONLY SINK HAS A STEADY STREAM OF WATER COMING FROM FAUCET ,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,
FO-301576	11/14/2014	11/19/2014		RESET CLOCKS THROUGHT BUILDING. Completed 11-19-2014 SRP
FO-301595	11/14/2014			ElectriciansPriority med.R/R 8TH FLR Please r/r problem with return fan #4, motor shorted to ground.
FO-301729	11/15/2014	11/18/2014		*ADDING LABORER: Pick up 2 1/2" RPZ from boiler room and bring to Pipe Shop . See Don Bear (**).PO Req DK replace back flow preventer located in 1st floor boiler room.....DB/JS.....9-4-14
FO-301783	11/17/2014	11/19/2014		Restore electrical power to receptacles in Cash Office Suite 4630 AAB. 3 of 4 receptacles are without power. Completed 11-19-2014 SRP
FO-301816	11/17/2014	11/19/2014		**ADDING ELECTRICIAN: Please Identify correct power supply/ voltage on domestic water booster pumps. Please report info to John Towle to support new pump order Plumber repair/rebuild water pressure regulators on both domestic water booster pumps, ,,,,,,
FO-302292	11/19/2014	11/20/2014		electricians R/R RM 253/MECH RM please wire 3 phase motor to pump on fan unit #15 asap
FO-302293	11/19/2014			R/R RM 274/MECH RM please replace seized motor to pump servicing dance room by #4 fan unit
FO-302470	11/21/2014			EMERGENCY ELEC R/R SUB BSMT MECH RM REPAIR SOLENOID VLV ON #1 ACID SUMP PUMP Electricians disconnected Solenoid (480V Coil), and is waiting for Plumbers to replace Solenoid to connect it back up.
FO-302476	11/21/2014			The light switch in room 316 (accessed through room 308) near room 368 is broken and needs repair. Contact Muhammad Faisal at 313-577-3022 to coordinate repair.
FO-302729	11/23/2014	11/25/2014		Repair faulty circuit breaker #4 located in Panel LP-2D, located inside electrical room 2522. Serves center section of lights on the second floor. Breaker is loose in the socket and does not work. Square D, 20 amp breaker.
FO-302737	11/24/2014			Trade: ElectricianPriority: MediumR/R RM 00028/MECH RM Please repair condensate pump #2 located near AHU #1. Motor hums but does not start.
FO-302821	11/24/2014	11/25/2014		Remove screws in telephone, and leave out. Let Team Leader know when they're out.
FO-302943	11/25/2014			install heat tape on h2o lines to the Geology dept rest room soon before they freeze again
FO-302944	11/25/2014			R/R motor circuit as nesc for the unit heater near the large garage door south wall
FO-302954	11/25/2014	11/25/2014		Trade: Electrician Priority: Medium R/R 6TH FLR Please adjust automatic lighting controls. This area is no longer occupied and is only used for book storage. Lights do not need to automatically go on. Completed 11-25-2014 SRP
FO-302977	11/25/2014			PARTIAL LIGHTS WILL NOT COME ON. 2ND FLOOR.
FO-303090	11/28/2014			CHECK SANITARY SUMP PUMP AND STORM SUMP PUMP FOR OPERATION. Changed to low, waiting for parts. Copied FO-292570, check both Storm, and Sanitary pumps for proper operation, and report parts needed to Team Leader.

WO	Recieved	Finished	Total	Request
T - Locksmith			1	
FO-301068	11/10/2014	11/10/2014		999111014 2- KEYS FOR KNOX BOX @ ATEC BLDG.
T - Painter			2	
FO-300846	11/5/2014	11/10/2014		trade painters priority medium please paint office walls and floor in engineers office area thank you .
FO-302444	11/21/2014			PAINTERS: Please paint/ repair ceiling in mens restroom on the 5th floor. MED.
T - Pipefitter			33	
FO-300796	11/4/2014			Tag #090-HVU-001 Replace leaking steam stop valve to H&V unit #1 in the easst penthouse..... JH/ 11-4-14
FO-300761	11/4/2014	11/5/2014		Fitters, please repair steam coil on AHU-1. EA/11-5-14
FO-300771	11/4/2014	11/6/2014		@Thompson House; near room #120; newly installed heat pump 3" inches shorter> will need new supply and return lines..... JH/11-5-14
				Please see Andy or Gordy.
FO-300850	11/5/2014			Fitter repair leak in chilled water line between AH-3 & 4. EA/11-5-14
FO-300866	11/5/2014	11/6/2014		Pipe fitters: please repair steam leak from flanges of shut off valve to reheat coils for lecture halls. Priority: med..... EA/11-6-14
FO-301136	11/10/2014			**Fire Protection Job / Sent to David Kuffner to Vender 11-15-14 JWT Fitter replace fire pump case relief valve. Not opening.
FO-301384	11/12/2014	11/19/2014		Have pipe fitters cut and cap water lines leading to chemical tanks, and remove old chemical feed lines from same in boiler room. ME/11-14-14
FO-301387	11/12/2014	11/14/2014		Steamfitter; Medium: Repack or replace valves as needed in sub basement. Approx. 4 valves need work. ME/11-13-14
FO-301430	11/13/2014	11/20/2014		pipefitter please repair leak in ceiling room410 medium pr see engineer JH/11-14-14
FO-301465	11/13/2014			Fitters, please repair leak at union from pre-heat coils behind AHU-4..... EA/11-15-14
FO-301491	11/13/2014			Please repair leaking coil labeled 1D near AHU #1
FO-301507	11/13/2014			FITTERS, PLEASE REPAIR LEAK ON (A) CONDENSATE RECEIVER PUMP. PRIORITY-MEDIUM RC/11-14-14
FO-301509	11/13/2014	11/17/2014		Fitter replace surface blow down valve on boiler #1..... JH/11-14-14
FO-301510	11/13/2014			Trade: Pipefitters Priority: Medium Please repair or replace steam valve to AHU #1. Valve appears to be leaking through. ME/11-14-14
FO-301533	11/13/2014	11/19/2014		There are 3 radiators and not one is working in Room 60.5 at Art Bldg. Previously submitted on FO-301396.**This was an Engineering FO#/ First Request to the PipeFitters JWT 11-15-14 Engineer investigated. Found one radiator working and two (2) not
FO-301534	11/13/2014	11/19/2014		Two out of three radiators not working in Room 162 Art Bldg. Previously submitted on FO-301397 ***This was an Engineering FO#/ First Request to the Pipefitters JWT 11-15-14 Engineer checked and found 2 out of 4 radiators not working. Radiators appear
FO-301820	11/17/2014	11/18/2014		Duplicate / Refer to FO#301534 RADIATOR LEAK. ROOM 162.
FO-301821	11/17/2014	11/18/2014		STEAM VALVE LEAKING IN CEILING. ROOM 60.5.
FO-302112	11/18/2014	11/25/2014		Trade: Pipefitter Priority: Medium Please repair steam leak in AHU #3 at Life Science. The leak is in the trap bypass line..... ME/11-24-14
FO-302147	11/18/2014			FITTERS: R/R RM 540 Please replace Heating Valve in room 0540 near SOUTH DOOR. MED.....JH/11-24-14
FO-302152	11/18/2014	11/19/2014		Pipefitters --Priority Medium Radiator needs vent valve in Mens basement restroom EA/11-19-14

WO	Recieved	Finished	Total	Request
FO-302153	11/18/2014	11/19/2014		Pipefitters -- Priority Medium Please replace vent valve on radiator in women's 2nd floor dressing room ,,,,,,,,,,,,,, EA/11-19-14 ,,,,,,,,,,,,,,
FO-302154	11/18/2014	11/19/2014		Pipefitters -- Priority Medium Please replace vent valve on radiator in men's 2nd floor dressing room ,,,,,,,,,,,,,, EA/11-19-14 ,,,,,,,,,,,,,,
FO-302200	11/19/2014	11/25/2014		Insulation: MED Priority. R/R RM 00011/MECH RM Please re-hang insulation on outside of AHU-5 that was removed for repair. Approximately 10ft x 2.5ft ,,,,,,,,,,,,,, CB/11-24-14 ,,,,,,,,,,,,,,
FO-302230	11/19/2014			Replace defective union and nipple on drain line off of boiler #2. Pipefitters.,,,,,,,,,,,,,, JH/11-24-14 ,,,,,,,,,,,,,,
FO-302267	11/19/2014	11/21/2014		Radiator in office is leaking from valve. Please investigate and repair.,,,,,,,,,,,,,, EA/11-21-14 ,,,,,,,,,,,,,,
FO-302369	11/20/2014			Trade: Pipefitters Priority: Medium Please restore heat to the west entrance vestibule. Convector have been bled. There appears to be little water flow.,,,,,,,,,,,,,, EA/11-24-14 ,,,,,,,,,,,,,,
FO-302386	11/20/2014			PF Med priority R/R RM 520/DLAR Replace 1/2 in heating hot water valve rm 520. Valve not opening on call for heat ,,,,,,,,,,,,,, ME/11-24-14 ,,,,,,,,,,,,,,
FO-302449	11/21/2014			RADIATOR LEAK. 2ND FLOOR WOMEN'S DRESSING ROOM.,,,,,,,,,,,,,, EA/11-24-14 ,,,,,,,,,,,,,,
FO-302942	11/25/2014			R/R rotted 1.5" condensate line as nesc into the surge tank
FO-303001	11/25/2014			Repair steam leak near meter room (boiler area). Line can be isolated will not need shut down. See Pete Smolenyak pager 684--0870
FO-303039	11/26/2014			Please have pipefitters repair replace clogged safety valve drain piping. the water is overflowing onto the electricalconduit in supply fan #7
FO-303046	11/26/2014			Fitters: The piping to the domestic hot water heat exchanger is leaking at the union, just ahead of the PRV controller. Please repair. Medium priority. FO-301896.
T - Plumber				37
FO-300330	11/3/2014	11/5/2014		Replace faulty temporary sump pump located in Mechanical Room 179. The pump is not pumping water and runs continuously. ,,,,,,,,,,,,,, DB/11-3-14 ,,,,,,,,,,,,,, **This work order is to check temporary pump weekly until replacement self primer r
FO-300334	11/3/2014	11/5/2014		Plumbers - Men's Room off the 1300 Hallway on the North End of the Bldg next to Room 1321 1st Toilet closest to the door does not flush, Contact Engineer for details. ,,,,,,,,,,,,,, MP/11-3-14 ,,,,,,,,,,,,,,
FO-300389	11/3/2014	11/8/2014		Plumber; Medium Please clear the basement drain that is used by the restaurant garbage. The water and debris will back up onto the floor. ,,,,,,,,,,,,,, MP/11-4-14 ,,,,,,,,,,,,,,
FO-300412	11/3/2014			1ST FLR MENS RR 3RD STALL TOILET NOT FLUSHING
FO-300786	11/4/2014			R/R RM 5344 ONLY SINK HAS A STEADY LEAK COMING FROM FAUCET (ENGINEER HAS ISOLATED LEAK)
FO-300791	11/5/2014			Toilet continuously flushing – Men's locker rm – inside restroom near shower. Engineer unable to resolve. Toilet isolated. Zurn valve kit needed.
FO-300925	11/6/2014	11/8/2014		janitors closet Fawcett will not shut ooff flow of water, supply valves are closed in basement below, sink still has flow, closet is between rooms 108 and 107 ,,,,,,,,,,,,,, GS/ 11-8-14 ,,,,,,,,,,,,,,
FO-300946	11/6/2014	11/21/2014		Plumber repair leaking 1/2" cold water line to washer in AF-28a ,,,,,,,,,,,,,, MM/11-15-14 ,,,,,,,,,,,,,,
FO-300947	11/6/2014			Plumber repair/rebuild water pressure regulators on both domestic water booster pumps, ,,,,,,,,,,,,,, DB/11-17-14 ,,,,,,,,,,,,,,
FO-301073	11/10/2014			FAUCET IS NOT WORKING (POSSIBLE BATTERIES) 4TH FLOOR LADIES RESTROOM. RIGHT SINK.,,,,,,,,,,,,,, MP/11-13-14 ,,,,,,,,,,,,,,
FO-301143	11/10/2014	11/20/2014		1ST SINK LEFT HANDLE SPINS. LADIES RESTROOM 0111.,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,
FO-301145	11/10/2014	11/20/2014		SINK PIPE LEAKING. ROOM 225. ,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-301195	11/11/2014	11/17/2014		WATER FOUNTAIN IS CLOGGED. 1ST FLOOR MEN AND WOMEN RESTROOMS..... MM/11-13-14
FO-301201	11/11/2014	11/11/2014		**Duplicate Refer to 301416 JWT 1ST URINAL LEAKING AT BOTTOM. 1ST FLOOR MEN'S RESTROOM NEAR OLD STOCKROOM.
FO-301258	11/11/2014	11/21/2014		1st flr men's restroom-please repair toilet in third stall. it has been out of order for some weeks now. Thank you MM/11-13-14
FO-301297	11/12/2014			Plumbers: Women's rest room on the third floor, second toilet from the left, the pipe just below the sloan valve at the vacuum breaker connection will leak from time to time. Please repair. Medium Priority. MP/11-13-14
FO-301453	11/13/2014	11/17/2014		Plumbers: Back - flow preventer near the Radiant hot water pumps and city water main piping is dripping again. Serial number 655880. Pleas repair. Medium Priority. DB/11-15-14
FO-301505	11/13/2014	11/13/2014		*Completed JWT EMERGENCY PLUM R/R 3RD FLR NEAR RM 3432 AFTER WATER WAS SHUT OFF WHEN IT CAME BACK ON THE DRINK FOUNT WATER IS SHOOTING UP WILL NOT SHUT OFF
FO-301506	11/13/2014			R/R INSIDE STE 1600 CK BOTH MENS/WOMENS RR FOR TOILETS THAT ARE CON'T FLUSHING & PLUGGED UP MP/11-17-14
FO-301726	11/14/2014			2nd Men's bathroom-1st stall's toilet seat is detached and needs repair..... MP/11-15-14
FO-301727	11/14/2014	11/19/2014		This is the men's room in Kado Clinical Skills center. Faucent on right it not working; please repair. MM/11-17-14
FO-301733	11/16/2014			Repair leaking backflow preventer serving the temper heating water system, located near Pump 5/Pump 6 in the main mechanical room. Fixture is blowing water to waste. Currently isolated.
FO-301798	11/17/2014			Trade: Plumbers Priority: Medium R/R 2ND FLR Please repair handicapped toilet on the second floor (east side) in the men's room near 271. When the toilet is flushed the pipes in the wall are vibrating at the end of the flush..... MP/11-2
FO-301804	11/17/2014	11/17/2014		*Duplicate / Refer to FO#302348 Room 5324 - Sink clogged/draining very slow. Please fix.
FO-302122	11/18/2014	11/25/2014		4TH FLOOR WOMEN'S RESTROOM IN THE E-WING THE HANDICAP STALL TOILET IS CLOGGED. DB/11-24-14
FO-302137	11/18/2014			Large sink by door,hot and cold water faucet leaking . Sink on west wall, faucet is hard to work and and has low pressure water flow..... MM/11-24-14
FO-302185	11/19/2014			MEN'S RESTROOM #25 IN BASEMENT OF PURDY LIBRARY IS CLOGGED AND LEAKING ON FLOOR.PLEASE REPAIR..... MP/11-24-14
FO-302321	11/20/2014			MEN'S RESTROOM #14100.3 THE TOILET SEAT IS BROKEN. PLEASE REPAIR..... MP/11-24-14
FO-302347	11/20/2014			SINK LEAKING ROOMS 5324 AND 5344. SEE ENGINEER FOR MORE DETAILS. (MULTI-TASK)..... MM/11-24-14
FO-302348	11/20/2014			SINK DRAINS SLOWLY. ROOM 5324. MM/11-24-14
FO-302440	11/21/2014			R/R RM 1302/MENS RR THE 3RD STALL TOILET ISN'T FLUSHING MM/11-24-14
FO-302446	11/21/2014	11/25/2014		TOILET CONTINUOUSLY FLUSHING. 8TH FLOOR WOMEN'S RESTROOM..... MM/11-24-14
FO-302488	11/21/2014	11/21/2014		**Duplicate / Refer to FO#302511 The mens restroom marked room 125 has the sink plugged up.
FO-302970	11/25/2014			Plumber repair leaking PVC drain line on ice machine. MM/11-25-14
FO-303008	11/25/2014			SLOP SINK IS PLUGGED. ROOM 106.

WO	Recieved	Finished	Total	Request
FO-303009	11/25/2014			RM 1111 CEILING LEAK This work order is being submitted to trades for follow-up. Engineering has been informed that repair work will be scheduled for completion between Thanksgiving and Christmas Closure. Prior work order references: FO-301543,
FO-303024	11/25/2014			please repair ,leak in safety shower in room 230....DB....TT
T - Sheetmetal			2	
FO-300824	11/5/2014			Replace missing insulation on the duct work from AC-1 to the 200 suite
FO-303038	11/26/2014			please have sheet metal repair expansion joint on roof. exhaust fan 38. this fan is located on the roof. unable to adjust air pressure on fume hood.
Low			460	
T - Carpenter			71	
FO-300323	11/2/2014	11/4/2014		Hall to 0171A & B - replace 3 ceiling tiles (1 found on floor 11/2; 1 water stained but Bldg Eng said no active leak; 1 tile damaged); please replace no later than 11/4 before AAALAC site visit. THANKS!
FO-300367	11/3/2014	11/17/2014		R/R RM 2131 REPLACE 2 MISSING CLNG TILES
FO-300385	11/3/2014			TEAM LEADER TIME (NOVEMBER 2014)
FO-300715	11/4/2014	11/5/2014		Drywall entrance, from Grounds common area, to custodial / front offices.... area
FO-300782	11/4/2014			R/R RM 311 I would like to have the "D" part of a "U" shaped workstation removed. Then re-attached once the heat/cooling unit is replaced. Thank you.11/4/14 lps: Please confir w/Anthony S before doing above work order (this is a project under Comman Ce
FO-300907	11/6/2014	11/7/2014		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN ROOM 4206 & HALLWAY @RM 4228.PRIORITY-LOW.
FO-300908	11/6/2014			CARPENTERS, PLEASE REPAIR/REPLACE DOOR GASKETS ON SOUNDPROOF DOORS. (RMS- 4210, 4212, & 4228.)PRIORITY-LOW
FO-300909	11/6/2014			CARPENTERS, PLEASE REPAIR/REPLACE DOOR GASKETS ON SOUNDPROOF DOORS. (RMS- 4225, 4227, 4229, & 4233.)PRIORITY-LOW
FO-301532	11/6/2014			Current door handle on Room 128, Suite 1-A, has no lock mechanism. Have locksmith swap out existing handle for one with lock, and provide three keys.Dorothy Carter 11/13/2014 16:26 - E-mail dated 11/12/13 received from Elizabeth Roggenbuck to charge acco
FO-301007	11/7/2014	11/6/2014		SAFETY MEETING (NOVEMBER 2014)
FO-301009	11/7/2014	11/10/2014		CARPENTERS, PLEASE REPAIR DAMAGED SPLASH GUARD ON SINK AREA. PRIORITY-LOW.
FO-301046	11/7/2014	11/10/2014		JUST DO IT, please repair n/w ADA door into University Pharmacy ASAP index # 228400
FO-301063	11/10/2014	11/17/2014		CARPENTERS TO INSTALL HANDRAIL SOUTH ENTRANCE
FO-301086	11/10/2014			CARPENTERS, PLEASE REPLACE DAMAGED FLOOR TILES.PRIORITY-LOW
FO-301087	11/10/2014			CARPENTERS, PLEASE REPLACE DAMAGED FLOOR TILE IN HALLWAY NEAR ROOM 0383.PRIORITY-LOW
FO-301117	11/10/2014	11/10/2014		In UGL Auditorium there are two broken seats.
FO-301120	11/10/2014			There is a nut and bolt missing on the right side of the garage door. We have placed a green post-it note to indicate where the nut is missing.
FO-301124	11/10/2014	11/10/2014		CARPENTERS TO MAKE A SET OF STAIRS THAT ARE INSIDE THE CLOCK TOWER (NOT IN SERVICE)
FO-301126	11/10/2014			CARPENTERS TO TIGHTEN ALL THE SEATING IN BERNATH AUDITORIUM HALL
FO-301239	11/10/2014	11/20/2014		Need a locksmith to look at a door where the latch gets stuck on the striker plate. Please have someone look at it. The work order through TMA is H48957 Thank you
FO-301148	11/10/2014			Ceiling tiles were damaged when lighting crew was working on lights.
FO-301213	11/11/2014			Insurance - Police Report #W14-3140054 Please R/R cracked window. Window located in walkway between Science Hall & Life Science, 3rd floor, south facing window. Damage unknown.
FO-301220	11/11/2014			Handy man: please remove scaffolding in mechanical room by AHU-1, it was set up a few months ago for pipe fitters, the job was done but the scaffolding still sitting there and blocking part of the room. Priority: low.
FO-301304	11/12/2014	11/17/2014		Men's restroom 1st floor we have damages item, mirror and partition needs new 1

WO	Recieved	Finished	Total	Request
FO-301452	11/13/2014	11/17/2014		R/R RM 125 There are problems with the interior doors in the research lab. The researchers office door is very sticky and if you shut it it's hard to open (researcher cannot open once closed). The lock to that door is also very hard to turn and it feel
FO-301456	11/13/2014			<p>**ADDING CARPENTER: Install plywood on wall in key shop so water filter can be properly installed. See Mike Pummill when complete</p> <p>Please change filter to water fountain in break room by lock shop,,,,,,,,,,,,,,,,, MP/11-13-14 ,,,,,,,,,,,,,</p>
FO-301464	11/13/2014			R/R 2ND FLR SOUTH STRWL REPLACE MISSING/DAMAGED Floor Tile - needs to be replaced in the south stairwell
FO-301504	11/13/2014	11/14/2014		R/R 9TH FLR Stairwell door B on the ninth floor. Latch on door in not working correctly. Will not open. Safety issue.
FO-301511	11/13/2014			The emergency exit in the stairwell by room 174 on the first floor, the push bar that activates the emergency exit does not work.
FO-301606	11/14/2014	11/19/2014		Please have Carpenters cut long wooden pallet into smaller sections for disposal. Pallet is approx. 10' long.
FO-301616	11/14/2014	11/17/2014		MOUNT A NEW FIRE EXTINGUISHER HANGING RED BOARD & SIGNAGE ROOM # 1025 NEAR THE MAIN ENTRANCE
FO-301670	11/14/2014	11/17/2014		R/R Room 3321 (Electrtical Room0 Signage has fallen off the wall.
FO-301818	11/14/2014			<p>Kresge Library, 3rd Floor, Room 315</p> <p>Insurance - Cracked window in Conference room. Reported to Public Safety: Case #W143180053</p> <p>Please see Georgia Cox 106 Kresge or Richard at Purdy Check Out desk if additional information or access is needed.</p> <p>Th</p>
FO-301753	11/14/2014			R/R 14TH FLR Can the window near the restrooms on the 14th floor be sealed shut for the winter season? There is a lot of air that seeps through the windows during the cold months. Sometimes the window can also blow open and causes problems with the
FO-302851	11/14/2014			<p>desired_date: 11/21/2014funding_source: 122101funding_year: 2015preferred_billing_method: Directproject_description: Card reader on door to 1200 and 2218 need to be repaired or batteries replaced.project_name: Card Reader RepairDorothy Carter 11/24/</p>
FO-301788	11/17/2014	11/19/2014		CARPENTERS TO REPAIR LOUVERS IN A CLOSET DOOR @ THE PRESIDENTS APARTMENT PER DAVID KUFFNER
FO-301826	11/17/2014	11/18/2014		R/R RM 282 Repair latch plate for the door to room 282 mezzanine. The latch hangs up on latch plate so door does not lock.
FO-302085	11/18/2014			PS2 Lodge Srevice Dr. student entrance. The pedestrian door is in need of a new door closer. Thanks
FO-302107	11/18/2014	11/19/2014		<p>Trade: Carpenters</p> <p>Priority: Please repair leak from upper part of window in room 3027.1 in Science Hall.</p>
FO-302127	11/18/2014			Repair base board around sink in Ladies Restroom, 1st Floor, Engineering Technology Bldg.
FO-302129	11/18/2014			R/R RM 1004/WOMENS RR Repair base board around sink in Ladies Restroom, 1st Floor, Engineering Technology Bldg.
FO-302132	11/18/2014			Lower Level - Outside of hot kitchen - Floor tile replacement on both sides of diamond plate in basement hall. Small area of repair, one tile width on either side of diamond plate.
FO-302244	11/18/2014	11/20/2014		Door is not latching properly. Please call Nate (Maintenance Tech.) at 313-205-1344 when locksmith comes out. Nate has a part to the door.
FO-302264	11/18/2014	11/19/2014		Outside door is very hard to shut and lock, please have someone take a look at it. Thanks
FO-302158	11/18/2014	11/18/2014		CAPENTERS TO GRIND CEMENT FERRY EXIT
FO-302295	11/19/2014	11/20/2014		CARPENTERS TO CLEAN OUT TELECOM CLOSETS /CEILING TILES & FLOOR TILES / GLUE
FO-302362	11/20/2014			Wire covering needed in Grounds.
FO-302391	11/20/2014	11/21/2014		Locksmith, please repair lock in room 32, barrel is loose.
FO-302392	11/20/2014	11/21/2014		R/R RM 14200.70 THE ENTRY DOOR WHEN CLOSING YOU HAVER TO MANEUVER DOOR TO ALIGN IT W/LOCK IN ORDER TO CLOSE & LOCK DOOR *SECURITY PROBLEM*

WO	Recieved	Finished	Total	Request
FO-302396	11/20/2014			Carpenter glue laminate panels to wall in both elevators.
FO-302433	11/21/2014			R/R RM 150/SVC CTR THE CHAIR NEXT TO MY DESK DRAWER WILL NOT STAY CLOSE
FO-302455	11/21/2014	11/25/2014		Please fix Ms. Lisa Turner B.A.'s office door. It will not close all the way and then randomly shuts, which scares her.
FO-302473	11/21/2014			R/R Rm. 2603 has a ceiling tile panel that is rusted out and needs to be replaced.
FO-302481	11/21/2014			R/R RM 00012/KITCHEN Ceiling grid and tile repair at the door leading into the hot kitchen on the lower level of McGregor. I will email a photo to Rick Massa for reference. Ceiling appears to have dropped causing the door to scrape. Health inspection
FO-302502	11/21/2014			Replace loose/missing overhead door edge sealing on the East end overhead door located on the South side of the building. Cold air is infiltrating the warehouse.
FO-302504	11/21/2014			Replace loose/missing overhead door edge sealing on the West end overhead door located on the South side of the building. Cold air is infiltrating the salt room/warehouse.
FO-302739	11/24/2014	11/24/2014		Carpenters, please repair/replace broken lock on handicap stall in 1st floor women's restroom. (Lock is sitting on top of the toilet paper dispenser)
FO-302803	11/24/2014			Historic wood window shutter needs to be put back on the track in the 2nd floor meeting room.
FO-302804	11/24/2014			University Services Building Rm 134 (Next to AVP);Hang folder holder (mailbox) on wood door with screws.
FO-302841	11/24/2014	11/25/2014		Carpenter repair door latch to roof in freezer room 3rd floor.
FO-302842	11/24/2014			Carpenter repair wooden steps on lower roof west side.
FO-302858	11/24/2014	11/25/2014		Repair door entrance to gym 110 on the south side. Gym door will not close....See Bob Ostrowski on specs.
FO-303020	11/24/2014			Insurance - Police Report #W14-3290046 - Hallway outside 153, 1st floor Knapp in the Child Care Center. There are two glass panes that need replacement. One has a crack that is gradually getting bigger. The other has a hole in it
FO-302989	11/25/2014	11/25/2014		Insurance Police Report #W14-3290031- Please R/R Room 4364- window which has been blown out. Need cleanup and boarding of the big hole where the window was.
FO-303022	11/25/2014			LOCKSMITH REPAIR please repair non working Detex panic exit device located on the south exit to the service elevators, will not open by key or by pushing the panic handle. JUST DO IT, index # 227149
FO-303003	11/25/2014			R/R RM 113.10 Repair cracked floor at the south entrance to the racquetball/squash court galleries. See Bob Ostrowski on specs.
FO-303013	11/25/2014	11/25/2014		Locksmith called in to open door for student last Saturday night, 11/22/14.
FO-303016	11/25/2014	11/25/2014		Key broke off in lock, locksmith called to extract on 11/23/14.
FO-303059	11/26/2014			R/R 2ND FLR outside of the restroom/2126 there are tiles missing, possible trip hazard, small area by the column
FO-303072	11/26/2014			LOCKSHOP pleaseR/R RM 0195/MECH RM lock to west facing exterior boiler room door. Door does not close on it's own. You must put in your key in hold locking mechanism in to close door.
FO-303076	11/26/2014			Requesting to put basic ceiling tiles in the 0006 sub-basement area. The lights are in place but no ceiling tiles to cover the pipes and fixtures. Contact: Dr. Neha Gothe (313-577-6222) nehagothe@wayne.edu
T - Electrician			134	
FO-300339	11/3/2014			Time for Team Leader for the month of November, 2014.
FO-300349	11/3/2014			There is a light out in basement storage area, voice mail was left, so call 7-1246 for further instructions. This request is being forwarded to electricians.Electrical problems too many.
FO-300352	11/3/2014			There are two lights out in men's restroom room 2238. one at the entrance and one inside the rest room.This request is for electricians all bulbs have been changed. Fixtures are electrical problems.
FO-300354	11/3/2014	11/10/2014		Several lights out in suit 2800, call Gloria at 7-4673 for specifications. Completed 11-10-2014 SRP
FO-300364	11/3/2014	11/5/2014		R/R RM 113 Reset Master clock in Cohn Building so that the clock in Room 113 reads the correct time - it is still on daylight savings time. Completed 11-5-2014 SRP

WO	Recieved	Finished	Total	Request
FO-300395	11/3/2014			upon entry one light out over the conference room. one light in the rear hallway over the copiers. room in free legal clinic. 2 EP's
FO-300406	11/3/2014	11/21/2014		Time to clean shops for the Trades for the month of November.
FO-300408	11/3/2014			Time to repair clocks throughout the University for the month of November, 2014.
FO-300686	11/4/2014	11/7/2014		Repair/Replace bad clock in hallway near room 208. Completed 11-7-2014 SRP
FO-300704	11/4/2014	11/25/2014		Electrician R/R 4TH FLR replace thermal overload for cooling tower #3 high speed.
FO-300713	11/4/2014	11/20/2014		LABORER, PLEASE PICKUP & DROPOFF BOILER CHEMICALS. 1) QUEST 250S-#17010030 -30 GAL 2) NEUTRAMINE XF-P - #17070042 - 30 GAL 3) OXYKOR S1100-P - #17010000 - 30 GAL FO-274376 PRIORITY-LOW
FO-300724	11/4/2014	11/4/2014		ELECTRICIANS TO DROP LIGHT FIXTURE TO INSTALL HEAT PUMP ROOM # 114
FO-300740	11/4/2014	11/7/2014		there are 4 EP's to the right just as you get off the freight elevator...in front of office 2614 Completed 11-7-2014 SRP
FO-300742	11/4/2014	11/20/2014		There is 1 electrical problem near the guard's desk. The bulb partially cracked inside of the fixture. (1st floor.)
FO-300744	11/4/2014			Rm 123 - 2 EP - Broken fixture dangling.
FO-300745	11/4/2014	11/6/2014		Rm 246 - 2 EP
FO-300756	11/4/2014	11/11/2014		Electrician R/R GARAGE remove ceiling light in garage to inspect for water leak above the ceiling.
FO-300757	11/4/2014			ElectricianR/R 3RD FLR repair HHW pump #1 for animal facility in 3rd floor mechanical room.
FO-300785	11/4/2014	11/13/2014		room 419 has 6 electrical problems and room 422 has 1 electrical problem. room 408 has 2 EP's, room 415 has 6 EP's. room 422.1 has 2 EP's, and Kitchen has 1 EP.
FO-300825	11/5/2014			R/R 3RD FLR MENS RR Please fix-electric hand dryer, 3rd flr men's restroom-not working-Thank you
FO-300867	11/5/2014			the tasks are one exit light loosely hanging and one wrap around light.in main auditorium (2 EP's) contact Michael Donahue theater manager for location.
FO-300868	11/5/2014			Clock is ahead one hour. Please adjust clock back one hour.
FO-300870	11/5/2014			R/R 2ND FLR Clocks is the Kado clinical skills center need to be adjusted. Room numbers were not available on drop down menu.Room 215 clock behind 3 hours; Room 225 Clock ahead an hour; Room 226 Clock ahead an hour; Room 228 Clock ahead 1 hour. Staff i
FO-300879	11/6/2014	11/6/2014		Safety Training in elect. shop
FO-300887	11/6/2014	11/26/2014		Room 3341 has 1 electrical problem. Completed 11-26-2014 SRP
FO-300888	11/6/2014			Half of the lights are out in Room 2156. There are 2 electrical problems in 2156. Enter thru room 2190 to get there
FO-300889	11/6/2014			The hallway outside of room 1237 has 1 electrical problem.
FO-300914	11/6/2014	11/10/2014		R/R BSMT Central Corridor Basement , between labs 310 &320 Clock needs to be set EST. Clock back corridor (basement) reset clock to EST. Cafeteria clock by cashier (north face) needs to be reset to EST. Green Lecturer Hall, both clocks need to be rese
FO-300965	11/6/2014	11/28/2014		1 EP located in front of last stall on first floor men's restroom. Completed 11-28-2014 SRP
FO-301026	11/6/2014	11/12/2014		Just Do It. Request WSU electricians to turn on lights at Tom Adams Field for WSU intrmaurals on Wednesday November 12th. 6:00 report to Cass. 6:30 lights on. 10:00 lights off. 10:30 out at Cass. Use index #227980 for billing
FO-300966	11/6/2014			1 EP located in front porch.
FO-300969	11/7/2014			Please install timers on State Hall Old Wing AHU's 1 & 2
FO-300970	11/7/2014			Please install timers on Supply Fans 1,2&3

WO	Recieved	Finished	Total	Request
FO-300983	11/7/2014			The Men's restroom on the 14th floor has an electrical problem.
FO-300986	11/7/2014	11/21/2014		There is a light over the stairwell going toward McGregor that can't be reached without a scaffold.
FO-301038	11/7/2014	11/28/2014		repair clock near room 2344 Completed 11-28-2014 SRP
FO-301039	11/7/2014	11/28/2014		repair clock on second floor near bridge leading to Mazurek. Completed 11-28-2014 SRP
FO-301059	11/8/2014			Replace faulty motor located on #2 condensate transfer pump in Mechanical Room 10. The motor bearings bind after the pump runs only a minute or two, causing the pump starter to trip on overcurrent.
FO-301085	11/10/2014	11/18/2014		the fixture is located between the second floor and the basement. one electrical problem. stair 2 stairwell. Completed 11-18-2014 SRP
FO-301122	11/10/2014			The EXIT sign outside of room 249 has 1 electrical problem.
FO-301142	11/10/2014	11/11/2014		Trade: Laborer Priority: Low Please remove damaged door located on the roof near the 4th floor roof access near the elevator.
FO-301140	11/10/2014	11/10/2014		This is to order Vise grips for the Electricians.
FO-301144	11/10/2014	11/14/2014		Repair bad clock in room 523. Completed 11-14-2014 SRP
FO-301146	11/10/2014	11/28/2014		Repair clock in room 2105. Completed 11-28-2014 SRP
FO-301147	11/10/2014	11/28/2014		Repair bad clock in room 2106. Completed 11-28-2014 SRP
FO-301150	11/10/2014	11/17/2014		Repair bad clock in room 2115. Completed 11-17-2014 SRP
FO-301152	11/10/2014	11/17/2014		Repair bad clock in room 2125. Completed 11-17-2014 SRP
FO-301186	11/10/2014			Room 324 is a computer lab that also functions as a testing room for students. Overhead lighting problem. On the right side of the room looking in the 3rd row ceiling panel light is out, and on the left side of the room the 1st rom ceiling panel light i
FO-301189	11/11/2014			The Donor Gallery has 7 electrical problems. (1st floor)
FO-301208	11/11/2014			The lights at the instructor station in room 13 are not functioning at all. There are 6 of them - they are controlled by 2 switches with dimmers at the instructor station. Please have electrician look and report back to Ruth Jensen, Suite 100, Cohn.
FO-301216	11/11/2014			need scaffolding for the West dock heaters @ 1200 Holden. Please contact Dean Dennis when ready.
FO-301296	11/12/2014	11/12/2014		Time clock for paint shop lunch room.
FO-301298	11/12/2014			STAIR A between the 9th floor an the Penthouse has 1 electrical problem. It's too high to reach.
FO-301299	11/12/2014	11/17/2014		Request 3-phase wiring to be run on heat pump units @Thompson House 1st. floor; rm#114 & unit near elevator. Please see Andy or Gordy.
FO-301301	11/12/2014	11/12/2014		Electricians, R/R BSMT please reset master clock. Completed 11-12-2014 SRP
FO-301305	11/12/2014			This is to add lighting to the crosswalk at the Lodge Freeway service drive on the east side.
FO-301308	11/12/2014			Room 1520 EDC in the Main Engineering Building has 1/2 of its lights out that need to be replaced. Thank you. There are 20 light bulbs that will be ordered for this area By Eugene Owens...
FO-301318	11/12/2014	11/25/2014		Lights out in room 349, there are two panels with two lights out in each. One electrical problem. This request is being forwarded to electricians.

WO	Recieved	Finished	Total	Request
FO-301333	11/12/2014	11/14/2014		R/R front and back doorbell
FO-301372	11/12/2014			Install light at front of Building, and move Blue Light up.
FO-301380	11/12/2014			4th floor special events office. Jeff block needs all non-working light bulbs replaced ASAP. Lets get to work on this immediately. after installing 30 bulbs...4-(ep's) were found in this area....
FO-301398	11/12/2014	11/19/2014		R/R 3RD FLR Wired clock in room 385 & 389 not working. It started making a high pitched wailing sound. The clock appears to need replacement. See Muhammad Faisal, 577-0931, for more information. Completed 11-19-2014 SRP
FO-301436	11/13/2014			Electricians Low:R/R RM 103 Repair light fixtures in vestibule.
FO-301490	11/13/2014			2 lights out in hallway (closest to Suite 4650)... there are 2 ep's in this location...
FO-301523	11/13/2014			17 total fixtures out on second floor hallway.
FO-301524	11/13/2014	11/24/2014		Two fixtures out in room 264.
FO-301547	11/13/2014			Hallway corridor outside room 352- need lights replaced- 50% of the lights stopped functioning all at once- may be a power issue
FO-301570	11/14/2014	11/25/2014		Wall clock is ahead an hour as if it was never turned back when daylight savings time ended. Completed 11-18-2014 SRP Completed 11-25-2014 SRP
FO-301571	11/14/2014			R/R MALL Observed open junction box at planter on mall between Alumni & Law Library
FO-301589	11/14/2014	11/17/2014		6 lights out - east side back stair well. these lights have EP's that are too high to label...this will be forwarded to the electricians
FO-301596	11/14/2014			Cubicle area outside of room 3219 has a desk light out. Please repair/replace. There is 1 electrical problem.
FO-301741	11/17/2014			There is 1 electrical problem in the women's restroom on the 7th floor.
FO-301764	11/17/2014			There is 1 electrical problem in the Men's restroom on the 2nd floor. West end.
FO-301784	11/17/2014			Request for four heat pumps to be delivered to Thompson House 3rd. floor from stockroom. Thank You
FO-301823	11/17/2014	11/17/2014		Electricians to attend TMA feedback meeting Completed 11-17-2014 SRP
FO-302050	11/17/2014	11/22/2014		1st Floor - Front Desk - We have a panic button that was linked to WSU Police. The line is currently disconnected. We want the line re-connected and the panic button to be in full working order.
FO-302027	11/17/2014			Need two lights replaced in 1st floor women's bathroom. There is an EP just as you come into womens restroom...
FO-302044	11/18/2014			Please replace ceiling light out in ladies restroom. 4th flr, COE thank you. This task is an electrical problem. A REQUEST FOR ELECTRICIAN IS BEING MADE.
FO-302074	11/18/2014			Margherio conference center elevator and the entrance light bulbs burned out, please replace. The entrance light bulb has 1 electrical problem and the elevator light bulb has 1 electrical problem Finished 6/26/2014LT Electricians to repair entrance li
FO-302116	11/18/2014	11/18/2014		Please R/R the Light Pole in C&IT Parking Lot, Waste Disposal Truck hit the light pole. Police Report number W14-322002. Blake from Public Safety call FP&M to report damage.
FO-302168	11/18/2014	11/25/2014		Room 2323 has 1 electrical problem. Hallway outside of room 9335. has 1 electrical problem. There is an orange rubber end that prevents me from taking the fixture down.
FO-302170	11/18/2014	11/25/2014		the fixtures are located above the door way 316. there are two EP's
FO-302186	11/18/2014			Need ELECTRICIAN to set the timer for the outside lollipop lamos on Cass Ave outside the Hilberry Theatre to be set to turn on at 5 p.m. and turned off at 7:30 am in the morning. Please see Michael in Hilberry Theatre box office if you have questions/pro
FO-302195	11/19/2014			ELECTRICIANS R/R RM 119/IT OFC please r/r small OA fan in server room at University Services. May be tripped breaker, but if so it is mismarked. Please identify correct breaker.
FO-302205	11/19/2014			Repair Ep. on third floor south side.

WO	Recieved	Finished	Total	Request
FO-302270	11/19/2014			There is a light bulb out outside of office 3125 in Electrical & Computer Engineering. If you have any questions you can contact Dories Ferris at 7-3834. Thank you... This is an EP that has the area very dim...
FO-302285	11/19/2014			EXIT sign light is out in room 233.
FO-302296	11/19/2014			Repair clock near front door in the multi purpose athletic complex. (indoor tennis courts)
FO-302298	11/19/2014	11/20/2014		Repair clock near elevator 1st floor.
FO-302300	11/19/2014	11/20/2014		Repair clock near stairwell 2nd floor.
FO-302313	11/19/2014			the fixture is located between 2nd and 3rd floor landing, stair 1- exit 1. one electrical problem
FO-302329	11/20/2014	11/21/2014		Range 223 has 1 electrical problem. (2nd fl.)
FO-302330	11/20/2014	11/21/2014		Range 225 has 1 electrical problem. (2nd fl)
FO-302331	11/20/2014	11/21/2014		Hallway outside of Range 237 has 1 electrical problem.
FO-302333	11/20/2014	11/21/2014		Range 310 has 1 electrical problem. (2nd fl)
FO-302336	11/20/2014	11/21/2014		Hallway outside of room 3341.
FO-302337	11/20/2014			The entrance light has 1 electrical problem.
FO-302343	11/20/2014	11/21/2014		Pick up bad piece of railing between Structure 5, and FAB where a car has ran into it.
FO-302361	11/20/2014	11/22/2014		Hand dryer in ladies restroom not operating.
FO-302372	11/20/2014	11/20/2014		Second Floor west side of building need the clock repaired.
FO-302395	11/20/2014			ElectricianR/R RM 201/MECH RM disconnect power to motor for reheat pump #4.
FO-302409	11/20/2014			third floor men's room facing DeRoy building. 1 EP
FO-302410	11/20/2014	11/24/2014		the bulbs have been replaced. lights wont stop strobbing. the fixture is located in the front handicapped entrance stairwell. 3rd floor landing.
FO-302411	11/20/2014			in the third floor hallway outside of blue liture. one EP
FO-302412	11/20/2014	11/25/2014		one fixture out in room 2111.
FO-302434	11/21/2014			The hallway between room 147 and the stairwell facing the art gallery has 1 electrical problem.
FO-302466	11/21/2014	11/21/2014		Repair clock on second floor next to elevator.
FO-302482	11/21/2014			inboard bearing on AHU-3 motor making noise
FO-302495	11/21/2014			Rm. 1236 has 4 floor covers missing off of the electric circuits that need to be installed.
FO-302494	11/21/2014			Replace faulty light switch controlling the 1st-floor radiant heating pump with a single-pole starter with overload.
FO-302497	11/21/2014			Replace light switch controlling the 2nd-floor radiant heating pump with a single-pole starter with overload.
FO-302501	11/21/2014			Replace light switch controlling the Reheat radiant heating pump with a single-pole starter with overload.
FO-302758	11/24/2014			2 fixtures out in room 0237. priority: Emergency
FO-302794	11/24/2014			Clock is not working. Please repair.
FO-302798	11/24/2014	11/25/2014		ELECTRICIANS TO PROVIDE THE POWER TO THE ADA OPENER SOUTH PURDY ENTRANCE INSIDE VESTIBULE DOOR
FO-302800	11/24/2014	11/24/2014		Time for Electrician to take vehicle to shop for oil change.
FO-302801	11/24/2014			Four ballasts with fluorescent lights out (3 with no tubes working, one with one out and one almost out). Two of these are right over our desks. This is in the bldg coordinator area...there are 3 EP's in this area...
FO-302806	11/24/2014			Two ballasts of fluorescent lights completely out. ther is 1 EP in this room...against the back wall.
FO-302835	11/24/2014			The first fixture upon entering the 4th floor ladies room.
FO-302859	11/24/2014			R/R RM 150 Change 7 burnt out lights in ceiling of pool...Left will be needed. Please see Bob Ostrowski on specs... Please rush. Thank You.
FO-302949	11/25/2014			Trade: Electrician/Laborer Priority: LowR/R RM 4505/MECH RM Please remove old refrigerated air dryer from EDC penthouse mechanical room and dispose.
FO-302955	11/25/2014			The spot light outside of room 1600 has 1 electrical problem.
FO-302956	11/25/2014			Room 330 has 2 electrical problem. (Basement)
FO-302957	11/25/2014			Room 360 has 2 electrical problems. (Basement)

WO	Recieved	Finished	Total	Request
FO-302958	11/25/2014			STAIR B between the 3rd and 4th floor has 1 electrical problem.
FO-302985	11/25/2014			Please have Maintenance Laborer take old copier from FP&M Stockroom to Property , Holden Warehouse.
FO-303006	11/25/2014			DENNIS/Laborer-R/R RM 0195/MECH RM please deliver 1) 8, 5 gallon jugs of OXYKOR to boiler room at 5425 Woodward. OXYKOR has been pulled from store and is across from store counter. Thanks.
FO-303010	11/25/2014			1st floor men's restroom there is 1 electrical problem.
FO-303033	11/26/2014			TMA training for the Buzz and Paul
FO-303040	11/26/2014			ELECTRICIANS TO REMOVE 3 LIGHT FIXTURES SO THE CARPENTERS CAN REPLACE DAMAGED CEILING TILES
FO-303083	11/28/2014			This is to purchase wire mold to protect against a trip hazard on the second floor at Matthaehi swimming pool area.
FO-303084	11/28/2014			Cashier Window number#2 (Irecia Cloyd) speaker is static and not working for the staff member to hear students. Please contact Lavinia @313-577-3650 9/11/14 lps: Chng to Est for Main (requester called & said this is an urgent req) 9/16/14 11:30 tlj: P
FO-303085	11/28/2014			Purdy Library 2nd and 3rd Floors Lamp replacement requested for built in display cases. These lights need to be retro fitted. This request is being forwarded to electricians. See Richard at the Check out desk for key to display cases. Thank you.
FO-303086	11/28/2014			the fixture is a flood light facing overhead tile art. Electricians need lift to repair
T - Locksmith			71	
FO-300317	11/1/2014	11/4/2014		#999-10-3-2014 2 Keys University Pediatrics Autism Center
FO-300318	11/3/2014	11/4/2014		#104-11-3-14 3 Keys and 2 Cores Room 605
FO-300386	11/3/2014	11/7/2014		KEYS & CORES (NOVEMBER 2014)
FO-300387	11/3/2014			LOCKSMITH TRAINING(NOVEMBER 2014)
FO-300797	11/5/2014	11/5/2014		#507-11-5-14 2 Keys Room 318
FO-300799	11/5/2014	11/15/2014		#127-11-5-14 6 Keys and 2 Cores Room 542.2
FO-301320	11/5/2014	11/14/2014		007-110514 - To cover the cost of 1 core change. Key fits door 385 Chemistry. "NTE \$100.00" Dorothy Carter 11/12/2014 09:41 - Received approval e-mail 11-11-14 regarding budget being loaded into the account index 142216 which is being used to fund this r
FO-300808	11/5/2014	11/5/2014		130-110514 - To cover the cost of 1 core change and 4 keys. Key fits door 1267 FAB. "NTE \$100.00"
FO-300830	11/5/2014	11/5/2014		#612-11-5-14 1 Key Lock Block Building Masker
FO-300859	11/5/2014	11/6/2014		#608-11-5-14 1 Key Podium Locks
FO-300873	11/6/2014	11/5/2014		#612-11-6-14 5 Keys Room 7133
FO-300883	11/6/2014	11/6/2014		#608-11-6-14 1 Key
FO-300886	11/6/2014	11/6/2014		#608-11-6-14-1 1 Key Room 309,324, 325
FO-300927	11/6/2014	11/6/2014		SWITCH CORES BETWEEN 6305.1 AND KITCHENETTE (Labeled 6304 on floor plan).
FO-300935	11/6/2014	11/6/2014		071110614 2-KEYS
FO-300936	11/6/2014	11/6/2014		130110614 6/desk keys
FO-300937	11/6/2014	11/7/2014		999110614 9-KEYS
FO-300939	11/6/2014	11/6/2014		001110614 5-KEYS
FO-300941	11/6/2014	11/6/2014		189110614 7-KEYS B-462
FO-300984	11/7/2014	11/7/2014		72503 5-KEYS
FO-301033	11/7/2014	11/7/2014		603110714-1 3-KEYS RM 4621
FO-301034	11/7/2014	11/7/2014		6031107142 5-KEYS RM 2525
FO-301035	11/7/2014	11/7/2014		603110714-3 3-KEYS RM 2138
FO-301042	11/7/2014	11/10/2014		006110714 10-keys 4th floor
FO-301069	11/10/2014	11/10/2014		#603-11-10-14 3 Keys Room 2138

WO	Recieved	Finished	Total	Request
FO-301100	11/10/2014			#611-11-10-14 1 Key Main door and office
FO-301131	11/10/2014	11/18/2014		#507-11-10-14 6 Keys and 2 Cores Room 1115
FO-301234	11/11/2014	11/14/2014		#049-11-11-14 2 keys
FO-301235	11/11/2014	11/14/2014		#040-11-11-14 6 Keys Room 056
FO-301337	11/12/2014	11/18/2014		#629-11-12-14 3 Keys
FO-301403	11/12/2014			071-111214 - To cover the cost of 6 core changes 6/4/24 keys 5057 Woodward, 6th floor Graduate School Modifications. See attached sketch. *NTE \$600.00.
FO-301515	11/13/2014	11/14/2014		74394 5-KEYS
FO-301544	11/14/2014	11/19/2014		#612-11-14-14 1 Key Frieight Elevator
FO-301545	11/14/2014	11/20/2014		#612-11-14-14-1 1 Key Animal Room
FO-301742	11/17/2014	11/20/2014		#001-11-17-14 3 Keys Room 1201
FO-301811	11/17/2014	11/18/2014		#089-11-17-14 4 Keys Room 5155
FO-302056	11/18/2014	11/19/2014		629111114-1 3-KEYS
FO-302084	11/18/2014	11/19/2014		127111814 1-KEY
FO-302087	11/18/2014	11/19/2014		603111414-1 3-KEYS ROOM 5132
FO-302089	11/18/2014	11/19/2014		603111814-2 3-KEYS ROOM 5134
FO-302092	11/18/2014	11/19/2014		603111814-3 3-KEYS ROOM 5136
FO-302095	11/18/2014	11/19/2014		603111814-4 3-KEYS ROOM 5138
FO-302139	11/18/2014	11/19/2014		016111814 7-KEYS ROOM 223
FO-302178	11/19/2014			#001-11-18-14 2 Keys
FO-302179	11/19/2014	11/25/2014		#060-11-18-14 1 Key
FO-302190	11/19/2014	11/21/2014		#104-11-18-14 3 Keys and 2 Cores Room 359
FO-302238	11/19/2014	11/20/2014		#060-11-19-14 2 Keys Desk Cabinet
FO-302271	11/19/2014	11/20/2014		#026-10-23-14-1 2 Keys Room 231
FO-302277	11/19/2014	11/19/2014		195111914 2-KEYS Ford Truck
FO-302272	11/19/2014	11/20/2014		#026-10-23-14 2 Keys Room 155
FO-302274	11/19/2014	11/20/2014		#608-10-23-14 3 Keys Room 232
FO-302275	11/19/2014	11/25/2014		#096-10-23-14-1 4 Keys Room 2210
FO-302276	11/19/2014	11/21/2014		#096-10-23-14 3 Keys Room 515
FO-302279	11/19/2014	11/24/2014		#003-11-19-14 1 Key Room 025
FO-302280	11/19/2014	11/24/2014		#999-11-19-14 1 Key Brown Box
FO-302281	11/19/2014	11/20/2014		#034-11-19-14 5 Keys Restooms
FO-302287	11/19/2014	11/24/2014		#006-11-19-14 1 Key Elevator Access
FO-302291	11/19/2014	11/24/2014		#016-11-19-14 1 Key Room 225.4
FO-302328	11/20/2014	11/21/2014		#217-11-20-14 1 Key Gate entry lock and gate opener
FO-302365	11/20/2014	11/24/2014		#071-11-20-14 4 Keys Room 6303
FO-302467	11/21/2014	11/21/2014		#611-11-21-14 10 Keys Room 258
FO-302468	11/21/2014			#611-11-21-14-1 10 Keys Room 212
FO-302483	11/21/2014	11/21/2014		#603-11-21-14 3 Keys Room 4621
FO-302760	11/24/2014	11/25/2014		039112714 3-Keys Gate for loading dock.
FO-302811	11/24/2014			068112414 5-Keys ROOM 351
FO-302822	11/24/2014			#082-11-24-14 4 Keys Lobby Bulletin
FO-302825	11/24/2014	11/25/2014		#082-11-24-14-1 4 Keys Cubicle Desk
FO-302826	11/24/2014	11/25/2014		#082-11-24-14-2 4 Keys Lobby Desk
FO-302846	11/24/2014			Replace core in glass corridor door leading to 3634. Core to be provided 11/25/2014.
FO-302854	11/24/2014	11/25/2014		#603-11-24-14 3 Keys PT Lab Room SSM
FO-303060	11/26/2014			612-112414 - 1 core change and 4 keys. New core must run off of Departmental Master. Work must be done exactly on Monday the first, Faculty member retiring 11/30/14. Key fits room 7205

WO	Recieved	Finished	Total	Request
T - Painter			41	
FO-300784	11/4/2014			R/R BLDG BOTH STRWLS (APPR 40 DOORS) Paint outside of interior entry doors in stairwells where the paint has peeled off. Please provide estimate. See Ruth Jensen in Suite 100.project_name: Paint entry doors in stairwellsBrazen 11/04/2014 15:10 - Work po
FO-300798	11/5/2014	11/7/2014		PAINTERS TO MUD & PAINT CEILING 4TH FLOOR LADIES BATHROOM / CARPENTERS REPAIRED DAMAGED DRYWALL FROM A LEAK
FO-300831	11/5/2014	11/6/2014		CAP-4 #30, Patch & Paint wall
FO-300849	11/5/2014	11/11/2014		CAP-4 #119, Paint wall & door frames, 1st floor, by west entry, room -107
FO-300854	11/5/2014	11/7/2014		CAP-4 #121, Paint access panel, 1st floor by west entry -stair 3,
FO-300855	11/5/2014	11/12/2014		CAP-4 #126, Clean supply vents at soffit (4 total)1st floor by room 116.
FO-300856	11/5/2014	11/10/2014		CAP-4 #135 Repaint supply grilles, 1st floor, west wall by room 117.
FO-300857	11/5/2014	11/11/2014		CAP-4 #136, Paint sheet metal access panel, 1st floor south wall by room #4.
FO-300892	11/6/2014	11/17/2014		Painters, please seal floor INSIDE air handling unit 1 to prevent leaks in office space below. Priority: low
FO-300893	11/6/2014	11/17/2014		Painters, please seal floor INSIDE air handling unit 2 to prevent leaks in office space below. Priority: low
FO-300977	11/7/2014			HANDY MAN TIME.
FO-300988	11/7/2014			MTL TIME.
FO-301024	11/7/2014	11/7/2014		R/R 150/AD/CMDMNT CTR/SVC CTR OFC NEED 2 BOXES OF COPY PAPER
FO-301138	11/10/2014			Painter; MediumPlease finish painting the rest of the loading dock area; which includes the rest of the doors that were not painted, window sills, walls, ceiling and exposed piping in the loading dock area.
FO-301153	11/10/2014	11/28/2014		Painters: Please re-paint area above interior door inside room 346, after hot water heating valve had been replaced that caused the wall paint to bubble. FO-301121. Med. priority.
FO-301154	11/10/2014	11/10/2014		Touch up walls in auditorium for town hall meeting.
FO-301251	11/11/2014	11/13/2014		There are penetrations in the west wall of the nitrogen generator (mechanical penthouse) that is attached to the elevator machine room. Seal penetrations between the hazardous locations.
FO-301321	11/12/2014			Clean off or paint over Graffiti on campus.
FO-301324	11/12/2014	11/12/2014		Please paint WSU FPM logo on electric heaters. Will bring up to shop
FO-301357	11/12/2014	11/26/2014		CAP-4 #144 Paint door frame on 2nd floor, west side, by room 207.
FO-301363	11/12/2014	11/26/2014		CAP-4 #145 Refinish doors,2nd floor, west side by room 207.
FO-301365	11/12/2014	11/24/2014		CAP-4 #146 Paint wall, 2nd floor, west side by room 207.
FO-301367	11/12/2014	11/18/2014		CAP-4 #148 Patch & paint concrete beam, 2nd floor, north side by room 207.
FO-301368	11/12/2014	11/19/2014		CAP-4 #150, Scrape & repaint around windows, 2nd floor, north side by room 207.
FO-301369	11/12/2014	11/13/2014		CAP-4 #168, Paint door frame, 1st floor, by room 108.
FO-301371	11/12/2014	11/13/2014		CAP-4 #170, Repaint graffiti over speaker. 1st floor-(restrooms) by room 107
FO-301374	11/12/2014			R/R RM 3141 DUE TO ROOF LEAKS THE PLASTER CEILILNG HAS STARTED FLAKING & LARGE CHUNKS OF PLASTER HAVE STARTED FALLING
FO-301477	11/13/2014			R/R 4TH FLR OUTSIDE OF BOTH ELEVS REPAIR PLASTERED CLNG THAT IS PEELING & FALLING
FO-301520	11/13/2014			R/R RM 1025 Please place a 10# ABC fire extinguisher inside the lab at the entrance/exit door. The fire extinguisher will need to be mounted on board/hook with a fire extinguisher sign above same.
FO-301539	11/13/2014			Repair and paint wall above interior door in room 346. Leak above has been repaired /Refer to FO#301121 JWT
FO-301618	11/14/2014			PAINTERS TO MUDD & PAINT REPAIRED DRYWALL CEILING WOMENS BATHROOM ACROSS FORM ROOM # 2342
FO-302041	11/18/2014	11/25/2014		PAINTERS TO TOUCH UP PAINT & REMOVE GRAFFITTI FROM MENS 1ST FLOOR RESTROOM PARTITION
FO-302390	11/20/2014			Request Maintenance on vehicles/Units #7 & #8
FO-303000	11/25/2014			R/R I NEED FOR SHERROD TO PICK UP X-SHTS & MWRF FROM KINKO
FO-303037	11/26/2014			Paint Hallway from grounds/common area, to front offices.

WO	Recieved	Finished	Total	Request
FO-303074	11/26/2014			PAINTERS TO MUD & PAINT WATER FOUNTAIN COVE & WALL NEAR ROOM 2134
FO-303075	11/26/2014			HANDYMAN TO RELOCATE 25 PODIUMS FROM THE PUBLIC SIDE OF THE WAREHOUSE TO FP&MS ENCLOSED CAGE
FO-303078	11/28/2014			CAP-4 #151 (General) Painting ceiling & column, North wall by room 207
FO-303079	11/28/2014			CAP-4 #154 Paint walls an door frames, 2nd floor east wall by room 207.
FO-303080	11/28/2014			CAP-4 #156 Paint walls 2nd floor,
FO-303081	11/28/2014			CAP-4 #157 Signage labeling High Voltage Panels, 2nd floor, north wall stair 4.
T - Pipefitter			84	
FO-300683	11/3/2014	11/3/2014		ECM meeting
FO-300685	11/3/2014	11/3/2014		met with contractor to show boiler room and mechanical room to where as they will perform there work.....CB.....11-3-14
FO-300687	11/3/2014	11/3/2014		take contractor and show him all the areas that he will be insulating.....CB.....11-3-14
FO-300688	11/3/2014	11/3/2014		get notifications ready communicate with OEHS for bills of lading, post asbbestos removal notices, etc.....CB.....11-3-14
FO-300689	11/3/2014	11/3/2014		processing time for hot work permits.....CB.....11-3-14
FO-300690	11/3/2014	11/3/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-3-14
FO-301017	11/3/2014			STEAM TRAP SURVEY / REPLACEMENT PROJECT 2014/2015 HEATING SEASON ,,,,,,,,,,,,, JH/11-3-14 ,,,,,,,,,,,,,,
FO-301018	11/3/2014			(**) PO REQ DK 11/15/14 STEAM TRAP SURVEY / REPLACEMENT PROJECT 2014/2015 HEATING SEASON ,,,,,,,,,,,,, JH/11-3-14 ,,,,,,,,,,,,,,
FO-300407	11/3/2014			Replace existing 6" gate valve with chain for steam supply that feeds Art. ,,,,,,,,,,,,,, EA/11-3-14 ,,,,,,,,,,,,,,
FO-300820	11/4/2014	11/4/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-4-14
FO-300823	11/4/2014	11/4/2014		processing time for hot work permits.....CB.....11-4-14
FO-300725	11/4/2014	11/4/2014		Please add check valve to down stream side of backflow preventer for chill water make up ,,,,,,,,,,,,, EA/11-4-14 ,,,,,,,,,,,,,,
FO-300772	11/4/2014	11/10/2014		re pipe 1/4" air compressor drain as nesc ,,,,,,,,,,,,,, ME/11-6-14 ,,,,,,,,,,,,,,
FO-300776	11/4/2014	11/4/2014		run down signatures for project notification form for Saturday shutdown.....CB.....11-4-14
FO-300778	11/4/2014	11/4/2014		discuss and distribute paperwork for Applebaum shutdown this Saturday.....CB.....11-4-14
FO-300869	11/5/2014	11/5/2014		assist power vac in getting around campus all day for various different jobs.....CB.....11-5-14
FO-300982	11/6/2014	11/6/2014		processing time for paperwork, e-mails, phonecalls, etc.....CB.....11-6-14
FO-300985	11/6/2014	11/6/2014		distribute notification sheets and speak with Ferna in regards to abatement job and Saturday's shutdown.....CB.....11-6-14
FO-300881	11/6/2014	11/7/2014		Fitters, please repair steam leaks on AHU-1. ,,,,,,,,,,,,,, JH/11-6-14 ,,,,,,,,,,,,,,
FO-300882	11/6/2014	11/7/2014		Fitters, please repair steam leaks on AHU-2. ,,,,,,,,,,,,,, JH/11-6-14 ,,,,,,,,,,,,,,
FO-300926	11/6/2014	11/10/2014		install Hoffman 79 & stop v in 1.25 " copper hwh line ,,,,,,,,,,,,,, JH/11-10-14 ,,,,,,,,,,,,,,
FO-300951	11/6/2014	11/6/2014		safety meeting.....CB.....11-6-14
FO-300954	11/6/2014	11/6/2014		LOTO meeting with Rick.....CB.....11-6-14
FO-300956	11/6/2014	11/6/2014		processing time for hot work permits.....CB.....11-6-14
FO-300991	11/7/2014	11/7/2014		Fabricate gasket for pot feeder.....CB.....11-7-14 ,,,,,,,,,,,,,,
FO-300992	11/7/2014	11/10/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank.....CB.....11-10-14 ,,,,,,,,,,,,,, DUE MONDAY BY 9:00am
FO-300993	11/7/2014	11/10/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank. ,,,,,,,,,,,,,, EA/11-10-14 ,,,,,,,,,,,,,, DUE MONDAY 11-10-14 BY 12:00 PM
FO-300994	11/7/2014	11/11/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank.....CB.....11-11-14 ,,,,,,,,,,,,,, DUE TUESDAY 11-11-14 BY 10:00am
FO-300995	11/7/2014	11/11/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank.....CB.....11-11-14 ,,,,,,,,,,,,,, DUE TUESDAY 11-11-14 BY 1:00pm
FO-300996	11/7/2014	11/7/2014		**Cancelled / Quill had already been installed JWT Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank.

WO	Recieved	Finished	Total	Request
FO-300997	11/7/2014	11/12/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank..... EA/11-12-14 DUE 11-12-14 AT 12:00pm
FO-300998	11/7/2014	11/14/2014		Install quill in DA tank for Eldon Water chemical injectors. Engineer to shut down steam and drain DA tank..... EA/11-13-14
FO-301055	11/7/2014	11/8/2014		supervise gain access and follow up completion of abatement job in several different rooms, stage abatement for pick-up, lock up and contact public safety....CB.....11-7-14
FO-301050	11/8/2014	11/7/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-7-14
FO-301051	11/8/2014	11/7/2014		processing time for hot work permits.....CB.....11-7-14
FO-301052	11/8/2014	11/7/2014		get bills of lading and notifications for 6 abatement jobs that are for next week.....CB.....11-7-14
FO-301053	11/8/2014	11/7/2014		schedule emergency abatment job, meet with mike D, discuss scheduling and repairs of womens restroom.....CB.....11-7-14
FO-301060	11/9/2014	11/10/2014		Repair condensate return pump #2. Located in mechanical room 10. RC/11-10-14
FO-301067	11/10/2014	11/14/2014		Fitters, please repair steam leak on AHU-2 EA/11-14-14
FO-301078	11/10/2014	11/12/2014		PIPE FITTERS TO WELD MOUNTING PLATES & STAIGHTEN HANDRAIL JH/11-10-14
FO-301091	11/10/2014	11/11/2014		Relocate the Low Water Level Alarm float assembly on the boiler feed water heater tank up 3.5 - 4 inches from its current location. This will ensure that the Spence valve sensor is submerged in water. Coordination with electricians will be required to
FO-301121	11/10/2014	11/12/2014		Please check for the cause to the bubbling/peeling paint above the interior door (door between offices). This was repaired and painted earlier this semester but is bubbling again. Possible water leak??? JH/11-12-14
FO-301123	11/10/2014	11/10/2014		meet with asbestos company for emergency abatement removal, post notifications speak to building coordinator, supervise job and inspect when completed.....CB.....11-10-14
FO-301125	11/10/2014	11/10/2014		meet with Ed from OEHS so that he could pick up 4 bags of remediation that was staged from Late Friday nights abatement removal.....CB.....11-10-14
FO-301127	11/10/2014	11/10/2014		post notifications for Tuesdays and Wednesdays abatement jobs, get bills of lading and inform all building coordinators.....CB.....11-10-14
FO-301128	11/10/2014	11/10/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-10-14
FO-301130	11/10/2014	11/10/2014		time to run to Air Gas to pick up oxygen tanks and silver solder.....CB.....11-10-14
FO-301262	11/11/2014	11/11/2014		gain access for, supervise, and follow up 4 abatement jobs on campus today.....CB.....11-11-14
FO-301264	11/11/2014	11/11/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-11-14
FO-301287	11/12/2014			Replace gaskets on all 6" gate valves (3) behind SF-6 / AHU-6 in mechanical room 025 EA/11-11-14
FO-301413	11/12/2014	11/12/2014		go with Power Vac, to parking structures and surface lots to identify sewer basins for PM quote for parking.....CB.....11-12-14
FO-301414	11/12/2014	11/12/2014		supervise and get access for asbestos removal contractor at a few buildings on campus.....CB.....11-12-14
FO-301415	11/12/2014	11/12/2014		processing time for paperwork, e-mails, phone calls, etc.....CB.....11-12-14
FO-301418	11/13/2014	11/13/2014		PIPEFITTERS- R/R BSMT please install valve in basement office at Beecher to isolate steam to server room. Engineer can show you the line. engineer can isolate steam to area at any time. pipe covering is fiberglass. thanks. JH/11-13-1
FO-301461	11/13/2014			Repair leaking economizer located in mechanical room 15 EA/11-13-14
FO-301484	11/13/2014			Trade: Pipefitters Priority: Low Please repair steam leak in pipe for hydronic heat exchanger #1 in the boiler room. JH/11-15-14
FO-301485	11/13/2014			Trade: Pipefitters Priority: Low Please repair steam leak in pipe for hydronic heat exchanger #2 in the boiler room. JH/11-15-14
FO-301550	11/14/2014			monitor air for abatement job in room 100.....
FO-301730	11/15/2014	11/25/2014		Repair Trailer Bracket for front docking wheel. See Dennis (Laborer) JH/11-15-14

WO	Recieved	Finished	Total	Request
FO-301734	11/16/2014			Repair high pressure steam valve located at pressure reducing station in basement mechanical room. Valve is leaking at the bonnet gasket. Leak is minor at this time.
FO-302180	11/18/2014	11/18/2014		processing time for paperwork, e-mails phone calls, etc.....CB....11-18-14
FO-302181	11/18/2014	11/18/2014		investigate various steam/water leaks at different buildings through-out campus....CB.....11-18-14
FO-302182	11/18/2014	11/18/2014		meet with Carolyn Brzuchowski to schedule shut down work.....CB.....11-18-14
FO-302183	11/18/2014	11/18/2014		processing time for hot work permits.....CB.....11-18-14
FO-302184	11/18/2014	11/18/2014		chk on finished plumbing repair and speak to Mike D in regards to scheduling work.....CB.....11-18-14
FO-302187	11/19/2014			PIPEFITTERS please move strainer at boiler #1 in feed water line so that it can be accessed easily for cleaning. also, please install a valve attached so it can be blown out regularly. (request will be made for Blr #2 as well.),,,,,,,,,,,,,, ME/11-20-
FO-302188	11/19/2014			PIPEFITTERS R/R RM 0305/MECH BLR RM please move strainer at boiler #2 in feed water line so that it can be accessed easily for cleaning. also, please install a valve attached so it can be blown out regularly. ,,,,,,,,,,,,,, ME/11-19-14 ,,,,,,,,,,,,,,
FO-302192	11/19/2014	11/21/2014		PIPEFITTERS please R/R RM 0002/MECH RM PRV in basement mechanical room by AHU#3. This PRV is in line to AHU's did not reduce pressure and safety (set for 15psi) popped when steam was introduced to line for season. supply valve currently throddled to mai
FO-302194	11/19/2014	11/21/2014		PIPEFITTERS R/R RM 00016/MECH RM please r/r leaking 1" black pipe on condensate line to the rear of the feed water tank in the boiler room at Beecher. slow constant drip. ,,,,,,,,,,,,,, ME/11-19-14 ,,,,,,,,,,,,,,
FO-302201	11/19/2014			Fitters, R/R PENTHOUSE please repair/replace spence valve above air compressor in penthouse. Priority: Low ,,,,,,,,,,,,,, ME/11-24-14 ,,,,,,,,,,,,,,
FO-302368	11/20/2014			FITTERS, R/R RM 00429/ASSEMBLY SVC AREA PLEASE REPLACE BAD ISOLATION/STRAINER VALVE ON VAV BOX. PRIORITY-MEDIUM ,,,,,,,,,,,,,, JH/11-24-14 ,,,,,,,,,,,,,,
FO-302403	11/20/2014	11/20/2014		took several trips to theatre to show 2 different contracts existing steam leak issues and what will be needed for ceiling removal.....CB.....11-20-14
FO-302405	11/20/2014	11/20/2014		processing time for paperwork, e-mails, phone calls, etc.....CB...11-20-14
FO-302406	11/20/2014	11/20/2014		processing time for hot work permits.....CB.....11-20-14
FO-302407	11/20/2014	11/20/2014		start calling vendors for x-mas party donations.....CB.....11-20-14
FO-302828	11/24/2014			Fitters, R/R PENTHOUSE please repair leak in steam coil on AHU-2.,,,,,,,,,,,,,, ME/11-24-14 ,,,,,,,,,,,,,,
FO-302840	11/24/2014			Fitter R/R RM 201/MECH RM repair domestic hot water exchanger leak in basement steam room. ,,,,,,,,,,,,,, ME/11-24-14 ,,,,,,,,,,,,,,
FO-303004	11/25/2014			Fitter R/R GARAGE replace surface blow down valve on boiler #1 with a needle valve.
FO-303015	11/25/2014	11/25/2014		processing time for hot work permits.....CB.....11-25-14
FO-303017	11/25/2014	11/25/2014		processing time for paperwork, e-mails, phone calls, etc....
FO-303018	11/25/2014	11/25/2014		meeting with Liz Raes to coordinate projector room work.....CB.....11-25-14
FO-303025	11/25/2014	11/25/2014		chk for un-insulated steam lines throughout building.....CB.....11-25-141
FO-303066	11/26/2014			Please replace (2) Powers 3-way valves supplying heating coils #12 & #13 adjacent to store on level #1 of SCB. Please contact building engineer Jim Oman for details; 313-300-0826.
FO-303070	11/26/2014			PIPEFITTERS R/R RM 211 please lift vent side of radiator so that it's tilted to allow draining of condensate. Please replace steam valve b/c it does not close completely and allows steam by. Please replace vent and pipe in a drain (w/ valve and plug) so
T - Plumber			57	
FO-300315	11/1/2014	10/31/2014		*Duplicate / Refer to FO#300251 JWT 3rd floor women's restroom all the toilets are leaking.,,,,,,,,,,,,,, MP/11-1-14 ,,,,,,,,,,,,,,
FO-300316	11/1/2014	11/4/2014		Repair leaking copper pipe in Green House. See David Kuffner for location if needed ,,,,,,,,,,,,, MP/11-1-14 ,,,,,,,,,,,,,,
FO-300338	11/3/2014			Plumbers: please install a hose bib in basement boiler room. priority: low.,,,,,,,,,,,,,, MP/11-3-14 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-301104	11/3/2014			Administrative Time for November 2014
FO-301111	11/3/2014	11/3/2014		Getting New Plumber one card and new hire paperwork processed ,,,,,,,,,,,,,, DB/11-3-14 ,,,,,,,,,,,,,
FO-300692	11/4/2014	11/5/2014		Toilet in basement bathroom is plugged up.,,,,,,,,,,,,,, MP/11-4-14 ,,,,,,,,,,,,,,
FO-300758	11/4/2014			women's bathroom, toilet seat needs replacing
FO-300865	11/5/2014			Plumbers: please run the discharge pipe of the sump pump to floor drain. it was cut off temporarily to snake the floor drain. priority: low.
FO-300874	11/6/2014			Basement ladies restroom(no room number located across from 036) water leaking from handle on toilet 1st stall ,,,,,,,,,,,,,, MP/11-15-14 ,,,,,,,,,,,,,,
FO-300877	11/6/2014			Replace storm water pumps in sumps #1 and #2 ,,,,,,,,,,,,,, MP/11-6-14 ,,,,,,,,,,,,,,
FO-300894	11/6/2014			(**) PO REQ DK Please R/R RM 257/MECH RM B&G pump for DHW #2, in basement mechanical room ,,,,,,,,,,,,,, MM/11-10-14 ,,,,,,,,,,,,,,
FO-301016	11/7/2014			Plumbers: R/R BLDG Please tighten or replace all toilet seats in bathrooms on the basement, 1st, 2nd, and third floors restrooms. FO-301014 ,,,,,,,,,,,,,, MP/11-15-14 ,,,,,,,,,,,,,,
FO-301043	11/7/2014	11/13/2014		R/R 4TH FLR The women's bathroom 4TH STALL TOILET NEEDS FLUSH VLV REPLACED DUE IT is constantly flushing.,,,,,,,,,,,,,, MP/11-13-14 ,,,,,,,,,,,,,,
FO-301134	11/10/2014	11/21/2014		2ND FLOOR WOMEN'S RESTROOM THE FAUCET LEAKING. WATER RUNNING SLOW. REPORTED BY DR. NANCY LEVIN. PLEASE REPAIR. ,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,
FO-301207	11/11/2014	11/13/2014		Please change filter to water fountain in break room by lock shop.,,,,,,,,,,,,,, MP/11-13-14 ,,,,,,,,,,,,,
FO-301248	11/11/2014	11/25/2014		Toilet now repaired GS/ Now replace 1st floor with Zurn Flush Valves 1ST FL LADIES RM TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,,,,,, GS/11-12-14 ,,,,,,,,,,,,,,
FO-301263	11/11/2014			Check operations of domestic water booster pump #1 ,,,,,,,,,,,,,, GS/11-11-14 ,,,,,,,,,,,,,,
FO-301265	11/11/2014	11/11/2014		Assist in rebuilding of watts prv on domestic water booster pump ,,,,,,,,,,,,,, GS/11-11-14 ,,,,,,,,,,,,,
FO-301467	11/12/2014			PS#1 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301327	11/12/2014			Staff Lounge, Rm. 3112 has a garbage disposal that needs repair. The switch does nothing when you turn it on. ,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,
FO-301381	11/12/2014	11/13/2014		Men's Room on the 1st floor - the first faucet has a constant leak.,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,
FO-301411	11/13/2014	11/14/2014		R/R backflow for sprinkler system in basement mechanical room ,,,,,,,,,,,,,, DB/11-13-14 ,,,,,,,,,,,,,
FO-301416	11/13/2014	11/13/2014		Repair leaking urinal in first floor mens ,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,
FO-301470	11/13/2014			PS#2 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301471	11/13/2014	11/13/2014		**No Water in This Structure to be Winterized Per Don Bear PS#3 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301472	11/13/2014	11/12/2014		PS#4 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301473	11/13/2014			PS#5 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301475	11/13/2014			PS#6 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301476	11/13/2014	11/13/2014		**No water in this Structure to be Winterized Per Don Bear PS#7 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301478	11/13/2014	11/12/2014		PS#8 Please turn off water and drain down all parking structures to prevent winter freeze and broken pipes.
FO-301540	11/13/2014	11/24/2014		Unclog sink in 3rd floor men's Also 2 of 4 sinks do not work ,,,,,,,,,,,,,, MM/11-13-14 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-301581	11/14/2014			3rd floor ladies room (no room number)middle stall not flushing ,,,,,,,,,,,,,, MP/11-17-14 ,,,,,,,,,,,,,
FO-301597	11/14/2014			All toilet seats are loose. Please tighten.,,,,,,,,,,,,,, MP/11-17-14 ,,,,,,,,,
FO-301598	11/14/2014	11/14/2014		**Duplicate / Refer to FO#301597 JWT All toilet seats are loose. Please tighten.
FO-301601	11/14/2014	11/14/2014		**Duplicate / Refer to FO#301597 JWT All toilet seats are loose. Please tighten.
FO-301600	11/14/2014			R/R Third floor dressing room bathroom(North East end of building) toilet is not functioning and smells terrible. ,,,,,,,,,,,,,, MM/11-17-14 ,,,,,,,,,
FO-301732	11/16/2014			Repair leaking copper domestic hot water line located in the water line where pipe travels in the basement tunnel through the wall thimble from Reuther Library into the Fitness Center basement. Minor drip at this time.
FO-301749	11/17/2014	11/18/2014		Plumbers, R/R 1ST FLR LADIES RR please unclog drain in 1st floor ladies restroom, right sink. ,,,,,,,,,,,,, MM/11-18-14 ,,,,,,,,,
FO-301772	11/17/2014	11/17/2014		*Duplicate / Refer to FO#302086 R/R 4TH FLR Drinking fountain does not turn off
FO-301831	11/17/2014			**Steam Traps Leaking By Are The suspected cause. Replacement Steam Traps on Order under FO#301018 JWT R/R 00022/MECH RM Entire Building - Hot Water too hot. I just checked at taps on 3rd floor and it's coming out @ 155 degrees. Had complaint from
FO-301855	11/17/2014			Office 137 - Please remove the sink that is mounted on the wall.
FO-302052	11/18/2014			Purdy Library, R/R 4th Floor, Women's Restroom Toilet plugged. Custodial Services covered with bag. Please send plumber. Thank you. ,,,,,,,,,,,,,, MP/11-24-14 ,,,,,,,,,
FO-302239	11/18/2014			PS#8 - Please fix hot water heater in Structure 8 office restroom. bpm ,,,,,,,,,
FO-302261	11/18/2014			Sanitary line leak. Same room mechanical room off alley entrance were water heaters are located.,,,,,,,,,, This one is directly above GAS water heater.
FO-302133	11/18/2014			Lower Level - Hot Kitchen - Cap or cover floor drain near sink per health inspection by Nov. 25, if possible.,,,,,,,,,,,,,, GS/11-24-14 ,,,,,,,,,
FO-302163	11/18/2014	11/25/2014		R/R 2nd Floor Men's bathroom right when you get off the elevator. One urinal is backing up and constantly clogged up and the handicap toilet is not working. Needs to be addressed. This has been going on for 6 months. Thank you.,,,,,,,,,,,,,, GS/11
FO-302315	11/19/2014		11/20/2014	Shower drain is clogged
FO-302335	11/20/2014			Women's Restroom - 2nd floor North office pod - the top of the toilet tank is cracked and needs to be replaced. Please contact Ruth Jensen in suite 100 when tank lid is replaced.,,,,,,,,,,,,,, GS/11-24-14 ,,,,,,,,,
FO-302442	11/21/2014			WOMEN RESTROOM 1ST FLOOR NEAR MAIN ENTRANCE, THE TOILET IS CLOGGED IN LAST STALL.,,,,,,,,,,,,,, MP/11-24-14 ,,,,,,,,,
FO-302445	11/21/2014			R/R RM 1004/MENS RR 2nd Floor Men Bathroom TIGHTEN ALL toilet seatS slides off track.,,,,,,,,,,,,,, MP/11-24-14 ,,,,,,,,,
FO-302443	11/21/2014			MEN'S RESTROOM ON 1ST FLOOR NEAR MAIN ENTRANCE THE FIRST URINAL IS CLOGGED. PLEASE UNCLOG.,,,,,,,,,,,,,, MP/11-24-14 ,,,,,,,,,
FO-302498	11/21/2014			In Rm. 1306 the faucet on the north wall has low water pressure ,,,,,,,,,,,,,, MM/11-24-14 ,,,,,,,,,,,,,
FO-302793	11/24/2014	11/25/2014		Unisex bathroom in DJK Center is not working. Please send plumbers.,,,,,,,,,,,,,, GS/11-24-14 ,,,,,,,,,
FO-302809	11/24/2014			The Y splitter, backflow adapter and hose adapter needs replacement for proper water flow to chemical sispenser in Rackham Building. 2ND FLOOR RM 250, EASTSIDE IN ROOM ,,,,,,,,,,,,, MM/11-24-14 ,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-302824	11/24/2014			R/R 2ND FLR WOMENS RR We have received a report that the middle stall in the women's restroom on the 2nd floor is clogged and unable to function. ,,,,,,,,,,,,,, MM/11-24-14 ,,,,,,,,,,,,,
FO-302959	11/25/2014			Kresge Library, 1st Floor, Room 107 Public Men's Room: Urinal plugged. Please unplug,,,,,,,,,,,,, MP/11-25-14 ,,,,,,,,,, Thank you.
FO-303073	11/26/2014			PLUMBERS R/R RM 106/MECH RM please clear blocked floor drain in generator room at 5435 Woodward. Standing water.
T - Roofing			2	
FO-302802	11/24/2014			There is a roof leak by the garage door. This is in the area of the building where the water meter is at.
FO-302843	11/24/2014			Roofers R/R ROOF repair roof leak at south west corner. See engineer.
Routine			18	
T - Electrician			18	
FO-300365	11/3/2014	11/3/2014		CAMPUS WIDE FOR TURNING CLOCKS ON DAYLITE SAVINGS TIME Completed 11-3-2014 SRP
FO-300699	11/4/2014	11/8/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300700	11/4/2014	11/7/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300701	11/4/2014	11/7/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300702	11/4/2014	11/8/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300703	11/4/2014	11/8/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300705	11/4/2014	11/8/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-300706	11/4/2014	11/8/2014		ROUTINE CHECK 11/3 THRU 11/7/14
FO-301092	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301093	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301094	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301095	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301096	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301097	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-301098	11/10/2014	11/14/2014		ROUTINE CHECK 11/10 TO 11/14/14
FO-302338	11/20/2014			1EP - Overhead lights across from room 1281. (Routine)
FO-302339	11/20/2014			1 EP - Just east of the entrance. 0 no. of fixtures replaced.
FO-302341	11/20/2014			1 EP - Room 133

Scheduled Maint. (PM) 870

Engineering 834

Routine 834

E - Auxiliary 50

FO-298971	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298972	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298973	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298982	11/1/2014	11/24/2014		PM - Heat Exchanger and Economizer
FO-299172	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299173	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299174	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299184	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299199	11/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-299210	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299211	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-299212	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299213	11/1/2014	11/4/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299214	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299215	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299216	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299219	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299220	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299221	11/1/2014			PM - Heat Exchanger and Economizer
FO-299222	11/1/2014			PM - Heat Exchanger and Economizer
FO-299223	11/1/2014			PM - Heat Exchanger and Economizer
FO-299224	11/1/2014			PM - Heat Exchanger and Economizer
FO-299225	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299226	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299227	11/1/2014			PM - Air Handling Unit, HV Type
FO-299229	11/1/2014			PM - Air Handling Unit, HV Type
FO-299230	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299231	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299232	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299233	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299243	11/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-299244	11/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-299245	11/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-299246	11/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-299247	11/1/2014			PM - Monthly Fire Alarm/Fire Protection System Test
FO-299228	11/3/2014			PM - Emergency Shower/Eyewash Station
FO-299848	11/10/2014	11/17/2014		PM - Emergency Shower/Eyewash Station
FO-299838	11/11/2014	11/12/2014		Generator Maintenance, Monthly
FO-300297	11/12/2014	11/13/2014		Generator Maintenance, Monthly
FO-300462	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300475	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300477	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300469	11/17/2014	11/24/2014		PM - Emergency Shower/Eyewash Station
FO-300303	11/19/2014	11/19/2014		Generator Maintenance, Monthly
FO-301174	11/24/2014	11/24/2014		PM - Emergency Shower/Eyewash Station
FO-300277	11/25/2014			Generator Maintenance, Monthly
FO-300279	11/25/2014			Generator Maintenance, Monthly
FO-300281	11/25/2014			Generator Maintenance, Monthly
FO-300283	11/25/2014			Generator Maintenance, Monthly
FO-300285	11/25/2014			Generator Maintenance, Monthly
E - MedPharm			74	
FO-298773	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298774	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298775	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298776	11/1/2014	11/19/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298777	11/1/2014	11/19/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298778	11/1/2014	11/4/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298779	11/1/2014	11/4/2014		PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-298780	11/1/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-298781	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298782	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298783	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298784	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298785	11/1/2014	11/14/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298786	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298787	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298788	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298789	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298790	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298791	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298792	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298793	11/1/2014	11/1/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298794	11/1/2014	11/1/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298795	11/1/2014	11/1/2014		PM - Heat Exchanger and Economizer
FO-298796	11/1/2014			PM - Heat Exchanger and Economizer
FO-298797	11/1/2014	11/1/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298798	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298799	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298800	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298801	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298802	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298803	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298804	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298805	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298806	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298807	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298808	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298809	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298810	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298811	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298812	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298813	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298814	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298815	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298816	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298817	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298818	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298819	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298820	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298821	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298822	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298823	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298824	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298825	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298826	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-298827	11/1/2014	11/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299834	11/7/2014			Generator Maintenance, Monthly
FO-299831	11/9/2014	11/20/2014		PM - Condensate Return Pump
FO-299832	11/9/2014	11/20/2014		PM - Condensate Return Pump
FO-299833	11/9/2014			PM - Condensate Return Pump
FO-300418	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300419	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300420	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300421	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300422	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300423	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300424	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300425	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300426	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300427	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300428	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300306	11/18/2014	11/19/2014		Generator Maintenance, Monthly
FO-300273	11/28/2014			Generator Maintenance, Monthly
FO-300275	11/28/2014			Generator Maintenance, Monthly
FO-301864	11/28/2014			PM - Reverse Osmosis Water Softener System
E - North			116	
FO-298828	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298829	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298830	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298831	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298832	11/1/2014	11/10/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298833	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298834	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298835	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298836	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298837	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298838	11/1/2014	11/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298839	11/1/2014	11/11/2014		PM - Unspecified
FO-298840	11/1/2014	11/11/2014		PM - Unspecified
FO-298841	11/1/2014	11/11/2014		PM - Unspecified
FO-298842	11/1/2014	11/12/2014		PM - Unspecified
FO-298843	11/1/2014	11/12/2014		PM - Unspecified
FO-298844	11/1/2014	11/12/2014		PM - Unspecified
FO-298845	11/1/2014	11/12/2014		PM - Unspecified
FO-298846	11/1/2014	11/13/2014		PM - Unspecified
FO-298847	11/1/2014	11/13/2014		PM - Unspecified
FO-298848	11/1/2014	11/13/2014		PM - Unspecified
FO-298849	11/1/2014	11/13/2014		PM - Unspecified
FO-298850	11/1/2014	11/18/2014		PM - Unspecified
FO-298851	11/1/2014	11/18/2014		PM - Unspecified
FO-298852	11/1/2014	11/18/2014		PM - Unspecified
FO-298853	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-298854	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298855	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298856	11/1/2014	10/29/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298857	11/1/2014	10/29/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298858	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298859	11/1/2014	10/29/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298860	11/1/2014	10/22/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298861	11/1/2014	10/22/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298862	11/1/2014	10/31/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298863	11/1/2014	10/31/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298864	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298865	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298866	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298867	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298868	11/1/2014	10/20/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298869	11/1/2014	10/20/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298870	11/1/2014	11/14/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298871	11/1/2014	11/14/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298872	11/1/2014	11/14/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298873	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298874	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298875	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298876	11/1/2014	10/31/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298877	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298878	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298879	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298880	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298881	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298882	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298883	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298884	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298885	11/1/2014	11/5/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298886	11/1/2014	11/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298887	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298888	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298889	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298890	11/1/2014	11/18/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298891	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298892	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298893	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298894	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298895	11/1/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298896	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298897	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298898	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298899	11/1/2014	11/13/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298900	11/1/2014	10/30/2014		PM - Harmsco Side Stream Filter

WO	Recieved	Finished	Total	Request
FO-298901	11/1/2014	10/30/2014		PM - Harmsco Side Stream Filter
FO-298902	11/1/2014	10/30/2014		PM - Harmsco Side Stream Filter
FO-298903	11/1/2014	11/20/2014		PM - Harmsco Side Stream Filter
FO-298904	11/1/2014	10/28/2014		PM - Harmsco Side Stream Filter
FO-298905	11/1/2014	11/13/2014		PM - Harmsco Side Stream Filter
FO-298906	11/1/2014	11/13/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298907	11/1/2014	10/28/2014		PM - Heat Exchanger and Economizer
FO-298908	11/1/2014			PM - Domestic Water Heater, Steam
FO-298909	11/1/2014	10/30/2014		PM - Harmsco Side Stream Filter
FO-298910	11/1/2014	10/20/2014		PM - Chemical Feed/Metering Pump/Controller
FO-298911	11/1/2014	10/31/2014		PM - Water Booster Pump
FO-298912	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298913	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298914	11/1/2014	10/22/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298915	11/1/2014	10/15/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298916	11/1/2014	10/15/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298918	11/1/2014			Replace PRE-filters
FO-298919	11/1/2014			Replace PRE-filters
FO-298920	11/1/2014			Replace PRE-filters
FO-298921	11/1/2014			Replace PRE-filters
FO-298922	11/1/2014			Replace PRE-filters
FO-299835	11/6/2014	11/20/2014		PM - Outside/Fresh Air Intake Screens
FO-299836	11/6/2014	11/20/2014		PM - Outside/Fresh Air Intake Screens
FO-300441	11/12/2014	11/20/2014		PM - Condensate Return Pump
FO-300442	11/12/2014	11/20/2014		PM - Condensate Return Pump
FO-300444	11/12/2014	11/24/2014		PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-300308	11/14/2014	11/20/2014		Generator Maintenance, Monthly
FO-300429	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300430	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300431	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300432	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300433	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300434	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300435	11/15/2014	11/13/2014		PM - Punch Tubes - Chiller/Absorber
FO-300436	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300437	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300438	11/15/2014	11/24/2014		PM - Punch Tubes - Chiller/Absorber
FO-300439	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300440	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300443	11/15/2014			PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-301173	11/20/2014	11/12/2014		PM - Water/Air Cooled Condenser
FO-300291	11/26/2014			Generator Maintenance, Monthly
FO-301914	11/26/2014			PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
E - Northeast			52	
FO-298923	11/1/2014	11/10/2014		PM - Water Softener
FO-298924	11/1/2014	11/10/2014		PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-298925	11/1/2014	11/10/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298926	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298927	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298928	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298929	11/1/2014	11/11/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298930	11/1/2014	11/10/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298931	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-298932	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-298933	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-298934	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298935	11/1/2014	11/12/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298936	11/1/2014	11/10/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298937	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298938	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298939	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298940	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298941	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298942	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298943	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298944	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298945	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298946	11/1/2014	11/17/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298947	11/1/2014	11/17/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298948	11/1/2014	11/17/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298949	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298950	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298951	11/1/2014	11/12/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298952	11/1/2014	11/12/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298953	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298954	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298955	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298956	11/1/2014	11/10/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298957	11/1/2014	11/10/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298958	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298959	11/1/2014	11/19/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298960	11/1/2014	11/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299837	11/6/2014	10/30/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299839	11/7/2014	11/11/2014		Generator Maintenance, Monthly
FO-299840	11/7/2014	11/10/2014		Generator Maintenance, Monthly
FO-299841	11/7/2014	11/12/2014		Generator Maintenance, Monthly
FO-299842	11/7/2014	11/11/2014		Generator Maintenance, Monthly
FO-300310	11/12/2014	11/13/2014		Generator Maintenance, Monthly
FO-300445	11/15/2014	11/3/2014		PM - Punch Tubes - Chiller/Absorber
FO-300446	11/15/2014	11/10/2014		PM - Chemical Feed/Metering Pump/Controller
FO-300447	11/15/2014	11/7/2014		PM - Chemical Feed/Metering Pump/Controller
FO-300448	11/15/2014	11/26/2014		PM - Water/Air Cooled Condenser
FO-300449	11/15/2014	11/26/2014		PM - Water/Air Cooled Condenser

WO	Recieved	Finished	Total	Request
FO-300299	11/18/2014	11/11/2014		Generator Maintenance, Monthly
FO-300305	11/20/2014	11/20/2014		Generator Maintenance, Monthly
FO-300270	11/26/2014	11/21/2014		Generator Maintenance, Monthly
E - Preventative Maintenance			246	
FO-297260	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297261	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297262	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297263	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297264	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297265	11/1/2014	11/7/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297266	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297267	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297268	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297269	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297270	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297271	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297272	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297273	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297274	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297275	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297276	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297277	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297278	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297279	11/1/2014	11/10/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297280	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297281	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297282	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297283	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297284	11/1/2014	11/15/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297285	11/1/2014	11/15/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297286	11/1/2014	11/15/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297287	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297288	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297289	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297290	11/1/2014	11/20/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297291	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297292	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297293	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297294	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297295	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297296	11/1/2014	11/3/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297297	11/1/2014	11/4/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297298	11/1/2014	11/4/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297299	11/1/2014	11/4/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297300	11/1/2014	11/4/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297301	11/1/2014	11/4/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297302	11/1/2014	11/5/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-297303	11/1/2014	11/6/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297304	11/1/2014	11/6/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297305	11/1/2014	11/6/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297306	11/1/2014	11/6/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297307	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297308	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297309	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297310	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297311	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297312	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297313	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297314	11/1/2014	11/11/2014		PM - Fan Coil/HV/AC Unit
FO-297315	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297316	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297317	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297318	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297319	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297320	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297321	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297322	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297323	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297324	11/1/2014	11/13/2014		PM - Fan Coil/HV/AC Unit
FO-297325	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297326	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297327	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297328	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297329	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297330	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297331	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297332	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297333	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297334	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297335	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297336	11/1/2014	11/14/2014		PM - Fan Coil/HV/AC Unit
FO-297337	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297338	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297339	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297340	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297341	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297342	11/1/2014	11/20/2014		PM - Fan Coil/HV/AC Unit
FO-297343	11/1/2014			PM - Air Handling Unit, HV Type
FO-297344	11/1/2014	11/11/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297345	11/1/2014	11/12/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297346	11/1/2014	11/12/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297347	11/1/2014	11/12/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297348	11/1/2014	11/12/2014		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-297349	11/1/2014	11/21/2014		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-297397	11/1/2014	11/24/2014		Replace PRE-filters
FO-297398	11/1/2014	11/24/2014		Replace PRE-filters
FO-297399	11/1/2014	11/12/2014		Replace PRE-filters
FO-297400	11/1/2014	11/24/2014		Replace PRE-filters
FO-297401	11/1/2014	11/25/2014		Replace PRE-filters
FO-297402	11/1/2014	11/6/2014		Replace PRE-filters
FO-297403	11/1/2014	11/7/2014		Replace PRE-filters
FO-297404	11/1/2014	11/7/2014		Replace PRE-filters
FO-297405	11/1/2014	11/7/2014		Replace PRE-filters
FO-297406	11/1/2014	11/6/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-297407	11/1/2014	11/6/2014		Replace PRE-filters
FO-297408	11/1/2014	11/21/2014		PM - Fan Coil/HV/AC Unit
FO-297409	11/1/2014	11/21/2014		PM - Fan Coil/HV/AC Unit
FO-297410	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297411	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297412	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297413	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297414	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297415	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297416	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297417	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297418	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297419	11/1/2014	11/20/2014		PM - Air Handling Unit (ANNUAL)
FO-297420	11/1/2014	11/20/2014		PM - Air Handling Unit (ANNUAL)
FO-297421	11/1/2014	11/19/2014		PM - Air Handling Unit (ANNUAL)
FO-297422	11/1/2014	11/15/2014		PM - Air Handling Unit (ANNUAL)
FO-297423	11/1/2014	11/14/2014		PM - Air Handling Unit (ANNUAL)
FO-297424	11/1/2014	11/13/2014		PM - Air Handling Unit (ANNUAL)
FO-297425	11/1/2014	11/12/2014		PM - Air Handling Unit (ANNUAL)
FO-297426	11/1/2014	11/11/2014		PM - Air Handling Unit (ANNUAL)
FO-297427	11/1/2014	11/7/2014		PM - Air Handling Unit (ANNUAL)
FO-297428	11/1/2014	11/6/2014		PM - Air Handling Unit (ANNUAL)
FO-297429	11/1/2014	11/6/2014		PM - Air Handling Unit (ANNUAL)
FO-297430	11/1/2014	11/26/2014		PM - Air Handling Unit (ANNUAL)
FO-297431	11/1/2014	11/5/2014		PM - Air Handling Unit (ANNUAL)
FO-297432	11/1/2014	11/4/2014		PM - Air Handling Unit (ANNUAL)
FO-297433	11/1/2014	11/4/2014		PM - Air Handling Unit (ANNUAL)
FO-297434	11/1/2014	11/12/2014		Replace PRE-filters
FO-297435	11/1/2014	11/11/2014		Replace PRE-filters
FO-297436	11/1/2014	11/8/2014		Replace PRE-filters
FO-297437	11/1/2014	11/8/2014		Replace PRE-filters
FO-297438	11/1/2014	11/13/2014		Replace PRE-filters
FO-297439	11/1/2014	11/18/2014		Replace PRE-filters
FO-297440	11/1/2014	11/25/2014		Replace PRE-filters
FO-297441	11/1/2014	11/25/2014		Replace PRE-filters
FO-297442	11/1/2014	11/25/2014		Replace PRE-filters
FO-297443	11/1/2014	11/25/2014		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-297444	11/1/2014	11/25/2014		Replace PRE-filters
FO-297445	11/1/2014	11/13/2014		Replace PRE-filters
FO-297446	11/1/2014	11/19/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-297447	11/1/2014	11/25/2014		Replace PRE-filters
FO-297448	11/1/2014	11/22/2014		Replace PRE-filters
FO-297449	11/1/2014	11/11/2014		Replace PRE-filters
FO-297450	11/1/2014	11/11/2014		Replace PRE-filters
FO-297451	11/1/2014	11/7/2014		Replace PRE-filters
FO-297452	11/1/2014	11/7/2014		Replace PRE-filters
FO-297453	11/1/2014	11/20/2014		Replace PRE-filters
FO-297454	11/1/2014	11/14/2014		Replace PRE-filters
FO-297455	11/1/2014	11/14/2014		Replace PRE-filters
FO-297456	11/1/2014	11/14/2014		Replace PRE-filters
FO-297457	11/1/2014	11/19/2014		Replace PRE-filters
FO-297458	11/1/2014	11/19/2014		Replace PRE-filters
FO-297459	11/1/2014	11/19/2014		Replace PRE-filters
FO-297460	11/1/2014			Replace PRE-filters
FO-297461	11/1/2014	11/21/2014		Replace PRE-filters
FO-297462	11/1/2014	11/21/2014		Replace PRE-filters
FO-297463	11/1/2014	11/19/2014		Replace PRE-filters
FO-297464	11/1/2014	11/21/2014		Replace PRE-filters
FO-297465	11/1/2014	11/19/2014		Replace PRE-filters
FO-297466	11/1/2014	11/19/2014		Replace PRE-filters
FO-297467	11/1/2014	11/26/2014		Replace PRE-filters
FO-297468	11/1/2014	11/26/2014		Replace PRE-filters
FO-297469	11/1/2014	11/15/2014		Replace PRE-filters
FO-297470	11/1/2014	11/15/2014		Replace PRE-filters
FO-297471	11/1/2014	11/15/2014		Replace PRE-filters
FO-297472	11/1/2014	11/15/2014		Replace PRE-filters
FO-297473	11/1/2014	11/15/2014		Replace PRE-filters
FO-297474	11/1/2014	11/15/2014		Replace PRE-filters
FO-297475	11/1/2014	11/14/2014		Replace PRE-filters
FO-297476	11/1/2014	11/15/2014		Replace PRE-filters
FO-297477	11/1/2014	11/18/2014		Replace PRE-filters
FO-297478	11/1/2014	11/21/2014		Replace PRE-filters
FO-297479	11/1/2014	11/18/2014		Replace PRE-filters
FO-297480	11/1/2014	11/18/2014		Replace PRE-filters
FO-297481	11/1/2014	11/18/2014		Replace PRE-filters
FO-297482	11/1/2014	11/26/2014		Replace PRE-filters
FO-297483	11/1/2014	11/26/2014		Replace PRE-filters
FO-297484	11/1/2014			Replace PRE-filters
FO-297485	11/1/2014			Replace PRE-filters
FO-297486	11/1/2014			Replace PRE-filters
FO-297487	11/1/2014	11/27/2014		Replace PRE-filters
FO-297488	11/1/2014			Replace PRE-filters
FO-297489	11/1/2014	11/22/2014		Replace PRE-filters
FO-297490	11/1/2014	11/22/2014		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-297491	11/1/2014	11/22/2014		PM - Fan Coil/HV/AC Unit
FO-297492	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297493	11/1/2014	11/25/2014		PM - Fan Coil/HV/AC Unit
FO-297494	11/1/2014	11/26/2014		Replace PRE-filters
FO-297495	11/1/2014	11/25/2014		PM - Monthly Fire Alarm/Fire Protection System Test
FO-297626	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297627	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297628	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297629	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297630	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297631	11/7/2014	11/6/2014		PM - Fan Motor Box (Old Main)
FO-297632	11/7/2014	11/20/2014		PM - Fan Motor Box (Old Main)
FO-297633	11/7/2014	11/20/2014		PM - Fan Motor Box (Old Main)
FO-297634	11/7/2014			PM - Fan Motor Box (Old Main)
FO-297635	11/7/2014			PM - Fan Motor Box (Old Main)
E - South			98	
FO-293247	11/1/2014	9/13/2014		Replace PRE-filters
FO-298963	11/1/2014	11/6/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-298964	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298965	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298966	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298967	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298968	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298969	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298970	11/1/2014	11/3/2014		PM - Centrifugal Pump, over 1 H.P.
FO-298974	11/1/2014			PM - Water Softener
FO-298975	11/1/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-298976	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298977	11/1/2014	11/10/2014		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-298984	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-298985	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298986	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298987	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298988	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298989	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298990	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298991	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298992	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298993	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298994	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298995	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298996	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298997	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298998	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298999	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299000	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299012	11/1/2014	11/4/2014		PM - Chemical Feed/Metering Pump/Controller

WO	Recieved	Finished	Total	Request
FO-299013	11/1/2014	11/4/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299014	11/1/2014	11/4/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299020	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299021	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299022	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299023	11/1/2014	11/6/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299024	11/1/2014			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-299025	11/1/2014	11/26/2014		PM - Vacuum Pump
FO-299026	11/1/2014	11/26/2014		PM - Vacuum Pump
FO-299027	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299028	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299048	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299049	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299050	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299051	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299052	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299053	11/1/2014	11/25/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299054	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299055	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299056	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299057	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299058	11/1/2014	11/26/2014		PM - Heat Exchanger and Economizer
FO-299140	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299141	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299142	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299143	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299144	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299145	11/1/2014	11/11/2014		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-299146	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299147	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299148	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299149	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299150	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299151	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299159	11/1/2014	11/21/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299160	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299161	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299165	11/1/2014	11/26/2014		PM - Water/Air Cooled Condenser
FO-299198	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299206	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299207	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299208	11/1/2014	11/26/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299209	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299217	11/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-299218	11/1/2014			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-299234	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299235	11/1/2014	11/4/2014		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-299236	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299237	11/1/2014	11/11/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299238	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299239	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299240	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299843	11/8/2014	11/11/2014		Monthly AHU Inspection Clean Room Unit 2
FO-299844	11/8/2014	11/11/2014		PM - Monthly AHU Inspection Clean Room Unit 1
FO-300262	11/13/2014	11/13/2014		Generator Maintenance, Monthly
FO-300264	11/13/2014	11/13/2014		Generator Maintenance, Monthly
FO-300302	11/13/2014	11/13/2014		Generator Maintenance, Monthly
FO-300451	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300453	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300460	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300470	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300471	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300472	11/15/2014	11/25/2014		PM - Punch Tubes - Chiller/Absorber
FO-300478	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300266	11/18/2014	11/18/2014		Generator Maintenance, Monthly
FO-300268	11/19/2014	11/25/2014		Generator Maintenance, Monthly
FO-300312	11/20/2014	11/26/2014		Generator Maintenance, Monthly
E - Southeast			144	
FO-298961	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298962	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298978	11/1/2014	11/18/2014		PM - Heat Exchanger and Economizer
FO-298979	11/1/2014	11/18/2014		PM - Heat Exchanger and Economizer
FO-298980	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298981	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-298983	11/1/2014	11/3/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299001	11/1/2014	10/15/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299002	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299003	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299004	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299005	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299006	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299007	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299008	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299009	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299010	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299011	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299016	11/1/2014	11/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299017	11/1/2014	11/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299018	11/1/2014	11/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299019	11/1/2014	11/25/2014		PM - Chemical Feed/Metering Pump/Controller
FO-299045	11/1/2014	11/5/2014		PM - Heat Exchanger and Economizer
FO-299059	11/1/2014	11/3/2014		PM - Heat Exchanger and Economizer
FO-299060	11/1/2014	11/3/2014		PM - Heat Exchanger and Economizer
FO-299061	11/1/2014	9/29/2014		PM - Heat Exchanger and Economizer

WO	Recieved	Finished	Total	Request
FO-299062	11/1/2014	9/29/2014		PM - Heat Exchanger and Economizer
FO-299063	11/1/2014	9/30/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299064	11/1/2014	10/1/2014		PM - Heat Pumps (5057 Woodward)
FO-299065	11/1/2014	10/1/2014		PM - Heat Pumps (5057 Woodward)
FO-299066	11/1/2014	10/1/2014		PM - Heat Pumps (5057 Woodward)
FO-299067	11/1/2014	10/1/2014		PM - Heat Pumps (5057 Woodward)
FO-299068	11/1/2014	10/1/2014		PM - Heat Pumps (5057 Woodward)
FO-299069	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299070	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299071	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299072	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299073	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299074	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299075	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299076	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299077	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299078	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299079	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299080	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299081	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299082	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299083	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299084	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299085	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299086	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299087	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299088	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299089	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299090	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299091	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299092	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299093	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299094	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299095	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299096	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299097	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299098	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299099	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299100	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299101	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299102	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299103	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299104	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299105	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299106	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299107	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299108	11/1/2014			PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-299109	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299110	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299111	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299112	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299113	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299114	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299115	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299116	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299117	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299118	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299119	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299120	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299121	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299122	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299123	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299124	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299125	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299126	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299127	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299128	11/1/2014	10/3/2014		PM - Heat Pumps (5057 Woodward)
FO-299129	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299130	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299131	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299132	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299133	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299134	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299135	11/1/2014	10/2/2014		PM - Heat Pumps (5057 Woodward)
FO-299136	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299137	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299138	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299139	11/1/2014			PM - Heat Pumps (5057 Woodward)
FO-299152	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299153	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299154	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299155	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299156	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299157	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299158	11/1/2014			PM - Heat Exchanger and Economizer
FO-299162	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299163	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299164	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299192	11/1/2014			PM - Heat Exchanger and Economizer
FO-299193	11/1/2014			PM - Heat Exchanger and Economizer
FO-299241	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299242	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-300450	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300452	11/15/2014			PM - Punch Tubes - Chiller/Absorber

WO	Recieved	Finished	Total	Request
FO-300454	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300455	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300456	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300461	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300465	11/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-300466	11/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-300467	11/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-300468	11/15/2014			PM - Chemical Feed/Metering Pump/Controller
FO-300473	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300474	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300476	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300479	11/15/2014			PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-300480	11/15/2014			PM - Carrier Chillers: Seasonal Shut Down Services for Centrifugal Chillers
FO-300287	11/18/2014	11/19/2014		Generator Maintenance, Monthly
FO-300289	11/18/2014	11/19/2014		Generator Maintenance, Monthly
FO-301979	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301980	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301981	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301982	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301983	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301984	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301985	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301986	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
FO-301987	11/28/2014			PM - Chilled Water Coils - Drain (Old Main)
E - West			54	
FO-299015	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299029	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299030	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299031	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299032	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299033	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299034	11/1/2014	11/21/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299035	11/1/2014	10/22/2014		PM - Cooling Tower, 500 - 1000 Tons
FO-299036	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299037	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299038	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299039	11/1/2014	11/20/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299040	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299041	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299042	11/1/2014	11/24/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299043	11/1/2014	11/24/2014		PM - Water Softener
FO-299044	11/1/2014	11/25/2014		PM - Heat Exchanger and Economizer
FO-299046	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299047	11/1/2014	11/5/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299166	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299167	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299168	11/1/2014			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-299169	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299170	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299171	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299175	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299176	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299177	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299178	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299179	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299180	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299181	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299182	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299183	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299185	11/1/2014			PM - Cooling Tower, 500 - 1000 Tons
FO-299186	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299187	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299188	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299189	11/1/2014	11/18/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299190	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299191	11/1/2014	11/19/2014		PM - Centrifugal Pump, over 1 H.P.
FO-299194	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299195	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299196	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299197	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299204	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299205	11/1/2014			PM - Centrifugal Pump, over 1 H.P.
FO-299850	11/11/2014	11/12/2014		Generator Maintenance, Monthly
FO-300457	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300458	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300459	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300463	11/15/2014			PM - Punch Tubes - Chiller/Absorber
FO-300464	11/15/2014			PM - Water/Air Cooled Condenser
FO-300314	11/27/2014			Generator Maintenance, Monthly

Trades

36

Routine

36

T - Electrician

36

FO-299845	11/7/2014	11/7/2014	Generator Test
FO-299847	11/7/2014	11/7/2014	Generator Test
FO-299851	11/7/2014	11/7/2014	Generator Test
FO-299852	11/7/2014	11/7/2014	Generator Test
FO-299853	11/7/2014	11/7/2014	Generator Test
FO-299846	11/11/2014	11/12/2014	Generator Test
FO-299849	11/11/2014	11/12/2014	Generator Test
FO-300296	11/12/2014	11/12/2014	Generator Test
FO-300309	11/12/2014	11/12/2014	Generator Test
FO-300263	11/13/2014	11/13/2014	Generator Test
FO-300265	11/13/2014	11/13/2014	Generator Test
FO-300301	11/13/2014	11/13/2014	Generator Test

WO	Recieved	Finished	Total	Request
FO-300292	11/14/2014	11/14/2014		Generator Test
FO-300293	11/14/2014			Generator Maintenance, Monthly
FO-300294	11/14/2014	11/14/2014		Generator Test
FO-300295	11/14/2014			Generator Maintenance, Monthly
FO-300307	11/14/2014	11/14/2014		Generator Test
FO-300261	11/18/2014	11/18/2014		Generator Test
FO-300267	11/18/2014	11/18/2014		Generator Test
FO-300286	11/18/2014	11/18/2014		Generator Test
FO-300288	11/18/2014	11/18/2014		Generator Test
FO-300298	11/18/2014	11/18/2014		Generator Test
FO-300269	11/19/2014	11/19/2014		Generator Test
FO-300300	11/19/2014	11/19/2014		Generator Test
FO-300304	11/20/2014	11/20/2014		Generator Test
FO-300311	11/20/2014	11/20/2014		Generator Test
FO-300276	11/25/2014	11/25/2014		Generator Test
FO-300278	11/25/2014	11/25/2014		Generator Test
FO-300280	11/25/2014	11/25/2014		Generator Test
FO-300282	11/25/2014	11/25/2014		Generator Test
FO-300284	11/25/2014	11/25/2014		Generator Test
FO-300271	11/26/2014			Generator Test
FO-300290	11/26/2014			Generator Test
FO-300313	11/27/2014			Generator Test
FO-300272	11/28/2014			Generator Test
FO-300274	11/28/2014			Generator Test

Total: 2785