

# Facilities Operations Backlog as of 11/30/2014

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
<b>Maint. Work Order</b>			<b>1270</b>	<b>624</b>	<b>277</b>	<b>103</b>	<b>181</b>	<b>50</b>	<b>35</b>	<b>646</b>
<b>Custodial</b>			<b>107</b>	<b>40</b>	<b>15</b>	<b>6</b>	<b>6</b>	<b>5</b>	<b>35</b>	<b>67</b>
<b>Medium</b>			<b>3</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>2</b>
<b>C-Director</b>			<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-286508	6/5/2014	178	Created	Replaces TMA #250732 which was rejected in error.						
FO-301832	11/17/2014	13	Created	Custodial and Grounds to support Thanksgiving Day Parade and Turkey Trott.						
<b>C-Projects</b>			<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-299515	10/23/2014	38	Created	Strip and wax floor of MRI lab and office on						
<b>Low</b>			<b>67</b>	<b>39</b>	<b>14</b>	<b>6</b>	<b>5</b>	<b>3</b>	<b>0</b>	<b>28</b>
<b>C-Director</b>			<b>13</b>	<b>1</b>	<b>4</b>	<b>5</b>	<b>2</b>	<b>1</b>	<b>0</b>	
FO-281338	4/11/2014	233	Created	custodial to provide support for Admitted Students Day on Saturday April 12, 2014 to th						
FO-286401	6/4/2014	179	Created	We need for all of the offices to be vacuumed.						
FO-291753	8/5/2014	117	Created	Work						
FO-294769	9/8/2014	83	Created	Custodial to Support Weekend and night football games for Fall 2014.						
FO-294821	9/9/2014	82	Created	Need new instructor podium. The podium now in the room is very wobbly and dangerou						
FO-294983	9/10/2014	81	Created	44 soak socks - 10-99-12						
FO-295999	9/22/2014	69	Created	Custodial to provide support for DElectricity on Saturday 9.27.2014.						
FO-296008	9/22/2014	69	Created	Custodial and Grounds to provide support for the WSU Home Coming game Saturday 9						
FO-296964	10/2/2014	59	Created	Grounds to provide support for the Fordson High School Football game against De La S						
FO-297080	10/3/2014	58	Created	Support needed for Governor's debate in Old Main on 10/11/14 & 10/12/14 from 8am-4p						
FO-298707	10/20/2014	41	Created	Custodial to support Event on 10/18/2014 11am-4pm-2 Custodians.						
FO-300055	10/29/2014	32	Created	custodial to support Noel Night						
FO-301499	11/13/2014	17	Created	Custodial to cover Scholar's Day.						
<b>C-Lighting</b>			<b>15</b>	<b>9</b>	<b>2</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>0</b>	
FO-279767	3/28/2014	247	Created	Ceiling light bulb is out.						
FO-283956	5/9/2014	205	Created	Journalism Library -- One of the thin, plastic covers has come off one of the overhead li						
FO-289787	7/14/2014	139	Created	Rm 2924 - light fixture is hanging outside this room in the hall.						
FO-296605	9/29/2014	62	Created	filter needs to be changed						
FO-298498	10/16/2014	45	Created	Lower Level in room 0260 the carpet has lots of stains and needs cleaning/shampooing						
FO-299407	10/22/2014	39	Created	The light fixture over the northwest lobby entrance door, at the top of the ramp is missin						
FO-300345	11/3/2014	27	Created	Relamp Round light fixture at the south end of the west 3rd floor corridor.(Entry to lectur						
FO-301486	11/13/2014	17	Created	MD Lab 2106 -Relamp ceiling panel , back right corner of room.						
FO-302756	11/24/2014	6	Created	there are two lights out in lab 1305. please call 313-974-8716 for lab to be opened.						
FO-302849	11/24/2014	6	Created	Please replace burned out florescent bulbs in the lab.						
FO-302850	11/24/2014	6	Created	Please replace burned out florescent bulbs in the lab.						
FO-302852	11/24/2014	6	Created	Please replace burned out florescent bulbs in the lab.						
FO-302853	11/24/2014	6	Created	Please replace burned out florescent bulbs in the lab.						
FO-302857	11/24/2014	6	Created	Change 7 burnt out lights in ceiling of pool...Left will be needed. Please see Bob Ostrow						
FO-303077	11/26/2014	4	Created	Relamp two fixtures by vending area						
<b>C-Materials</b>			<b>5</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-286425	6/5/2014	178	Created	Pick up mats from Warren entrance for cleaning. 2 large black mats approximate20 feet						
FO-293572	8/27/2014	95	Created	Engineer,Replace gauges on HHWP-4 in mechanical room						
FO-297915	10/9/2014	52	Created	2 3xl Tyvek suits picked up from stockroom.						
FO-298191	10/14/2014	47	Created	NO SOAP. 2ND FLOOR MEN'S RESTROOM.						
FO-303012	11/25/2014	5	Created	Please replace the recycling bin in room 711 of the Hudson Webber Cancer Research C						

					Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
<b>C-Projects</b>					<b>3</b>	<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-298528	10/16/2014	45	Created	Lab Rm. 4363 floor needs cleaning by aft. shift (anytime aft. 6:00 pm). 10/9/14 was the								
FO-302946	11/25/2014	5	Created	Scrub and wax kitchen floor and bathroom floor								
FO-303030	11/26/2014	4	Created	Main corridors, buff and wax main corridor								
<b>C-Repair</b>					<b>15</b>	<b>14</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-297917	10/9/2014	52	Created	2nd Floor womens restroom #272. Toilet								
FO-300847	11/5/2014	25	Created	ADVANCE AUTO SCRUBBER, SERIAL #E254286 THERE A SHORTAGE IN THE SW								
FO-300860	11/5/2014	25	Created	The sweeper in Law has a damaged on/off switch.								
FO-300862	11/5/2014	25	Created	The sanitaire vacuum in Law has a missing screw to the handle.								
FO-300979	11/7/2014	23	Created	Order parts and repair two auto scrubbers for Sec 1 and for Sec 5 by November 17, 201								
FO-301281	11/11/2014	19	Parts on Order	Please replace the damaged power cord on the sector 9 project team Advance Pacesett								
FO-301303	11/12/2014	18	Created	Restroom #105 a small 1 needs a toilet paper dispenser. Also women's restroom on 1st								
FO-301313	11/12/2014	18	Created	There is broken towel dispenser on the first floor men's restroom across from room 169.								
FO-301370	11/12/2014	18	Created	NEED INK FOR PINTER FROM (FPM/STOCKROOM) (hp15) BLACK INK.								
FO-301822	11/17/2014	13	Created	2cnd floor men's room paper towel dispenser broke								
FO-302320	11/20/2014	10	Created	Sanitaire Vacuum model:sc882,ser#1351000925 needs the body repair and bolt nuts ar								
FO-302387	11/20/2014	10	Created	NEEDS TO ORDER SOME AUTO SCRUBBER PARTS FROM (ALLIED-EAGLE SUPP								
FO-302389	11/20/2014	10	Created	NEED TO ORDER SOME PARTS FROM (ALLIED-EAGLE SUPPLY CO.)								
FO-302490	11/21/2014	9	Created	The real wheel on the custodial cart in Community Arts is broken and needs to be replac								
FO-302941	11/25/2014	5	Project is under construction	Please check and repair the sector 9 project team Kent 20" side by side scrubber (0116								
<b>C-Sector 01</b>					<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-303058	11/26/2014	4	Created	Clean carpet in Room 1652 University Advising Center in the Academic Success Center								
<b>C-Sector 04</b>					<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-299677	10/24/2014	37	Created	Estimate of cost associated with cleaning carpeting in Reception area as well as hallway								
FO-299820	10/27/2014	34	Created	Carpet cleaning for the Center for Urban Studies Department located on the 2nd floor								
<b>C-Sector 06</b>					<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302109	11/18/2014	12	Created	Carpets in rooms BC and room LM need to be professionally cleaned.								
FO-302130	11/18/2014	12	Created	Request front entry hallway/foyer and stairwell and on the 1st Floor, Engineering Technol								
FO-302189	11/19/2014	11	Created	NEED CLEAN UP ON 5TH FLOOR OUTSIDE OF ROOM 586. (LEAK)								
<b>C-Sector 07</b>					<b>7</b>	<b>7</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-301782	11/17/2014	13	Created	Remove gum from terrazzo floor in first floor room 190.14 circulation desk. click on linke								
FO-301786	11/17/2014	13	Created	clan rusty water fountain on second floor. click on linked documents for picture.								
FO-301790	11/17/2014	13	Created	Remove yellow glue on book stacks on second floor outside 240. click on linked docum								
FO-301792	11/17/2014	13	Created	clean window sills along north wall on second floor. click on linked documents for picture								
FO-302788	11/24/2014	6	Created	clean or replace old faucets. click on linked documents for picture.								
FO-302790	11/24/2014	6	Created	clean terrazzo at bases and around toilets.click on linked documents for picture.								
FO-303029	11/25/2014	5	Created	Wax and seal floor in Room 3103 Old Main.								
<b>C-Sector 09</b>					<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-296996	10/2/2014	59	Created	Hello- Please wash and wax Multipurpose Room 002 also tunnel from Knapp to Skillma								
FO-299667	10/24/2014	37	Created	Scrub and wax 8th floor hallways								
<b>C-Sector 10</b>					<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302413	11/20/2014	10	Created	one case of dial soap								
<b>Routine</b>					<b>37</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>35</b>	<b>37</b>
<b>C-Director</b>					<b>37</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>35</b>	
FO-248169	4/18/2013	591	Created	FY2013 FO for HP Products								
FO-248174	4/18/2013	591	Created	FY2013 FO for Fraza Forklifts								
FO-248180	4/18/2013	591	Created	FY2013 for Rizzo Services								
FO-250313	5/9/2013	570	Created	FO for Pioneer Manufacturing Company FY2013								

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-250994	5/16/2013	563	Created	FO for Shock Brothers Inc FY2013						
FO-251498	5/22/2013	557	Created	From Heat Engineering purchase the (1) Champion Box 10 (j19LM),						
FO-251521	5/22/2013	557	Created	FO for Ricoh FY2013						
FO-257653	7/30/2013	488	Created	FO for Detroit Hardware - Grounds Purchase						
FO-257783	7/31/2013	487	Created	FO for Sells Equipment Parts						
FO-262184	9/18/2013	438	Created	FO for Hercules & Hercules						
FO-266436	11/5/2013	390	Created	FO for "CINTAS", Fiscal Year 2014						
FO-266507	11/5/2013	390	Created	Landscaping to fertilize main campus and Matthaei complex.						
FO-266509	11/5/2013	390	Created	cleaning services for floors 4-8.						
FO-267016	11/11/2013	384	Created	Grounds to address Curb Appeal III projects around campus.						
FO-267017	11/11/2013	384	Created	Custodial to Address Curb Appeal III Campus Issues.						
FO-267020	11/11/2013	384	Created	FO for "Alta Lift Truck", Fiscal Year 2014						
FO-267021	11/11/2013	384	Created	FO for "Anna's Uniforms", Fiscal Year 2014						
FO-267022	11/11/2013	384	Created	FO for "Detroit Chemical", Fiscal Year 2014						
FO-267023	11/11/2013	384	Created	FO for "Detroit Hardware", Fiscal Year 2014						
FO-267024	11/11/2013	384	Created	FO for "Grainger", Fiscal Year 2014						
FO-267025	11/11/2013	384	Created	FO for "Hercules and Hercules", Fiscal Year 2014						
FO-267026	11/11/2013	384	Created	FO for "Michigan Message Center", Fiscal Year 2014						
FO-267027	11/11/2013	384	Created	FO for "Terminix", Fiscal Year 2014						
FO-267028	11/11/2013	384	Created	FO for "Allied Eagle Supply", Fiscal Year 2014						
FO-267458	11/15/2013	380	Created	Curb Appeal III project						
FO-267513	11/15/2013	380	Created	Curb Appeal III project						
FO-267515	11/15/2013	380	Created	Matthaei- Curb Appeal III project						
FO-267516	11/15/2013	380	Created	Old Main- Curb Appeal III project						
FO-267517	11/15/2013	380	Created	Curb Appeal III project						
FO-267519	11/15/2013	380	Created	Curb Appeal III project						
FO-267520	11/15/2013	380	Created	Curb Appeal III project						
FO-267521	11/15/2013	380	Created	Curb Appeal III project						
FO-267522	11/15/2013	380	Created	Curb Appeal III project						
FO-267524	11/15/2013	380	Created	Curb Appeal III project						
FO-267525	11/15/2013	380	Created	Curb Appeal III project						
FO-281691	4/15/2014	229	Created	Fo for All American Window Cleaners, Presidents Inauguration (Mcgregor, walkway@ M						
FO-281693	4/15/2014	229	Created	Fo for All American Window Cleaners, spring cleanup( state hall entrance, wlcome cent						

## Engineering

**392    222    102    31    34    3    0    170**

### Emergency

**11    9    2    0    0    0    0    2**

#### E - Command Center

**1    0    1    0    0    0    0**

FO-297112 10/6/2014 55 Parts on Order Repair air compressor dryer.

#### E - MedPharm

**4    4    0    0    0    0    0**

FO-301022 11/7/2014 23 Created EMERGENCY ELEC

FO-302114 11/18/2014 12 Created RM 9360 CEILING LEAK, AHU# 9 AHU#13 LEAK ,,,,,,,,,,,,,, JH/11-18-14 ,,,,,,,,,,,,,,

FO-302734 11/24/2014 6 Parts on Order EMERGENCY ELEC

FO-303045 11/26/2014 4 Created EMERGENCY KROPF

#### E - North

**1    1    0    0    0    0    0**

FO-303027 11/26/2014 4 Created EMERGENCY ELEC

#### E - Northeast

**1    1    0    0    0    0    0**

FO-302833 11/24/2014 6 Created EMERGENCY ELEC

#### E - Preventative Maintenance

**1    1    0    0    0    0    0**

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-302308	11/19/2014	11	Not Finished	UPGRADING TO EMERGENCY DUE TO FOLLOWING						
<b>E - Southeast</b>			<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-297224	10/6/2014	55	Created	EMERGENCY ELEC						
FO-302738	11/24/2014	6	Created	FAP FIRE TROUBLE ALARM ACTIVE						
<b>E - West</b>			<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302837	11/24/2014	6	Created	CALLED SCHINDLER ELEV CO FOR #2 ELEV ENTRAPMENT 4TH FLR						
<b>High</b>			<b>74</b>	<b>44</b>	<b>17</b>	<b>3</b>	<b>7</b>	<b>3</b>	<b>0</b>	<b>30</b>
<b>E - Auxiliary</b>			<b>9</b>	<b>7</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
H-48359	10/3/2014	58	Created	pipes leaking in Salad 101 and no power on some of the electrical outletsauthenticate						
H-48438	10/7/2014	54	Created	The knob on the radiator in my living room came off.authenticated user: David Johnso						
H-48948	11/10/2014	20	Created	URGENT-The heater is not working from friday, the day when the engineers came to ch						
H-48984	11/10/2014	20	Created	Toilet in the first bathroom on right hand continues to not work. This is the FOURTH wor						
H-48987	11/11/2014	19	Created	I need urgent maintenance for the bathroom ceiling because there is a leaking since fou						
H-49128	11/19/2014	11	Created	Heating unit is not working.						
H-49210	11/21/2014	9	Created	Shower and sink are overflowing. Cannot use shower or sink.						
H-49218	11/24/2014	6	Created	The shower head in our bathroom has been leaking constantly for the past week or so.						
FO-302819	11/24/2014	6	Created	COG RETAIL SPACE NECT TO SUBWAY BACK DOOR WON'T CLOSE PROPERLY						
<b>E - Command Center</b>			<b>7</b>	<b>5</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-296577	9/29/2014	62	Created	Control High Priority						
FO-299354	10/22/2014	39	Created	Trade: Controls/Siemens Priority: High						
FO-301754	11/17/2014	13	Created	R/R RM 1301 REPAIR CONTROL VLV FOR HOT COIL THATS NOT WORKING CAUS						
FO-301755	11/17/2014	13	Created	R/R 1ST FLR CIRC DESK REPLACE T-STAT THATS NOT WORKINGH CAUSING CO						
FO-302169	11/18/2014	12	Parts on Order	RM 10303.30 IS TOO COLD						
FO-302175	11/18/2014	12	Created	RM 8405.7 TOO COLD						
FO-302424	11/21/2014	9	Created	HVAC Unit serving auditorium lighting booth is making loud noise.						
<b>E - MedPharm</b>			<b>20</b>	<b>16</b>	<b>3</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-294978	9/10/2014	81	Completed	ADDING CARP						
FO-298134	10/13/2014	48	Created	Room 7341 - Chemical fume hood has no flow -						
FO-298385	10/15/2014	46	Parts on Order	RM 1200 TOO HOT						
FO-298558	10/16/2014	45	Created	HIGH TEMP. ALARM. ROOM 5332.						
FO-300714	11/4/2014	26	Created	BSMNT 411 LOW TEMP						
FO-300807	11/5/2014	25	Created	LAB 200.08 LOW TEMP						
FO-300858	11/5/2014	25	Project on hold	CEILING LEAK. HALLWAY OUTSIDE OF ROOMS 5530 AND 5450.01.						
FO-300890	11/6/2014	24	Created	RM 200.01/DLAR HAS HI TEMP						
FO-301011	11/7/2014	23	Created	RM 200.07/DLAR HAS LOW HUMIDITY						
FO-301227	11/11/2014	19	Created	SHIFFMAN 139 FIRE TROUBLE ALARM						
FO-301376	11/12/2014	18	Created	PIPEFITTER:						
FO-301603	11/14/2014	16	Project on hold	CEILING LEAK. HALLWAY OUTSIDE OF ROOM 5530.						
FO-302062	11/18/2014	12	Created	LOUD BUZZING NOISE COMING FROM ROOM 212.07.						
FO-302068	11/18/2014	12	Created	1ST FL CIRCULATION AREA/ 2ND FL 232 TOO COLD						
FO-302379	11/20/2014	10	Created	RM 200.01 & 7119 HIGH TEMP						
FO-302428	11/21/2014	9	Created	TEMPERATURE ALARM. ROOM 4465.						
FO-302489	11/21/2014	9	Created	Fume hood is not drawing enough air.						
FO-302785	11/24/2014	6	Created	TOO COLD AND DOOR MAKES WHISTLING SOUND WHEN CLOSING (AIR PRESS						
FO-302818	11/24/2014	6	Created	HIGH TEMP. ALARM. ROOM 6353.						
FO-302953	11/25/2014	5	Parts on Order	ALARM SOUNDING. ROOM 2602.						
<b>E - North</b>			<b>4</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	
FO-281237	4/10/2014	234	Not Finished	ADDING						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-301754	11/17/2014	13	Created	R/R RM 1301 REPAIR CONTROL VLV FOR HOT COIL THATS NOT WORKING CAUS							
FO-301755	11/17/2014	13	Created	R/R 1ST FLR CIRC DESK REPLACE T-STAT THATS NOT WORKINGH CAUSING CO							
FO-302479	11/21/2014	9	Created	EINSTEIN BRO EXPRESS CART, BREAKER TRIPPED							
<b>E - Northeast</b>				<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-299905	10/28/2014	33	Created	ELECTRICIANS							
FO-301343	11/12/2014	18	Created	REPAIR SMOKE DETECTOR 1ST FLOOR (PUBLIC SAFETY CALLED IN FIRE ALAR							
<b>E - Preventative Maintenance</b>				<b>20</b>	<b>6</b>	<b>7</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
FO-287275	6/16/2014	167	Open to Shops	(**) P.O. Req DK 6/23/14							
FO-288179	6/24/2014	159	Created	ROOFER							
FO-293449	8/26/2014	96	Created	Windows are leaking into the room when it rains							
FO-293450	8/26/2014	96	Created	Windows are leaking into room when it rains							
FO-293462	8/26/2014	96	Created	due to the heavy rain there is water dripping into the elevator shaft and into the elevator							
FO-293586	8/27/2014	95	Not Finished	2ND FL WATER FOUNTAIN, NEAR MENS RM. PLEASE TURN FOUNTAIN OFF WAT							
FO-295497	9/16/2014	75	Created	2ND FL LAB 223 SINK NOT DRAINING, EXPERIMENT IN PROGRESS							
FO-298134	10/13/2014	48	Created	Room 7341 - Chemical fume hood has no flow -							
FO-298558	10/16/2014	45	Created	HIGH TEMP. ALARM. ROOM 5332.							
FO-298769	10/20/2014	41	Created	FAP FIRE TROUBLE ALARM SNDNG							
FO-299336	10/21/2014	40	Not Finished	**Duplicate work order / Refer to Pipefitters FO#299352 JWT							
FO-299586	10/23/2014	38	Created	5TH FL RM 5116 AND SURROUNDING AREA HEARS A PERIODIC WHINDING SOU							
FO-299819	10/27/2014	34	Created	LAB 5168 NO HEAT							
FO-299830	10/27/2014	34	Created	FIRE TROUBLE ALARM							
FO-300959	11/6/2014	24	Created	Active ceiling leak - Drywall damaged . Water is not pouring in but you can hear a stead							
FO-300967	11/6/2014	24	Created	RM 1631 LEAK COMING THROUGH LIGHT FIXTURE.							
FO-301530	11/13/2014	17	Created	Shower is leaking onto the floor in the NE corner							
FO-301854	11/17/2014	13	Created	IN BSMT LOWER LEVEL MENS RR HALLWAY LEADING TO RR WATER COMING F							
FO-302169	11/18/2014	12	Parts on Order	RM 10303.30 IS TOO COLD							
FO-302175	11/18/2014	12	Created	RM 8405.7 TOO COLD							
<b>E - South</b>				<b>6</b>	<b>2</b>	<b>2</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>0</b>	
FO-284657	5/19/2014	195	Open to Shops	**Being turned over to Vendor (Deppman)to Evaluate unresolved operations JWT 5-19-							
FO-286458	6/5/2014	178	Created	ADDING CONTRACTOR: KROPF							
FO-299819	10/27/2014	34	Created	LAB 5168 NO HEAT							
FO-300021	10/29/2014	32	Created	R/R 1ST FLR FAP PANEL FIRE PUMP IS IN TROUBLE CAUSING IT TO SOUND (EN							
FO-302945	11/24/2014	6	Created	Just outside of the doors to 3210 are three ceiling tiles that are wet/sagging on two. One							
FO-303065	11/26/2014	4	Created	MOTOR NEEDS REPLACING ON UNIT HEATER RM 1355 HEATING FAN NOT WOR							
<b>E - Southeast</b>				<b>4</b>	<b>4</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-301348	11/12/2014	18	Created	FIRE TROUBLE ALARM, CLEAN SMOKE DETECTOR							
FO-302221	11/19/2014	11	Created	RM 101.2 HAS A CLNG LEAK (believe its from the radiator above)							
FO-302732	11/24/2014	6	Created	CEILING LEAK. 3RD FLOOR STAIRWELL F.							
FO-302808	11/24/2014	6	Created	FIRE TROUBLE ALARM.							
<b>E - West</b>				<b>2</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	
FO-282429	4/23/2014	221	Created	ADDING PLUM							
FO-298739	10/20/2014	41	Created	R/R RM 336 CK SINK LKNG FROM UNDERNEATH CAUSING LEAKAGE IN RM 240 A							
<b>Medium</b>				<b>114</b>	<b>62</b>	<b>26</b>	<b>14</b>	<b>12</b>	<b>0</b>	<b>0</b>	<b>52</b>
<b>E - Auxiliary</b>				<b>7</b>	<b>7</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
H-48861	11/4/2014	26	Created	Faucet in bathroom is continuously running. It's not a full force run, but not just a drip eit							
H-48985	11/10/2014	20	Created	problem with sink grinder, heater is not working properly.authenticated user: Naveen R							
FO-301210	11/11/2014	19	Created	FREIGHT ELEVATOR 8492 IS NOT WORKING. BELIEVED TO BE STUCK ON THE 6							
H-49129	11/19/2014	11	Created	Heater is not working at all. Room is frigid.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
H-49187	11/20/2014	10	Created							Heating unit is not working. Unit is blowing out cold air.
H-49200	11/21/2014	9	Created							heat not getting hot enough in Ghafari CD apartment
H-49208	11/21/2014	9	Created							The shower is leaking and getting water on the bathroom floor.
<b>E - Command Center</b>			<b>34</b>	<b>11</b>	<b>12</b>	<b>10</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-293208	8/25/2014	97	Created							HVAC UNIT IS MAKING LOUD NOISE. ROOM 1332.
FO-294255	9/2/2014	89	Not Finished							RM 0134 AIR NOT WORKING
FO-294749	9/8/2014	83	Parts on Order							R/R RM 12205.2 HPR #2-87 ISN'T COOLING HAD PREVIOUSLY RESET HP HOWEV
FO-294749	9/8/2014	83	Parts on Order							R/R RM 12205.2 HPR #2-87 ISN'T COOLING HAD PREVIOUSLY RESET HP HOWEV
FO-294759	9/8/2014	83	Created							Trade: Command Center
FO-295479	9/16/2014	75	Created							Quote from faculty member:
FO-295776	9/18/2014	73	Created							Trade: Controls/Johnson Controls
FO-295804	9/18/2014	73	Created							R/R RM 040/LAB HEAT PUMP KEEPS TRIPPING. FILTER & COIL ARE CLEAN PRO
FO-295909	9/19/2014	72	Created							Control Engineer; Medium
FO-296396	9/25/2014	66	Created							BAS Controls Med. Priority
FO-296728	9/30/2014	61	Created							CONTROLS (HIGH)
FO-296901	10/1/2014	60	Created							MENS LOCKER RM, AIR NOT WORKING
FO-296981	10/2/2014	59	Created							Electrician's: MED High Priority
FO-297086	10/4/2014	57	Project on hold							Repair or Replace Power Controllers for Hot and Cold Deck on all three Supply Fans.
FO-297120	10/6/2014	55	Created							Controls: MED High Priority.
FO-297958	10/10/2014	51	Created							REPAIR HEAT PUMP UNIT CONTANTLY TRIPS
FO-297970	10/10/2014	51	Created							Repair leaking gas line on boiler #1.
FO-298366	10/15/2014	46	Created							Inspect and repair air leak on the diaphragm for the damper motor on the make up air fa
FO-299451	10/23/2014	38	Created							combustion analysis
FO-299789	10/27/2014	34	Created							Control Engineer; High
FO-299798	10/27/2014	34	Created							Repair pneumatic control system serving SF-4. Heating control is running wild, overheati
FO-299799	10/27/2014	34	Created							Repair pneumatic control system serving SF-7. Heating control is running wild, overheati
FO-300085	10/29/2014	32	Created							Repair furnace. When burner comes on flames shoot out the side.
FO-301488	11/13/2014	17	Created							Trade: Controls
FO-301517	11/13/2014	17	Parts on Order							RM 10303.3 IS TOO COLD
FO-301777	11/17/2014	13	Not Finished							R/R RM 235 REPAIR HTG/CLNG UNIT FOR RM 235 WILL ONLY WORK ON CLNG N
FO-301781	11/17/2014	13	Created							AIR HANDLER UNIT #1 FREEZE STAT KEEPS TRIPPING OUT. SEE ENGINEER FO
FO-301795	11/17/2014	13	Parts on Order							Rm#150 - Conf Rm- supplemental furnace not firing. Please investigate.
FO-301819	11/17/2014	13	Created							TOO COLD. ROOM 189.
FO-301850	11/17/2014	13	Created							TOO HOT. ROOM 2337.
FO-302202	11/19/2014	11	Created							Trade: Command Center
FO-302352	11/20/2014	10	Parts on Order							Command Center-Please repair #3 rooftop. Found off @ disconnect 11/19?
FO-302416	11/20/2014	10	Created							071-RM 8405.5 TOO COLD
FO-302990	11/25/2014	5	Created							CONTROLS please troubleshoot control related issues with operation of Boiler #2. Boile
<b>E - MedPharm</b>			<b>20</b>	<b>17</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-299495	10/23/2014	38	Created							Low humidity
FO-299660	10/24/2014	37	Created							RM 5248 HAS LOW WATER PRESSURE/STILL A PROBLEM
FO-300111	10/30/2014	31	Created							1ST FL SHIFFMAN LIBRARY TOO COLD
FO-300212	10/31/2014	30	Created							Loading Dock - Levelator will not operate properly only goes down will not go up.
FO-300708	11/4/2014	26	Created							RM 1230 TOO COLD
FO-301203	11/11/2014	19	Created							Please inspect the fume hood located in this room. It is running at 147 FPM so it is lik
FO-301474	11/13/2014	17	Created							RM 520 TOO COLD
FO-301500	11/13/2014	17	Created							RM 4263 IS TOO COLD (not the cold rm)

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-301501	11/13/2014	17	Created	INSIDE RM 4263 - RM 4265 IS TOO COLD (not the cold rm)						
FO-301502	11/13/2014	17	Created	INSIDE RM 4263 - RM 4267 IS TOO COLD (not the cold rm)						
FO-301586	11/14/2014	16	Created	TOO COLD. ROOMS 102 AND 108.						
FO-301646	11/14/2014	16	Created	RM 0225 HAS A CLNG LEAK						
FO-302061	11/18/2014	12	Created	Please repair brackets Ceiling tile is bulging and about to fall.						
FO-302347	11/20/2014	10	Created	SINK LEAKING ROOMS 5324 AND 5344. SEE ENGINEER FOR MORE DETAILS. (M						
FO-302349	11/20/2014	10	Created	TOO HOT. ROOM 8252.						
FO-302364	11/20/2014	10	Created	INNER & OUTER LOBBY IS TOO COLD PLS TURN ON HEAT						
FO-302465	11/21/2014	9	Created	RM 5245 TOO COLD						
FO-302474	11/21/2014	9	Created	RM 109 COLD AIR IS BLOWING DOWN ON OCCUPANT						
FO-302780	11/24/2014	6	Created	RM 315 TOO HOT						
FO-302789	11/24/2014	6	Created	RM 6111 TOO HOT						
<b>E - North</b>			<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-301479	11/13/2014	17	Created	BLDG TOO COLD						
FO-301819	11/17/2014	13	Created	TOO COLD. ROOM 189.						
<b>E - Northeast</b>			<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-300837	11/5/2014	25	Created	MAIL RM AREA SURROUNDING BASEBOARD HTG UNITS AREN'T ON COLD						
FO-303054	11/26/2014	4	Created	CONTRACTOR REQUESTING ENG TO GO OVER BLDG						
<b>E - Preventative Maintenance</b>			<b>22</b>	<b>8</b>	<b>7</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
FO-288010	6/23/2014	160	Created	Roof is leaking near the south east roof drain.						
FO-288305	6/25/2014	158	Work in Progress	WATER COMING FROM UNDERNEATH DOOR. ROOM 6373.						
FO-291104	7/30/2014	123	Not Finished	RM 174 STANDING WATER IN JANITOR'S CLOSET						
FO-293208	8/25/2014	97	Created	HVAC UNIT IS MAKING LOUD NOISE. ROOM 1332.						
FO-293423	8/26/2014	96	Created	RM 133 RAIN POURING IN FROM WINDOW						
FO-293517	8/27/2014	95	Created	Second window in conference room has a						
FO-294255	9/2/2014	89	Not Finished	RM 0134 AIR NOT WORKING						
FO-296901	10/1/2014	60	Created	MENS LOCKER RM, AIR NOT WORKING						
FO-298364	10/15/2014	46	Created	Replace motor mount						
FO-299587	10/23/2014	38	Created	RM 317 TOO COLD						
FO-299669	10/24/2014	37	Created	2ND FLR MENS RR (ONLY ONE) ONLY TOILET IS CON'T FLUSHING						
FO-299673	10/24/2014	37	Created	RM 1144/WOMENS RR HAS WATER POURING DOWN FROM CLNG						
FO-299676	10/24/2014	37	Created	FIRE TROUBLE ALARM						
FO-300174	10/30/2014	31	Created	hood W5, left side: The aspirator's pipe can't be closed in full, and water is constantly le						
FO-300412	11/3/2014	27	Created	1ST FLR MENS RR 3RD STALL TOILET NOT FLUSHING						
FO-300786	11/4/2014	26	Created	R/R RM 5344 ONLY SINK HAS A STEADY LEAK COMING FROM FAUCET (ENGINEE						
FO-301250	11/11/2014	19	Not Finished	WHOLE IS CEILING POSSIBLE LEAK. ROOM 3129.						
FO-301517	11/13/2014	17	Parts on Order	RM 10303.3 IS TOO COLD						
FO-301850	11/17/2014	13	Created	TOO HOT. ROOM 2337.						
FO-302416	11/20/2014	10	Created	071-RM 8405.5 TOO COLD						
FO-303009	11/25/2014	5	Created	RM 1111 CEILING LEAK						
FO-303019	11/25/2014	5	Created	PLEASE CHECK GENERATOR, MAKING A STRANGE NOISE. SEE LOUISE						
<b>E - South</b>			<b>7</b>	<b>0</b>	<b>2</b>	<b>2</b>	<b>3</b>	<b>0</b>	<b>0</b>	
FO-290667	7/23/2014	130	Created	R/R RM 255 REPAIR GLASS FLR DRAIN LINE FOR SINK Water on floor near door. S						
FO-292623	8/18/2014	104	Not Finished	ELECTRICIANS						
FO-292625	8/18/2014	104	Not Finished	SHEETMETAL						
FO-294391	9/3/2014	88	Created	ADDING PLUMB						
FO-295804	9/18/2014	73	Created	R/R RM 040/LAB HEAT PUMP KEEPS TRIPPING. FILTER & COIL ARE CLEAN PRO						
FO-299587	10/23/2014	38	Created	RM 317 TOO COLD						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-299864	10/28/2014	33	Created	RM 146 IS EXTREMELY HOT SAYS T-STAT IS FLASHING						
<b>E - Southeast</b>			<b>18</b>	<b>15</b>	<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-295479	9/16/2014	75	Created	Quote from faculty member:						
FO-298424	10/15/2014	46	Created	RM 1107 IS EXTREMELY HOT						
FO-298454	10/15/2014	46	Created	RM 1321 IS TOO HOT						
FO-301222	11/11/2014	19	Created	No heat in Room 203 Rackham, in particular 203.3.						
FO-301302	11/12/2014	18	Created	WINDOW STUCK OPEN. ROOM 1137. (Multi-Task)						
FO-301362	11/12/2014	18	Created	RM 109 TOO COLD						
FO-301364	11/12/2014	18	Created	RM 201.4 TOO HOT						
FO-301375	11/12/2014	18	Created	BLDG IS TOO COLD						
FO-301777	11/17/2014	13	Not Finished	R/R RM 235 REPAIR HTG/CLNG UNIT FOR RM 235 WILL ONLY WORK ON CLNG N						
FO-302111	11/18/2014	12	Created	TOO COLD. ROOM 416.						
FO-302381	11/20/2014	10	Created	RM 340 WINDOW UNIT NEEDS FILTER REPLACED						
FO-302750	11/24/2014	6	Created	It is very hot in suite 207. Can the heat be turned off just for today since it is warm out si						
FO-302751	11/24/2014	6	Created	BLDG TOO HOT.						
FO-302752	11/24/2014	6	Created	STE 5000 TOO HOT						
FO-302827	11/24/2014	6	Created	RM 2218 IS TOO HOT						
FO-302845	11/24/2014	6	Created	STE 5000 TOO COLD						
FO-302988	11/25/2014	5	Created	9th FL 9310 BURNNING RUBBER SMELL						
FO-302991	11/25/2014	5	Created	2ND FL RM 228 CREEK IN CEILING						
<b>E - West</b>			<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-292141	8/11/2014	111	Created	ADDING ROOFER						
FO-292170	8/11/2014	111	Created	ADDING ROOFER						
<b>Low</b>			<b>193</b>	<b>107</b>	<b>57</b>	<b>14</b>	<b>15</b>	<b>0</b>	<b>0</b>	<b>86</b>
<b>E - Area 1 Engineer</b>			<b>7</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-287925	6/23/2014	160	Created	CLASSROOM #0171, WATER LEAKING OVER RADITOR NEAR WINDOW. WATER L						
FO-298688	10/20/2014	41	Created	2cnd floor ladies(no room number) room/handy-cap stall toilet contiguously flushing						
FO-298689	10/20/2014	41	Created	1st floor state Hall exit 4/ handy-cap door closing very slowly						
FO-299736	10/27/2014	34	Created	the 1st floor ladies room inside of Suite 1600 (no room number) toilet continuously flushi						
FO-299739	10/27/2014	34	Created	Second floor men's room 2238 urinal overflowing when flushed						
FO-300065	10/29/2014	32	Created	3rd floor restroom 309/no water coming from the faucets in 2 of the sinks						
FO-302051	11/18/2014	12	Created	Water is coming from under the door of locked mechanical room/custodial dept has no						
<b>E - Auxiliary</b>			<b>34</b>	<b>26</b>	<b>7</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-291190	7/31/2014	122	Created	CALLED SCHINDLER ELEV CO FOR #1 ELEV STUCK ON 11TH FLR						
H-48394	10/6/2014	55	Created	Heat is not working, need to fix thermostat or some functionality with the ventilation. Als						
H-48466	10/9/2014	52	Created	please check for leak in ceiling near soda pop machines in gold n greens						
H-48470	10/9/2014	52	Created	room 124 Ghafari, DWB-004 broke! burners broke, need parts						
H-48474	10/9/2014	52	Created	Resident said that faucet in kitchen has been dripping for a long time. Resident would lik						
H-48501	10/12/2014	49	Created	under sink unit, there is a leak that has wet the carpet inside the lounge as well as in the						
H-48726	10/28/2014	33	Created	Light is flickering between 510 and 508						
H-48740	10/29/2014	32	Created	Fix toilet - toilet won't flush. authenticated user: Ramona Stamatin - fo3091requester						
H-48796	10/31/2014	30	Created	Above door inside the lounge, a round metal piece is coming out from the ceiling. Not su						
H-48803	10/31/2014	30	Created	NOT IN THE LOUNGE!!! Drinking fountains in back hallway are broken.						
H-48830	11/1/2014	29	Created	Please take care of 2 problems at DeRoy #812:1. Leaking under the kitchen sink (in						
H-48825	11/1/2014	29	Created	The AC's temperature sensor to control the temperature of the apartment doesn't work						
H-48867	11/5/2014	25	Created	Leak in the ceiling near the office						
H-48869	11/5/2014	25	Created	ballasts marked by blue tape in the multipurpose room need to be replaced.						
H-49015	11/13/2014	17	Created	The fire alarm red light is flashing - potential low battery issue.authenticated user: Per						



			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
H-49055	11/14/2014	16	Created	The heating unit in room 326 is out.						
H-49060	11/16/2014	14	Created	room is only blowing cold air.						
H-49061	11/16/2014	14	Created	room is only blowing cold air.						
H-49062	11/16/2014	14	Created	Our shower started dripping water a few days ago.Last night that drip increased to a full						
H-49063	11/16/2014	14	Created	Resident's heat is not working						
H-49123	11/18/2014	12	Created	we have problem with the heat it keeps giving cold air and the light in the bathroom doe						
H-49127	11/18/2014	12	Created	The A/C is not working. It is only circulating cold air.						
H-49170	11/19/2014	11	Created	The blinds and heater are both not functioning. Please fix them as soon as possible.						
H-49171	11/19/2014	11	Created	Heat not working						
H-49172	11/20/2014	10	Created	Heat not working in room 437. Unit is blowing out cold air.						
H-49186	11/20/2014	10	Created	The heat in our room is not working at all! We are sleeping in a freezer!authenticated						
H-49160	11/20/2014	10	Created	Replace all faucets: bathrooms and kitchen						
H-49176	11/20/2014	10	Created	Shower leaks.						
H-49178	11/20/2014	10	Created	The shower leaks.						
H-49180	11/20/2014	10	Created	The heat in the lounge is broken.						
H-49224	11/21/2014	9	Created	Thermostat is not working in the room. Blows air, but doesn't get hot or cold. authentic						
H-49227	11/21/2014	9	Created	The heater inside the room can not be adjusted. authenticated user: Christopher Cros						
H-49285	11/25/2014	5	Created	Ceiling leaking.						
H-49283	11/25/2014	5	Created	The vents need to be cleaned.						
<b>E - Command Center</b>			<b>111</b>	<b>59</b>	<b>30</b>	<b>11</b>	<b>11</b>	<b>0</b>	<b>0</b>	
FO-290749	7/24/2014	129	Parts on Order	Siemens BAS:						
FO-291187	7/31/2014	122	Created	W.J. O Neil						
FO-291213	7/31/2014	122	Created	SIEMENS:						
FO-292123	8/11/2014	111	Parts on Order	Please investigate DHW heater #2-valve control issue - see P. Belcher.						
FO-292867	8/20/2014	102	Completed	Please raise thermastat in room to 78* F. I have a special animal study that requires th						
FO-292867	8/20/2014	102	Completed	Please raise thermastat in room to 78* F. I have a special animal study that requires th						
FO-292987	8/22/2014	100	Created	R/R RM 0100/MECH RM please have controls repair, replace or order discharge air sen						
FO-293069	8/22/2014	100	Created	HONEYWELL:						
FO-293070	8/22/2014	100	Created	HONEYWELL:						
FO-293154	8/25/2014	97	Parts on Order	Siemens/Refg. Crew:						
FO-293582	8/27/2014	95	Created	Water is still leaking in to front room and running down Glass Block windows. Previous						
FO-292630	9/1/2014	90		refrigeration crew please troubleshoot cooling tower fans controls for auto operation,the						
FO-294857	9/9/2014	82	Created	Trade: Controls/Siemens Priority: Medium						
FO-294858	9/9/2014	82	Created	Trade: Controls/Siemens Priority: Medium						
FO-295099	9/11/2014	80	Created	Engineering Controls Medium						
FO-295100	9/11/2014	80	Created	Engineering Controls Medium						
FO-295136	9/12/2014	79	Parts on Order	Refg. Crew:						
FO-295258	9/13/2014	78	Created	Trade: Command Center						
FO-295741	9/17/2014	74	Created	Trade: Controls						
FO-296263	9/23/2014	68	Created	Control Engineer; Medium						
FO-296531	9/27/2014	64	Created	Engineering Controls Medium						
FO-294495	9/30/2014	61	Created	Control Engineer; High						
FO-296888	10/1/2014	60	Created	Repair or replace Draft Controller on boiler						
FO-296889	10/1/2014	60	Created	OCC Boiler # 1, leave rear door open.						
FO-297221	10/6/2014	55	Created	Trade: Command Center						
FO-297679	10/8/2014	53	Created	Trade: Controls Priority: MediumTag#090-HWP-017R/R RM 346/MECH RM On the						
FO-297722	10/8/2014	53	Created	Engineering Controls; High,						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-297724	10/8/2014	53	Created							Engineering Controls; High,
FO-297728	10/8/2014	53	Created							Engineering controls; High,
FO-297846	10/9/2014	52	Created							REFRIG CREW,
FO-297848	10/9/2014	52	Created							REFRIG CREW,
FO-297969	10/10/2014	51	Created							Boiler #3 has leaking gas valve (hydraulic oil).
FO-298006	10/10/2014	51	Created							Trade: Controls/Siemens Priority: MediumR/R BLDG The Siemens system is not main
FO-298030	10/13/2014	48	Parts on Order							Trade: Controls Priority: High
FO-298063	10/13/2014	48	Created							Repair Belimo controller serving HX-1 at McGregor. The controller is wide open this mor
FO-298076	10/13/2014	48	Created							Controls Med. Priority
FO-298175	10/13/2014	48	work in progress							Siemens-BAS-Chiller enable point is not responding to commands, resulting in chiller co
FO-298462	10/15/2014	46	Created							AC-shop:R/R RM 0024.10/MECH-BLR RM please repair or replace boiler # 2 feed wa
FO-298479	10/16/2014	45	Created							PLEASE REPAIR CONTROL LINE AIR LEAK TO PRESSURE SWITCH ON POOL CO
FO-298591	10/17/2014	44	Created							BAS: R/R BLDG Please install bldg. humidity sensor for Siemens system to avoid net
FO-298594	10/17/2014	44	Created							CONTROLS R/R RM 00021/MECH RM please repair several minor pneumatic leaks
FO-298680	10/19/2014	42	Created							HVAC-2, (serves the Law Classroom), will only run in manual. Repair fan starter circuit s
FO-298681	10/19/2014	42	Created							HV-3, (serves the Law Library Locker Rooms), will only run in manual. Repair fan starter
FO-299433	10/22/2014	39	Created							Trade: ControlsPriority: HighR/R RM 0000.62/MECH BLR RM Boiler 4 - Perform flu
FO-299609	10/24/2014	37	Created							Trade: ControlsPriority: MediumR/R RM 027.5 Please repair controls for room 27.5.
FO-299630	10/24/2014	37	Created							Refr. Crew:
FO-299731	10/27/2014	34	Created							AUBREY WALLER/ REFRIG CREW- please check boiler #1 5425 Woodward. Filled an
FO-299959	10/28/2014	33	Created							Controls --Priority medium
FO-300050	10/29/2014	32	Created							Controls, please assist in determining the proper rm. # of the thermostats and air motor
FO-300145	10/30/2014	31	Created							Control Engineer; HighR/R E PUTNAM LOBBY Please repair the heat pump 071-HW
FO-300147	10/30/2014	31	Created							Control Engineer; HighR/R W WOODWARD LOBBY Please repair the heat pump 071
FO-300162	10/30/2014	31	Created							Trade: Controls
FO-300347	11/3/2014	27	Created							controls crew
FO-300358	11/3/2014	27	Created							BAS Section:
FO-300391	11/3/2014	27	Created							Steven is experiencing wide temp/air volume swings. There is also the issue of the VAV
FO-300707	11/4/2014	26	Parts on Order							Controls group/SIEMENS
FO-300822	11/5/2014	25	Created							Please investigate Rm#VAV's #1200 Scott Hall. NTE \$1500.00. Refer PO#696055.
FO-300940	11/6/2014	24	Created							Trade: Controls/Siemens Priority: HighR/R BLDG EDC Engine lab 1551 is in a negativ
FO-300943	11/6/2014	24	Created							Needed diaphragm for A. Kotal
FO-301008	11/7/2014	23	Parts on Order							CONTROLS CREW,
FO-301119	11/10/2014	20	Created							BAS crew: Please troubleshoot ahu 2 mixed air dampers,: responding slow, possible le
FO-301199	11/11/2014	19	Created							R/R MAIN ENTRANCE A BUZZING NOISE ELECS' TO CK LIGHT BALLAST
FO-301334	11/12/2014	18	Created							trade controls priority high
FO-301373	11/12/2014	18	Created							Controls -- Priority Medium
FO-301408	11/13/2014	17	Created							Face & Bypass Dampers not working
FO-301512	11/13/2014	17	Created							HONEYWELL- R/R RM 112/RECEIVING please r/r heat in main office. control valve f
FO-301593	11/14/2014	16	Created							HONEYWELL-
FO-301747	11/17/2014	13	Created							Trade: Command Center
FO-301766	11/17/2014	13	Created							Control Engineer; High
FO-301825	11/17/2014	13	Created							Controls-- Priority MediumR/R RM 201 Heating/Cooling unit (part# 26) not getting hot.
FO-301830	11/17/2014	13	Created							Refr. Crew:R/R RM 316/MECH RM Please check stroke on new 3-way control valve o
FO-302042	11/18/2014	12	Created							R/R RM 00025/MECH RM Supply fan 1 serving the auditorium has a defective controller
FO-302124	11/18/2014	12	Created							Controls,
FO-302138	11/18/2014	12	Created							BAS crew:

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-302149	11/18/2014	12	Created	R/R RM 00032/MECH RM Supply fan 13 for Alumni house has hot deck programmed to							
FO-302160	11/18/2014	12	Created	Repair/replace controller on AHU # 5.							
FO-302193	11/19/2014	11	Created	CONTROLS-							
FO-302196	11/19/2014	11	Created	CONTROLS-							
FO-302204	11/19/2014	11	Created	Controls: MED PriorityR/R 2ND FLR Please repair/replace Trane thermostat located 2							
FO-302223	11/19/2014	11	Created	Control Engineer; High							
FO-302224	11/19/2014	11	Created	Control Engineer; High							
FO-302254	11/19/2014	11	Created	Controls, R/R RM 400.10/MECH BLR RM repair/replace alarm horn on boiler #3.							
FO-302324	11/20/2014	10	Created	HONEYWELL please r/r control valve that is stuck in closed position for south half of ro							
FO-302340	11/20/2014	10	Created	R/R RM 4087.01 EF-35 is only showing 13 cfm and is showing as an 'AO' point, it sho							
FO-302353	11/20/2014	10	Created	Control Engineer; HighR/R RM 8307.20 Please check the refrigerant pressures in heat							
FO-302354	11/20/2014	10	Created	Control Engineer; HighR/R RM 9305.20 Please check the refrigerant pressures in heat							
FO-302356	11/20/2014	10	Created	Control Engineer; HighR/R RM 9204.10 Please check the refrigerant pressures in heat							
FO-302357	11/20/2014	10	Created	Control Engineer; HighR/R RM 9311 Please check the refrigerant pressures in heat pu							
FO-302358	11/20/2014	10	Created	Control Engineer; HighR/R RM 10410.00 Please check the refrigerant pressures in he							
FO-302363	11/20/2014	10	Created	Control Engineer; HighR/R RM 10202 Please check the refrigerant pressures in heat p							
FO-302359	11/20/2014	10	Created	Control Engineer; HighR/R RM 10303 Please check the refrigerant pressures in heat p							
FO-302360	11/20/2014	10	Created	Control Engineer; HighR/R RM 10304.40 Please check the refrigerant pressures in he							
FO-302388	11/20/2014	10	Created	Controls Med. to High PriorityR/R 1ST FLR HALLWAY NEAR RM 1108 replace small							
FO-302397	11/20/2014	10	Created	Trade: Controls/Siemens Priority: HighR/R EDC Engine test cell lab 1539 room temper							
FO-302436	11/21/2014	9	Created	Control Engineer; HighR/R MEZZANINE Please repair heat pumps #142 & #143(Mast							
FO-302437	11/21/2014	9	Created	Control Engineer; High							
FO-302441	11/21/2014	9	Created	Controls: High Priority.							
FO-302452	11/21/2014	9	Created	Controls: Med High							
FO-302457	11/21/2014	9	Created	Trade controls priority medium R/R RM 530.10 please check air handler #2 at ugl pint h							
FO-302742	11/24/2014	6	Created	Trade: Command CenterPriority: MediumR/R RM 0231/LAB Please repair VAV box							
FO-302963	11/25/2014	5	Created	trade controls priority high R/R RM 1147 please service air dryer here at bio-science fan							
FO-302966	11/25/2014	5	Created	Controls -- Priority HighR/R RM 337.10 Heat Pump constantly kicks off and needs res							
FO-302994	11/25/2014	5	Created	Investigate AHU#4 F&BP dampers & coil> no airflow.							
FO-302995	11/25/2014	5	Created	BAS group: R/R PENTHOUSE Please replace ahu 4 steam valve actuator diaphragm							
FO-302996	11/25/2014	5	Created	BAS group: R/R PENTHOUSE please replace ahu 4 preheat damper controls to work							
FO-303047	11/26/2014	4	Created	Refg. Crew:R/R RM 410/MECH RM The PRV that controls the domestic hot water will							
FO-303049	11/26/2014	4	Created	Honeywell/Refg. Crew.R/R 3133/MECH RM The outside air sensor for Law School BA							
FO-303055	11/26/2014	4	Created	Replace needed damper motors for combustion air.							
FO-303056	11/26/2014	4	Created	Investigate Boiler #3, fail to ignite> see Gregg Ray.							
FO-303069	11/26/2014	4	Created	Controls:							
FO-303093	11/30/2014	0	Created	Adjust pneumatic controls on AHU-1 serving the large lecture hall room 100 for proper o							
<b>E - MedPharm</b>				<b>10</b>	<b>6</b>	<b>3</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-292852	8/20/2014	102	Created	Room 5357 and 5353 have little to no water pressure. Please fix ASAP. Thanks!.....							
FO-299309	10/21/2014	40	Created	Fume hood sash need to be adjusted for proper operation.							
FO-299501	10/23/2014	38	Created	RM 469 Low humidity							
FO-300169	10/30/2014	31	Created	NOTE: Room 5203 is not listed. That is where the							
FO-300896	11/6/2014	24	Created	BSMT NEED ACCESS TO RM NEAR DOCK AREA CHANGINE OUT METER PH #313							
FO-301196	11/11/2014	19	Created	Low humidity							
FO-301197	11/11/2014	19	Created	Low humidity							
FO-301198	11/11/2014	19	Created	Low humidity							
FO-302414	11/20/2014	10	Created	Have engineer pick up ladder that was loaned to Pharmacology department. Thank yo							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-303061	11/26/2014	4	Created	The outlets in 232B, 232D, and the open suite area of 232 are not working.							
<b>E - North</b>				<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-297587	10/7/2014	54	Created	Building is having heating issues. Please send							
FO-301547	11/13/2014	17	Created	Hallway corridor outside room 352- need lights							
<b>E - Northeast</b>				<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-301325	11/12/2014	18	Created	Clean gutters of leaves and debris for the Winter							
<b>E - Preventative Maintenance</b>				<b>11</b>	<b>5</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-296809	9/30/2014	61	Created	Lab, Rm 3437 - repair sink leaks; starting with 1 from the North/Brady side, 1st sink fast							
FO-298137	10/13/2014	48	Created	(**) PO REQ DK							
FO-298356	10/15/2014	46	Created	Belt order							
FO-298362	10/15/2014	46	Created	Replacement Belts for Atrium Supply Fan (for PM shift)							
FO-299588	10/24/2014	37	Created	Filter order for Lande DLAR Labs							
FO-299976	10/28/2014	33	Created	Distilled water not working in research labs.							
FO-300679	11/4/2014	26	Created	Fan Sheave:							
FO-302728	11/22/2014	8	Created	January Filter Order for Matthaei OA Intakes							
FO-302938	11/25/2014	5	Created	Please purchase 6 qts oil for fans with oil bearings. Grainger Part # 1UBX8							
FO-302939	11/25/2014	5	Created	Belt order							
FO-302940	11/25/2014	5	Created	Belt order							
<b>E - South</b>				<b>10</b>	<b>4</b>	<b>5</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-286353	6/4/2014	179	Created	R/R RM 0247 CUT/CAP THE copper pipe coming from ceiling that needs to be removed							
FO-297168	10/6/2014	55	Created	ADDING PLUMBERS							
FO-299366	10/22/2014	39	Created	Received a report of a loud fan in the ceiling of							
FO-299863	10/28/2014	33	Created	ROOFER/CONTRACTOR							
FO-299938	10/28/2014	33	Created	Fume hood is running too high and is in alarm.							
FO-299976	10/28/2014	33	Created	Distilled water not working in research labs.							
FO-301442	11/13/2014	17	Created	The fume hood in this room is running too high							
FO-301445	11/13/2014	17	Created	The fume hood in this room is running too low							
FO-301446	11/13/2014	17	Created	The fume hood in this room is running too high							
FO-301831	11/17/2014	13	Created	**Steam Traps Leaking By Are The suspected cause. Replacement Steam Traps on Or							
<b>E - Southeast</b>				<b>7</b>	<b>4</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-294383	9/3/2014	88	Created	ADDING ROOFER:							
FO-294385	9/3/2014	88	Created	ADDING ROOFER							
FO-297691	10/8/2014	53	Created	We have the Governor's Debate coming to campus on Sunday, October 12, 2014 startin							
FO-301437	11/13/2014	17	Created	WILL NEED ACCESS TO MECH RM PH #313-220-2637							
FO-302385	11/20/2014	10	Created	Ms. Faith Williams says it is too hot in her office she is in room 207.3.							
FO-302458	11/21/2014	9	Created	Room 101.2 ceiling is still leaking water. It was fixed twice this week but it is still leaking							
FO-302830	11/24/2014	6	Created	HVAC not circulating air in this office.Needs to be reset.							
<b>Grounds</b>				<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Low</b>				<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>G - Moving/Storage</b>				<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-300948	11/6/2014	24	Created	Grounds to support Friday Night 11/7/2014 HS Football Game							
FO-301758	11/17/2014	13	Created	Grounds:R/R BSMT Please remove old valves and other debris in mechanical rooms							
<b>G - Physical Grounds</b>				<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302815	11/24/2014	6	Created	need 3 bangs of oil absorbent, 2 boxes of dust masks, and 6 clear safety glasses.							
<b>Trades</b>				<b>768</b>	<b>359</b>	<b>160</b>	<b>66</b>	<b>141</b>	<b>42</b>	<b>0</b>	<b>409</b>
<b>Emergency</b>				<b>19</b>	<b>14</b>	<b>5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>5</b>
<b>T - Carpenter</b>				<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-302278	11/19/2014	11	Created	ADDING CARPENTER: Please remove ceiling in closet located in basement north east						
FO-303031	11/26/2014	4	Created	EMERGENCY CARP						
<b>T - Electrician</b>			<b>9</b>	<b>6</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-297224	10/6/2014	55	Created	EMERGENCY ELEC						
FO-298600	10/17/2014	44	Created	Electricians--R/R BLDG OUTSIDE AREA -Repair Outside Lamp Post closest to east B						
FO-299465	10/23/2014	38	Created	R/R BSMNT NW CORNER SUMP PUMP WON'T START						
FO-301022	11/7/2014	23	Created	EMERGENCY ELEC						
FO-302734	11/24/2014	6	Parts on Order	EMERGENCY ELEC						
FO-302735	11/24/2014	6	Created	EMERGENCY ELEC						
FO-302833	11/24/2014	6	Created	EMERGENCY ELEC						
FO-303027	11/26/2014	4	Created	EMERGENCY ELEC						
FO-303064	11/26/2014	4	Created	Electrician; Emergency R/R RM 0195/MECH RM No. 1 Boiler down due to blown fuse						
<b>T - Pipefitter</b>			<b>4</b>	<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-297815	10/8/2014	53	Created	**Adding Contractor: Next Generation						
FO-297818	10/8/2014	53	Created	Adding Contractor:EKS Air Monitoring for abatement being done in plenum of room 225						
FO-302114	11/18/2014	12	Created	RM 9360 CEILING LEAK, AHU# 9 AHU#13 LEAK ,,,,,,,,,,,,,, JH/11-18-14 ,,,,,,,,,,,,,,						
FO-303082	11/28/2014	2	Created	chk condensate flowing out of mechanical room 11.....						
<b>T - Plumber</b>			<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302278	11/19/2014	11	Created	ADDING CARPENTER: Please remove ceiling in closet located in basement north east						
FO-302308	11/19/2014	11	Not Finished	UPGRADING TO EMERGENCY DUE TO FOLLOWING						
FO-302748	11/24/2014	6	Created	EMERGENCY ELEC						
<b>T - Roofing</b>			<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302203	11/19/2014	11	Created	**ADDING ROOFER: Roof leak 3027.1 See John Covert Sisung for location or Marty El						
<b>High</b>			<b>150</b>	<b>59</b>	<b>28</b>	<b>15</b>	<b>35</b>	<b>13</b>	<b>0</b>	<b>91</b>
<b>T - Carpenter</b>			<b>21</b>	<b>12</b>	<b>3</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	
FO-286934	6/11/2014	172	Created	Trade: Carpenter						
FO-287457	6/17/2014	166	Created	Replace broken cracked floor tile outside room 2313 in 2nd floor hallway. Tile is surroun						
FO-289085	7/2/2014	151	Created	Trade: Carpenter						
FO-293449	8/26/2014	96	Created	Windows are leaking into the room when it rains						
FO-293450	8/26/2014	96	Created	Windows are leaking into room when it rains						
FO-294978	9/10/2014	81	Completed	ADDING CARP						
FO-296974	10/2/2014	59	Created	Carpentry--Priority High Someone has broken off the bolts on the hinge to the entranc						
FO-298001	10/10/2014	51	Created	Trade: Carpenters						
FO-299804	10/27/2014	34	Created	Lock is not working. Door cannot be unlocked.						
FO-300213	10/31/2014	30	Created	STAIR RUBBER THREAD IS COMING OFF. STAIRWELL BETWEEN THE 1ST AND 2						
FO-300789	11/4/2014	26	Created	Repair trap door in ceiling over sink that is stuck half open. Very low ceiling and pose						
FO-301132	11/10/2014	20	Created	WSU carpenters to construct weather enclosure protecting the west, north, and east ext						
FO-302334	11/17/2014	13	Created	Repair of M. Basketball Team Room Code that is NOT functioning....Please rush...Mik						
FO-302268	11/19/2014	11	Created	GARAGE DOOR NOT CLOSING PROPERLY PLEASE CONTACT RAYNOR DOOR						
FO-302425	11/20/2014	10	Created	Electronic handicap door at Purdy (south) entrance not functioning						
FO-302500	11/21/2014	9	Created	White floor tiles are lifting and need to be replaced. The problem is considered highly ur						
FO-302761	11/24/2014	6	Created	Request section of ceiling grid to be removed Rm# 8307.1; heat pump will need to be ta						
FO-302844	11/24/2014	6	Created	Install backer board and replace cinder blocks on 2ed floor mens urinal that has been re						
FO-302987	11/25/2014	5	Created	2ND FL WINDOWS NEED TO BE STABILIZED BY DEC 11						
FO-303026	11/26/2014	4	Created	Door 016-03E will not secure.						
FO-303042	11/26/2014	4	Created	Student locked out of room. The key will go into the lock but the lock will not turn.						
<b>T - Electrician</b>			<b>36</b>	<b>19</b>	<b>12</b>	<b>1</b>	<b>1</b>	<b>3</b>	<b>0</b>	
FO-278841	3/18/2014	257	Created	Electrician; High						



			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-291059	7/30/2014	123	Created	Pipefitters: MED HIGH Priority						
FO-291079	7/30/2014	123	Created	FITTERS: Please repair replace regulating						
FO-291304	8/1/2014	121	Created	FITTERS (HIGH)						
FO-292998	8/22/2014	100	Created	CEILING LEAK. 4TH FLOOR CUSTODIAL CLOSET.....ME/EA....8-22-14						
FO-293053	8/22/2014	100	Created	(**) PO Req DK						
FO-293200	8/25/2014	97	Created	**Priority Lowered / Material requested JWT						
FO-296024	9/22/2014	69	Created	(**) PO REQ DK						
FO-296980	10/2/2014	59	Created	Pipefitters: MED High PriorityFabricate baffles to prevent air channeling through AHU-						
FO-297212	10/6/2014	55	Created	Fitter replace top cover gasket on D.A. tank in boiler room. It's leaking. Priority High,,,,,,,,,						
FO-297890	10/9/2014	52	Created	Dirty Cagewash room has ceiling cracks and water leaking from those cracks. Thank yo						
FO-299336	10/21/2014	40	Not Finished	**Duplicate work order / Refer to Pipefitters FO#299352 JWT						
FO-299586	10/23/2014	38	Created	5TH FL RM 5116 AND SURROUNDING AREA HEARS A PERIODIC WHINDING SOU						
FO-300959	11/6/2014	24	Created	Active ceiling leak - Drywall damaged . Water is not pouring in but you can hear a stead						
FO-300967	11/6/2014	24	Created	RM 1631 LEAK COMING THROUGH LIGHT FIXTURE.						
FO-301113	11/10/2014	20	Created	Fitters, please repair leaky seal on condensate pump in room 11. Priority: high ,,,,,,,,,,,,,,						
FO-301376	11/12/2014	18	Created	PIPEFITTER:						
FO-301526	11/13/2014	17	Created	BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH RM.						
FO-302197	11/19/2014	11	Created	Pipefitters: MED High Priority.						
FO-302755	11/24/2014	6	Created	Dr. Frade's office ceiling is leaking again. Please repair the ceiling. I have already conta						
FO-302784	11/24/2014	6	Created	1ST FL TO THE RIGHT OF ENTRANCE CEILING LEAK, LEAKING ON PROPERTY ,,,,,						
FO-302968	11/25/2014	5	Created	Trade: Pipefitters						
FO-303087	11/28/2014	2	Created	please investigate large steam leak in mech room in basement, room 11						
<b>T - Plumber</b>			<b>47</b>	<b>15</b>	<b>6</b>	<b>7</b>	<b>14</b>	<b>5</b>	<b>0</b>	
FO-281947	4/18/2014	226	Created	Trade: Plumbers						
FO-282429	4/23/2014	221	Created	ADDING PLUM						
FO-283163	5/2/2014	212	Created	R/R RM 108/MENS RR HANDICAP STALL TOILET IS LKNG FROM BOTTOM (BAG IS						
FO-285653	5/29/2014	185	Created	CEILING LEAKS. BASEMENT LADIES RESTROOM - ROOM 0504. ALSO BASEMEN						
FO-285687	5/30/2014	184	Created	Trade: Plumbing						
FO-286564	6/6/2014	177	Created	R/R RM 410/DLAR CAGEWASH RM BIB FOR THE HOSE UNABLE TO SHUT OFF W						
FO-287055	6/12/2014	171	Created	ELECTRICIANS/PLUMBRES						
FO-287275	6/16/2014	167	Open to Shops	(**) P.O. Req DK 6/23/14						
FO-287683	6/18/2014	165	Created	.HIGH PRIORITY - Public Safety - Dispatch RM						
FO-289157	7/3/2014	150	Created	Trade: Plumbers						
FO-289478	7/9/2014	144	Created	(**) P.O. Req TH/DK						
FO-290968	7/29/2014	124	Created	(**) PO Req TH						
FO-291194	7/31/2014	122	Created	TOILET SPRAYING WATER. LADIES RESTROOM. ROOM 125. NORTH SIDE OF B						
FO-291207	7/31/2014	122	Created	R/R RM 109/MENS RR 1ST STALL TOILET IS BROKEN (bagged? Did not specify prob						
FO-291350	8/4/2014	118	Created	Replace distilled water (RO water) faucet. Leaks when used.....MP...8-4-14						
FO-291840	8/6/2014	116	Created	NO HOT WATER. ROOM 203 (KITCHEN),,,,,,,,,,,,,, MP/8-6-14 ,,,,,,,,,, DUE ASAP						
FO-292088	8/9/2014	113	Created	PLUMBERSR/R RM 00060/LAB Insulate process cooling water supply and return lines						
FO-293089	8/22/2014	100	Created	DI water faucet will not shut off, please repair,,,,,,,,,,,,, MM/8-27-14 ,,,,,,,,,, DUE A						
FO-293586	8/27/2014	95	Not Finished	2ND FL WATER FOUNTAIN, NEAR MENS RM. PLEASE TURN FOUNTAIN OFF WAT						
FO-294771	9/8/2014	83	Created	3RD FL 3102 LADIES RM, TOILET CONTINUOUSLY FLUSHING ,,,,,,,,,, MM/9-9-14						
FO-295497	9/16/2014	75	Created	2ND FL LAB 223 SINK NOT DRAINING, EXPERIMENT IN PROGRESS						
FO-295842	9/17/2014	74	Created	Attention Plummer. turn on water line PS4						
FO-295760	9/17/2014	74	Created	Room 3112 (kitchenette) has a clogged sink and water is running slowly,,,,,,,,,,,,, RB						
FO-295994	9/22/2014	69	Created	FAUCET CONTINUOUSLY RUNNING. JANITOR'S CLOSET. ROOM 029,,,,,,,,,,,,, M						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-296253	9/23/2014	68	Created	Sink is lab is stopped up. The sink next of the coffee machine in the lab. ...., MP							
FO-296506	9/26/2014	65	Created	Fitters please replace cracked steam cock to drain in room 423.1. ...., MM/9-28-							
FO-297049	10/3/2014	58	Created	(**) PO Req DK							
FO-298255	10/14/2014	47	Created	Trade: Plumbers							
FO-298739	10/20/2014	41	Created	R/R RM 336 CK SINK LKNG FROM UNDERNEATH CAUSING LEAKAGE IN RM 240 A							
FO-299943	10/28/2014	33	Created	2 sink faucets are leaking in room 6312 and 1							
FO-300119	10/30/2014	31	Created	(**) PO REQ DK							
FO-300132	10/30/2014	31	Created	Plumbers:							
FO-300241	10/31/2014	30	Created	Trade: Plumbers							
FO-300871	11/5/2014	25	Created	R/R RM 5324 ONLY SINK HAS A LEAKY FAUCET (wtr comes out when faucet is on di							
FO-300900	11/6/2014	24	Created	CEILING LEAK. ROOM 3202....., GS/11-6-14 .....							
FO-301108	11/10/2014	20	Created	2ND FL WATER FOUNTAIN OUTSIDE 226 NOT WORKING ....., MP/11-13-14 ,,							
FO-301115	11/10/2014	20	Created	LOCKER RM DRINKING FOUNTAIN COMING AWAY FROM WALL ....., MP/11-							
FO-301526	11/13/2014	17	Created	BSMNT MENS RM LEAK, POSSIBLY COMING FROM 3RD MECH RM.							
FO-301530	11/13/2014	17	Created	Shower is leaking onto the floor in the NE corner							
FO-302086	11/18/2014	12	Created	4TH FL DRINKING FOUNTAIN HAS LEAK, WATER LEAKING ON FL ....., MP/1							
FO-302123	11/18/2014	12	Created	Three compartment sinks leaking from faucets in							
FO-302222	11/19/2014	11	Created	PLUMBERS please r/r p-trap that's leaking onto switchgear in primary room. Drain locat							
FO-302367	11/20/2014	10	Created	**ADDING CONTRACTOR: Macomb Mechanical for Sheet Metal Support:							
FO-303043	11/26/2014	4	Created	R/R RM/STE 1600 IN THE BACK OF THE STE JANITORS CLOSET SLOP SINK FAUC							
FO-303051	11/26/2014	4	Created	R/R RM 225/ONLY SINK - FAUCET SPIGOT IS LKNG IN 3 AREAS....MM.....11-26-14							
FO-303051	11/26/2014	4	Created	R/R RM 225/ONLY SINK - FAUCET SPIGOT IS LKNG IN 3 AREAS....MM.....11-26-14							
FO-303067	11/26/2014	4	Created	Only sink in the room has a garbage disposal. The disposal does not work and the sink							
<b>T - Roofing</b>				<b>13</b>	<b>2</b>	<b>0</b>	<b>5</b>	<b>5</b>	<b>1</b>	<b>0</b>	
FO-285776	5/30/2014	184	Created	Repair rain water leaking into Lab 3027 fume hood, Exhaust Fan #37.							
FO-287101	6/13/2014	170	Created	The sky light in the dome is leaking during rains. The water is dripping very near to elect							
FO-288179	6/24/2014	159	Created	ROOFER							
FO-290620	7/23/2014	130	Cancelled	POSSIBLE ROOF LEAK FLOOR IS FLOODED CALL FRED 313-570-3556							
FO-292190	8/11/2014	111	Created	Roofers: Water coming in along north wall of rooms 126+127. Priority:High							
FO-292220	8/12/2014	110	Created	Roofers							
FO-294200	9/2/2014	89	Created	3RD FL RAMP FROM EDC TO DANTO NEAR WINDOW,CEILING LEAK							
FO-294226	9/2/2014	89	Created	*Adding Roofer:							
FO-295010	9/10/2014	81	Created	SEVERAL RM'S HAVE CEILING LEAKS WHEN RAIN OCCURS, 2ND TIME ALL RM'S							
FO-295047	9/11/2014	80	Created	Room 2156: There is water dripping from roof onto the dropped ceiling tiles on north sid							
FO-295096	9/11/2014	80	Created	Roofers High Repair leaks at roof joint were cooling tower roof meets side of building.							
FO-302732	11/24/2014	6	Created	CEILING LEAK. 3RD FLOOR STAIRWELL F.							
FO-302945	11/24/2014	6	Created	Just outside of the doors to 3210 are three ceiling tiles that are wet/sagging on two. One							
<b>T - Sheetmetal</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	
FO-280117	4/1/2014	243	Created	Trade: SheetmetalPriority: HighR/R 2ND FLR Numerous complaints the fume hoo							
<b>Medium</b>				<b>160</b>	<b>76</b>	<b>27</b>	<b>10</b>	<b>37</b>	<b>10</b>	<b>0</b>	<b>84</b>
<b>T - Carpenter</b>				<b>27</b>	<b>17</b>	<b>6</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
FO-291283	8/1/2014	121	Created	Three wall moldings need repair. Two open ends have to be closed, and one strip needs							
FO-291888	8/7/2014	115	Created	CARPENTRY- R/R BLDG please add railing to ROOF. There are RTU's that will need							
FO-293423	8/26/2014	96	Created	RM 133 RAIN POURING IN FROM WINDOW							
FO-293517	8/27/2014	95	Created	Second window in conference room has a							
FO-297937	10/10/2014	51	Created	Recital hall wall mounted Fluorescent light boxes don't work.							
FO-299689	10/25/2014	36	Created	Please repair wall access hole with cinder block in room 180							
FO-299772	10/27/2014	34	Created	**ADDING CARPENTERS: See Scott Brown on sealing up a area in the basement mec							



			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-299821	10/27/2014	34	Created	Please replace broken floor tile from the front door (on Brady street) to room 1600.						
FO-299822	10/27/2014	34	Created	Please replace missing and broken floor tile in the lower lobby.						
FO-299927	10/28/2014	33	Created	Floor tiles are loose						
FO-300340	11/3/2014	27	Created	Please remove ceiling grid for heat pump installations on 1st. floor.						
FO-301161	11/10/2014	20	Created	Drywall around outside window needs to be fixed since it was damaged during the install						
FO-301211	11/11/2014	19	Created	FRONT ENTRANCE DOOR INTERIOR DOOR CLOSER IS MAKING A POPING SOUN						
FO-301250	11/11/2014	19	Not Finished	WHOLE IS CEILING POSSIBLE LEAK. ROOM 3129.						
FO-301302	11/12/2014	18	Created	WINDOW STUCK OPEN. ROOM 1137. (Multi-Task)						
FO-301340	11/12/2014	18	Created	Carp. Med. priorityRepair ceiling and trap door in hall leading to boiler rm. NW corner						
FO-301541	11/14/2014	16	Created	**ADDING CARPENTER: Cut access in hard ceiling in janitor closet. See Don Bear for I						
FO-302061	11/18/2014	12	Created	Please repair brackets Ceiling tile is bulging and about to fall.						
FO-302082	11/18/2014	12	Created	Several tiles are pulling up of floor on 3rd floor hallway in front of elevator.						
FO-302096	11/18/2014	12	Created	RM 137 TRIP HAZARD NEAR FRONT RIGHT OF BOARD SIDE 2 FL TILES LIFTING						
FO-302371	11/20/2014	10	Created	Trade: CarpentersPriority: MediumPlease repair terrazzo floor. Floor has dropped c						
FO-302486	11/21/2014	9	Created	Need access panels in ceiling in basement of Thompson> we are running comm cable.						
FO-302510	11/21/2014	9	Created	6350 WINDOW LEAKING						
FO-302770	11/24/2014	6	Created	Trade: CarpentersPriority: MediumWest auditorium door interferes with the roll dow						
FO-302773	11/24/2014	6	Created	Carp. med priorityCut access hole and install panel to facilitate engineer working on c						
FO-302952	11/25/2014	5	Created	Trade: CarpentersPriority: MediumPlease repair the basement door to the west stai						
FO-303092	11/30/2014	0	Created	Repair door closer on outside exit door 050-05-S.						
<b>T - Electrician</b>			<b>28</b>	<b>18</b>	<b>7</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-292452	8/14/2014	108	Created	Electrician; Medium						
FO-292623	8/18/2014	104	Not Finished	ELECTRICIANS						
FO-296357	9/25/2014	66	Created	R/R RM 124/CLASS RM LEFT SIDE LITE SWITCH HAS 3 OPTIONS:						
FO-296881	10/1/2014	60	Created	110 E. Warren the outside entrance lights are burn out. There a total of 14 lights out. Pl						
FO-297879	10/9/2014	52	Created	Electricians, please repair/replace 1st floor emergency lights in front of the St. Antoine e						
FO-298634	10/17/2014	44	Created	Outside room 2313 - Simplex clock has stopped						
FO-299617	10/24/2014	37	Created	Repair clock on front of building facing Woodward.						
FO-299676	10/24/2014	37	Created	FIRE TROUBLE ALARM						
FO-299760	10/27/2014	34	Created	elect Med.priorityPlease make necessary repairs to boiler rm exhause fan. Unit will n						
FO-299855	10/28/2014	33	Created	Inspect and repair booster pumps. See Pete Smolyenak for details.						
FO-300227	10/31/2014	30	Created	Replace exterior lights/blue lights on campus. See sheet 5 with notes						
FO-300228	10/31/2014	30	Created	Replace exterior lights/blue lights on campus. See sheet 20 with notes						
FO-300793	11/5/2014	25	Created	Vestibule unit heater blower motor not working.						
FO-300844	11/5/2014	25	Created	trade labor priority medium please deliver 20 bags of salt pallets for the water softner he						
FO-300953	11/6/2014	24	Created	Electricians:R/R RM 00024/MECH RM please repair or replace light fixture just inside						
FO-301037	11/7/2014	23	Created	R/R RM 253/MECH RM fan unit #11 won't run repair ASAP						
FO-301214	11/11/2014	19	Created	RESTROOM 2432 HAND DRYER NOT WORKING						
FO-301429	11/13/2014	17	Created	ELECTRICIANR/R RM 00010/MECH RM PLEASE RECONNECT SOLONOID VALVE						
FO-301435	11/13/2014	17	Created	Electricians; Medium:R/R RM 195/MECH BLR RM Please repair Unit Heater No. 2 in b						
FO-301595	11/14/2014	16	Created	ElectriciansPriority med.R/R 8TH FLR Please r/r problem with return fan #4, motor s						
FO-302293	11/19/2014	11	Created	R/R RM 274/MECH RM please replace seized motor to pump servicing dance room by						
FO-302470	11/21/2014	9	Created	EMERGENCY ELEC						
FO-302476	11/21/2014	9	Created	The light switch in room 316 (accessed through room 308) near room 368 is broken and						
FO-302737	11/24/2014	6	Created	Trade: ElectricianPriority: MediumR/R RM 00028/MECH RM Please repair condens						
FO-302943	11/25/2014	5	Created	install heat tape on h20 lines to the Geology dept rest room soon before they freeze ag						
FO-302944	11/25/2014	5	Created	R/R motor circuit as nesc for the unit heater near the large garage door south wall						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-302977	11/25/2014	5	Created	PARTIAL LIGHTS WILL NOT COME ON. 2ND FLOOR.						
FO-303090	11/28/2014	2	Created	CHECK SANITARY SUMP PUMP AND STORM SUMP PUMP FOR OPERATION.						
<b>T - Painter</b>			<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302444	11/21/2014	9	Created	PAINTERS: Please paint/ repair ceiling in mens restroom on the 5th floor. MED.						
<b>T - Pipefitter</b>			<b>39</b>	<b>17</b>	<b>5</b>	<b>2</b>	<b>9</b>	<b>6</b>	<b>0</b>	
FO-282313	4/22/2014	222	Created	(**) P.O. Req DK						
FO-284101	5/12/2014	202	Created	(**) P.O. Req LC						
FO-284317	5/14/2014	200	Created	Fitter repair chilled water leak between air handlers, see engineer....., JH/5-15-14 ,						
FO-284368	5/14/2014	200	Created	(**) P.O. Req DK 6/17/14						
FO-285040	5/22/2014	192	Created	(**) P.O. Req DK						
FO-285140	5/23/2014	191	Created	Fitters please repair leaking soldered joint on heat pump near Rm.6400/6499. Priority:M						
FO-286400	6/4/2014	179	Created	(**) P.O. Req DK 6/17/14						
FO-289507	7/9/2014	144	Created	Trade: Pipefitter						
FO-290201	7/17/2014	136	Created	(**)PO Req DK #2						
FO-290874	7/28/2014	125	Created	Fitters, please repair leak in condensate line coming from UNH-5. Unit is located behind						
FO-291326	8/4/2014	118	Created	Pf. Med. Priority Repair steam leak on main steam line boiler above boiler #1.....ME/E						
FO-291995	8/7/2014	115	Created	Trade: Pipefitter						
FO-292335	8/13/2014	109	Created	Pipefitters -- Priority Medium						
FO-292522	8/15/2014	107	Created	(**).PO Req DK						
FO-292525	8/15/2014	107	Created	PIPEFITTERS Please replace valve for water column blow down that leaks by on Boiler						
FO-294478	9/4/2014	87	Created	please chk water chiller for microscope in room 46.4...see attached e-mail for more info						
FO-295672	9/17/2014	74	Created	Replace piping from pumps to the DLAR 200 suites with copper. ...., JH/9-17-1						
FO-297594	10/7/2014	54	Created	Pipefitter: MED High Priority						
FO-297980	10/10/2014	51	Created	(**) PO Req TH						
FO-298715	10/20/2014	41	Created	condensate pump b {west } is leaking in the boiler room ..... RC/10-20-14 .....						
FO-299256	10/21/2014	40	Created	Trade: Pipefitter Priority: Medium						
FO-299514	10/23/2014	38	Created	Pipe fitter; Medium						
FO-300193	10/31/2014	30	Created	Trade: Pipefitter						
FO-300796	11/4/2014	26	Created	Tag #090-HVU-001						
FO-300850	11/5/2014	25	Created	Fitter repair leak in chilled water line between AH-3 & 4. ...., EA/11-5-14 .....						
FO-301136	11/10/2014	20	Created	**Fire Protection Job / Sent to David Kuffner to Vender 11-15-14 JWT						
FO-301465	11/13/2014	17	Created	Fitters, please repair leak at union from pre-heat coils behind AHU-4....., EA/11-						
FO-301491	11/13/2014	17	Created	Please repair leaking coil labeled 1D near AHU #1						
FO-301507	11/13/2014	17	Created	FITTERS,						
FO-301510	11/13/2014	17	Created	Trade: Pipefitters						
FO-302147	11/18/2014	12	Created	FITTERS:						
FO-302230	11/19/2014	11	Created	Replace defective union and nipple on drain line off of boiler #2. Pipefitters..... J						
FO-302369	11/20/2014	10	Created	Trade: Pipefitters						
FO-302386	11/20/2014	10	Created	PF Med priority						
FO-302449	11/21/2014	9	Created	RADIATOR LEAK. 2ND FLOOR WOMEN'S DRESSING ROOM....., EA/11-24-14						
FO-302942	11/25/2014	5	Created	R/R rotted 1.5" condensate line as nesc into the surge tank						
FO-303001	11/25/2014	5	Created	Repair steam leak near meter room (boiler area). Line can be isolated will not need shu						
FO-303039	11/26/2014	4	Created	Please have pipefitters repair replace clogged safety valve drain piping. the water is ove						
FO-303046	11/26/2014	4	Created	Fitters:						
<b>T - Plumber</b>			<b>51</b>	<b>21</b>	<b>7</b>	<b>4</b>	<b>15</b>	<b>4</b>	<b>0</b>	
FO-281129	4/9/2014	235	Created	(**) P.O. Req DK						
FO-283779	5/7/2014	207	Created	R/R RM 382/JANITOR'S CLOSET SLOP SINK NOTE: AS OF TODAY 5/7/14, THE FAU						
FO-284004	5/11/2014	203	Created	(**) P.O. Req DK						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-285666	5/29/2014	185	Created							Repair shower handle in men's faculty locker room shower. Handle is broken on the right
FO-287119	6/13/2014	170	Created							R/R RM 3341 1ST BENCH WTR SUPPLY LINE FIBER GLASS PIPECHASE LINE HAS
FO-287119	6/13/2014	170	Created							R/R RM 3341 1ST BENCH WTR SUPPLY LINE FIBER GLASS PIPECHASE LINE HAS
FO-287973	6/23/2014	160	Created							Plumber; Medium
FO-288305	6/25/2014	158	Work in Progress							WATER COMING FROM UNDERNEATH DOOR. ROOM 6373.
FO-289166	7/3/2014	150	Created							**Work in Progress / Ceiling to be Removed for access JWT 7-8-14 JWT
FO-290667	7/23/2014	130	Created							R/R RM 255 REPAIR GLASS FLR DRAIN LINE FOR SINK Water on floor near door. S
FO-291104	7/30/2014	123	Not Finished							RM 174 STANDING WATER IN JANITOR'S CLOSET
FO-291335	8/4/2014	118	Created							(**) P.O. Req DK
FO-291351	8/4/2014	118	Created							Second floor men's room faucet is leaking.....RB....8-4-14
FO-291760	8/5/2014	117	Created							RESTROOM 1302 4TH STALL OUT OF ORDER
FO-291858	8/6/2014	116	Created							Room 3250 - The cold water tap does not get cold. IMPEDING RESEARCH. Please fix
FO-292478	8/14/2014	108	Created							(**) PO Req DK
FO-292528	8/15/2014	107	Created							lower floor drain to be level with floor. Currently the floor drain is @ 3/4" above floor gra
FO-292617	8/18/2014	104	Created							PLUMBERS please r/r broken drain line in ground in basement fan room of 5425 Wood
FO-293054	8/22/2014	100	Created							In Room 2112 the sink has a constant leak when it is turned off.....MM/8-27-14 ,,,,
FO-294391	9/3/2014	88	Created							ADDING PLUMB
FO-294895	9/10/2014	81	Created							Investigate source of leak in fume hood 1 room 3038 ,,,,,,,,,, MP/9-10-14 ,,,,,,,,,
FO-295248	9/13/2014	78	Created							(**) PO Req TH
FO-296563	9/29/2014	62	Created							Engineer: Water on floor of women's restroom. Please inspect possible leak from toil
FO-299558	10/23/2014	38	Created							PLUMBERS: Pleasr repair leaking drain pipe in room 4545. Leak coming from 5th floor
FO-299644	10/24/2014	37	Created							PLUMBERS: Please repair leak city water line near ceiling and near BOILER#1
FO-299647	10/24/2014	37	Created							3rd floor kitchen garbage disposal is not working. ,,,,,,,,,, MP/10-24-14 ,,,,,,,,,
FO-299669	10/24/2014	37	Created							2ND FLR MENS RR (ONLY ONE) ONLY TOILET IS CON'T FLUSHING
FO-299673	10/24/2014	37	Created							RM 1144/WOMENS RR HAS WATER POURING DOWN FROM CLNG
FO-299915	10/28/2014	33	Created							WATER FOUNTAIN LEAKING AT BOTTOM. 2ND FLOOR (OLD WING)..... MP/
FO-300174	10/30/2014	31	Created							hood W5, left side: The aspirator's pipe can't be closed in full, and water is constantly le
FO-300252	10/31/2014	30	Created							Plumbers,
FO-300412	11/3/2014	27	Created							1ST FLR MENS RR 3RD STALL TOILET NOT FLUSHING
FO-300786	11/4/2014	26	Created							R/R RM 5344 ONLY SINK HAS A STEADY LEAK COMING FROM FAUCET (ENGINEE
FO-300791	11/5/2014	25	Created							Toilet continuously flushing – Men's locker rm – inside restroom near shower. Engineer
FO-300947	11/6/2014	24	Created							Plumber repair/rebuild water pressure regulators on both domestic water booster pumps
FO-301073	11/10/2014	20	Created							FAUCET IS NOT WORKING (POSSIBLE BATTERIES) 4TH FLOOR LADIES RESTRO
FO-301297	11/12/2014	18	Created							Plumbers:
FO-301506	11/13/2014	17	Created							R/R INSIDE STE 1600 CK BOTH MENS/WOMENS RR FOR TOILETS THAT ARE CO
FO-301726	11/14/2014	16	Created							2nd Men's bathroom-1st stall's toilet seat is detached and needs repair..... MP/1
FO-301733	11/16/2014	14	Created							Repair leaking backflow preventer serving the temper heating water system, located nea
FO-301798	11/17/2014	13	Created							Trade: Plumbers
FO-302137	11/18/2014	12	Created							Large sink by door,hot and cold water faucet leaking . Sink on west wall, faucet is hard t
FO-302185	11/19/2014	11	Created							MEN'S RESTROOM #25 IN BASEMENT OF PURDY LIBRARY IS CLOGGED AND LE
FO-302321	11/20/2014	10	Created							MEN'S RESTROOM #14100.3 THE TOILET SEAT IS BROKEN. PLEASE REPAIR.....
FO-302347	11/20/2014	10	Created							SINK LEAKING ROOMS 5324 AND 5344. SEE ENGINEER FOR MORE DETAILS. (M
FO-302348	11/20/2014	10	Created							SINK DRAINS SLOWLY. ROOM 5324. ,,,,,,,,,, MM/11-24-14 ,,,,,,,,,
FO-302440	11/21/2014	9	Created							R/R RM 1302/MENS RR THE 3RD STALL TOILET ISN'T FLUSHING ,,,,,,,,,, MM/1
FO-302970	11/25/2014	5	Created							Plumber repair leaking PVC drain line on ice machine. ,,,,,,,,,, MM/11-25-14 ,,,,,,,,,
FO-303008	11/25/2014	5	Created							SLOP SINK IS PLUGGED. ROOM 106.
FO-303009	11/25/2014	5	Created							RM 1111 CEILING LEAK

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-303024	11/25/2014	5	Created	please repair ,leak in safety shower in room 230....DB....TT						
<b>T - Roofing</b>			<b>10</b>	<b>0</b>	<b>2</b>	<b>3</b>	<b>5</b>	<b>0</b>	<b>0</b>	
FO-288010	6/23/2014	160	Created	Roof is leaking near the south east roof drain.						
FO-290640	7/23/2014	130	Created	R/R 3RD FLR IN FRONT OF ONLY ELEV CLNG IS LKNG (RAIN YESTERDAY)						
FO-292141	8/11/2014	111	Created	ADDING ROOFER						
FO-292170	8/11/2014	111	Created	ADDING ROOFER						
FO-292274	8/12/2014	110	Created	Roof Leak Med. PriorityR/R ATRIUM Repair leak in roof or flashing N.E. section of atri						
FO-295007	9/10/2014	81	Created	With the rain today, we are experiencing a leak in our South West staircase. On the so						
FO-295069	9/11/2014	80	Created	Roofer; MediumPlease repair the water leak in the WGPR Radio Transmission room						
FO-296732	9/30/2014	61	Created	CHECK FLASHING FOR POSSIBLE LEAK. CEILING TILES ARE BROWN. ROOM 20						
FO-299899	10/28/2014	33	Created	Roofer repair large water leak under north generator on lower roof.						
FO-300091	10/29/2014	32	Created	There is a roof leak, above the ceiling tile, in room 413						
<b>T - Sheetmetal</b>			<b>4</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-289402	7/8/2014	145	Created	Sheet Metal, Medium, Rm. 13202.7						
FO-292625	8/18/2014	104	Not Finished	SHEETMETAL						
FO-300824	11/5/2014	25	Created	Replace missing insulation on the duct work from AC-1 to the 200 suite						
FO-303038	11/26/2014	4	Created	please have sheet metal repair expansion joint on roof. exhaust fan 38. this fan is locate						
<b>Low</b>			<b>436</b>	<b>207</b>	<b>100</b>	<b>41</b>	<b>69</b>	<b>19</b>	<b>0</b>	<b>229</b>
<b>T - Carpenter</b>			<b>82</b>	<b>39</b>	<b>18</b>	<b>9</b>	<b>14</b>	<b>2</b>	<b>0</b>	
FO-281141	4/9/2014	235	Created	R/R RM 150.80 The door that leads from the spectator seats to the pool balcony will not						
FO-284846	5/20/2014	194	Created	CAP3-190 Cracked and missing tiles at entry, e/w corridor room 0208.						
FO-287920	6/23/2014	160	Created	CAP3-457 Cracked window 3rd floor room 328. window size 102" x 15.5" approx.						
FO-288403	6/26/2014	157	Created	CAP3-761 repair or replace countertop.						
FO-291384	7/30/2014	123	Created	Lower Level - Women's Locker Room - Need all						
FO-297586	8/4/2014	118	Created	contact: Anita Knight						
FO-292093	8/11/2014	111	Created	CARPENTERS TO INSTALL SAFETY RAILINGS ON THE ROOF						
FO-292151	8/11/2014	111	Created	CAP3-848 Provide ne corner cap at window framing, exterior south elevation.						
FO-292153	8/11/2014	111	Created	CAP3-849Provide expansion/closure fitting for window framing.						
FO-292374	8/13/2014	109	Created	R/R RM 4108 Windows in greenhouse leak when it rains. The epoxy floor in the greenh						
FO-292383	8/13/2014	109	Created	R/R RM 2103/CLASS LAB *Replacement of 65+ VCT floor tiles, they are broken away +						
FO-295735	8/18/2014	104	Created	Office workstation missing a back panel for a pedestal cabinet. Please have carpenter						
FO-293013	8/22/2014	100	Created	Carpenters: please replace the missing and damaged ceiling tiles in lecture hall 101. pri						
FO-293050	8/22/2014	100	Created	please remove ceramic tile from wall near removed urinal for access so plumber can re						
FO-293559	8/27/2014	95	Created	fix the damn shades						
FO-293712	8/28/2014	94	Created	CAP4-15 Door laminate chipped Room 012, basement.						
FO-294400	9/2/2014	89	Created	contact: David Barnettcontact_email: david >R.Barnett@wayne .educontact_ph: 313.						
FO-294184	9/2/2014	89	Created	**Adding Carpenter : Make wall opening at wall coolers on 1st and 3rd floor to meet AD						
FO-294999	9/2/2014	89	Created	Replace cracked window in Room 259 & 259.2.						
FO-294832	9/9/2014	82	Created	please replace ceiling tiles and plastic piece on light in room 487.....						
FO-294935	9/10/2014	81	Created	R/R BLDG There are 7 stair/carpet rods that need to be replaced in the Hilberry Theatre						
FO-295287	9/15/2014	76	Created	Room 253 remove loose tile due to fall and slip hazard						
FO-295433	9/16/2014	75	Created	CAP4-125 Repair broken window,1st floor north.						
FO-295435	9/16/2014	75	Created	CAP4-129 Replace glass with hole in it,1st floor north.						
FO-296410	9/25/2014	66	Created	1ST FLOOR MEN'S RESTROOM ON WESTSIDE OF BUILDING THE TILE FLOOR UN						
FO-296934	10/2/2014	59	Created	CAP4-212 Floor tiles chipped and cracked, replace.						
FO-297238	10/3/2014	58	Created	Please replace the hand towel dispenser in the rest room inside structure 5 office. The						
FO-299484	10/6/2014	55	Created	I need a white board hung on the wall in my office. Please note this is an office and no						
FO-297222	10/6/2014	55	Created	R/R RM 101/CLASS RM The Library Computing Help Desk has received several com						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-297525	10/7/2014	54	Created	CAP4-222 Replace floor tiles SW staircase.						
FO-297547	10/7/2014	54	Created	CARPENTERS TO BUILD 4 EACH 8' HIGH PARTITION TO STABILIZE EXTERIOR W						
FO-297650	10/8/2014	53	Created	CAP4-234 Repair crack in skyline.						
FO-297900	10/9/2014	52	Created	CARPENTER TO COMPRESS ALL CEILING TILES IN THE STOCK ROOM ALL CEILI						
FO-297987	10/10/2014	51	Created	R/R TILE IN ROOM 253 AND THE 4TH FLOOR HALLWAY. COORDINATE WITH LIZ						
FO-298511	10/14/2014	47	Created	Insurance - Police Report #W14-2870037 - The door leading in and out of the Grounds						
FO-300134	10/15/2014	46	Created	Push bar on the inside lobby front door . push bar needs to be replaced.						
FO-301529	10/21/2014	40	Created	contact: J Hill						
FO-299479	10/23/2014	38	Created	Carpenter's portion of this job.						
FO-299523	10/23/2014	38	Created	CAP4-18 Base missing at door, basement.						
FO-299812	10/27/2014	34	Created	Please reattach wooden bar at the back of Mazurek Classrooms 240 and 241. The bar i						
FO-299972	10/28/2014	33	Created	R/R 4TH FLR RE-SECURE At the west end of hallway there is a majority of the floor tile						
FO-300089	10/29/2014	32	Created	Fluorescent lights in room 413 are burned out, and missing their plastic diffuser lenses.						
FO-300094	10/29/2014	32	Created	R/R RM 413 Please replace ceiling tiles ( damaged from a leak above them) in room 41						
FO-300385	11/3/2014	27	Created	TEAM LEADER TIME ( NOVEMBER 2014 )						
FO-300782	11/4/2014	26	Created	R/R RM 311 I would like to have the "D" part of a "U" shaped workstation removed. The						
FO-300908	11/6/2014	24	Created	CARPENTERS, PLEASE REPAIR/REPLACE DOOR GASKETS ON SOUNDPROOF						
FO-300909	11/6/2014	24	Created	CARPENTERS, PLEASE REPAIR/REPLACE DOOR GASKETS ON SOUNDPROOF						
FO-301532	11/6/2014	24	Created	Current door handle on Room 128, Suite 1-A, has no lock mechanism. Have locksmith s						
FO-301086	11/10/2014	20	Created	CARPENTERS, PLEASE REPLACE DAMAGED FLOOR TILES.PRIORITY-LOW						
FO-301087	11/10/2014	20	Created	CARPENTERS, PLEASE REPLACE DAMAGED FLOOR TILE IN HALLWAY NEAR R						
FO-301120	11/10/2014	20	Created	There is a nut and bolt missing on the right side of the garage door. We have placed a						
FO-301126	11/10/2014	20	Created	CARPENTERS TO TIGHTEN ALL THE SEATING IN BERNATH AUDITORIUM HALL						
FO-301148	11/10/2014	20	Created	Ceiling tiles were damaged when lighting crew was working on lights.						
FO-301213	11/11/2014	19	Created	Insurance - Police Report #W14-3140054 Please R/R cracked window. Window located						
FO-301220	11/11/2014	19	Created	Handy man: please remove scaffolding in mechanical room by AHU-1, it was set up a fe						
FO-301456	11/13/2014	17	Created	**ADDING CARPENTER: Install plywood on wall in key shop so water filter can be prop						
FO-301464	11/13/2014	17	Created	R/R 2ND FLR SOUTH STRWL REPLACE MISSING/DAMAGED Floor Tile - needs to be						
FO-301511	11/13/2014	17	Created	The emergency exit in the stairwell by room 174 on the first floor, the push bar that activ						
FO-301818	11/14/2014	16	Created	Kresge Library, 3rd Floor, Room 315						
FO-301753	11/14/2014	16	Created	R/R 14TH FLR Can the window near the restrooms on the 14th floor be sealed shut for t						
FO-302851	11/14/2014	16	Created	desired_date: 11/21/2014funding_source: 122101funding_year: 2015preferred_bill						
FO-302085	11/18/2014	12	Created	PS2 Lodge Srevic Dr. student entrance. The pedestrian door is in need of a new door						
FO-302127	11/18/2014	12	Created	Repair base board around sink in Ladies Restroom, 1st Floor, Engineering Technology						
FO-302129	11/18/2014	12	Created	R/R RM 1004/WOMENS RR Repair base board around sink in Ladies Restroom, 1st Flo						
FO-302132	11/18/2014	12	Created	Lower Level - Outside of hot kitchen - Floor tile						
FO-302362	11/20/2014	10	Created	Wire covering needed in Grounds.						
FO-302396	11/20/2014	10	Created	Carpenter glue laminate panels to wall in both elevators.						
FO-302433	11/21/2014	9	Created	R/R RM 150/SVC CTR THE CHAIR NEXT TO MY DESK DRAWER WILL NOT STAY C						
FO-302473	11/21/2014	9	Created	R/R Rm. 2603 has a ceiling tile panel that is rusted out and needs to be replaced.						
FO-302481	11/21/2014	9	Created	R/R RM 00012/KITCHEN Ceiling grid and tile repair at the door leading into the hot kit						
FO-302502	11/21/2014	9	Created	Replace loose/missing overhead door edge sealing on the East end overhead door locat						
FO-302504	11/21/2014	9	Created	Replace loose/missing overhead door edge sealing on the West end overhead door loca						
FO-302803	11/24/2014	6	Created	Historic wood window shutter needs to be put						
FO-302804	11/24/2014	6	Created	University Services Building Rm 134 (Next to AVP);Hang folder holder (mailbox) on wo						
FO-302842	11/24/2014	6	Created	Carpenter repair wooden steps on lower roof west side.						
FO-303020	11/24/2014	6	Created	Insurance - Police Report #W14-3290046 - Hallway outside 153, 1st floor Knapp in the						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-303022	11/25/2014	5	Created	LOCKSMITH REPAIR	please repair non working Detex panic exit device located on the						
FO-303003	11/25/2014	5	Created	R/R RM 113.10	Repair cracked floor at the south entrance to the racquetball/squash co						
FO-303059	11/26/2014	4	Created	R/R 2ND FLR	outside of the restroom/2126 there are tiles missing, possible trip hazard,						
FO-303072	11/26/2014	4	Created	LOCKSHOP	pleaseR/R RM 0195/MECH RM lock to west facing exterior boiler room d						
FO-303076	11/26/2014	4	Created	Requesting to put basic ceiling tiles in the 0006							
FO-303091	11/30/2014	0	Created	Repair faulty door closer located on the door to Mechanical Room 15, (located next to ro							
T - Electrician				117	84	28	2	2	1	0	
FO-281125	4/9/2014	235	Created	To cover the cost for WSU Electricians for electrical preventative maintenance work at S							
FO-287038	6/12/2014	171	Created	two fixtures out in front porch lights.							
FO-292570	8/18/2014	104	Created	CHECK SANITARY SUMP PUMP AND STORM SUMP PUMP FOR OPERATION.							
FO-296553	9/29/2014	62	Created	Repair motor starter serving Supply Fan AC-1, located in Mechanical Room #10 in base							
FO-296795	9/30/2014	61	Created	Purdy Library 2nd and 3rd Floors							
FO-296882	10/1/2014	60	Created	Have laborer deliver three 5-gal pails of Oxycor, and three 5-gal. pails of Neutrmine to M							
FO-297140	10/6/2014	55	Created	Replacement of 2 fluorescent light bulb tubes.							
FO-297167	10/6/2014	55	Created	R/R BLDG There are three lights out in the main athletic area. Both lights are emergen							
FO-298467	10/15/2014	46	Created	Purdy Library, Basement, Room 25							
FO-298517	10/16/2014	45	Created	There are 2 electrical problems inside of the elevator.							
FO-298612	10/17/2014	44	Created	The emergency blue light on the northwest corner of the theatre is not operating. Please							
FO-298765	10/17/2014	44	Created	Lights on the stage area need replacing. Stage is dark. Charge to account 227149.							
FO-299250	10/21/2014	40	Created	The outside light is out. It's a mercury bulb.							
FO-299466	10/23/2014	38	Created	Lighting Crew; Medium							
FO-299480	10/23/2014	38	Created	Electricians: R/R BSMT please install additional light fixtures in basement boiler room,							
FO-299530	10/23/2014	38	Created	There are 6 lights out above the stairwell that are too high to reach.							
FO-299610	10/24/2014	37	Created	Ceiling light on 3rd floor directly in front of							
FO-299723	10/25/2014	36	Created	Electricians: South mushroom exhaust fan motor will not run. Priority:Low							
FO-299701	10/25/2014	36	Created	Hook up welding machines and plazma machine for Pipe Shop, See John for locations							
FO-299748	10/27/2014	34	Created	ELECTRICIANS please r/r closer for disconnect on boiler #1. Does not close properly. L							
FO-299726	10/27/2014	34	Created	The elevator has 1 electrical problem.							
FO-299773	10/27/2014	34	Created	this person left a message, and did not leave contact information. there is a blow drier th							
FO-299780	10/27/2014	34	Created	There is a dimmer switch not working. the switch controls 2 rows of globe lights in the S							
FO-299886	10/28/2014	33	Created	The switches that control the two of the make up mirror light fixtures are not working. It							
FO-299894	10/28/2014	33	Created	Repair Toilet Exhaust Fan starter. Fan will run only when the momentary contact starter							
FO-299941	10/28/2014	33	Created	R/R BLDG electrician please troubleshoot fire alarm system,it show 7th floor NAC-14&1							
FO-299929	10/28/2014	33	Created	Several light fixtures have lamps that are not working. These fixtures have EP's in the							
FO-300059	10/29/2014	32	Created	Check all exterior lights/blue lights out. See David Kuffner and Sheet 11							
FO-300061	10/29/2014	32	Created	Check all exterior lights/blue lights out. See David Kuffner and Sheet 13							
FO-300063	10/29/2014	32	Created	Check all exterior lights/blue lights out. See David Kuffner and Sheet 7							
FO-300064	10/29/2014	32	Created	Check all exterior lights/blue lights out. See David Kuffner and Sheet 14							
FO-300079	10/29/2014	32	Created	the fixture is located in front of the conference room 200.							
FO-300080	10/29/2014	32	Created	the fixture is located between 3rd and 4th floor over a landing. the stairwell facing the FA							
FO-300184	10/31/2014	30	Created	Please repair and replace mall lights and blue lights. See Sheet 10							
FO-300186	10/31/2014	30	Created	Please repair and replace mall lights and blue lights. See Sheet 24							
FO-300187	10/31/2014	30	Created	Please repair and replace mall lights and blue lights. See Sheet 25							
FO-300189	10/31/2014	30	Created	Please repair and replace mall lights and blue lights. See Sheet 3							
FO-300191	10/31/2014	30	Not Finished	Please repair and replace mall lights and blue lights. See Sheet 2							
FO-300225	10/31/2014	30	Created	Replace exterior lights/blue lights on campus. See sheet 4 with notes							
FO-300242	10/31/2014	30	Created	1 EP - first floor, exit 2. One bad wall switch. Tagged.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-300339	11/3/2014	27	Created	Time for Team Leader for the month of November, 2014.						
FO-300349	11/3/2014	27	Created	There is a light out in basement storage area, voice mail was left, so call 7-1246 for furt						
FO-300352	11/3/2014	27	Created	There are two lights out in men's restroom room 2238. one at the entrance and one insi						
FO-300395	11/3/2014	27	Created	upon entry one light out over the conference room. one light in the rear hallway over the						
FO-300408	11/3/2014	27	Created	Time to repair clocks throughout the University for the month of November, 2014.						
FO-300744	11/4/2014	26	Created	Rm 123 - 2 EP - Broken fixture dangling.						
FO-300757	11/4/2014	26	Created	ElectricianR/R 3RD FLR repair HHW pump #1 for animal facility in 3rd floor mechanic						
FO-300825	11/5/2014	25	Created	R/R 3RD FLR MENS RR Please fix-electric hand dryer, 3rd flr men's restroom-not worki						
FO-300867	11/5/2014	25	Created	the tasks are one exit light loosely handing and one wrap around light.in main auditoriu						
FO-300868	11/5/2014	25	Created	Clock is ahead one hour. Please adjust clock back one hour.						
FO-300870	11/5/2014	25	Created	R/R 2ND FLR Clocks is the Kado clinical skills center need to be adjusted. Room numb						
FO-300888	11/6/2014	24	Created	Half of the lights are out in Room 2156. There are 2 electrical problems in 2156. Enter t						
FO-300889	11/6/2014	24	Created	The hallway outside of room 1237 has 1 electrical problem.						
FO-300966	11/6/2014	24	Created	1 EP located in front porch.						
FO-300969	11/7/2014	23	Created	Please install timers on State Hall Old Wing AHU's 1 & 2						
FO-300970	11/7/2014	23	Created	Please install timers on Supply Fans 1,2&3						
FO-300983	11/7/2014	23	Created	The Men's restroom on the 14th floor has an electrical problem.						
FO-301059	11/8/2014	22	Created	Replace faulty motor located on #2 condensate transfer pump in Mechanical Room 10.						
FO-301122	11/10/2014	20	Created	The EXIT sign outside of room 249 has 1 electrical problem.						
FO-301186	11/10/2014	20	Created	Room 324 is a computer lab that also functions as a testing room for students.						
FO-301189	11/11/2014	19	Created	The Donor Gallery has 7 electrical problems. (1st floor)						
FO-301208	11/11/2014	19	Created	The lights at the instructor station in room 13 are not functioning at all. There are 6 of th						
FO-301216	11/11/2014	19	Created	need scaffolding for the West dock heaters @ 1200 Holden. Please contact Dean Denni						
FO-301298	11/12/2014	18	Created	STAIR A between the 9th floor an the Penthouse has 1 electrical problem. It's too high t						
FO-301305	11/12/2014	18	Created	This is to add lighting to the crosswalk at the Lodge Freeway service drive on the east si						
FO-301308	11/12/2014	18	Created	Room 1520 EDC in the Main Engineering Building has 1/2 of its lights out that need to b						
FO-301372	11/12/2014	18	Created	Install light at front of Building, and move Blue Light up.						
FO-301380	11/12/2014	18	Created	4th floor special events office. Jeff block needs all non-working light bulbs replaced ASA						
FO-301436	11/13/2014	17	Created	Electricians Low:R/R RM 103 Repair light fixtures in vestibule.						
FO-301490	11/13/2014	17	Created	2 lights out in hallway (closest to Suite 4650)...						
FO-301523	11/13/2014	17	Created	17 total fixtures out on second floor hallway.						
FO-301547	11/13/2014	17	Created	Hallway corridor outside room 352- need lights						
FO-301571	11/14/2014	16	Created	R/R MALL Observed open junction box at planter on mall between Alumni & Law Libra						
FO-301596	11/14/2014	16	Created	Cubicle area outside of room 3219 has a desk light out. Please						
FO-301741	11/17/2014	13	Created	There is 1 electrical problem in the women's restroom on the 7th floor.						
FO-301764	11/17/2014	13	Created	There is 1 electrical problem in the Men's restroom on the 2nd floor. West end.						
FO-301784	11/17/2014	13	Created	Request for four heat pumps to be delivered to Thompson House 3rd. floor from stockro						
FO-302027	11/17/2014	13	Created	Need two lights replaced in 1st floor women's bathroom.						
FO-302044	11/18/2014	12	Created	Please replace ceiling light out in ladies restroom. 4th flr, COE thank you. This task is a						
FO-302074	11/18/2014	12	Created	Margherio conference center elevator and the entrance light bulbs burned out, please r						
FO-302186	11/18/2014	12	Created	Need ELECTRICIAN to set the timer for the outside lollipop lamos on Cass Ave outside						
FO-302195	11/19/2014	11	Created	ELECTRICIANS						
FO-302205	11/19/2014	11	Created	Repair Ep. on third floor south side.						
FO-302270	11/19/2014	11	Created	There is a light bulb out outside of office 3125 in Electrical & Computer Engineering. If y						
FO-302285	11/19/2014	11	Created	EXIT sign light is out in room 233.						
FO-302296	11/19/2014	11	Created	Repair clock near front door in the multi purpose athletic complex. (indoor tennis courts)						
FO-302313	11/19/2014	11	Created	the fixture is located between 2nd and 3rd floor landing, stair 1- exit 1. one electrical pro						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-302337	11/20/2014	10	Created	The entrance light has 1 electrical problem.							
FO-302395	11/20/2014	10	Created	ElectricianR/R RM 201/MECH RM disconnect power to motor for reheat pump #4.							
FO-302409	11/20/2014	10	Created	third floor men's room facing DeRoy building. 1 EP							
FO-302411	11/20/2014	10	Created	in the third floor hallway outside of blue liture. one EP							
FO-302434	11/21/2014	9	Created	The hallway between room 147 and the stairwell facing the art gallery has 1 electrical pr							
FO-302482	11/21/2014	9	Created	inboard bearing on AHU-3 motor making noise							
FO-302495	11/21/2014	9	Created	Rm. 1236 has 4 floor covers missing off of the electric circuits that need to be installed.							
FO-302494	11/21/2014	9	Created	Replace faulty light switch controlling the 1st-floor radiant heating pump with a single-pol							
FO-302497	11/21/2014	9	Created	Replace light switch controlling the 2nd-floor radiant heating pump with a single-pole sta							
FO-302501	11/21/2014	9	Created	Replace light switch controlling the Reheat radiant heating pump with a single-pole start							
FO-302758	11/24/2014	6	Created	2 fixtures out in room 0237.							
FO-302794	11/24/2014	6	Created	Clock is not working. Please repair.							
FO-302801	11/24/2014	6	Created	Four ballasts with fluorescent lights out (3 with no tubes working, one with one out and o							
FO-302806	11/24/2014	6		Two ballasts of fluorescent lights completely out.							
FO-302835	11/24/2014	6	Created	The first fixture upon entering the 4th floor ladies room.							
FO-302859	11/24/2014	6	Created	R/R RM 150 Change 7 burnt out lights in ceiling of pool...Left will be needed. Please se							
FO-302949	11/25/2014	5	Created	Trade: Electrician/Laborer Priority: LowR/R RM 4505/MECH RM Please remove old ref							
FO-302955	11/25/2014	5	Created	The spot light outside of room 1600 has 1 electrical problem.							
FO-302956	11/25/2014	5	Created	Room 330 has 2 electrical problem. (Basement)							
FO-302957	11/25/2014	5	Created	Room 360 has 2 electrical problems. (Basement)							
FO-302958	11/25/2014	5	Created	STAIR B between the 3rd and 4th floor has 1 electrical problem.							
FO-302985	11/25/2014	5	Created	Please have Maintenance Laborer take old copier from FP&M Stockroom to Property ,							
FO-303006	11/25/2014	5	Created	DENNIS/Laborer-R/R RM 0195/MECH RM please deliver 1) 8, 5 gallon jugs of OXY							
FO-303010	11/25/2014	5	Created	1st floor men's restroom there is 1 electrical problem.							
FO-303033	11/26/2014	4	Created	TMA training for the Buzz and Paul							
FO-303040	11/26/2014	4	Created	ELECTRICIANS TO REMOVE 3 LIGHT FIXTURES SO THE CARPENTERS CAN REP							
FO-303083	11/28/2014	2	Created	This is to purchase wire mold to protect against a trip hazard on the second floor at Matt							
FO-303084	11/28/2014	2	Created	Cashier Window number#2 (Irecia Cloyd) speaker is static and not working for the staff							
FO-303085	11/28/2014	2	Created	Purdy Library 2nd and 3rd Floors							
FO-303086	11/28/2014	2	Created	the fixture is a flood light facing overhead tile art.							
<b>T - Locksmith</b>				<b>15</b>	<b>10</b>	<b>3</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-295339	9/15/2014	76	Created	#090-09-15-14-3 3 Keys Room 3340							
FO-295341	9/15/2014	76	Created	#090-09-15-14-4 3 Keys Room 3355							
FO-296961	10/2/2014	59	Created	104100214 1-CORE 24-KEYS ACCESS BLOCK AND CONTROL KEY							
FO-298004	10/10/2014	51	Created	Make the key to the generator enclosure the same as the 25296-121 key. As per Dave							
FO-298585	10/17/2014	44	Created	#507-10-17-14 2 Keys Room 925							
FO-300387	11/3/2014	27	Created	LOCKSMITH TRAINING( NOVEMBER 2014 )							
FO-301100	11/10/2014	20	Created	#611-11-10-14 1 Key Main door and office							
FO-301403	11/12/2014	18	Created	071-111214 - To cover the cost of 6 core changes 6/4/24 keys 5057 Woodward, 6th floo							
FO-302178	11/19/2014	11	Created	#001-11-18-14 2 Keys							
FO-302468	11/21/2014	9	Created	#611-11-21-14-1 10 Keys Room 212							
FO-302811	11/24/2014	6	Created	068112414 5-Keys ROOM 351							
FO-302822	11/24/2014	6	Created	#082-11-24-14 4 Keys Lobby Bulletin							
FO-302846	11/24/2014	6	Created	Replace core in glass corridor door leading to 3634. Core to be provided 11/25/2014.							
FO-303060	11/26/2014	4	Created	612-112414 - 1 core change and 4 keys. New core must run off of Departmental Master.							
FO-303094	11/30/2014	0	Created	Install a standard mechanical room core on the outside door to the boiler room. Door 03							
<b>T - Painter</b>				<b>25</b>	<b>19</b>	<b>6</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	



			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-297088	10/4/2014	57	Created	outside room 008 in corridor, repair & paint- plaster in various areas.						
FO-297090	10/4/2014	57	Created	Southside Stairwell- remove wallpaper/vinyl, patch & paint to finish.						
FO-298448	10/15/2014	46	Created	Clean upper cabinets / clean an paint west wall in lab room 2258. Scott hall white.						
FO-299323	10/21/2014	40	Created	Repair water damage to plaster and paint in east corners of the office.						
FO-299567	10/23/2014	38	Created	CAP-4 #73 paint stairwell walls & risers.						
FO-300170	10/30/2014	31	Created	SAFTEY TIME FOR THE MONTH OF NOVEMBER.						
FO-300784	11/4/2014	26	Created	R/R BLDG BOTH STRWLS (APPR 40 DOORS) Paint outside of interior entry doors in s						
FO-300977	11/7/2014	23	Created	HANDY MAN TIME.						
FO-300988	11/7/2014	23	Created	MTL TIME.						
FO-301138	11/10/2014	20	Created	Painter; MediumPlease finish painting the rest of the loading dock area; which includ						
FO-301321	11/12/2014	18	Created	Clean off or paint over Graffiti on campus.						
FO-301374	11/12/2014	18	Created	R/R RM 3141 DUE TO ROOF LEAKS THE PLASTER CEILILNG HAS STARTED FLAKI						
FO-301477	11/13/2014	17	Created	R/R 4TH FLR OUTSIDE OF BOTH ELEVS REPAIR PLASTERED CLNG THAT IS PEE						
FO-301520	11/13/2014	17	Created	R/R RM 1025 Please place a 10# ABC fire extinguisher inside the lab at the entrance/ex						
FO-301539	11/13/2014	17	Created	Repair and paint wall above interior door in room 346.						
FO-301618	11/14/2014	16	Created	PAINTERS TO MUDD & PAINT REPAIRED DRYWALL CEILING WOMENS BATHROO						
FO-302390	11/20/2014	10	Created	Request Maintenance on vehicles/Units #7 & #8						
FO-303000	11/25/2014	5	Created	R/R I NEED FOR SHERROD TO PICK UP X-SHTS & MWRF FROM KINKO						
FO-303037	11/26/2014	4	Created	Paint Hallway from grounds/common area, to front offices.						
FO-303074	11/26/2014	4	Created	PAINTERS TO MUD & PAINT WATER FOUNTAIN COVE & WALL NEAR ROOM 2134						
FO-303075	11/26/2014	4	Created	HANDYMAN TO RELOCATE 25 PODIUMS FROM THE PUBLIC SIDE OF THE WARE						
FO-303078	11/28/2014	2	Created	CAP-4 #151 (General) Painting ceiling & column, North wall by room 207						
FO-303079	11/28/2014	2	Created	CAP-4 #154 Paint walls an door frames, 2nd floor east wall by room 207.						
FO-303080	11/28/2014	2	Created	CAP-4 #156 Paint walls 2nd floor,						
FO-303081	11/28/2014	2	Created	CAP-4 #157 Signage labeling High Voltage Panels, 2nd floor, north wall stair 4.						
<b>T - Pipefitter</b>			<b>55</b>	<b>19</b>	<b>15</b>	<b>5</b>	<b>12</b>	<b>4</b>	<b>0</b>	
FO-275728	2/14/2014	289	Created	3 way valve on hot water perimeter heat is leaking thru, needs rebuilt or replaced ,,,,,,,,,,						
FO-281544	4/14/2014	230	Created	Fitter, install drain lines at energy recovery coils for AH-1, 2, 4, and 5 so engineer can cl						
FO-283258	5/2/2014	212	Created	(**) P.O. Req DK 6/16/14						
FO-285387	5/27/2014	187	Created	(**)P.O. Req DK 6/11/14, 11-18-14						
FO-287523	6/17/2014	166	Created	(**). PO Req DK						
FO-287802	6/20/2014	163	Created	**Quote in Progress to Evaluate 6/30/14 JWT						
FO-288469	6/26/2014	157	Created	(**) PO REQ DK						
FO-288696	6/30/2014	153	Created	(**) P.O. Req DK						
FO-289671	7/11/2014	142	Created	(**) P.O. Req TH/ DK						
FO-289754	7/12/2014	141	Created	Please repair the pin hole leaks in the heating coil in fan No. 2.						
FO-290080	7/16/2014	137	Created	R/R RM 00032/MECH RM For SF-12. Common condensate line for unit appears to have						
FO-290081	7/16/2014	137	Created	R/R RM 00032/MECH RM For SF-13. Common condensate line for unit appears to have						
FO-291232	7/31/2014	122	Created	R/R Music mech room 205 AHU-3 has defective cooling coil. Replace with new.....JH...8						
FO-292068	8/8/2014	114	Created	(**).PO Req DK						
FO-293730	8/28/2014	94	Created	R/R hand pump for thinner in paint shop ,,,,,,,,,,,,,, JT/8-28-14 ,,,,,,,,,,,,,,						
FO-293731	8/28/2014	94	Created	(**) PO Req DK						
FO-295240	9/13/2014	78	Created	**Important to be completed by end of October						
FO-295267	9/15/2014	76	Created	R/R RM 3100 investigate ceiling leak/tile damage above reception desk in computer lab.						
FO-295454	9/16/2014	75	Created	(**) PO Req DK						
FO-295848	9/18/2014	73	Created	met with bldg. coordinator to discuss repairs on 5th floor and explain to her what will be						
FO-295899	9/19/2014	72	Created	(**) PO Req TH						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-296861	10/1/2014	60	Created	R/R RM 187.01/MECH Please repair or replace relief valve in basement mech rm. Valv							
FO-297979	10/10/2014	51	Created	Replace or unplug supply and return piping to reheat coil for room 270. Located in fish b							
FO-298277	10/14/2014	47	Created	chk 3 way valve in basement leaking, leak is near ceiling level to the right, just before bl							
FO-298485	10/16/2014	45	Created	Fitter install insulation on new condensate line in 3rd floor mechanical room....., J							
FO-298486	10/16/2014	45	Created	Fitter replace leaking safety valve on boiler #1 .....JH/10-16-14 .....							
FO-298540	10/16/2014	45	Created	FITTERS ,							
FO-299320	10/21/2014	40	Created	*STS2014							
FO-299420	10/22/2014	39	Created	fitters- please install heating coil & control in mechanical room 417. Do not want to freez							
FO-299425	10/22/2014	39	Created	Work Order Created for funnels for 6 different shot feeders installed for 2014 heating se							
FO-299686	10/23/2014	38	Created	Repair trailer lift for Dennis (Laborer) ..... JH/10-22-14 .....							
FO-299705	10/25/2014	36	Created	Trade: Pipefitter Priority: Medium							
FO-299706	10/25/2014	36	Created	Trade: Pipefitter Priority: medium							
FO-299707	10/25/2014	36	Created	Trade Pipefitter Priority medium							
FO-299813	10/27/2014	34	Created	Vacuum breakers for steam traps and coils ..... JH/ 10-27-14 .....							
FO-300098	10/30/2014	31	Created	FITTERS							
FO-300382	10/31/2014	30	Created	room 160 replace 3 leaking radiator steam coils ..... ME/1-31-14 .....							
FO-301017	11/3/2014	27	Created	STEAM TRAP SURVEY / REPLACEMENT PROJECT 2014/2015 HEATING SEASON ,,							
FO-301018	11/3/2014	27	Created	(**) PO REQ DK 11/15/14							
FO-300407	11/3/2014	27	Created	Replace existing 6" gate valve with chain for steam supply that feeds Art. ...., EA							
FO-301287	11/12/2014	18	Created	Replace gaskets on all 6" gate valves (3) behind SF-6 / AHU-6 in mechanical room 025							
FO-301461	11/13/2014	17	Created	Repair leaking economizer located in mechanical room 15 ..... EA/11-13-14 .....							
FO-301484	11/13/2014	17	Created	Trade: Pipefitters							
FO-301485	11/13/2014	17	Created	Trade: Pipefitters							
FO-301550	11/14/2014	16	Created	monitor air for abatement job in room 100.....							
FO-301734	11/16/2014	14	Created	Repair high pressure steam valve located at pressure reducing station in basement mec							
FO-302187	11/19/2014	11	Created	PIPEFITTERS please move strainer at boiler #1 in feed water line so that it can be acce							
FO-302188	11/19/2014	11	Created	PIPEFITTERS							
FO-302201	11/19/2014	11	Created	Fitters,							
FO-302368	11/20/2014	10	Created	FITTERS,							
FO-302828	11/24/2014	6	Created	Fitters,							
FO-302840	11/24/2014	6	Created	Fitter							
FO-303004	11/25/2014	5	Created	Fitter R/R GARAGE replace surface blow down valve on boiler #1 with a needle valve.							
FO-303066	11/26/2014	4	Created	Please replace (2) Powers 3-way valves supplying heating coils #12 & #13 adjacent to s							
FO-303070	11/26/2014	4	Created	PIPEFITTERS							
<b>T - Plumber</b>			<b>122</b>	<b>34</b>	<b>28</b>	<b>15</b>	<b>34</b>	<b>11</b>	<b>0</b>		
FO-279418	3/24/2014	251	Created	We have a broken drain pipe on the second							
FO-280787	4/6/2014	238	Created	Repair leaks in 1/2 inch copper water line serving the hose bibb near outside exit door 0							
FO-283684	4/23/2014	221	Created	Standing water around the drain (drain not allowing water to drain properly, may be clog							
FO-283174	5/2/2014	212	Created	Lower Level Weight Room - Drinking fountain							
FO-283655	5/6/2014	208	Created	(**) P.O. Req DK							
FO-283722	5/7/2014	207	Created	R/R UPPER PENTHOUSE Please have plumbers replace or repair leaking back flow pr							
FO-283903	5/8/2014	206	Created	R&R sanitary pit - sump pump - 1 pump is out							
FO-284005	5/11/2014	203	Created	(**) P.O. Req DK 6/17/14							
FO-284377	5/14/2014	200	Created	Lower Level - Women's Locker Room - 5th							
FO-285648	5/29/2014	185	Created	FAUCET IS LOOSE. 3RD FLOOR CUSTODIAL CLOSET..... MM/5-29-14 .....							
FO-285760	5/31/2014	183	Created	(**) P.O. Req DK 6/17/14							
FO-286353	6/4/2014	179	Created	R/R RM 0247 CUT/CAP THE copper pipe coming from ceiling that needs to be removed							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-286421	6/5/2014	178	Created	R/R drains on waterless urinals 1st floor men's ,,,,,,,,,,,,,, MM/ 6-5-14 ,,,,,,,,,, DUE 7-						
FO-286585	6/6/2014	177	Created	(**) P.O> Req DK 6/23/14						
FO-286853	6/11/2014	172	Created	Please Locate, Test, Inspect, and Repair water backflow devices in Building. Complete						
FO-286895	6/11/2014	172	Created	The drinking fountain (near the nFab lab) on the 3rd floor cannot be repaired please repl						
FO-287107	6/13/2014	170	Created	R/R 3rd FLR RESTROOMS toilets are not flushing. could be low pressure ,,,,,,,,,,,,,, R						
FO-287209	6/16/2014	167	Created	(**)#2 #3. P.O. Req LC						
FO-287948	6/20/2014	163	Created	All drains in lots and structures check and vacuumed as needed. Jack6/20/14 lp						
FO-288210	6/25/2014	158	Created	WOMEN'S RESTROOM 1ST FLOOR--THE TOILET SEAT IN THE THIRD STALL IS S						
FO-288470	6/26/2014	157	Created	(**) PO Req DK						
FO-288692	6/30/2014	153	Created	Administrative Time for July 2014						
FO-289468	7/9/2014	144	Created	The regular stall in this women's room has been						
FO-289938	7/15/2014	138	Created	Install a bypass around the abandoned booster water heater that formally served the lau						
FO-290277	7/18/2014	135	Created	Jon, on 5-23-14 we got a phone call from Schindler Elevator about parking structure 8 el						
FO-290873	7/28/2014	125	Created	MEN'S RESTROOM #0348 THE LAST STALL, WATER SHOOTING UP WHEN FLUSH						
FO-291049	7/30/2014	123	Created	(**) P.O. Req DK						
FO-291319	8/3/2014	119	Created	Repair dripping faucets on three-compartment sink in cold kitchen.,,,,,,,,,,,,,, MP/8-5-14						
FO-291349	8/4/2014	118	Created	The toilet seat in the second stall of this men's						
FO-291801	8/6/2014	116	Created	Men's bathroom; urinal on the left does not flush						
FO-291819	8/6/2014	116	Created	The women bathroom toilet internal housing no longer can fill and flush. Toilet does not						
FO-291821	8/6/2014	116	Created	E-WING WOMEN'S RESTROOM 0409 AND 2409 WHEN TOILET FLUSHED WATER						
FO-292103	8/11/2014	111	Created	14th floor men's restroom handle off sink. Please repair.....MP....8-11-14						
FO-292362	8/13/2014	109	Created	(**) .PO Req DK						
FO-292397	8/13/2014	109	Created	Replace check valves on high PSI domestic cold water tank pump #22, #23 ,,,,,,,,,,,,,,						
FO-292399	8/13/2014	109	Created	(**) P.O Req DK						
FO-292852	8/20/2014	102	Created	Room 5357 and 5353 have little to no water pressure. Please fix ASAP. Thanks!.....						
FO-292922	8/21/2014	101	Created	Slone Kits for 4 Plumber Trucks ,,,,,,,,,,,,,, MP/8-21-14 ,,,,,,,,,,,,,,						
FO-293486	8/27/2014	95	Created	Please Locate, Test, Inspect, and Repair water backflow devices in Building. Complete						
FO-293488	8/27/2014	95	Created	Please Locate, Test, Inspect, and Repair water backflow devices in Building. Complete						
FO-293601	8/28/2014	94	Created	tools for 2ed Backflow Plumber ,,,,,,,,,,,,,, JS/ 8-27-14 ,,,,,,,,,,,,,,						
FO-293617	8/28/2014	94	Created	r&r k-50 rigid snake machine.....MP.....8-28-14						
FO-293797	8/29/2014	93	Created	Repair faucet on custodial sink located in the basement level. The backflow preventer is						
FO-293798	8/29/2014	93	Created	Repair faucet on custodial sink located on the first floor.						
FO-293820	8/29/2014	93	Created	Please Locate, Test, Inspect, and Repair water backflow devices in Building. Complete						
FO-294117	9/2/2014	89	Created	(**). PO Req DK						
FO-294421	9/2/2014	89	Not Finished	(**) PO Req DK						
FO-294171	9/2/2014	89	Created	Replace backflow for HWH make up in penthouse....DB....9-2-14						
FO-294172	9/2/2014	89	Created	Replace backflow for irrigation system in 1st floor pump room....DB.....9-2-14						
FO-294174	9/2/2014	89	Created	R/R domestic hot water recirculation pump located in plumbers storage area....MM.....9-						
FO-294472	9/4/2014	87	Created	please locate, test, inspect, and repair water backflow devices in building. Complete test						
FO-294693	9/8/2014	83	Created	(**) PO Req DK						
FO-294696	9/8/2014	83	Created	(**).PO Req DK						
FO-294699	9/8/2014	83	Created	Please Locate, Test, Inspect, and Repair water backflow devices in Building. Complete						
FO-294987	9/9/2014	82	Not Finished	**Duplicate Work Order / Refer to FO#293837 JWT						
FO-295246	9/13/2014	78	Created	Replace 2 1/2" RPZ in penthouse for boiler and cooling tower ,,,,,,,,,,,,,, DB/9-13-14,,,,,,,,,						
FO-295725	9/17/2014	74	Created	bagged toilet basement mens room ,,,,,,,,,,,,,, MM/9-17-14 ,,,,,,,,,,,,,,						
FO-296257	9/23/2014	68	Created	NE corner of 3rd floor hallway, emergency shower is						
FO-296585	9/29/2014	62	Created	**R/R all backflows for all sterilizer. List all locations as they are completed ,,,,,,,,,,,,,, D						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-296809	9/30/2014	61	Created	Lab, Rm 3437 - repair sink leaks; starting with 1 from the North/Brady side, 1st sink fast							
FO-297683	10/2/2014	59	Created	PS#4 Please clean and fix clogged drain on the first floor in the VIP area. John Towle fr							
FO-297681	10/2/2014	59	Created	1st Floor - Men's Restroom - Toilet in handicap stall continually flushes without stopping							
FO-297682	10/2/2014	59	Created	The water bottle filling station on the main floor, south end is out of order. In addition the							
FO-297168	10/6/2014	55	Created	ADDING PLUMBERS							
FO-298108	10/13/2014	48	Created	Sewage backing up in 1st floor restrooms ladies 102 & Men's (no room number) State H							
FO-298109	10/13/2014	48	Created	Repair leaking domestic hot-water line locate in the tunnel between Alumni House and							
FO-298137	10/13/2014	48	Created	(**) PO REQ DK							
FO-298384	10/15/2014	46	Created	R/R RM 427 Sink in room has plugged drain. Please fix....., GS/10-16-14 .....							
FO-298590	10/16/2014	45	Created	R/R women's shower mixing valves in S/E locker room. ...., MP/10-16-14 .....							
FO-298620	10/17/2014	44	Created	This is for Zurn Transformers for this area....., GS/10-17-14 ....., 10-17-14 .....							
FO-298685	10/18/2014	43	Created	Plumbers: please repair or replace leaking 4" y on sewer line in the northwest corner of							
FO-298745	10/20/2014	41	Created	**ADDING CONTRACTOR: GUARDIAN PLUMBING							
FO-299415	10/22/2014	39	Created	For purchase of quick connection test cock adp kit for backflow testing ....., DB/1							
FO-299430	10/22/2014	39	Created	R/R RM 3108 Sink Faucet leaking at top, spraying water over counter....., MM/10-							
FO-299485	10/23/2014	38	Created	(**) PO REQ DK							
FO-299555	10/23/2014	38	Created	R/R BLDG ALL FLRS WOMENS RR NEED TO HAVE ALL TOILET SEATS REPLACED							
FO-299653	10/24/2014	37	Created	R/R RM 326/MENS RR Middle urinal in Men's bathroom is out of order....., MM/10							
FO-299692	10/25/2014	36	Created	(**) PO REQ DK							
FO-299702	10/25/2014	36	Created	Install new ADA double / bottle filling station near vending machine on 1st floor .....							
FO-299703	10/25/2014	36	Created	2ed floor women's room pipe chase. R/R plumbing fixtures ....., MP/10-25-14 .....							
FO-299756	10/27/2014	34	Created	**Now insulate 4" water main from repair that is now complete ....., DB/10-27-14 ....							
FO-299762	10/27/2014	34	Created	(**) PO REQ DK							
FO-299807	10/27/2014	34	Created	Restore water supply to Chiller #3, Pond fill line and sprinkler systems. There is a 1 1/4 i							
FO-299860	10/28/2014	33	Created	Trade: Plumber Priority: Low							
FO-300031	10/29/2014	32	Created	P.M. water distribution header of mice rooms . See John Towle for info ....., GS/1							
FO-300051	10/29/2014	32	Created	3rd floor men's room 309 2 urinals not working ....., MP/10-30-14 .....							
FO-300070	10/29/2014	32	Created	pls repair outdoor hose bib northeast corner of AAB near loading dock. See Ram constr							
FO-300117	10/30/2014	31	Created	(**) PO REQ DK							
FO-300210	10/31/2014	30	Created	(**) PO REQ DK							
FO-300338	11/3/2014	27	Created	Plumbers: please install a hose bib in basement boiler room. priority: low....., M							
FO-301104	11/3/2014	27	Created	Administrative Time for November 2014							
FO-300758	11/4/2014	26	Created	women's bathroom, toilet seat needs replacing							
FO-300865	11/5/2014	25	Created	Plumbers: please run the discharge pipe of the sump pump to floor drain. it was cut off t							
FO-300874	11/6/2014	24	Created	Basement ladies restroom(no room number located across from 036) water leaking fro							
FO-300877	11/6/2014	24	Created	Replace storm water pumps in sumps #! and #2 ....., MP/11-6-14 .....							
FO-300894	11/6/2014	24	Created	(**) PO REQ DK							
FO-301016	11/7/2014	23	Created	Plumbers:							
FO-301263	11/11/2014	19	Created	Check operations of domestic water booster pump #1 ....., GS/11-11-14 .....							
FO-301467	11/12/2014	18	Created	PS#1 Please turn off water and drain down all parking structures to prevent winter freez							
FO-301327	11/12/2014	18	Created	Staff Lounge, Rm. 3112 has a garbage disposal that needs repair. The switch does not							
FO-301470	11/13/2014	17	Created	PS#2 Please turn off water and drain down all parking structures to prevent winter freez							
FO-301473	11/13/2014	17	Created	PS#5 Please turn off water and drain down all parking structures to prevent winter freez							
FO-301475	11/13/2014	17	Created	PS#6 Please turn off water and drain down all parking structures to prevent winter freez							
FO-301581	11/14/2014	16	Created	3rd floor ladies room (no room number)middle stall not flushing ....., MP/11-17-1							
FO-301597	11/14/2014	16	Created	All toilet seats are loose. Please tighten....., MP/11-17-14 .....							
FO-301600	11/14/2014	16	Created	R/R Third floor dressing room bathroom(North East end of building) toilet is not functioni							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-301732	11/16/2014	14	Created	Repair leaking copper domestic hot water line located in the water line where pipe travel							
FO-301831	11/17/2014	13	Created	**Steam Traps Leaking By Are The suspected cause. Replacement Steam Traps on Or							
FO-301855	11/17/2014	13	Created	Office 137 - Please remove the sink that is mounted on the wall.							
FO-302052	11/18/2014	12	Created	Purdy Library,							
FO-302239	11/18/2014	12	Created	PS#8 - Please fix hot water heater in Structure 8							
FO-302261	11/18/2014	12	Created	Sanitary line leak. Same room mechanical room off							
FO-302133	11/18/2014	12	Created	Lower Level - Hot Kitchen - Cap or cover floor drain							
FO-302335	11/20/2014	10	Created	Women's Restroom - 2nd floor North office pod - the top of the toilet tank is cracked and							
FO-302442	11/21/2014	9	Created	WOMEN RESTROOM 1ST FLOOR NEAR MAIN ENTRANCE, THE TOILET IS CLOGG							
FO-302445	11/21/2014	9	Created	R/R RM 1004/MENS RR 2nd Floor Men Bathroom TIGHTEN ALL toilet seatS slides off t							
FO-302443	11/21/2014	9	Created	MEN'S RESTROOM ON 1ST FLOOR NEAR MAIN ENTRANCE THE FIRST URINAL IS							
FO-302498	11/21/2014	9	Created	In Rm. 1306 the faucet on the north wall has low water pressure ,,,,,,,,,,,,,, MM/11-24-1							
FO-302809	11/24/2014	6	Created	The Y splitter, backflow adapter and hose adapter needs replacement for proper water f							
FO-302824	11/24/2014	6	Created	R/R 2ND FLR WOMENS RR We have received a report that the middle stall in the wom							
FO-302959	11/25/2014	5	Created	Kresge Library, 1st Floor, Room 107							
FO-303073	11/26/2014	4	Created	PLUMBERS R/R RM 106/MECH RM please clear blocked floor drain in generator roo							
<b>T - Roofing</b>				<b>17</b>	<b>2</b>	<b>1</b>	<b>7</b>	<b>6</b>	<b>1</b>	<b>0</b>	
FO-285402	5/28/2014	186	Created	ROOOFER:							
FO-288825	7/1/2014	152	Created	ROOFERS: R/R DOME ROOF 2nd request, please repair Dome leak (Dome roof). ME							
FO-292226	8/12/2014	110	Created	EMERGENCY ROOF							
FO-292627	8/18/2014	104	Created	Office 315.3 had a witnessed leak during the historical rain/flood last week. I am followin							
FO-293512	8/27/2014	95	Created	ROOFER, PLEASE REPAIR ROOF LEAK ON HANCOCK ENTRANCE OVERHAN							
FO-293527	8/27/2014	95	Created	The skylight over the atrium is leaking every time it rains. It has gotten worse with the la							
FO-293563	8/27/2014	95	Created	Determine source of leaks and repair and replace drywall. stairwell ceiling leak							
FO-294383	9/3/2014	88	Created	ADDING ROOFER:							
FO-294385	9/3/2014	88	Created	ADDING ROOFER							
FO-295012	9/11/2014	80	Created	Roof Leak - Rm 5177							
FO-295015	9/11/2014	80	Created	Roof Leak - Rm 2412							
FO-295016	9/11/2014	80	Created	Roof Leak							
FO-295017	9/11/2014	80	Created	Roof Leak - Rm 126							
FO-295020	9/11/2014	80	Created	Ceiling Leak - Rm 2412							
FO-299863	10/28/2014	33	Created	ROOFER/CONTRACTOR							
FO-302802	11/24/2014	6	Created	There is a roof leak by the garage door. This is in the area of the building where the wat							
FO-302843	11/24/2014	6	Created	Roofer R/R ROOF repair roof leak at south west corner. See engineer.							
<b>T - Sheetmetal</b>				<b>3</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-291178	7/31/2014	122	Created	Sheetmetal: AHU-4: R/R PENTHOUSE One of two OA dampers jamming at linkage fr							
FO-294235	9/2/2014	89	Created	Sheet metal contractor,R/R RM 414 please replace damaged supply air ductwork insid							
FO-298013	10/10/2014	51	Created	Trade: Sheet Metal							
<b>Routine</b>				<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>T - Electrician</b>				<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-302338	11/20/2014	10	Created	1EP - Overhead lights across from room 1281. (Routine)							
FO-302339	11/20/2014	10	Created	1 EP - Just east of the entrance. 0 no. of fixtures replaced.							
FO-302341	11/20/2014	10	Created	1 EP - Room 133							

**Total: 1270**