

# Facilities Operations Work Orders Received 6/1/2015 through 6/30/2015

WO	Recieved	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1684</b>	
<b>Custodial</b>			<b>227</b>	
<b>Emergency</b>			<b>1</b>	
<b>C-Repair</b>			<b>1</b>	
FO-320554	6/25/2015	6/25/2015		A BROKEN ROLL TOWEL DISPENSER IN BASEMENT AREA ROOM # 0104.
<b>High</b>			<b>6</b>	
<b>Pest Controller</b>			<b>6</b>	
FO-318878	6/3/2015	6/3/2015	6/3/2015	RM 218 SQUIRREL IN RM PLEASE COME ASAP
FO-319060	6/5/2015	6/5/2015	6/5/2015	PLEASE REMOVE LIVE BIRD FROM STOCKROOM
FO-320178	6/19/2015	6/19/2015	6/19/2015	RM 100/AUDITORIUM THERE IS A MOUSE RUNNING AROUND
FO-320179	6/19/2015	6/19/2015	6/19/2015	OUTSIDE OF SIDE ENTRANCE OF BLDG ARE MICE RUNNING AROUND TRYING TO ENTER BLDG
FO-320614	6/26/2015	6/26/2015	6/26/2015	RM 149 PLEASE SPRAY FOR ANTS
FO-320702	6/29/2015			RM 2222 PLEASE SPRAY FOR ROACHES
<b>Medium</b>			<b>5</b>	
<b>C-Repair</b>			<b>1</b>	
FO-319106	6/5/2015	6/5/2015		PIPE SHOP BROKEN SOAP DISPENSER OVER SINK
<b>Pest Controller</b>			<b>4</b>	
FO-318455	6/1/2015	6/4/2015	6/4/2015	BREAK RM 4000, MOUSE SITED PLEASE SET TRAPS
FO-318793	6/2/2015	6/4/2015	6/4/2015	PEST CONTROL-PLEASE REPLACE GLUE TRAPS IN MECH ROOMS 1 & 5, TRAPS LOADED PRIORITY MED
FO-319151	6/8/2015	6/8/2015	6/8/2015	RM 117 SQUIRREL IN RM
FO-319565	6/15/2015	6/15/2015	6/16/2015	PEST CONTROL-PLEASE PUT DOWN GLUE TRAPS IN ENGINEERS OFFICE, MICE CRAP ON DESK
<b>Low</b>			<b>215</b>	
<b>C-Lighting</b>			<b>69</b>	
FO-318771	6/2/2015	6/3/2015		Re-lamp fixture in room 271 Mezz.
FO-318794	6/2/2015	6/3/2015		Stairwell D, between 2nd and 3rd floors - 1 light out.
FO-318866	6/3/2015	6/4/2015		Located in basement. Ladies restroom has a light out.
FO-318875	6/3/2015	6/18/2015		rm. 200.15 light(s) out
FO-318883	6/3/2015	6/5/2015		chemistry building, there are 4 lights out in Lab room 20.
FO-318903	6/3/2015	6/4/2015		South stairwell between 2nd and 3rd floor has lights out.
FO-318923	6/3/2015	6/4/2015		on the first floor janitors closet the only light in that closet is out.
FO-318996	6/4/2015	6/9/2015		Light out. Please replace bulb or fix.
FO-319115	6/5/2015	6/19/2015		many lights out in rms. 330 & 340
FO-319119	6/5/2015	6/9/2015		Two lights out in room 259. please contact the building coordinator, Tracy at 7-1277, to gain access to this room.
FO-319122	6/5/2015	6/8/2015		Rm. 2602.1 - 3 Fluorescent lights are blown and need to be replaced in the ceiling
FO-319142	6/8/2015	6/8/2015		UGL Ladies Room, #1134, overhead light flickering above small stall.
FO-319166	6/8/2015	6/8/2015		Room 6374 - Several lights burnt out. Please fix.
FO-319167	6/8/2015	6/8/2015		Room 6374 - Several lights burnt out. Please fix. See FO-319166.
FO-319174	6/8/2015	6/9/2015		Basement - Lab 20 - Down to ONE light. **This is the pump room and staff cannot tell if there is smoke or not, because there is not enough light!**
FO-319186	6/8/2015	6/9/2015		Stairway A at first floor relamp light fixture inside stairs
FO-319238	6/8/2015	6/9/2015		3rd floor ladies' restroom needs a light replaced over 4th stall.

WO	Recieved	Finished	Total	Request
FO-319257	6/9/2015	6/10/2015		3rd floor - Men's Rest Room - 2 lights out near urinals.
FO-319278	6/9/2015	6/12/2015		Room 3213 - 4 Fluorescent bulbs are out in office.
FO-319336	6/10/2015	6/10/2015		In suite 2190 (Pharm Practice) all the middle fluorescent lights (8) in the suite have blown & need replacing.
FO-319349	6/10/2015	6/11/2015		The emergency exit stairwell light from the Studio Theatre to the Hilberry lobby needs light bulb replacement.  Also in the downstairs Studio Theatre Men's dressing room the light also needs light bulb replacement. Please see Michael in the box office
FO-319359	6/10/2015	6/15/2015		Re-lamp fixture in room 114.
FO-319360	6/10/2015	6/15/2015		Re-lamp fixture in hall outside room 296.
FO-319371	6/10/2015	6/10/2015		There are a couple of lights out in suit 7908 on 5057 Woodward in the main office. open from 7:30am and on, please call Jacqueline Patterson at 72804 in case you don't have access.
FO-319441	6/11/2015	6/15/2015		florescent light bulbs need to be changed.
FO-319456	6/11/2015	6/15/2015		all lights in hallway between rooms 240-243 are out. above magerio conference center
FO-319492	6/12/2015	6/15/2015		In the Manoogian building there are 6 light out on the third floor, room 358. room is locked please contact pamela at 313-577-3002
FO-319502	6/12/2015	6/19/2015		Room 200.15 - Light burnt out - please fix ASAP. This is an animal room and is affecting the well being of the animals.
FO-319512	6/12/2015	6/19/2015		Repair blinking light in faculty office as soon as possible.
FO-319515	6/12/2015	6/15/2015		Half of the lights are out in the 3rd floor hallway near the classrooms (outside rms. 301 - 308).
FO-319523	6/12/2015	6/18/2015		Light in stairwell 3 between the basement and first floor is blinking rapidly (like a strobe light). Stairwell 3 is the one in the middle of the building next to the elevator.
FO-319548	6/15/2015	6/15/2015		LIGHT OUT - ENTRANCE INTO SERVICE CENTER.
FO-319561	6/15/2015	6/19/2015		Replace lamp lighting Art work a in front lobby by security sation and front entry.
FO-319884	6/15/2015	6/15/2015		Please replace burned out light bulbs in office 1223.
FO-319891	6/15/2015	6/16/2015		I need the light replaced under my overhead cabinet.
FO-319900	6/15/2015	6/16/2015		Wayne State Police - Dispatch - Room 133 - need 2 new light bulbs for workstation lamps. LED desirable.  FEIT MR16/GU10 120V 35W
FO-319931	6/16/2015	6/22/2015		Several light fixtures have non working lamps.
FO-319958	6/16/2015	6/19/2015		Lights out in 200.15. If room is locked, ask to be let in by room attendants in the morgue.
FO-319975	6/16/2015	6/18/2015		Please change light blub Florescent
FO-319988	6/16/2015	6/19/2015		Rooms 330 and 340 - Relamp several light fixtures that need replacement lamps.
FO-319996	6/16/2015	6/17/2015		Room 1501 - lights out.
FO-319997	6/16/2015	6/17/2015		Lobby - main light is flickering.
FO-320017	6/17/2015	6/18/2015		Couple of lights out in the Education building in room 370 South.
FO-320049	6/17/2015	6/11/2015		Requet Lights Bulb replacement. Need 2 of 4 lights replaced in the Handicap Wheelchair Lift room off lobby going up into theatre. Please see Michael in box office for exact location. Thanks,
FO-320059	6/17/2015	6/19/2015		In 200.15 of Scott hall there are a couple lights out, emergency.
FO-320060	6/17/2015	6/19/2015		first floor mens restroom there is one light out and the other is very dim.
FO-320141	6/18/2015	6/23/2015		Ceiling Light Bulb is out and needs to be replaced.
FO-320264	6/22/2015	6/24/2015		Football Stadium players' locker room 7 lights out, main hallway 2 lights out. SEE TERRANCE FOR EXACT LOCATION.
FO-320287	6/22/2015	6/25/2015		Trade: Lighting Crew Priority: low Please replace burnt out light bulbs in the EDC freight/passenger elevator.
FO-320289	6/22/2015			Relamp Light Fixture over the sinks.

WO	Recieved	Finished	Total	Request
FO-320330	6/22/2015			Light out in men's restroom.
FO-320331	6/22/2015	6/23/2015		Rm. 2629 please replace 6 fluorescent lights, but leave middle bulbs out in each section of lights.
FO-320372	6/23/2015	6/24/2015		Lights out in basement, near 020. Please replace. Thank you.  Dawn C.
FO-320375	6/23/2015	6/24/2015		Actual Room Number is 027. Lights out - please replace. Thank you. Dawn C.
FO-320380	6/23/2015	6/24/2015		Near Room Number 002. Lights out. Please replace. Thank you. Dawn C.
FO-320381	6/23/2015	6/24/2015		Real Room Number 171 (toilet area). Please replace. Thank you. Dawn C.
FO-320382	6/23/2015	6/24/2015		Real Room Number 151.3. Lights out. Please replace. Thank you. Dawn C.
FO-320413	6/23/2015	6/24/2015		Replace florescent light bulbs in hallway of suit 201 and in office 102.6.
FO-320428	6/23/2015			Multiple lights out in lab and rooms within the lab. Conference room is completely dark. If no one is in lab, see someone in 1102 Scott Hall for access.
FO-320449	6/24/2015			Lighting Crew; MediumPlease replace the bad lamps in the fixture inside the machinery room located at the west end of the basement.
FO-320492	6/24/2015	6/25/2015		In the AAB building there are three lights out in room 2701.
FO-320566	6/25/2015	6/29/2015		Fluorescent bulbs burnt out; also in 4233
FO-320588	6/25/2015	6/25/2015		Location: Conference room #3. One of the bulbs is flickering and appears to need to be replaced.
FO-320634	6/26/2015	6/29/2015		Need Light Bulb replacement to replace 3 lights under the wrap-around inside the Hilberry Theatre.  Need Light bulb replacement for Lobby of Hilberry Theatre: 1 flood light out in center of lobby 1 spotlight out on East wall.  Please see Michael in
FO-320652	6/26/2015	6/29/2015		two lights out in room 405 Manoogian.
FO-320680	6/29/2015			6th floor - West corridor - 6th light down there is one light out.
FO-320688	6/29/2015			3rd floor, near room 366 - Energy bulb needs to be replaced.
FO-320689	6/29/2015			Room 320/Gross Lab - Light out
FO-320708	6/29/2015			Overhead light is flickering. Light is located above mailbox area.
<b>C-Materials</b>			<b>18</b>	
FO-318390	6/1/2015	6/17/2015		5th floor - Room 5133 - Recycling bin drop off. *Please speak with Jordan Redwine to place it in the correct room*
FO-318392	6/1/2015	6/17/2015		2nd floor, Room 2108 - Recycling bin pick up and replaced.
FO-318448	6/1/2015	6/9/2015		Room 300 - Recycle bin picked up and replaced.
FO-318772	6/2/2015	6/17/2015		FP&M Stock Room Request: 1 Tyvac Suit - Medium Shoe Covers - 1 package Goggles - 6 Hair bonnets - 1 package
FO-318820	6/2/2015	6/10/2015		3rd floor, room 3157 - Recycling bin pick up and drop off.
FO-318872	6/3/2015	6/10/2015		Please pick up and replace a large recycle bin in front of Timothy A. Herr's office at the facility's planing and management building.
FO-318995	6/4/2015	6/10/2015		On the fourth floor of the Karmanos building, please pick up and replace a large recycle bin. Please knock at the front office and the assistant will let you in and show you where the recycling bin is.
FO-319160	6/8/2015	6/17/2015		shampoo carpet. Clean carpet Room is armed; contact Lee in Music; 1321 Old Main, for access. 7-2614

WO	Recieved	Finished	Total	Request
FO-319367	6/10/2015	6/10/2015		In the second Floor of the FAB building, in the economics department in room 2077 there are multiple bags full of book and paper, and there is a full container with books and paper materials in the hallway outside of room 2077, which also needs to be disp
FO-319568	6/15/2015			Stock Issue Request: Shoe Covers
FO-319979	6/16/2015	6/19/2015		I need a recycle bin for books.
FO-320025	6/17/2015	6/18/2015		Requesting two recycle bins ( the ones made out of metal for pop-cans and paper). not the large trash can recycle bins, placed at the entrance of each of these buildings. McGregor, State Hall and Education.
FO-320103	6/18/2015	6/18/2015		Please pick up a large recycle bin on the fourth floor of the Hudson webber building at karmanos and replace it with 2 large recycle bins.
FO-320188	6/19/2015			EQUIPMENT TRANSFER: Back to building, service repairs is completed (AdVance/Conv. 26'). From: Main Office Stockroom To: (Applebaum) BLD
FO-320220	6/19/2015			requesting a recycle bin in room 3100 on the Danto engineering.
FO-320404	6/23/2015			R/R RM 3121 The large recycling bin needs to be emptied. It is located in the hallway for easy collection
FO-320451	6/24/2015			Please pick up and replace a large recycle bin in suit 3100 of danto engineering.
FO-320621	6/26/2015			On the fourth floor Karmanos building there are two full recycle bins, please pick up and replace both bins.
<b>C-Projects</b>			<b>3</b>	
FO-319897	6/8/2015	6/11/2015		Shampoo/Extract both Auditoriums rm's. 100 & 300 & all of the open common area carpeting.
FO-319896	6/11/2015	6/13/2015		Strip/wax all tile flooring in Main Corridor to include walkway corridor at Music Bldg. also behind stage area including both restrooms & the one single restroom located in Art Wing near double doors. Also the service the stage itself & the vacuuming of t
FO-319898	6/11/2015	6/12/2015		Top scrub marble flooring to remove build-up especially at elevator & also various water spots. Vacuum entry rugs.
<b>C-Repair</b>			<b>45</b>	
FO-318407	6/1/2015	6/3/2015		NEEDS TO ORDER PARTS FOR AUTO SCRUBBER (FO317785), ADVANCE/CONV. X26DC. FROM: ALLIED-EAGLE SUPPLY CO. APPROVED BY: SHERYL LLOYD
FO-318757	6/2/2015	6/2/2015		Transfer: TWO, SERVICE REPAIRED VACUUMS CLEANER (Transfer) BACK TO (STATE, HALL) BLD. ROOM # 107 THE PAPER STOCKROOM CLOSET AS REQUESTED FOR RETURN. THE (FO-315921 and FO-315923) WAS WORK REQUEST.
FO-318835	6/2/2015	6/3/2015		Women's restroom 2126( second floor near elevators), has broken paper towel dispenser.
FO-318852	6/3/2015	6/3/2015		Nobles auto scrubber, clear hose that removes clean water is leaking. 6129431/ Serial:61293100771
FO-318876	6/3/2015	6/4/2015		Science Hall: (Janitor closet 1019) Nilfisk Advance Advac Upright Vacuum Cleaner: Model no. AD Vacuum R; Ser. no. 1792083: The vacuum requires a new cord & plug adaptor (I will bring the vacuum up to main stockroom on Mon. 6/1/15 after 2pm).
FO-318877	6/3/2015	6/5/2015		Manoogian: (Women Restroom 170): Seven (7) out of eight (8) restroom stalls require a sanitary napkin box.
FO-318911	6/3/2015	6/4/2015		Soap dispenser in woman's restroom of general lectures is broken. an event is coming up please fix ASAP.
FO-319038	6/5/2015	6/10/2015		Nobles scrubber is making rubbing noise when pad is dropped. Seems like disk is loose in housing area. Model: 6129431/Serial: 61293100771
FO-319179	6/8/2015	6/12/2015		Hand sanitizers on the first floor of both purdy and kresge are no longer working. May be the matter of needing a battery.
FO-319280	6/9/2015	6/23/2015		Please mark the 3 vacuum cleaners in the Main Office (Geneva's) and install magnet bars. They can be stored in the stockroom once marked.
FO-319383	6/10/2015	6/12/2015		Requesting 24 size D Batteries from the stockroom for the following buildings hand sanitizes dispensers. Karmanos, purdy, and kresgy buildings.
FO-319457	6/11/2015	6/25/2015		Engrave WSU Grounds LOGO onto (3) FS100RX Trimmers with Autocut  S/N: 503019418 S/N: 503019420 S/N: 503019433

WO	Recieved	Finished	Total	Request
FO-319459	6/11/2015	6/25/2015		Engrave WSU Grounds LOGO onto (3) 21" OHC Push, Zone Start Rear Bagger Lawnmowers (HOHRR216K9PKA)  Serial numbers: MZCG-9189090, MZCG-9376734, and MZCZ-9376737
FO-319470	6/11/2015	6/12/2015		Soap dispenser in 1 st floor unisex restroom is missing. Need to be replaced
FO-319483	6/12/2015	6/12/2015		A REQUEST TO DO A SERVICE CHECK OR REPAIRS NEEDED ON (ADVANCE/SPECTRUM 12-H) VACUUM CLEANER FROM MAIN OFFICE AREA.
FO-319493	6/12/2015	6/12/2015		NEW EQUIPMENT: VACUUM CLEANER, UP RIGHT (SANITAIRE/SER.#-1448012156/M#-SC887) PART OF: (FO318165) From: (Allied-Eagle Supply Co. / Ticket #-778005)
FO-319505	6/12/2015	6/30/2015		Repair Sanitary vacuum: M-SC684 Serial #1251034103
FO-319532	6/12/2015	6/16/2015		Unisex restroom on first floor (near #113), soap dispenser needs to be repaired. does not stick to wall anymore.
FO-319570	6/15/2015	6/15/2015		NEW EQUIPMENT: NEED TO BE LABEL AND MANGET BAR INSTALL, UP-RIGHT VACUUM CLEANER W/DUSTCUP (SANITAIRE/M#-SC887/SER.#1416003582)  FROM: (ALLIED-EAGLE SUPPLY CO.)DELIVERY TICKET#-784909
FO-319585	6/15/2015	6/15/2015		New Equipment: Need to be label (WSU), and magnet bar install, up-right vacuum cleaner W/Dust cup. (SANITAIRE/M#-SC887/SER.#1508001606) FROM: (ALLIED-EAGLE SUPPLY CO.) NO DELIVERY TICKET # WITH THIS VACUUM
FO-319956	6/16/2015	6/18/2015		Upright sanitaire vacuum at the main office has an odor smell. Please check and repair ASAP.  Thanking you in advance Andre.
FO-319959	6/16/2015	6/16/2015		Please replace dial soap dispenser in 4103 unisex restroom.  Thank you in advance Andre.
FO-319980	6/16/2015	6/16/2015		A REQUEST TO REMOVER ALL THE CUSTOD. EQUIPMENT FROM THE DECK AREA OF BUILDING. AND TRANSFER TO MAIN OFFICE STOCKROOM.
FO-320027	6/17/2015			1st floor vacuum belong to Patrick has several problem it should be warranted ser# is 1351000927 model: SC882.Allied will be taking care of the problem.
FO-320149	6/18/2015	6/19/2015		1st floor women's restroom. Paper towel dispenser is broken. Near room #1129.
FO-320158	6/19/2015	6/19/2015		Sector 9 Custodial janitor cart: Replace broken wheel. Web TMA does not recognize Colleen Johns in it's system so I had to place AD name on this work order.
FO-320176	6/19/2015	6/19/2015		PAPER TOWEL DISPENSER HANDLE IS BROKEN. 1ST FLOOR WOMEN RESTROOM. NEAR LUNCH ROOM. woman's restroom on business services side the restroom next to Angela Strickland's office.
FO-320192	6/19/2015	6/22/2015		5th floor ladies room 5204 Scott Hall broken paper towel dispenser
FO-320193	6/19/2015	6/22/2015		5th floor ladies room broken dispenser 5204
FO-320196	6/19/2015	6/18/2015		NEW EQUIPMENT: NEED TO BE LABEL (WSU), AND A MAGNET BAR INSTALL, THIS VACUUM CLEANER IS FROM (A.D. / GENEVA, GUICE), PART OF (FO319280) REQUEST. APPROVED/AUTHORIZED BY: (A.D. / GENEVA, GUICE)
FO-320233	6/19/2015			There are (3) Sanitaire vacuums in the Science & Engineering Library. One will not power up at all and the other 2 will not pick up and are loud. They are located in the basement closet of the building.
FO-320234	6/19/2015			There are (2) Saintaire vacuums in the Fitness Center that do not work. Both are very loud and do not pick up. The vacuums are in State Hall near the Sector 1 stock room.
FO-320236	6/19/2015			There is a upright buffer that has a hole in the tank and the handle is broken as well. The buffer is located near the Sector 1 stock room in State Hall.
FO-320346	6/22/2015	6/23/2015		Trade : Custodian/Carpenter Priority: Medium Broken toilet paper dispenser in handicap restroom near room 1632/study room no. 8(Academic Success Services).
FO-320337	6/23/2015			Adfinity X20D Serial#08302171. Auto scrubber Squeegee is buckling in the center and is not picking up in that area.
FO-320360	6/23/2015			Removal of white board and message board from 5057 to State Hall for installation
FO-320412	6/23/2015	6/25/2015		3rd floor mens room roll towel dispenser in FAB is broken.

WO	Recieved	Finished	Total	Request
FO-320508	6/24/2015	6/25/2015		In 1st floor ladies restroom there are two soap dispensers that are out of soap that need refilling.
FO-320517	6/24/2015	6/25/2015		Convertamatic Auto Scrubber; Model X24D-C; Ser. no. 1956591: Replace the squeegee rubberized blades. I have dropped off at main office stockroom area for Andre to replace. I will pick the squeegee back up from stockroom area. Thanks
FO-320558	6/25/2015	6/29/2015		1st floor men's restroom, closest to elevator area, soap dispenser needed. Broken and off the wall.
FO-320589	6/26/2015	6/29/2015		Andre, the scrubber at Scott Hall(in basement near dock/cremation room), The pad holders won't release, can't change pads. convertamatic X26D-C/Serial 1958712.
FO-320615	6/26/2015	6/29/2015		Low level ladies restroom on the Brady side of the building - need soap dispenser in the middle. There is just a bracket there.
FO-320616	6/26/2015	6/29/2015		1st floor men's room has a broken soap dispenser that needs to be replaced or repaired.
FO-320676	6/29/2015	6/29/2015		R/R RM 6100 tissue dispenser. Tissue divider does not slide when one side is empty. This is a just do it request.
FO-320733	6/29/2015			Advance Power Washer; Model no. All Cleaner SP; Ser. no. N4000055612: Found trigger hose & Pressure hose in the tank area saturated in "Acid Bathroom & Shower Cleaner" which resulted in a formation of rust inside tank & also it seems that the trigger hose
<b>C-Sector 01</b>			<b>1</b>	
FO-319044	6/5/2015	6/5/2015		Stains on carpet wants them removed before the June 18th,2015 performance. Michael at 70853
<b>C-Sector 02</b>			<b>6</b>	
FO-320051	6/17/2015	6/17/2015		Scrub and waxed labs 9224,9228
FO-320053	6/17/2015	6/17/2015		scrub and waxed lab 8336
FO-320054	6/17/2015	6/17/2015		scrub gross lab in Scott Hall room 330
FO-320296	6/22/2015	6/23/2015		3rd Floor - CMG - Restrooms haven't been cleaned in a week.
FO-320531	6/25/2015	6/25/2015		Scrubbed and waxed lab 9359 of Scott Hall
FO-320532	6/25/2015	6/25/2015		Scrubbed and waxed labs 8133 and 8127 floors. One big lab 2 room numbers
<b>C-Sector 03</b>			<b>2</b>	
FO-320601	6/26/2015	6/25/2015		5 cases of dial soap
FO-320602	6/26/2015	6/25/2015		4 cases of Gojo soap
<b>C-Sector 04</b>			<b>2</b>	
FO-319880	6/15/2015	6/16/2015		2 cases of dial soap.
FO-319882	6/15/2015	6/17/2015		2 cases of dial soap.
<b>C-Sector 05</b>			<b>8</b>	
FO-318964	6/4/2015	6/11/2015		3 cases of dial soap
FO-318966	6/4/2015	6/11/2015		4 cases of dial soap
FO-318969	6/4/2015	6/11/2015		3 cases of dial soap
FO-318971	6/4/2015	6/11/2015		4 cases of dial soap
FO-318972	6/4/2015	6/11/2015		4 cases of gojo soap
FO-318973	6/4/2015	6/11/2015		two boxes of white rages
FO-319970	6/16/2015	6/16/2015		ENGINEER: R/R RM 1216 CHECK GARAGE DISPOSAL WONT START BY ON/OFF SWITCH PRIORITY LOW
FO-320685	6/29/2015			Clean carpet in the graduate study lounge--room 408
<b>C-Sector 06</b>			<b>19</b>	
FO-318777	6/2/2015	6/9/2015		2 cases of dial soap.
FO-318779	6/2/2015	6/9/2015		2 cases of dial soap.
FO-318780	6/2/2015	6/9/2015		2 cases of dial soap.
FO-318781	6/2/2015	6/9/2015		2 cases of dial soap.
FO-318783	6/2/2015	6/9/2015		2 cases of dial soap. did not receive but closing the w.o anyway
FO-318786	6/2/2015	6/9/2015		4 cases of gojo for law/Mcgregor. only recieved 1 case but closing out the w.o anyway
FO-318787	6/2/2015	6/9/2015		4 cases of rags for Sector 6. Only received one case but closing out the w.o

WO	Recieved	Finished	Total	Request
FO-319046	6/5/2015	6/9/2015		Please clean and mop both North and South stairways at the education building, from the basement to 4th floor. Thanks task is complete
FO-319100	6/5/2015	6/8/2015		shampoo carpet. Room is armed; contact Lee in Music; 1321 Old Main, for access. 7-2614
FO-319108	6/5/2015	6/19/2015		Strip and wax floor. Room is empty. We'll schedule asap. Task is complete
FO-319531	6/12/2015	6/17/2015		Senator Levin is having a meeting June 17th and we are requesting to have Room 1243 (including glass wall/door) and the Atrium cleaned and vacuumed. Also the family restroom in Atrium cleaned and stocked.
FO-320590	6/25/2015			Please dust all flat surfaces, rug needs to be shampooed. Also, the office number 3089 needs to be painted in July. Please give us an estimate, it is non-standard color, we kinda need to get on their calendar quickly.
FO-320626	6/26/2015			2 cases of gojo soap
FO-320627	6/26/2015			2 cases of gojo soap
FO-320628	6/26/2015			2 cases of dial soap
FO-320629	6/26/2015			2 cases of dial soap
FO-320630	6/26/2015			2 cases of dial soap
FO-320631	6/26/2015			1 case of dial soap
FO-320632	6/26/2015			1 case of dial soap
<b>C-Sector 07</b>			<b>8</b>	
FO-319161	6/8/2015			shampoo carpet. Room is armed; contact Lee in Music; 1321 Old Main, for access. 7-2614
FO-320639	6/26/2015	6/29/2015		4 cases of dial soap
FO-320640	6/26/2015	6/29/2015		3 cases of dial soap
FO-320642	6/26/2015	6/29/2015		2 cases of dial soap
FO-320643	6/26/2015	6/29/2015		3 cases of dial soap
FO-320645	6/26/2015	6/29/2015		1 case of dial soap
FO-320646	6/26/2015	6/29/2015		2 cases of dial soap
FO-320647	6/26/2015	6/29/2015		1 case of dial soap
<b>C-Sector 08</b>			<b>5</b>	
FO-319045	6/5/2015	6/5/2015		R/R STOCKROOM IN THE BACK AREA BY THE PIPE RACK NEED A WET VAC TO CLEAN UP WATER FROM RAIN LAST WEEKEND
FO-320039	6/17/2015	6/22/2015		2 cases of dial soap
FO-320041	6/17/2015	6/22/2015		6 cases of dial soap
FO-320043	6/17/2015	6/22/2015		6 cases of go-jo soap
FO-320617	6/26/2015			R/R RM 150 BOTH A.D. SIDE & THE SVC CTR SIDE NEED THE CARPET SHAMPOOED AND ALSO THE COMMAND CTR AREA FLOOR TO BE STRIPPED & WAXED. THE BEST TIME FOR THIS SHOULD BE WEEKEND (SEE ME LORETTA FOR ANY QUESTIONS Good afternoon Ms. Small I will walk this area
<b>C-Sector 09</b>			<b>7</b>	
FO-319323	6/10/2015	6/11/2015		Building: General Lecture Bldg.  Location: Lecture Hall rm. 100 & Large Atrium Area  Job:Shampooing & extracting carpeting
FO-320109	6/18/2015	6/19/2015		2 cases dial soap.
FO-320110	6/18/2015	6/19/2015		2 cases of dial soap.
FO-320130	6/18/2015	6/19/2015		2 cases of dial soap.
FO-320131	6/18/2015	6/19/2015		2 cases of dial soap.
FO-320132	6/18/2015	6/19/2015		1 case of dial soap.
FO-320133	6/18/2015	6/19/2015		1 case of dial soap.
<b>Pest Controller</b>			<b>22</b>	
FO-318382	6/1/2015	6/4/2015	6/4/2015	1st floor ladies restroom, 1st stahl appears to have little tiny bugs flying around

WO	Recieved	Finished	Total	Request
FO-318915	6/3/2015	6/4/2015	6/4/2015	replace bug traps in mechanical room in basement.
FO-319000	6/4/2015	6/11/2015	6/11/2015	We have red ants crawling on the floor and desks by the window in classroom 121
FO-319026	6/4/2015			R/R RM 430 HAS TINY RED BUGS ALL OVER NEED TO BE SPRAYED
FO-319062	6/5/2015			R/R E STRWL 2ND FLR LANDING BTWN 1ST & 2ND FLRS ROACH NEED SPRAY & OR TRAPS
FO-319154	6/8/2015	6/8/2015	6/8/2015	Basement, Women's R/R - Roaches
FO-319350	6/10/2015	6/16/2015	6/16/2015	Can the stairwell outside on Cass Ave leading downstairs to the Studio Theatre be sprayed with bug repellant spray as there are many mosquitos as you go to enter the Studio entrance? Please see Michael in the box office for exact location. Thanks,
FO-319373	6/10/2015	6/11/2015	6/11/2015	Boiler room in community arts building, there is an insect(cockroaches) problem. Please contact Doug at 7-7735 for exact location.
FO-319427	6/11/2015	6/12/2015	6/12/2015	Ladies restroom on 1st floor has little Gnats all over the walls and inside the stahls
FO-319526	6/12/2015	6/15/2015	6/15/2015	Having a fly problem in his office. Room 112
FO-319571	6/15/2015	6/15/2015	6/15/2015	Lay mouse traps in Grounds office.
FO-319920	6/16/2015	6/16/2015	6/16/2015	Payroll department - Conference room needs to be sprayed for ants. (SUITE 3800)
FO-319925	6/16/2015	6/25/2015	6/25/2015	R/R BLDG Please have the glue boards changed for the roaches in rooms 087.1 and 087.2. Also leave me a stack of extra boards.
FO-319924	6/16/2015	6/16/2015	6/16/2015	Trade: Pest Control Priority: Medium  Please install new glue boards in the entire boiler room, pump room, sub-basement area. The bugs have gotten BAD!
FO-319942	6/16/2015	6/16/2015	6/16/2015	R/R FRONT OF BLDGS BTWN KNAPP/SKILLMAN BY STATUE DEAD BIRD PLS REMOVE
FO-320029	6/17/2015	6/19/2015	6/19/2015	R/R BLDG PLS REPLACE ALL STICKY TRAPS IN RESTROOMS & HALLWAYS
FO-320031	6/17/2015	6/18/2015		On the fifth floor woman's restroom by room 5125 of Applebaum. Bed bugs have been found in this restroom, this is a restroom that contains bathrooms as well as lockers. please contact Dab Achcraft at 7-5824 for exact location.
FO-320118	6/18/2015	6/29/2015	6/29/2015	EXTERMINATION FOR ROACHES. 5TH FLOOR.
FO-320142	6/18/2015	6/19/2015	6/19/2015	EXTERMINATION FOR ANTS. NEED ANT TRAPS. 1ST FLOOR BREAK ROOM.
FO-320258	6/22/2015	6/22/2015	6/22/2015	REMOVAL OF HORNETS FROM WINDOW OF TRAINING TRAILER.
FO-320321	6/22/2015	6/23/2015	6/23/2015	R/R MENS LOCKER RM OUTSIDE OF SHOWER AREA NEAR LOCKERS LIVE/DEAD BUGS INSIDE BENCHES
FO-320448	6/24/2015	6/26/2015	6/26/2015	REMOVE 2 WASPS NEST OUTSIDE OF FRONT ENTRANCE OF BUILDING.
<b>Engineering</b>			<b>644</b>	
<b>Emergency</b>			<b>34</b>	
<b>E - Auxiliary</b>			<b>2</b>	
FO-319419	6/11/2015	6/11/2015		EMERGENCY FAP FIRE ALARM ACTIVE
FO-319467	6/11/2015	6/12/2015		13TH FLR FAP FIRE ALARM ACTIVE
<b>E - Command Center</b>			<b>4</b>	
FO-318901	6/3/2015			BOILER RM: LEAKING PUMP CONTROLLER, LEAKING INTO ELECTRICAL CABINET.
FO-319357	6/10/2015	6/10/2015		RM 108 SHIFFMAN LIBRARY, TROUBLESHOOT CONTROLS
FO-319563	6/15/2015			CHILLER WILL NOT START. CONTACT ENGINEER FOR MORE DETAILS.
FO-320388	6/23/2015	6/23/2015		MAIN CHILLER WILL NOT STAY RUNNING. 4TH FLOOR.
<b>E - MedPharm</b>			<b>6</b>	
FO-319971	6/16/2015	6/16/2015		EMERGENCY PLUM R/R BSMT NEAR RM 522, WOMENS RR & LOCKER RM FLR DRAINS ARE BACKING UP..... MM/6-16-15 .....
FO-319978	6/16/2015	6/16/2015		**DUPLICATE WORK ORDER REFER TO FO#319971 JWT  R/R BSMT NEAR RM 522, WOMENS RR & LOCKER RM FLR DRAINS ARE BACKING UP
FO-320391	6/23/2015			NO POWER IN BASMENT INCLUDING ROOM 302.



WO	Recieved	Finished	Total	Request
FO-320609	6/26/2015			RM 5113 EXHAUST FAN #10 TROUBLESHOOT & REPAIR MOTOR PROBLEM, FAN WON'T START RM 5113 NO SUCTION ON FUME HOODS, STRONG ODOR WITHIN RM
FO-320649	6/26/2015			CALLED SCHINDLER ELEV CO FOR ENTRAPMENT DON'T KNOW WHICH ELEV NOR WHICH FLR REF #48801449
FO-320722	6/29/2015			RM 3148 LOST POWER IN BOTH WALL OUTLETS & CLNG LITES
<b>E - North</b>			<b>4</b>	
FO-318819	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-318822	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-318824	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-320256	6/22/2015			NO POWER IN AREA OF ROOM 4055.
<b>E - Northeast</b>			<b>2</b>	
FO-318823	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-320128	6/18/2015			BSMT EQUIPMENT IS BEEPING AFTER THE DTE/EMERG GEN PWR
<b>E - Preventative Maintenance</b>			<b>6</b>	
FO-318844	6/2/2015	6/2/2015		FAP FIRE ALARM ACTIVE
FO-320225	6/19/2015	6/20/2015		LOST POWER IN BLDG
FO-320237	6/19/2015	6/20/2015		2ND FLR MENS RR (only one on flr) ONE OF THE TOILET IS PLUGGED & OVERFLOWING CAUSING A FLOOD
FO-320433	6/23/2015	6/23/2015		FAP FIRE ALARM ACTIVE
FO-320574	6/25/2015	6/25/2015		AHU #3 HAS A HI TEMP ALARM
FO-320575	6/25/2015	6/25/2015		WEST SIDE OF BLDG ENTRANCE DOOR FOR ABOVE PARKING (GARAGE) LOT THAT HAS A COVER OVER IT DOOR IS MISSING ALL THE LOCKING MECHANISM
<b>E - South</b>			<b>6</b>	
FO-318801	6/2/2015			ACTIVE FIRE ALARM, ALARM PANEL WON'T RESET ENG NEEDS ELEC TO TROUBLESHOOT
FO-318816	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-318817	6/2/2015	6/12/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
FO-320014	6/17/2015	6/17/2015		EMERGENCY ELEC R/R 1ST FLR (NEAR WARREN ENT)FAP FIRE ALARM WILL NOT RESET PANEL INDICATE LOOP #2 IS OPEN  Completed 6-17-2015 SRP
FO-320356	6/23/2015	6/23/2015		FIRE ALARM - CIRCUIT 13.  Completed 6-23-2015 SRP
FO-320714	6/29/2015	6/29/2015		SAYS THERE'S SOMETYPE OF ALARM SNDNG & A WIERD SMELL
<b>E - Southeast</b>			<b>3</b>	
FO-318924	6/3/2015	6/3/2015		INVESTIGATE FLOODING IN BSMT RM UNDER RM 1232 MENS RR ONE OF THE TOILETS IS PLUGGED & OVERFLOWING (Note: Custodian unable to unplug),,,,,,,,,,,,,, MM/6-3-15 ,,,,,,,,,,,,,,
FO-319294	6/9/2015	6/9/2015		5TH FLR EAST WING SMELLS LIKE AN ELECTRICAL BURNING SMELL
FO-320307	6/22/2015			CALLED SCHINDLER ELEV CO FOR ONLY ELEV ENTRAPMENT 4TH FLR REF #48732379
<b>E - West</b>			<b>1</b>	
FO-318821	6/2/2015	6/2/2015		POWER BUMP APPR 1:25 PLS CK YOUR EQ
<b>High</b>			<b>356</b>	
<b>E - Auxiliary</b>			<b>31</b>	
H-52645	6/1/2015	6/17/2015	6/17/2015	Second request: The bathroom sink is draining very slowly. There is a spray bottle cap stuck in there. Also the sink tap is leaking. authenticated user: Najifa Choudhury - er0737 requester ip address: 141.217.23.216
H-52644	6/2/2015	6/3/2015	6/17/2015	The sink is leaking underneath. Third complaint. I request that you come take a look and fix it. authenticated user: Corinne Caldwell - ez6882 requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
H-52653	6/2/2015	6/3/2015	6/17/2015	The pipe under the sink in the kitchen is leaking. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52665	6/3/2015	6/4/2015	6/17/2015	- Garbage disposal is leaking water. (The bottom part in the cabinet) authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
FO-318906	6/3/2015	6/3/2015		4TH FL BACK OFFICES, OUTLETS NOT WORKING
H-52683	6/4/2015	6/5/2015	6/17/2015	Conference Guest said hot water is not working and was very upset about it, please have someone look at/fix it as soon as possible. authenticated user: Carly Malburg - fh1228 requester ip address: 141.217.23.218
H-52691	6/4/2015	6/5/2015	6/17/2015	Resident said that the shower handle fell off. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
FO-319047	6/5/2015	6/5/2015		FIRE TROUBLE ALARM.
FO-319050	6/5/2015	6/8/2015		CEILING LEAK. JIMMY JOHNS RESTAURANT.
H-52721	6/5/2015	6/9/2015	6/23/2015	When the toilet is flushed, water pours out of the tank. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52750	6/9/2015	6/9/2015	6/23/2015	Air conditioner broken, emergency speaker in room not functioning. Works orders were put in over the weekend and not received. authenticated user: Olivia Wyche - fo3784 requester ip address: 141.217.23.225
FO-319253	6/9/2015	6/10/2015		FIRE TROUBLE ALARM IS STILL ACTIVE ON PUB SAFE'S PANEL
FO-319420	6/11/2015	6/11/2015		FIRE TROUBLE ALARM.
H-52867	6/12/2015	6/17/2015	6/24/2015	-One of the power plugs does not work. - Please call so I can show which plug isn't working. authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52869	6/13/2015	6/17/2015	6/24/2015	No lighting in half of the apartment and energy constantly going off. authenticated user: Keaira Stewart - fg9760 requester ip address: 141.217.23.210
H-52872	6/14/2015	6/15/2015	6/23/2015	Ceiling in kitchen is leaking; may be due to the resident's kitchen sink leaking. authenticated user: Najimah Allah - ej2633 requester ip address: 141.217.23.210
FO-319582	6/15/2015	6/16/2015		A/C LEAKING. 3RD FLOOR. CONTACT ERIK AT 962-4986.
H-52941	6/17/2015	6/18/2015	6/24/2015	From Nate to engineers: Garbage disposal is leaking. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
FO-320064	6/17/2015	6/17/2015		RM 313 ACU IS LEAKING
FO-320170	6/19/2015	6/19/2015		TOO HOT. 2ND FLOOR.
FO-320187	6/19/2015	6/19/2015		TOWERS CAFE THE GRILL THATS LOCATED IN THE SVC AREA HOODS AREN'T VENTING (orientation is in 20mins)
H-52982	6/21/2015	6/23/2015	6/25/2015	The toilet is leaking water on the floor after flushing and possibly leaking before and after the fact. Water is leaking through floor to the room below me. authenticated user: Michael Niven - fk4342 requester ip address: 35.16.70.248
H-52991	6/22/2015	6/23/2015	6/25/2015	3rd request...please RUSH...There is an electrical issue in the apartment. Half of the apartment is still without power. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
FO-320298	6/22/2015	6/22/2015		FAP FIRE TROUBLE ALARM ACTIVE
H-53013	6/23/2015	6/24/2015	6/25/2015	Toilt Seat not flushing properly! authenticated user: Logayn Hussam Aldin - et0486 requester ip address: 141.217.233.37
H-53014	6/23/2015	6/24/2015	6/25/2015	PLEASE RUSH-Pipe broke off of bathroom sink while Nate (maintenance tech) was fishing out a ring for the resident. Pipe was very rusty and old so Nate was unable to reconnect it. Please replace pipe or notify Patrick Armstrong if plumbers are needed. Plea
FO-320437	6/23/2015	6/24/2015		RM 147 ACU STOPPED WRKNG
H-53024	6/24/2015			Kitchen faucet is leaking.authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.216

WO	Recieved	Finished	Total	Request
H-53079	6/26/2015			The bathroom seat flushing keeps draining since morning and wasting all the water.authenticated user: Logayn Hussam Aldin - et0486requester ip address: 141.217.233.37
H-53089	6/27/2015			Resident says that ceiling is leaking in master bedroom and living room. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210
FO-320707	6/29/2015			HANDRAIL OUTSIDE JIMMY JOHNS ON ANTHONY WAYNE DR. IS LOOSE NEAR GRASS
<b>E - Command Center</b>			<b>28</b>	
FO-318804	6/2/2015	6/4/2015		Trade: Controls Group Priority: High  Please repair problem with the building loop controls. Siemens is calling for 120, we have 175. There is only 5 psig air on the actuator for the steam valve.
FO-319048	6/5/2015	6/12/2015		Trade: Controls/Siemens Priority: High Tag#090-AHU-547 R/R RM 4505/MECH RM Air Handler #7 at EDC is tripping on Virtual High static alarm, I had to reset it twice today.
FO-319131	6/8/2015	6/9/2015		COMMAND CENTER, PLEASE TROUBLESHOOT COOLING TOWER PROGRAM FOR CHILLERS, TOWER VALVES & FANS ARE NOT RESPONDING PROPERLY, PLACED CV-18 VALVE @ 18PSI TO CLOSE , SENDING FULL WATER TO TOWER. PRIORITY-HIGH
FO-319155	6/8/2015	6/9/2015		TOO COLD. ROOM 520.
FO-319194	6/8/2015	6/9/2015		Trade: Command Center - Siemens Priority: High Please repair fume hood 150 #7.
FO-319281	6/9/2015	6/18/2015		Refrig shop, repair Ahu #4 unit does not cool priority high
FO-319282	6/9/2015	6/18/2015		refrig shop repair ahu 003 unit does not cool priority high
FO-319283	6/9/2015	6/19/2015		Refrig shop repair ahu 005 unit does not cool priority high
FO-319295	6/9/2015	6/16/2015		Trade: Controls/Siemens Priority: High Tag#090-AHU-543 R/R RM 4505/MECH RM AHU#3 at EDC the duct static pressure is not reading the correct static pressure, its reading is to low, I can hear the duct work making loud noises, and the fan duct static sens
FO-319304	6/9/2015			REFRIG. CREW: R/R RM 00152 PLEASE CHECK AND REPAIR VAV BOXES IN STAFF OFFICE, ONLY 1 OF 6 BOXES SEEMS TO BE WORKING BY THE STATE( PRIORITY HIGH)
FO-319386	6/10/2015	6/12/2015		HVAC-2 has capillary line off TXV  unit not cooling located on 2nd floor
FO-319923	6/16/2015	6/17/2015		Trade: Controls Group Priority: High R/R RM 00018/MECH RM The building loop temp is 200+ degrees this morning, a power cycle on the controller did not work this time. The steam valve actuators only has 3 psig.
FO-319316	6/17/2015	6/23/2015		Control Engineer; High Please check the refrigerant pressures in heat pump #1-127-071-HWP-085. The unit is not cooling correctly.
FO-320020	6/17/2015	6/18/2015		Trade: Controls/Siemens Priority: HIGH Tag#090-AHU-541 - Air handler #1 tripping on virtual high static on restarts, please tune so fan slows down before it trips on high static because they are still ramping the speed higher when it trips.
FO-320021	6/17/2015	6/16/2015		Trade: Controls/Siemens Priority: HIGH Tag#090-AHU-548 - Air handler #8 tripping on virtual high static on restarts, please tune so fan slows down before it trips on high static because they are still ramping the speed higher when it trips.
FO-320030	6/17/2015	6/18/2015		R/R RM 315 UNABLE TO RAISE HI LEVEL SET POINT FOR SIEMENS PANEL (F608.02.AO1.314) Kathleen Connors would like somebody to come and take a look at the thermostat. She states that her office is to cold.
FO-320035	6/17/2015	6/25/2015		Control Engineer; High R/R RM 9405.4 Please check the refrigerant pressures in heat pump #1-123-071-HWP-081. The unit is not cooling.

WO	Recieved	Finished	Total	Request
FO-319315	6/18/2015	6/24/2015		Control Engineer; High Please check the refrigerant pressures in heat pump #1-125-071-HWP-083. The unit is not cooling correctly.
FO-320097	6/18/2015	6/22/2015		Trade: Controls/Siemens Priority: High R/R RM 3528 The Siemens system for EDC lab 3528 seems to be wacked out. I had to put fume hood EF4A/B in override to get the exhaust fan to start and the room temp setpoint is 72 and the room temp is 80. Also fume h
FO-320164	6/19/2015	6/22/2015		Trade: Controls/Siemens Priority: High Tag#090-EXF-556B Strobic exhaust fan 6B is on but can not make static pressure set point. The set point is 1.5 inches and the static is 0.69 with the by-pass damper at 50%. The by-pass damper should be closed. Plea
FO-320194	6/19/2015	6/22/2015		Trade: Command Center Priority: High R/R PENTHOUSE Please check operation of the process water loop. Water temperatures are hunting.
FO-320221	6/19/2015	6/22/2015		Trade: Command Center Priority: High R/R PENTHOUSE Please supply or replace AOP transducer for the chilled water coil for AHU #1. AOP will not bleed in auto or hand.
FO-320271	6/22/2015			R/R RM 287.01/MECH RM repair ahu 003
FO-320272	6/22/2015			RM 234/MECH RM Repair AHU 005
FO-320304	6/22/2015	6/23/2015		Trade: Command Center Priority: High R/R PENTHOUSE Please repair AHU #5. Fan alarm is going on causing unit to shut down. Current detector is blinking on and off (sometimes).
FO-320394	6/23/2015	6/23/2015		High Priority BAS AHU 4 and 6 will not start please check units. on BAS side.
FO-320459	6/24/2015	6/24/2015		Control Engineer; High Please check the refrigerant pressues in heat pump #1-124-071-HWP-082. The unit is not cooling.
FO-320542	6/25/2015			Hoobler Lounge repair ahu 003
<b>E - MedPharm</b>			<b>88</b>	
FO-318391	6/1/2015	6/2/2015		RM 7244 HAS NO STEAM
FO-318410	6/1/2015	6/1/2015		TOO COLD. ROOM 520.
FO-318409	6/1/2015	6/1/2015		RM 0502 LOW TEMP ALARM
FO-318424	6/1/2015	6/2/2015		RM 4421 TOO HOT
FO-318431	6/1/2015	6/1/2015		TOO COLD. ROOMS 3120A AND 3141.
FO-318759	6/2/2015	6/2/2015		RM 310.10 IS EXTREMELY HOT
FO-318775	6/2/2015	6/5/2015		RM 520 IS STILL TOO COLD.
FO-318805	6/2/2015	6/2/2015		RM 3109 TOO COLD
FO-318925	6/3/2015	6/4/2015		RM 5364 IS TOO COLD
FO-318999	6/4/2015			RM 256 AIR VENTS ARE VERY LOUD
FO-319004	6/4/2015	6/8/2015		RM 410 DIRTY SIDE CAGE WASH DOOR WON'T CLOSE
FO-319013	6/4/2015	6/4/2015		RM 141.1 (OUTSIDE OF MAGHERIO) INDEPENDENT HVAC UNIT ISN'T WRKNG
FO-319057	6/5/2015	6/5/2015		RM 5455 HIGH HUMIDITY
FO-319059	6/5/2015	6/5/2015		RM 2377 LADIES RM NO WATER
FO-319063	6/5/2015	6/13/2015		2ND FLR RESTROOMS NO WATER
FO-319064	6/5/2015	6/19/2015		3RD FLR RESTROOMS NO WATER
FO-319101	6/5/2015	6/5/2015		room becoming overheated
FO-319102	6/5/2015	6/5/2015		Room becoming over overheated
FO-319141	6/8/2015	6/10/2015		Please call in KROPF to service ACU-008,suspect low on refrigerant,will not stay running.FO-319013.priority High
FO-319155	6/8/2015	6/9/2015		TOO COLD. ROOM 520.
FO-319187	6/8/2015	6/19/2015		200.02 HIGH HUMIDITY

WO	Recieved	Finished	Total	Request
FO-319246	6/9/2015	6/9/2015		RM 139 FAP FIRE TROUBLE ALARM STILL COMING IN ON PANEL **SEE RESULTS**
FO-319255	6/9/2015	6/9/2015		FAP FIRE TROUBLE ALARM ACTIVE STILL ON PUB SAFE'S PANEL
FO-319259	6/9/2015	6/19/2015		RM 413 HIGH TEMP
FO-319266	6/9/2015	6/19/2015		COMPRESSOR DID NOT START UP AFTER POWER BUMP.
FO-319267	6/9/2015	6/19/2015		RM 200.12 HAS A HI TEMP
FO-319279	6/9/2015	6/18/2015		HIGH HUMIDITY. ROOM 5453.
FO-319332	6/10/2015	6/19/2015		TOO HOT. ROOM 9248.
FO-319333	6/10/2015	6/10/2015		WATER CEILING LEAK. ROOM 261.
FO-319340	6/10/2015	6/19/2015		RM 5136, AHU MAKING A LOUD NOISE
FO-319352	6/10/2015	6/19/2015		TOO HOT. ROOMS 521, 525 & 527.
FO-319361	6/10/2015	6/11/2015		TOO COLD. ROOM 315.
FO-319362	6/10/2015	6/18/2015		RM 5453 HIGH HUMIDITY
FO-319363	6/10/2015	6/11/2015		RM 0520 TOO HOT
FO-319379	6/10/2015			HIGH TEMP. ROOM 103.
FO-319380	6/10/2015	6/24/2015		FUME HOOD IS VERY NOISY. ROOM 5229.
FO-319430	6/11/2015			R/R 2306 REPLACE DAMAGED SMOKE HEAD FOR FOR SMOKE DETECTOR. FAP FIRE ALARM IS ACTIVE (SMOKE DETECTOR HEAD MISSING 2ND FLR RM 2218)
				Completed 6-12-2015 SRP
FO-319466	6/11/2015	6/24/2015		RM 5136 ACU IS BLOWING VERY HARD THRU VENTS
FO-319516	6/12/2015	6/18/2015		HIGH HUMIDITY. ROOM 5455.
FO-319575	6/15/2015	6/24/2015		HIGH HUMIDITY. ROOMS 417, 413 & 9332.
FO-319583	6/15/2015	6/25/2015		RM 2105, EYEWASH STATION WATER TOO HOT
FO-319589	6/15/2015	6/24/2015		HIGH HUMIDITY. ROOM 419.
FO-319595	6/15/2015			HIGH HUMIDITY. ROOM 5455.
FO-319877	6/15/2015	6/24/2015		TOO HOT. VENT IS VERY NOISY. ROOM 5136.
FO-319938	6/16/2015	6/26/2015		RM 415 HAS HI HUMIDITY
FO-319939	6/16/2015	6/26/2015		RM 423 HAS HI HUMIDITY
FO-319945	6/16/2015	6/16/2015		HOSE LEAK. ROOM 234.
FO-319950	6/16/2015	6/24/2015		RM 5229 TOO HOT
FO-319951	6/16/2015	6/24/2015		RM 5234 TOO HOT
FO-319957	6/16/2015	6/16/2015		RM 0610 TOO HOT PLEASE ADJUST ASAP EVENT AT 11:00
FO-319968	6/16/2015	6/17/2015		RM 103 TOO HOT
FO-319973	6/16/2015	6/16/2015		AUTOClave IS NOT WORKING. ROOM 1232.
FO-319987	6/16/2015	6/24/2015		LEAK COMING FROM WALL. ROOM 2352.
FO-319991	6/16/2015	6/16/2015		TOO HOT. ROOM 5215.
FO-320022	6/17/2015	6/17/2015		RM AF-14 HAS A HI TEMP
FO-320030	6/17/2015	6/18/2015		R/R RM 315 UNABLE TO RAISE HI LEVEL SET POINT FOR SIEMENS PANEL (F608.02.AO1.314) Kathleen Connors would like somebody to come and take a look at the thermostat. She states that her office is to cold.
FO-320042	6/17/2015	6/17/2015		RM 3610 TOO COLD
FO-320055	6/17/2015	6/24/2015		CHECK PRESSURE IN BUILDING. PROBLEM WITH DOORS. SUITE 400.
FO-320127	6/18/2015	6/24/2015		RM 423 HAS A HI TEMP (RABBIT RM)
FO-320140	6/18/2015	6/18/2015		TOO COLD. STUDY ROOMS 130, 131 & 132.
FO-320173	6/19/2015	6/24/2015		TOO HOT. ROOMS 523, 527, 525 & 521.
FO-320174	6/19/2015	6/24/2015		TOO HOT. ROOM 325.
FO-320183	6/19/2015	6/19/2015		ALARM SOUNDING. ROOM 4210.
FO-320274	6/22/2015	6/23/2015		RM 5324 IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-320277	6/22/2015	6/25/2015		RM 103 IS EXTREMELY HOT
FO-320283	6/22/2015	6/23/2015		TOO HOT. ROOM 9232.
FO-320301	6/22/2015	6/22/2015		RM 143 IS TOO COLD
FO-320303	6/22/2015	6/23/2015		RM 200.12 HAS HI HUMIDITY
FO-320305	6/22/2015	6/23/2015		RM 200.13 HAS HI HUMIDITY
FO-320354	6/23/2015	6/24/2015		TOO HOT. MAGERIO CONFERENCE CENTER. ROOM 141.
FO-320366	6/23/2015	6/24/2015		STEAMER IS NOT WORKING IN KITCHEN. ROOM 1348.
FO-320367	6/23/2015	6/25/2015		FREEZER IS NOT WORKING. ROOM 9232.
FO-320369	6/23/2015	6/25/2015		TOO HOT. ROOM 221.
FO-320376	6/23/2015	6/25/2015		NO WATER ON THE 9TH FLOOR.
FO-320378	6/23/2015	6/25/2015		NO WATER ON THE 1ST FLOOR.
FO-320386	6/23/2015	6/25/2015		TOO HOT. 9TH FLOOR.
FO-320403	6/23/2015	6/25/2015		TOO HOT. ROOM 6263.
FO-320414	6/23/2015	6/26/2015		RM 3125 HAS A CLNG GLASS DRAIN PIPE LEAKING (believe to be a waste pipe)
FO-320419	6/23/2015	6/26/2015		FAP BY GUARDS' DESK IS BEEPING
FO-320454	6/24/2015	6/25/2015		2 WALK IN REFERIGERATORS ARE READING 70 DEGREES. ROOM 1348.
FO-320470	6/24/2015			RM 1374 TOO COLD
FO-320486	6/24/2015			The cold room which is next to/south of 3220 - the power outlet is not working and needs repairing again.
FO-320529	6/25/2015	6/25/2015		TOO HOT. ROOM 525.
FO-320537	6/25/2015	6/26/2015		HOODS OVER GRILL IS NOT SUCTIONING. KITCHEN ROOM 1351.
FO-320547	6/25/2015			Room 309 computer lab - Please investigate - No power at computer stations 50 and 51.
FO-320636	6/26/2015	6/26/2015		CHECK BEEPING (ALARM) NOISE COMING FROM 1ST FLOOR.
FO-320654	6/26/2015			RM 322 IS TOO HOT
FO-320691	6/29/2015	5/29/2015		1ST FL MECH RM NEXT TO RM 1367, LOUD HISSING NOISE
<b>E - North</b>			<b>41</b>	
FO-318363	6/1/2015	6/2/2015		LIGHTS ARE OUT ON THE 2ND FLOOR NORTHEAST CORNER OF BUILDING. (Multi-Task)
FO-318365	6/1/2015	6/1/2015		TOO COLD. BUILDING.
FO-318367	6/1/2015	6/1/2015		TOO COLD. BUILDING.
FO-318402	6/1/2015	6/1/2015		2ND FL NORTH SIDE TOO COLD
FO-318425	6/1/2015	6/1/2015		RM 2074 IS TOO COLD
FO-318427	6/1/2015	6/1/2015		RM 3198 TOO COLD
FO-318795	6/2/2015	6/2/2015		VERY COLD. PROVOST OFFICE ROOM 4129. SEE KATHY BARRETTE.
FO-318874	6/3/2015	6/3/2015		RM BC IS TOO HOT, EVENT TODAY
FO-318960	6/4/2015	6/4/2015		ROOM B/C IS TOO HOT.
FO-319003	6/4/2015	6/4/2015		TOO HOT. ROOM 4092.
FO-319143	6/8/2015	6/8/2015		RM 287 MO POWER
FO-319242	6/9/2015	6/9/2015		ALARM SOUNDING. 1ST FLOOR.
FO-319243	6/9/2015	6/9/2015		NO HOT WATER IN BOTH WOMENS/MENS LOCKER RMS
FO-319288	6/9/2015	6/9/2015		FRONT LOBBY SIMPLEX BOX MOUNTED ON WALL IS MAKING A HIGH PITCH NOISE
FO-319339	6/10/2015	6/10/2015		TOO WARM. WOODCOCK SIDE (WEST) OF BUILDING.
FO-319346	6/10/2015	6/10/2015		FIRE TROUBLE ALARM WITH RESET.
FO-319348	6/10/2015	6/10/2015		RM 4144 BLOWER TOO LOUD
FO-319375	6/10/2015	6/10/2015		RM 4259 TOO COLD
FO-319381	6/10/2015	6/10/2015		TOO COLD. ROOMS 423 AND 424.
FO-319433	6/11/2015	6/11/2015		RM 327 IN VESTIBULE SATURATED CLNG TILES FELL
FO-319461	6/11/2015	6/11/2015		TOO COLD. BUILDING.

WO	Recieved	Finished	Total	Request
FO-319508	6/12/2015	6/12/2015		RM 233 HAS HOT AIR BLOWING OUT OF AIR VENTS
FO-319572	6/15/2015	6/15/2015		RM 1198 DUST BLOWING FROM VENTS
FO-319587	6/15/2015	6/15/2015		DUST AND BUGS BLOWING FROM CEILING VENTS. ROOM 1198.
FO-319914	6/16/2015	6/16/2015		STILL LKNG @ 3RD FL HALLWAY ON NORTH SIDE, NOW @ TWO (2) AREAS INSTEAD OF ONE (1) ACTIVE CEILING LEAK BUCKET IS CATCHING WATER ,,,,,,,,,,,,,,,,,, EA/6-15-15 ,,,,,,,,,,,,,,,,,
FO-319921	6/16/2015	6/16/2015		ENTIRE STE IS EXTREMELY HOT (WOULD LIKE PORTABLE UNITS DUE TO ACU IS BEING WORKED ON)
FO-319986	6/16/2015	6/16/2015		RM 3256 TOO HOT
FO-320028	6/17/2015	6/17/2015		RM 4200 PORTABLE AIR CONDITIONER IS LOOSE FROM THE WINDOW
FO-320040	6/17/2015	6/17/2015		RM 4259 PLEASE TURN FAN DOWN TOO COLD
FO-320111	6/18/2015	6/18/2015		COLD AIR BLOWING VERY HARD FROM CEILING VENT. (WANT VENT CLOSED) ROOM 3265.
FO-320113	6/18/2015	6/18/2015		PORTABLE AIR CONDITIONER IS PULLING AWAY FROM WINDOW. PRESIDENT'S OFFICE. ROOM 4200.
FO-320177	6/19/2015	6/19/2015		RM 4092 BLOWERS A RUNNING VERY STRONG
FO-320273	6/22/2015	6/22/2015		TOO COLD. ROOM 3265. 2ND REQUEST.
FO-320475	6/24/2015	6/24/2015		RM 2074 TOO COLD
FO-320477	6/24/2015	6/24/2015		RADIATOR IS VERY HOT. ROOM 233.
FO-320484	6/24/2015	6/24/2015		GALLERY LIGHTS NOT WORKING
FO-320553	6/25/2015	6/25/2015		ENTIRE BLDG IS TOO COLD
FO-320561	6/25/2015	6/25/2015		PLS CK RTU ON TOP FLR IT IS LKNG THRU CEILING
FO-320662	6/26/2015			FGH TOO COLD
FO-320682	6/29/2015	6/29/2015		ALARM SOUNDING. 1ST FLOOR.
FO-320681	6/29/2015	6/29/2015		FIRE TROUBLE ALARM
<b>E - Northeast</b>			<b>16</b>	
FO-318399	6/1/2015	6/1/2015		TOO COLD. BUILDING.
FO-318887	6/3/2015			TROUBLESHOOT TOUCH SCREEN SHOWS WRONG TIME & DATE SEE ROSE FOR DETAILS FIRE ALARM WITH RESET. FRONT ENTRANCE  Completed 6-3-2015 SRP
FO-318895	6/3/2015	6/3/2015		CUSTODIAL OFFICE TOO COLD
FO-318974	6/4/2015	6/4/2015		FIRE TROUBLE ALARM.
FO-319007	6/4/2015			BLACK PARTICLES ON DESK MAYBE FALLING FROM CEILING VENT. ROOM 3666.
FO-319140	6/8/2015	6/8/2015		FREEZING COLD. BUILDING.
FO-319263	6/9/2015	6/10/2015		RM 223 TOO HOT AIR NOT WORKING
FO-319265	6/9/2015	6/10/2015		RM 136 STAT NOT WORKING, TOO HOT
FO-319344	6/10/2015	6/10/2015		RM 202 TOO HOT
FO-319378	6/10/2015	6/10/2015		CUSTODIAL OFFICE TOO COLD
FO-319432	6/11/2015	6/11/2015		FAP FIRE TROUBLE ALARM
FO-319452	6/11/2015	6/16/2015		There's a drain that runs into the sink in the kitchen. According to Larry Fodor, this drain is connected to the AC on the second level in the athletic offices. This drain is continuously running. And again, according to Larry, it should be run
FO-319559	6/15/2015	6/15/2015		TOO WARM. ROOM 240.
FO-320255	6/22/2015			CHECK A/C UNIT. TOO HOT. 2ND FLOOR ELECTRICAL SHOP. SEE EUGEN OWENS FOR MORE DETAILS.
FO-320489	6/24/2015			RM 4308/4310 OUTLETS NOT WORKING
FO-320675	6/29/2015			OCCUPANT IS LOCKED OUT OF OFFICE. ROOM 3638.
<b>E - Preventative Maintenance</b>			<b>56</b>	
FO-318450	6/1/2015	6/2/2015		TOO HOT. 7TH FLOOR.

WO	Recieved	Finished	Total	Request
FO-318452	6/1/2015			ceiling / pipe leak water is dripping quite rapidly from it....
FO-318454	6/1/2015	6/2/2015		LOUD BEEPING NOISE FROM ALARM PANEL NEAR GUARDS DESK FIRE TROUBLE ALARM
FO-318839	6/2/2015		6/30/2015	TOO COLD. ROOM 170.
FO-318843	6/2/2015	6/2/2015		BSMNT DOOR ALARM SOUNDING, EMERGENCY DOOR LEADING TO CHEM BLDG
FO-318845	6/2/2015	6/2/2015		RM 330 HAS A CLNG LEAK
FO-318933	6/3/2015	6/4/2015		There is water dripping from the ceiling in room 2 of the Prentis building. It has created a hole in one of the ceiling tiles.
FO-318934	6/3/2015	6/4/2015		There is water dripping from the ceiling in room 2 of the Prentis building. It has created a hole in one of the ceiling tiles.
FO-318935	6/3/2015	6/3/2015		RM 221 IS TOO HOT
FO-318936	6/3/2015	6/4/2015		NO HOT WATER THROUGHOUT BLDG
FO-319007	6/4/2015			BLACK PARTICLES ON DESK MAYBE FALLING FROM CEILING VENT. ROOM 3666.
FO-319022	6/4/2015	6/4/2015		4092 TOO HOT
FO-319027	6/4/2015	6/5/2015		RM 218 IS TOO HOT
FO-319028	6/4/2015	6/5/2015		ALUMNI LOUNGE TOO HOT, EVENT TODAY PLEASE FIX ASAP
FO-319029	6/4/2015	6/5/2015		1ST FL LADIES RM HAS LEAK FROM RM ABOVE
FO-319121	6/5/2015	6/6/2015		2ND FLR WOMENS RR ACROSS FROM RM 207 LAST STALL (HANDICAP STALL) TOILET IS CON'T FLUSHING
FO-319202	6/8/2015	6/9/2015		FREEZER #1 ALARM. ROOM 0136.
FO-319203	6/8/2015	6/9/2015		MENS RM 3RD FL 2ND URINAL CONSTANTLY RUNNING AND FLOWING OVER
FO-319207	6/8/2015	6/9/2015		RM 6402.1 TOO HOT, HEAT COMING FROM VENT
FO-319210	6/8/2015	6/9/2015		RM 3315 & 3317 TOO WARM PLEASE LOWER TEMP 5 DEGREES
FO-319302	6/9/2015	6/10/2015		RM 5136 VENTS MAKING A LOUD NOISE
FO-319303	6/9/2015	6/10/2015		RM 5136 TOO HOT
FO-319305	6/9/2015	6/10/2015		FIRE TROUBLE ALARM
FO-319331	6/10/2015			RM 108 SHIFFMAN LIBRARY TOO HOT
FO-319394	6/10/2015	6/15/2015		Check Exhaust Fan# 37, to see if it is functioning. Hood in room 2335, fed by this fan is not operational.
FO-319387	6/10/2015	6/11/2015		RM 240 EXTREMELY HOT ANNEX TOO HOT PLEASE UPDATE FERNA 7-4488
FO-319389	6/10/2015			GOLDEN GREENS RM, PLEASE TURN ON AIR
FO-319390	6/10/2015			GOLDEN GREENS RM, PLEASE TURN ON HOODS IN KITCHEN
FO-319391	6/10/2015	6/11/2015		RM 230 AIR NOT WORKING
FO-319404	6/10/2015	6/11/2015		150 TOO HOT
FO-319521	6/12/2015	6/29/2015		(**) PO REQ DK 6-17-15 ADDING ENG: (RM 110 NEED TO EMPTY BUCKET OVER WEEKEND) R/R RM 110 (ONLY) Sink leaking from underneath. (NOTE: BUCKET UNDERNEATH SINK ALSO IS LKNG EVEN WHEN FAUCET ISN'T ON),,,,,,,,,,,,,, GS/6-15-15 ,,,,,,,,,,
FO-319527	6/12/2015	6/13/2015		NEED AIR TURNED ON IN BLDG IS TOO HOT WOULD LIKE IT LEFT ON THRU JULY 1ST.
FO-319886	6/15/2015	6/15/2015		BOUNCING FIRE TROUBLE ALARM RM 1209 PLEASE UPDATE PUBLIC SAFETY
FO-319999	6/16/2015	6/24/2015		Kresge entrance vestibule area: heating vent leaking water/fluid
FO-320062	6/17/2015	6/18/2015		RM 2218 TOO HOT
FO-320144	6/18/2015	6/18/2015		TOO COLD. ROOM 112.
FO-320146	6/18/2015	6/19/2015		FAN BLOWING VERY HARD. PROVOST OFFICES ROOM 4092.
FO-320147	6/18/2015	6/19/2015		FIRE TROUBLE ALARM.
FO-320231	6/19/2015	6/20/2015		TOILET CONTINOSLY FLUSHING. MEN'S RESTROOM. ROOM 110.
FO-320319	6/22/2015	6/23/2015		RM 2212 HAS NO ACU
FO-320320	6/22/2015	6/22/2015		RM 2218 HAS NO ACU
FO-320322	6/22/2015	6/22/2015		TOO COLD. ROOMS 2074 AND 2110.



WO	Recieved	Finished	Total	Request
FO-320323	6/22/2015	6/22/2015		TOO COLD. ROOM 113 AND BUILDING.
FO-320324	6/22/2015	6/22/2015		TOO HOT. 3RD FLOOR - NORTH SIDE OF BUILDING.
FO-320327	6/22/2015	6/23/2015		No air in office--very hot.
FO-320430	6/23/2015	6/24/2015		RM 3372 IS TOO COLD
FO-320431	6/23/2015	6/24/2015		RM 3374 IS TOO COLD
FO-320435	6/23/2015	6/23/2015		RM 2074 IS EXTREMELY COLD
FO-320436	6/23/2015	6/24/2015		1ST FLR HALLWAY NEAR RM 1122 NEED BREAKER RESET
FO-320509	6/24/2015	6/24/2015		TRAILER, WATER IS OFF IN TRAILER
FO-320538	6/25/2015	6/26/2015		Trade: Afternoon/PM Priority: High Tag#090-EXF-024 R/R LAB ROOF Exhaust fan 24 has thrown its belt please install new one. This EF is for a fume hood in lab 2348.
FO-320571	6/25/2015	6/25/2015		RM 5263 IS TOO HOT
FO-320576	6/25/2015			LAB 140 FH# 4 LOW FLOW VELOCITY
FO-320585	6/25/2015	6/25/2015		3RD FL CMG LABS, BURNING SMELL
FO-320663	6/26/2015	6/27/2015		0364 LIGHTS WENT OUT, NEED ENG ASAP
FO-320723	6/29/2015			HIGH TEMP. ALARM. ROOM 6130.
<b>E - South</b>			<b>37</b>	
FO-318423	6/1/2015	6/1/2015		RM 3123 TOO COLD
FO-318756	6/2/2015	6/2/2015		TOO HOT. DEAN'S OFFICE INSIDE SUITE 3100.
FO-318776	6/2/2015	6/2/2015		COLD ROOM IS TOO HOT. ROOM 430.
FO-318797	6/2/2015	6/2/2015		RM 1520 AIR WOT WORKING
FO-318873	6/3/2015	6/3/2015		RM 203 TOO COLD
FO-318882	6/3/2015	6/3/2015		RM 221,215,225 TOO COLD
FO-318899	6/3/2015	6/3/2015		RM 5178 HAS HEAT BLOWING IN THRU AIR VENTS
FO-318959	6/4/2015	6/5/2015		CEILING TILES ARE WET. ROOM 3100 SEE JIM.
FO-318988	6/4/2015	6/4/2015		RM 1173 HAS A BEEPING SOUND
FO-319058	6/5/2015	6/12/2015		RM 1674 TOO HOT
FO-319137	6/8/2015	6/8/2015		We must of loss power during the storms. In the Dean's Office suite when you walk into the receptionist area the alarm is constantly beeping. Need Building Engineer to reset so it doesn't keep beeping. Thank you.
FO-319178	6/8/2015	6/8/2015		TOO COLD. ROOM 101.
FO-319188	6/8/2015	6/12/2015		CIRC DESK TOO COLD, AIR BLOWING OVER DESK
FO-319193	6/8/2015	6/8/2015		Electrical outlet straight across from the door has just stopped working. The lab uses this outlet for their cell culture hood. The plug /receptacle is not standard, so they can't just plug the hood into another outlet. High priority.
FO-319256	6/9/2015	6/9/2015		BEEPING SOUND COMING FROM EMERGENCY RESPONSE ROOM. ROOM 1100.
FO-319358	6/10/2015			DIGITAL SIGNS NOT WORKING, PLEASE RESET BREAKER. ENG UNABLE TO LOCATE BREAKER
FO-319365	6/10/2015	6/10/2015		RM 1330 AIR NOT WORKING, ALSO LIGHT ON STAT OUTSIDE DOOR NOT WORKING
FO-319372	6/10/2015			ANNEX TOO HOT
FO-319462	6/11/2015	6/11/2015		WATER LEAKING UNDERNEATH EQUIPMENT. ROOM 3171.
FO-319486	6/12/2015	6/12/2015		SHUT OFF VALVE TO BOTTLE WASHER. ROOM 0239. CONTACT DEB ASHCRAFT FOR MORE DETAILS.
FO-319510	6/12/2015	6/16/2015		RM 2177 IS TOO COLD
FO-319511	6/12/2015	6/16/2015		1ST FLR UNISEX RR NEAR RECEIVING & STUDENT DISABILITES HAVE A SEWAGE SMELL
FO-319560	6/15/2015	6/15/2015		RM 101 TOO COLD, PLEASE RAISE TEMP TO 73 DEGREES
FO-319933	6/16/2015	6/17/2015		TOO COLD. (DANTO) ROOM 1527.
FO-319954	6/16/2015	6/17/2015		TOO HOT. ROOM 169.
FO-320081	6/18/2015	6/18/2015		2ND FLR IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-320082	6/18/2015	6/18/2015		3RD FLR IS TOO COLD
FO-320112	6/18/2015	6/18/2015		NO COMPRESSED AIR. ROOMS 110 AND 120.
FO-320163	6/18/2015	6/19/2015		This is not an inactive room; it is a cold room that is too cold. Should be about 4 degrees celcius but is -7 degrees celcius. Research samples are freezing which has ruined them. High priority.
FO-320249	6/22/2015	6/24/2015		INFO FROM ANS MACH LEFT BY A STUDENT SAYS THAT AFTER PWR OUTAGE COMPUTER ISN'T WRKNG
FO-320267	6/22/2015	6/22/2015		COLD ROOM IS WARM. ROOM 430.
FO-320308	6/22/2015	6/24/2015		RM 219.1 IS TOO HOT
FO-320309	6/22/2015			RM 219.2 IS TOO HOT
FO-320329	6/22/2015	6/23/2015		FUME HOOD #1 SASH IS OFF TRACK AND CAUSING VELOCITY ALARMS. ROOM 160.
FO-320390	6/23/2015	6/23/2015		ALL FANS AND FUME HOODS WENT OUT. BUILDING.
FO-320562	6/25/2015			BEEPING NOISE COMING FROM EMERGENCY RESPONSE ROOM. 1ST FLOOR (TMA WAS DOWN - Work request came in at approx. 12:10 p.m.)
FO-320694	6/29/2015			RM 2528 NO AIR CIRCULATING
<b>E - Southeast</b>			<b>37</b>	
FO-318381	6/1/2015	6/1/2015		RED SUBSTANCE LEAKING FROM FURNANCE. ROOM 145.
FO-318796	6/2/2015	6/2/2015		RM 212 TOO HOT
FO-318825	6/2/2015	6/2/2015		7TH FLR IS TOO HOT
FO-318984	6/4/2015	6/4/2015		GAS SMELL - 1ST FLOOR.
FO-318997	6/4/2015	6/4/2015		POWER LOSS, POSSIBLE POWER BUMP
FO-319040	6/4/2015	6/5/2015		No air circulation for the past couple of days. Must reset HVAC system.
FO-319156	6/8/2015	6/8/2015		TOO HOT. ROOM 212.
FO-319162	6/8/2015	6/8/2015		TOO HOT. ROOM 9405.4.
FO-319273	6/9/2015	6/9/2015		TOO HOT. ROOM 212.
FO-319284	6/9/2015	6/9/2015		RM 9408 TOO HOT
FO-319328	6/10/2015	6/10/2015		TOO HOT. ROOM 4101.02.
FO-319341	6/10/2015	6/10/2015		FIRE ALARM.
FO-319345	6/10/2015	6/16/2015		NEED AIR TURNED ON IN THE LOBBY
FO-319464	6/11/2015	6/11/2015		RM 201 IS TOO HOT
FO-319465	6/11/2015	6/11/2015		RM 212 IS TOO HOT
FO-319490	6/12/2015	6/12/2015		LOUD NOISE COMING FROM AIR CONDITIONING UNIT. 7TH FLOOR HALLWAY.
FO-319562	6/15/2015	6/18/2015		RM 2219 NO HOT WATER
FO-319566	6/15/2015	6/17/2015		RM 0326 BSMNT TOO HOT AIR NOT WORKING
FO-319569	6/15/2015	6/15/2015		RM 5018 NO AIR FOR THE PAST WEEK
FO-319926	6/16/2015	6/16/2015		RM 109 POWER STRIPS HAVE RED SURGE LIGHTS ON, OUTLETS NOT WORKING
FO-319928	6/16/2015	6/16/2015		LIGHTS WENT OUT ALL AT ONE TIME. ROOM 5117.
FO-319965	6/16/2015	6/16/2015		7TH FL WEST END TOO HOT
FO-319976	6/16/2015			LARGE WATER GUSHING SOUNDS COMING FROM THE 2ND FLOOR MEN AND WOMEN RESTROOM.
FO-320011	6/17/2015	6/17/2015		POWER FAILURE ALARM. ROOM 0057.
FO-320012	6/17/2015	6/17/2015		NO POWER IN BUILDING.
FO-320026	6/17/2015	6/17/2015		RM 9405.4 IS STILL TOO HOT ACU ISN'T WRKNG
FO-320048	6/17/2015	6/17/2015		RM 2347 HAS NO POWER TO WALL OUTLETS
FO-320092	6/18/2015			TOO WARM. THEATRE
FO-320116	6/18/2015	6/18/2015		TOO WARM. NEED HEAT TURNED DOWN 5 DEGREES ROOMS 3372 AND 3374.
FO-320263	6/22/2015	6/22/2015		RM 5018 ACU STOPPED WRKNG
FO-320275	6/22/2015	6/22/2015		CLOCK MAKING LOUD NOISE. CAUSING DISTURBANCE TO TEACHING CLASS. ROOM 103.

WO	Recieved	Finished	Total	Request
FO-320297	6/22/2015	6/22/2015		FAP FIRE TROUBLE ALARM ACTIVE
FO-320362	6/23/2015	6/23/2015		TOO HOT. ROOMS 001 AND 002.
FO-320368	6/23/2015	6/23/2015		LEAK - CARPET IS WET. UNKNOWN WHERE LEAK IS COMING FROM. HALLWAY OUTSIDE OF ROOM 3372 DANCE STUDIO.
FO-320402	6/23/2015	6/23/2015		7TH FLR WEST END ACU IS MAKING A VERY LOUD RACKET/NOISE
FO-320523	6/25/2015	6/25/2015		FIRE TROUBLE ALARM. BASEMENT.
FO-320535	6/25/2015	6/25/2015		BSMNT COMPUTER LAB TOO HOT
<b>E - West</b>			<b>22</b>	
FO-318374	6/1/2015	6/1/2015	6/1/2015	1ST FL TOO COLD
FO-318440	6/1/2015	6/3/2015		RM 175/LOUNGERIE RM NO POWER TO WASH MACHINE #2 WOULD LIKE TO KNOW IF IT CIRCUIT
FO-318784	6/2/2015	6/2/2015	6/2/2015	RM 2145 HAS COLD AIR BLOWING IN FROM VENTS
FO-318799	6/2/2015	6/4/2015		BLDG TOO COLD PLEASE SEE DEE
FO-318826	6/2/2015	6/3/2015		RM 131 NEED BREAKER RESET
FO-318828	6/2/2015	6/3/2015		RM 135 NEED BREAKER RESET
FO-318830	6/2/2015	6/3/2015		RM 137 NEED BREAKER RESET
FO-318831	6/2/2015	6/3/2015		RM 139 NEED BREAKER RESET
FO-318892	6/3/2015	6/3/2015		AUD RM 100 IS TOO COLD
FO-318893	6/3/2015	6/3/2015		AUD RM 150 IS TOO COLD
FO-318967	6/4/2015	6/4/2015		ENTIRE BLDG HAS NO AIR FLOW ALSO TOO HOT/STUFFY
FO-319249	6/9/2015	6/9/2015		BLDG TOO WARM
FO-319254	6/9/2015	6/9/2015		FAP FIRE TROUBLE ALARM IS STILL ACTIVE ON PUB SAFE'S PANEL
FO-319317	6/10/2015	6/11/2015		TOO HOT. ROOM 103.
FO-319446	6/11/2015			FIRE TROUBLE ALARM.
FO-319550	6/15/2015	6/15/2015		FIRE TROUBLE ALARM WITH RESET. 1ST FLOOR SOUTHWEST STAIRWELL.
FO-319580	6/15/2015	6/16/2015		A/C UNIT LEAKING. ROOM 106.1.
FO-320023	6/17/2015	6/17/2015		ENTIRE BLDG HAS NO AIR FLOW/STUFFY & TOO HOT
FO-320172	6/19/2015	6/22/2015		TOO HOT. BUILDING.
FO-320216	6/19/2015	6/22/2015		HUMIDITY IS VERY HIGH IN THE MORNING. 1ST FLOOR. FLOOR IS WET EVERY MORNING.
FO-320482	6/24/2015	6/25/2015		FOOTBALL STADIUM BOTH OFFICES HAVE NO AIR CONDITIONING
FO-320622	6/26/2015	6/29/2015		No air in office--very hot.
<b>Medium</b>			<b>25</b>	
<b>E - Auxiliary</b>			<b>4</b>	
H-52868	6/12/2015	6/17/2015	6/24/2015	-One of the power plugs isn't working. Please call, to come in while resident is available, to show which plug is malfunctioning. authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52993	6/22/2015	6/23/2015	6/25/2015	living room plug-in switch not working. authenticated user: Poonam Bhardwaj - fs3639 requester ip address: 141.217.161.227
H-53017	6/24/2015	6/24/2015	6/25/2015	Please fix the set of 2 outlets that suddenly stop working. The outlets are located in the master bedroom (larger room), near by a pillow on the bed. authenticated user: Miwa Ito - fj6636 requester ip address: 35.16.76.229
H-53083	6/27/2015			No electricity in my kitchen authenticated user: Logayn Hussam Aldin - et0486 requester ip address: 141.217.233.37
<b>E - Command Center</b>			<b>17</b>	
FO-318857	6/2/2015	6/18/2015		controls- med. priority- Replace leaking diaphragm on reheat coil valve in room 2109., causing room to overheat.
FO-318864	6/3/2015	6/9/2015		Trade: Controls/Siemens Priority: Medium The TEC set back schedule for EDC is not working properly please trouble shoot and repair.

WO	Recieved	Finished	Total	Request
FO-318902	6/3/2015	6/10/2015		High absorber temperature, hose on purge pump has failed, absorber supply temp @ 75 degrees
FO-318907	6/3/2015	6/18/2015		Controls -- Priority medium Room too hot. Thermostat set point has to be change. Points are not accessible to Engineer
FO-319181	6/8/2015	6/25/2015		Control Engineer; Medium Please check the refrigerant pressures in heat pump #1-76-071-HWP-034. The unit is going out on the lock out relay.
FO-319195	6/8/2015	6/9/2015		Trade: Command Center - Siemans Priority: Medium Please repair fume hood 150 #2.
FO-319395	6/10/2015	6/11/2015		Trade: Command Center Priority: Medium Please repair heat wheel on AHU #5. Alarm needs to be reset on a daily basis.
FO-319436	6/11/2015			Electrician; Medium R/R RM 00195/MECH/BLR RM Please check the electrical integrity between the the #2 Boiler power distribution disconnect and the boilers control panel.
FO-319930	6/16/2015			REWIRE CONTROL BOX VALVE: CONTACT JOHN TOWLE FOR DETAILS.  AHU#5 HEATING VALVE NEEEDS REPLACING,,,,,,,,,,,,, ME/6-17-15,,,,,,,,,,,,,
FO-320013	6/17/2015			Command Center : Please install program in Freer & Carriage House Siemens Panels. Industrial Cooler runs only in Manual.
FO-320016	6/17/2015	6/18/2015		Trade: Controls/Siemens Priority: Medium R/R Room 1527 is too cold, I checked VAV box operation and found that the heating valve is not opening, please repair.
FO-320085	6/18/2015	6/18/2015		Trade: Controls/Siemens Priority: medium R/R The 1st floor lobby room 1590 for EDC is too warm. When I look at the graphic the control set point is at 76 in OVRD. The day/ngt is in OVRD DAY. The unit is in heating mode. Please trouble shoot.
FO-320087	6/18/2015	6/24/2015		Trade: Controls/Siemens Priority: Medium R/R Room 1520 too cold. The Siemens system is calling for the heating valve to open at 100% and it says its open 100% but the aux temp is 62 degrees. Control Set point is 72 and the unit is in heating mode. Sieme
FO-320096	6/18/2015	6/24/2015		Trade: Controls/Siemens Priority: Medium R/R 3RD FLR Electrical room 3535 is hot 81 degrees. The flow sensor shows failed, please repair.
FO-320175	6/19/2015	6/22/2015		Siemens: R/R 3RD FLR My computer will not let me access any points in regard to corridor VAV box # CC1N between rooms 328 and 330 and only shows the temperature, which is showing 83 degrees; wall stat is set to 55 degrees. Please correct and repair. M
FO-320563	6/25/2015	6/29/2015		Please repair AC unit located in receiving office area. Unit will not run.
FO-320667	6/29/2015			Repair boiler # 2 at Matthaei. Boiler will not light off unless mod-motor is manually assisted past the bind in the travel of the gas valve adjustment spring.
<b>E - North</b>			<b>1</b>	
FO-320528	6/25/2015	6/25/2015		TOO COLD. BUILDING, INCLUDING ROOM F,G,H.
<b>E - Preventative Maintenance</b>			<b>1</b>	
FO-319307	6/9/2015	6/9/2015		Please turn on the air conditioning unit in the office area, and shut off the heat in the rest of the building.
<b>E - South</b>			<b>1</b>	
FO-319190	6/8/2015	6/10/2015		Fix plug on benchtop, labeled with blue tape. Not working.
<b>E - Southeast</b>			<b>1</b>	
FO-320704	6/29/2015			Request for Air conditioning to be ON for rehearsals and public performances in the STUDIO THEATRE in July 2015.Performances to public:Faust(us)Thursday July 9 at 7pm  Friday July 10 at 7pmSaturday July 11 at 2pm and 7pmA Behanding in SpokaneThurs
<b>Low</b>			<b>229</b>	
<b>E - Area 2 Engineer</b>			<b>1</b>	

WO	Recieved	Finished	Total	Request
FO-320338	6/23/2015			Please inspect/fix continuous leak coming from under one of the two doors opposite/nearest Sector 9 Supervisor office rm. 130. Thanks
<b>E - Auxiliary</b>			<b>130</b>	
H-52619	6/1/2015	6/1/2015	6/17/2015	leak in ceiling in back hallway of ghafari hall leading to back doors of Einstein bagels.
H-52630	6/1/2015	6/2/2015	6/17/2015	Second bathroom toilet handle is broken.
H-52642	6/1/2015	6/3/2015	6/17/2015	our washing dish is stuck because the cutting machine was not working it may have been an electrical or an waste disposal unit problem authenticated user: Hassan Alkhwaildi - ft8883 requester ip address: 35.16.79.234
H-52643	6/1/2015	6/3/2015	6/17/2015	Resident put in a work order about his AC, it was fixed, but now it has stopped working again. authenticated user: - requester ip address: 141.217.23.210
H-52650	6/2/2015	6/4/2015	6/23/2015	The bathtub faucet in the main bathroom doesn't work well. Most of the water still comes out from the faucet when the controller is lifted. authenticated user: Hao Song - ei9668 requester ip address: 141.217.220.179
H-52637	6/2/2015	6/2/2015	6/17/2015	The fan never turns off in this unit. Even if the AC/Heat is off and the fan is set to auto, it doesn't turn off. I would like to be able to turn the fan off. Please fix. Thank you. authenticated user: Christopher Binno - eg8502 requester ip address: 3
H-52663	6/3/2015			A/C is busted. Needs to be fixed. authenticated user: Zachary Rich - eu7441 requester ip address: 141.217.23.230
H-52687	6/3/2015	6/5/2015	6/17/2015	The air conditioning/heating system isn't working authenticated user: Faith Basheer - fp3620 requester ip address: 35.16.104.171
H-52664	6/3/2015	6/4/2015	6/17/2015	air conditioning not working. authenticated user: Dharmaja Hemamber Koka - ft6419 requester ip address: 141.217.23.186
H-52675	6/3/2015	6/5/2015	6/23/2015	my flush in the restroom isn't working , i couldn't use the restroom , pls fix my issue as soon as possible authenticated user: Praveen Padmanaban - ft8925 requester ip address: 35.16.193.122
H-52676	6/3/2015			Tap is not working in bathtub. There is leakage of water from the tap. authenticated user: Sahith Nadipalli - fs2504 requester ip address: 35.16.73.33
H-52677	6/3/2015	6/19/2015	6/25/2015	Room air conditioning not working again. authenticated user: Joshua Gatz - ef0656 requester ip address: 97.95.8.206
H-52678	6/4/2015	6/17/2015	6/24/2015	Room Cooling Unit not working properly authenticated user: Godwin Richmond Martin - fs4764 requester ip address: 35.16.198.169
H-52679	6/4/2015	6/19/2015	6/25/2015	Air Conditioner does not seem to cool the apartment. authenticated user: Kunal Deulkar - fv1235 requester ip address: 35.16.74.237
H-52680	6/4/2015			I turned the air conditioning on and no cold air comes out. The fan is working but the air isn't conditioned. authenticated user: Cailey Miller - fm3618 requester ip address: 141.217.220.229
H-52707	6/4/2015	6/17/2015	6/24/2015	air conditioning not cooling authenticated user: Basavarajeshwari Shirol - fs0950 requester ip address: 35.16.195.19
H-52708	6/4/2015	6/5/2015	6/17/2015	Alr conditioning not working properly.  Kitchen basin sink motor is not working. (Disposal) authenticated user: Sanket Chinchwade - fj5750 requester ip address: 35.16.195.29
H-52698	6/4/2015	6/9/2015	6/23/2015	air conditioner in bedroom needs a new funnel  *please give work order to Angelica if work order should be for maintenance authenticated user: Michelle Talukder - ev6408 requester ip address: 141.217.232.85
H-52703	6/4/2015	6/19/2015	6/25/2015	Water leaking from the roof .urgent action required authenticated user: Akshay Jadhav - fk1699 requester ip address: 107.227.218.130

WO	Recieved	Finished	Total	Request
H-52705	6/4/2015	6/8/2015	6/23/2015	Electrical Socket not working  In apartment hall authenticated user: Viswajith Kodu Subramanian - fq9051 requester ip address: 35.16.197.66
H-52711	6/5/2015	6/5/2015	6/17/2015	I'd like for my AC unit to be checked. It seems that the air conditioning system isn't working properly because it isn't blowing out cold air. It's fairly warm compared to the cooler hallway air. I'm in the RA room 221. authenticated user: Thomas Wolf -
H-52713	6/5/2015	6/8/2015	6/23/2015	Towers 345 A needs light switch replaced.
H-52736	6/5/2015	6/9/2015	6/23/2015	Kitchen drain is not functioning, has been serviced twice before but is still not fixed. authenticated user: Paramveer Swaich - fh2790 requester ip address: 141.217.221.149
H-52733	6/7/2015	6/8/2015	6/23/2015	The air conditioner isn't working again. authenticated user: Dharmaja Hemamber Koka - ft6419 requester ip address: 141.217.225.225
H-52725	6/7/2015	6/9/2015	6/23/2015	The resident complains of issues with the garbage disposal. Currently it turns on, but nothing is going through. The issue has lasted a couple of days and continues to get worse. It would be appreciated if it could get fixed soon. Thank you. authenticate
H-52729	6/7/2015	6/12/2015	6/23/2015	The fire alarm in the foyer by the kitchen has its light on. It turned on after the alarm went off from cooking incident. It is believed that the alarm just needs to be reset. authenticated user: Vivien Okechukwu - fh2758 requester ip address: 141.217.
H-52735	6/7/2015	6/8/2015	6/23/2015	Sink vacuum in kitchen is not working. We people will not be in home. So kindly please repair it. Thanks. authenticated user: Vishnu Shanmugasundaram - fq8161 requester ip address: 141.217.220.105
H-52743	6/8/2015	6/10/2015	6/23/2015	Hi,  Our apartment's bathroom frequently doesn't have hot water. Hot water comes fine in the kitchen sink but it's not the case for our shower and bathroom sink.  Can you please look into this? You can contact me or my roommates if you need any more d
H-52726	6/8/2015	6/8/2015	6/23/2015	Air Conditioning broken authenticated user: Dazsanique Davis - fp0309 requester ip address: 141.217.23.225
FO-319146	6/8/2015	6/11/2015		Exam Room 3 & 6 have water leaking from cooling system
H-52747	6/8/2015	6/19/2015	6/25/2015	Power out by vending machines.
H-52748	6/8/2015			Lights flickering in WDET
H-52749	6/8/2015	6/9/2015	6/23/2015	air conditioner is not working properly. authenticated user: Thomas Wolf - fj0736 requester ip address: 35.16.193.42
H-52762	6/9/2015	6/19/2015	6/25/2015	No electricity in hall and two bedrooms. Power suddenly stopped tonight. authenticated user: Sai Bindu - fn8337 requester ip address: 35.16.198.188
H-52763	6/9/2015			Request for temporary resident:Access ID: CONF04699It is related with Bathroom.The shower is not working because pull up/down pin of shower is broken.Water is coming from tap only.authenticated user: Tejaskumar Patil - fq4478requester ip address: 14
H-52777	6/9/2015			The pipe under the sink is leaking.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-52780	6/9/2015			Issue with Toilet, continuously runs.authenticated user: Samantha Mannino - ez5465requester ip address: 141.217.23.240
H-52775	6/9/2015	6/11/2015	6/23/2015	No hot water authenticated user: Brook Higgins - ft3268 requester ip address: 35.16.197.224
H-52766	6/10/2015	6/12/2015	6/24/2015	Toilet in bathroom farther from door won't stop running. Clogs when used. authenticated user: Alexis Nowicki - fy8432 requester ip address: 35.16.195.45
H-52759	6/10/2015	6/20/2015	6/25/2015	Faucet linking since last Friday. Can it please be fixed as soon as possible. authenticated user: JaNel Stephens-Dantzler - eo2346 requester ip address: 141.217.23.225

WO	Recieved	Finished	Total	Request
H-52765	6/10/2015			441 VENT COVER IS COMPLETELY APART AND IT NEEDS TO BE PUT BACK authenticated user: Joanna Berry - fa3511 requester ip address: 141.217.23.225
H-52761	6/10/2015	6/22/2015	6/25/2015	203 WALL FIXTURE IS NOT WORKING MAINTENANCE CHANGED BULB authenticated user: Joanna Berry - fa3511 requester ip address: 141.217.23.225
H-52774	6/10/2015	6/22/2015	6/25/2015	Light out next to elevator in front of bulletin board. 6th floor
H-52793	6/10/2015	6/12/2015	6/23/2015	Resident says: the vent for the small bedroom is not functioning well and doesn't push cold air into her room. authenticated user: - requester ip address: 141.217.23.210
H-52789	6/10/2015	6/16/2015	6/24/2015	Air conditioning is working. authenticated user: Sukumar Hirani - fo5246 requester ip address: 35.16.78.224
H-52787	6/10/2015	6/16/2015	6/24/2015	Air conditioning is either defective or not working.Cooling is very ineffective. authenticated user: Dinesh Subramanian - fq6895 requester ip address: 141.217.220.171
H-52792	6/11/2015	6/18/2015	6/25/2015	Air conditioning is not working properly. No cool air. Kindly fix the problem at your earliest. authenticated user: Rishad Bhoir - fc6807 requester ip address: 35.16.78.84
H-52784	6/11/2015	6/17/2015	6/24/2015	The A/C unit in room 505 is non-functional. authenticated user: Tevin Monroe - fh3994 requester ip address: 141.217.23.186
H-52786	6/11/2015	6/15/2015	6/24/2015	Air conditioner is not working in the apartment. Please fix it as soon as possible. authenticated user: Gowtami Datla - fg8188 requester ip address: 35.16.65.16
H-52788	6/11/2015	6/16/2015	6/24/2015	Air conditioning has not been blowing air since yesterday (6/10/2015). I noticed on the night of 6/9/2015 that it was very stuffy and that warm air had been blowing out. Yesterday night and this morning, I noticed that there was no air blowing out at all,
H-52807	6/12/2015	6/17/2015	6/24/2015	AC broken in room authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.224.76
H-52808	6/12/2015	6/15/2015	6/23/2015	Air not working and making sound every few min. authenticated user: Zoha Zaidi - fn9925 requester ip address: 35.16.196.236
H-52810	6/12/2015	6/15/2015	6/23/2015	A/C and heat in room goes in and out. Sometimes it comes on and sometimes it does not work! authenticated user: Joanna Berry - fa3511 requester ip address: 141.217.23.225
H-52854	6/12/2015	6/19/2015	6/25/2015	The Air conditioning is not working. The meter says it is on however there is no cold air blowing. authenticated user: John Schmidt - fz0418 requester ip address: 141.217.83.130
H-52827	6/12/2015	6/17/2015	6/24/2015	Water will not stop running in bathroom. authenticated user: Keontae Ware - fg9660 requester ip address: 141.217.23.210
H-52828	6/12/2015	6/17/2015	6/24/2015	no water at all authenticated user: Keontae Ware - fg9660 requester ip address: 141.217.23.210
H-52829	6/12/2015	6/17/2015	6/24/2015	The sink in my kitchen does not work very well; water does not flow down smoothly. authenticated user: Takahiko Kudo - fh9892 requester ip address: 141.217.83.189
H-52832	6/12/2015	6/17/2015	6/24/2015	Mechanical check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52835	6/12/2015	6/17/2015	6/24/2015	Mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52838	6/12/2015	6/17/2015	6/24/2015	Mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52839	6/12/2015	6/17/2015	6/24/2015	Mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
H-52844	6/12/2015	6/17/2015	6/24/2015	Mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52847	6/12/2015	6/17/2015	6/24/2015	mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52848	6/12/2015	6/17/2015	6/24/2015	mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52853	6/12/2015	6/17/2015	6/24/2015	mechanical Check authenticated user: Lofti Kerzabi - fo8196 requester ip address: 141.217.23.210
H-52824	6/12/2015			mechanical Checkauthenticated user: Lofti Kerzabi - fo8196requester ip address: 141.217.23.210
H-52855	6/12/2015	6/23/2015	6/23/2015	Air not working and making sound every few min. authenticated user: - requester ip address: 35.16.103.131
H-52858	6/13/2015	6/15/2015	6/23/2015	A/C is broken and is not getting cold.  Electric plug is not working in the restroom authenticated user: William Alexander - ew0056 requester ip address: 141.217.23.191
H-52896	6/14/2015			the shower in the first bathroom near the entrance is broken. needs fixing.authenticated user: Ujaas Bagati - fo6922requester ip address: 35.16.194.249
H-52862	6/15/2015			Air condition is not working authenticated user: Cordaro Smith - eh9947requester ip address: 35.16.193.42
H-52901	6/15/2015			AC is broken: No cool blow coming out.authenticated user: Rong Liu - fd2578requester ip address: 35.16.199.172
H-52897	6/15/2015			Ever since the maintenance done last week around June 8 when the air conditioner was shut off for several hours, the AC unit in our apt first was putting out warm air the next two days, then stopped putting out any air at all since June 10, even though it
H-52932	6/15/2015	6/19/2015	6/25/2015	Air conditioning i not working. authenticated user: Cordaro Smith - eh9947 requester ip address: 141.217.230.145
H-52899	6/15/2015			Cool Air Conditioner does not work.authenticated user: Jiaxing Tan - fr1589requester ip address: 141.217.221.190
H-52903	6/16/2015	6/18/2015	6/24/2015	Water leaking in kitchen ceiling authenticated user: Yazhong Lu - fb7350 requester ip address: 141.217.233.16
H-52907	6/16/2015	6/17/2015	6/24/2015	Mechanical check authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52908	6/16/2015	6/17/2015	6/24/2015	Mechanical check authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52915	6/16/2015	6/24/2015	6/25/2015	Mechanical check authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52909	6/16/2015	6/17/2015	6/24/2015	Mechanical check authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52919	6/16/2015	6/17/2015	6/24/2015	There is an electrical issue with the room. Resident described the lights going out and staying off for varying times, and then coming back on. When the lights go out, the outlets do not work as well. This happens regularly, multiple times a day, or lasts
H-52921	6/16/2015	6/17/2015	6/24/2015	The toilet continues to run. Angelica played with the handle when doing the move-out. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-52923	6/16/2015			Please repair the garbage disposal in this apartment.
FO-320010	6/16/2015	6/18/2015		Air conditioning unit is not working properly inside transmitter building. It is becoming too hot for the equipment. *Priority*



WO	Recieved	Finished	Total	Request
H-52924	6/16/2015	6/17/2015	6/24/2015	The kitchen sink crusher is not working. Please send someone to fix it as soon as possible. Thank you for your time! authenticated user: Ruta Jog - fj1102 requester ip address: 35.16.65.253
H-52931	6/17/2015	6/19/2015	6/25/2015	Air in room is not working experiencing thermostat issues! authenticated user: Brianna Elum - ei6112 requester ip address: 141.217.23.191
H-52928	6/17/2015			Bathroom exhaust not working.authenticated user: Tanmay Dhopade - ft7728requester ip address: 35.16.194.242
H-52930	6/17/2015	6/19/2015	6/25/2015	Air Conditioner is not working for some reason. authenticated user: Manpreet Unavailable - fo7240 requester ip address: 35.16.195.33
H-52937	6/17/2015	6/19/2015	6/25/2015	AC in apartments on the 9th floor is not working. Complaints from 930, 918, 916.
H-52976	6/17/2015			A/C not working.
H-52954	6/18/2015			kitchen sink disposer is broken and leaks water.authenticated user: Nariman Ammar - eg3167requester ip address: 35.16.197.93
H-52955	6/18/2015			Washroom leak since morning authenticated user: Abhijeet Kale - fr0112requester ip address: 141.217.59.50
FO-320117	6/18/2015	6/19/2015		CONTRACTORS NEED ACCESS TO ROOF. PLEASE CALL FRONT DESK.
H-52966	6/18/2015			In my Second bath room shower, when i put the knob on cold side i am still getting extreme hot water, if i do further then the water is shut. please fix this problem. authenticated user: Santhosh Gunda - fc0339requester ip address: 136.2.1.105
H-52959	6/18/2015	6/19/2015	6/25/2015	The air conditioning is not working. authenticated user: Bianca Dean - fo1867 requester ip address: 141.217.23.186
H-52968	6/19/2015			RUSH, RUSH, RUSHIt is an emergency situation, the garbage disposal doesn't work, we cannot wash the dishes. Please fix it as soon as possible, thanks. authenticated user: Nafiseh Saberian - fj7048requester ip address: 141.217.220.203
H-52960	6/19/2015	6/19/2015	6/25/2015	Towers 338 AC is not working.
H-52970	6/19/2015			Lights flickering in WDET
H-52983	6/20/2015	6/23/2015	6/25/2015	The faucet in the bathroom has been leaking for over a week. authenticated user: Megan Landskroener - er9935 requester ip address: 141.217.23.225
H-52972	6/21/2015			Air conditioner is broken in room. Cool air will not come out. Please come and fix, I would really appreciate it as I overheat at night and can't sleep!authenticated user: Mahpara Khan - fh3271requester ip address: 141.217.224.157
H-52984	6/22/2015	6/23/2015	6/25/2015	Air Conditioner is not working. authenticated user: Jasmyynn Brown - fk4951 requester ip address: 141.217.23.225
H-53000	6/22/2015			get a glass door fixed and three outlets in the kitchen that need to be fixed.authenticated user: Dharmaja Hemamber Koka - ft6419requester ip address: 141.217.23.186
H-53004	6/22/2015			Bathroom (the one closer to the entrance) toilet lever gets stuck midwayauthenticated user: Donghan Sohn - fg1224requester ip address: 35.16.196.44
H-52999	6/22/2015			The light is out next to room 203.authenticated user: Jayla Jackson - fo6904requester ip address: 141.217.203.131
H-52998	6/22/2015			The light is out next to room 263.authenticated user: Jayla Jackson - fo6904requester ip address: 141.217.203.131
H-52995	6/23/2015	6/23/2015	6/25/2015	Hi, I am Karine Montenegro Costa, and I am contacting housing because I am needing a repair in my Thermostat, because it is broken, my building is Atchison hall, room 549.  authenticated user: Karine Montenegro Costa - fz0190 requester ip address: 35.1
H-52996	6/23/2015	6/23/2015	6/25/2015	The air conditioning doesn't work in the lounge. authenticated user: Faith Basheer - fp3620 requester ip address: 35.16.197.107
H-52997	6/23/2015			The air conditioning system does not work in the lounge.authenticated user: Faith Basheer - fp3620requester ip address: 35.16.197.107
H-53012	6/23/2015	6/24/2015	6/25/2015	The bathroom sink appears to be leaking from the hot water inlet. authenticated user: David Johnson - fn9187 requester ip address: 141.217.232.230

WO	Recieved	Finished	Total	Request
H-53020	6/23/2015			Something is wrong with my toilet. The tank portion keeps running out of water and it makes this loud ongoing sound. authenticated user: Dreana Williams - fi2266requester ip address: 146.9.23.140
H-53021	6/24/2015			Came back to apartment after 1.5 months and found toilet not working properly and leaking from the back and not flushing properlyauthenticated user: Syeda Hasan - fm9278requester ip address: 35.16.74.231
H-53022	6/24/2015			Subway - faucet leaking in men's restroom.
H-53025	6/24/2015			The vent to the small bedroom is not pushing enough cold air through to cool the room. Please adjust vents.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53026	6/24/2015			There is a notification for 1005 on the fire panel behind the desk that will not clear. "System Reset" does not remove the notification so the alarm sounds every so often for room 1005.authenticated user: Ashley Fry - ej8471requester ip address: 141.217
H-53039	6/25/2015			The exhaust fan in the bathroom (the bathroom at the far end of the hallway with the tub in it) is making loud noises, and it never used to before. I don't think it's working properly anymore.authenticated user: Juhi Kushwaha - fk4773requester ip address
H-53045	6/25/2015			The Air Conditioning system for the whole apartment is not working.authenticated user: Jigeet Desai - ex7685requester ip address: 141.217.220.232
H-53051	6/26/2015			Last night my air went out so I called an engineer. They came and looked at it and then went to the roof to look at the actual air system. They came back and told me that something had broke on it, but that they were able to fix it and that it actually af
H-53068	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53069	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53070	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53071	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53072	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53073	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53074	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53075	6/26/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53078	6/26/2015			Garbage Disposal in the kitchen doesn't work.authenticated user: Xiaoce Feng - ex6818requester ip address: 141.217.203.131
H-53093	6/27/2015			my kitchen ceiling is leaking above the refrigerator. authenticated user: Taylor Wilkerson - fa2205requester ip address: 35.16.70.249
H-53082	6/28/2015			My a/c keeps flashing the red service light. Also, sometimes I will have it set for 70 degrees, but my room temp will be higher than that and the a/c will still not turn on. I have reset it multiple times with little success. Can someone please come look
H-53096	6/29/2015			Power not working by vending machines in lobby.
H-53101	6/29/2015			My shower head has been leaking for the past couple weeks and has gotten worse sense. There is also water dripping from the ceiling and I'm not sure if it's from the constant water flow in the bath room or from something else. authenticated user: Marcus
H-53111	6/29/2015			fan motor is making room smell like smoke. Needs fixing authenticated user: Anthony Eid - eh2083requester ip address: 35.16.195.29
<b>E - Command Center</b>			<b>32</b>	
FO-318375	6/1/2015			Control Engineer; High R/R RM 7406 Please repair heat pump #102-071-HWP-060 located on the seventh floor. The unit is not running.
FO-318376	6/1/2015	6/8/2015		Control Engineer; High R/R 6304 Please repair heat pump #81-071-HWP-039. The unit is going out on the lock out relay, continuously.

WO	Recieved	Finished	Total	Request
FO-318833	6/2/2015			BAS, High, R/R RM 2145 Please adjust stat in room 2145, no stat cover and stat has been adjusted out of calibration, no literature for stat on site. Jeff davis ENG'S NOTES:Checked room, no stat cover and someone turned stat down controlling RTU, placed
FO-318916	6/3/2015	6/8/2015		Trade: Command Center Priority: High Follow up to FO 318312 R/R Room 160 fume hood 6 did not pass re-inspection for air flow. Please repair.
FO-318917	6/3/2015	6/8/2015		Trade: Command Center Priority: High R/R Room 160 fume hood 3 did not pass re-inspection for air flow. Please repair.
FO-319020	6/4/2015			COMMAND CTR/HONEYWELL R/R PENTHOUSE have `Honeywell, Rich Moon,replace bad chill water valve on AC-8, valve wont open or close automatically,only open manually. priority,High
FO-319099	6/5/2015			HONEYWELL/CONTROLS R/R RM 9309/MECH-PIPECHASE VAV BOX 9062 AIR FLOW DAMPER WILL NOT MODULATE TO LOAD. CHECK/REPROGRAM THE VAV CONTROLLER 6/5/15 lps: Per Bldg Eng Orlandis M eq is off of eq #AHU 11
FO-319113	6/5/2015	6/10/2015		trade siemens controls priority high R/R RM 1674 please service room 1674 its over heating room temp 79degrees check tec coil is hot could be leaking through
FO-319205	6/8/2015	6/18/2015		Please Order the following replacement Parts/Supplies:  Siemens Part # 192-208: Reverse Acting Thermostat Qty: 3  Siemens Part # 192-202: Direct Acting Thermostat Qty: 3 Siemens Part # 192-252: TX19 Thermostat Cover Qty: 2
FO-319417	6/11/2015			R/R BLDG write a tec setback program for the units in field panel 80
FO-319418	6/11/2015			Repair float check on Boiler # 3.
FO-319422	6/11/2015	6/19/2015		Pneumatic Supplies for Campus Use
FO-319504	6/12/2015			Control Engineer; High R/R TM 7206 Please repair heat pump #1-96-071-HWP-054. The unit has a bad Blower/Motor Bearing, making alot of noise. The heat pump has been shut down.
FO-311070	6/13/2015	6/16/2015		Trade: Command Center R/R PENTHOUSE Priority: Medium Please repair vane damper motor for supply fan 2 on AHU #2.
FO-319534	6/14/2015			Alter graphics programming on Insight to show the fan schedule and fan overview at Education building. Please include the current day in the fan schedule.
FO-319574	6/15/2015	6/25/2015		Control Engineer; High Please check the refrigerant pressures in the system of heat pump #1-51-071-HWP-009. The compressor keeps going out on the lock out relay. The area space is very warm.
FO-319908	6/16/2015			To refrigeration crew. The outside air temperature sensor for Alumni has been reading - 39.42F for several days. This is causing problems with the economizer functions on SF-2 and SF-13. Please repair or replace.
FO-320024	6/17/2015	6/18/2015		HVAC Refrigeration Shop Supplies:  Parts Request: Unistrut Tees Grainger part # P-1031
FO-320094	6/18/2015			Provide & Install Replacement Carrier Unit  Carrier Model 50PCH030BCC6ACC1 (Right Return, Rear Discharge)  Original new unit warranty limited/ voided.  Currently replacing unit.  Reference FO-305323 & FO-311941 for details  Unit installed 5-6-

WO	Recieved	Finished	Total	Request
FO-320101	6/18/2015			PARTS ORDER - BAS Supplies:  Siemens Part # QAM1035.008P50 - Duct Temperature Sensor - 100k Ohm Thermistor (50 Pack) Qty: 1Pk
FO-320134	6/18/2015	6/19/2015		Refr. Crew/Siemens: R/R RM 332 VAV box CCIS For the corridor is showing "0" cfm's with the damper and positioner showing 100% open and the area temperature is 75 degrees. I believe damper drive is bad. VAV box is located just inside of room 332. Plea
FO-320281	6/22/2015			AC shop: R/R BLDG Please clean condenser and evaporator coils of all window AC units in the building. Priority: med.
FO-320295	6/22/2015	6/25/2015		REFRIG CREW R/R ELEC SHOP please r/r FRIEDRICH window air in Electrical Shop at UNIVERSITY SERVICES. Blower runs. Compressor runs. filter is clean. Appears to be short on charge. Discharge air did not drop below 74 degrees. unit uses R410A.
FO-320497	6/24/2015			BAS/Siemens Techs: Please troubleshoot field panel 4 failures. Need access to mechanical spaces.
FO-320520	6/25/2015			CONTROLS (LLOYD)- please assist engineer with diagnosing problem with CWV response AHU1 at Mort Sci. CHW always at 0% (in auto), but is cooling. Doesn't appear to respond to higher discharge SP.
FO-320527	6/25/2015			Please replace Heat Pump 2-139. Unit is down. Suggested replacement unit; Carrier, Model #50PCV030BCC6ACC1 480v 3ph. Right Return Top Discharge. (this unit is vertical)
FO-320557	6/25/2015			Please replace Loading dock heat Pump. Unit is down. Suggested replacement unit (Larger size; Carrier, Model #50PVC042RCCEACC1 208/230 3ph.  Left Return Top Discharge.  Also, Replacement unit will require sheet metal & piping rework.
FO-320595	6/26/2015	6/26/2015		BAS section: Please wire new heating valve, ahu 5.
FO-320653	6/26/2015			Refrigeration Supplies for Campus Use
FO-320671	6/29/2015			CONTROLS/SIEMENS R/R RM 3237 Repair or replace faulty humidity sensor for the Elliman Research building.
FO-320696	6/29/2015			BAS Section: R/R RM 00128/CLASS RM Please replace VAV box damper motor. Motor is not responding.
FO-320697	6/29/2015			BAS Section: R/R Lab 3556: Please troubleshoot lab exhaust flow issues/ replace damper motor.
<b>E - MedPharm</b>			<b>21</b>	
FO-318778	6/2/2015	6/4/2015		AIKENS' CONST CO NEED ACCESS TO ROOF
FO-318881	6/3/2015	6/4/2015		PLEASE CALL BOB GAGNIER AT 7-1461.
FO-318979	6/4/2015	6/4/2015		Need the air filters changed in room 124 Lande. Black soot affecting experiments.
FO-318980	6/4/2015	6/4/2015		Need the air filters changed in room 132 Lande. Black soot affecting experiments.
FO-319049	6/5/2015			Check and correct operation of mixing air boxes - 9th floor.
FO-319051	6/5/2015			Check and correct operation of mixing air boxes - 8th floor.
FO-319052	6/5/2015			Check and correct operation of mixing air boxes - 7th floor.
FO-319053	6/5/2015			Check and correct operation of mixing air boxes - 6th floor.
FO-319054	6/5/2015			Check and correct operation of mixing air boxes - 5th floor.
FO-319055	6/5/2015			Check and correct operation of mixing air boxes - 4th floor.
FO-319270	6/9/2015	6/9/2015		room starting to get warm
FO-319274	6/9/2015	6/9/2015		Rooms 228-234 baffles in duct need to be opened manually due to increasing temperatures in rooms due to warm weather outside.
FO-319414	6/11/2015			R/R RM 227 Please change the filter of air conditioner in Room 227
FO-319415	6/11/2015			R/R RM 229 Please change the filter of air conditioner in Room 229.
FO-319416	6/11/2015	6/11/2015		R/R RM 227 Please lower ~2°C of Room 227, thanks.
FO-319507	6/12/2015	6/24/2015		RM 1374 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-319909	6/16/2015	6/25/2015		open the cold air a little bit in 231 Lande. please contact Dr. Hu in 212 or 252.1 when you come. Thank you!
FO-320181	6/19/2015	6/24/2015		Room 8344 - Chemical Fume hood in room is not working - no flow. Please fix ASAP as it is affecting the researcher's ability to do experiments.
FO-320211	6/19/2015	6/19/2015		POLYFILLER IS FULL. ROOM AF4.
FO-320347	6/23/2015	6/24/2015		ceiling filter needs to be changed
FO-320565	6/25/2015			Replace ceiling air supply diffuser in room 200.08 with one provided by Ops. AD.
<b>E - North</b>			<b>3</b>	
FO-319111	6/5/2015	6/5/2015		need fuses FNQ-R-5
FO-319291	6/9/2015			Please have the air turned on in office room #136. Thank You
FO-320749	6/29/2015	6/30/2015		Water is running along the wall outside of the Kresge Entrance
<b>E - Northeast</b>			<b>2</b>	
FO-319104	6/5/2015	6/5/2015		Two hanging quad power receptacles closest to the west wall are not working.
FO-320124	6/18/2015			Please repair thermostat in Northwest corner of room. There is a loud screech coming from it randomly. (near cubicle #41)
<b>E - Preventative Maintenance</b>			<b>17</b>	
FO-318435	6/1/2015	6/4/2015		Replace RF Belt CX195 Qty: 4
FO-318436	6/1/2015	6/5/2015		Replace EF Belt 4L210 Qty: 2
FO-318437	6/1/2015	6/9/2015		Replace Boiler Rm Belts Qty: 4  4L190 (A17)  Ordered additional belts on 6-5-15:  4L210 Qty: 2 4L230 Qty: 2
FO-318453	6/1/2015	6/2/2015		Kresge Library, 1st Floor North east corner, open study area Water leaking from ceiling. Wet ceiling tile nearby. Looks like water is running along ceiling.  Please see Richard at the Check Out desk if additional information is needed.  Thank you.
FO-319024	6/4/2015	6/5/2015		Lights out in office area. High priority due to no lights at all in space.
FO-319388	6/10/2015			PLEASE CALL JASON AT 7-2400 REGARDING GHAFARI HALL.
FO-319533	6/12/2015	6/12/2015		KUMASH SAYS DARNEL SMILEY ASK HIM TO CK OUT FREIGHT ELEV STUCK ON 6TH FLR
FO-319878	6/15/2015			Filter Order - Matthaei  OA Intakes
FO-319995	6/16/2015	6/16/2015		Had issues for 3 years-condenser on air conditioner makes load noise (every time engineer came, it didn't make the noise so it never was fixed) It comes on approx. every 1/2 hour and makes a loud noise until it shuts off for the next cycle.
FO-320137	6/18/2015	6/18/2015		Admissions office is complaining about the temperature, states the thermostat reads 67 degrees, which is too cold.
FO-320138	6/18/2015	6/18/2015		Room 8344 - Chemical Fume hood in room is not working - no flow. Please fix ASAP as it is affecting the researcher's ability to do experiments.
FO-320135	6/18/2015	6/22/2015		Part Request:  Grainger Item: 1WJT1 Water Key 4-W Qty: 4

WO	Recieved	Finished	Total	Request
FO-320145	6/18/2015			The Fume Hood in the lab has low air flow and is alarming. The Variable airflow regulator on the duct is constantly operating and making unusual noises.
FO-320148	6/18/2015	6/18/2015		Inside lab 3250 is a smaller room; the sink in there has pipes under it that are leaking.
FO-320200	6/19/2015	6/26/2015		Trade: Preventive Maintenance Priority: High Tag#090-EXF-035 R/R LAB WING Please replace fan belt on Exhaust Fan #35, it is barely hanging on. It is located on the N.E. corner of the lab wing roof. 6/19/15 lps: Per Mark B (PM)
FO-320202	6/19/2015	6/26/2015		trade afternoon pm crew R/R RM 6149/MECH RM please replace broken fan belt on ahu #3 exhaust fan broken belt is located in office priority medium
FO-320660	6/26/2015	6/26/2015		Chemical hood/fume vent not working.
<b>E - South</b>			<b>8</b>	
FO-318790	6/2/2015	6/2/2015		Multiple roof leaks into lab. Carpet in attached office is also wet.
FO-318832	6/2/2015	6/4/2015		There is a problem with the drain line in the nFab nitrogen generator compressor. The drain line for the compressor was routed through a penthouse wall drain onto the roof. This line will freeze during the winter months. The drain line needs to be eith
FO-318885	6/3/2015	6/3/2015		Air conditioning unit is making noise when it comes on.
FO-320186	6/19/2015	6/19/2015		RM 2074 IS TOO COLD ALSO AIR IS BLWNG VERY HARD
FO-320552	6/25/2015			Trade: Command Center Priority: High R/R RM 00000.62/MECH-BLR RM Please supply flexible gasket located between the burner and the boiler.
FO-320560	6/25/2015			RM 2529 IS TOO HOT NO AIR FLOW
FO-320567	6/25/2015			Strong Sewer gas smell in stairwell 0 ( west stairwell)and also in basement of building.
FO-320625	6/26/2015			Chemical hood/fume vent not working.
<b>E - Southeast</b>			<b>6</b>	
FO-319056	6/5/2015			no air coming out of heating/cooling mechanism, blower not working at all
FO-319269	6/9/2015	6/11/2015		No vacuum in biosafety cabinets in lab 2125.1
FO-320248	6/22/2015			Had issues for 3 years-condenser on air conditioner makes load noise (every time engineer came, it didn't make the noise so it never was fixed) It comes on approx. every 1/2 hour and makes a loud noise until it shuts off for the next cycle. (SEE RESULT
FO-320262	6/22/2015	6/22/2015		No air circulation for the past couple of days. Must reset HVAC system.
FO-320270	6/22/2015	6/22/2015		Lab 4116 is to hot.
FO-320371	6/23/2015			There are two A/C units. One is not working. Please check and repair.
<b>E - West</b>			<b>9</b>	
FO-319012	6/4/2015	6/5/2015		The power on the west wall is no longer working.
FO-319297	6/9/2015	6/19/2015		Process chill water for the building is hot and unable to cool experimental equipment. Please repair.
FO-319435	6/11/2015	6/12/2015		Remove condensate pump # 1 replace seal
FO-319506	6/12/2015	6/15/2015		Replace bearing AHU Purchase part 5YLK4 and 5YKF0 from Grainger
FO-319555	6/15/2015	6/16/2015		Inspect HVAC unit serving Mid-City Grill. Tenant complains of loud air flow noise, too cold.
FO-319944	6/16/2015	6/16/2015		PLS IDENTIFY DOOR # TO NW MAIN ENTRY HANDICAP DOOR
FO-319947	6/16/2015	6/16/2015		2ND FLR CONTROL PANEL IS DISPLAYING COOLFAIL
FO-320114	6/18/2015	6/19/2015		ENTIRE BLDG IS TOO HOT
FO-320710	6/29/2015			R/R RM 201/MECH RM Replace fan, outer fan bearing Fafnir ( RCJ 1 ,7/8) need to order two.

**Grounds** **3**

**Low** **3**

**G - Moving/Storage** **2**

WO	Recieved	Finished	Total	Request
FO-319528	6/3/2015			I would like to request the transfer of the following items from Property Surplus Warehouse to 3315 Deans Office.  Tag# Law01 Round table Tag# Law02 2 tall chairs (1 Brown and 1 black/gray) Tag# P Brown Couch Tag# Law03 Coffee table Tag# Law04
FO-320361	6/9/2015	6/29/2015		Go to property and pick up 12 wood chairs, 2 round oak tables and 1 square oak table labeled Fine Arts and move to room 2314 Old Main. Please contact Lee Dyament when moving to gain access to room 7-2614. Myron Harper 06/15/2015 09:09 -Estimate in the am
<b>G - Physical Grounds</b>			<b>1</b>	
FO-320608	6/26/2015	6/29/2015		Grounds: remove invasive vines from Cass side main entrance steps to prevent damage to the railing. Remove back to the root to prevent from further damage to stairs and railing.
<b>Trades</b>			<b>810</b>	
<b>Emergency</b>			<b>52</b>	
<b>T - Carpenter</b>			<b>17</b>	
FO-319097	6/5/2015	6/8/2015		CARP: R/R RM 410 please tr0ubleshoot cage-washer door switch (PUSH BUTTON),door will not close automatically.FO-319004,priority high.
FO-319129	6/8/2015	6/8/2015		KEY BROKEN OFF IN DOOR LOCK. 5TH FLOOR JANITOR'S CLOSET. ROOM 5104.
FO-319135	6/8/2015	6/8/2015		DOOR WON'T OPEN. PROBLEM WITH DOOR LOCK. SOMEONE STUCK INSIDE ROOM. ROOM 0231.
FO-319549	6/15/2015	6/15/2015		DOOR OF HINGES. 1ST FLOOR ENTRANCE.
FO-319551	6/15/2015	6/15/2015		FRONT ENTRANCE DOOR OFF THE HENGES
FO-320009	6/17/2015	6/17/2015		Trade: Carpenter Priority: High Door 17S has broken door closer.
FO-320185	6/18/2015	6/19/2015		Carpenter secure broken hook for safety chain on gas bottles on loading dock.
FO-320180	6/19/2015	6/19/2015		EMERGENCY CARP R/R STE 4200 INSIDE STE PRESIDENT'S OFC THE PORTABLE ACU NEEDS TO BE ADJUSTED SO IT WILL STAY MOUNTED IN WINDOW
FO-320246	6/20/2015	6/23/2015		R/R ENT DOOR #130 06N. ADJUST DOOR CLOSURE & REPAIR LOCKING MECHANISM FOR FIRST Floor Door 6N, North Ext Door does not secure, causing door to remain unsecure. Scrapes on threshold and frame.
FO-320282	6/22/2015	6/22/2015		DOOR WILL NOT UNLOCK. 1ST FLOOR ROUNDED STAIRWELL DOOR OFF LOBBY.
FO-320284	6/22/2015	6/22/2015		KEY STUCK IN DOOR LOCK. ROOM 4320. (KEY BELONGS TO EKTA)
FO-320485	6/24/2015	6/24/2015		BOLER RM DOOR# B3E, UNABLE TO SECURE DOOR
FO-320534	6/25/2015	6/25/2015		KEY STUCK IN DOOR LOCK. NORTH EXTERIOR DOOR. ATT: CLEON CLEAVER.
FO-320541	6/25/2015	6/25/2015		EMERGENCY CARP R/R RM 15001.2 COMMAND CONTROL RM (ENGINEERS') CANNOT UNLOCK DOOR LOCK KEEPS TURNING
FO-320575	6/25/2015	6/25/2015		WEST SIDE OF BLDG ENTRANCE DOOR FOR ABOVE PARKING (GARAGE) LOT THAT HAS A COVER OVER IT DOOR IS MISSING ALL THE LOCKING MECHANISM
FO-320606	6/26/2015	6/26/2015		HANDICAP DOOR WILL NOT CLOSE.
FO-320651	6/26/2015	6/26/2015		CARP R/R LOADING DOCK AREA THE LIFT IS STUCK IN AN UPRIGHT POSITION
<b>T - Electrician</b>			<b>17</b>	
FO-318801	6/2/2015			ACTIVE FIRE ALARM, ALARM PANEL WON'T RESET ENG NEEDS ELEC TO TROUBLESHOOT
FO-319424	6/11/2015	6/11/2015		BLOWN CIRCUIT. (CAN'T LOCATE CIRCUIT)BASEMENT POOL MECHANICAL ROOM.
FO-319450	6/11/2015	6/11/2015		BYPASS FIRE ALARM SYSTEM.
Completed 6-11-2015 SRP				

WO	Recieved	Finished	Total	Request
FO-319541	6/15/2015	6/15/2015		AIR COMPRESSOR #3 BLOWN FUSES. ROOM 100.
FO-319542	6/15/2015	6/15/2015		R.O. SYSTEM NEED FUSE. PENTHOUSE. CONTACT ENGINEER FOR DETAILS.
FO-320014	6/17/2015	6/17/2015		EMERGENCY ELEC R/R 1ST FLR (NEAR WARREN ENT)FAP FIRE ALARM WILL NOT RESET PANEL INDICATE LOOP #2 IS OPEN  Completed 6-17-2015 SRP
FO-320019	6/17/2015	6/17/2015		NATIONAL TIME FIRE PANEL IN TROUBLE, WILL NOT RESET.  Completed 6-17-2015 SRP
FO-320119	6/18/2015			Meet Elevator mechanics in room 243 to kill power to elevators so mechanics can work on them.
FO-320182	6/19/2015	6/19/2015		In the DLAR room 200.05 there is one fixture out. emergency, Mieee need the Lite!
FO-320222	6/19/2015	6/19/2015		LOST POWER IN SOUTH SIDE OF BUILDING.
FO-320227	6/19/2015	6/19/2015		LOST POWER IN BLDG
FO-320241	6/20/2015	6/20/2015		Repair lighting circuit serving the Gallery and Lobby of Community Arts Center. Event being held and lights are needed immediately.
FO-320256	6/22/2015			NO POWER IN AREA OF ROOM 4055.
FO-320352	6/23/2015	6/23/2015		FIRE ALARM STATION AT SECURITY DESK IS DOWN. ELEVATORS SMOKE CAPTURED.  Completed 6-23-2015 SRP
FO-320356	6/23/2015	6/23/2015		FIRE ALARM - CIRCUIT 13.  Completed 6-23-2015 SRP
FO-320498	6/24/2015	6/24/2015		AIR HANDLER #4 IS NOT RUNNING. PENTHOUSE.
FO-320609	6/26/2015			RM 5113 EXHAUST FAN #10 TROUBLESHOOT & REPAIR MOTOR PROBLEM, FAN WON'T START RM 5113 NO SUCTION ON FUME HOODS, STRONG ODOR WITHIN RM
<b>T - Pipefitter</b>			<b>2</b>	
FO-319244	6/9/2015	6/9/2015		CEILING LEAK. AUDITORIUM IN THE BALCONY ..... EA/6-9-15 .....
FO-320291	6/22/2015	6/23/2015		STEAM LINE BLOWING STEAM FROM STEAMER. ROOM 0346. CONTACT PETER BELCHER FOR MORE DETAILS. (MULTI-TASK) ..... EA/ 6-22-15 .....
<b>T - Plumber</b>			<b>16</b>	
FO-318393	6/1/2015	6/1/2015		SUMP PUMP NOT WORKING PROPERLY. MECHANICAL ROOM. CONTACT ENGINEER FOR MORE DETAILS..... GS/6-1-15 .....
FO-318442	6/1/2015	6/1/2015		PLUGGED TOILET. PRISONER LOCK-UP. .... DB/6-1-15 .....
FO-318919	6/3/2015	6/4/2015		R/R RM 1232 MENS RR ONE OF THE TOILETS IS PLUGGED & OVERFLOWING (Note: Custodian unable to unplug)..... MM/6-3-15 .....
FO-318983	6/4/2015	6/4/2015		1ST FL WATER FOUNTAIN NEAR WOMENS RM, FOUNTAIN LEAKING BADLY IN HALLWAY ..... MM/6-4-15 .....
FO-318985	6/4/2015	6/4/2015		Water is coming out of the mechanical closet (301.1). It is starting to flood the narrow hallway just outside the closet. See Engineer for details. .... MP/6-4-15 .....
FO-318985	6/4/2015	6/4/2015		Water is coming out of the mechanical closet (301.1). It is starting to flood the narrow hallway just outside the closet. See Engineer for details. .... MP/6-4-15 .....
FO-319182	6/8/2015	6/8/2015		FAUCET LEAKING ONTO FLOOR. 1ST FLOOR JANITOR'S CLOSET ..... DB/6-8-15 .....
FO-319964	6/16/2015	6/17/2015		AF32 SINK LEAKING FROM WALL ..... MM/6-16-15 .....
FO-319971	6/16/2015	6/16/2015		EMERGENCY PLUM R/R BSMT NEAR RM 522, WOMENS RR & LOCKER RM FLR DRAINS ARE BACKING UP..... MM/6-16-15 .....
FO-319978	6/16/2015	6/16/2015		**DUPLICATE WORK ORDER REFER TO FO#319971 JWT  R/R BSMT NEAR RM 522, WOMENS RR & LOCKER RM FLR DRAINS ARE BACKING UP
FO-320291	6/22/2015	6/23/2015		STEAM LINE BLOWING STEAM FROM STEAMER. ROOM 0346. CONTACT PETER BELCHER FOR MORE DETAILS. (MULTI-TASK) ..... EA/ 6-22-15 .....



WO	Recieved	Finished	Total	Request
FO-320310	6/22/2015	6/23/2015		EMERGENCY PLUM R/R BLDG DHWS STOPPED WORKING UNABLE TO START UP CAUSING NO HOT WATER BLDG ,,,,,,,,,, DB/6-22-15 ,,,,,,,,,,
FO-320310	6/22/2015	6/23/2015		EMERGENCY PLUM R/R BLDG DHWS STOPPED WORKING UNABLE TO START UP CAUSING NO HOT WATER BLDG ,,,,,,,,,, DB/6-22-15 ,,,,,,,,,,
FO-320396	6/23/2015	6/23/2015		SINK HAS PULLED AWAY FROM WALL. RESTROOM INSIDE OF 1ST FLOOR DISPATCH ROOM.,,,,,,,,,, DB/6-23-15 ,,,,,,,,,,
FO-320467	6/24/2015	6/24/2015		ANIMAL QUARTERS, REPLACE SHUT OFF VALVE TO CAGE WASHER,,,,,,,,,,,,, *DB/EA/6-24-15 ,,,,,,,,,,
FO-320578	6/25/2015	6/25/2015		Please clear attic drain line for AC ,,,,,,,,,, GS/6-25-15 ,,,,,,,,,,
<b>High</b>			<b>252</b>	
<b>T - Carpenter</b>			<b>61</b>	
FO-318372	6/1/2015	6/19/2015		MAIN ENTRANCE DOOR, INNER HANDICAP BUTTON NOT WORKING
FO-318373	6/1/2015	6/1/2015		MAIN ENTRANCE HANDICAP PUSH BUTTON NOT WORKING
FO-318395	6/1/2015	6/2/2015		DOOR #3 EAST IS NOT LOCKING AT NIGHT.
FO-318753	6/2/2015	6/3/2015		Carpenters: Handicapped door 039-1-S will not operate. Priority: High
FO-318912	6/3/2015	6/4/2015		LOADING DOCK DOOR NOT CLOSING
FO-318913	6/3/2015	6/4/2015		HANDICAP DOOR CANFIELD SIDE STAYS AJAR WHEN BUTTON PRESSED, SECURITY ISSUE
FO-318940	6/3/2015	6/5/2015		RM 209 PLANETARIUM (2) DOORS WITHIN SECURED AREA NEED LOCK REPAIRS PLEASE CONTACT JEFF 248-915-8260 TO GAIN ENTRY
FO-318950	6/4/2015	6/4/2015		CarpenterHigh priorityDoor 4N won't secured due to rubbing on the floor.
FO-318991	6/4/2015	6/5/2015		Build Scaffold in room 1535 for Electricians to repair light fixture, and remove it when their done.
FO-319042	6/5/2015	6/8/2015		CarpenterHigh priorityDoor no 3N Need door closer adjustment.Door gets open due draft.
FO-319061	6/5/2015	6/8/2015		STE 1600 ENTRANCE LEFT DOOR SLAMS
FO-319149	6/5/2015	6/8/2015		The Disability door opener at the entrance of the CAPS office area is not functioning. Please service urgently. Thanks 6/5/15 lps: Chng to Est for Main
FO-319150	6/5/2015	6/8/2015		The Disability door opener on the men's restroom on the third floor (toward the south just before the active construction area) is not functioning. Please service urgently. Thanks! 6/5/15 lps: Chng to Est for Main
FO-319192	6/8/2015	6/9/2015		Latch failure on bio room door. Doesn't work to prop door open.
FO-319201	6/8/2015			****TRIPPING HAZZARD**** Need to replace floor tiles-many tiles are broken/missing. Please estimate job
FO-319240	6/9/2015	6/9/2015		Outside door 5 - North the threshold is come lose and door willn't close .this is for the Carpentry Department.
FO-319241	6/9/2015	6/10/2015		The door latch for closet rm1520.01 doesn't latch correctly and can be easily pulled open without using a key or even turning the handle. Need the room secured as soon as possible as it's being used to stage tools and items for construction in the room as
FO-319262	6/9/2015	6/9/2015		DOOR LOCK PLATE IS LOOSE. DOOR HARD TO LOCK. BASEMENT ROOM 115.
FO-319268	6/9/2015	6/10/2015		EMERGENCY CARP R/R RM 1600 ENTRY DOOR TO STE ISN'T CLOSING *PLS NOTE PREVIOUS WO FO-319061/6-5-15 DOOR SLAMMING SHUT*
FO-319275	6/9/2015			R/R RM 4200.04 Two chairs will be delivered to the office on June 10, we would like to have someone stop by to assemble them.
FO-319310	6/9/2015			*ADDING CARPENTER: Needed ASAP Replace part of wall behind janitor sink in room 1234. Mold found in this area. See Mike Pummill for detail
				PLUMBERS, PLEASE REPAIR DRAIN LEAK @ SINK. ,,,,,,,,,, MP/5-15-15 ,,,,,,,,,,
FO-319338	6/10/2015	6/10/2015		DOOR WON'T LOCK. ROOM 237.

WO	Recieved	Finished	Total	Request
FO-319369	6/10/2015	6/12/2015		**ADDING PAINTERS: Paint ceiling at entrance of room 2322 where hole for access panel is to be installed . Paint in chiped and flaking falling on people when they enter room. See Rocky if needed
				ADDING CARP R/R HALLWAY OUTSIDE OF RM 2322 NEED CARPEN
FO-319370	6/10/2015	6/9/2015		WITHIN GARAGE: KEY STUCK IN GUN CABINET
FO-319401	6/10/2015	6/11/2015		The (West Side)Door latch to RM 3551 sticks such that the door can not always close and lock. Seems to be dependant on humidity levels.
FO-319503	6/12/2015	6/15/2015		**ADDING CARPENTER: Provide 2 pieces of wood 1"x 2 1/2"x 47" with a dozen drywall screws for protecting chill water coil during moving to location. See Jim Hill **NEEDED BY MONDAY MORNING 6-15-15
				Fitters, please repair leak in chill water coil on A
FO-319544	6/15/2015	6/16/2015		Carpenter; HighPlease repair handicapped door 071-02-N. The door will stay in the open position, unless powered down.
FO-319553	6/15/2015	6/16/2015		Purdy Library, 1st Floor - Main EntranceInterior Handicap door 026 01 S squeaking again. Same problem that recurs every couple of months.Most resent occurrence Work Order # FO-316961 completed 13 May 2015.
FO-320235	6/15/2015	6/22/2015		R/R BLDG Key box to gain entry to parking/building is working inconsistently. I and 2 others could not open the gate via the key box. May need to be (OKAY FOR MONDAY MORN) adjusted?  Thanks! 6/19/15 lps: Chng to IServ-Per Dorothy C says this shoul
FO-319584	6/15/2015	6/16/2015		HANDICAP DOOR BUTTON WORKS INTERMITTENTLY ALSO DOOR IS MAKING A SQUEAKING SOUND.
FO-319895	6/15/2015	6/26/2015		**ADDING CARPENTER: ASAP Remove ceiling tiles and erect scaffold in 1st floor men's bathroom 108 to access plumbing leak. **Also remove cinder block in 2ed floor men's bathroom to access drains for this repair. See Mike Pummill for direction
				WATER
FO-319907	6/16/2015	6/17/2015		CarpentersMain Entrance door 02 east door closer not working. BUILDING SECRTY ISSUEEMERGENCY HIGH PRIORITY
FO-319932	6/16/2015	6/18/2015		BSMNT RM 520 EXTERIOR DOOR UNABLE TO OPEN
FO-319934	6/16/2015	6/18/2015		BSMNT RM 523 UNABLE TO INSERT KEY IN LOCK
FO-319941	6/16/2015	6/18/2015		R/R RM 200.03 ENTRY DOOR LOCK VERY HARD TO TURN KEY
FO-319948	6/16/2015	6/17/2015		FRONT ENTRANCE DOOR INTERMENTALLY WON'T CLOSE PROPERLY. DOOR STAYS OPEN. I
FO-319955	6/16/2015	6/17/2015		R/R ENTRY HANDICAP DOOR #155 20W INSIDE/OUTSIDE BUTTONS WILL NOT OPEN DOOR
FO-320075	6/18/2015	6/19/2015		FRIDAY 7:30AM:  Remove Sky light closet to the Fan room on the roof so the Electricians can replace the motor in the fan room, and replace it when they get the new motor back on the roof.
FO-320167	6/19/2015	6/19/2015		Cut wooden blocks to make feet for the Electricians A Frame motor hoist.
FO-320184	6/19/2015			R/R RM 131/CLASS RM PROJECTION SCREEN WILL NOT STAY IN THE DOWN POSITION (@ the moment they are tying it down on furniture)
FO-320189	6/19/2015	6/22/2015		DOOR NOT CLOSING PROPERLY. ENTRANCE DOOR TO ROOM 1374.
FO-320217	6/19/2015	6/24/2015		Two ceiling tiles have fallen in the classroom and several tiles appear loose. Please replace tiles. If you need access to the room please contact me. Thank you.
FO-320229	6/19/2015	6/22/2015		North side of Prentis, the Fishbowl Door does not close properly. Door#022 16N
FO-320242	6/22/2015	6/22/2015		Repair outside entrance door 637-01-E at Karmanos. The door is sticking leaving the building unsecure.
FO-320325	6/22/2015	6/22/2015		Please repair the door to the Shipping and Receiving area, it will not close or lock.

WO	Recieved	Finished	Total	Request
FO-320351	6/23/2015	6/24/2015		<p>**ADDING CARPENTER: Please remove cabinet permanently in room 389. This needs to be done week of 6-22-15. See Gerry (Plumber) for detail</p> <p>PLUMBER PLEASE REPAIR SINK LEAK INSIDE WALL ROO 389 SEE ENGINEER MEDIUM PR,,,,,,,,,,,,, GS/4-2-15,,,,,,,,,,,,,</p>
FO-320355	6/23/2015	6/23/2015		In the basement room 0377 is jammed tight at the top of the door, and tenants can not get it to open. Please repair door to open freely.
FO-320363	6/23/2015	6/24/2015		WINDOW WON'T CLOSE. ROOM 2083.
FO-320384	6/23/2015	6/29/2015		Build some KV Shelving next to Electric shop door, and use the pipes as a border.
FO-320387	6/23/2015	6/24/2015		DOOR WON'T CLOSE PROPERLY CAUSING DOOR NOT TO LATCH OR LOCK. MAIN DOOR TO ROOM 354.
FO-320447	6/24/2015	6/25/2015		Trade: CarpenterHigh priorityDoor no. 2N T strike need replacement and also screw hold the T strike is stripped. Too many service calls for this door.
FO-320457	6/24/2015	6/25/2015		RM 200.08 METAL PIECE AT THE BOTTOM OF DOOR IS CAUSING THE DOOR TO STICK
FO-320494	6/24/2015			Loading dock door 603-14E doesn't latch after carding into building. Door has a continuous hinge and doesn't close flush.
FO-320499	6/24/2015			<p>**ADDING CARPENTER: Evaluate hours needed for Carpenters to support Plumbing repairs on 2ed floor mens bathroom. See Don Bear or John Towle for detail. **NEED ASAP</p> <p>WATER CEILING LEAK OVER URINAL. 1ST FLOOR MEN'S RESTROOM. ROOM 108.,,,,,,,,,,,,,,</p>
FO-320501	6/24/2015	6/26/2015		The transition gasket and tile are buckling at the entrance to the Music Department main office
FO-320530	6/25/2015	6/24/2015		Emergency exit door will not open. If you push the door the alarm will sound off but the door will not open. This door is located by the stairwell across from the exterior door by room 124.
FO-320551	6/25/2015	6/26/2015		The door handle for room 169 is really sticky. it's difficult to get in and out of the classroom. my students and i had trouble with it. please fix door handle. thank you
FO-320596	6/26/2015	6/29/2015		please have carpenters make an adjustment on door closer. the laches wont connect to the hasp to shut the door
FO-320650	6/26/2015	6/26/2015		The CONTROL key is stuck inside a mailbox core at University Towers. See Eric Johnson at the front desk. Please send a locksmith out today to remove the key. Thank you
FO-320673	6/29/2015			<p>Build Scaffold in the Red Lecture Hall/Jafar with wheels on it for Electricians to re-lamp the room, starting at the front/tallest section of the room.</p> <p>Also, a scaffold in the Blue lecture Hall under the panel that is completely out.</p>
FO-320729	6/29/2015			The back door (#16903N) to the garage on the north side is not closing/locking properly. You have to pull/push the door in order for it to close/lock.
<b>T - Electrician</b>			<b>59</b>	
FO-318363	6/1/2015	6/2/2015		LIGHTS ARE OUT ON THE 2ND FLOOR NORTHEAST CORNER OF BUILDING. (Multi-Task)
FO-318383	6/1/2015	6/3/2015		Place 2 pylons over loading dock drain trough to avoid people stepping into trough that is missing grate cover. New trough being replaced soon. See John Towle if needed
FO-318396	6/1/2015	6/4/2015		<p>Transport Spence valve in Stockroom to subbasement of Chatsworth beyond Engineers office.</p> <p>Also Transport duct hoist from Applebaum penthouse to same area in Chatsworth. See Jim Hill for assistance if needed</p>
FO-318434	6/1/2015			<p>Electricians:</p> <p>R/R RM 00016/MECH RM please repair 4 wall outlets in mechanical room 016, circuit breaker tripped and can not be reset. this is the same problem that happened about a month ago ( FO-314562), one of these outlet is for sump pump. Priority:</p>
FO-318773	6/2/2015	6/2/2015		<p>Electricians to meet Shambough &amp; Sons to correct smoke detectors in building.</p> <p>Completed 6-2-2015 SRP</p>
FO-318853	6/3/2015	6/3/2015		Please assist in removing debris. See Mike McAlinden for location

WO	Recieved	Finished	Total	Request
FO-318887	6/3/2015			<p>TROUBLESHOOT TOUCH SCREEN SHOWS WRONG TIME &amp; DATE SEE ROSE FOR DETAILS FIRE ALARM WITH RESET. FRONT ENTRANCE</p> <p>Completed 6-3-2015 SRP</p>
FO-318897	6/3/2015	6/3/2015		<p>*ADDING ELECTRICIAN: Hook up condensate pump #2 in mechanical room 32. See Ron Clark if needed</p> <p>To pipe fitters. Condensate pump #2 has blown the seal again and needs to be replaced. Also need plug in condensate tank removed and a drain line with ball v</p>
FO-318908	6/3/2015	6/4/2015		<p>The OneCard Office is stationed in the Italian Room in General Lectures for picture taking during Orientations over the summer. The issue is that 7 of the overhead lights are out making it difficult to take good photos of incoming students. There is a pie</p>
FO-318921	6/3/2015	6/4/2015		<p>ELECTRICAL DEPT- R/R RM 585 PLEASE REPLACE 3 BAD BALLAST IN MAIN COMUNICATIONS OFFICE,LIGHTS HAVE BEEN OUT FOR A FEW MONTHS PROURITY HIGH</p>
FO-318928	6/3/2015	6/4/2015		<p>Electrical Closet 2141 has a bundle of conduit, and other debris in it that need to be moved. Please clean the entire room out.</p>
FO-318993	6/4/2015	6/5/2015		<p>Electricians -- Priority High R/R RM 00045/MECH RM Hot-water heaters are not working</p>
FO-319025	6/4/2015	6/4/2015		<p>Power Outage, Electricians was called to check it out.</p>
FO-319041	6/5/2015			<p>The electricians are needed to trouble shoot the fire panel for fire trouble alarm.</p>
FO-319126	6/5/2015			<p>The fire panel in the chiller room isn't sounding the alarm when the system is beening tested , this is a Building Safety Problem.This is for the Eletrical Department.</p>
FO-319130	6/8/2015	6/11/2015		<p>Adjust time schedule on new Timer for the Pole Lights in the Parking Lot. On at 7PM, and off at 7AM.</p>
FO-319157	6/8/2015	6/8/2015		<p>Trade: Electrician Priority: High Please repair lab air compressor #2. Compressor will not run in auto in both local and remote mode. Compressor will run in test mode.</p>
FO-319165	6/8/2015	6/9/2015		<p>CHECK BATTERY IN FIRE PANEL. 1ST FLOOR VESTIBULE.</p> <p>Completed 6-9-2015 SRP</p>
FO-319211	6/8/2015	6/9/2015		<p>The smoke detector located over the 1st floor elevators is dangling from the wall. All of the wire appear to be connected.</p> <p>Completed 6-9-2015 SRP</p>
FO-319231	6/9/2015	6/9/2015		<p>fire alarm panel goes into trouble @ every 5 minutes "earth to ground"</p> <p>Completed 6-9-2015 SRP</p>
FO-319311	6/9/2015	6/10/2015		<p>**ADDING ELECTRICIAN: Check no power to 2 right urinal flush valves in south men's bathroom used by public. See Gerry (Plumber)</p> <p>P.M. facility plumbing fixtures on Monday 6-8-15 prior to training camp starting. See Bob on details ,, , , , , , , , , , , GS/6</p>
FO-319356	6/10/2015	6/11/2015		<p>200.01 LIGHT TIMER NOT WORKING, MUST MANUALLY TURN ON LIGHT</p>
FO-319358	6/10/2015			<p>DIGITAL SIGNS NOT WORKING, PLEASE RESET BREAKER. ENG UNABLE TO LOCATE BREAKER</p>
FO-319364	6/10/2015	6/11/2015		<p>Electricians -- Priority High Can not run both Chill water pumps at the same time without blowing fuses</p>
FO-319430	6/11/2015			<p>R/R 2306 REPLACE DAMAGED SMOKE HEAD FOR FOR SMOKE DETECTOR. FAP FIRE ALARM IS ACTIVE (SMOKE DETECTOR HEAD MISSING 2ND FLR RM 2218)</p> <p>Completed 6-12-2015 SRP</p>
FO-319447	6/11/2015	6/11/2015		<p>WATER COMING FROM ELECTRICAL CONDUIT NEAR HAND DRYER. LADIES RESTROOM. ROOM 9204.</p>
FO-319488	6/12/2015	6/12/2015		<p>Electricians: R/R RM 00410/MECH RM Cooling tower East fan motor, new last year, will only run for 40 sec. and then trips-off. I cannot reset breaker right away but must wait for a while until to reset. Perhaps the control heaters are bad. Please repa</p>
FO-319540	6/13/2015			<p>LABORER (HIGH)DELIVER TO SCOTT HALL ROOM 100 1 PALLET OF SALT 17010010FO#297763</p>

WO	Recieved	Finished	Total	Request
FO-319543	6/15/2015	6/15/2015		Trade: Electrician Priority: High Tag #090-EXF-037 Fume hood exhaust fan #37 is tripping at the starter which is located in lab 2335, please trouble shoot and repair. The exhaust fan is located on the roof of the lab wing.
FO-319545	6/15/2015	6/16/2015		Electrician; High Please pull new wire from the motor starter to the motor junction box on the #2 Boiler
FO-319588	6/15/2015	6/19/2015		Please clear material from various communication rooms. See John Towle for direction  *Need these item moved by Friday 6-19-15
FO-319892	6/15/2015	6/17/2015		**ADDING ELECTRICIAN: Requesting Paul. Please check operations on domestic water boosters. Seem to have high PSI. Water from 4th floor toilets coming out of toilet bowl from currently set PSI. See Gerry (PLUMBER) for detail  4th floor mens room 1st sta
FO-319902	6/15/2015			The fire alarm system has a Ground fault alarm , system willn't clear problem , Law school in lobby area.  This is for the electrical Department.
FO-319904	6/16/2015	6/19/2015		Trade: Electrician Priority: High Please check motor on SF3. Funny noise.
FO-319905	6/16/2015			Trade: Electrician Priority: High Please check motor on supply fan no.1 Very noisy.
FO-319906	6/16/2015			Trade : Electrician Priority: High Fire alarm trouble (a) Ground fault (b) CKT-2 Heat detector in boiler room missing.
FO-319913	6/16/2015	6/16/2015		Elect. High Priority R/R ROOF Please check VFD on PRV #3 on roof. Unit will stall out and not turn fan.
FO-319936	6/16/2015			RM 215 LIGHT TIMER NOT WORKING
FO-319952	6/16/2015			Trade: Laborer Priority: High Please deliver the following chemicals...3 drums of Aquaklean 2 drums of Lokor Wednesday delivery if possible.
FO-319953	6/16/2015	6/19/2015		Trade: Laborer Priority: High  Please deliver one pallet of softener salt.  Wednesday delivery if possible.
FO-319994	6/16/2015	6/16/2015		Meet Centerline Electricians, and close Main Switch feeding building.  Also take photos of the newly installed lights on AAB, and the Lodge Crosswalk on both sides.
FO-320033	6/17/2015	6/24/2015		1ST FL WITHIN FREE LEGAL AID CLINIC UNISEX RESTROOM HAS A LIGHT THAT WORKS ON & OFF SEEMS TO BE A SHORT IN WIRING  Completed 6-24-2015 SRP
FO-320125	6/18/2015	6/19/2015		Electricians: R/R 1ST FLR Fire panel showing "trouble" on one of the fire sensor heads. Please repair or replace. High priority.
FO-320201	6/19/2015	6/22/2015		electrical problem in Presidents bathroom with in master bedroom in Alumni house. Please call Henrietta before coming over at 7-4882 .  Completed 6-22-2015 SRP
FO-320210	6/19/2015			electrical problem in Presidents bathroom with in master bedroom in Alumni house. Please call Henrietta before coming over at 7-4882 .
FO-320261	6/22/2015			Electrician; High R/R LOBBY/W. WOODWARD Please repair the bad alarm monitor for the Siemens Firefinder System. The screen is blank and there is no way to monitor issues with the system.
FO-320279	6/22/2015	6/24/2015		WEDNESDAY 6/24/2015:  Install 200Amp Contactor for the lights in the Auditorium.

WO	Recieved	Finished	Total	Request
FO-320370	6/23/2015	6/30/2015		This deals with the whole third floor. According to the email of a student, the theater has no backup emergency lighting working, and a number of the emergency lighting units on the third floor are either not working or appear to be nearly dead.
FO-320420	6/23/2015	6/24/2015		Electrician R/R PH/MECH RM please troubleshoot EF-4 THE VFD is fried a loud bang after closing breaker.Priority HIGH
FO-320444	6/23/2015			ELECTRICIANS PLEASE R/R SMOKE DETECTOR IN RM.0203AND ROOM 2306.PRIORITY:HIGH
FO-320460	6/24/2015			The fire/smoke doors located at the north corridor/passageway into the Law School building did not self close and latch upon activation of the fire alarm system. The doors at 1st and 2nd floor did not close completely.
FO-320476	6/24/2015			Trouble alarm sounding in new fire panel on North wall in room 130. Trouble notification is battery replacement needed.
FO-320635	6/26/2015			Electrician please troubleshoot fire alarm system,buzzer going off at panel 1st. floor lobby, this is what panel reads-5th fl. nag-10&11 Trigger 2:sig16 visual off.
FO-320641	6/26/2015	6/29/2015		RM 201 CLOCK NOT WORKING  Completed 6-29-2015 SRP
FO-320656	6/26/2015	6/29/2015		DISCONNECT POWER TO FUEL LEVEL CONTROL FOR THE GENERATOR.
FO-320683	6/29/2015			Electricians: R/R RM 410/MECH RM Light fixture over the tower test station is not working. Please repair. High priority.
FO-320706	6/29/2015			ELECTRICIANS (HIGH) R/R RM 402/MECH RM REPLACE/RELOCATE GFI OUTLET IN MECHANICAL ROOM 402 TO LEFT OF DOOR TO COOLING TOWERS. CIRCUIT IS IN BAD LOCATION AND WILL NOT RESET. CIRCUIT IS USED FOR COOLING TOWER CONTROLS
FO-320715	6/29/2015			Pick up material from LakeShore Welding on TUESDAY MORNING 6-30-15 at 10:00am . See John Towle for direction
FO-320727	6/29/2015			Trade: Laborer Priority: High R/R RM 00000.62/MECH BLR RM Please deliver 1) 4 keg of Halochlor, 2) 1 pallet of salt, 3) 2 keg Aquaklean 4) and 2 of Lokor. There are no spare kegs of Halochlor or Aquaklean. FO-297706
<b>T - Locksmith</b>			<b>10</b>	
FO-318422	6/1/2015	6/11/2015		Please cut 2 keys (90514-1) for Holden Mail room door to provide after hour access for an abatement project for Pipe Shop, See John Towle
FO-318931	6/3/2015	6/16/2015		New KeyNew Space AssignmentKey #: B200Key Holder ID: Dr. HeydariQty: 10action: Need to have 10 keys in order for the staff to get over to Life Science from Science Hall and back again for the construction phase.Account #: 771929
FO-319321	6/10/2015	6/16/2015		New KeyNew Space AssignmentKey #: OE12Key Holder ID: Dennis Pearson, Eugene OwensQty: 2action: Pad Lock at the Loading dock.
FO-319437	6/11/2015	6/16/2015		New KeyLost / StolenKey #: Key 63162Key Holder ID: Cindy HildrethQty: 1action: request one key for room 1125.1. This room was not available for section in the drop down boxAccount #: 228400
FO-319474	6/11/2015	6/12/2015		New KeyNew Space AssignmentKey #: 17623Key Holder ID: Valeria CookQty: 6action: Note: The Department is Center for Urban Studies
FO-319454	6/11/2015	6/25/2015		Please remove 287 key that is stuck in door lock to mechanical room next to service elevator on 7th floor. Key is from Mike McAlinden (Plumber)
FO-320458	6/24/2015	6/25/2015		Change core for room 101 (Custodial Director's Office) with 2-KEYS.
FO-320500	6/24/2015	6/26/2015		New KeyNew Space AssignmentKey #: 89806Key Holder ID: Geneva GuiceQty: 1action: Brown Box Key # 89806.180

WO	Recieved	Finished	Total	Request
FO-320543	6/25/2015			New Key New Staff Member Key #: 10AM4.22 Key Holder ID: Krista Mitchell Qty: 2  action: Please provide 2 keys for room 1310.02. Core Mark is 10AM4.22. Must have keys in hand by June 30. Keys for new Vice President of University.
FO-320568	6/25/2015	6/29/2015		New Key New Staff Member Key #: 60600 Key Holder ID: Krista Mitchell Qty: 2  action: Please provide 2 keys, Key #60600 for entry into room 1206 Scott Hall. Need in hand my June 30 if possible - For New VP staff members
<b>T - Painter</b>				<b>6</b>
FO-318998	6/4/2015	6/4/2015		Pick up consumables from AIRGAS in Lincoln Park. See John Towle for direction
FO-319369	6/10/2015	6/12/2015		**ADDING PAINTERS: Paint ceiling at entrance of room 2322 where hole for access panel is to be installed . Paint in chipped and flaking falling on people when they enter room. See Rocky if needed  ADDING CARP R/R HALLWAY OUTSIDE OF RM 2322 NEED CARPEN
FO-319998	6/16/2015			R/R 1ST FLR MENS RR (only one on flr) MIDDLE STALL HAS GRAFFITI WRITTEN W/MAGIC MARKER (custodian unable to clean) POL REP #W151550046 6/16/15 lps: Chng to Est for Main
FO-320002	6/16/2015			Sweep loose debris and glass from roof parking deck. Stage large debris items in same location to be hauled away. Also sweep and remove debris from upper landing of roof stairwell near men's bathroom
FO-320070	6/18/2015	6/19/2015		PAINTERS: R/R RM 3133/MECH RM Please seal the sheet metal to floor seam on #3 AHU. See Engineer for more details. High priority.
FO-320481	6/24/2015	6/25/2015		PAINT CANS & ETC. LEFT IN BACK ENTRANCE STAIRWELL NEAR ROOM 103. PLEASE PICK UP. NEED ITEMS PICKED UP BY 6/25/15.
<b>T - Pipefitter</b>				<b>30</b>
FO-318369	6/1/2015	6/1/2015		**ROOF LEAK / TIM HERR for contact  CEILING LEAK. 1ST FLOOR. CONTACT CAROL TALBOTT FOR MORE INFORMATION.,,,,,,,,,,,,,, EA/6-1-15 ,,,,,,,,,,,,,,
FO-318388	6/1/2015	6/1/2015		LAB 450 CEILING LEAK ,,,,,,,,,,,,,, EA/6-1-15 ,,,,,,,,,,,,,,
FO-318909	6/3/2015	6/4/2015		Room 1213 (Jewitt Lab) has a brown spot where leaking is occurring from the ceiling; need leak fixed ,,,,,,,,,,,,,, JH/6-3-15 ,,,,,,,,,,,,,,
FO-318977	6/4/2015	6/4/2015		SteamFitters please replace 2" tee above stop valve,it is leaking at nipple threads.priority high,it was repaired about three weeks ago.this is located in south pipe chase,4210.,,,,,,,,,,,,,, ME/6-4-15 ,,,,,,,,,,,,,,
FO-318981	6/4/2015	6/5/2015		4TH FL HALLWAY OUTSIDE ELEV ACTIVE CEILING LEAK ,,,,,,,,,,,,,, JH/6-4-15 ,,,,,,,,,,,,,,
FO-318994	6/4/2015	6/5/2015		Trade: Pipe Fitter Priority: High Pipe insulation is falling apart and some of it is laying on the floor, it looks like asbestos, please test.,,,,,,,,,,,,,, CB/6-4-15 ,,,,,,,,,,,,,,
FO-319011	6/4/2015	6/5/2015		CEILING LEAK. HALLWAY OUTSIDE OF ROOM 0111 ,,,,,,,,,,,,,, ME/6-4-15 ,,,,,,,,,,,,,,
FO-319098	6/5/2015	6/5/2015		BSMNT CEILING LEAK, PLEASE SEE MARY BONK FOR EXACT LOCATION DETAILS ,,,,,,,,,,,,, EA/6-5-15 ,,,,,,,,,,,,,,
FO-319105	6/5/2015	6/8/2015		RM 0318 CEILING LEAK ,,,,,,,,,,,,,, ME/6-5-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-319148	6/8/2015	6/8/2015		**REFER TO ROOF REQ FO#319313 JWT  The ceiling is leaking in the basement in the audiology clinic room 002 right above the computer. .... EA/6-8-15 .....
FO-319293	6/9/2015	6/10/2015		Steamfitters-please clear drain from chilled water coils in main air handling unit, line plugged and condensate running all over floor priority high ..... EA/6-9-15 .....
FO-319329	6/10/2015	6/10/2015		CEILING LEAK. 1ST FLOOR SERVICE CENTER AREA. .... EA/6-10-15 ..... *NOTE: Source of leak could not be located. Appears to only show on heavy rains. Could be migrating from a variety of parking deck leaks from failing deck coating or tu
FO-319485	6/12/2015	6/12/2015		drain valve on individual evapco tower is leaking thru, wasting chemicals and water ..... JH/ 6-12-15 .....
FO-319498	6/12/2015	6/12/2015		*REFER TO PLUMBER FO#319597  trade pipe fitters priority high please replace broken shut off valve on cage washer in basement of animal quarters the valve just spins and will not shut supply off ..... EA/6-15-15 .....
FO-319546	6/15/2015	6/15/2015		**REFER TO ROOFING WORK ORDER FO#320004 JWT  CEILING LEAK. ROOM 3100 (DEAN'S OFFICE)..... EA/6-15-15 .....
FO-319567	6/15/2015	6/15/2015		**REFER TO INSULATION REQUEST FO#320006 JWT  water leaking into office. Cannot tell form where, but room is located near cold room, 423..... JH/6-15-15 .....
FO-319573	6/15/2015	6/15/2015		**REFER TO ROOFING WORK ORDER FO#320005 JWT  3RD FL HALLWAY ON NORTH SIDE, ACTIVE CEILING LEAK BUCKET IS CATCHING WATER ..... EA/6-15-15 .....
FO-319888	6/15/2015	6/16/2015		**REFER TO PLUMBER WORK ORDER FO#319977 JWT  CEILING LEAK. BASEMENT STUDIO THEATRE. NORTH WALL NEXT TO ELECTRICAL CLOSET..... EA/6-16-15 .....
FO-319927	6/16/2015	6/16/2015		RM 3372 CEILING LEAK ..... EA/6-16-15 .....
FO-319949	6/16/2015	6/17/2015		**REFER TO FO#320065  CEILING LEAK. ROOM 136..... ME/6-17-15 .....
FO-320001	6/16/2015	6/18/2015		Ceiling leak in room 2111 ..... EA/6-16-15 .....
FO-320095	6/18/2015	6/29/2015		CEILING LEAK. CEILING TILES ARE WET. ROOM 1351..... *ME/JH/ 6-18-15 .....
FO-320115	6/18/2015	6/22/2015		WATER LEAK AT BASE OF WALL. CAFETERIA. ROOM 1352.1. .... EA/6-18-15 .....
FO-320136	6/18/2015			Pipefitters. High R/R RM 00024/MECH RM Repair piping and coil leaks Ahu-3..... ME/6-18-15 .....
FO-320379	6/23/2015	6/24/2015		**REFER TO ROOFING WORK ORDER FO#320724 JWT  CEILING LEAK. 1ST FLOOR ATRIUM NEAR WINDOW AND ROOM 111.3. .... EA/6-23-15 .....
FO-320466	6/24/2015	6/24/2015		CEILING LEAK. ROOM 2105..... EA/6-24-15 .....  ***SEE RESULTS***
FO-320490	6/24/2015	6/24/2015		HALLWAY OUTSIDE OF RM 0111 WOMENS RM, ACTIVE CEILING LEAK ..... ME/6-24-15 .....
FO-320545	6/25/2015			Trade: Pipefitter Priority: High Please modify LWCO blowdown piping on boiler #3 to eliminate 90 degree ells. Boiler is currently dry. .... EA/6-30-15 .....
FO-320670	6/29/2015	6/29/2015		CEILING LEAK, CEILING TILE HAS FALLEN. ROOM 4032..... EA/6-29-15 .....
FO-320703	6/29/2015	6/30/2015		Steamfitter please repair 2 1/2" union, leaking steam,Priority High-FO-320691 this in mech. rm. 7th ft. up from floor. .... ME/6-29-15 .....
<b>T - Plumber</b>			<b>78</b>	
FO-318761	6/2/2015	6/3/2015		LADIES RM 2ND FL RIGHT SINK, NO WATER ..... MM/6-2-15 .....
FO-318782	6/2/2015	6/3/2015		2nd floor men's restroom - the faucet that is on the sink 2nd from the end has a constant stream of water running from it..... MM/6-2-15 .....



WO	Recieved	Finished	Total	Request
FO-318800	6/2/2015	6/3/2015		PLUGGED TOILET. MEN'S RESTROOM. ROOM 3238. .... MM/ 6-2-15 .....
FO-318910	6/3/2015	6/4/2015		2nd floor ladies restroom - the 1st sink by the entrance is stopped up ..... MM/6-3-15 .....
FO-318939	6/3/2015	6/4/2015		5TH FL LADIES RM NEAR 5190, 3RD STALL WATER SHOOTS OUT WHEN FLUSHED ..... MM/6-4-15 .....
FO-318942	6/3/2015	6/4/2015		1ST FL NEAR BACK ENTRANCE UNISEX RESTROOM, SINK LEAKING UNDERNEATH WHEN TURNED ON AND SHOOTS WATER WHEN IN USE ..... MM/6-4-15 .....
FO-318946	6/3/2015	6/4/2015		Install Cherni plug in ceiling 4" penetration above air de-fuser to contain ceiling leak from unknown source identified by engineer in room 330 ..... DB/6-3-15 .....
FO-319006	6/4/2015	6/4/2015		*DUPLICATE WORK ORDER  RM 2210 SERVER RM HAS A BAD LEAK, LEAKING DOWN INTO 1st FL ..... GS/6-4-15 .....
FO-319034	6/4/2015	6/6/2015		Please snake sink in Men's restroom down the hall from Jim Sears office. Not draining properly..... DB/6-4-15 .....
FO-319109	6/5/2015	6/8/2015		BSMNT COLD KITCHEN, WATER PRESSURE TO SINK IS LOW AND TEMP NEEDS TO BE INCREASED ..... GS/ 6-5-15 .....
FO-319110	6/5/2015	6/5/2015		REQUEST FINISHED FROM **REFER TO FO#319109 JWT  .BSMNT MENS RM TOILET NOT FLUSHING ..... GS/6-5-15 .....
FO-319147	6/8/2015	6/9/2015		ROOM 4128 - Ice Room. Bruce Company needs to install a new ice maker, the water value in that room is broken and needs to be replaced so that company can hook up the machine Ice machine has been delivered and we need this value replace as soo
FO-319212	6/8/2015	6/9/2015		Front Desk - Storage Room Behind Front Desk - Sink is clogged and disposal does not work. Need repaired as soon as possible. See Rob Latva (3-4105) if more details are needed.....
FO-319175	6/8/2015	6/8/2015		please have plumbers investigate a leaking back flow preventer. It is leaking on the floor into the hall. High priority thank you ..... DB/6-8-15 .....
FO-319191	6/8/2015	6/11/2015		Fix sink, leaking from the top..... MP/6-8-15 .....
FO-319208	6/8/2015	6/9/2015		WOMENS RM 1ST SINK IS LEAKING ..... MM/6-9-15 .....
FO-319271	6/9/2015	6/24/2015		Faucet in lab 3119 will not turn off..... MM/6-10-15 .....
FO-319290	6/9/2015	6/10/2015		R/R RM 5101 MENS RR 1 OF THE 2 TOILETS IS CON'T FLUSHING ..... MM/6-10-15 .....
FO-319351	6/10/2015	6/10/2015		2ND FL MENS RM 3RD STALL TOILET PLUGGED ..... DB/ 6-10-15 .....
FO-319368	6/10/2015	6/12/2015		3RD FL MENS RM FLOODING POSSIBLE URINAL OVERFLOWING ..... DB/6-10-15 .....
FO-319384	6/10/2015			Plumbers -- Priority High Women 2nd floor restroom toilet seal/wax ring needs replacing. Toilet is leaking into restroom on 1st floor ..... GS/6-11-15 .....
FO-319428	6/11/2015	6/12/2015		Ladies restroom inside the 3rd and 4th bathroom stahl there is water leaking from toilets. Leak looks like it is coming from the bottom of the toilet so it leaks when you sit on it ..... MM/6-11-15 .....
FO-319442	6/11/2015	6/12/2015		TOILET HANDLE LEAKS. LADIES RESTROOM. ROOM 380. 1ST STALL..... MM/6- 11-15 .....
FO-319460	6/11/2015	6/12/2015		TOILET CONTINUOUSLY FLUSHING. 12TH FLOOR UNISEX RESTROOM..... MP/6- 11-15 .....
FO-319487	6/12/2015			WATER CEILING LEAK OVER URINAL. 1ST FLOOR MEN'S RESTROOM. ROOM 108..... DB/6-15-15 .....
FO-319495	6/12/2015	6/15/2015		LEAKS UNDERNEATH 2 SINKS. 1ST FLOOR MEN'S RESTROOM..... MP/6-15-15 .....
FO-319521	6/12/2015	6/29/2015		(**) PO REQ DK 6-17-15 ADDING ENG: (RM 110 NEED TO EMPTY BUCKET OVER WEEKEND) R/R RM 110 (ONLY) Sink leaking from underneath. (NOTE: BUCKET UNDERNEATH SINK ALSO IS LKNG EVEN WHEN FAUCET ISN'T ON)..... GS/6-15-15 .....

WO	Recieved	Finished	Total	Request
FO-319547	6/15/2015	6/19/2015		TOILET LEAK. WOMEN'S RESTROOM. ROOM 3100. .... MP/6-15-15 .....
FO-319579	6/15/2015	6/17/2015		FAUCET CONTINUOUSLY LEAKING. ROOM 417. .... MM/6-15-15 .....
FO-319581	6/15/2015			4th floor mens room 1st stall water is running out of bottom of toilet. .... GS/ 6-15-15 .....
FO-319597	6/15/2015			trade pipe fitters priority high please replace broken shut off valve on cage washer in basement of animal quarters the valve just spins and will not shut supply off .... GS/6-15-15 .....
FO-319874	6/15/2015			FAUCET LEAK. ROOM 0225. .... MM/6-15-15 .....
FO-319889	6/15/2015	6/16/2015		Dewater loading dock .... GS/MM6-15-15 .....
FO-319929	6/16/2015	6/17/2015		FAUCET CONTINUOUSLY RUNNING. 1ST FLOOR UNISEX RESTROOM. .... MM/6-16-15 .....
FO-319961	6/16/2015	6/22/2015		MENS RESTROOM ACROSS FROM RM 109, SINK ELBOW LEAKING .... MM/6-16-15 .....
FO-319962	6/16/2015			R/R 3RD FLR MENS RR 3RD URINAL IS PLUGGED UP .... MP/6-16-15 .....
FO-319966	6/16/2015	6/16/2015		DUPLICATE / REFER TO FO#319971 JWT  BSMNT RM NEXT TO LUNCH RM LARGE PUDDLE OF WATER LEAKING UNDER DOOR
FO-319969	6/16/2015			SHIFFMAN LIBRARY LOADING DOCK DRAIN AND EMERGENCY EXIT DOOR DRAIN BOTH NEED TO BE CLEANED .... MM/6-16-15 .....
FO-319981	6/16/2015	6/17/2015		Plumbers: Floor drain by AHU-3 needs to be sealed from dripping down onto the third floor. See Engineer for more info. High Priority. .... GS/6-16-15 .....
FO-319977	6/16/2015			**ADDING PLUMBER: Repair leaking floor drain traps from 1st floor possible janitors sink and drinking fountain drains leaking into studio B CEILING LEAK, .... GS/ 6-16-15 .....
				. BASEMENT STUDIO THEATRE. NORTH WALL NEXT TO ELECTRICAL
FO-320034	6/17/2015	6/18/2015		FAUCET CONTINUOUSLY LEAKING. GROUNDS DEPT. NEAR HYDRONIC LIFT. .... MM/ 6-17-15 .....
FO-320036	6/17/2015	6/19/2015		Plumbers R/R RM 2352 please repair leaking RO connection in wall of storage room 2330,RO is shut off on 4th floor south west pipe chase.priority High.FO-319987 .... DB/6-17-15 .....
FO-320052	6/17/2015			**ADDING PLUMBER: Check sump pump A" . Blows fuse when energized. Electrical operations have been checked and pump is dewired .... MM/6-17-15 .....
				ELECTRICIANS: R/R RM 00187.01/MECH RM PLEASE CHECK A" SUMP PUMP BREAKER TRIPS AS SOO
FO-320065	6/17/2015	6/17/2015		**REFER TO ROOFING WORK ORDER FO#320153 JWT  CEILING LEAK Check plumbing above bucket in room 136 .... GS/6-17-15 .....
				*Roofer FO#320153 6-18-15 JWT
FO-320068	6/18/2015	6/22/2015		Trade: Plumber High priority R/R 2ND FLR Women's restroom toilet running continuously .... MM/6-18-15 .....
FO-320084	6/18/2015			VERY BAD SEWAR SMELL COMING FROM 1ST AND 2ND FLOOR RESTROOMS. (ROOMS 136, 137, 236 & 237) .... MM/6-29-15 .....
FO-320093	6/18/2015	6/19/2015		Plumbers please odorize mens and ladies restrooms, urinals and floor drains very bad smell coming from them,rm.136,137,236,237.Priority HIGH,FO-320084 .... MM/6-18-15 .....
FO-320120	6/18/2015			PIPE LEAK. FRONT OF JANITOR'S CLOSET. 1ST FLOOR. .... DB/6-18-15 .....
FO-320169	6/19/2015	6/22/2015		LOW WATER PRESSURE IN TOILET. 2ND FLOOR MEN'S RESTROOM. ROOM 2124. .... MP/6-22-15 .....
FO-320213	6/19/2015	6/19/2015		**CANCELLED / Bathroom being reinitiated JWT  1ST FLOOR MEN AND WOMEN'S RESTROOMS ARE DOWN. TAPE AROUND FRONT ENTRANCE OF DOORS.
FO-320214	6/19/2015	6/22/2015		CLOGGED TOILET. 2ND FLOOR WOMEN'S RESTROOM. ROOM 170. .... DB/6-22-15 .....
FO-320215	6/19/2015	6/22/2015		CLOGGED TOILET. MEN'S RESTROOM. ROOM 154. 1ST STALL. .... DB/6-20-15 .....

WO	Recieved	Finished	Total	Request
FO-320290	6/22/2015	6/23/2015		WATER LEAK COMING FROM WALL. ROOM 234. ,,,,,, MM/6-22-15 ,,,,,,
FO-320328	6/22/2015	6/23/2015		Water temperature is not able to be controlled. Scald hazard when showering. ,,,,,, MM/6-23-15 ,,,,,,
FO-320389	6/23/2015	6/23/2015		PLUGGED TOILET. 2ND FLOOR MEN'S RESTROOM. HANDICAP STALL.,,,,,, DB/6-23-15 ,,,,,,
FO-320395	6/23/2015	6/24/2015		Far left sink is spraying water all over the counter and the person using it. My shirt got all wet while washing my hands. ,,,,,, MM/6-23-15 ,,,,,,
FO-320408	6/23/2015			R/R RM 00054/MECH AREA Plumber repair water leak in ceiling. Same leak as last week. It rained last night and water this morning in basement area. Priority high. REFER TO WO #FO-319319 Plumber repair drain line leak in ceiling room 056. Possible loose c
FO-320410	6/23/2015	6/24/2015		R/R RM 413/DLAR THE ONLY SINK IS PLUGGED UP ,,,,,, MM/6-23-15 ,,,,,,
FO-320411	6/23/2015	6/24/2015		R/R RM 6321 ONLY SINK IS LKNG FROM UNDERNEATH ,,,,,, MM/6-23-15 ,,,,,,
FO-320434	6/23/2015	6/25/2015		R/R 1ST FLR MENS RR IN ATRIUM AREA (Behind Elevs) HAS A SIGN ON DOOR STATING TOILET IS PLUGGED & OUT OF ORDER ,,,,,, DB/6-24-15 ,,,,,,
FO-320441	6/23/2015	6/23/2015		Dewater loading dock from rain ,,,,,, MM/6-23-15 ,,,,,,
FO-320463	6/24/2015	6/24/2015		**DUPLICATE WORK ORDER / REFER TO FO#319874 MATERIAL ON ORDER JWT RM 225 NO COLD WATER
FO-320472	6/24/2015	6/30/2015		WATER FAUCET IS CONTINUOUSLY RUNNING. 1ST FLOOR (NEW) MEN'S RESTROOM.,,,,,, MP/6-24-15 ,,,,,,
FO-320483	6/24/2015	6/24/2015		The handle on the #1 toilet in the women's 3rd floor restroom is not working.,,,,,, MP/6-24-15 ,,,,,,
FO-320496	6/24/2015	6/25/2015		PLUGGED TOILET. 3RD FLOOR MEN'S RESTROOM. STALL NEXT TO HANDICAP STALL.,,,,,, DB/6-24-15 ,,,,,,
FO-320514	6/24/2015			Men's room 32 replace: -1/2" solenoid valve for first three urinals -Repair seal on toilet -Reattach vanity to wall ,,,,,, MP/ 6-24-15 ,,,,,,
FO-320522	6/25/2015	6/26/2015		2 PLUGGED TOILETS. MEN'S RESTROOM. ROOM 3338. NEAR DANCE DEPT.,,,,,, GS/6-25-15 ,,,,,,
FO-320572	6/25/2015			ADDING PLUMBERS R/R RM 040 NEED TO REPAIR CLNG DRAIN LINE THATS IS LKNG FROM CEILING ,,,,,, MM/6-29-15 ,,,,,,
FO-320572	6/25/2015			ADDING PLUMBERS R/R RM 040 NEED TO REPAIR CLNG DRAIN LINE THATS IS LKNG FROM CEILING ,,,,,, MM/6-29-15 ,,,,,,
FO-320593	6/26/2015	6/29/2015		URINAL CONTINUOUSLY FLUSHING. 1ST FLOOR MEN'S RESTROOM.,,,,,, MM/6-29-15 ,,,,,,
FO-320603	6/26/2015	6/29/2015		PLEASE CLEAR FLOOR DRAIN. (TROFT DRAIN IS BACKING UP). ROOM 0247. (MULTI-TASK) ,,,,,, MM/6-29-15 ,,,,,,
FO-320603	6/26/2015	6/29/2015		PLEASE CLEAR FLOOR DRAIN. (TROFT DRAIN IS BACKING UP). ROOM 0247. (MULTI-TASK) ,,,,,, MM/6-29-15 ,,,,,,
FO-320618	6/26/2015			R/R 3RD FLR MENS RR (only one) THE ONLY URINAL ISN'T DRAINING ,,,,,, MM/6-29-15 ,,,,,,
FO-320623	6/26/2015			The commode in the smaller stall in this ladies lavatory appears to leaking water out the back/bottom.,,,,,, MM/6-29-15 ,,,,,,
FO-320668	6/29/2015	6/29/2015		cannot get water to shut off at sink. running full force ,,,,,, MM/6-29-15 ,,,,,,
FO-320700	6/29/2015	6/30/2015		URINAL CONTINUOUSLY FLUSHING CAUSING IT TO OVERFLOW. 1ST FLOOR MEN'S RESTROOM.,,,,,, DB/6-29-15 ,,,,,,
FO-320705	6/29/2015			Ceiling tiles have fallen down in room 422. They are waterlogged.,,,,,, *DB/ME/6-29-15 ,,,,,,
FO-320730	6/29/2015			3RD FL WOMENS RM NEXT TO 3339, SINK RUNNING CONTINUOSLY

#### T - Roofing

8

FO-318863	6/3/2015			RooferHigh priorityPlease repair roof leak at North-East corner of the 1st floor. The leak is from flat roof at various location.Leaks only when it rains. Also leak can be located by damaged ceiling tiles.
-----------	----------	--	--	---

WO	Recieved	Finished	Total	Request
FO-318949	6/3/2015	6/11/2015		Roofers  Please repair roof leak in Lab. 422  High Priority. REPAIRS HAVE BEEN MADE. 6/11/15. TAH
FO-319118	6/5/2015			R/R ROOF Repair roof leaks around cooling tower. Priority high.
FO-319313	6/9/2015			**ADDING ROOFER: Water migrating into room 002. Need to be addressed ASAP See Corey Blair for detail  The ceiling is leaking in the basement in the audiology clinic room 002 right above the computer CB
FO-319960	6/16/2015			ADDING ROOFER R/R 3RD FL HALLWAY ON NORTH SIDE, 2 ACTIVE CEILING LEAK BUCKET IS CATCHING WATER (THIS IS NOT PIPEFITTER WORK,,,,,,,,,,,,,,,,, EA/6-15-15,,,,,,,,,,,,,,,,,)
FO-320004	6/16/2015			**ADDING ROOFER: Roof leak in Dean's office 3100. Migrating from roof outside of mechanical room on north east side of building EA  CEILING LEAK. ROOM 3100 (DEAN'S OFFICE),,,,,,,,,,,,,,,,, EA/6-15-15 ,,,,,,,,,,,,,,
FO-320005	6/16/2015			**ADDING ROOFER: 3rd floor hallway on north side has a ceiling leak from roof in front of boiler room doors CB  3RD FL HALLWAY ON NORTH SIDE, ACTIVE CEILING LEAK BUCKET IS CATCHING WATER ,,,,,,,,,,,,,,,,,, EA/6-15-15 ,,,,,,,,,,,,,,
FO-320153	6/18/2015			**ADDING ROOFER: Repair roof leak around roof sump and curb of air conditioner water leaking down to room 136. See Gerry (Plumber) for detail  CEILING LEAK Check plumbing above bucket in room 136 ,,,,,,,,,,,,,,,,,, GS/6-17-15 ,,,,,,,,,,,,,,
<b>Medium</b>			<b>133</b>	
<b>T - Carpenter</b>			<b>31</b>	
FO-318405	6/1/2015	6/10/2015		**ADDING CARPENTER: Replace stained ceiling tile in lab 450  LAB 450 CEILING LEAK ,,,,,,,,,,,,,,,,,, EA/6-1-15 ,,,,,,,,,,,,,,
FO-318862	6/3/2015	6/9/2015		Carpenter Medium priority Please replace damaged ceiling tiles due to roof leak at North-East corner of 1st floor.
FO-318896	6/3/2015	6/4/2015		**ADDING CARPENTER: Please erect scaffold in T.V. Studio. See Mike Pummil for detail Also provide access to locate plumbing leak  Investigate source of leak from ceiling in Studio ,,,,,,,,,,,,,,,,,, MP/6-3-15 ,,,,,,,,,,,,,,
FO-318927	6/3/2015	6/4/2015		Trade: CarpentersPriority: MediumPlease tighten door closer top bracket screws for door number 007 13W. This is on the west side of the switch gear room.
FO-318929	6/3/2015	6/11/2015		The women's bathroom on the North end of the stadium needs cinder block repair. See Jonathan Williams for locations
FO-318938	6/3/2015	6/10/2015		Replace ceiling tiles in front of main office at front door on Ferry side of building JH
FO-318944	6/3/2015	6/5/2015		*ADDING CARPENTER: Remove scaffold and repair access hole in west side overhang . See Ron Clark if needed  Trade: Plumber Priority: High Please repair water leak coming from the west overhang,,,,,,,,,,,,,,,,, ME/3-23-15 ,,,,,,,,,,,,,,
FO-318945	6/3/2015	6/24/2015		**ADDING CARPENTER: Remove section of 3 marked ceilings on 3rd floor for plumbing access. See Gerry (Plumber) for detail  (**) PO REQ DK 4-15-15 lower floor drain to be level with floor. Currently the floor drain is @ 3/4" above floor grade and water
FO-318951	6/4/2015	6/10/2015		CarpenterMedium priorityPlease replace damaged drop ceiling tiles
FO-318992	6/4/2015	6/5/2015		Carpenters --Priority MediumAccess door to roof jammed.

WO	Recieved	Finished	Total	Request
FO-319123	6/5/2015	6/26/2015		**ADDING CARPENTER: Replace stained ceiling tiles in room 1213 JH  Room 1213 (Jewitt Lab) has a brown spot where leaking is occurring from the ceiling; need leak fixed ,,,,,,,,,,,,,, JH/6-3-15 ,,,,,,,,,,,,,,
FO-319169	6/8/2015	6/9/2015		Carpenters- Please remove ceiling tile and grid for Heat pump removal...area from light fixture to sprinkler head... HP 2-86.. Med. Priority
FO-319196	6/8/2015	6/9/2015		RETURN FAN #1 IS OUT.  CARPENTERS:  to remove Skylight so Electricians can replace motor, and replace when job is done.
FO-319335	6/10/2015	6/11/2015		Carpenter; Medium Please repair doors #88-1 & #88-2. The doors are the entrance to the boiler room for 5057 Woodward. The doors will not latch and the weather stripping needs to be replaced. The rain water will flow through those doors and flood
FO-319397	6/10/2015			RM 2125 BROKEN FLOOR TILE NEEDS REPLACING
FO-319398	6/10/2015			RM 2133 BROKEN FLOOR TILE NEEDS REPLACING
FO-319399	6/10/2015			RM 2137 BROKEN FLOOR TILE NEEDS REPLACING
FO-319434	6/11/2015			CARPENTERS: Please replace multiple broken tiles on lower level near south stairs.MED.
FO-319489	6/12/2015	6/12/2015		STALL DIVIDER HAS COME APART. 2ND FLOOR MEN'S RESTROOM. NEAR ROOM 2506.
FO-319514	6/12/2015	6/26/2015		Carpenters: please repair sliding door # 01601E, it stops working in closed position and after resetting it works for short period of time and quits again. priority: med.
FO-319517	6/12/2015	6/24/2015		**ADDING CARPENTER: Please remove and replace cabinet in 3119 to access isolation valve. See Mike McAlinden  Faucet in lab 3119 will not turn off,,,,,,,,,,,,,,,,, MM/6-10-15 ,,,,,,,,,,,,,,
FO-319967	6/16/2015	6/16/2015		Door adjacent to room 109 has a loose door closer. Door closer needs another machine screw tapped/threaded into door frame.
FO-320046	6/17/2015			CEILING TILE HAS FALLEN. ROOM 235.
FO-320150	6/18/2015			**ADDING CARPENTER: Replace ceiling tiles outside room 351 EA  CEILING LEAK. CEILING TILES HAS FALLEN. HALLWAY OUTSIDE OF ROOM 351,,,,,,,,,,,,,,,,, EA/GS/6-18-15 ,,,,,,,,,,,,,,
FO-320152	6/18/2015			Replace ceiling tiles in men's training room above whirlpool and ice maker GS
FO-320156	6/19/2015			**ADDING CARPENTER: Extend down spouts on east side of boiler room away from boiler room to avoid water from migrating into Lisa's office and control center from where brick wall meets parking deck. See Dave Kuffner for detail if needed  **ADDING LABO
FO-320165	6/19/2015			Carpenters-please rebuild ceiling in hallway outside room 11205. Med. Priority
FO-320471	6/24/2015			Trade: Carpenter Priority: MediumRM 3545 MENS RESTROOM Cut access opening (2ftx2ft) and install access door so control engineer can make a repair on a VAV box above the ceiling.See Rocky for location or Rich Hosking (734-223-9398).
FO-320511	6/24/2015	6/26/2015		Metal plate at the bottom of swinging door in this office is loose. Needs to be tightened. See Nicole Johnson
FO-320607	6/26/2015	6/4/2015		Carp. Med priorityRepair wood railing on loading dock ramp. First rail at the top is broken.
FO-320701	6/29/2015	6/29/2015		**ADDING CARPENTER: Please replace damaged and stained ceiling tile in room 4032 CB  CEILING LEAK, CEILING TILE HAS FALLEN. ROOM 4032,,,,,,,,,,,,,,,,, EA/6-29-15 ,,,,,,,,,,,,,,

T - Electrician

49

WO	Recieved	Finished	Total	Request
FO-318378	6/1/2015	6/2/2015		**ADDING LABORER: Pickup piping debris in Subbasement near elevator. See Gerry (PLUMBER) if needed  . See R/R acid waste pump not running correctly ,,,,,,,,,,,,,, GS/2-27-14 ,,,,,,,,,,
FO-318432	6/1/2015			Electrician R/R PENTHOUSE repair HHW pump #1. Won't start.
FO-318433	6/1/2015			Electrician R/R 3RD FLR repair Supply air fan 3A-1A. No power to it after power bump over the weekend.
FO-318889	6/3/2015	6/16/2015		Please assist Mike Pummill to pick up a double drinking fountain in Trades lockup at Holden for Science / Engineering Library
FO-318905	6/3/2015			**ADDING ELECTRICIAN: Unwire unit heater #2 in penthouse. Also rewire after new unit is installed. See Jim Hill  Fitter repair leaking unit heater #2,,,,,,,,,,,,, JH/ 2-2-15 ,,,,,,,,,,
FO-318943	6/3/2015	6/4/2015		**ADDING LABORER: Transport new coil from Stockroom to Penthouse of Lande. See Jim Hill for assistance  Fitters, please repair leak in chill water coil on AHU-4. Priority: High. ,,,,,,,,,,,,,, JH/4-8-15 ,,,,,,,,,,,,,
FO-318963	6/4/2015	6/4/2015		trade electrians priority medium R/R PENTHOUSE please service ahu # 5 here in pent house cannot run unit in auto mode my have a problem with the circuit board
FO-318990	6/4/2015	6/4/2015		fan motor bearings very noisy, it would appear replacement is required
FO-319017	6/4/2015	6/4/2015		Clean up leaves that has fallen down the grating outside of Prentis. The leaves collect at the basement level, and you have to go thru the Air Handler to access the exterior where the leaves has collected.
FO-319199	6/8/2015	6/10/2015		laborer- med priority- please deliver 2 5 gal units of Neutramine to boilerroom.
FO-319209	6/8/2015	6/9/2015		Please check dusk to dawn lights on the North side of the building, behind London Luggage. They are not on at night. Also check the lights on the poles in the emergency generator(s) area.
FO-319285	6/9/2015	6/10/2015		To laborer, please deliver 4-five gallon pails of Aquaklean, and 3-five gallon pails of halochlor, to room 25 community Arts.
FO-319326	6/10/2015	6/11/2015		Elect. Med Priority Supervisory alarm on fire panel will not reset. (Duct Basement ahu 4 hot supply rmc.)  Completed 6-11-2015 SRP
FO-319337	6/10/2015			Trade: Electrician Priority: Medium Please repair or replace emergency exit lighting on the 1st floor east (hallway), 2, 3 & 4 floors at both ends.
FO-319374	6/10/2015	6/10/2015		Meet Centerline Electricians at Scott Hall, and assist them in locating panel.
FO-319376	6/10/2015	6/12/2015		Trade: Electrician Priority: Medium Please fix or replace engine exhaust fan indicating light that is not working outside engine lab 1330, it is above the door to the lab.
FO-319377	6/10/2015	6/12/2015		Trade: Electrician Priority: Medium Bench top electrical outlet is working intermittently, please repair.
FO-319449	6/11/2015	6/12/2015		**ADDING LABORER: Transport booster pump in front of Pipe Shop to basement mechanical room. See Gerry for assistance  Plumber; Medium Please install water booster pump; 071-DWBP-001. **GUARDIAN REBUILDING THIS PUMP ON FO#306234 JWT 1/22/15 ,,,,,,,,,,
FO-319591	6/15/2015	6/16/2015		**ADDING LABORER: Remove old steam coil and debris from 3rd floor mechanical room 0346. See Eric for assistance if needed  **THIS COIL IS UNREPAIRABLE AT THE HEADER. NEW COIL MEASURED FOR QUOTE 1/30/15 JWT COIL IS CURRENTLY OUT OF SERVICE  EMERGENC

WO	Recieved	Finished	Total	Request
FO-319596	6/15/2015	6/16/2015		<p>**ADDING LABORER: Please pick up wood skid from coil on dock.  **ALSO pick up wood skid and 4 wheel cart at Scott Hall loading dock. See Ron Clark if needed</p> <p>Fitters, please repair leak in chill water coil on AHU-4. Priority: High. ,,,,,,,,,, JH</p>
FO-319598	6/15/2015	6/18/2015		Clean all debris out of rooms 020, and 353, and dispose of. Also sweep room out.
FO-319871	6/15/2015	6/19/2015		Clean all debris out of room 3248, and dispose of all. Also sweep room out.
FO-319872	6/15/2015	6/24/2015		Clean all debris out of room 0377, and dispose of all. Also sweep room out.
FO-319873	6/15/2015	6/19/2015		<p>Clean all debris out of rooms 030, and 305, and dispose of all. Also sweep room out.</p> <p>See Building Coordinator.</p>
FO-319875	6/15/2015	6/18/2015		Clean out all debris in room 049 by the service elevator, and dispose of all. Also sweep room out.
FO-319876	6/15/2015	6/16/2015		Clean all debris out of rooms 278, and 406, and dispose of all. Also sweep room out.
FO-319890	6/15/2015	6/24/2015		Clean out electrical room across from the elevator of the lamps, and debris left by WSU Electricians.
FO-320066	6/17/2015			<p>**ADDING LABORER: Please provide gondola to clear trench drain and haul off debris. See Mike McAlinden</p> <p>SHIFFMAN LIBRARY LOADING DOCK DRAIN AND EMERGENCY EXIT DOOR DRAIN BOTH NEED TO BE CLEANED ,,,,,,,,,, MM/6-16-15 ,,,,,,,,,</p>
FO-320108	6/18/2015	6/19/2015		<p>Go to Winston Brothers Iron &amp; Metal, and pick up 4 collapsible cardboard recycling bins, and deliver to Stockroom.</p> <p>Let Dave Kuffner know when you're about to leave so he can call them, and let them know you're on your way there.</p>
FO-320151	6/18/2015			<p>**ADDING LABORER: Erect scaffold near AH#1. See Eric for location</p> <p>Pipe fitters: Please repair steam leak from the flanges of 8" steam shut off valve next to AHU-1. Priority: med.,,,,,,,,,, EA/6-15-15 ,,,,,,,,,</p>
FO-320155	6/18/2015	6/29/2015		<p>**ADDING LABORER: Repair mortar outside east wall of boiler room where brick wall meets parking deck to avoid water from migrating to Lisa's office and the control center during heavy rain. See Dave Kuffner for detail</p> <p>CEILING LEAK. 1ST FLOOR SERVIC</p>
FO-320191	6/19/2015			Room 4200. President's suite. The conference room has an electrical problem. The light over the President's desk has an electrical problem.
FO-320260	6/22/2015	6/25/2015		Repair outside lighting control. Perimeter lights are staying on in daytime.
FO-320292	6/22/2015	6/23/2015		<p>Trade: Electricians  Priority: Medium  R/R BLDG Please adjust clocks in Chemistry. Clocks are slow from power bump on Friday.</p> <p>Completed 6-23-2015 SRP</p>
FO-320293	6/22/2015	6/25/2015		<p>Trade: Electricians  Priority: Medium  R/R BLDG Please adjust clocks in the Science and Engineering Library. Clocks are slow from power bump on Friday.</p> <p>Completed 6-25-2015 SRP</p>
FO-320348	6/23/2015			<p>2 Requests:</p> <p>1. Convert existing Exit Lights into Exit/EBU's in the Basement, between the 2 stairwells.</p> <p>2. Install an EBU in the Men's restroom, and the Women's also in the Basement.</p>
FO-320438	6/23/2015	6/24/2015		<p>**ADDING LABORER: Please transport backflow from stockroom to fire pump room. See Don Bear for assistance</p> <p>BFS/2015  Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,</p>
FO-320440	6/23/2015			Cut up flat stock in stockroom . See Larry Cook for direction

WO	Recieved	Finished	Total	Request
FO-320445	6/24/2015			ELECTRICIANS:FIRE ALARM PANEL BATTERY HAS LOW VOLTAGE.PRIORITY:MEDIUM.
FO-320446	6/24/2015			Trade: ElectricianPriority: MediumThree flood light at loading lock are burned out or not working. SAFETY CONCERN. Very dark at night.
FO-320450	6/24/2015			Electrician needed for Shut-Down at 6AM Friday 6/26/2015 in new Electrical Rm., as per Larry Fodor.
FO-320487	6/24/2015			**ADDING LABORER: Please transport sink in stockroom to Scott Hall room3108. See Mike McAlinden  (**) PO REQ DK 6-2-15 The sink that was recently repaired is unfortunately leaking quite a bit, and cannot be used. If someone could come repair it agai
FO-320600	6/26/2015			Go to 1200 Holden, cut up the old coils, and bring them back to the stockroom.
FO-320664	6/27/2015			Repair 11 fire troubles on Siemens fire panel at McGregor.
FO-320665	6/27/2015	6/29/2015		Repair fire trouble on fire panel at Science Hall, "Ground Fault".  Completed 6-29-2015 SRP
FO-320678	6/29/2015	6/29/2015		PLEASE RUN GENERATOR TEST AFTER LUNCH
FO-320709	6/29/2015			**ADDING ELECTRICIAN: Disconnect and reconnect power for condensate pump #1. See Ron Clark  (**) PO REQ DK 6-17-15 Repair condensate return pump #1 at McGregor. The unit is tripping on motor overload. ,,,,,,,,,,,,, RC/ 6-15-15 ,,,,,,,,,,,,,,
FO-320717	6/29/2015			**ADDING LABORER: Please transport scissor lift to fish bowl area . See Jim Hill for location  PM heating coils in fish bowl ,,,,,,,,,,,,,, JH/ 3-19-15 ,,,,,,,,,,,,,,
FO-320732	6/29/2015	6/30/2015		**ADDING ELECTRICIAN : Rewire condensate pump on the west side of mechanical room 00003 . See Ron Clark if needed  (**) PO REQ DK 6-10-15 fitters R/R RM 00003/MECH RM replace the pump seal on the west condensate pump on the condensate receiver pri
<b>T - Locksmith</b>			<b>1</b>	
FO-320285	6/22/2015			New KeyLost / StolenKey #: 71111 & 63624Key Holder ID: Stephanie SpielmannQty: 10 (5-of each)action: Please complete asap.Thank you
<b>T - Painter</b>			<b>4</b>	
FO-318397	6/1/2015			repair plaster damage and repaint in room 119 Cecelia Dawson office
FO-318401	6/1/2015	6/22/2015		repair plaster wall as necessary near condensate pumps and waterprof this wall in mechanical room to prevent water damage in to office space
FO-318922	6/3/2015			Requesting to seal area above lab 450 to eliminate ceiling leaks. See Corey Blair for location if needed. Ken aware of this request
FO-319564	6/15/2015			PAINTER DEPT-PLEASE PAINT CHILLER/MECH ROOM FLOOR, MECH ROOM FLOOR LOOKS GROSS
<b>T - Pipefitter</b>			<b>16</b>	
FO-318439	6/1/2015	6/4/2015		R/R RM 540 Please replace Heating Valve in room 0540 near SOUTH DOOR. MED,,,,,,,,,,,,,JH/6-1-15 ,,,,,,,,,,,,,,
FO-318752	6/1/2015	6/4/2015		Steamfitters- med priority. Repair or replace malfunctioning reheat valve on reheat coil serving room 133 ,,,,,,,,,,,,,, ME/6-2-15 ,,,,,,,,,,,,,,
FO-318859	6/2/2015	6/8/2015		Steamfittes. Med priority- replace malfunctioning HW valve on reheat coil for south hallway. Repipe strainer system to make it possible to do maintenance on steam valve. See Engineer for details. ,,,,,,,,,,,,,, ME/6-3-15 ,,,,,,,,,,,,,,
FO-318869	6/3/2015	6/3/2015		Trade: Pipe Fitter Priority: Medium Tag #090-WSS-001 Elbow is leaking on softener water line in the boiler room please repair. ,,,,,,,,,,,,,, JH/6-3-15 ,,,,,,,,,,,,,



WO	Recieved	Finished	Total	Request
FO-319117	6/5/2015	6/17/2015		Pipefitters Please install new condensate drain line in new heat pump; Run new to existing trap. Med. Priority.. From FO 311927 (HP Replacement) ,,,,,,,,,, ME/6-5-15 ,,,,,,,,,
FO-319189	6/8/2015			steam fitters- med priority- Replace malfunctioning 3 way valve on reheat coil for west hallway. Install ball cock valve on coil strainer for system servicing. ,,,,,,,,,, EA/6-8-15 ,,,,,,,,,
FO-319312	6/9/2015			Provide bypass on HWH in 3rd floor mechanical room prior to repairs being made on heat exchanger  NEED HOT WATER TANK TURNED ON. 4TH FLOOR. CALL STAR AT 7-1757 FOR MORE DETAILS. ,,,,,,,,,, ME/6-10-15 ,,,,,,,,,
FO-319423	6/11/2015	6/12/2015		Fitters, repair leaking heat exchanger ay flange priority medium ,,,,,,,,,, JH/6-11-15 ,,,,,,,,,
FO-319578	6/15/2015			PF Med Priority/Make necessary repairs to drip pans on ahu 1-7 water leaking through bases of fan housings. see engineer
FO-319879	6/15/2015			Pipe fitters: Please repair steam leak from the flanges of 8" steam shut off valve next to AHU-1. Priority: med.,,,,,,,,,, EA/6-15-15 ,,,,,,,,,
FO-319887	6/15/2015			(**) PO REQ DK 6-17-15 Disconnect water to and from absorption chiller condenser, to facilitate leak check and repair.,,,,,,,,,, ME/6-15-15 ,,,,,,,,,
FO-319930	6/16/2015			REWIRE CONTROL BOX VALVE: CONTACT JOHN TOWLE FOR DETAILS.  AHU#5 HEATING VALVE NEEEDS REPLACING ,,,,,,,,,, ME/6-17-15 ,,,,,,,,,
FO-320620	6/26/2015			FITTERS: Please replace CHILLED WATER VALVE on AHU#1 in lower level mech. room.....CB/EA.....6-26-15 MED.
FO-320716	6/29/2015			Pipe fitters: please unplug or replace plugged up reheat lines for room 226.6, the reheat unit is in room 105.4.Priority: med. ,,,,,,,,,, JH/6-29-15 ,,,,,,,,,
FO-320721	6/29/2015	6/30/2015		Please replace 2 victaulic valves on the suction and discharge side of pump 5 near engineers office. can not isolate pump.,,,,,,,,,, JH/ 6-29-15 ,,,,,,,,,
FO-320726	6/29/2015			Trade: Pipefitter Priority: Medium Please repair leaking flange at the west boiler room reducing station.,,,,,,,,,,EA/6-29-15 ,,,,,,,,,
<b>T - Plumber</b>			<b>27</b>	
FO-318385	6/1/2015	6/5/2015		**ADDING PLUMBERS: Provide bypass on HWH so unit can be repaired by Pipefitter (Marty) ,,,,,,,,, DB/6-1-15 ,,,,,,,,,  NEED HOT WATER TANK TURNED ON. 4TH FLOOR. CALL STAR AT 7-1757 FOR MORE DETAILS. ,,,,,,,,,, ME/5-22-15 ,,,,,,,,,
FO-318758	6/2/2015	6/4/2015		R/R 4TH FLR WOMENS RR (ONLY ONE ON FLR) 1ST STALL TOILET IS PLUGGED ,,,,,,,,, MM/6-2-15 ,,,,,,,,,
FO-318894	6/3/2015	6/4/2015		Investigate source of leak from ceiling in Studio ,,,,,,,,,, MP/6-3-15 ,,,,,,,,,
FO-318932	6/3/2015			Trade: Plumbers Priority: Medium  Please repair the drinking fountain in the basement elevator lobby. ,,,,,,,,,, MP/6-3-15 ,,,,,,,,,
FO-318976	6/4/2015			Trade: Plumber Priority: Medium Sump pump #2 located in fan room #2 is not pumping. Casing was warm and sump level was not decreasing. ,,,,,,,,,, MP/6-4-15 ,,,,,,,,,
FO-318989	6/4/2015	6/15/2015		R/R RM 456/MENS RR @ ENTRANCE FACING RM URINAL ON THE (R) URINAL ISN'T FLUSHING ,,,,,,,,,, GS/6-4-15 ,,,,,,,,,
FO-319127	6/6/2015	6/9/2015		Plumber Medium priority Please repair Sloan valve at the last toilet located across R207 women's rest room. Water is running continuously. ASAP ,,,,,,,,,, MM/6-8-15 ,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-319128	6/6/2015	6/9/2015		Plumber Medium 1st floor near main entrance. Two toilet at the end of the rest room running water. Toilets isolated. Bad Sloan valve and need valve kit.,,,,,,,,,,,,,, MM/6-8-15 ,,,,,,,,,,,,,,
FO-319183	6/8/2015	6/11/2015		Plumbers: Basement men's restroom toilet back-up and needs snake-out. Stall door has sign saying, "Out of order." Medium priority. ,,,,,,,,,,,,,, GS/6-8-15 ,,,,,,,,,,,,,,
FO-319184	6/8/2015	6/11/2015		Plumbers: 2nd floor man's restroom urinal backs up and needs to be snaked-out. Urinal has a bag placed over it. See engineer if you need to obtained access to 2nd floor elevator. Medium priority. ,,,,,,,,,,,,,, GS/6-8-15 ,,,,,,,,,,,,,,
FO-319185	6/8/2015			Plumber; Medium Please re-seal the down comer joint on the surface water drain line located in the custodial closet across from room 00130.10. When heavy rain occurs water will leak out onto the floors. ,,,,,,,,,,,,,, MP/ 6-8-15 ,,,,,,,,,,,,,,
FO-319396	6/10/2015	6/11/2015		The tall water fountain across from room 381 (there are two) has a blocked drain. It needs to be cleared and bowl area cleaned. ,,,,,,,,,,,,,, MM/6-11-15 ,,,,,,,,,,,,,,
FO-319429	6/11/2015	6/15/2015		PLUMBERS: Please repair URINAL(left) 4th floor mens room. MED.,,,,,,,,,,,,,, GS/6-11-15 ,,,,,,,,,,,,,
FO-319448	6/11/2015			Plumber; Medium Please install water booster pump; 071-DWBP-001. **GUARDIAN REBUILDING THIS PUMP ON FO#306234 JWT 1/22/15 ,,,,,,,,,,,,,, GS/6-11-15 ,,,,,,,,,,,,,
FO-319471	6/11/2015	6/12/2015		R/R 3RD FLR WOMENS RR BOTH SINK FAUCETS NEED BATTERIES REPLACED BEEPING & LOW WATER PRESSURE ,,,,,,,,,,,,,, MM/6-11-15 ,,,,,,,,,,,,,,
FO-319535	6/14/2015	6/15/2015		Repair #1 sanitary sump pump at Fitness Center. Pump was found running continuously on Sunday, casing hot, water level 4 feet from top of sump.,,,,,,,,,,,,,, DB/6-15-15 ,,,,,,,,,,,,,,
FO-319982	6/16/2015			Plumbers: Please snake-out 2nd floor men's urinal that is bagged-out. Backs-up when flushed. Medium priority. ,,,,,,,,,,,,,, GS/6-16-15 ,,,,,,,,,,,,,,
FO-319983	6/16/2015	6/22/2015		Plumber; Medium Please repair the leaking urinal trap located in the men's restroom on the west end of the eleventh floor.,,,,,,,,,,,,,, MP/6-16-15 ,,,,,,,,,,,,,,
FO-320069	6/18/2015	6/22/2015		Trade: Plumber Priority: Medium R/R BSMT Men's restroom next to elevator has urinal plugged. At present covered with plastic bag.,,,,,,,,,,,,,, MM/6-18-15 ,,,,,,,,,,,,,,
FO-320126	6/18/2015	6/23/2015		Trade: Plumber Priority: Medium Tag#090-SP-005 R/R RM 310/MECH RM Sump pump #5 will not shut off. This pump was installed by the plumbers around a year ago.,,,,,,,,,,,,,, GS/6-18-15 ,,,,,,,,,,,,,,
FO-320244	6/20/2015	6/22/2015		Trade: Plumber Priority: Medium R/R RM 00032/MENS RR Broken Sloan valve-Handicap stall. Please check. ,,,,,,,,,,,,,, MP/6-22-15 ,,,,,,,,,,,,,,
FO-320245	6/22/2015	6/23/2015		Trade: Plumber Priority: Medium R/R RM 00032/MENS RR one of the Urinal has caution tape. Please check. ,,,,,,,,,,,,,, MP/6-22-15 ,,,,,,,,,,,,,,
FO-320316	6/22/2015			Plumbers --Priority Medium R/R RM 00001/MECH RM Eye wash in boiler room leaking ,,,,,,,,,,,,,, MP/6-22-15 ,,,,,,,,,,,,,,
FO-320506	6/24/2015			Plumber, Medium, Hot water storage tank is leaking, repair or replace as necessary. "Request" request sent to Tilson. He usually directs me to submit a request, after he requests the request . Whew! Will be off the next to days, so, I'm doing it now.,,,
FO-320533	6/25/2015			Trade: Plumber Priority: Medium Pump out water from fresh air intake by PLD room, clear drain if it has one. There is lots of standing water in this shaft. I showed Don (Plumber) the location of this shaft today. ,,,,,,,,,,,,, DB/6-25-15 ,,,,,,,,,,,,,,
FO-320693	6/29/2015	6/30/2015		AUTOMATIC SINK FAUCET IS NOT WORKING. (LEFT SIDE) 4TH FLOOR MEN'S RESTROOM. ROOM 456.,,,,,,,,,,,,,, MP/6-29-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-320720	6/29/2015	6/30/2015		Plumber; Medium Please repair the sink in the women's restroom located in the basement of the building. The sink is pulling away from the wall. .... MP/6-29-15 .....
<b>T - Roofing</b>			<b>4</b>	
FO-318404	6/1/2015			**ADDING ROOFER: Roof leaking around roof conductor water migrating into lab 450. **Reoccurring from last year  LAB 450 CEILING LEAK ....., EA/6-1-15 .....
FO-319484	6/12/2015			Roofer Med. PriorityRoof still leaking on boiler Rm, SW corner. See FO 317192
FO-320037	6/17/2015			Trade: Roofer Priority: Medium R/R ROOF AREA Please repair roof around the cooling tower return line. Contact Percy at 313-590-7142 or John at 313-684-1706.
FO-320724	6/29/2015			**ADDING ROOFER: Structural leak at Corner of building leaking into atrium during rain storms. Near room 113 shipping / receiving. See Eric Adams for more detail if needed  CEILING LEAK. 1ST FLOOR ATRIUM NEAR WINDOW AND ROOM 111.3. ...., EA/6-2
<b>T - Sheetmetal</b>			<b>1</b>	
FO-319159	6/8/2015			Trade: Sheet Metal Priority: Medium Please repair or replace drip pan on AHU #3. Bottom of the pan is loose and flapping in the breeze.
<b>Low</b>			<b>363</b>	
<b>T - Carpenter</b>			<b>66</b>	
FO-318370	6/1/2015	6/1/2015		Carpenter; lowPlease replace the bad ceiling tile located in Suite 7501.
FO-318371	6/1/2015	6/1/2015		Carpenter; lowPlease replace the bad ceiling tile located outside of Suite 7206.
FO-318398	6/1/2015	6/12/2015		Install ceiling hatch in ceiling outside door 2322. Hole in asbestos already provided
FO-318400	6/1/2015	6/2/2015		Please modify Pipe Shop window by welding table for exhaust. See John Towle for direction
FO-318408	6/1/2015	6/16/2015		ADDING PAINTER/PLASTER (AFTER CARP REPAIR WALL PAINT REPAIRED WALL) R/R 1ST FLR HALLWAY REPAIR WALL WHERE wall doorstop pushed through drywall. Located outside of stairwell F, next to wooden doors on 1st floor.
FO-318412	6/1/2015	6/16/2015		ADDING PAINTER (AFTER CARPENTERS REPAIR PAINT NECESSARY AREA) R/R 2ND FLR REPAIR drywall corner beads; stairwell F, 2nd floor hallway
FO-318414	6/1/2015	6/2/2015		Repair 2 hole in wall on 1st floor near bathrooms, Add louvered vent to 1 of the holes. See John Towle for better location and direction on job
FO-318755	6/2/2015	6/23/2015		R/R RM 404 Several tiles have come up on the north side of the room where the overhang of the building is. I have stacked these tiles on one of the bench tops near the front of the room.
FO-318774	6/2/2015	6/3/2015		Carpenter; Low Please replace the two bad ceiling tiles in the hallway outside of Suite 5110.
FO-318788	6/2/2015	6/9/2015		TEAM LEADER TIME ( JUNE 2015 )
FO-318834	6/2/2015	6/4/2015		The fence on the garage side of the building needs to be repaired. The opening is large enough for a person to walk through.
FO-318836	6/2/2015	6/3/2015		CARPENTERS TO ADD DOOR SWEEPS & WEATHER STRIP ON 2 DOORS / CLOSE GAPS SIDE OF DISHWASHER /PULL DISHWASHER OUT
FO-318842	6/2/2015	6/10/2015		CARPENTERS TO BLOCK UP ACCESS HOLE FOR THE PLUMBERS 3RD FLOOR LOCATION
FO-318868	6/3/2015	6/3/2015		R/R LOBBY DOOR TO ENTRANCE DOOR #080 04S has a broken closure again...This is the 3rd time over the past two months. Please see Bob Ostrowski on specifics. Thank You. REFER TO FOLLOWING WOS': 1) FO-314527 *04/17/15* 2) FO-326879 *05/11/15/Bruce Lan
FO-318918	6/3/2015	6/4/2015		Carpenter; Low Please replace the bad ceiling tile at Suite 4000 area, fourth floor elevator lobby area and hallway boutside of Suite 4114.

WO	Recieved	Finished	Total	Request
FO-318978	6/4/2015	6/4/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES.(FO-318924)PRIORITY-LOW.
FO-318982	6/4/2015	6/4/2015		R/R ENT DOOR #083-03N stays ajar intermittently. Door closer needs adjustment
FO-319010	6/4/2015	6/5/2015		R/R RM 00084 Door handle needs to be repaired; very loose and difficult to lock and unlock.
FO-319039	6/5/2015	6/8/2015		SAFTEY TIME FOR MONTH OF JUNE.
FO-319043	6/5/2015			Please erect scaffold in Lecture room 101. There are 2 lights fixtures that need to be repaired. See Paul Prouty for locations.
FO-319114	6/5/2015	6/9/2015		Carpenter; LowPlease replace the bad ceiling tile in the hallway outside of Suite area 2119.
FO-319124	6/8/2015	6/10/2015		CARPENTERS TO CAULK EXTERIOR PENETRATIONS NORTH SIDE OF BUILDING GROUND LEVEL
FO-319136	6/8/2015	6/8/2015		safety railing pulled off wall basement machine room 16
FO-319286	6/9/2015	6/10/2015		Receiving doors on the east side of the building need to be tagged, per Joe Foucher.
FO-319287	6/9/2015	6/10/2015		Rollup door is improperly tagged. Tag number should be 104-1OH, not 104-01E. Please change tag numbers, per Joe Foucher.
FO-319406	6/11/2015	6/11/2015		CARPENTER TO REPLACE WINDOW STOPS ON BOARDED UP WINDOW
FO-319407	6/11/2015	6/11/2015		CARPENTERS TO CINDER BLOCK UP PLUMBING REPAIR WOMENS BATHROOM NORTH END OF STADIUM
FO-319482	6/11/2015	6/12/2015		Hello- The Men's restroom on the 7th floor will not close fully. Building engineer has inspected, and advised that a work order be placed for service. Please bill to index 227149.
FO-319509	6/12/2015	6/12/2015		Please R/R Lisa's door. Thank you
FO-319522	6/12/2015			R/R ENTRY DOOR #005 016N The morning custodian told me this today she has been unable to unlock door 16 (north facing stairwell) all week. She thinks the lock is broken.
FO-319538	6/12/2015	6/16/2015		the door to this room Rm 125 , will not close without forcing it too. the lock is working but the air pressure keeps forcing the door open. thanks Michelle
FO-319577	6/15/2015	6/15/2015		LOCKSMITH TO REPAIR / REPLACE CLOSER DOOR #129
FO-319943	6/16/2015	6/17/2015		R/R 1ST FLR Child Development's west interior double doors scrape each other and stay ajar, causing door alarms. Alarm keypad inside north vestibule must be disarmed before entering area.
FO-319985	6/16/2015	6/17/2015		Entry door into office pod on third floor, North, in the Cohn building is not closing all of the way. This is a "card reader" door and needs to close completely for security purposes.
FO-319993	6/16/2015	6/16/2015		INSTALL NEW FLOORING LANDING 1ST FLOOR PALMER SIDE
FO-320050	6/17/2015	6/19/2015		I need someone to show me, step by step how to reset the unican key pad system that's in the MEB building as well as how to change the batteries. I did submit a similar WO back in February, but no one came.
FO-320061	6/17/2015	6/17/2015		CARPENTERS TO INSTALL SAFETY RAILING ON THE ROOF
FO-320073	6/18/2015	6/18/2015		CLEAN OUT ATTIC STOCK CARPENTERS ALL CTI ROOMS 1ST FLOOR
FO-320076	6/18/2015	6/23/2015		CARPENTERS TO CLEAN OUT ALL CTI STORAGE CLOSET'S OF ATTIC STOCK MATERIALS THRU OUT CAMPUS
FO-320079	6/18/2015	6/19/2015		Please replace damaged ceiling tile in room 356 Cohn.
FO-320203	6/19/2015	6/23/2015		R/R RM 204 Two lower balcony seats, A20 and C39 are not secure to the floor and may pose a safety issue with a patron. Please check and repair.Thanks
FO-320205	6/19/2015	6/22/2015		R/R Door 028-03E intermittently stays ajar. ADJUST Door closer's latching speed is intermittently too slow.
FO-320206	6/19/2015	6/22/2015		R/ 1ST FLR North stair door across from room 138 stays ajar because it's scraping the door frame. NEED DOOR CLOSURE OR DOOR ITSELF ADJUSTED
FO-320208	6/19/2015	6/22/2015		R/R 1210/Custodial closet, interior door knob fell off. Please replace
FO-320259	6/19/2015	6/22/2015		Main entrance door is not unlocking. This is not an emergency.
FO-320232	6/19/2015	6/23/2015		R/R BLDG Repair boards on porch and ramp to entrance to training trailer. They are popping up.

WO	Recieved	Finished	Total	Request
FO-320280	6/22/2015	6/22/2015		Carpenters: Please repair door closer, the arm is broken. Priority: low.
FO-320286	6/22/2015			Trade: Carpenters Priority: MediumThe 3rd floor nFab clean room is experiencing critters (birds) getting into the clean room. Please seal any openings that are allowing them to get into the building.Please contact either one of the following techs becau
FO-320294	6/22/2015	6/23/2015		R/R RM 2063 Key will not open this door, when turning the handle there is a clicking sound, but the door will not open
FO-320302	6/22/2015	6/23/2015		Locksmith R/R RM 110 REpair/replace door handle room 110. Door is difficult to close and lock.
FO-320311	6/22/2015	6/23/2015		R/R RM 126 Women's restroom, Please lubricate the hinges on the exterior door into the bathrooms as well as the doors into the stalls within the bathroom.
FO-320312	6/22/2015	6/23/2015		R/R RM 128/men's restroom, Please lubricate the hinges on the exterior door into the bathrooms as well as the doors into the stalls within the bathroom.
FO-320326	6/22/2015	6/23/2015		Actual location is the University Art Collection, Room 0014 in the sub-basement of the Old Main annex. (there is no drop-down location for this office). Our door is not closing properly. NOTE: THIS IS AN ALARMED DOOR. PLEASE CONTACT SANDRA TO SCHEDULE
FO-320383	6/23/2015	6/23/2015		Need a locksmith to unlock 8th/9th floor lounge.
FO-320409	6/23/2015	6/24/2015		R/R RM 419/LAB There is a inner door to this room that is hard to open. Door is very sticky.
FO-320415	6/23/2015			CARPENTERS TO REPLACE CEILING TILES 1ST FLOOR SHERYL MACGILLIS OFFICE
FO-320429	6/23/2015			R/R RM 2126 Replace ceiling tiles that have been missing since a leak was repaired over 6 months ago. Lab contact, Dr. Farhad Ghoddoussi 577-6910 or 745-6949.
FO-320442	6/24/2015			CARPENTER TO RECLAIM DOOR HARDWARE OFF METAL DOORS ROOM #3023
FO-320469	6/24/2015	6/25/2015		CARPENTERS TO REPAIR GATE BETWEEN ALLEY & HOUSE SOUTH SIDE OF 5057 WOODWARD
FO-320473	6/24/2015			RNR padlock for grounds storage ATTN: Cleon
FO-320479	6/24/2015	6/25/2015		The lock on the sliding glass door between Towers Lobby and Towers Café is not locking.
FO-320480	6/24/2015	6/25/2015		Main entrance door is not unlocking from the outside.
FO-320504	6/24/2015			CARPENTERS TO REPAIR KEY SWITCH ROLLING GATE ENTRANCE
FO-320559	6/25/2015			the exit doors to this suite 120 are not closing and latching , could be air pressure is too high ? thanks Michelle
FO-320610	6/26/2015	6/29/2015		R/R RM 00328 Our keys are sticking in the lock when we try to enter the faculty suite. We have to jiggle the key in order to get it to go all the way in the lock and make it turn.
FO-320684	6/29/2015			TO ORDER 3 SETS OF INTERMEDIATE RIXSON PIVOT HINGES / RIGHTS & LEFTS
<b>T - Electrician</b>			<b>91</b>	
FO-318350	6/1/2015			Time for Laborer to clean shops for the Trades for the month of June, 2015.
FO-318351	6/1/2015	6/30/2015		Time for Electricians to repair Wall Clocks throughout the Campus for the month of June, 2015.  Completed 6-30-2015 SRP
FO-318352	6/1/2015			Administrative time for Team Leader in Electric Shop for the month of June, 2015.
FO-318353	6/1/2015			Time for Electrical Crew to attend Safety Meeting in shop for the month of June, 2015.
FO-318377	6/1/2015	6/4/2015		EXIT sign in room 044.
FO-318379	6/1/2015	6/4/2015		Room 040 has 2 electrical problems.
FO-318406	6/1/2015	6/8/2015		pls deliver 3 pails of lokor and 2 gasket sets for the comp center boilers
FO-318429	6/1/2015	6/8/2015		room 337 has 7 electrical problems.
FO-318430	6/1/2015	6/8/2015		Electrical Problems and number of per room. 355 has 2 electrical. 359 has 12 electrical. 351 has 7 electrical. 357 has 1 electrical. 363 back room has 1 electrical. 363 main room has 2 electrical. The third floor has 3 electrical problems.
FO-318444	6/1/2015	6/4/2015		Replace bad clock on 5th floor near room #5176  Completed 6-4-2015 SRP

WO	Recieved	Finished	Total	Request
FO-318446	6/1/2015	6/3/2015		Replace bad clock in basement near room #0154.  Completed 6-3-2015 SRP
FO-318447	6/1/2015	6/4/2015		Replace bad clock in room #1136.  Completed 6-4-2015 SRP
FO-318451	6/1/2015			Room 3660 - 4 Lights out... there is 2 EP's in this area...the lights are directly over a cubicle, making it dim in this area.  This will be forwarded to the electricians.
FO-318768	6/2/2015	6/4/2015		REPLACE BLOWN OUT LIGHTS. ROOM 200.
FO-318806	6/2/2015	6/15/2015		Trade: Electricians Priority: low to medium R/R RM 00022/MECH RM Please repair or replace a shorted light fixture socket located near the Engineer's office rm 0018.
FO-318827	6/2/2015	6/26/2015		To electricians, R/R RM 00047/MECH RM Supply fan 2 in the Art building will not stay on line. Have to continually press reset which is no longer holding circuit closed. Please repair or replace.
FO-318871	6/3/2015	6/12/2015		the fixture is near the wall across from elevators. coming in the entrance from the lecture hall on first floor of the alex manoogian building.
FO-318890	6/3/2015	6/4/2015		Disconnect welding pigtails at Rackham basement mechanical room and Chemistry Penthouse. Don Brown knows locations
FO-318955	6/4/2015			Light fixture in back of the cages of the grounds dept has an electrical problem.
FO-318986	6/4/2015			Handicap men's restroom on the 1st floor has an electrical problem over the sink. I don't have any LED fluorescent lights at my disposal.
FO-318987	6/4/2015	6/19/2015		Light fixture across between rooms 045 and 047 has an electrical problem.
FO-319023	6/4/2015	6/10/2015		Two Light out in lab room 255. Light needs to be fixed as soon as possible.
FO-319116	6/5/2015	6/9/2015		REMOVE ALL CONTRACTORS NAME SIGNS OFF ALL BLACK FENCES ON CAMPUS AND GIVE TO TIM HERR.
FO-319120	6/5/2015	6/8/2015		Laborer-- Priority High R/R 00047/MECH RM Please deliver 1) 5 gallon buckets of Lokor 2000TM to boiler room
FO-319144	6/8/2015	6/10/2015		LABORER  DELIVER TO SCOTT HALL ROOM 100:  NITROKLEENZ 17010050 10 PAILS  PLEASE SEE ENGINEER BELCHER TO OPERATE LIFT  FO#297763
FO-319145	6/8/2015	6/9/2015		LABORER  PLEASE DELIVER TO SCOTT HALL PENTHOUSE  NITROKLEENZ 17010050 10 PAILS HALOCHLOR 17010100 10 PAILS AQUAKLEEN 17010106 15 PAILS LOKOR 17010060 10 PAILS  FO#297763  SEE ENGINEER BELCHER TO OPERATE DOCK LIFT
FO-319153	6/8/2015	6/11/2015		Rm. 3450 Need light(s) repaired. There is 1 electrical problem.
FO-319158	6/8/2015	6/12/2015		Room 1128 - Please check automatic timer for office lights. Lights our turning off often when people are working in office.
FO-319180	6/8/2015			Electrical wall outlet on one side of lab #2524 is not working. It is labeled for reference. Qian can be reached at 7-0138. Thank you.
FO-319200	6/8/2015	6/9/2015		laborer- low priority- Pleas deliver the following chemicals in 40gal drums. Aquaclean, Lokor, Halochlor, Neutramine, Oxycor, and Quest. ( 1 of each in 40 gallon drums)
FO-319245	6/9/2015	6/10/2015		Room 259 - Electrical Problem - 2 out of 8 of the fixtures are out.
FO-319247	6/9/2015	6/15/2015		Room 255 - Electrical Problem - 2 out of 8 of the fixtures are out.

WO	Recieved	Finished	Total	Request
FO-319250	6/9/2015	6/12/2015		Spot lights in room 610 has 2 electrical problems. (Basement)
FO-319251	6/9/2015	6/19/2015		Spot light outside from room 610 has an electrical problem. (Basement)
FO-319252	6/9/2015	6/12/2015		Hallway between STAIR and the elevators has an electrical problem. (4th fl)
FO-319289	6/9/2015	6/10/2015		Fire alarm warning light is going off in the main foyer. Might be the battery. 6/9/15 lps: Chng to Est for Maihn  Completed 6-10-2015 SRP
FO-319277	6/9/2015	6/15/2015		Purdy Library 3rd Floor Open area across from elevators  Two rows of lights are not working. Check light panel: all switches are on.  Please repair.  Thank you.
FO-319354	6/10/2015	6/17/2015		Please check light fixture in FP&M Stockroom , not working. See Lynda Kinder.
FO-319385	6/10/2015	6/12/2015		pls deliver a keg of lokor to the comp center and 2 pails of nitroklens
FO-319392	6/10/2015	6/15/2015		R&R tagged light fixtures (4) outside/near room 4608.
FO-319438	6/11/2015			Please repair both of the switches in room 4070. and one electrical problem in an office with in 4070. Thank you.
FO-319463	6/11/2015	6/12/2015		R/R RM 00025/MECH RM Please have laborer deliver 1) four 5 gallon pails of Aquaklean to room 25 Comm. Arts. Thank you.
FO-319472	6/11/2015			Install wire mesh in plenum area to stop the leaves from coming in.
FO-319473	6/11/2015	6/15/2015		Install lens in the 2' fixtures, the ones missing.
FO-319475	6/11/2015	6/12/2015		Meet Duane Copeland at Student Center, and bring back the disconnects recently removed from the mechanical room on the 4th floor.
FO-319494	6/12/2015	6/17/2015		Stairwell across from the women's restroom. The electrical problem is between the 1st and 2nd floor.
FO-319501	6/12/2015	6/25/2015		Electrician R/R RM 3119 repair fume hood light. No power to switch lamps replaced. CAUTION content in hood is hazardous.
FO-319513	6/12/2015	6/15/2015		R/R RM 00100/MECH RM please have laborer deliver: 1) 1 pallet of salt to room 100 scott hall thank you
FO-319529	6/12/2015	6/18/2015		R/R Room 310 has an automatic switch to control shutting off the lights when the room is unoccupied, but it takes a very long time to shut off. Can it be adjusted to shut off after a minute or two, please?
FO-319557	6/15/2015	6/19/2015		One of the pull down outlets in room340 non-functional. It is locatedby the sign for table 46 and ia currently pulled down for easy identification.
FO-319558	6/15/2015	6/16/2015		Office 2158 and next door office 2154 shared wall has no power on the electric outlets that are shared. Thank you.
FO-319922	6/16/2015			Replace light bulbs. Fixture is located in cubicle area outside of room 134. It's an electrical problem.
FO-319963	6/16/2015	6/18/2015		In the cold room which is next to/south of 3220 - the power outlet is not working and needs repairing.
FO-319974	6/16/2015	6/30/2015		Please repair both of the switches in room 4070. and one electrical problem in an office with in 4070. Thank you.
FO-319984	6/16/2015			ELECTRICIANS: R/R RM 00187.01/MECH RM PLEASE CHECK A" SUMP PUMP BREAKER TRIPS AS SOON AS PUMP STARTS (PRIORITY HIGH0
FO-320003	6/16/2015	6/25/2015		Transport 3 toilets from clock shop area to Holden Trades lock up. See Gerry for assistance if needed
FO-320047	6/17/2015	6/18/2015		In room 0333 part of the light lens fell down down when I removed the bulbs and it won't go back up in there.  Completed 5-28-2015 SRP  New Lens delivered 6/17/2015.
FO-320077	6/18/2015	6/19/2015		Hallway outside of Range 8.(Basement)
FO-320078	6/18/2015	6/18/2015		Range 153. (1st floor)
FO-320080	6/18/2015	6/18/2015		Hallway in the far back corner outside of Range 141. (1st floor)

WO	Recieved	Finished	Total	Request
FO-320083	6/18/2015	6/18/2015		Range 267. (2nd floor)
FO-320088	6/18/2015			the bulbs have been changed, the fixture is clearly tagged in lobby of education building
FO-320089	6/18/2015			the bulbs were replaced but kept blowing out. the fixture is located upon restroom inner entrance of the 2nd floor woman's restroom.
FO-320090	6/18/2015			4 electrical problems in the lande building room 363.
FO-320091	6/18/2015			2 electrical problems in the lande building room 369.
FO-320121	6/18/2015			R/R BLDG During the generator test today, the simulation of a power failure resulted in none of the emergency lighting wall packs operating. My guess is that the batteries are dead. TROUBLESHOOT REPAIR/REPLACE BATTERIES AS NECESSARY THROUGH OUT BLD
FO-320143	6/18/2015			R/R 3RD FLR Emergency Lighting Battery Units require repair and/or replacement. Check, repair, replace as needed.
FO-320207	6/19/2015	6/25/2015		Electricians, Medium R/R RM 505/MECH-ENG'S OFC Emergency lighting ballast beeping, Eng. Office. Repair or replace as necessary.
FO-320199	6/19/2015			in rooms 330-340 of scott hall there are 15 fixtures out. Lites on and taped cross labs.
FO-320238	6/19/2015	6/19/2015		R/R WEST LAWN Please fill diesel fuel tank ,due to power loss on 6-19-2015.
FO-320247	6/22/2015	6/23/2015		ELECTRICIANS, R/R RM 00347/MECH RM PLEASE REPAIR FIRE ALARM, PANEL IN FAULT. PRIORITY-HIGH  Completed 6-23-2015 SRP
FO-320253	6/22/2015	6/22/2015		Deliver one drum of Oxicor to the Matthaehi boiler room
FO-320269	6/22/2015			First Floor - Unisex restroom has three lights out.
FO-320299	6/22/2015			Hall along side of the food cart. (1st floor)
FO-320300	6/22/2015			There is an electrical problem in the office of the Language and Speech Center. (1st floor) (East end)
FO-320318	6/22/2015	6/26/2015		ELECTRICIANS, PLEASE REPLACE DEFECTIVE CLOCK. (FO-320275) PRIORITY-LOW.  Completed 6-26-2015 SRP
FO-320425	6/23/2015	6/23/2015		We need the Mechanics to come out from Cummins Bridge-way to check for Radiator leaking, and Oil Leak.
FO-320452	6/24/2015	6/24/2015		The passenger elevator has an electrical problem.
FO-320488	6/24/2015			Repair broken lights in grass at Dantos Engineering Building
FO-320493	6/24/2015			Repair Fluorescent lights in the Vanity, in the Bathroom.
FO-320507	6/24/2015			Hall entrance light in front of the Woodcock hall on the 1st floor and light fixture out by the exit door on the third floor in Reuther Library. Hall entrance in front of the Woodcock has an electrical problem. It's a mercury bulb.
FO-320512	6/24/2015	6/25/2015		Pick up sump pump from mechanical room and return to Pipe Shop. See John for location
FO-320570	6/25/2015			Cement Repair, Handrail
FO-320591	6/25/2015			Several fluorescent fixtures that have had their lamps replaced are flickering in our office area. This is very distracting in our office setting.
FO-320597	6/26/2015	6/26/2015		LABORER R/R RM 00100 PLEASE DELIVER TO SCOTT HALL: 1) 1 PALLET WATER SOFTNER PELLETS 17010010  FO#297763 WATER
FO-320598	6/26/2015			LABORER (HIGH) R/R RM PH DELIVER: 1) 10 PAILS NITROKLENZ 17010050 2) 10 PAILS HALOCHLOR 17010100 3) 10 PAILS AQUAKLEEN 17010106 4) 2 DRUMS LOKOR 17010061 5) 8 PAILS LOKOR 17010060  FO#297763



WO	Recieved	Finished	Total	Request
FO-320604	6/26/2015			2 fluorescent lights out in room 385 in manoogian.
FO-320613	6/26/2015	6/26/2015		Replace bad clock near room #422.
FO-320637	6/26/2015			Repair 2 lights in office room 127. there are 2 EP's in this office, This is the coaches room....area a little dim
FO-320666	6/29/2015	6/29/2015		Repair fire panel fault at Hilberry Theater: "Ground Fault, Loop 1".  Completed 6-29-2015 SRP
FO-320679	6/29/2015			ELECTRICIANS, R/R BSMT AREA, PLEASE REPLACE DEFECTIVE EMERGENCY LIGHTING IN HALLWAYS. PRIORITY-LOW
<b>T - Locksmith</b>			<b>71</b>	
FO-318428	6/1/2015	6/16/2015		New KeyNew Staff MemberKey #: NoneKey Holder ID: Bin WuQty: 1action: We need access to our animals in room 515 after-hours. Thanks.
FO-318443	6/1/2015			ReplacementLost / StolenKey #: variousKey Holder ID: Mary LinedeckerQty: 17action: There are multiple cabinets in multiple rooms that we need keys for.
FO-318751	6/1/2015	6/12/2015		New KeyDamagedKey #: 7892Key Holder ID: Li Liu/Dr Jena SteinleQty: 1action: the old key does not working anymore, like to have a replacementAccount #: 69222372
FO-318754	6/2/2015			Lock shop Training for Jeff Hammell
FO-318809	6/2/2015	6/15/2015		Core ChangeLost / StolenKey #: Room 61323, Mail 4651AFKey Holder ID: Cindy HildrethQty: Room 1, Mail 4action: New keys and core for room and mailboxAccount #: 228400
FO-318810	6/2/2015	6/15/2015		Core ChangeLost / StolenKey #: Room 61027, Mailbox 4529AF Key Holder ID: Cindy HildrethQty: Room 2, Mailbox 4action: New core and keys for room and mailboxAccount #: 228400
FO-318811	6/2/2015	6/12/2015		Core ChangeLost / StolenKey #: Room 61354, Mailbox 4765AF Key Holder ID: Cindy HildrethQty: Room 1, Mailbox 4action: new core and key for room and mailbox.Account #: 228400
FO-318812	6/2/2015	6/12/2015		Core ChangeLost / StolenKey #: Room 62298, Mailbox 4842AF Key Holder ID: Cindy HildrethQty: Room 2, Mailbox 4action: new core for room and mailbox and keysAccount #: 228400
FO-318813	6/2/2015	6/12/2015		Core Change Lost / Stolen Key #: room 63084, Mailbox 4969 AF Key Holder ID: Cindy Hildreth Qty: Room 1, Mailbox 4  action: New core and keys for room and mailbox Account #: 228400
FO-318814	6/2/2015	6/15/2015		Core ChangeLost / StolenKey #: Mailbox 4089AF Key Holder ID: Cindy HildrethQty: Mailbox 4action: new core and keys for mailboxAccount #: 228400
FO-318815	6/2/2015			Core ChangeLost / StolenKey #: Room 62370, Mailbox 4006AFKey Holder ID: Cindy HildrethQty: Room 1, Mailbox 4action: new core and keys for room and mailboxAccount #: 228400
FO-318818	6/2/2015	6/10/2015		Core ChangeLost / StolenKey #: Room 61881, Mailbox 4897 AF Key Holder ID: Cindy HildrethQty: Room 1, Mailbox 4action: new core and keys for room and mailboxAccount #: 228400
FO-318854	6/2/2015	6/15/2015		Core ChangeLost / StolenKey #: Mailbox 4814 AF Key Holder ID: Cindy HildrethQty: 2 Mailbox Keysaction: 1 mailbox core and 2 mailbox keys for TowersAccount #: 228400
FO-318855	6/2/2015	6/8/2015		Core ChangeLost / StolenKey #: Core AA12, Key 036975Key Holder ID: Angelica ReynaQty: 1 Core, 2 Keysaction: 1 Room Core and 2 Keys. Temp core has been installed. Please return to front desk. Thank youAccount #: 228156
FO-318856	6/2/2015	6/15/2015		New KeyNew Staff MemberKey #: 16EB1 Key Holder ID: Eric JohnsonQty: 2action: Request key only.Account #: 228184
FO-318858	6/2/2015	6/15/2015		New KeyNew Staff MemberKey #: 16EB30 Key Holder ID: Eric JohnsonQty: 1 Keyaction: Request key onlyAccount #: 228184
FO-318860	6/2/2015	6/15/2015		New KeyLost / StolenKey #: 16EC52 Key Holder ID: Eric JohnsonQty: 1 Keyaction: Request 1 Key onlyAccount #: 228184
FO-318861	6/2/2015	6/12/2015		New KeyDamagedKey #: CONTROLKey Holder ID: Eric JohnsonQty: 2action: CONTROL key is bent and is sticking in locks. Need new CONTROL keyAccount #: 228184

WO	Recieved	Finished	Total	Request
FO-318914	6/3/2015	6/8/2015		Need keys made to Fire Panels, keys CAT60, T45, LL802, 1309, 1309X. Please make 3 of each.
FO-318947	6/3/2015	6/10/2015		New KeyLost / StolenKey #: key 72036Key Holder ID: Judy Marek and Student Center AdminQty: 2action: Please make two keys for the office.Account #: 227149
FO-318948	6/3/2015	6/10/2015		ReplacementLost / StolenKey #: XF 1004 and XF 1005Key Holder ID: Yolanda PittsQty: 1 eachaction: Please make one copy of each of these two keys, which I believe are to Steelcase file cabinets: XF 1004XF 1005
FO-319232	6/8/2015	6/16/2015		New KeyNew Space AssignmentKey #: B200Key Holder ID: Nerissa Viola VillegasQty: 3action: We need three copies of key B200.thanks
FO-319233	6/8/2015	6/16/2015		New KeyNew Space AssignmentKey #: 11984-41Key Holder ID: Nerissa Viola VillegasQty: 3action: We need three copies of key 11984-41.Thanks
FO-319234	6/8/2015	6/22/2015		New KeyNew Space AssignmentKey #: 105622--2Key Holder ID: Nerissa Viola VillegasQty: 3action: We need three copies of key 105622--2Thanks
FO-319235	6/8/2015	6/15/2015		New Key New Space Assignment Key #: 105622--2 Key Holder ID: Nerissa Viola Villegas Qty: 3  action: We need three copies of key 105622--2. thanks
FO-319236	6/8/2015	6/15/2015		New KeyLost / StolenKey #: M232Key Holder ID: Sharon ProgarQty: 1action: Meridian M232 File Cabinet
FO-319237	6/8/2015	6/16/2015		New KeyNew Space AssignmentKey #: UnknownKey Holder ID: Brix Corp.Qty: 3action: I request 3 keysMechanical room keyElectrical room keyBrown box key
FO-319314	6/9/2015	6/16/2015		New KeyNew Staff MemberKey #: 27764Key Holder ID: Ben AlfaroQty: 2action: I just tried submitting this request but nothing seemed to happen when I hit "submit" so I'm sending it again in case it didn't go through.
FO-319411	6/10/2015	6/22/2015		New KeyLost / StolenKey #: HON 338EKey Holder ID: Jacqueline PattersonQty: 2action: File Cabinet HON 338EApproved by Ben Phillips
FO-319410	6/10/2015	6/23/2015		New Key Lost / Stolen Key #: 71111 Key Holder ID: Stephanie Spielmann Qty: 10  action: For Room 5314A not in dropdown
FO-319409	6/10/2015	6/16/2015		New KeyNew Staff MemberKey #: Coremark is worn. No key number is known. Tenant had an unauthorized copy.Key Holder ID: Aramark. Issued through Nick Board.Qty: 3action: Can I have three keys made for room 147? Dining Services has added staff and r
FO-319408	6/10/2015	6/16/2015		New KeyNew Space AssignmentKey #: X2791Key Holder ID: Sylvia MooreQty: 1action: Mike, Sylvia has my permission to obtain the Media Service key, X2791 to complete her project with C&IT. ThanksAl BartlettAccount #: 773006
FO-319412	6/11/2015	6/29/2015		Core Change Damaged Key #: new Key Holder ID: Jon Barth Qty: 4-Cores 3-Keys  action: 1301 Apartment A & B plus suite entrance & mailbox.
FO-319413	6/11/2015	6/26/2015		New KeyLost / StolenKey #: NewKey Holder ID: Jon BarthQty: 4-Cores 3-Keysaction: Change cores in apartment 1314A & 1314B, The suite entrance & Mailbox. Provide 3-Keys
FO-319421	6/11/2015	6/16/2015		New KeyNew Space AssignmentKey #: 109743Key Holder ID: Gary CendrowskiQty: 1action: 1-Key for card reader alarm shut off.
FO-319440	6/11/2015	6/16/2015		New KeyLost / StolenKey #: X302Key Holder ID: William WillardQty: 1action: The AAUP Union Office.The original key was locked in the Engineer's Key Lock Box.During my FMLA Absence the key was used and not returned

WO	Recieved	Finished	Total	Request
FO-320424	6/11/2015			Core ChangeLost / StolenKey #: 13309Key Holder ID: Gail Clavenna/Claudia BessoloQty: 5action: Please change core at Lande MRB #58 and make 5 keys. Thank you!Account #: 1-44081
FO-319518	6/12/2015			Core Change New Space Assignment Key #: 11 LC2.C3 Key Holder ID: Valeria Cook Qty: 1  action: Note: Department is Center for Urban Studies. Please re-core suite 1900 (entrance from the front lobby. Core number 11 LC2.C3) to the Center fo
FO-320418	6/12/2015	6/24/2015		Core Change New Staff Member Key #: see below Key Holder ID: Jodi Young Qty: 4 cores - 12 keys  action: Estimate only to re-core east and west perimeter doors. Need to know if restricted keyway that prohibits duplication is an option. Co
FO-319537	6/12/2015	6/22/2015		New KeyNew Space AssignmentKey #: XA9CBW BKey Holder ID: 2Qty: 2action: Access to basement via elevator in Life Sciences
FO-320564	6/15/2015			Core Change New Staff Member Key #: 00000 Key Holder ID: Susan Dibbley Qty: 1  action: Program Director's office needs to be secure; currently shares access with all staff Account #: 422444 Tonya Jones 06/16/2015 14:48 - Before I can move forwar
FO-319594	6/15/2015	6/22/2015		New KeyLost / StolenKey #: 160E and 190EKey Holder ID: Margaret GreenwaldQty: 2eachaction: Make keys for HON black lateral file cabinets, key #160E and 190E, for Communication Sciences and Disorders.
FO-319592	6/15/2015	6/22/2015		New KeyNew Staff MemberKey #: H-1Key Holder ID: Karen WilsonQty: 5action: Request additional keys for Rm. 1410
FO-319590	6/15/2015	6/22/2015		New KeyNew Staff MemberKey #: B-59Key Holder ID: Karen WilsonQty: 5action: Request additional keys for Room 1527
FO-319883	6/15/2015	6/22/2015		New Key New Staff Member Key #: C Key Holder ID: Nicole Middleton/Andy Murrell Qty: 1  action: Request one sub-master key for room 2410, key#30699
FO-319915	6/16/2015	6/22/2015		New Key New Staff Member Key #: A9CB7 & A9B21 (2 new cores needed) Key Holder ID: Gabrielle SiKora (R-FaST) Qty: 10 keys each (A9CB7 & new core keys)  action: Please provide (10) keys for Room 363/363.1; Please provide (1) new core for Room

WO	Recieved	Finished	Total	Request
FO-319972	6/16/2015	6/24/2015		New KeyLost / StolenKey #: 103RKey Holder ID: Dean Ambika MathurQty: 3action: Black storage cabinet to be moved from Holden by Nate and movers this week to State Hall 425. Cabinet core code 103R. New keys needed by Monday June 22, 2015. Ph
FO-320166	6/16/2015	6/24/2015		New KeyLost / StolenKey #: MF521Key Holder ID: Zhengqing HuQty: 5action: key request from hu lab
FO-320007	6/16/2015	6/24/2015		New KeyNew Staff MemberKey #: MT 8Key Holder ID: Marcus DartyQty: 1action: New employee , needed for the FP&M StockroomAccount #: 163725
FO-320008	6/16/2015	6/24/2015		New KeyNew Staff MemberKey #: 39659-3Key Holder ID: Marcus DartyQty: 1action: New employee , needed for the FP&M StockroomAccount #: 163725
FO-320018	6/17/2015			#75154 2 Keys
FO-320162	6/18/2015	6/24/2015		ReplacementLost / StolenKey #: 112EKey Holder ID: Angelique MeiuQty: 4action: Hi, I need a key for a two-drawer file cabinet (brand HON). Account #: 129611
FO-320122	6/18/2015			KEYS & CORES ( JUNE 2015 )
FO-320161	6/18/2015	6/24/2015		New KeyNew Space AssignmentKey #: 37937Key Holder ID: Mark GibbonsQty: 2action: I am in need of Two Keys #37937, for contractor access.Account #: N/A
FO-320198	6/19/2015	6/24/2015		New Key New Space Assignment Key #: B-200 Key Holder ID: Dr. Ahmad Heydari Qty: 15  action: Need to have 15 keys in order for the staff assistances to get over to Life Science from Science Hall on the overpass and back again for the construction p
FO-320190	6/19/2015			Key Request Lost / Stolen Key #: 9GL4 Key Holder ID: Cindy Hildreth Qty: 2 Keys  action: Request new core and 2 keys on storage room. Room is across from suite 614. Please contact Cindy at the front desk or myself if you have any questions Acco
FO-320315	6/22/2015			New KeyNew Staff MemberKey #: 13107-19Key Holder ID: Ty PetersQty: 1action: one key for a new graduate student
FO-320314	6/22/2015			New KeyLost / StolenKey #: KeyKey Holder ID: MCEQty: 1 eachaction: 1 Brown Box Key1 Mechanical Key #25296
FO-320342	6/22/2015		6/30/2015	New Key Lost / Stolen Key #: w77x Key Holder ID: art office Qty: 11  action: same core multiple doors to be changed. west blue door. dbl north gray doors one core has no core number now not sure what key it takes. Large east foundry gate has gener
FO-320422	6/23/2015			New KeyNew Space AssignmentKey #: 38322Key Holder ID: Leo A. TomaszewskiQty: 3action: New Xerox workers will use office for supplies for building.Account #: 152595
FO-320443	6/23/2015			New KeyNew Space AssignmentKey #: 13308-2Key Holder ID: Zhengqing HuQty: 1action: Key request from Hu lab
FO-320518	6/24/2015			New KeyNew Space AssignmentKey #: 77896Key Holder ID: Catherine BroadnaxQty: 2action: Please provide 2 copies of key #77896
FO-320550	6/25/2015			New KeyNew Space AssignmentKey #: 13186-48Key Holder ID: Lande DLARQty: 1action: New key for Lande Building animal rooms for Alexander Gow lab to move mice to animal facilities.
FO-320633	6/26/2015			New KeyLost / StolenKey #: 1101XKey Holder ID: Leo A. TomaszewskiQty: 2action: Book drop bin in Pharmacy LRC. Need to replace lost keyAccount #: 152595
FO-320686	6/29/2015			New KeyNew Space AssignmentKey #: 11LC5.5Key Holder ID: Cheri NowakQty: 1action: This space has been converted to an office and the occupant needs access.Account #: 165102
FO-320690	6/29/2015			New KeyLost / StolenKey #: 17986Key Holder ID: Brittany Thompson-JohnsonQty: 1action: Sub Master key for HRAccount #: 165102

WO	Recieved	Finished	Total	Request
FO-320711	6/29/2015			New KeyNew Staff MemberKey #: 6326.14Key Holder ID: multiple -I'll hold a record of individual holdersQty: 10action: The pull down only have the room number with "fix me" on it??Account #: 124961
FO-320712	6/29/2015			New KeyLost / StolenKey #: 102XKey Holder ID: I'll track holdersQty: 4action: 4156.1 and 4156.1 - inter rooms of 4156Account #: 124961
FO-320713	6/29/2015			New KeyNew Staff MemberKey #: 76XKey Holder ID: ac0485Qty: noneaction: Faculty member will now have both sides of the lab and they just need the door opened for access.Account #: 124961
FO-320781	6/29/2015			New KeyNew Space AssignmentKey #: 31829Key Holder ID: Dwanja KingQty: 1 of eachaction: Please provide the key (31829) fro Dwanja to enter the suite and another key to open her office 154.4 within Lande. Any questions, please call Brittany 313-577-6
FO-320748	6/29/2015			New KeyNew Space AssignmentKey #: Electrical / Mechanical Room KeysKey Holder ID: LaSalle ConstructionQty: 1action: Fountain Court Project requires access to Mech/ Elec Rooms served from Mort Harris Fitness Center. Contact me with Key availabili
<b>T - Painter</b>			<b>28</b>	
FO-318361	6/1/2015	6/16/2015		NEAR ROOM #105 REPAIR AT&T REMOVAL OF PHONE LEFT A LARGE HOLE
FO-318389	6/1/2015			HANDYMAN TIME ( June 2015 )
FO-318408	6/1/2015	6/16/2015		ADDING PAINTER/PLASTER (AFTER CARP REPAIR WALL PAINT REPAIRED WALL) R/R 1ST FLR HALLWAY REPAIR WALL WHERE wall doorstep pushed through drywall. Located outside of stairwell F, next to wooden doors on 1st floor.
FO-318412	6/1/2015	6/16/2015		ADDING PAINTER (AFTER CARPENTERS REPAIR PAINT NECESSARY AREA) R/R 2ND FLR REPAIR drywall corner beads; stairwell F, 2nd floor hallway
FO-318426	6/1/2015			Plasterer to repair the walls in the kitchen 1st floor
FO-318791	6/2/2015	6/3/2015		PAINT FRONT ENTRANCE DOORS AND FRAME.
FO-318792	6/2/2015			Repair of ceiling over Academic Success Center Reception Desk in Advising, UGL Suite 1600, is needed. Two spots remain in ceiling where there was water leaking earlier in Fall and/or Winter Semester. Although water leaks were repaired, two spots to righ
FO-318838	6/2/2015			CLEAN & PAINT OVER GRAFFITI, CAMPUS WIDE, FOR THE MONTH OF JUNE.
FO-319005	6/4/2015	6/23/2015		PAINTER TO REPAINT HANDRAIL NORTH SIDE HANCOCK SIDE
FO-319039	6/5/2015	6/8/2015		SAFTEY TIME FOR MONTH OF JUNE.
FO-319125	6/8/2015	6/11/2015		PAINTERS TO MUD & PAINT CEILING REPAIR T.V STUDIO REPAIR BY CARPENTERS ( SEE STEPHEN & KEVIN )
FO-319292	6/9/2015	6/24/2015		R/R FIRE EXT LOCATION-[09RFR] INSIDE STORAGE RM: 195: 1ST FLR CUSTODIAL EQUIPMENT-[5296]: SENTRY 10LBS ABC: FIRE EXT: ABC. DISCREPANCY DETAILS: DISCREPANCY FOR 5296. CAUSE CATEGORY: NEED TO RECHARGE  (DISCREPANCY # 000815) **SEE ATTACHMENT**
FO-319322	6/10/2015	6/19/2015		Varnish to finish, all benches in Court yard.
FO-319324	6/10/2015	6/22/2015		Varnish to finish, all exterior doors in court yard area.
FO-319468	6/11/2015	6/15/2015		PAINTERS PAINT BLOCKED UP WALL 3RD FLOOR LOCATION ( SEE STEPHEN BURCHART )
FO-319469	6/11/2015	6/16/2015		PAINTERS TO PAINT ACCESS PANEL WOMENS RESTROOM NORTH END OF STADIUM
FO-319918	6/15/2015			Repaint large "W" on Anthony Wayne in front of Atchison as well as the large "W" on Cass in front of UT. Painting should be done a week prior to move-in in August.
FO-319899	6/16/2015	6/17/2015		Remove & Paint over Graffiti from Basement to 4th floor. men's & women's bathroom.
FO-320139	6/18/2015	6/18/2015		Near room #105 repaint wall that was just repaired.
FO-320254	6/19/2015			Repaint the "W" on Anthony Wayne Dr.
FO-320257	6/19/2015			Repaint the "W" in front of University Towers.
FO-320243	6/22/2015	6/24/2015		PAINTERS NTO PRIME / PAINT THE NEW STEEL SAFETY RAILINGS. INSTALLED ON THE SOUTH PENTHOUSE ROOF EXHAUST FAN. PAINTERS MUST WEAR MIOSHA APPROVED SAFETY HARNESS AND ARE SECURELY TIED OFF WHILE WORKING ON THE ROOF
FO-320344	6/23/2015			PAINTERS TO PAINT EXTERIOR RAILINGS BLACK ON THE WEST & SOUTH ELEVATIONS. THEY ARE RUSTING & NEED TO BE PRIMED & PAINTED

WO	Recieved	Finished	Total	Request
FO-320345	6/23/2015	6/26/2015		PAINTERS TO PAINT DOOR ON THE PENTHOUSE OF CHEMISTRY AFTER THE HANDRAILS
FO-320349	6/23/2015	6/24/2015		Scrape, sand, prime & paint to finish, front entry- window transom. Cass side entrance.
FO-320350	6/23/2015			Scrape & paint all trash can lids, campus wide.
FO-320427	6/23/2015			Scrape, Caulk, Prime & Paint- Black to finish all Handrail.
FO-320592	6/26/2015			PAINTERS TO MUD & TAPE & PAINT 1ST FLOOR MENS & WOMENS BATHROOMS
<b>T - Pipefitter</b>			<b>56</b>	
FO-318413	6/1/2015	6/3/2015		R/R pipe bracket on cooling tower return piping ,,,,,,,,,, EA/6-1-15 ,,,,,,,,,,
FO-318449	6/1/2015	6/1/2015		energy curtailment meeting....CB....6-1-15
FO-318865	6/2/2015	6/2/2015		remove asbestos notifications on completed abatement jobs throughout campus....CB....6-2-15
FO-318803	6/2/2015	6/8/2015		Fitters to install new side stream filter system to heating hot water loop. Please install unit in the basement of UGL where Bio Science HHW enters UGL. See Bobick ,,,,,,,,,, ME/6-2-15 ,,,,,,,,,,
FO-318837	6/2/2015	6/2/2015		processing time for paperwork, e-mails, phone calls etc....CB...6-2-15
FO-318841	6/2/2015	6/2/2015		chk on abatement completion in tunnel.....CB....6-2-15
FO-318840	6/2/2015	6/30/2015		(**) PO REQ DK 6-8-15 Replace heating control valve in room 520 to NC control valve ,,,,,,,,,, RC/6-2-15 ,,,,,,,,,,
FO-318888	6/3/2015	6/3/2015		R/R cooling tower solenoid blow down valve ,,,,,,,,,, JH/6-3-15 ,,,,,,,,,,
FO-319014	6/4/2015	6/4/2015		get signatures for impact report.....CB....6-4-15
FO-319015	6/4/2015	6/4/2015		investigate possible animal quarters leak on 5th floor into 4th floor, take pictures and document....CB....6-4-15
FO-319016	6/4/2015	6/4/2015		meet plumbers on roof, flood roof, chk Dr Frades office for leaks...get info back to john...CB....6-4-15
FO-319018	6/4/2015	6/4/2015		Safety Meeting....CB....6-4-15
FO-319019	6/4/2015	6/4/2015		processing time for paperwork, e-mails, phone calls, etc....CB....6-4-15
FO-319177	6/8/2015	6/9/2015		Repair broken stool for Tim Herr ,,,,,,,,,, EA/ 6-8-15 ,,,,,,,,,,
FO-319298	6/9/2015	6/9/2015		processing time for paperwork, e-mails, phone calls, etc.....CB....6-9-15
FO-319299	6/9/2015	6/9/2015		meeting with Dave over outstanding abatement quotes.....CB.....6-9-15
FO-319300	6/9/2015	6/9/2015		get final signatures on project notification.....CB....6-9-15
FO-319309	6/9/2015			Relocate blowdown tank from penthouse to mechanical room 100 in basement. See John Towle for detail ,,,,,,,,,, ME/6-9-15 ,,,,,,,,,,
FO-319443	6/11/2015	6/11/2015		processing time for paperwork, e-mails, phone calls, etc....CB....6-11-15
FO-319444	6/11/2015	6/11/2015		take insulation contractor to penthouse and show him insulation job.....CB....6-11-15
FO-319445	6/11/2015	6/11/2015		chk access hole for asbestos in womens restrrom that was created by contractor....CB...6-11-15
FO-319520	6/12/2015	6/24/2015		Steam fitters- low priority- R/R RM 1195/MECH BLR RM Replace 2 malfunctioning gate valves on boiler#1 continuous blowdown.....ME/6-15-15 ,,,,,,,,,,
FO-319536	6/14/2015			(**) PO REQ DK 6-17-15 Repair condensate return pump #1 at McGregor. The unit is tripping on motor overload. ,,,,,,,,,, RC/ 6-15-15 ,,,,,,,,,,
FO-319893	6/15/2015	6/16/2015		Repair ceiling leak in room 1213 ,,,,,,,,,, JH/6-15-15 ,,,,,,,,,,
FO-319894	6/15/2015			Steam supply gate valve on AH#6 is leaking through. Please replace 1 1/2" gate valve ,,,,,,,,,, EA/6-15-15 ,,,,,,,,,,
FO-319903	6/16/2015	6/17/2015		Pipefitters: Repair/Replace leaking Powers heating control valve in #1 FCU. Priority: Low ,,,,,,,,,, EA/6-16-15 ,,,,,,,,,,
FO-319990	6/16/2015	6/16/2015		processing time for paperwork, e-mails, phone calls, etc....CB...6-16-15
FO-319992	6/16/2015	6/16/2015		meeting with Dave to clear up some po issues with asbestos projects.....CB...6-16-15
FO-320159	6/18/2015	6/18/2015		set contractors up with asbestos jobs, chk in, and finalize completion.....CB...6-18-15
FO-320160	6/18/2015	6/18/2015		processing time for paperwork, e-mails, phone calls etc...CB....6-18-15
FO-320102	6/18/2015	6/18/2015		CEILING LEAK. CEILING TILES HAS FALLEN. HALLWAY OUTSIDE OF ROOM 351.....EA/GS/6-18-15 ,,,,,,,,,,
FO-320105	6/18/2015	6/23/2015		Fitter repair steam leak on main header in garage.....ME/6-18-15 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-320106	6/18/2015	6/22/2015		Fitter repair water leak on HHW line in ceiling at animal room AF-18 ,,,,,,,,,,,,,, ME/6-18-15 ,,,,,,,,,,,,,
FO-320107	6/18/2015	6/23/2015		Fitter repair water leak on make up line to boiler #2 ,,,,,,,,,,,,,, ME/6-18-15 ,,,,,,,,,,,,,,
FO-320157	6/19/2015			Replace condensate transfer pumps to larger lift to avoid starving feed water tank under a heavy load day ,,,,,,,,,,,,,, RC/ 6-18-15 ,,,,,,,,,,,,,,
FO-320223	6/19/2015	6/19/2015		processing time for paperwork, de-mails, phone calls etc....CB...6-19-15
FO-320224	6/19/2015	6/19/2015		supervise abatement job.....CB....6-19-15
FO-320226	6/19/2015	6/19/2015		supervise abatement removal and completion.....CB.....6-19-15
FO-320228	6/19/2015	6/19/2015		post notifications at 3 different buildings for 3 different abatement jobs on Monday.....6-19-15.....CB....
FO-320339	6/22/2015	6/22/2015		supervise abatement job.....CB....6-22-15
FO-320340	6/22/2015	6/22/2015		supervise abatement job.....CB.....6-22-15
FO-320341	6/22/2015	6/22/2015		supervise abatement job.....CB.....6-22-15
FO-320313	6/22/2015	6/25/2015		pls extend the 1/2 pvc tubing so the condensate does not flow down the outer wall causing a unsightly alge stain on the west wall near rays office ,,,,,,,,,,,,,, *EA/MP/6-22-15 ,,,,,,,,,,,,,,
FO-320317	6/22/2015	6/22/2015		processing time for paperwork, e-mails, phone calls etc....CB....6-22-15
FO-320353	6/23/2015	6/24/2015		Cinder block is wet from ceiling to floor at the entrance of the department. Not sure if this is condensation or a pipe that is leaking. Around the corner of the wall (approximately 18 inches) a leak was reported on May 29. This has never been addressed
FO-320421	6/23/2015			PIPEFITTERS R/R RM 305/MECH BLR RM please r/r steam valve (gasket) that leaks badly for main header in boiler room at university services. behind boiler #2. ,,,,,,,,,,,,,, EA/6-23-15 ,,,,,,,,,,,,,,
FO-320505	6/24/2015	6/25/2015		Pipe fitters: please repair or replace leaking hot water control valve on reheat coil for room 219, it is leaking through and making the space hot. The reheat coil is located in room 105.1 and I have closed the reheat shut off valve. Priority: low. ,,,,,,
FO-320521	6/25/2015	6/29/2015		PIPEFITTERS- please add check valve to blowdown lines for boilers. When #2 is BD the tank overfills and backs up into offline boiler. overflow will also need added to BD/tempering tank.,,,,,,,,,,,,,, EA/6-25-15 ,,,,,,,,,,,,,,
FO-320539	6/25/2015			**LEAK STOPED / COIL TO BE ORDERED JWT RM 13 CEILING LEAK, LEAKING ON EQUIPMENT ,,,,,,,,,,,,,, JH/6-24-15 ,,,,,,,,,,,,,,
FO-320577	6/25/2015	6/25/2015		processing time for paperwork, e-mails, phone calls, etc...CB...6-25-15
FO-320580	6/25/2015	6/25/2015		supervise asbestos job in room 9320....CB...6-25-15
FO-320581	6/25/2015	6/25/2015		supervise asbestos job....CB...6-25-15
FO-320583	6/25/2015	6/25/2015		supervise asbestos job.....CB.....6-25-15
FO-320586	6/25/2015	6/25/2015		take pictures of both first and second floor mens room....CB....6-25-15
FO-320644	6/26/2015	6/26/2015		take all coils that are in tin shop and bring them down to stockroom to be scrapped....CB/EA....6-26-15
FO-320728	6/29/2015			R/R abated condensate return piping in penthouse ,,,,,,,,,,,,,, EA/6-29-15 ,,,,,,,,,,,,,,
<b>T - Plumber</b>			<b>49</b>	
FO-318357	6/1/2015	6/1/2015		Clear loading docks of water at Applebaum and Lande ,,,,,,,,,,,,,, MM/6-1-15 ,,,,,,,,,,,,,,
FO-318359	6/1/2015	6/5/2015		R/R leaking drain in room 0045. ,,,,,,,,,,,,,, DB/6-1-15 ,,,,,,,,,,,,,,
FO-318366	6/1/2015			Administrative Time for JUNE 2015
FO-318368	6/1/2015			R/R 1st floor mens bathroom leaking faucets ,,,,,,,,,,,,,, MP/6-1-1 ,,,,,,,,,,,,,,
FO-318386	6/1/2015	6/1/2015		Provide steel plate to cover sump pit for sump pump replacement project below ,,,,,,,,,,,,,, GS/6-1-15 ,,,,,,,,,,,,,,
				Please repair or replace sump pump #4. Pump is seized. Pump was previously disconnected electrically
FO-318387	6/1/2015	6/3/2015		Repair or replace covers and structure for the acid sump. Top of tank and covers are rotted ,,,,,,,,,,,,,, GS/6-1-15 ,,,,,,,,,,,,,,
FO-318411	6/1/2015	6/1/2015		*DUPLICATE WORK ORDER / REFER TO FO#318314  The women's restroom on the 6th floor has a sink that is not draining. It has standing water in the sink for weeks now. Our staff has removed the water and covered it with a bag.  Bill to 227149

WO	Recieved	Finished	Total	Request
FO-318898	6/3/2015			trade plumbers priority high please repair or replace piping in hallway that's dripping water into a bucket right in front of mens and ladies bath room on 5th fl ,,,,,,,,,,,,,, GS/6-3-15 ,,,,,,,,,,,,,
FO-318920	6/3/2015	6/23/2015		(**) PO REQ DK 6-10-15 P.M. facility plumbing fixtures on Monday 6-8-15 prior to training camp starting. See Bob on details ,,,,,,,,,,,,,, GS/6-3-15 ,,,,,,,,,,,,,,
FO-318926	6/3/2015	6/10/2015		Recalibrate backflow testers ,,,,,,,,,,,,,, DB/6-3-15 ,,,,,,,,,,,,,,
FO-319008	6/4/2015	6/9/2015		Men's Locker Room - Handicap Stall and 2nd standard stall - Shower knobs are not working correctly. Continually spin without turning water on. 06/04/15 lps: Chng to Est for Main ,,,,,,,,,,
FO-319009	6/4/2015	6/10/2015		The water fountain on the 7th floor needs to be snaked. Duane tried to use a plunger to unplug it, but it did not work ,,,,,,,,,,  Use 227149 06/04/15 lps: Chng to Est for Main
FO-319152	6/8/2015	6/9/2015		Request for grounds: At the bottom of the rear handicap ramp into the Cohn building, as you enter the basement hall, there has been an abundance of mosquitos due to water in the grated drain JUST OUTSIDE OF THE ENTRY DOOR. Can this standing water be treat
FO-319258	6/9/2015	6/11/2015		1st floor Men Restroom: End/last urinal: Horrific smell coming from the urinal. Custodian has been using freshener to keep down the odor & thereafter placing a bag over the urinal. Some staff personnel have complained to her. ,,,,,,,,,,,,,, GS/6-9-15
FO-319261	6/9/2015	6/11/2015		1st floor Men Restroom: Handicap stall: The toilet does flush properly however there is water leaking out from the back pipe area. ,,,,,,,,,,,,,, GS/ 6-9-15 ,,,,,,,,,,,,,,
FO-319272	6/9/2015	6/10/2015		Plumber R/R RM 1369 repair leaking faucet in the failities kitchen sink as soon as possible. Alternate contact in the event I am not available Kelley Denk at 313 577-0355 or kdenk@med.wayne.edu ,,,,,,,,,,,,,, MM/6-10-15 ,,,,,,,,,,,,,,
FO-319319	6/10/2015	6/18/2015		Plumber repair drain line leak in ceiling room 056. Possible loose clamp.,,,,,,,,,,,,,, MM/6-10-15 ,,,,,,,,,,,,,,
FO-319327	6/10/2015	6/10/2015		Flooded from the rain - needs to be pumped out.,,,,,,,,,,,,,, MM/6-10-15 ,,,,,,,,,,,,,,
FO-319455	6/11/2015			R/R leaking 2" water supply in basement ceiling mechanical room ,,,,,,,,,,,,,, GS/6-11-15 ,,,,,,,,,,,,,
FO-319500	6/12/2015	6/24/2015		Plumber repair leaking faucet in lab.,,,,,,,,,,,,,, MM/6-15-15 ,,,,,,,,,,,,,,
FO-319539	6/13/2015	6/19/2015		Handicapped willn't stop flushing 1st floor womens bathroom ,,,,,,,,,,,,,, MM/6-15-15 ,,,,,,,,,,,,,
FO-319554	6/15/2015			1st floor Women's restroom-new, handicap stall toilet handle is broken off. Toilet will not flush. Please repair.,,,,,,,,,,,,,, MP/6-15-15 ,,,,,,,,,,,,,,
FO-319917	6/15/2015	6/15/2015		The sub pump at PS8 is broken and is in need of repairs  Thanks Jack ,,,,,,,,,,,,,,
FO-320032	6/17/2015	6/18/2015		*REFER TO ROOFING WORK ORDER FO#320154 JWT  Check ceiling leak in main Compliance office. See Bob Ostrowski for specs. Thank You. ,,,,,,,,,,,,,, GS/6-17-15 ,,,,,,,,,,,,,, Bob Ostrowski **ROOFER FO#320154 6-18-15 JWT
FO-320038	6/17/2015	6/19/2015		R/R RM BSMT/EDC AREA The left side of the sink located in the Women's bathroom in the EDC basement is clogged. You can contact Liz Luzsinski at 7-9163 with any questions. Thank you. ,,,,,,,,,,,,,, DB/6-17-15 ,,,,,,,,,,,,,,
FO-320067	6/17/2015	6/17/2015		Domestic water booster pump walk through ,,,,,,,,,,,,,, DB/ 6-17-15 ,,,,,,,,,,,,,,
FO-320086	6/18/2015	6/22/2015		R/R Rm. 2305 has a sink with very low running hot water pressure.,,,,,,,,,,,,,, MM/ 6-18-15 ,,,,,,,,,,,,,
FO-320104	6/18/2015	6/30/2015		Plumber repair small leak at new back flow preventer in penthouse ,,,,,,,,,,,,,, DB/6-18-15 ,,,,,,,,,,,,,
FO-320204	6/19/2015	6/22/2015		R/R RM 310/WOMENS RR One of the toilets in the women's 3rd floor rest room is continually flushing ,,,,,,,,,,,,,, MP/6-22-15 ,,,,,,,,,,,,,,
FO-320209	6/19/2015	6/26/2015		R/R RM 2121 PLS SEAL IF POSSIBLE OR REPLACE IF NECESSARY Crack in sink, leaking onto floor. Please repair.,,,,,,,,,,,,,, MM/6-22-15 ,,,,,,,,,,,,,,



WO	Recieved	Finished	Total	Request
FO-320239	6/19/2015	6/26/2015		R/R 3RD FLR unisex bathroom toilet leaks on floor, from below the flush valve, when flushed.,,,,,,,,,, MM/6-22-15 ,,,,,,,,,
FO-320240	6/19/2015	6/26/2015		R/R 3RD FLR unisex bathroom toilet. NEED TOILET SEAT REPLACED IT IS WORN OUT ,,,,,,,,, MM/6-22-15 ,,,,,,,,,
FO-320250	6/22/2015			PLUMBERS- R/R RM 00010/BSMT MECH RM please r/r 6 gal HWT in basement at university services in cabinet under sink. Leaking. ,,,,,,,,, MP/ 6-22-15 ,,,,,,,,,
FO-320266	6/22/2015	6/23/2015		R/R BSMT/POOL on pool by pass line Repair leaking flange pool area basement ,,,,,,,,, DB/6-22-15 ,,,,,,,,,
FO-320357	6/22/2015			Evaluate floor drains backing up on floor in kitchen. Plumbers (FP&M)... for work done on 6-19-15 ,,,,,,,,,
FO-320358	6/22/2015			CONTRACTOR POWERVAC: Towers Cafeteria Kitchen Jet and vac floor drain piping and clear grease trap. Camera to verify. Provide general clean up with simple green. Work done 6-19 & 6-20 ,,,,,,,,,
FO-320359	6/22/2015	6/23/2015		Hi- The slop sink drain in the room is clogged and has standing water. Please bill to 227149. 6/22/15 lps: Chng to Est for Main ,,,,,,,,,
FO-320407	6/23/2015	6/24/2015		R/R RM 310/WOMENS RR The 1ST STALL toilet in the women's 3rd floor rest room that is directly across from the door is continuously running. The handle does not seem to be working to try to get it to stop. PLS NOTE THE OTHER TOILET WAS WORKED ON WO #FO-3
FO-320406	6/23/2015	6/24/2015		R/R RM 126/WOMENS RR 2ND STALL TOILET ISN'T WRKNG (OUT OF ORDER SIGN) ,,,,,,,,, DB/6-23-15 ,,,,,,,,,
FO-320426	6/23/2015			Plumbers-- Priority High R/R RM 00001/MECH RM Lead joint before water meter is leaking.,,,,,,,,,, MP/6-23-15 ,,,,,,,,,
FO-320495	6/24/2015			The toilet in the handicapped stall of the first floor women's bathroom is clogged and not flushing. There is a similar issue with the adjacent toilet. The custodian has cleaned up around it, but both will need to be serviced ASAP. Thanks ,,,,,,,,,
FO-320502	6/24/2015	6/26/2015		Water faucets will not completely shut off, pretty good drip ,,,,,,,,,, MM/6-24-15 ,,,,,,,,,
FO-320516	6/24/2015	6/25/2015		PM all bathroom fixtures for debris related to domestic water building shut down ,,,,,,,,,,MM/6-24-15 ,,,,,,,,,
FO-320582	6/25/2015	6/30/2015		A urinal in the 5th floor Men's restroom needs the handle repaired. There is water leaking that is staining the floor. 6/25/15 lps: Chng to Est for Main ,,,,,,,,,
FO-320657	6/26/2015			R/R RM 00152/FOOD FACILITY Please repair cracked molding on water fountain by the Hall of Fame. Specs - Bob Ostrowski ,,,,,,,,,, GS/6-29-15 ,,,,,,,,, Thank you.
FO-320672	6/29/2015			Plumbers-low priority R/R RM 3237/MECH RM Replace rusted out bladder tank on RO system ,,,,,,,,,, DB/6-29-15 ,,,,,,,,,
FO-320677	6/29/2015	6/30/2015		R/R RM 61002.20 UNISEX RR replace broken toilet seat. ,,,,,,,,,, MP/6-29-15 ,,,,,,,,,
FO-320674	6/29/2015	6/29/2015		Dewater loading dock from rain ,,,,,,,,,, MM/6-29-15 ,,,,,,,,,
FO-320718	6/29/2015			Cinder block is wet from ceiling to floor at the entrance of the department. Not sure if this is condensation or a pipe that is leaking. Around the corner of the wall (approximately 18 inches) a leak was reported on May 29. This has never been addressed
<b>T - Roofing</b>			<b>2</b>	
FO-319173	6/8/2015	6/11/2015		Bill Funk of nFab has discovered some holes in the roof. Animals are getting in there. The holes are above the nFab clean room facility. If more details are needed please call Bill Funk at 586-216-9128. Thank you. REPAIRS HAVE BEEN MADE. TAH
FO-320154	6/18/2015			**ADDING ROOFER: Ceiling leak from roof in compliance room 106.21. See Gerry (PLUMBER) for detail. no pipes in this area  Check ceiling leak in main Compliance office. See Bob Ostrowski for specs. Thank You. ,,,,,,,,,, GS/6-17-15 ,,,,,,,,,
<b>Routine</b>			<b>10</b>	
<b>T - Electrician</b>			<b>7</b>	
FO-318415	6/1/2015			PS#1 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15

WO	Recieved	Finished	Total	Request
FO-318416	6/1/2015			PS#2 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
FO-318417	6/1/2015			PS#3 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
FO-318418	6/1/2015			PS#3 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
FO-318419	6/1/2015			PS#5 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
FO-318420	6/1/2015			PS#5 Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
FO-318421	6/1/2015			VARIOUS LOTS AND STRUCTURES Electrician Monthly ROUTINE CHECK for 6/1 THRU 6/30/15
<b>T - Plumber</b>			<b>3</b>	
FO-319168	6/8/2015	6/9/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,,,,,, DB/ 6-8-15 ,,,,,,,,,,,,,,
FO-319170	6/8/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,,,,,, DB/ 6-8-15,,,,,,,,,,,,,
FO-319171	6/8/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,,,,,, DB/ 6-8-15 ,,,,,,,,,,,,,,

## Scheduled Maint. (PM)

**630**

### Engineering

**587**

#### Routine

**587**

#### E - Auxiliary

**30**

FO-317581	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317582	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317590	6/1/2015			PM - Air Handling Unit
FO-317591	6/1/2015			PM - Air Handling Unit
FO-317592	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-317593	6/1/2015			PM - Water/Air Cooled Condenser
FO-317594	6/1/2015	6/5/2015		PM - Emergency Shower/Eyewash Station
FO-317596	6/1/2015	6/15/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317606	6/1/2015	6/15/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317611	6/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-317612	6/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-317613	6/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-317614	6/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-317615	6/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-317627	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317628	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317629	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317630	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317983	6/8/2015	6/12/2015		PM - Emergency Shower/Eyewash Station
FO-317981	6/9/2015	6/10/2015		Generator Maintenance, Monthly
FO-318495	6/10/2015	6/11/2015		Generator Maintenance, Monthly
FO-318499	6/15/2015	6/19/2015		PM - Emergency Shower/Eyewash Station
FO-319086	6/17/2015	6/24/2015		Generator Maintenance, Monthly
FO-319230	6/22/2015	6/26/2015		PM - Emergency Shower/Eyewash Station
FO-319074	6/23/2015	6/24/2015		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-319076	6/23/2015	6/24/2015		Generator Maintenance, Monthly
FO-319078	6/23/2015	6/24/2015		Generator Maintenance, Monthly
FO-319080	6/23/2015	6/24/2015		Generator Maintenance, Monthly
FO-319082	6/23/2015	6/24/2015		Generator Maintenance, Monthly
FO-319766	6/29/2015	6/30/2015		PM - Emergency Shower/Eyewash Station
<b>E - MedPharm</b>			<b>44</b>	
FO-317435	6/1/2015			PM - Heat Exchanger and Economizer
FO-317436	6/1/2015			PM - Heat Exchanger and Economizer
FO-317437	6/1/2015			PM - Heat Exchanger and Economizer
FO-317439	6/1/2015			PM - Sump Pump
FO-317440	6/1/2015			PM - Sump Pump
FO-317441	6/1/2015	6/18/2015		PM - Heat Exchanger and Economizer
FO-317442	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317443	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-317444	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-317445	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317446	6/1/2015	6/16/2015		PM - Reverse Osmosis Water Softener System
FO-317447	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317448	6/1/2015	6/25/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317449	6/1/2015	6/25/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317450	6/1/2015	6/17/2015		PM - Centrifugal Pump, over 1 H.P.
FO-317451	6/1/2015	6/17/2015		PM - Centrifugal Pump, over 1 H.P.
FO-317452	6/1/2015	6/17/2015		PM - Centrifugal Pump, over 1 H.P.
FO-317453	6/1/2015			PM - Heat Exchanger and Economizer
FO-317454	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317455	6/1/2015	6/16/2015		PM - Water Softener
FO-317456	6/1/2015	6/30/2015		PM - Centrifugal Pump, over 1 H.P.
FO-317457	6/1/2015	6/30/2015		PM - Centrifugal Pump, over 1 H.P.
FO-317458	6/1/2015	6/19/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317459	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317460	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317461	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317462	6/1/2015	6/5/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317463	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317464	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317465	6/1/2015	6/5/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317466	6/1/2015	6/24/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317467	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317468	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317469	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317470	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317471	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317472	6/1/2015	6/30/2015		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~

WO	Recieved	Finished	Total	Request
FO-317473	6/1/2015	6/30/2015		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317474	6/1/2015			Replace PRE-filters
FO-317960	6/6/2015			PM - Condensate Return Pump
FO-317961	6/6/2015			PM - Condensate Return Pump
FO-318458	6/16/2015	6/18/2015		Generator Maintenance, Monthly
FO-319070	6/26/2015			Generator Maintenance, Monthly
FO-319072	6/26/2015			Generator Maintenance, Monthly
<b>E - North</b>			<b>38</b>	
FO-317475	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317476	6/1/2015	6/24/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317477	6/1/2015	6/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317478	6/1/2015	6/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317479	6/1/2015	6/19/2015		PM - Water Booster Pump
FO-317480	6/1/2015	6/19/2015		PM - Water Booster Pump
FO-317481	6/1/2015			PM - Heat Exchanger and Economizer
FO-317482	6/1/2015	6/22/2015		PM - Heat Exchanger and Economizer
FO-317483	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317484	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317485	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317486	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317487	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317488	6/1/2015	6/2/2015		PM - Heat Exchanger and Economizer
FO-317489	6/1/2015	6/15/2015		PM - Domestic Water Heater, Steam
FO-317490	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317491	6/1/2015	6/22/2015		PM - Heat Exchanger and Economizer
FO-317492	6/1/2015			PM - Heat Exchanger and Economizer
FO-317493	6/1/2015	6/22/2015		PM - Heat Exchanger and Economizer
FO-317494	6/1/2015	6/22/2015		PM - Heat Exchanger and Economizer
FO-317495	6/1/2015			PM - Heat Exchanger and Economizer
FO-317496	6/1/2015	6/15/2015		PM - Heat Exchanger and Economizer
FO-317497	6/1/2015	6/15/2015		PM - Water Booster Pump
FO-317498	6/1/2015	6/2/2015		PM - Water Booster Pump
FO-317499	6/1/2015	6/19/2015		PM - Water Booster Pump
FO-317500	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317501	6/1/2015	6/10/2015		PM - Heat Exchanger and Economizer
FO-317502	6/1/2015	5/26/2015		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317503	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317504	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317505	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317506	6/1/2015	6/23/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317507	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317508	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-318460	6/12/2015	6/12/2015		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-318459	6/15/2015			PM - Outside/Fresh Air Intake Screens
FO-319213	6/18/2015	6/18/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-319084	6/24/2015	6/25/2015		Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>26</b>	
FO-317509	6/1/2015			PM - Heat Exchanger and Economizer
FO-317510	6/1/2015			PM - Heat Exchanger and Economizer
FO-317511	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317512	6/1/2015	6/18/2015		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317513	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317514	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317515	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317516	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317517	6/1/2015	6/22/2015		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317518	6/1/2015	6/22/2015		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317519	6/1/2015	6/9/2015		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317963	6/5/2015	6/5/2015		Generator Maintenance, Monthly
FO-317964	6/5/2015	6/5/2015		Generator Maintenance, Monthly
FO-317965	6/5/2015	6/5/2015		Generator Maintenance, Monthly
FO-317966	6/5/2015	6/5/2015		Generator Maintenance, Monthly
FO-318462	6/12/2015			PM - Domestic Water Heater, Gas
FO-318463	6/12/2015			PM - Domestic Water Heater, Gas
FO-318464	6/12/2015			PM - Domestic Water Heater, Gas
FO-318465	6/12/2015			PM - Domestic Water Heater, Gas
FO-318466	6/12/2015			PM - Domestic Water Heater, Gas
FO-318467	6/12/2015			PM - Domestic Water Heater, Gas
FO-318461	6/16/2015			Generator Maintenance, Monthly
FO-319088	6/18/2015	6/18/2015		Generator Maintenance, Monthly
FO-319067	6/24/2015	6/22/2015		Generator Maintenance, Monthly
FO-319094	6/25/2015	6/18/2015		Generator Maintenance, Monthly
FO-319096	6/25/2015	6/18/2015		Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>264</b>	
FO-316179	6/1/2015	6/27/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316180	6/1/2015	6/27/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316181	6/1/2015	5/27/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316182	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316183	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316184	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316185	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316186	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316187	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316188	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316189	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316190	6/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-316191	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316192	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316193	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316194	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316195	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316196	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316197	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316198	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316199	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316200	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316201	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316202	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316203	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316204	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316205	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316206	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316207	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316208	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316209	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316210	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316211	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316212	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316213	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316214	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316215	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316216	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316217	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316218	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316219	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316220	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316221	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316222	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316223	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316224	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316225	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316226	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316227	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316228	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316229	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316230	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316231	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316232	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316233	6/1/2015	5/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316234	6/1/2015	5/28/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316235	6/1/2015	5/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316236	6/1/2015	5/28/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316237	6/1/2015	5/19/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-316238	6/1/2015	5/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316239	6/1/2015	5/19/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316240	6/1/2015	5/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316241	6/1/2015	5/20/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316242	6/1/2015	5/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316243	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316244	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316245	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316246	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316247	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316248	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316249	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316250	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316251	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316252	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316253	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316254	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316255	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316256	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316257	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316258	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316259	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316260	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316261	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316262	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316263	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316264	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316265	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316266	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316267	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316268	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316269	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316270	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316271	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316272	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316273	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316274	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316275	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316276	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316277	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316278	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316279	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316280	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316281	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316282	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316283	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316284	6/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-316285	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316286	6/1/2015			PM - Fan Coil/HV/AC Unit
FO-316287	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316288	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316289	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316290	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316291	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316292	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316293	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316294	6/1/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316295	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316296	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316297	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316298	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316299	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316300	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316301	6/1/2015	6/26/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316303	6/1/2015	6/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316304	6/1/2015	6/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316305	6/1/2015	6/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316306	6/1/2015	6/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316307	6/1/2015	6/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316308	6/1/2015	6/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316309	6/1/2015	6/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316310	6/1/2015	6/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316311	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316312	6/1/2015	6/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316313	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316314	6/1/2015	6/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316315	6/1/2015	6/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316316	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316317	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316318	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316319	6/1/2015	6/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316320	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316321	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316322	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316323	6/1/2015	6/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316324	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316325	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316326	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316327	6/1/2015	6/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316328	6/1/2015	6/18/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316329	6/1/2015	6/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316330	6/1/2015	6/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316331	6/1/2015	6/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316332	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test



WO	Recieved	Finished	Total	Request
FO-316333	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316334	6/1/2015	6/12/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316335	6/1/2015	6/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316336	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316337	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316338	6/1/2015	6/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316339	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316340	6/1/2015	6/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316341	6/1/2015	6/13/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316342	6/1/2015	6/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316343	6/1/2015	6/4/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316344	6/1/2015	6/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316345	6/1/2015	6/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316346	6/1/2015	6/18/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316347	6/1/2015	6/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316348	6/1/2015	6/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316349	6/1/2015	6/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316350	6/1/2015	6/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316351	6/1/2015	6/25/2015		Replace PRE-filters
FO-316352	6/1/2015	7/1/2015		Replace PRE-filters
FO-316353	6/1/2015	7/1/2015		Replace PRE-filters
FO-316354	6/1/2015	6/25/2015		Replace PRE-filters
FO-316366	6/1/2015	6/15/2015		Replace PRE-filters
FO-316367	6/1/2015	6/12/2015		Replace PRE-filters
FO-316368	6/1/2015			Replace PRE-filters
FO-316369	6/1/2015			Replace PRE-filters
FO-316370	6/1/2015			Replace PRE-filters
FO-316371	6/1/2015	6/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316372	6/1/2015	6/22/2015		Replace PRE-filters
FO-316373	6/1/2015	6/17/2015		Replace PRE-filters
FO-316374	6/1/2015	6/17/2015		Replace PRE-filters
FO-316375	6/1/2015	6/11/2015		Replace PRE-filters
FO-316376	6/1/2015	6/11/2015		Replace PRE-filters
FO-316377	6/1/2015	6/11/2015		Replace PRE-filters
FO-316378	6/1/2015	6/12/2015		Replace PRE-filters
FO-316379	6/1/2015	6/12/2015		Replace PRE-filters
FO-316380	6/1/2015	6/12/2015		Replace PRE-filters
FO-316381	6/1/2015	6/8/2015		Replace PRE-filters
FO-316382	6/1/2015	6/8/2015		Replace PRE-filters
FO-316383	6/1/2015	6/22/2015		Replace PRE-filters
FO-316384	6/1/2015	6/22/2015		Replace PRE-filters
FO-316385	6/1/2015	6/24/2015		Replace PRE-filters
FO-316386	6/1/2015	6/15/2015		PM - Air Handling Unit (ANNUAL)
FO-316387	6/1/2015	6/15/2015		PM - Air Handling Unit (ANNUAL)
FO-316388	6/1/2015	6/18/2015		PM - Air Handling Unit (ANNUAL)
FO-316389	6/1/2015	6/18/2015		PM - Air Handling Unit (ANNUAL)
FO-316390	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-316391	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316392	6/1/2015	6/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316393	6/1/2015			Replace PRE-filters
FO-316394	6/1/2015			Replace PRE-filters
FO-316395	6/1/2015			Replace PRE-filters
FO-316396	6/1/2015			Replace PRE-filters
FO-316397	6/1/2015			Replace PRE-filters
FO-316398	6/1/2015			Replace PRE-filters
FO-316399	6/1/2015			Replace PRE-filters
FO-316400	6/1/2015			Replace PRE-filters
FO-316401	6/1/2015			Replace PRE-filters
FO-316402	6/1/2015			Replace PRE-filters
FO-316403	6/1/2015			Replace PRE-filters
FO-316404	6/1/2015	5/21/2015		Replace PRE-filters
FO-316405	6/1/2015	5/19/2015		Replace PRE-filters
FO-316406	6/1/2015			Replace PRE-filters
FO-316407	6/1/2015			Replace PRE-filters
FO-316408	6/1/2015			Replace PRE-filters
FO-316409	6/1/2015			Replace PRE-filters
FO-316410	6/1/2015	5/21/2015		Replace PRE-filters
FO-316411	6/1/2015			Replace PRE-filters
FO-316412	6/1/2015			Replace PRE-filters
FO-316413	6/1/2015			Replace PRE-filters
FO-316414	6/1/2015	5/21/2015		Replace PRE-filters
FO-316415	6/1/2015			Replace PRE-filters
FO-316416	6/1/2015			Replace PRE-filters
FO-316417	6/1/2015			Replace PRE-filters
FO-316418	6/1/2015			Replace PRE-filters
FO-316419	6/1/2015			Replace PRE-filters
FO-316420	6/1/2015			Replace PRE-filters
FO-316421	6/1/2015			Replace PRE-filters
FO-316422	6/1/2015			Replace PRE-filters
FO-316423	6/1/2015			Replace PRE-filters
FO-316424	6/1/2015			Replace PRE-filters
FO-316427	6/1/2015	6/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316428	6/1/2015			Replace PRE-filters
FO-316429	6/1/2015	6/29/2015		Replace PRE-filters
FO-316430	6/1/2015			Replace PRE-filters
FO-316431	6/1/2015			Replace PRE-filters
FO-316432	6/1/2015			Replace PRE-filters
FO-316433	6/1/2015	6/18/2015		Replace PRE-filters
FO-316434	6/1/2015	6/18/2015		Replace PRE-filters
FO-316435	6/1/2015	6/19/2015		Replace PRE-filters
FO-316436	6/1/2015	6/19/2015		Replace PRE-filters
FO-316437	6/1/2015	6/23/2015		Replace PRE-filters
FO-316438	6/1/2015	6/24/2015		Replace PRE-filters
FO-316439	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-316440	6/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316441	6/1/2015			Replace PRE-filters
FO-316442	6/1/2015			Replace PRE-filters
FO-316443	6/1/2015			Replace PRE-filters
FO-316444	6/1/2015			Replace PRE-filters
FO-316445	6/1/2015			Replace PRE-filters
FO-316446	6/1/2015			Replace PRE-filters
FO-316447	6/1/2015			Replace PRE-filters
FO-316448	6/1/2015			Replace PRE-filters
FO-316449	6/1/2015			Replace PRE-filters
FO-316450	6/1/2015	6/30/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-316451	6/1/2015	6/10/2015		Replace PRE-filters
FO-316452	6/1/2015	6/10/2015		Replace PRE-filters
FO-316453	6/1/2015	6/9/2015		Replace PRE-filters
FO-316454	6/1/2015	6/9/2015		Replace PRE-filters
FO-316459	6/1/2015	6/9/2015		Replace PRE-filters
FO-316302	6/7/2015	7/1/2015		Animal Lab Filter Changes for Applelebaum
<b>E - South</b>			<b>49</b>	
FO-316474	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316475	6/1/2015	6/3/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316476	6/1/2015	6/3/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316477	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317520	6/1/2015	6/2/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317568	6/1/2015	6/5/2015		PM - Water Booster Pump
FO-317569	6/1/2015	6/5/2015		PM - Water Booster Pump
FO-317570	6/1/2015	6/5/2015		PM - Domestic Water Heater, Electric
FO-317571	6/1/2015	6/5/2015		PM - Domestic Water Heater, Electric
FO-317572	6/1/2015	6/5/2015		PM - Domestic Water Heater, Electric
FO-317573	6/1/2015	6/5/2015		PM - Water Booster Pump
FO-317578	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317595	6/1/2015	6/1/2015		PM - Water Softener
FO-317597	6/1/2015	6/1/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317598	6/1/2015	6/1/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317599	6/1/2015	6/1/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317600	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317601	6/1/2015	6/24/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317602	6/1/2015	6/24/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317610	6/1/2015	6/1/2015		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317631	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317632	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317633	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317634	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

WO	Recieved	Finished	Total	Request
FO-317635	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317636	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317652	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317987	6/4/2015	6/16/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-317974	6/6/2015	6/18/2015		PM - Clayton Valves for Booster Pumps (UGL)
FO-317975	6/6/2015	6/18/2015		PM - Sump Pump
FO-317976	6/6/2015	6/23/2015		PM - Clayton Valves for Booster Pumps (UGL)
FO-317977	6/8/2015	6/16/2015		Monthly AHU Inspection Clean Room Unit 2
FO-317978	6/8/2015	6/19/2015		PM - Monthly AHU Inspection Clean Room Unit 1
FO-318482	6/11/2015	6/11/2015		Generator Maintenance, Monthly
FO-318484	6/11/2015	6/11/2015		Generator Maintenance, Monthly
FO-318498	6/11/2015	6/11/2015		Generator Maintenance, Monthly
FO-316465	6/13/2015	6/20/2015		Replace PRE-filters
FO-316466	6/13/2015	6/20/2015		Replace PRE-filters
FO-316467	6/13/2015	6/13/2015		Replace PRE-filters
FO-316468	6/13/2015	6/20/2015		Replace PRE-filters
FO-316469	6/13/2015	6/20/2015		Replace PRE-filters
FO-316470	6/13/2015	6/13/2015		Replace PRE-filters
FO-316471	6/13/2015	6/13/2015		Replace PRE-filters
FO-316472	6/13/2015	6/13/2015		Replace PRE-filters
FO-316473	6/13/2015	6/13/2015		Replace PRE-filters
FO-318468	6/13/2015	6/18/2015		PM - Chemical Feed/Metering Pump/Controller
FO-318486	6/16/2015	6/16/2015		Generator Maintenance, Monthly
FO-319065	6/17/2015	6/23/2015		Generator Maintenance, Monthly
FO-319090	6/18/2015	6/18/2015		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>113</b>	
FO-317521	6/1/2015	6/23/2015		PM - Heat Exchanger and Economizer
FO-317522	6/1/2015	6/23/2015		PM - Heat Exchanger and Economizer
FO-317523	6/1/2015	6/23/2015		PM - Heat Exchanger and Economizer
FO-317524	6/1/2015	6/23/2015		PM - Heat Exchanger and Economizer
FO-317526	6/1/2015	5/26/2015		PM - Fan Coil/HV/AC Unit
FO-317527	6/1/2015	5/25/2015		PM - Fan Coil/HV/AC Unit
FO-317528	6/1/2015	5/26/2015		PM - Heat Pumps (5057 Woodward)
FO-317529	6/1/2015	5/27/2015		PM - Heat Pumps (5057 Woodward)
FO-317530	6/1/2015	5/27/2015		PM - Heat Pumps (5057 Woodward)
FO-317531	6/1/2015	5/27/2015		PM - Heat Pumps (5057 Woodward)
FO-317532	6/1/2015	5/1/2015		PM - Heat Pumps (5057 Woodward)
FO-317533	6/1/2015	5/1/2015		PM - Heat Pumps (5057 Woodward)
FO-317534	6/1/2015	5/4/2015		PM - Heat Pumps (5057 Woodward)
FO-317535	6/1/2015	5/4/2015		PM - Heat Pumps (5057 Woodward)
FO-317536	6/1/2015	5/4/2015		PM - Heat Pumps (5057 Woodward)
FO-317537	6/1/2015	5/5/2015		PM - Heat Pumps (5057 Woodward)
FO-317538	6/1/2015	5/5/2015		PM - Heat Pumps (5057 Woodward)
FO-317539	6/1/2015	5/5/2015		PM - Heat Pumps (5057 Woodward)
FO-317540	6/1/2015	5/5/2015		PM - Heat Pumps (5057 Woodward)
FO-317541	6/1/2015	5/5/2015		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-317542	6/1/2015	5/6/2015		PM - Heat Pumps (5057 Woodward)
FO-317543	6/1/2015	5/6/2015		PM - Heat Pumps (5057 Woodward)
FO-317544	6/1/2015	5/6/2015		PM - Heat Pumps (5057 Woodward)
FO-317545	6/1/2015	5/6/2015		PM - Heat Pumps (5057 Woodward)
FO-317546	6/1/2015	5/6/2015		PM - Heat Pumps (5057 Woodward)
FO-317547	6/1/2015	5/11/2015		PM - Heat Pumps (5057 Woodward)
FO-317548	6/1/2015	5/11/2015		PM - Heat Pumps (5057 Woodward)
FO-317549	6/1/2015	5/12/2015		PM - Heat Pumps (5057 Woodward)
FO-317550	6/1/2015	5/12/2015		PM - Heat Pumps (5057 Woodward)
FO-317551	6/1/2015	5/13/2015		PM - Heat Pumps (5057 Woodward)
FO-317552	6/1/2015	5/13/2015		PM - Heat Pumps (5057 Woodward)
FO-317553	6/1/2015	5/13/2015		PM - Heat Pumps (5057 Woodward)
FO-317554	6/1/2015	5/14/2015		PM - Heat Pumps (5057 Woodward)
FO-317555	6/1/2015	5/14/2015		PM - Heat Pumps (5057 Woodward)
FO-317556	6/1/2015	5/15/2015		PM - Heat Pumps (5057 Woodward)
FO-317557	6/1/2015	5/15/2015		PM - Heat Pumps (5057 Woodward)
FO-317558	6/1/2015	5/18/2015		PM - Heat Pumps (5057 Woodward)
FO-317559	6/1/2015	5/19/2015		PM - Heat Pumps (5057 Woodward)
FO-317560	6/1/2015	5/19/2015		PM - Heat Pumps (5057 Woodward)
FO-317561	6/1/2015	5/19/2015		PM - Heat Pumps (5057 Woodward)
FO-317562	6/1/2015	5/20/2015		PM - Heat Pumps (5057 Woodward)
FO-317563	6/1/2015	5/21/2015		PM - Heat Pumps (5057 Woodward)
FO-317564	6/1/2015	5/21/2015		PM - Heat Pumps (5057 Woodward)
FO-317565	6/1/2015	5/21/2015		PM - Heat Pumps (5057 Woodward)
FO-317566	6/1/2015	5/28/2015		PM - Heat Pumps (5057 Woodward)
FO-317567	6/1/2015	5/28/2015		PM - Heat Pumps (5057 Woodward)
FO-317574	6/1/2015	6/17/2015		PM - Sump Pump
FO-317575	6/1/2015	6/17/2015		PM - Sump Pump
FO-317576	6/1/2015	6/22/2015		PM - Sump Pump
FO-317577	6/1/2015	6/22/2015		PM - Sump Pump
FO-317579	6/1/2015			PM - Heat Exchanger and Economizer
FO-317584	6/1/2015	5/29/2015		PM - Heat Pumps (5057 Woodward)
FO-317585	6/1/2015	6/1/2015		PM - Heat Pumps (5057 Woodward)
FO-317586	6/1/2015	5/29/2015		PM - Heat Pumps (5057 Woodward)
FO-317587	6/1/2015	5/29/2015		PM - Heat Pumps (5057 Woodward)
FO-317588	6/1/2015	6/1/2015		PM - Heat Pumps (5057 Woodward)
FO-317589	6/1/2015	6/1/2015		PM - Heat Pumps (5057 Woodward)
FO-317603	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317604	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317605	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317607	6/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317608	6/1/2015			PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317609	6/1/2015			PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317616	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317617	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317618	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

WO	Recieved	Finished	Total	Request
FO-317619	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317620	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317637	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317638	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317639	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317640	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317641	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317642	6/1/2015	6/23/2015		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317643	6/1/2015	6/11/2015		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317644	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317647	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317648	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317649	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317651	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317984	6/4/2015	6/18/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-317985	6/4/2015	6/18/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-317986	6/4/2015	6/18/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-317972	6/5/2015			PM - Condensate Return Pump
FO-317973	6/5/2015			PM - Condensate Return Pump
FO-317967	6/6/2015	6/29/2015		PM - Condensate Return Pump
FO-317968	6/6/2015	6/29/2015		PM - Condensate Return Pump
FO-317969	6/6/2015	6/29/2015		PM - Condensate Return Pump
FO-317970	6/6/2015	6/29/2015		PM - Condensate Return Pump
FO-318477	6/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-318478	6/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-318479	6/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-318480	6/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-318489	6/16/2015	6/18/2015		Generator Maintenance, Monthly
FO-318491	6/16/2015	6/18/2015		Generator Maintenance, Monthly
FO-319214	6/20/2015			PM - Condensate Return Pump
FO-319215	6/20/2015			PM - Condensate Return Pump
FO-319216	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319217	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319218	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319219	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319220	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319221	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319222	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319223	6/20/2015			PM - Air Intake Dampers (Old Main)

WO	Recieved	Finished	Total	Request
FO-319224	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319225	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319226	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319227	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319228	6/20/2015			PM - Outside/Fresh Air Intake Screens
FO-319229	6/20/2015			PM - Air Intake Dampers (Old Main)
FO-319643	6/27/2015	6/29/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319644	6/27/2015	6/29/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
<b>E - West</b>			<b>23</b>	
FO-317525	6/1/2015			PM - Heat Exchanger and Economizer
FO-317580	6/1/2015			PM - Centrifugal Pump, over 1 H.P.
FO-317583	6/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317621	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317622	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317623	6/1/2015	6/15/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317624	6/1/2015	6/15/2015		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317625	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317626	6/1/2015			Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317645	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317646	6/1/2015			Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317650	6/1/2015			Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317971	6/8/2015	6/10/2015		PM - Domestic Water Heater, Gas
FO-317988	6/9/2015	6/11/2015		Generator Maintenance, Monthly
FO-318469	6/15/2015	6/30/2015		PM - Water/Air Cooled Condenser
FO-318470	6/15/2015			PM - Water/Air Cooled Condenser
FO-318471	6/15/2015			PM - Water/Air Cooled Condenser
FO-318472	6/15/2015			PM - Water/Air Cooled Condenser
FO-318473	6/15/2015			PM - Water/Air Cooled Condenser
FO-318474	6/15/2015			PM - Water/Air Cooled Condenser
FO-318475	6/15/2015			PM - Water/Air Cooled Condenser
FO-318476	6/15/2015			PM - Water/Air Cooled Condenser
FO-319092	6/25/2015	6/29/2015		Generator Maintenance, Monthly
<b>Trades</b>			<b>43</b>	
<b>Routine</b>			<b>43</b>	
<b>T - Electrician</b>			<b>38</b>	
FO-317962	6/5/2015			Generator Maintenance, Monthly
FO-317979	6/5/2015	6/4/2015		Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317982	6/5/2015	6/2/2015		Generator Test Tuesday 6/2/2015 @ 7:15AM.
FO-317989	6/5/2015	6/4/2015		Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317990	6/5/2015	6/4/2015		Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317991	6/5/2015	6/4/2015		Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317980	6/9/2015	6/9/2015		Generator Test Tuesday 6/9/2015 @ 1PM.

WO	Recieved	Finished	Total	Request
FO-318494	6/10/2015	6/10/2015		Generator Test Wednesday 6/10/2015 @ 1PM.
FO-318483	6/11/2015	6/11/2015		Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318485	6/11/2015	6/11/2015		Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318497	6/11/2015	6/11/2015		Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318456	6/12/2015			Generator Maintenance, Monthly
FO-318457	6/12/2015			Generator Maintenance, Monthly
FO-318492	6/12/2015	6/9/2015		Generator Test Tuesday 6/9/2015 @ 7:15 AM.
FO-318493	6/12/2015	6/9/2015		Generator Test Tuesday 6/9/2015 @ 7:15AM.
FO-318500	6/12/2015	6/12/2015		Generator Test Friday 6/12/2015 @ 7:15AM.
FO-318501	6/12/2015	6/9/2015		Generator Test Tuesday 6/9/2015 @ 7:15AM.
FO-318481	6/16/2015	6/16/2015		Generator Test Tuesday 6/16/2015 @ 7:15AM.
FO-318487	6/16/2015	6/16/2015		Generator Test Tuesday 6/16/2015 @ 9:30AM.
FO-318488	6/16/2015	6/16/2015		Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318490	6/16/2015	6/16/2015		Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318496	6/16/2015	6/16/2015		Generator Test Tuesday 6/16/2015 @ 9:15AM.
FO-319066	6/17/2015	6/17/2015		Generator Test Wednesday 6/17/2015 @ 10AM.
FO-319085	6/17/2015	6/17/2015		Generator Test Wednesday 6/17/2015 @ 7:15AM.
				Completed 6-17-2015 SRP
FO-319087	6/18/2015	6/18/2015		Generator Test Thursday 6/18/2015 @ 7:15AM.
FO-319089	6/18/2015	6/18/2015		Generator Test Thursday 6/18/2015 @ 7:15AM.
FO-319073	6/23/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 10AM
FO-319075	6/23/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 8AM
FO-319077	6/23/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 8AM
FO-319079	6/23/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 8AM
FO-319081	6/23/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 8AM
FO-319068	6/24/2015	6/24/2015		Generator Test Wednesday 6/24/2015 @ 7:15AM
FO-319083	6/24/2015	6/24/2015		Generator Test Wednesday 6/24/2014 @ 7:15AM
FO-319091	6/25/2015	6/25/2015		Generator Test Thursday 6/25/2015 @ 7:15AM
FO-319093	6/25/2015		6/25/2015	Generator Test Thursday 6 25/2015 @ 1PM
FO-319095	6/25/2015	6/24/2015		Generator Test Wednesday 6/24/2015 @ 9:30AM
				This is the generator on the roof.
FO-319069	6/26/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 7:15AM
FO-319071	6/26/2015	6/23/2015		Generator Test Tuesday 6/23/2015 @ 10AM
<b>T - Plumber</b>			<b>5</b>	
FO-316083	6/1/2015	6/12/2015		PM - Main Drain with Copper Sulfate,,,,,,,,,,,,,, DB/6-1-15 ,,,,,,,,,,
FO-316084	6/1/2015	6/1/2015		*CANCELLED THIS MONTH JWT
				PM - Main Drain with Copper Sulfate
FO-316085	6/1/2015			PM - Waterless Urinals ,,,,,,,,,,,,,,, MM/6-1-15 ,,,,,,,,,,
FO-316086	6/1/2015	6/1/2015		*CANCELLED THIS MONTH JWT
				PM - Waterless Urinals
FO-316087	6/1/2015	6/1/2015		*CANCELLED THIS MONTH JWT
				PM - Waterless Urinals

**Total: 2314**