

# DRAFT Facilities Operations PM Analysis from 2/1/2015 through 2/28/2015

Requested Finished Open WND

% Finished

Engineering			367	354	-2	15			96%
E - Auxiliary			27	27	0	0			100%
FO-306415	Finished	034-RAF-001	2/1/2015	3/2/2015		False	0.10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
RAF #1 is being over hauled as part of building renovation.									
FO-306416	Finished	034-RAF-002	2/1/2015	3/2/2015		False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
RAF #2 has been renovated with new motor, controls and dampers.									
FO-306417	Finished	034-RAF-003	2/1/2015	3/2/2015		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
Lubed motor, bearings and dampers. Checked belts.									
FO-306418	Finished	034-RAF-004	2/1/2015	3/2/2015		False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
RAF #4 has been replaced by a new unit.									
FO-306419	Finished	034-RAF-005	2/1/2015	3/2/2015		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
Lubed motor, bearings and dampers. Checked belts.									
FO-306425	Finished	134-AHU-001	2/1/2015	3/3/2015		False		PM - Air Handling Unit	
FO-306426	Finished	134-AHU-002	2/1/2015	3/3/2015		False		PM - Air Handling Unit	
FO-306427	Finished	501-ACU-001	2/1/2015	2/13/2015		False		PM - Water/Air Cooled Condenser	
FO-306428	Finished	536-AHU-201	2/1/2015	2/13/2015		False		PM - Air Handling Unit, HV Type	
FO-306429	Finished	992-ES-001*	2/2/2015	2/6/2015		False		PM - Emergency Shower/Eyewash Station	
FO-306430	Finished	536-HP-001	2/1/2015	2/13/2015		False		PM - Air Handling Unit, HV Type	
FO-306440	Finished	134-FP-001	2/1/2015	3/3/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-306441	Finished	127-FP-001	2/1/2015	3/3/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-306442	Finished	115-FP-001	2/1/2015	3/3/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-306443	Finished	104-FP-001	2/1/2015	3/3/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-306444	Finished	507-FP-001	2/1/2015	3/3/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-306910	Finished	501-GEN-001	2/10/2015	2/11/2015		False		Generator Maintenance, Monthly	
FO-306912	Finished	992-ES-001*	2/9/2015	2/13/2015		False		PM - Emergency Shower/Eyewash Station	
FO-307203	Finished	104-GEN-001	2/24/2015	2/24/2015		False	0.75	Generator Maintenance, Monthly	
Unit oil low and dirty as it has been for the last few months. Added oil. Puddle of fluid under generator.									
Turned off Ghafari elevators during test to not trap anyone. Turned elevators back on after test was completed.									
FO-307205	Finished	127-GEN-001	2/24/2015	2/24/2015		False	0.25	Generator Maintenance, Monthly	
No issues specific to this generator.									
Lost power to Chatsworth when test switched from generator to utility power. Electricians restored power.									
FO-307207	Finished	127-GEN-002	2/24/2015	2/24/2015		False	0.25	Generator Maintenance, Monthly	
Noticed no issues specific to this generator.									
Lost power to Chatsworth when the test switched from generator to utility power. Electricians restored power.									
FO-307209	Finished	127-GEN-003	2/24/2015	2/24/2015		False	0.25	Generator Maintenance, Monthly	
Noticed no issues specific to this generator.									
Lost power to Chatsworth when the test switched from generator to utility power.									
Electricians restored power.									
FO-307211	Finished	127-GEN-004	2/24/2015	2/24/2015		False	0.25	Generator Maintenance, Monthly	
Noticed no issues specific to this generator.									
Lost power to Chatsworth when the test switched from generator to utility power.									
Electricians restored power.									
FO-307223	Finished	507-GEN-001	2/11/2015	2/12/2015		False		Generator Maintenance, Monthly	

## Requested Finished Open WND

% Finished

FO-307229	Finished	536-GEN-001	2/18/2015	2/18/2015	False		Generator Maintenance, Monthly	
FO-307701	Finished	992-ES-001*	2/16/2015	2/20/2015	False		PM - Emergency Shower/Eyewash Station	
FO-308214	Finished	992-ES-001*	2/23/2015	2/27/2015	False		PM - Emergency Shower/Eyewash Station	
<b>E - MedPharm</b>			<b>34</b>	<b>34</b>	<b>0</b>	<b>0</b>		<b>100%</b>
FO-306333	Finished	612-EXF-001	2/1/2015	2/19/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306334	Finished	612-EXF-002	2/1/2015	2/19/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306335	Finished	612-EXF-003	2/1/2015	2/21/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306336	Finished	612-EXF-004	2/1/2015	2/25/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306337	Finished	612-EXF-005	2/1/2015	3/5/2015	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306338	Finished	612-EXF-006	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306339	Finished	612-EXF-007	2/1/2015	3/9/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306340	Finished	612-EXF-008	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306341	Finished	612-EXF-009	2/1/2015	3/5/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306342	Finished	612-EXF-010	2/1/2015	3/5/2015	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306343	Finished	612-EXF-011	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306344	Finished	612-EXF-012	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306345	Finished	612-EXF-016	2/1/2015	3/9/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306346	Finished	612-EXF-017	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306347	Finished	612-EXF-019	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306348	Finished	612-EXF-020	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306349	Finished	612-EXF-021	2/1/2015	2/25/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306350	Finished	612-EXF-022	2/1/2015	2/26/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306351	Finished	612-EXF-023	2/1/2015	3/5/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306352	Finished	612-EXF-024	2/1/2015	3/9/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306353	Finished	612-EXF-025	2/1/2015	3/9/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-306354	Finished	629-ES-001**	2/1/2015	4/28/2015	False		PM - Emergency Shower/Eyewash Station	
FO-306355	Finished	629-ES-002**	2/1/2015	4/28/2015	False		PM - Emergency Shower/Eyewash Station	
FO-306356	Finished	629-ES-003**	2/1/2015	4/28/2015	False		PM - Emergency Shower/Eyewash Station	
FO-306357	Finished	620-DHW-001	2/1/2015	4/14/2015	False	1.00	PM - Domestic Water Heater, Electric	
done								
FO-306358	Finished	620-DHW-002	2/1/2015	4/6/2015	False	1.00	PM - Domestic Water Heater, Electric	
done								
FO-307199	Finished	611-GEN-001	2/27/2015	2/27/2015	False	0.25	Generator Maintenance, Monthly	
Entrance doors blocked by snow. Called for grounds to remove snow. Electricians did monthly generator test before I could do preliminary checks.								
FO-307201	Finished	629-GEN-001	2/27/2015	3/27/2015	False		Generator Maintenance, Monthly	
FO-307232	Finished	609-GEN-001	2/17/2015	2/4/2015	False		Generator Maintenance, Monthly	
checked fluids battery and heaters								
FO-307695	Finished	612-CFP-001	2/14/2015	3/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller	
FO-307696	Finished	612-CFP-002	2/14/2015	3/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller	
FO-307697	Finished	612-CFP-003	2/14/2015	3/9/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller	
FO-307698	Finished	612-CFP-004	2/14/2015	3/10/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller	
FO-307699	Finished	612-CFP-005	2/14/2015	3/10/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller	
<b>E - North</b>			<b>21</b>	<b>21</b>	<b>-2</b>	<b>2</b>		<b>100%</b>

**Requested Finished Open WND**

**% Finished**

FO-306359	Finished	027-SP-001	2/1/2015	1/22/2015	False	1.00	PM - Sump Pump
FO-306360	Finished	027-SP-002	2/1/2015	1/22/2015	False	0.75	PM - Sump Pump
FO-306361	Finished	027-SP-003	2/1/2015	1/22/2015	False	0.75	PM - Sump Pump
FO-306362	Finished	036-SP-001	2/1/2015	1/28/2015	False	0.50	PM - Sump Pump
FO-306363	Finished	036-SP-002	2/1/2015	1/28/2015	False	0.75	PM - Sump Pump
FO-306364	Finished	048-SSF-001	2/1/2015	1/28/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-306365	Finished	048-SSF-002	2/1/2015	1/28/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-306366	Finished	046-SSF-001	2/1/2015	1/26/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-306367	Finished	046-SSF-003	2/1/2015	1/26/2015	False	0.35	PM - Harmsco Side Stream Filter
FO-306368	Finished	027-SP-004	2/1/2015	1/22/2015	False	0.75	PM - Sump Pump
FO-306369	Finished	040-PNEM-001	2/1/2015	1/22/2015	False	1.00	PM - Unspecified
Reattached loose pneumatic air line							
FO-306370	Finished	046-SSF-002	2/1/2015	1/27/2015	False	0.75	PM - Harmsco Side Stream Filter
FO-306371	Finished	025-AHU-005	2/1/2015	1/28/2015	False	2.00	Replace PRE-filters
FO-306372	Finished	025-AHU-004	2/1/2015	1/30/2015	False	5.00	Replace PRE-filters
FO-306373	Finished	025-AHU-003	2/1/2015	1/30/2015	False	5.00	Replace PRE-filters
FO-306374	Finished	025-AHU-002	2/1/2015	3/11/2015	True		Replace PRE-filters
FO-306375	Finished	025-AHU-001	2/1/2015	3/11/2015	True		Replace PRE-filters
FO-306905	Finished	130-AHU-001	2/4/2015	3/6/2015	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-307217	Finished	130-GEN-001	2/18/2015	2/25/2015	False	1.00	Generator Maintenance, Monthly
FO-307233	Finished	048-GEN-001	2/13/2015	2/13/2015	False	1.40	Generator Maintenance, Monthly
FO-308212	Finished	130-AHU-001	2/18/2015	3/17/2015	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
<b>E - Northeast</b>			<b>16</b>	<b>16</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-306376	Finished	193-DAT-001	2/1/2015	2/25/2015	False	1.00	PM - Deaerator Tank
FO-306377	Finished	193-WSS-001	2/1/2015	2/25/2015	False	1.00	PM - Water Softener
FO-306378	Finished	195-ACU-001	2/1/2015	2/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-306379	Finished	195-ACU-002	2/1/2015	2/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-306380	Finished	195-ACU-003	2/1/2015	2/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-306381	Finished	067-DHW-001	2/1/2015	1/29/2015	False	1.00	PM - Domestic Water Heater, Steam
FO-306382	Finished	065-VPS-001	2/1/2015	1/29/2015	False		PM - Vacuum Pump
this unit is OOS and has been for years.							
FO-306383	Finished	141-DHW-001	2/1/2015	3/2/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-306384	Finished	193-GEN-001	2/2/2015	1/27/2015	False	1.00	Generator Maintenance, Monthly
FO-306385	Finished	193-GEN-002	2/2/2015	1/27/2015	False	1.00	Generator Maintenance, Monthly
FO-306386	Finished	193-GEN-003	2/2/2015	1/27/2015	False	0.50	Generator Maintenance, Monthly
FO-306387	Finished	193-GEN-004	2/2/2015	1/27/2015	False	1.00	Generator Maintenance, Monthly
FO-307196	Finished	066-GEN-001	2/25/2015	3/10/2015	False	1.00	Generator Maintenance, Monthly
FO-307225	Finished	203-GEN-001	2/17/2015	2/17/2015	False	1.50	Generator Maintenance, Monthly
FO-307231	Finished	527-GEN-001	2/19/2015	2/19/2015	False	1.50	Generator Maintenance, Monthly
checked operation fluid levels damper operation elect. conn.							
FO-308213	Finished	193-DHW-001	2/21/2015	2/25/2015	False	1.00	PM - Domestic Water Heater, Gas
<b>E - Preventative Maintenance</b>			<b>213</b>	<b>200</b>	<b>0</b>	<b>13</b>	<b>94%</b>

**Requested Finished Open WND**

**% Finished**

FO-302563	Finished	090-EXF-555A	2/1/2015	3/2/2015	False	1.00	PM Replace Exhaust Air Filters
FO-302564	Finished	090-EXF-555B	2/1/2015	3/2/2015	False	1.00	PM Replace Exhaust Air Filters
FO-302565	Completed	090-EXF-556A	2/1/2015		True		PM Replace Exhaust Air Filters
FO-302566	Completed	090-EXF-556B	2/1/2015		True		PM Replace Exhaust Air Filters
FO-302567	Completed	090-EXF-5410A	2/1/2015		True		PM Replace Exhaust Air Filters
FO-302568	Completed	090-EXF-5410B	2/1/2015		True		PM Replace Exhaust Air Filters
FO-303823	Finished	001-FCU-2106-1	2/1/2015	2/19/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303824	Finished	001-FCU-2106-2	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303825	Finished	001-FCU-2106-3	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303826	Finished	001-FCU-2106-4	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303827	Finished	001-FCU-2106-5	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303828	Finished	001-FCU-2106-6	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303829	Finished	001-FCU-2106-7	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303830	Finished	001-FCU-2106-8	2/1/2015	2/23/2015	False	0.25	PM - Fan Coil/HV/AC Unit
general maintenance .checked filter, oiled motor and cleaned unit							
FO-303831	Finished	001-FCU-2114-1	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303832	Finished	001-FCU-2114-2	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303833	Finished	001-FCU-2114-3	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303834	Finished	001-FCU-2117-1	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303835	Finished	001-FCU-2117-2	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303836	Finished	001-FCU-2117-3	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303837	Finished	001-FCU-2134-1	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303838	Finished	001-FCU-2134-2	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-303839	Finished	001-FCU-2134-3	2/1/2015	2/27/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303840	Finished	001-FCU-2135-1	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT, LUBE , CHANGE FILTER.							
FO-303841	Finished	001-FCU-2135-2	2/1/2015	2/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT, LUBE & CHANGE FILTER.							
FO-303842	Finished	001-FCU-2137-1	2/1/2015	2/28/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT, LUBE, CHANGE FILTER.							
FO-303843	Finished	001-FCU-2137-2	2/1/2015	2/28/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT, LUBE.CHANGE FILTER.							
FO-303844	Finished	001-FCU-2147.3	2/1/2015	2/28/2015	False	0.00	PM - Fan Coil/HV/AC Unit
ROOM DOES NOT EXSIST.							
FO-303845	Finished	001-FCU-2147.1:	2/1/2015	2/28/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT , CHANGE FILTER , LUBE.							
FO-303846	Finished	001-FCU-2147.1:	2/1/2015	2/28/2015	False	0.50	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT , NO FILTER RM 2147.12							

**Requested Finished Open WND**

**% Finished**

FO-303847	Finished	001-FCU-2147.4	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303848	Finished	001-FCU-2147.5	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303849	Finished	001-FCU-2147.6	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303850	Finished	001-FCU-2147.7	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303851	Finished	001-FCU-2147.8	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303852	Finished	001-FCU-2147.9	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303853	Finished	001-FCU-2147.10	2/1/2015	2/28/2015	False	0.50	PM - Fan Coil/HV/AC Unit
INSPECT & OPERATE UNIT, NO FILTER NEEDED.							
FO-303854	Finished	001-FCU-2147.11	2/1/2015	2/28/2015	False	0.00	PM - Fan Coil/HV/AC Unit
NO ACCESS TO UNIT , DESK IN WAY.							
FO-303855	Finished	001-FCU-2152	2/1/2015	2/28/2015	False		PM - Fan Coil/HV/AC Unit
FO-303856	Finished	001-FCU-2153-1	2/1/2015	2/28/2015	False	0.90	PM - Fan Coil/HV/AC Unit
FO-303857	Finished	001-FCU-2153-2	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
FO-303858	Completed	001-FCU-2155.10	2/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-303859	Finished	001-FCU-2155.10	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303860	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303861	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303862	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303863	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303864	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303865	Finished	001-FCU-2155.11	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303866	Finished	001-FCU-2155.2	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303867	Finished	001-FCU-2374-1	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR,AND WIPED UNIT DOWN,AND TEST OPERATION							
FO-303868	Finished	001-FCU-2374-2	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER,LUBRICATED FAN MOTOR,WIPED UNIT DOWN AND TEST RAN UNIT							
FO-303869	Finished	001-FCU-2374-3	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER,LUBRICATED FAN MOTOR,WIPED UNIT DOWN, AND TEST RAN UNIT							
FO-303870	Finished	001-FCU-2374-4	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR, WIPED UNIT DOWN AND TEST RAN UNIT							
FO-303871	Finished	001-FCU-2380-1	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR, WIPED UNIT DOWN, AND TEST RAN UNIT							
FO-303872	Finished	001-FCU-2380-2	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR, WIPED UNIT DOWN, AND TEST RAN UNIT							
FO-303873	Finished	001-FCU-2380-3	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR,WIPED UNIT DOWN AND TEST RAN UNIT							
FO-303874	Finished	001-FCU-2383-1	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR,WIPED UNIT DOWN AND TEST RAN UNIT							
FO-303875	Finished	001-FCU-2383-2	2/1/2015	2/28/2015	False	0.45	PM - Fan Coil/HV/AC Unit
CHANGED FILTER, LUBRICATED FAN MOTOR,WIPED UNIT DOWN AND TEST RAN UNIT							
FO-303876	Finished	001-FCU-2388	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303877	Finished	001-FCU-2390	2/1/2015	3/5/2015	False	0.33	PM - Fan Coil/HV/AC Unit
FO-303878	Completed	203-AHU-003	2/1/2015		True		PM - Air Handling Unit, HV Type
FO-303879	Completed	001-FCU-4349	2/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-303880	Finished	603-AHU-010	2/1/2015	2/19/2015	False	1.00	HEPA Filter Replacement at Applebaum Pharmacy Building

## Requested Finished Open WND

% Finished

FO-303881	Finished	603-EXF-005	2/1/2015	2/20/2015	False	1.00	HEPA Filter Replacement at Applebaum Pharmacy Building
FO-303882	Completed	603-AHU-009	2/1/2015		True		HEPA Filter Replacement at Applebaum Pharmacy Building
FO-303883	Finished	046-FAP-001	2/1/2015	2/21/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303884	Finished	048-FAP-001	2/1/2015	2/13/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303885	Finished	049-FAP-001	2/1/2015	2/21/2015	False	1.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303886	Finished	156-FAP-001	2/1/2015	2/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303887	Finished	499-FAP-001	2/1/2015	2/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303888	Finished	620-FAP-001	2/1/2015	2/23/2015	False	0.34	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303889	Finished	036-FP-001	2/1/2015	2/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303890	Finished	025-FP-001	2/1/2015	2/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303891	Finished	007-FP-001	2/1/2015	2/26/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303892	Finished	001-FP-001	2/1/2015	2/14/2015	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303893	Finished	005-FAP-001	2/1/2015	2/26/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303894	Finished	040-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303895	Finished	038-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303896	Finished	028-FAP-001	2/1/2015	2/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303897	Finished	026-FAP-001	2/1/2015	2/4/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303898	Finished	022-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303899	Finished	017-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303900	Finished	016-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303901	Finished	003-FAP-001	2/1/2015	2/26/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303902	Finished	006-FP-001	2/1/2015	2/26/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303903	Finished	050-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303904	Finished	043-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303905	Finished	042-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303906	Finished	062-FP-001	2/1/2015	2/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303907	Finished	065-FP-001	2/1/2015	2/12/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303908	Finished	068-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303909	Finished	067-FP-001	2/1/2015	2/12/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303910	Finished	089-FP-001	2/1/2015	2/26/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303911	Finished	082-FP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303912	Finished	080-FAP-001	2/1/2015	2/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303913	Finished	090-FP-001	2/1/2015	2/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303914	Finished	155-FP-001	2/1/2015	2/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303915	Finished	150-FAP-001	2/1/2015	2/2/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303916	Finished	167-FAP-001	2/1/2015	2/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303917	Finished	166-FP-001	2/1/2015	2/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303918	Finished	140-FAP-001	2/1/2015	2/7/2015	False	0.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303919	Finished	130-FP-001	2/1/2015	2/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303920	Finished	193-FAP-001	2/1/2015	2/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303921	Finished	189-FP-001	2/1/2015	2/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303922	Finished	510-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303923	Finished	509-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303924	Finished	504-FAP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

## Requested Finished Open WND

% Finished

FO-303925	Finished	629-FP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303926	Finished	612-FP-001	2/1/2015	2/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303927	Finished	611-FP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303928	Finished	609-FP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303929	Finished	603-FP-001	2/1/2015	2/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303930	Finished	608-FP-001	2/1/2015	2/4/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303931	Finished	603-AHU-010	2/1/2015	2/24/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303932	Finished	603-AHU-009	2/1/2015	2/19/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303933	Finished	603-AHU-008	2/1/2015	2/20/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303934	Finished	603-AHU-007	2/1/2015	2/23/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303935	Finished	603-AHU-006	2/1/2015	2/24/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303936	Finished	603-AHU-005	2/1/2015	2/25/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-303937	Finished	603-AHU-004	2/1/2015	2/27/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-303938	Finished	603-AHU-003	2/1/2015	2/28/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303939	Finished	603-AHU-002	2/1/2015	2/28/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303940	Finished	603-AHU-001	2/1/2015	2/28/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303941	Finished	629-EXF-011A	2/1/2015	2/17/2015	False	2.00	Replace PRE-filters
FO-303942	Finished	629-AHU-003	2/1/2015	2/16/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-303943	Finished	629-AHU-002	2/1/2015	2/17/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-303944	Finished	629-AHU-001	2/1/2015	2/18/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303945	Finished	074-FAP-001	2/1/2015	2/21/2015	False	0.55	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303946	Finished	629-EXF-011B	2/1/2015	2/17/2015	False	2.00	Replace PRE-filters
FO-303947	Finished	016-FCU-001	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303948	Finished	016-FCU-002	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303949	Finished	016-FCU-003	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303950	Finished	016-FCU-004	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303951	Finished	016-FCU-005	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303952	Finished	016-FCU-006	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303953	Finished	016-HVU-001	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303954	Finished	016-HVU-002	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303955	Finished	016-HVU-003	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303956	Finished	016-HVU-004	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303957	Finished	016-HVU-005	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-303958	Finished	090-AHU-548	2/1/2015	2/7/2015	False	1.50	Replace PRE-filters
FO-303959	Finished	090-AHU-547	2/1/2015	2/7/2015	False	1.50	Replace PRE-filters
FO-303960	Finished	090-AHU-546	2/1/2015	2/6/2015	False	1.50	Replace PRE-filters
FO-303961	Finished	090-AHU-545	2/1/2015	2/5/2015	False	1.50	Replace PRE-filters
FO-303962	Finished	090-AHU-544	2/1/2015	2/5/2015	False	1.50	Replace PRE-filters
FO-303963	Finished	090-AHU-543	2/1/2015	2/4/2015	False	1.50	Replace PRE-filters
FO-303964	Finished	090-AHU-542	2/1/2015	2/4/2015	False	1.50	Replace PRE-filters
FO-303965	Finished	090-AHU-541	2/1/2015	2/4/2015	False	2.00	Replace PRE-filters
FO-303966	Finished	090-AHU-003	2/1/2015	2/26/2015	False	2.50	Replace PRE-filters
FO-303967	Finished	090-AHU-002	2/1/2015	2/25/2015	False	2.50	Replace PRE-filters
FO-303968	Finished	090-AHU-001	2/1/2015	2/25/2015	False	2.50	Replace PRE-filters

**Requested Finished Open WND**

**% Finished**

FO-303969	Finished	090-HVU-004	2/1/2015	2/19/2015	False	2.50	Replace PRE-filters
FO-303970	Finished	090-HVU-003	2/1/2015	2/18/2015	False	2.50	Replace PRE-filters
FO-303971	Finished	090-HVU-002	2/1/2015	2/13/2015	False	2.50	Replace PRE-filters
FO-303972	Finished	090-HVU-001	2/1/2015	2/12/2015	False	2.50	Replace PRE-filters
FO-303973	Finished	611-AHU-007**	2/1/2015	2/14/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-303974	Finished	611-AHU-006	2/1/2015	2/11/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303975	Finished	611-AHU-005	2/1/2015	2/12/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-303976	Finished	611-AHU-004	2/1/2015	2/6/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303977	Finished	611-AHU-003	2/1/2015	2/5/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-303978	Finished	611-AHU-002	2/1/2015	2/4/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303979	Finished	611-AHU-001	2/1/2015	2/3/2015	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-303980	Finished	049-AHU-005	2/1/2015	2/21/2015	False	2.00	Replace PRE-filters
FO-303981	Finished	049-AHU-004	2/1/2015	2/21/2015	False	2.00	Replace PRE-filters
FO-303982	Finished	049-AHU-003	2/1/2015	2/21/2015	False	2.00	Replace PRE-filters
FO-303983	Finished	049-AHU-002	2/1/2015	2/21/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303984	Finished	049-AHU-001	2/1/2015	3/27/2015	False	5.50	PM - Air Handling Unit (ANNUAL)
FO-303985	Finished	062-AHU-004	2/1/2015	3/4/2015	False	2.75	PM - Air Handling Unit (ANNUAL)
FO-303986	Finished	062-AHU-003	2/1/2015	2/13/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303987	Finished	062-AHU-002	2/1/2015	2/13/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303988	Finished	062-AHU-001	2/1/2015	2/13/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-303989	Finished	046-SAF-003	2/1/2015	3/4/2015	False	1.75	Replace PRE-filters
FO-303990	Finished	046-AHU-002	2/1/2015	2/13/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-303991	Finished	046-AHU-001	2/1/2015	2/13/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-303992	Completed	510-EXF-002	2/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-303993	Completed	510-EXF-001	2/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-303994	Finished	096-FP-001	2/1/2015	2/12/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-303995	Finished	085-ACU-001	2/1/2015	3/29/2015	False	8.00	Replace PRE-filters
FO-303996	Completed	026-AHU-006	2/1/2015		True		Replace PRE-filters
FO-303997	Finished	026-AHU-005	2/1/2015	2/21/2015	False	1.00	Replace PRE-filters
FO-303998	Finished	026-AHU-004	2/1/2015	2/21/2015	False	1.00	Replace PRE-filters
FO-303999	Finished	026-AHU-003	2/1/2015	2/21/2015	False	2.00	Replace PRE-filters
FO-304000	Finished	026-AHU-002	2/1/2015	2/21/2015	False	1.00	Replace PRE-filters
FO-304001	Finished	026-AHU-001	2/1/2015	2/21/2015	False	1.00	Replace PRE-filters
FO-304002	Finished	027-SAF-002	2/1/2015	2/21/2015	False	1.00	Replace PRE-filters
FO-304003	Completed	027-SAF-001	2/1/2015		True		Replace PRE-filters
FO-304004	Finished	028-SAF-006	2/1/2015	2/20/2015	False	0.25	Replace PRE-filters
filters changed							
FO-304005	Finished	028-SAF-005	2/1/2015	2/20/2015	False	0.25	Replace PRE-filters
filters changed							
FO-304006	Finished	028-SAF-004	2/1/2015	2/19/2015	False	0.25	Replace PRE-filters
replaced filters							
FO-304007	Finished	028-SAF-003	2/1/2015	2/19/2015	False	3.25	Replace PRE-filters
changed filters....							



**Requested Finished Open WND**

**% Finished**

FO-304008	Finished	028-SAF-002	2/1/2015	2/20/2015	False	0.25	Replace PRE-filters	
changed filters, greased motor and inspected belts								
FO-304009	Finished	028-SAF-001	2/1/2015	2/19/2015	False	0.75	Replace PRE-filters	
changed filters, greased motor and inspected belts								
FO-304010	Finished	016-AHU-005	2/1/2015	2/4/2015	False	2.00	Replace PRE-filters	
FO-304011	Finished	016-AHU-004	2/1/2015	2/4/2015	False	2.00	Replace PRE-filters	
FO-304012	Finished	016-AHU-002	2/1/2015	2/4/2015	False	2.00	Replace PRE-filters	
FO-304013	Finished	016-AHU-001	2/1/2015	2/4/2015	False	2.00	Replace PRE-filters	
FO-304014	Finished	023-AHU-003	2/1/2015	2/19/2015	False	0.75	Replace PRE-filters	
changed filters, greased bearings and checked belts								
FO-304015	Finished	023-AHU-002	2/1/2015	2/19/2015	False	0.75	Replace PRE-filters	
changed filters, greased motor and check belt integrity...								
FO-304016	Finished	023-AHU-001	2/1/2015	2/19/2015	False	0.75	Replace PRE-filters	
changed filters, greased bearings and check belt integrity								
FO-304017	Finished	022-HVU-001	2/1/2015	2/27/2015	False	2.50	Replace PRE-filters	
FO-304018	Finished	022-HVU-002	2/1/2015	2/27/2015	False	2.50	Replace PRE-filters	
FO-304019	Finished	036-SAF-001	2/1/2015	2/20/2015	False	1.00	Replace PRE-filters	
FO-304020	Completed	036-RTU-001	2/1/2015		True		Replace PRE-filters	
FO-304021	Finished	036-AHU-003	2/1/2015	2/20/2015	False	1.00	Replace PRE-filters	
FO-304022	Finished	036-AHU-002	2/1/2015	2/20/2015	False	1.00	Replace PRE-filters	
FO-304023	Finished	082-AHU-002	2/1/2015	3/30/2015	False	4.00	Replace PRE-filters	
FO-304024	Finished	082-AHU-001	2/1/2015	3/30/2015	False	4.00	Replace PRE-filters	
FO-304025	Finished	016-HVU-006	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit	
FO-304026	Finished	016-HVU-007	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit	
FO-304027	Finished	016-HVU-008	2/1/2015	2/11/2015	False	0.50	PM - Fan Coil/HV/AC Unit	
FO-304028	Finished	022-AHU-001	2/1/2015	2/27/2015	False	2.50	Replace PRE-filters	
FO-304029	Finished	169-FAP-001	2/1/2015	2/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test	
<b>E - South</b>			<b>30</b>	<b>30</b>	<b>0</b>	<b>0</b>		<b>100%</b>
FO-306388	Finished	089-WSS-001	2/1/2015	2/5/2015	False	1.00	PM - Water Softener	
FO-306389	Finished	089-DAT-001	2/1/2015	2/4/2015	False	1.00	PM - Deaerator Tank	
FO-306394	Finished	090-DHW-002	2/1/2015	1/29/2015	False	1.00	PM - Domestic Water Heater, Electric	
FO-306396	Finished	089-VP-001**	2/1/2015	2/4/2015	False	1.00	PM - Vacuum Pump	
FO-306397	Finished	089-VP-002**	2/1/2015	2/2/2015	False	1.00	PM - Vacuum Pump	
FO-306400	Finished	006-AIR-001	2/1/2015	2/13/2015	False	3.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306401	Finished	005-AIR-001	2/1/2015	2/13/2015	False	3.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306422	Finished	006-AIR-002	2/1/2015	2/13/2015	False	2.50	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306423	Finished	007-AIR-008	2/1/2015	2/11/2015	False	3.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306424	Finished	007-AIR-009	2/1/2015	2/18/2015	False	4.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306431	Finished	090-DHW-003	2/1/2015	1/30/2015	False	1.00	PM - Domestic Water Heater, Electric	
FO-306432	Finished	007-AIR-005	2/1/2015	2/23/2015	False	4.50	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-306433	Finished	090-ECP-541B	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump	
FO-306434	Finished	090-ECP-542	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump	
FO-306435	Finished	090-ECP-543	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump	
FO-306436	Finished	090-ECP-544	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump	

**Requested Finished Open WND**

**% Finished**

FO-306437	Finished	090-ECP-545	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump
FO-306438	Finished	090-ECP-546	2/1/2015	2/3/2015	False	0.10	PM - Water Booster Pump
FO-306439	Finished	090-ERP-542	2/1/2015	2/3/2015	False	0.50	PM - Water Booster Pump
FO-306445	Finished	007-MAU-001	2/1/2015	2/12/2015	False	4.50	Replace PRE-filters
FO-306906	Finished	090-ACU-CR2	2/8/2015	2/18/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-306907	Finished	090-ACU-CR1	2/8/2015	2/18/2015	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-306913	Finished	090-ECP-541A	2/4/2015	2/3/2015	False	0.10	PM - Water Booster Pump
FO-307188	Finished	007-GEN-001	2/12/2015	2/12/2015	False	1.00	Generator Maintenance, Monthly
FO-307190	Finished	007-GEN-002	2/12/2015	2/12/2015	False	1.00	Generator Maintenance, Monthly
FO-307192	Finished	090-GEN-001	2/17/2015	2/17/2015	False	1.00	Generator Maintenance, Monthly
FO-307194	Finished	089-GEN-001	2/18/2015	2/18/2015	False	1.00	Generator Maintenance, Monthly
FO-307228	Finished	090-GEN-002	2/12/2015	2/12/2015	False	0.10	Generator Maintenance, Monthly
FO-307236	Finished	006-GEN-001	2/19/2015	2/23/2015	False	1.00	Generator Maintenance, Monthly
FO-307700	Finished	089-BSG-HW1	2/16/2015	2/18/2015	False	1.00	PM - Domestic Water Heater, Gas

**E - Southeast 18 18 0 0 100%**

FO-306390	Finished	082-AIR-001	2/1/2015	12/16/2014	False		PM - Air Compressor, Reciprocating 5-40 H.P. changed oil, checked belts cleaned surfaces.
FO-306391	Finished	001-SP-018A	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION, LUBE,& CLEAN AREA.
FO-306392	Finished	001-SP-019A	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION & LUBE.
FO-306393	Finished	001-SP-020A	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION & LUBE.
FO-306402	Finished	071-AIR-001	2/1/2015	4/30/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-306403	Finished	071-AIR-002	2/1/2015	4/30/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-306404	Finished	071-HWP-206	2/1/2015	4/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-306405	Finished	071-HWP-207	2/1/2015	4/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-306406	Finished	071-HWP-208	2/1/2015	4/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-306407	Finished	071-HWP-209	2/1/2015	4/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-306408	Finished	001-AHU-001ML	2/1/2015	3/19/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION, & LUBE.
FO-306409	Finished	001-AHU-002ML	2/1/2015	3/19/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE.
FO-306410	Finished	001-AHU-003ML	2/1/2015	3/19/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE.
FO-306411	Finished	001-SP-018B	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION & LUBE.
FO-306412	Finished	001-SP-019B	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION & LUBE.
FO-306413	Finished	001-SP-020B	2/1/2015	3/20/2015	False	0.25	PM - Sump Pump CHECK OPERATION & LUBE.
FO-307213	Finished	637-GEN-001	2/17/2015	2/26/2015	False		Generator Maintenance, Monthly checked fluids

## Requested Finished Open WND

% Finished

FO-307215	Finished	637-GEN-002	2/17/2015	2/26/2015	False	Generator Maintenance, Monthly
checked fluids						

<b>E - West</b>	<b>8</b>	<b>8</b>	<b>0</b>	<b>0</b>		<b>100%</b>
-----------------	----------	----------	----------	----------	--	-------------

FO-306395	Finished	155-DHW-001	2/1/2015	2/25/2015	False	PM - Domestic Water Heater, Steam
FO-306398	Finished	003-DHW-001	2/1/2015	2/25/2015	False	PM - Domestic Water Heater, Electric
FO-306399	Finished	003-WSS-001	2/1/2015	2/25/2015	False	PM - Water Softener
FO-306414	Finished	003-DHW-002	2/1/2015	2/25/2015	False	PM - Domestic Water Heater, Electric
FO-306420	Finished	166-DHW-001	2/1/2015	2/25/2015	False	PM - Domestic Water Heater, Electric
FO-306421	Finished	166-DHW-002	2/1/2015	2/25/2015	False	PM - Domestic Water Heater, Electric
FO-306915	Finished	001 SPARE from	2/10/2015	2/11/2015	False	Generator Maintenance, Monthly
FO-307238	Finished	169-GEN-001	2/26/2015	2/27/2015	False	Generator Maintenance, Monthly

<b>Trades</b>	<b>41</b>	<b>38</b>	<b>3</b>	<b>0</b>		<b>93%</b>
---------------	-----------	-----------	----------	----------	--	------------

<b>T - Electrician</b>	<b>36</b>	<b>33</b>	<b>3</b>	<b>0</b>		<b>92%</b>
------------------------	-----------	-----------	----------	----------	--	------------

FO-306904	Finished	608-GEN-001	2/6/2015	2/6/2015	False	Generator Maintenance, Monthly
FO-306908	Finished	193-GEN-001	2/6/2015	2/6/2015	False	1.00 Generator Test
FO-306909	Finished	501-GEN-001	2/10/2015	2/10/2015	False	4.00 Generator Test
FO-306911	Created By PM Schedule	608-GEN-001	2/6/2015		False	4.00 Generator Test
FO-306914	Finished	048-GEN-001	2/9/2015	2/13/2015	False	4.00 Generator Test
FO-306916	Finished	193-GEN-002	2/6/2015	2/6/2015	False	1.00 Generator Test
FO-306917	Finished	193-GEN-003	2/6/2015	2/6/2015	False	1.00 Generator Test
FO-306918	Finished	193-GEN-004	2/6/2015	2/6/2015	False	1.00 Generator Test
FO-307187	Finished	609-GEN-001	2/17/2015	2/17/2015	False	4.00 Generator Test
FO-307189	Finished	007-GEN-001	2/12/2015	2/12/2015	False	2.00 Generator Test
FO-307191	Finished	007-GEN-002	2/12/2015	2/12/2015	False	2.00 Generator Test
FO-307193	Finished	090-GEN-001	2/17/2015	2/17/2015	False	4.00 Generator Test
FO-307195	Finished	089-GEN-001	2/18/2015	2/18/2015	False	4.00 Generator Test
FO-307197	Finished	066-GEN-001	2/25/2015	2/25/2015	False	4.00 Generator Test
FO-307198	Finished	611-GEN-001	2/27/2015	2/27/2015	False	4.00 Generator Test
FO-307200	Finished	629-GEN-001	2/27/2015	2/27/2015	False	4.00 Generator Test
FO-307202	Finished	104-GEN-001	2/24/2015	2/24/2015	False	4.00 Generator Test
FO-307204	Finished	127-GEN-001	2/24/2015	2/24/2015	False	1.00 Generator Test
FO-307206	Finished	127-GEN-002	2/24/2015	2/24/2015	False	1.00 Generator Test
FO-307208	Finished	127-GEN-003	2/24/2015	2/24/2015	False	1.00 Generator Test
FO-307210	Finished	127-GEN-004	2/24/2015	2/24/2015	False	1.00 Generator Test
FO-307212	Finished	637-GEN-001	2/17/2015	2/17/2015	False	2.00 Generator Test
FO-307214	Finished	637-GEN-002	2/17/2015	2/17/2015	False	2.00 Generator Test
FO-307216	Finished	130-GEN-001	2/18/2015	2/25/2015	False	4.00 Generator Test
FO-307218	Finished	612-GEN-001	2/13/2015	2/13/2015	False	2.00 Generator Test
FO-307219	Created By PM Schedule	612-GEN-001	2/13/2015		False	Generator Maintenance, Monthly
FO-307220	Finished	612-GEN-002	2/13/2015	2/13/2015	False	2.00 Generator Test
FO-307221	Created By PM Schedule	612-GEN-002	2/13/2015		False	Generator Maintenance, Monthly
FO-307222	Finished	507-GEN-001	2/11/2015	2/11/2015	False	4.00 Generator Test
FO-307224	Finished	203-GEN-001	2/17/2015	2/17/2015	False	4.00 Generator Test

Requested Finished Open WND

% Finished

FO-307226	Finished	536-GEN-001	2/18/2015	2/18/2015	False	4.00	Generator Test
FO-307227	Finished	090-GEN-002	2/12/2015	2/12/2015	False	4.00	Generator Test
Completed 2-12-2015 SRP							
FO-307230	Finished	527-GEN-001	2/19/2015	2/19/2015	False	4.00	Generator Test
FO-307234	Finished	001 SPARE from	2/10/2015	2/10/2015	False	4.00	Generator Test
FO-307235	Finished	006-GEN-001	2/19/2015	2/19/2015	False	4.00	Generator Test
FO-307237	Finished	169-GEN-001	2/26/2015	2/26/2015	False	4.00	Generator Test
<b>T - Plumber</b>			<b>5</b>	<b>5</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-305790	Finished	042	2/1/2015	2/5/2015	False	1.50	PM - Main Drain with Copper Sulfate ,,,,,,, MP/2-3-15 ,,,,,,,
FO-305791	Finished	527	2/1/2015	2/6/2015	False	0.50	PM - Main Drain with Copper Sulfate ,,,,,,, MM/2-3-15 ,,,,,,,
FO-305792	Finished	608	2/1/2015	2/3/2015	False	3.00	PM - Waterless Urinals ,,,,,,, MM/2-3-15 ,,,,,,,
FO-305793	Finished	049	2/1/2015	2/16/2015	False	1.00	PM - Waterless Urinals ,,,,,,, MP/2-3-15 ,,,,,,,
FO-305794	Finished	090	2/1/2015	2/17/2015	False	2.00	PM - Waterless Urinals ,,,,,,, MP/2-3-15 ,,,,,,,
<b>Report Total</b>			<b>408</b>	<b>392</b>	<b>1</b>	<b>15</b>	<b>96%</b>