

Facilities Operations Backlog as of 4/30/2014

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Maint. Work Order (MWRF)				1125	677	183	106	116	40	3	448
Custodial				133	70	23	4	26	7	3	63
Medium				1	1	0	0	0	0	0	0
C-Repair				1	1	0	0	0	0	0	
FO-281023	4/8/2014	22	Created	First Floor Women's Restroom 1. Paper toweling dispenser does not oper							
Low				95	67	23	4	1	0	0	28
C-Director				1	1	0	0	0	0	0	
FO-281338	4/11/2014	19	Created	custodial to provide support for Admitted Students Day on Saturday April 12, 2014 to th							
C-Lighting				9	8	1	0	0	0	0	
FO-279767	3/28/2014	33	Created	Ceiling light bulb is out.							
FO-282335	4/22/2014	8	Created	Please replace bulb outside lab door. Also,							
FO-282704	4/28/2014	2	Created	3 lights out in 4632 and 1 light flickering in 2651							
FO-282837	4/29/2014	1	Created	Light bulbs need to be replaced.							
FO-282845	4/29/2014	1	Created	Replace light bulbs.							
FO-282882	4/29/2014	1	Created	In the Women's lockerroom #176 there are three lights out.							
FO-282956	4/30/2014	0	Created	please replace lights - one light is completely out and another is dimming out. Thank yo							
FO-282958	4/30/2014	0	Created	Over half of the ceiling lights are not working in the first floor hallway and it is very dark.							
FO-283038	4/30/2014	0	Created	lights out in room 3669							
C-Materials				13	11	1	1	0	0	0	
FO-276898	2/28/2014	61	Created	Soap Dispensor broken in the men's restroom, basement							
FO-277634	3/4/2014	57	Created	No toilet paper dispenser in last stall in 4th floor men's room							
FO-281474	4/14/2014	16	Created	room# 3103							
FO-281852	4/17/2014	13	Created	recycle bin needs to be picked up and dropped off at room 3100							
FO-281898	4/17/2014	13	Created	Recycle bin pickup in room 3178							
FO-281900	4/17/2014	13	Created	Recycle bin pickup in room 7233 and drop off new bin.							
FO-281945	4/18/2014	12	Created	big recycle bin needed at room 2155.15, 2nd floor							
FO-282114	4/21/2014	9	Created	Grey recycle bin needs to be picked up and dropped off in room, 7233							
FO-282116	4/21/2014	9	Created	recycle bin needs to be picked up and dropped off in room 300							
FO-282309	4/22/2014	8	Created	RECYCLE BIN PICKED UP AND DROPPED OFF IN ROOM , 2155							
FO-282504	4/24/2014	6	Created	need big black recycle bin emptied and returned at 3178 FAB							
FO-282505	4/24/2014	6	Created	Gondola to be picked up and returned 1900 AAB							
FO-282534	4/24/2014	6	Created	recycle bin pick up and replacement							
C-Projects				1	0	1	0	0	0	0	
FO-279684	3/27/2014	34	Created	Clean carpet in WDET green room. Salt stains							
C-Relief				2	0	1	0	1	0	0	
FO-273096	1/17/2014	103	Created	We need to install atleast 2 hand santize in the building 1st floor by the back door other							
FO-277510	3/4/2014	57	Created	Advance convertamatic auto scrubber (1955712)located in the basement off the dock.T							
C-Repair				30	12	15	3	0	0	0	
FO-276349	2/21/2014	68	Created	Convertamatic micro max Advance 20 DX auto scrubber vacuum hose not working							
FO-276572	2/25/2014	64	Created	Needs a new vaccum cleaner bags the hook is broken it for a Sanitaire.It's red.							
FO-276573	2/25/2014	64	Created	The carpet machine juan is broken at the joint needs fix.							
FO-277505	3/4/2014	57	Created	batterys need replacing in Noble ECO H20 SS#-10423215 FOR auto-scrubber							
FO-277509	3/4/2014	57	Created	Advance Adphibian AXP (100000479)located in the basement off the dock area. The wa							
FO-277830	3/6/2014	55	Created	The battery in the auto scrubber in student center will not hold a charge.							
FO-277866	3/7/2014	54	Created	Advance convertamatic auto scrubber (1955713)will not run for any extended period of ti							

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-277868	3/7/2014	54	Created	The Sanitaire upright vacuum (s/n0404001033)located in janitors closet #030.1 does not							
FO-278129	3/11/2014	50	Created	Sanitare vacuum in the Cohn building is very loud and will not pick up.							
FO-278404	3/14/2014	47	Created	auto scrubber cord on handle to raise squeegee blade is broken. adfinityXZOD 0830231							
FO-278556	3/17/2014	44	Created	Speed Srcub #2601,model#613385,ser#613385-1009-8505 for repair turn on and that it							
FO-278866	3/18/2014	43	Created	The Small autoscrubber(Adfinity 20D) at Mattheai isn't putting out any water.							
FO-278868	3/19/2014	42	Created	Please check/repair the sector 9 project team Powr Flite Power Pro bac pac vac (S/N00							
FO-278869	3/19/2014	42	Created	Please repair the advance micromatic 20DX auto scrubber (s/n070906174) located in th							
FO-278871	3/19/2014	42	Created	Please check and repair the sanitaire upright vacuum cleaner located in room 158. It ru							
FO-278968	3/20/2014	41	Created	Sanitaire vacuum is needed for the Education building. Current Vacuum has a broken d							
FO-279110	3/21/2014	40	Created	NOBLE SWEEPER MODEL#614213, SERIAL #16757-80000 THE BRUSH NOT TURNI							
FO-279589	3/27/2014	34	Created	Sanitare SC-689 SER#0825003439 left wheel can move beatter bar worn down.							
FO-280150	4/1/2014	29	Created	UGL 3rd floor mens room 3438/tissue dispenser key broke off in the dispenser							
FO-280152	4/1/2014	29	Created	2 tissue dispensers broke(tape holding them close)1st floor suite 1600 ladies room SAS							
FO-280187	4/2/2014	28	Created	Walk behind burnisher:Nobles Model(612966)Serial(612966-10153712). Has broken dri							
FO-280524	4/2/2014	28	Created	Please replace the c-fold paper towel dispenser with a regular roll dispenser. The dispe							
FO-280755	4/4/2014	26	Created	Soap dispenser broke/1st bathroom inside of basement ladies lockerroom							
FO-280783	4/4/2014	26	Created	In the 1st floor ladies room middle stall the silver wax paper bag holder has falling off th							
FO-281358	4/11/2014	19	Created	Install sanitary disposal container in this unisex restroom.							
FO-281812	4/16/2014	14	Created	Ladies room - Papertowel dispenser is broken. Please fix/replace.							
FO-281917	4/18/2014	12	Created	SOAP DISPENSER IS BROKEN. 3RD FLOOR WOMEN'S RESTROOM NEAR ELEVA							
FO-282370	4/23/2014	7	Created	Men's Restroom on the 5th floor,the paper towel dispenser broken needs new one,							
FO-282625	4/28/2014	2	Created	We have 3 carpet juans that needs repairs you can come an check out this issue.							
FO-282790	4/29/2014	1	Created	1st Floor Men's restroom soap dispenser off the wall needs new 1							
C-Sector 01				8	8	0	0	0	0	0	
FO-282970	4/30/2014	0	Created	2 cases of dial soap							
FO-282972	4/30/2014	0	Created	2 cases of dial soap							
FO-282973	4/30/2014	0	Created	2 cases of Dial Soap							
FO-282975	4/30/2014	0	Created	2 cases of Dial Soap							
FO-282978	4/30/2014	0	Created	2 cases of Dial Soap							
FO-282980	4/30/2014	0	Created	2 cases of Dial Soap							
FO-282981	4/30/2014	0	Created	2 cases of Dial Soap							
FO-282983	4/30/2014	0	Created	2 cases of Dial Soap							
C-Sector 02				2	2	0	0	0	0	0	
FO-282120	4/21/2014	9	Created	Rooms 4105 and 4117 (these are conncting rooms). Please strip and wax lab floors.							
FO-282431	4/23/2014	7	Created	Please stip and wax lab floors. Please contact Philip Alther at 577-3089 to schedule tim							
C-Sector 03				5	5	0	0	0	0	0	
FO-282960	4/30/2014	0	Created	2 cases of dial soap							
FO-282964	4/30/2014	0	Created	2 cases of dial soap							
FO-282965	4/30/2014	0	Created	2 cases of dial soap							
FO-282968	4/30/2014	0	Created	2 cases of dial soap							
FO-282969	4/30/2014	0	Created	2 cases of dial soap							
C-Sector 04				1	1	0	0	0	0	0	
FO-282355	4/22/2014	8	Created	Special custodial cleaning for May 4th event							
C-Sector 05				1	1	0	0	0	0	0	
FO-282383	4/23/2014	7	Created	and 4167 - the custodian on our floor says that							
C-Sector 06				2	2	0	0	0	0	0	
FO-281150	4/9/2014	21	Created	Requesting that the Carpet be cleaned in Dr. K. Brown's Office (suite 2245 Sociology D							
FO-281469	4/14/2014	16	Created	Clean and wax floors in Art Collection Offices, 0014 Old Main - sub-basement. Alarmed							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
C-Sector 07			11	11	0	0	0	0	0	
FO-281121	4/9/2014	21	Created		Hallway needs to be waxed - @ 2 years since last done					
FO-281122	4/9/2014	21	Created		Hallway needs to be waxed - @ 2 years since last done					
FO-281389	4/11/2014	19	Created		Carpet in front of Office #230, 2nd floor has a large brown looking stain on the carpet dir					
FO-282944	4/30/2014	0	Created		There was a large coffee spill in cubicle 300.06, please shampoo.					
FO-282985	4/30/2014	0	Created		3 cases of Dial Soap					
FO-282986	4/30/2014	0	Created		3 cases of Dial Soap					
FO-282987	4/30/2014	0	Created		3 cases of Dial Soap					
FO-282988	4/30/2014	0	Created		1 case of Dial Soap					
FO-282991	4/30/2014	0	Created		2 cases of Dial Soap					
FO-282992	4/30/2014	0	Created		2 cases of Dial Soap					
FO-282993	4/30/2014	0	Created		2 cases of Dial Soap					
C-Sector 08			3	3	0	0	0	0	0	
FO-280843	4/7/2014	23	Created		Sub Basement-Basement, Ground, 1st and Second Floor, scrub and wax floors, includ					
FO-282931	4/30/2014	0	Created		2ND FL PIPE SHOP CLEAN CARPET					
FO-282932	4/30/2014	0	Created		1ST FL HALL NEAR ENG CLOSET NEEDS TO BE STRIPPED AND WAXED					
C-Sector 09			2	2	0	0	0	0	0	
FO-281404	4/11/2014	19	Created		Please strip and wax hallway floors. Please contact Krista Mitchell at 7-9028 to schedul					
FO-282878	4/29/2014	1	Created		Standing water on the floor just outside of the					
C-Sector 10			4	0	4	0	0	0	0	
FO-278360	3/13/2014	48	Created		Replace (and reposition if possible) toilet paper dispenser in first stall of main Ladies Ro					
FO-279523	3/26/2014	35	Created		In the Women restroom #170 The Sanitary Napkin holder is missing needs to be replac					
FO-279524	3/26/2014	35	Created		In the Women restroom #170 the soap dependser by the door is broken					
FO-279582	3/27/2014	34	Created		Toilet paper despensors is broken in the men restroom room 172					
Routine			37	2	0	0	25	7	3	35
C-Director			37	2	0	0	25	7	3	
FO-248169	4/18/2013	377	Created		FY2013 FO for HP Products					
FO-248174	4/18/2013	377	Created		FY2013 FO for Fraza Forklifts					
FO-248180	4/18/2013	377	Created		FY2013 for Rizzo Services					
FO-250313	5/9/2013	356	Created		FO for Pioneer Manufacturing Company FY2013					
FO-250994	5/16/2013	349	Created		FO for Shock Brothers Inc FY2013					
FO-251498	5/22/2013	343	Created		From Heat Engineering purchase the (1) Champion Box 10 (j19LM),					
FO-251521	5/22/2013	343	Created		FO for Ricoh FY2013					
FO-257653	7/30/2013	274	Created		FO for Detroit Hardware - Grounds Purchase					
FO-257783	7/31/2013	273	Created		FO for Sells Equipment Parts					
FO-262184	9/18/2013	224	Created		FO for Hercules & Hercules					
FO-266436	11/5/2013	176	Created		FO for "CINTAS", Fiscal Year 2014					
FO-266507	11/5/2013	176	Created		Landscaping to fertilize main campus and Matthaiei complex.					
FO-266509	11/5/2013	176	Created		cleaning services for floors 4-8.					
FO-267016	11/11/2013	170	Created		Grounds to address Curb Appeal III projects around campus.					
FO-267017	11/11/2013	170	Created		Custodial to Address Curb Appeal III Campus Issues.					
FO-267020	11/11/2013	170	Created		FO for "Alta Lift Truck", Fiscal Year 2014					
FO-267021	11/11/2013	170	Created		FO for "Anna's Uniforms", Fiscal Year 2014					
FO-267022	11/11/2013	170	Created		FO for "Detroit Chemical", Fiscal Year 2014					
FO-267023	11/11/2013	170	Created		FO for "Detroit Hardware", Fiscal Year 2014					
FO-267024	11/11/2013	170	Created		FO for "Grainger", Fiscal Year 2014					
FO-267025	11/11/2013	170	Created		FO for "Hercules and Hercules", Fiscal Year 2014					
FO-267026	11/11/2013	170	Created		FO for "Michigan Message Center", Fiscal Year 2014					

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-267027	11/11/2013	170	Created	FO for "Terminix", Fiscal Year 2014							
FO-267028	11/11/2013	170	Created	FO for "Allied Eagle Supply", Fiscal Year 2014							
FO-267458	11/15/2013	166	Created	Curb Appeal III project							
FO-267513	11/15/2013	166	Created	Curb Appeal III project							
FO-267515	11/15/2013	166	Created	Matthaei- Curb Appeal III project							
FO-267516	11/15/2013	166	Created	Old Main- Curb Appeal III project							
FO-267517	11/15/2013	166	Created	Curb Appeal III project							
FO-267519	11/15/2013	166	Created	Curb Appeal III project							
FO-267520	11/15/2013	166	Created	Curb Appeal III project							
FO-267521	11/15/2013	166	Created	Curb Appeal III project							
FO-267522	11/15/2013	166	Created	Curb Appeal III project							
FO-267524	11/15/2013	166	Created	Curb Appeal III project							
FO-267525	11/15/2013	166	Created	Curb Appeal III project							
FO-281691	4/15/2014	15	Created	Fo for All American Window Cleaners, Presidents Inauguration (Mcgregor, walkway@ M							
FO-281693	4/15/2014	15	Created	Fo for All American Window Cleaners, spring cleanup(state hall entrance, wlcome cent							
Engineering				369	228	26	41	44	30	0	141
High				102	55	13	10	13	11	0	47
E - Area 1 Engineer				7	0	0	0	0	7	0	
FO-263676	10/3/2013	209	Created	Make boiler plant ready to place in operation.							
FO-263897	10/8/2013	204	Created	LOW TEMP. ROOM 200.01							
FO-264272	10/11/2013	201	Created	LOW TEMP. ROOM 411.							
FO-264278	10/11/2013	201	Created	Rooms 200.01 and 200.07 have positive air pressure to the hallway. Needs to be negati							
FO-264293	10/11/2013	201	Created	HIGH TEMP ALARM ON AIR HANDLER UNIT #3.							
FO-264521	10/15/2013	197	Created	COLD ROOM IS WARM. ROOM 5113.							
FO-264603	10/16/2013	196	Created	HIGH TEMP. COLD ROOM 5125.							
E - Auxiliary				5	5	0	0	0	0	0	
H-45051	4/13/2014	17	Created	I think there is a rag stuck in my garbage disposal. Garbage disposal is not working.							
H-45247	4/28/2014	2	Created	Please check out the leak in the lobby. It is coming from the loose panel above the caut							
H-45256	4/28/2014	2	Created	Kitchen sink right hand drainage pipe is leakingauthenticated user: Daniel Krupp - fn52							
H-45270	4/29/2014	1	Created	The flusher in the rest room is not working from yesterday.Water is not coming to flush.							
H-45271	4/29/2014	1	Created	Toilet is continuously running.							
E - Command Center				23	11	0	8	4	0	0	
FO-266881	11/8/2013	173	Parts on Order	6TH FLR EAST WING HALLWAY NEAR RM 6016 BELIEVE NEWLY INSTALLED CLN							
FO-266881	11/8/2013	173	Parts on Order	6TH FLR EAST WING HALLWAY NEAR RM 6016 BELIEVE NEWLY INSTALLED CLN							
FO-268011	11/21/2013	160	Work in progress	RM 1200 SLED AREA TOO HOT CADAVERS ARE KEPT IN THIS RM							
FO-274115	1/29/2014	91	Open to Shops	ADDING CONTROLS GROUP							
FO-275806	2/17/2014	72	Created	ADDING REF CREW							
FO-275806	2/17/2014	72	Created	ADDING REF CREW							
FO-275810	2/17/2014	72	Completed	ADDING REF CREW							
FO-275810	2/17/2014	72	Completed	ADDING REF CREW							
FO-275811	2/17/2014	72	Created	ADDING REF CREW							
FO-275811	2/17/2014	72	Created	ADDING REF CREW							
FO-275812	2/17/2014	72	Created	ADDING REF CREW							
FO-275812	2/17/2014	72	Created	ADDING REF CREW							
FO-281219	4/10/2014	20	Created	Trae: Controls Priority: High							
FO-281256	4/10/2014	20	Created	Ac Controls High Priority							
FO-281418	4/12/2014	18	Created	COMMAND CENTER: Please check the operation of the #1 chiller oil pump and oil pum							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-281744	4/16/2014	14	Created	DOORS BLOWING OPEN CHECK AIR PRESSURE THROUGHOUT LAW COMPLEX.						
FO-281769	4/16/2014	14	Created	Boilers & controls-Boiler #1 has not been in operation since 4-14-14 on afternoon's.Engi						
FO-281793	4/16/2014	14	Created	CONTROLS (HIGH)						
FO-281809	4/16/2014	14	Created	Trade: Controls						
FO-282642	4/28/2014	2	Created	FURNACE KEEPS IGNITING, MAKING A LOUD EXPLODING SOUND.						
FO-282898	4/30/2014	0	Created	Controls High Priority						
FO-282907	4/30/2014	0	Created	controls crew,please troubleshoot HPLHW,heater,not holding temperature. priority High.						
FO-282914	4/30/2014	0	Created	controls crew please troubleshoot AC-5c chill coil regulating valve,not opening in auto. p						
E - MedPharm			47	27	12	1	5	2	0	
FO-265442	10/24/2013	188	Created	Evaluate needed material to winterize chill water coils throughout building ,,,,,,,,,,,,,, ME						
FO-265415	10/24/2013	188	FINISHED	SHIFFMAN LIBRARY, STAPLETON RM ACROSS FROM RM 109 TOO COLD						
FO-266903	11/11/2013	170	Work in progress	low humidity						
FO-267915	11/21/2013	160	Work in progress	low humidity						
FO-270983	12/18/2013	133	Work in progress	air pressure is negative. Needs to be positive						
FO-272876	1/15/2014	105	Created	WATER IS EXTREMELY HOT. 3RD FLOOR WOMEN AND MEN RESTROOM AND KI						
FO-273623	1/23/2014	97	Created	Repair/replace circ pump on boiler.						
FO-274806	2/4/2014	85	Work in progress	reading negative air flow. Needs to be positive						
FO-278494	3/17/2014	44	Created	ALL ANIMAL ROOMS ARE POSITIVE AND SHOULD BE NEGATIVE. 400 SUITES.						
FO-278511	3/17/2014	44	Created	RM 200.01/DLAR HAS LOW HUMIDITY						
FO-278512	3/17/2014	44	Created	RM 200.03/DLAR HAS LOW HUMIDITY						
FO-278513	3/17/2014	44	Created	RM 200.07/DLAR HAS LOW HUMIDITY						
FO-278514	3/17/2014	44	Created	RM 200.08/DLAR HAS LOW HUMIDITY						
FO-278515	3/17/2014	44	Created	RM 200.09/DLAR HAS LOW HUMIDITY						
FO-278517	3/17/2014	44	Created	RM 412/DLAR HAS LOW HUMIDITY						
FO-278518	3/17/2014	44	Created	RM 413/DLAR HAS LOW HUMIDITY						
FO-278519	3/17/2014	44	Created	RM 415/DLAR HAS LOW HUMIDITY						
FO-278520	3/17/2014	44	Created	RM 416/DLAR HAS LOW HUMIDITY						
FO-278522	3/17/2014	44	Created	RM 417/DLAR HAS LOW HUMIDITY						
FO-278996	3/20/2014	41	Created	HIGH TEMP. ROOM 0247.						
FO-280482	4/2/2014	28	Work in progress	Air pressure in rooms 205, 215,217,219,221,216 is positive to the hallway it needs to be						
FO-280532	4/2/2014	28	Created	ENGINEER						
FO-281276	4/10/2014	20	Created	Room 9332 - Exhaust vent in room is very noisy. Please correct. Please note, this roo						
FO-281339	4/11/2014	19	Created	AUTOCLAVE IS MALFUNCTIONING. ROOM 2314.						
FO-281355	4/11/2014	19	Created	8125 HIGH TEMP						
FO-281462	4/14/2014	16	Created	TOO HOT. ROOM 8128.						
FO-281651	4/15/2014	15	Created	BLUE LECT HALL IS EXTREMELY COLD/FREEZING						
FO-281657	4/15/2014	15	Created	RM 200.07/DLAR LOW TEMP						
FO-281700	4/15/2014	15	Created	RM 1331/SERVER RM SUPPLIMENTAL HVAC LOCATED IN CLNG FAILED 3xs' (once						
FO-281915	4/18/2014	12	Created	There is a gritty white powder comming from the fan and blowing around inside the cold						
FO-282010	4/21/2014	9	Created	LAB 7259 TOO HOT						
FO-282019	4/21/2014	9	Created	HIGH TEMPS. ROOMS 200.06, 200.10, 200.03, 200.09 & 8125.						
FO-282046	4/21/2014	9	Created	AHU#3 DISCHARGE HIGH TEMP						
FO-282289	4/22/2014	8	Created	8th & 9th FL NO IONIZED WATER						
FO-282315	4/22/2014	8	Created	NO DISTILLED WATER ON THE 7TH FLOOR.						
FO-282328	4/22/2014	8	Created	AHU #3 HAS HI TEMP ALARM ACTIVE						
FO-282384	4/23/2014	7	Created	LOW TEMPS. ROOMS 200.07, 200.08, 200.03 & 416.						
FO-282385	4/23/2014	7	Created	LOW HUMIDITY IN ROOMS 200.09, 200.06, 200.01 & 200.04						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282554	4/25/2014	5	Created	RM 3250 COLD RM TOO HOT							
FO-282555	4/25/2014	5	Created	BSMT SMALL ANIMAL QUAARTERS HAS HUMIDITY							
FO-282563	4/25/2014	5	Created	GENERATOR FUEL IS LOW ALARM (RECORDING)							
FO-282566	4/25/2014	5	Created	GENERATOR RUNNING ALARM							
FO-282567	4/25/2014	5	Created	GENERATOR TROUBLE ALARM							
FO-282569	4/25/2014	5	Created	AHU #3 IS IN ALARM							
FO-282573	4/25/2014	5	Created	POWER FAIL ALARM							
FO-282846	4/29/2014	1	Created	AHU #3 HAS HI TEMP ALARM							
FO-282928	4/30/2014	0	Created	RM 3323 TOO COLD. PLEASE TURN AIR DOWN							
E - North				2	2	0	0	0	0	0	
FO-281237	4/10/2014	20	Not Finished	ADDING							
FO-281842	4/17/2014	13	Created	CONTRACTOR/RAYNOR OVERHEAD DOOR:							
E - Preventative Maintenance				7	3	0	0	2	2	0	
FO-265415	10/24/2013	188	FINISHED	SHIFFMAN LIBRARY, STAPLETON RM ACROSS FROM RM 109 TOO COLD							
FO-265770	10/29/2013	183	Work in progress	FAUCET WATER IS VERY HOT AND MAKING BEEPING SOUND. 3RD FLOOR MEN'							
FO-267151	11/12/2013	169	Work in progress	RM 162 LEAK FROM PIPES, FLOODED RM							
FO-268011	11/21/2013	160	Work in progress	RM 1200 SLED AREA TOO HOT CADAVERS ARE KEPT IN THIS RM							
FO-282697	4/28/2014	2	Open to Shops	STEAM LEAK NEAR BAY DOOR/ROCKS							
FO-282876	4/29/2014	1	Created	Exhaust fans and/or air handling unit is not working properly.							
FO-282869	4/29/2014	1	Not Finished	THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED							
E - South				7	3	1	1	2	0	0	
FO-273810	1/27/2014	93	Created	ADDING PIPEFITTER:							
FO-274115	1/29/2014	91	Open to Shops	ADDING CONTROLS GROUP							
FO-274220	1/30/2014	90	Open to Shops	ADDING PLUMBER							
FO-279027	3/20/2014	41	Work in progress	ADDING PIPEFITTERS							
FO-281739	4/15/2014	15	Work in progress	RM 318 CLNG ACU IS DRIPPING WATER & CHUNKS OF ICE IS FALLING OUT THIS							
FO-282488	4/24/2014	6	Work in progress	LAB 40 TOO HOT							
FO-282953	4/30/2014	0	Created	RM 0033.1 TOO HOT, ALARM WILL BE SOUNDING IF TEMP RISES							
E - Southeast				2	2	0	0	0	0	0	
FO-282006	4/21/2014	9	Work in progress	ANIMAL RM's ARE POSITIVE SHOULD BE NEGATIVE. AF14,AF18,AF22,AF24,AF23,							
FO-282894	4/30/2014	0	Created	NO POWER IN THE BLDG, PLEASE INVESTIGATE AND CONTACT SVC CTR							
E - West				2	2	0	0	0	0	0	
FO-282429	4/23/2014	7	Created	ADDING PLUM							
FO-282876	4/29/2014	1	Created	Exhaust fans and/or air handling unit is not working properly.							
Medium				127	88	5	11	8	15	0	39
E - Area 1 Engineer				1	0	1	0	0	0	0	
FO-278308	3/12/2014	49	Created	TOO COLD. ROOM 134							
E - Area 2 Engineer				1	0	0	0	0	1	0	
FO-262785	9/23/2013	219	Not Completed	Replace seal on return pump.							
E - Auxiliary				23	23	0	0	0	0	0	
H-44912	4/4/2014	26	Created	3 canisters are broken and the 2 in the ceiling have bad ballasts.							
H-44918	4/4/2014	26	Created	Pipes in shower rattle real loud whenever water is in use. The problem had been reporte							
H-44923	4/6/2014	24	Created	One of the metal pieces in the vent is broken.							
H-44957	4/7/2014	23	Created	Engineer says the combustion fan on BSG-001 is broken. Please order replacement							
H-45109	4/17/2014	13	Created	There is a water leak in the bathroom sink. Please look into it ASAP.authenticated use							
H-45178	4/21/2014	9	Created	My air conditioner is not working. The red light below the thermostat is on and remains o							
H-45174	4/22/2014	8	Created	Air is not working red light on thermostat keeps coming on. Room is hotauthenticated							
H-45162	4/22/2014	8	Created	Water is running in bathroom sink and Tub authenticated user: Tamika Davis - eq2532							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
H-45194	4/23/2014	7	Created	#1 Bathroom sink has leaked for a long time, had not been fixed with first work order. Al						
H-45282	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45283	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45284	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45285	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45286	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45287	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45288	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45289	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45290	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45291	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45292	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45293	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45294	4/29/2014	1	Created	Please perform a engineering check on this room.						
H-45296	4/30/2014	0	Created	kitchen faucet leaks authenticated user: Aja Pettiford - fi6887requester ip address: 1						
E - Command Center			42	28	2	4	1	7	0	
FO-265275	10/23/2013	189	Completed	VERY COLD. ROOM 2033.						
FO-265418	10/24/2013	188	Created	RM 320 HOOD NOT WORKING						
FO-265513	10/25/2013	187	Created	RM 3210 IS TOO COLD needs work on VAV box.						
FO-265513	10/25/2013	187	Created	RM 3210 IS TOO COLD needs work on VAV box.						
FO-265533	10/25/2013	187	Not Finished	3RD FLR WOODCOCK WING STACK AREA IS TOO HOT						
FO-265630	10/28/2013	184	Completed	Too cold in this room - air flow stronger in ths room than others.						
FO-265631	10/28/2013	184	Completed	Too cold in this room - air flow stronger in this room than others.						
FO-269424	12/10/2013	141	Created	REPLACE NOISY DAMPER ACTUATOR ON EXHAUST VAV. ROOM 2550.						
FO-276460	2/18/2014	71		R/R RM 220 HEAT PUMP NEEDS TO BE CHARGED CAUSING HAS RED LITE ON T						
FO-276460	2/18/2014	71		R/R RM 220 HEAT PUMP NEEDS TO BE CHARGED CAUSING HAS RED LITE ON T						
FO-276094	2/19/2014	70	Need to work with Honeywell	ADDING CONTROLS GROUP:						
FO-276485	2/24/2014	65	Work in progress	1ST FL SUITE TOO HOT						
FO-279382	3/25/2014	36	Completed	R/R RM 3209 William Willard-Reset the processor and submitted a work order for the C						
FO-279382	3/25/2014	36	Completed	R/R RM 3209 William Willard-Reset the processor and submitted a work order for the C						
FO-280481	4/2/2014	28	Created	Trade: BAS Engineer						
FO-280595	4/3/2014	27	Created	Trade: Controls Priority: Medium						
FO-280669	4/3/2014	27	Created	Investigate and correct cause of faulty temperature control on #3 dom water heater.						
FO-280724	4/4/2014	26	Created	Found on CSD-1						
FO-280725	4/4/2014	26	Created	Found on CSD-1						
FO-280726	4/4/2014	26	Created	Found on CSD-1						
FO-280727	4/4/2014	26	Created	Found on CSD-1						
FO-280759	4/4/2014	26	Work in progress	controls- an on going problem with the room 117 unit has not been corrected.the fan is						
FO-280762	4/4/2014	26	Created	Please repair ACU 2 condenser fan and controls. Fan is cycling on and off every10 sec						
FO-281825	4/17/2014	13	Created	Trade: Controls Priority: High						
FO-281855	4/17/2014	13	Created	Trade: Controls						
FO-281895	4/17/2014	13	Created	RMS 1107.4 & 1107.5 CLNG VENT IS MAKING A LOUD NOISE.						
FO-281985	4/20/2014	10	Created	Repair AHU-1 return air fan speed control. The RAF constantly stays at 15 hz, and the b						
FO-282055	4/21/2014	9	Created	AC shop. Please replace heat pump for room 410.						
FO-282056	4/21/2014	9	Created	AC shop. Please replace heat pump for room 409.						
FO-282057	4/21/2014	9	Created	AC shop. Please replace heat pump for room 409.						
FO-282058	4/21/2014	9	Created	AC shop. Please replace heat pump for room 427.						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282102	4/21/2014	9	Created	Controls: MED Priority,						
FO-282404	4/23/2014	7	Created	Inspect controls to roof top unit that serves AD office. Verify thermostat operation and c						
FO-282424	4/23/2014	7	Created	Repair control serving reheat heat exchanger. Loop is overheating.						
FO-279456	4/29/2014	1	Work in progress	Trade: Controls Priority: Medium						
FO-278769	4/29/2014	1	Created	Control Engineer; Medium						
FO-278772	4/29/2014	1	Created	Control Engineer; Medium						
FO-282334	4/29/2014	1	Created	Controls (High Priority)						
FO-282916	4/30/2014	0	Created	CSD-1 Repair, boiler # 2, high limit switch won't trip boiler.						
FO-282923	4/30/2014	0	Created	Failed CSD-1, gas leak at gas valve Boiler #1.						
FO-282926	4/30/2014	0	Created	Passed CSD-1 Combustion air works but it shows it is in alarm mode, needs to be looke						
FO-282927	4/30/2014	0	Created	Passed CSD-1, Steam leak at top of boiler. Boiler "d"						
E - MedPharm			33	23	1	1	7	1	0	
FO-264902	10/21/2013	191	Created	Laborer- remove old sheaves and bushings by boilerroom door.						
FO-267738	11/19/2013	162	Work in progress	270 FAN NO LONGER WORKING						
FO-268814	12/3/2013	148	Work in progress	Repair leaking hydronic pump						
FO-269111	12/5/2013	146	Work in progress	Repair/replace pump 20 coupling.						
FO-269384	12/9/2013	142	Created	Chemical Fume Hood not working.						
FO-271086	12/18/2013	133	Work in progress	Room 3565 needs cardboard to be replaced with permanent vent in ceiling.						
FO-271605	1/2/2014	118	Created	TOO COLD. ROOM 1210.						
FO-273868	1/27/2014	93	Work in progress	RM 2156 TOO COLD						
FO-275406	2/11/2014	78	Created	ENGINEER						
FO-279469	3/26/2014	35	Created	Room 8355 at Scott Hall has cold air blowing excessively from supply vent. Check HVA						
FO-280650	4/3/2014	27	Created	RM 3343.1 IS TOO COLD						
FO-281446	4/14/2014	16	Created	TOO HOT. ROOM 6263.						
FO-281451	4/14/2014	16	Created	CEILING A/C IS NOT WORKING. ROOM 1331.						
FO-281453	4/14/2014	16	Created	TOO HOT. ROOM 5344, 5324 AND 9245.						
FO-281455	4/14/2014	16	Created	TOO HOT. ROOM 3240.						
FO-281471	4/14/2014	16	Created	RM 6226 IS EXTREMELY TOO HOT						
FO-281803	4/16/2014	14	Created	PARTICALS BLOWING FROM CEILING VENTS. ROOMS 1107.4 AND 1107.5.						
FO-281845	4/17/2014	13	Created	RM 1328 IS TOO HOT (BLOOD DRIVE)						
FO-281867	4/17/2014	13	Created	GREEN LECT HALL IS TOO HOT						
FO-281869	4/17/2014	13	Created	RM 1350/CAFETERIA IS TOO HOT						
FO-281870	4/17/2014	13	Created	RM 200.06 HAS HI TEMP						
FO-281871	4/17/2014	13	Created	RM 200.06 HAS LOW HUMIDITY						
FO-282096	4/21/2014	9	Created	Fitters please repair leaky chill water recirculating pump on AHU-6 in room 12.						
FO-282346	4/22/2014	8	Created	RM 3343.1 IS STILL TOO COLD						
FO-282347	4/22/2014	8	Created	RM 1233 IS TOO COLD						
FO-282357	4/22/2014	8	Created	Close chiller for the season						
FO-282393	4/23/2014	7	Created	TOO COLD. ROOM 5250.						
FO-282430	4/23/2014	7	Created	ADDING PIPE						
FO-282479	4/24/2014	6	Created	TOO HOT. ROOM 7259.						
FO-282489	4/24/2014	6	Created	TOO COLD. ROOM 3343.1						
FO-282548	4/25/2014	5	Created	RM 200.03/DLAR HAS LOW TEMP						
FO-282852	4/29/2014	1	Created	Room 9332 - Please correct loud vent noise. Room is used to house animals and MUS						
FO-282948	4/30/2014	0	Created	RM 7259 TOO HOT						
E - North			5	5	0	0	0	0	0	
FO-281506	4/14/2014	16	Created	Room 25 Large set of condensate pumps (pit) not functioning. One pump is dead and th						
FO-282272	4/22/2014	8	Created	TOO HOT. BUILDING.						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282856	4/29/2014	1	Created	RM 206 IS TOO HOT						
FO-282938	4/30/2014	0	Created	RM 134 TOO HOT						
FO-282943	4/30/2014	0	Created	The air conditioner unit by room 156 in this suite is leaking again. They just repaired it I						
E - Northeast			3	3	0	0	0	0	0	
FO-282378	4/23/2014	7	Created	POD DOOR WILL NOT OPEN. 1ST FLOOR LOBBY.						
FO-282388	4/23/2014	7	Created	RM 120 IS TOO COLD						
FO-282935	4/30/2014	0	Created	Cold call. Cold now for 2 days.						
E - Preventative Maintenance			9	2	0	2	0	5	0	
FO-265275	10/23/2013	189	Completed	VERY COLD. ROOM 2033.						
FO-265418	10/24/2013	188	Created	RM 320 HOOD NOT WORKING						
FO-265533	10/25/2013	187	Not Finished	3RD FLR WOODCOCK WING STACK AREA IS TOO HOT						
FO-265630	10/28/2013	184	Completed	Too cold in this room - air flow stronger in ths room than others.						
FO-265631	10/28/2013	184	Completed	Too cold in this room - air flow stronger in this room than others.						
FO-276268	2/21/2014	68	Created	Replace motor mount & belts						
FO-276485	2/24/2014	65	Work in progress	1ST FL SUITE TOO HOT						
FO-281466	4/14/2014	16	Work in progress	R/R RM 3101 REPLACE DIAPHRAM ON TOILET CONTINUOUSLY FLUSHING. ROOM						
FO-281895	4/17/2014	13	Created	RMS 1107.4 & 1107.5 CLNG VENT IS MAKING A LOUD NOISE.						
E - South			2	2	0	0	0	0	0	
FO-282900	4/30/2014	0	Created	RM 0034 TOO HOT, OCCUPANT WOULD LIKE TO KNOW IF STEAM HAS BEEN TU						
FO-282977	4/30/2014	0	Created	room is 84 degrees and climbing.						
E - Southeast			6	0	1	4	0	1	0	
FO-265565	10/28/2013	184	Created	Make boiler #1 ready for normal operation.						
FO-274340	1/31/2014	89	Created	Fitter replace leaking remote grease lines to fan bearings on AH-6						
FO-275091	2/7/2014	82	Created	Engineer replace freeze stat on AH-2						
FO-276233	2/20/2014	69	Created	2ND FLR STORAGE AREA NEAR RESTROOMS (UNISEX SIDE BY SIDE) CLNG IS L						
FO-276234	2/20/2014	69	Created	RM 235 CLNG IS LKNG						
FO-279200	3/24/2014	37	Created	RM 220 TOO COLD, RED LIGHT ON						
E - West			2	2	0	0	0	0	0	
FO-280095	4/1/2014	29	Created	ROOFTOP UNIT 100 NOT HEATING						
FO-281140	4/9/2014	21	Created	RM 100/LECT HALL IS TOO HOT						
Low			139	85	8	20	22	4	0	54
E - Area 1 Engineer			5	0	1	0	2	2	0	
FO-261746	9/13/2013	229	Not Completed	grainger						
FO-264476	10/15/2013	197	Created	ENGINEER (J.KEYS) MED PRIORITY						
FO-271650	1/2/2014	118	Created	ceiling leak in front of elevators						
FO-271665	1/2/2014	118	Created	STEAMFITTERS-						
FO-278257	3/12/2014	49	Created	Custodial Med. Priority						
E - Auxiliary			29	26	1	2	0	0	0	
FO-274302	1/31/2014	89	Open to Shops	CALLED SCHINDLER ELEV CO FOR #2/SOUTH ELEV WAS SHUTDOWN YESTERD						
H-44420	2/26/2014	63	Created	track lighting over seating area not working. was changed out but still not working.						
H-44703	3/19/2014	42	Created	Please replace or repair the float valve in the toilet in the second bathroom.						
H-45023	4/10/2014	20	Created	loud noise coming from toilet						
H-45021	4/10/2014	20	Created	Please fix the shower.authenticated user: Suryakanth Krishna Sumanth Chebolu - fk3						
H-45028	4/13/2014	17	Created	Dropped an earring in the sink. Needs it to be removed ASAP						
H-45090	4/15/2014	15	Created	The heater in the main living room is broken. The thermostat screen is blank and appea						
H-45103	4/16/2014	14	Created	Kitchen Sink not working.Water leakageauthenticated user: Vikas Sanghavi - fl416						
H-45105	4/16/2014	14	Created	1. Closet door of 1st bedroom broken2. Exhaust fan of 2nd restroom not workingUrg						
H-45120	4/18/2014	12	Created	Ceiling is leaking water.						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
H-45121	4/18/2014	12	Created	Replace garbage disposal						
H-45127	4/18/2014	12	Created	My shower head is leaking and has been for the last few days. It's actually gotten worse						
H-45130	4/18/2014	12	Created	Erator not working.authenticated user: Sanjana Prabhakar - fd0456requester ip addr						
H-45136	4/19/2014	11	Created	Garbage disposal is not working. The sink in the first bathroom does not drain properly.						
H-45140	4/20/2014	10	Created	the kitchen sink is blocked because the rotor dosent work. olease help.authenticated u						
H-45137	4/20/2014	10	Created	In the second bathroom, the bath tub pipe is leaking . Kindly fix it.authenticated user:						
H-45142	4/21/2014	9	Created	request for the repair of kitchen sink garbage disposer, it's not working at all, thanks.a						
H-45155	4/21/2014	9	Created	The garbage disposal does not work. It makes a weird noise and doesn't grind anything,						
H-45196	4/23/2014	7	Created	1. The right side of my mirror medicine cabinet needs to be put back on its track. 2. M						
H-45188	4/23/2014	7	Created	Mechanical check						
H-45191	4/23/2014	7	Created	Mechanical check						
H-45216	4/24/2014	6	Created	Frisbee was thrown on the roof of Gold N Greens and a ladder is needed for it to be rem						
H-45212	4/25/2014	5	Created	the lights in the corridor and bathroom, the sink stirring in the kitchen, and one shower i						
H-45215	4/25/2014	5	Created	Please repair or replace the faucet in the kitchen sink.						
H-45221	4/25/2014	5	Created	Garbage Disposalauthenticated user: Emily Bryce - cp8833requester ip address: 35.						
H-45229	4/26/2014	4	Created	The garbage disposal / sink in the kitchen is leaking water whenever I run water in kitch						
H-45266	4/29/2014	1	Created	Kitchen sink disposer does not work authenticated user: Hui Guan - bb1733requeste						
H-45279	4/29/2014	1	Created	Room heating system is not working and became very cold,difficult to stay. Please rectif						
H-45281	4/29/2014	1	Created	The hot water tap in the shower is not working.authenticated user: Ashley Fry - ej8471						
E - Command Center			53	41	2	2	7	1	0	
FO-265966	10/31/2013	181	Created	Control Engineer; Medium						
FO-266306	11/4/2013	177	Work in progress	Labs are very warm (80+ degrees) on north west wing of building, all floors.						
FO-267754	11/19/2013	162	Created	Inspect large air compressor at MEB. Determine overall condition report to Rick Massa/						
FO-267973	11/21/2013	160	Created	CONTROLS CREW,						
FO-268121	11/22/2013	159	Need Siemens Assistance	Work with DOug VanDyke from Fishbeck, Thompson, Carr & Huber on Manoogian stud						
FO-269022	12/4/2013	147	Parts Arrived	REPLACE FAULTY DAMPER MOTOR ON EXHAUST DUCT. (RM 2550 LOUD RUBBI						
FO-271266	12/23/2013	128	Created	Trade Controls priority medium						
FO-271800	1/3/2014	117	Created	Trade: ControlsPriority: HighR/R PENTHOUSE Please adjust/repair controls for AH						
FO-276662	2/25/2014	64	Created	Blowers are too powerful, staff are complaining cool air is blowing on them and it is maki						
FO-276816	2/27/2014	62	Created	Control group,						
FO-278311	3/12/2014	49		R/R RM 140 AUXILIARY HVAC UNIT ISN'T WORKING RM HAS NO HEAT						
FO-278311	3/12/2014	49		R/R RM 140 AUXILIARY HVAC UNIT ISN'T WORKING RM HAS NO HEAT						
FO-280507	4/2/2014	28	Work in progress	A/C Controls, please repair/replace bad Siemens control in panel behind AHU-4 (AHU-5						
FO-280560	4/2/2014	28	Created	Trade: ControlsPriority: MediumR/R 8TH FLR Please supply one Honeywell 8" Diap						
FO-280642	4/3/2014	27	Created	Controls: Med High Priority.						
FO-280757	4/4/2014	26	Created	CSD-1 results found:						
FO-280880	4/7/2014	23	Created	Trade: Controls Priority: HighTag #090-COT-002R/R ROOF Pneumatic cooling tower						
FO-280966	4/8/2014	22	Created	CSD-1 results:						
FO-280968	4/8/2014	22	Work in progress	CSD-1 results:						
FO-281017	4/8/2014	22	Parts on Order	repair HVAC unit or stat that controls heating and cooling on the first floor of Freer hous						
FO-281481	4/14/2014	16	Created	HONEYWELL:						
FO-281484	4/14/2014	16	Created	HONEYWELL:						
FO-281725	4/15/2014	15	Created	R/R RM 00025/MECH RM Fan HV-1 for hot kitchen has defective return air damper mot						
FO-281726	4/15/2014	15	Created	A/C shop						
FO-281797	4/16/2014	14	Created	"Data Drop" mechanical room 1618						
FO-281790	4/16/2014	14	Created	CSD-1 results:						
FO-281791	4/16/2014	14	Created	CSD-1 results:						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-281792	4/16/2014	14	Created	CSD-1 results:						
FO-281795	4/16/2014	14	Created	CSD-1 results:						
FO-281798	4/16/2014	14	Created	CSD-1 results:						
FO-281804	4/16/2014	14	Not Finished	Control Engineer; High						
FO-281866	4/17/2014	13	Created	Trade: Controls						
FO-281877	4/17/2014	13	Created	Control Engineer; Medium						
FO-281986	4/20/2014	10	Created	Repair reheat control serving mixing box in hallway outside of Room 0407. Hot air blowi						
FO-281987	4/20/2014	10	Created	The mixing box reheat, (VAV?), serving the hallway outside of Room 0325 at Law Librar						
FO-282011	4/21/2014	9	Created	A/C shop repair boiler #1. No low water alarm.						
FO-282323	4/22/2014	8	Created	controls group,						
FO-282329	4/22/2014	8	Created	Investigate and correct cause of faulty temperature control on #2 dom water heater.						
FO-282395	4/23/2014	7	Created	Refg. Crew:						
FO-282396	4/23/2014	7	Created	Refg. Crew:						
FO-282471	4/24/2014	6	Created	The following fume hoods are not in the airflow range of 80 fpm:						
FO-282509	4/24/2014	6	Created	Control Engineer; High						
FO-282512	4/24/2014	6	Created	Control Engineer; High						
FO-282518	4/24/2014	6	Created	Trade: Controls						
FO-279378	4/29/2014	1	Created	Refg Crew:						
FO-279639	4/29/2014	1	Work in progress	Controls group.						
FO-278819	4/29/2014	1	Created	Trade: Controls						
FO-279420	4/29/2014	1	Work in progress	A/C shop						
FO-282903	4/30/2014	0	Created	Heat Pump Not Working - Please troubleshoot						
FO-282920	4/30/2014	0	Created	Bryant bolier # 1, Recommend bringing controls up to CSD-1 standards by adding separ						
FO-282921	4/30/2014	0	Created	Bryant bolier # 2, Recommend bringing controls up to CSD-1 standards by adding separ						
FO-282924	4/30/2014	0	Created	Laars boiler, gas valve actuator leaking oil, Unit passed CSD-1.						
FO-282937	4/30/2014	0	Created	Trade: Controls (Siemens) Priority: Medium						
E - Director			1	0	0	0	0	1	0	
FO-258262	8/6/2013	267	Created	Cooling tower on the roof of the building is leaking water all over the roof and the coils o						
E - MedPharm			34	11	3	10	10	0	0	
FO-267461	11/15/2013	166	Work in progress	Paint Engineer's office and mechanical room 11.						
FO-267830	11/20/2013	161	Work in progress	SHEETMETAL:						
FO-269590	12/11/2013	140	Created	Aquire data logger to record temperature and humidity						
FO-269962	12/13/2013	138	Created	ENGINEER						
FO-271165	12/20/2013	131	Created	Repair a humidifer for/in the DLAR area.						
FO-272883	1/15/2014	105	Created	Soot and dirt from air vent effecting						
FO-272905	1/15/2014	105	Created	ENGINEER						
FO-273535	1/22/2014	98	Work in progress	Re-build hydronic heating pump Y398232A.						
FO-273538	1/22/2014	98	Work in progress	Re-build hydronic heating pump Y398233A						
FO-273725	1/24/2014	96	Created	R/R RM 00018/MECH RM Engineer repace diaphragm on Steam control valve to prehe						
FO-274417	2/2/2014	87	Created	Is there any way to heat to this box office? It is currently 60 degrees in this room.						
FO-275381	2/11/2014	78	Created	ENGINEER						
FO-276882	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceilings. rooms: 4						
FO-276883	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 412.						
FO-276884	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 413.						
FO-276885	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 414.						
FO-276887	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 416.						
FO-276888	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 417.						
FO-276889	2/28/2014	61	Created	R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 419.						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-276890	2/28/2014	61	Created							R/R INSIDE STE 400 4-Air filters need to be changed in animal room ceiling. RM 415.
FO-277812	3/6/2014	55	Created							Bldg. Engineer
FO-278409	3/14/2014	47	Work in progress							EMERGENCY Isolated / Abatement in progress / Priority lowered JWT
FO-279461	3/26/2014	35	Work in progress							Air vents throughout entire animal quarters are rusty due to humidity issues. They need
FO-280088	4/1/2014	29	Created							R/R ROOF please replace the fills ON cooling tower #1 IT IS in bad shape. heat transfer
FO-280089	4/1/2014	29	Created							Please
FO-280492	4/2/2014	28	Work in progress							Air pressure in rooms ; 2314,2316, 2318, 2320, 2322 and 2323 is positive to the hall, it
FO-280497	4/2/2014	28	Work in progress							Room 2307 has duct tape over the exhaust vent. We need to have the exhaust fixed co
FO-281231	4/10/2014	20	Created							RM 9320 1ST BENCH @ ENT DOOR WHEN FAUCET IS ON IT TURNS ON THE FAU
FO-281432	4/14/2014	16	Created							Upper floors, 3rd and 4th floors temperature is too warm, average temp is 84. Please c
FO-281728	4/15/2014	15	Created							Please change filters in ceiling as soon as possible. There are black particles all over th
FO-281814	4/16/2014	14	Created							FILTER NEED TO BE CHANGED. ROOM 7119.
FO-282472	4/24/2014	6	Created							The following fume hoods need to be adjusted to proper airflow range of 80 -120 feet per
FO-282522	4/24/2014	6	Created							CONTRACTOR: KROPF MECH SVC:
FO-282841	4/29/2014	1	Created							MEET W/GOLDEN REFRIGERANT LOADING DOCK AREA PER CHARLES R APPR 1
E - North			3	0	0	2	1	0	0	
FO-273392	1/21/2014	99	Work in progress							There is insulation exposed around a major
FO-274885	2/5/2014	84	Created							Purdy Library, 2nd Floor
FO-274886	2/5/2014	84	Created							Purdy Library, 2nd Floor
E - Northeast			3	3	0	0	0	0	0	
FO-280754	4/4/2014	26	Created							Clean condenser coils on RTU's.
FO-280756	4/4/2014	26	Created							Clean condenser coils on RTU's.
FO-282530	4/24/2014	6	Not Finished							Furnace #5 in the Art Sculpture Foundry makes an explosion sound and then turns off.
E - Preventative Maintenance			5	2	0	1	2	0	0	
FO-266306	11/4/2013	177	Work in progress							Labs are very warm (80+ degrees) on north west wing of building, all floors.
FO-268319	11/25/2013	156	Open to Shops							RM 166/BATH RM SINK DRAINS HAVE A SEWAGE SMELL (BLEACH/DEODORIZER
FO-276662	2/25/2014	64	Created							Blowers are too powerful, staff are complaining cool air is blowing on them and it is maki
FO-280697	4/4/2014	26	Created							Misc Filter Order -
FO-282369	4/23/2014	7	Created							Replace Belt
E - South			3	1	0	2	0	0	0	
FO-276114	2/19/2014	70	Open to Shops							R/R RM 0034 SEAL WALLS THAT ARE OOZING WATER
FO-276975	2/28/2014	61	Created							R/R RM 0034 SEAL WALLS THAT ARE OOZING WATER
FO-281211	4/10/2014	20	Created							Room 310.5 walk in cooler short cycling.
E - Southeast			3	1	1	1	0	0	0	
FO-282326	2/25/2014	64	Created							CONTROLS CREW,PLEASE INSTALL BIMETAL THERMOMETERS IN THE SUPPL
FO-279397	3/25/2014	36	Created							CALLED SCHINDLER ELEV CO FOR #1/FREIGHT NOT RESPONDING
FO-280526	4/2/2014	28	Created							CHECK WINDOW SEAL FOR POSSIBLE LEAK. (WARPED)
Routine			1	0	0	0	1	0	0	1
E - Command Center			1	0	0	0	1	0	0	
FO-267967	11/21/2013	160								Closure project; Perform PM on Beecher House A/C units. Carl Ballou is available for as
Grounds			2	2	0	0	0	0	0	0
High			1	1	0	0	0	0	0	0
G - Physical Grounds			1	1	0	0	0	0	0	
FO-281279	4/10/2014	20	Created							Ray Lindenmuth, Grounds Supervisor, says: he cannot do this job.
Routine			1	1	0	0	0	0	0	0
G - Physical Grounds			1	1	0	0	0	0	0	
FO-281497	4/14/2014	16	Created							Received in Grounds 4/15/14 - given to Don Wrench.

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
Trades				621	377	134	61	46	3	0	244
Emergency				12	10	1	1	0	0	0	2
T - Electrician				5	4	1	0	0	0	0	
FO-279499	3/26/2014	35	Created	NEED ELEC TO CHECK WHY DC MOTOR GENERATOR IS RUNNING IN THE BSMN							
FO-282016	4/21/2014	9	Created	TROUBLESHOOT VFD4 CONDENSING PUMP#8 FAN WON'T RUN							
FO-282806	4/29/2014	1	Created	EMERGENCY ELEC							
FO-282834	4/29/2014	1	Created	FIRE TROUBLE ALARM							
FO-282896	4/30/2014	0	Created	FIRE TROUBLE ALARM							
T - Laborer				1	0	0	1	0	0	0	
FO-276167	2/20/2014	69	Created	Adding Laborer: please bring a gondola to eletrical room next to generator. See Mike Pu							
T - Pipefitter				3	3	0	0	0	0	0	
FO-282619	4/28/2014	2	Created	EMERGENCY/PIPE							
FO-282826	4/29/2014	1	Created	REPAIR LEAKING CHILLED WATER COIL FCU#1 FCU#2 RC/4-30-14							
FO-282890	4/30/2014	0	Created	A very bad ceiling leak through out suite 1600 1st floor UGL RC/4-30-14							
T - Plumber				3	3	0	0	0	0	0	
FO-282291	4/22/2014	8	Created	TRENCH DRAIN IS PLUGGED. ROOM 0235..... MM/ 4-22-14 DUE							
FO-282661	4/28/2014	2	Created	BSMNT; UTILITY CLOSET FLOOR DRAIN BACKING UP DB/ 4-28-14							
FO-282842	4/29/2014	1	Created	EMERGENCY (PLUMBING) POSSIBLE CONTRACTOR							
High				145	83	31	14	16	1	0	62
T - Carpenter				21	17	1	3	0	0	0	
FO-275501	2/12/2014	77	Created	Carpenters:							
FO-275759	2/15/2014	74	Created	Adding Carpenters: Evaluate erecting scaffold 3rd floor west stairwell. See Mike Pummil							
FO-276286	2/21/2014	68	Created	(** 2-24-14)Have carpenters re-do stair treads (2 steps) near Sandy Yarringtons cube in							
FO-277033	3/3/2014	58	Created	Adding Carpenter: Please provide a working platform to make Plumbing repair in clock t							
FO-280551	4/2/2014	28	Created	** Adding Carpenter: Disconnect 1 piece sink and counter top 0209 and deliver back to							
FO-280689	4/3/2014	27	Created	Adding Carpenter: Please remove and replace cider block to access plumbing repair ne							
FO-281092	4/9/2014	21	Created	CARPENTERS: Please replace broken floor tiles in room 4420. Trip/ Safety. MED.							
FO-281100	4/9/2014	21	Created	REMOVE METAL END CUP FROM SIDE OF BLDG. NEAR GARAGE DOOR. SEE S							
FO-281385	4/11/2014	19	Created	CARPENTERS: Please replace bad floor tiles in room 4230 trip/ safety MED.							
FO-281545	4/14/2014	16	Created	Trade: Carpenters							
FO-281701	4/15/2014	15	Created	ADDING CARP:							
FO-281747	4/16/2014	14	Created	Provide access in 1st floor mechanical room wall . See Mike Pummil for location							
FO-281827	4/17/2014	13	Created	ADDING ELEC/MAIN LABORER							
FO-281842	4/17/2014	13	Created	CONTRACTOR/RAYNOR OVERHEAD DOOR:							
FO-281878	4/17/2014	13	Created	Carpenter; High							
FO-282650	4/28/2014	2	Created	Trade: Carpenter							
FO-282687	4/28/2014	2	Created	**Adding Carpenter: Provide access in ceiling outside 2301 to repair condensate leak an							
FO-282830	4/29/2014	1	Created	416 CONF RM A LEAKING WINDOW SEAL, RM WILL BE OCCUPIED FROM 11:30am							
FO-282869	4/29/2014	1	Not Finished	THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED							
FO-282873	4/29/2014	1	Created	THE TRAINING RAMP BEHIND THE BLDG RAMP COLLAPSED							
FO-282945	4/30/2014	0	Created	ANGIE'S OFFICE CORE NEEDS TO BE FIXED, LOCK SPINS WITH KEY							
T - Electrician				43	18	23	1	1	0	0	
FO-272981	1/16/2014	104	Created	Adding Electricians : Order flow switch. Information provided by John Towle on 1-16-14.							
FO-274172	1/30/2014	90	Created	ADDING PIPE: RM 3133 FITTERS TO PULL MOTOR FROM THE PUMP FOR ELECT							
FO-278175	3/11/2014	50	Created	2 fixtures out in the loading dock							
FO-278753	3/18/2014	43	Created	Adding Electrician: Disconnect hotwater heater / recirculation pump and Rewire when PI							
FO-278832	3/18/2014	43	Created	Electrician; High							
FO-278833	3/18/2014	43	Created	Electrician; High							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-278834	3/18/2014	43	Created							Electrician; High
FO-278835	3/18/2014	43	Created							Electrician; High
FO-278836	3/18/2014	43	Created							Electrician; High
FO-278837	3/18/2014	43	Created							Electrician; High
FO-278838	3/18/2014	43	Created							Electrician; High
FO-278839	3/18/2014	43	Created							Electrician; High
FO-278840	3/18/2014	43	Created							Electrician; High
FO-278841	3/18/2014	43	Created							Electrician; High
FO-278842	3/18/2014	43	Created							Electrician; High
FO-278844	3/18/2014	43	Created							Electrician; High
FO-278845	3/18/2014	43	Created							Electrician; High
FO-278846	3/18/2014	43	Created							Electrician; High
FO-278847	3/18/2014	43	Created							Electrician; High
FO-278848	3/18/2014	43	Created							Electrician; High
FO-278849	3/18/2014	43	Created							Electrician; High
FO-278850	3/18/2014	43	Created							Electrician; High
FO-279677	3/28/2014	33	Created							FIRE TROUBLE ALARM NOT CLEARING:
FO-279722	3/28/2014	33	Created							Control air compressor unit #1 motor in basement, starting once, the tripping,, need elec
FO-279711	3/28/2014	33	Created							please amp motor, and check all controls to compressor # 1
FO-280106	4/1/2014	29	Created							Install light on pole to illuminate street next to drive way off Scott Hall.
FO-280615	4/3/2014	27	Created							ELECTRICIAN
FO-280832	4/7/2014	23	Created							PM - Air Compressor, Reciprocating 5-40 H.P.
FO-281111	4/9/2014	21	Created							Electricians: High Priority.
FO-281257	4/10/2014	20	Created							ELECTRICIANS,R/R RM 0001/MECH RM PLEASE REPAIR BAD MAKE-UP WATER
FO-281746	4/16/2014	14	Created							panel has 2 trouble issues
FO-281768	4/16/2014	14	Created							ELECTRICIANS (HIGH)
FO-281827	4/17/2014	13	Created							ADDING ELEC/MAIN LABORER
FO-282038	4/21/2014	9	Created							On the forth floor Carpenters are working off a scaffold, and noticed a fixture about to fal
FO-282623	4/28/2014	2	Created							R/R BLDG FAP FIRE TROUBLE ALARM ACTIVE
FO-282641	4/28/2014	2	Created							Evaluation of booster pump operations with Vendor on Tuesday 4-29-14. See John in Pi
FO-282854	4/29/2014	1	Created							Trade: Electricians
FO-282888	4/30/2014	0	Created							Power Outages Tuesday evening, and building experiencing low voltages Wednesday m
FO-282892	4/30/2014	0	Created							2ND FL LIGHTS NOT TURNING ON
FO-282974	4/30/2014	0	Created							Repair Light switch in Bathroom.
FO-282979	4/30/2014	0	Created							Hook up welder in basement mechanical room on 5-1-14 near chemical station. See Eri
FO-282984	4/30/2014	0	Created							Hook up welder in penthouse behind Engineers office for AH#2 on Friday 5-2-14 . See J
FO-282995	4/30/2014	0	Created							Time for Safety meeting for the month of May, 2014.
T - Laborer			1	0	1	0	0	0	0	
FO-278580	3/17/2014	44	Created							Adding Laborer: Transport hot water tank from stockroom to Engineering room 0310. Al
T - Pipefitter			42	24	4	3	11	0	0	
FO-267151	11/12/2013	169	Work in progress							RM 162 LEAK FROM PIPES, FLOODED RM
FO-271363	12/22/2013	129	Created							FITTERS:R/R PENTHOUSE Please repair the coil leaks in ACU #1 in the penthouse
FO-271400	12/24/2013	127	Created							please repair steam leak in pipe chase
FO-272171	1/8/2014	112	Created							RM 257 CEILING LEAK 3 DIFF AREAS ,,,,,,,,,,,,,, EA/RC 1-8-14 ,,,,,,,,,,,,,, DUE ASA
FO-272314	1/9/2014	111	Created							Water dripping through ceiling from floor above, through vent in middle of the room. Ani
FO-272516	1/10/2014	110	Created							Dirty side of cagewash has 4 ceiling leaks. One is dripping through the light fixture and t
FO-272981	1/16/2014	104	Created							Adding Electricians : Order flow switch. Information provided by John Towle on 1-16-14.
FO-273770	1/24/2014	96	Created							Fitters:

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-273779	1/24/2014	96	Created	Room 3567 has a water leak coming from the ceiling. We have a bucket collecting the						
FO-273810	1/27/2014	93	Created	ADDING PIPEFITTER:						
FO-273869	1/27/2014	93	Created	RM 2150 CEILING LEAK ,,,,,,,,,,,,,, EA/1-28-14 ,,,,,,,,,,,,,, DUE 1-29-14						
FO-274172	1/30/2014	90	Created	ADDING PIPE: RM 3133 FITTERS TO PULL MOTOR FROM THE PUMP FOR ELECT						
FO-274961	2/6/2014	83	Created	please replace 1/2 inch or 3/4 inch						
FO-276474	2/24/2014	65	Created	(**) P.O. Req DK						
FO-278033	3/10/2014	51	Created	CEILING LEAK. ROOM 0224,,,,,,,,,,,,,,,,, JH/3-10-14 ,,,,,,,,,,,,,, DUE 3-12-14						
FO-278366	3/13/2014	48	Created	Please have pipe fitters remove condensing tube bundle covers						
FO-278961	3/19/2014	42	Created	LAB 130 LEAK FROM VALVE ON WALL ,,,,,,,,,,,,,, EA/RC 3-20-14 ,,,,,,,,,,,,,, DUE 3-2						
FO-279027	3/20/2014	41	Work in progress	ADDING PIPEFITTERS						
FO-280140	4/1/2014	29	Created	CEILING LEAK. FACULTY LOCKER ROOM. ROOM 154.1						
FO-280713	4/4/2014	26	Created	fitters-R/R SUB BSMT sump pump #-2 leaking from seal,smell somewhat bad through						
FO-280958	4/8/2014	22	Created	(**) P.O. Req DK						
FO-280995	4/8/2014	22	Created	Plumbers:						
FO-281002	4/8/2014	22	Created	OUTSIDE RM 302 CEILING LEAK VERY CLOSE TO ELECTRICAL OUTLET ,,,,,,,,,,,,,,						
FO-281232	4/10/2014	20	Created	RM 415 WATER PIPE LEAKING OVER AUTO CLAVE, LEAKING ON CONTROLS SE						
FO-281874	4/17/2014	13	Created	Trade: Pipefitters						
FO-281969	4/18/2014	12	Created	Steam Leak abouve AH#2 on steam supply to air handler coil. Replace gasket at flange						
FO-282094	4/21/2014	9	Created	Ahu-3 on the third floor has a chill coil leak and needs repair. High- High Priority. ,,,,,,,,,,						
FO-282551	4/25/2014	5	Created	Trade: Pipefitter						
FO-282565	4/25/2014	5	Created	HALLWAY OUTSIDE RM 2238 CEILING LEAK ,,,,,,,,,,,,,, JH/ 4-25-14 ,,,,,,,,,,,,,, DUE A						
FO-282570	4/25/2014	5	Created	Fitters, please repair leak in steam coil on AHU-2. Priority: high ,,,,,,,,,,,,,,ME/ 4-25-14						
FO-282591	4/25/2014	5	Created	Lowered Priority JWT						
FO-282600	4/25/2014	5	Created	Trade: Pipefitter						
FO-282616	4/26/2014	4	Created	Repair leaking heating control valve located above the ceiling in 319. Relatively minor le						
FO-282634	4/28/2014	2	Created	Fitters, please repair steam leak on AHU-1. Priority: high						
FO-282635	4/28/2014	2	Created	Fitters, please repair steam leak on AHU-2. Priority: high						
FO-282636	4/28/2014	2	Created	Fitters, please repair steam leak on AHU-4. Priority: high						
FO-282643	4/28/2014	2	Created	1366 CEILING LEAK, TILE FELL FROM CEILING ,,,,,,,,,,,,,, EA/4-28-14 ,,,,,,,,,,,,,, DU						
FO-282656	4/28/2014	2	Created	Trade: Pipefitters						
FO-282671	4/28/2014	2	Created	Trade: Pipefitter						
FO-282697	4/28/2014	2	Open to Shops	STEAM LEAK NEAR BAY DOOR/ROCKS						
FO-282895	4/30/2014	0	Created	CEILING LEAK'S NEAR RM'S 200.02 AND 200.05						
FO-282922	4/30/2014	0	Created	Pipefitters Priority High						
T - Plumber			32	20	1	6	4	1	0	
FO-265770	10/29/2013	183	Work in progress	FAUCET WATER IS VERY HOT AND MAKING BEEPING SOUND. 3RD FLOOR MEN'						
FO-272263	1/9/2014	111	Created	Split 1" domestic water line located in mechanical closet near the office in Parking Struc						
FO-272635	1/13/2014	107	Created	the right hand urinal in the first floor men's room it missing the knob on the flusher valve,						
FO-272783	1/14/2014	106	Created	No hot water in UGL Staff Lounge, Room 1505 ,,,,,,,,,,,,,, RJC/RB 1-14-14 ,,,,,,,,,,,,,, D						
FO-273595	1/23/2014	97	Created	BSMNT 0249 FAUCET WONT TURN OFF ,,,,,,,,,,,,,, MP/DB 1-30-14 ,,,,,,,,,,,,,, DUE AS						
FO-274220	1/30/2014	90	Open to Shops	ADDING PLUMBER						
FO-275710	2/14/2014	75	Created	(**) P.O. Req DK						
FO-275759	2/15/2014	74	Created	Adding Carpenters: Evaluate erecting scaffold 3rd floor west stairwell. See Mike Pummil						
FO-276406	2/24/2014	65	Cancelled	BSMNT MENS LOCKER RM 114 LOW WATER PRESSURE						
FO-276763	2/26/2014	63	Created	RE: Labs 3028 & 3040						
FO-276771	2/27/2014	62	Created	SUMP PUMP PIPING IS LEAKING. MECHANICAL ROOM IN BASEMENT. SEE ENGI						
FO-279219	3/24/2014	37	Created	Trade: Plumber						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-279804	3/31/2014	30	Created	(**) P.O. Req DK						
FO-280635	4/3/2014	27	Created	Men's restroom has urinal (middle) that is not flushing. Room 2111. Please help.						
FO-280676	4/3/2014	27	Created	RM 0354 - GRAD STUDENT INSIDE SAYS ONLY SINK IS BADLY PLUGGED UP						
FO-281559	4/14/2014	16	Not Finished	INSIDE RM 1520 UNISEX BATH RM ONLY TOILET ISN'T FLUSHING RB/ 4-						
FO-281947	4/18/2014	12	Created	Trade: Plumbers						
FO-281948	4/18/2014	12	Created	SINK CRACKED. ROOM 2131. MP/DB 4-18-14 DUE ASAP						
FO-281957	4/18/2014	12	Work in progress	NO HOT WATER. ROOM 205..... MM/ 4-18-14 DUE ASAP						
FO-282358	4/22/2014	8	Created	TOILETS LEAKING AT BOTTOM. LADIES RESTROOM. ROOM 1378..... MM/ 4						
FO-282429	4/23/2014	7	Created	ADDING PLUM						
FO-282550	4/25/2014	5	Created	MAIN FL NEAR HANDICAP STALL WATER FOUNTAIN CONTINUOUSLY RUNNING ..						
FO-282556	4/25/2014	5	Created	MENS RM 3RD & 4TH FL WOMENS RM 4TH FL ALL SEEM TO RUN OVER AFTER B						
FO-282603	4/25/2014	5	Created	We are still getting complaints about the hot water in this building. Currently it's coming						
FO-282665	4/28/2014	2	Created	7TH FL MENS RM URINALS NOT FLUSHING RB/4-28-14 DUE A						
FO-282666	4/28/2014	2	Created	2ND FL WATER FOUNTAIN, WATER COMES OUT BROWNISH COLOR						
FO-282686	4/28/2014	2	Created	Lowered to High / To Return 4-30-14 9:00 AM JWT						
FO-282822	4/29/2014	1	Created	RM 8255 HOT WATER NOT WORKING RB/ 4-29-14 DUE 5-1-14						
FO-282823	4/29/2014	1	Created	R/R RM 382/JANITOR'S CLOSET SLOP SINK COLD WTR FAUCET WILL NOT SHUT						
FO-282824	4/29/2014	1	Created	RM 9204 DRAIN CLOGGED RB/ 4-29-14 DUE 5-1-14						
FO-282836	4/29/2014	1	Created	Trade: Plumbers						
FO-282925	4/30/2014	0	Created	Trade: Plumber Priority: High						
T - Roofing			4	3	0	1	0	0	0	
FO-276362	2/21/2014	68	Created	Adding Roofer: Please re-visit roof for leaking issue that is still in room 330						
FO-281701	4/15/2014	15	Created	ADDING CARP:						
FO-282814	4/29/2014	1	Created	RM 5625 CEILING LEAK, FLASHING LEAK SEE TONY CRAWLEY						
FO-282827	4/29/2014	1	Created	Roofing High Priority						
T - Sheetmetal			2	1	1	0	0	0	0	
FO-278910	3/19/2014	42	Created	Trade: Sheetmetal						
FO-280117	4/1/2014	29	Created	Trade: SheetmetalPriority: HighR/R 2ND FLR Numerous complaints the fume hoo						
Medium			156	90	30	19	16	1	0	66
T - Carpenter			20	12	3	4	1	0	0	
FO-272748	1/14/2014	106	Created	Reference WO #FO-256730/264677.						
FO-274504	2/3/2014	86	Created	Floor tile replacement needed through-out the hallways on the 2nd Floor. Outside of the						
FO-275413	2/11/2014	78	Created	(**2-12-14)Carpenters:						
FO-276191	2/20/2014	69	Created	Please replace missing floor tiles adjacent to room 2110, 2206 and 2216.						
FO-276192	2/20/2014	69	Created	Please replace missing floor tiles in the hallway adjacent to room 3124.						
FO-277024	3/3/2014	58	Created	CARPENTERS: Please repair uninsulated walls in rooms 2150 & 2156. Please refer to						
FO-277074	3/3/2014	58	Created	Carpenters: please repair or replace bent floor tile in front of west window, it is a trip haz						
FO-279139	3/21/2014	40	Created	Floor tiles are lifting off the floor on north wall of class room 315.						
FO-279799	3/31/2014	30	Created	CARPENTERS,						
FO-281027	4/8/2014	22	Created	CARPENTERS: Please replace bad floor tiles in room 4240. Trip/ Safety MED.						
FO-281301	4/10/2014	20	Created	Adding Carpenter: Please provide access in wall next to drinking fountain on 1st floor ne						
FO-281408	4/12/2014	18	Created	Repair wall from plumbing repair in room 14200. Also fire ext cabinet back needs repair n						
FO-281411	4/12/2014	18	Created	**Adding Carpenter: Repair block wall or cover hole in machine shop where new utility si						
FO-281439	4/14/2014	16	Created	Carpenter build support under duct for AH-1 exhaust under energy recovery coil so engi						
FO-282433	4/23/2014	7	Created	Carpenter; Medium						
FO-282561	4/25/2014	5	Created	CARPENTERS:R/R ROOF Please install 2 Cooling Tower Platforms on roof towers at						
FO-282581	4/25/2014	5	Created	Please replace missing floor tiles in the hallway adjacent to room 3087.2						
FO-282670	4/28/2014	2	Created	Carpenters please replace damaged ceiling tile Stairwell is located in hallway from cass						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282820	4/29/2014	1	Created	Trade: CARP Priority: MediumR/R 3RD FLR Water is leaking in at Window Wall of the						
FO-282835	4/29/2014	1	Created	Purdy Library, 4th Floor, Room 426 (corner office).						
T - Electrician			19	13	5	1	0	0	0	
FO-276268	2/21/2014	68	Created	Replace motor mount & belts						
FO-278266	3/12/2014	49	Created	Dewire / rewire condensate pump #1 in fan room . See Ron Clark						
FO-278398	3/13/2014	48	Created	ELECTRICIANS, R/R RM 307.1 CFC UNIT TRIPPING BREAKER, PLEASE REPAIR.						
FO-279617	3/27/2014	34	Created	Trade: Electrician Priority: MediumR/R OUTSIDE OF BLDG Please replace burnt out li						
FO-279697	3/28/2014	33	Created	Adding Electrician: Please dewire/rewire condensate pump #2. See Ron Clark						
FO-279775	3/29/2014	32	Created	Repair or replace faulty recessed can light located in president's apartment over the gra						
FO-280188	4/2/2014	28	Created	Continuous issues with intermittent trouble alarms. Ground fault,						
FO-281033	4/8/2014	22	Created	Relamp all Mall Lights.						
FO-281058	4/8/2014	22	Created	The aluminum frame around the light fixture is not screwed into the ceiling. It is hanging.						
FO-281821	4/17/2014	13	Created	Pick-up pole that was knocked down, make safe, and try to replace.						
FO-282027	4/21/2014	9	Created	R/R RM 400.10/MECH RM Electrician heat trace the blow down lines on boiler #3.						
FO-282797	4/29/2014	1	Created	ELECTRICIANR/R RM 00051/MECH RM PLEASE REPAIR OR REPLACE FAULTY						
FO-282829	4/29/2014	1	Created	Please have Maintenance Laborer deliver copier located outside Stockroom window to						
FO-282857	4/29/2014	1	Created	Trade: Laborer						
FO-282879	4/29/2014	1	Created	RE: Law Library						
FO-282940	4/30/2014	0	Created	Trade: Laborer						
FO-282976	4/30/2014	0	Created	please pick up steam coil that needs to be repaired and deliver when finished....						
FO-282982	4/30/2014	0	Created	Electrician//Laborer--please deliver heat pump and compressor to loading dock of 5057-						
FO-282994	4/30/2014	0	Created	ELECTRICIANS-please replace bad motor on chilled water circ pump in penthouse (1.5						
T - Laborer			2	1	1	0	0	0	0	
FO-279533	3/26/2014	35	Created	Retrive scaffold in Bio Sci basement mens room see Mike Pummill if needed. Also Base						
FO-282612	4/25/2014	5	Created	Adding Laborer: Insulate exposed domestic water lines from plumbing repair in garage.						
T - Locksmith			1	1	0	0	0	0	0	
FO-280710	4/4/2014	26		Replace broken OE31 key for Aubrey Waller.						
T - Painter			2	1	0	0	1	0	0	
FO-272748	1/14/2014	106	Created	Reference WO #FO-256730/264677.						
FO-282669	4/28/2014	2	Created	PAINTERS please replace damaged ceiling tile and paint/repair minor water damage on						
T - Pipefitter			52	25	9	8	10	0	0	
FO-266305	11/4/2013	177	Work in progress	RM 1305 THERE IS A CLNG PIPE LEAK						
FO-266305	11/4/2013	177	Work in progress	RM 1305 THERE IS A CLNG PIPE LEAK						
FO-272448	1/10/2014	110	Created	Trade: Pipefitter Priority: medium						
FO-272450	1/10/2014	110	Created	Trade: Pipefitter Priority: Medium						
FO-272451	1/10/2014	110	Created	Trade Pipefitter Priority medium						
FO-272621	1/13/2014	107	Created	Trade: Pipefitters						
FO-273135	1/17/2014	103	Created	(**) P.O. Req DK						
FO-273398	1/22/2014	98	Created	(**) P.O. Req DK						
FO-273442	1/22/2014	98	Created	*Work in progress JWT						
FO-273687	1/24/2014	96	Created	Trade: Pipefitter						
FO-274244	1/30/2014	90	Created	PIPEFITTERS please r/r bad trap from round reznor heating unit in main garage at FP&						
FO-275220	2/10/2014	79	Created	please chk room 263 cold possable blockage...See Corey b4 repair,,,,,,,,,,,,, EA/RC 2-						
FO-275400	2/11/2014	78	Created	PF Med Priority						
FO-275724	2/14/2014	75	Created	(**) P.O. Req DK						
FO-276094	2/19/2014	70	Need to work with Honeywell	ADDING CONTROLS GROUP:						
FO-276282	2/21/2014	68	Created	PIPEFITTERS						
FO-276672	2/26/2014	63	Created	(**) P.O. Req DK						

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-276871	2/28/2014	61	Created	Fitters:							
FO-277005	3/3/2014	58	Created	STEAM FITTERS-PLEASE REPAIR LEAK IN #1 CONDENSTATE TRANSFER PUMP-							
FO-277081	3/3/2014	58	Created	rplace seloind valve blown down controll n repair by pass valve							
FO-277602	3/4/2014	57	Created	(**) P.O. Req							
FO-278216	3/11/2014	50	Created	FITTERS,							
FO-278441	3/14/2014	47	Created	(**) P.O. Req DK							
FO-278448	3/14/2014	47	Created	PIPEFITTERS please repair leaking steam coil AHU1 at Mort Sci.,,,,,,,,,,,,,, ME/3-14-1							
FO-278450	3/14/2014	47	Created	PIPEFITTERS please r/r rear blowdown valve Boiler #1 at 5425 Woodward. Valve is ver							
FO-278988	3/20/2014	41	Created	Pipefitter; Medium							
FO-279108	3/21/2014	40	Created	(**) P.O. Req DK							
FO-279858	3/31/2014	30	Created	*Motor on order							
FO-280518	4/2/2014	28	Created	(**) P.O. Req DK							
FO-280714	4/4/2014	26	Created	Trade: Pipefitter Priority: Medium							
FO-280758	4/4/2014	26	Created	Trade: Pipefitters							
FO-280869	4/7/2014	23	Created	PIPEFITTERS,							
FO-281003	4/8/2014	22	Created	Pipefitters: MED HIGH Priority							
FO-281261	4/10/2014	20	Created	Condensate pump #1 has defective check valve and condensate pump #2 has broken s							
FO-281524	4/14/2014	16	Created	PIPEFITTERS,							
FO-282008	4/21/2014	9	Created	fitters: please replace bearing assembly on unit #13 leaking bad mechanical room 253 ,							
FO-282036	4/21/2014	9	Created	FITTERS: Please repair coil leak on AHU#8							
FO-282098	4/21/2014	9	Created	Fitters please replace/repair water regulating valve in PH. Valve is located above chilled							
FO-282313	4/22/2014	8	Created	R/R RM 114 RERHEAT LEAKING FOR VAV We have a leak in room 114. The engineer							
FO-282307	4/22/2014	8	Created	ELECTRICIAN							
FO-282373	4/23/2014	7	Created	replace frozen 3/4 polly valve into							
FO-282425	4/23/2014	7	Created	AHU-3 has a plugged heating coil and leaking isolation valves. Please repair or replace							
FO-282430	4/23/2014	7	Created	ADDING PIPE							
FO-282447	4/24/2014	6	Created	Packing is leaking on 8" control valve on fire protection system (inside boiler rm)							
FO-282470	4/24/2014	6	Created	PIPEFITTERS please r/r dripping condensate line in room 124. condensate line appears							
FO-282482	4/24/2014	6	Created	CEILING LEAK (TILES WET). WOMEN'S RESTROOM. ROOM 502.,,,,,,,,,,,,,, ME/4-25							
FO-282553	4/25/2014	5	Created	FITTERS: Please repair / replace heating valve in room 0540 NORTH VAV. MED.,							
FO-282590	4/25/2014	5	Created	Pipe fitter; Medium							
FO-282657	4/28/2014	2	Created	Trade: Pipefitters							
FO-282930	4/28/2014	2	Created	Repair 2ed leak from ceiling in hallway near room 2301, EA/4-28-14,							
FO-282682	4/28/2014	2	Created	R/R cracked return condensor water valves on roof.,,,,,,,,,,,,,, ME/4-28-14, DU							
FO-282906	4/30/2014	0	Created	Pipefitter; Medium							
T - Plasterer				1	0	0	0	1	0	0	
FO-268834	12/3/2013	148	Created	WALL NEEDS TO BE REPAIRED SQUIRRELS HAVE EATEN A WHOLE IN WALL.WA							
T - Plumber				55	34	11	6	3	1	0	
H-39863	8/7/2013	266	Created	Re plumb chemical supply equipment for Cooling Tower. Contact Joseph Ham (734)67							
FO-272622	1/13/2014	107	Created	Ceiling tiles damaged again from rain/thaw							
FO-272780	1/14/2014	106	Created	(**) P.O. Req DK							
FO-273436	1/22/2014	98	Created	TOILET WON'T FLUSH. 2ND FLOOR WOMEN'S RESTROOM. (2ND REQUEST),,,,,,							
FO-274322	1/31/2014	89	Created	PLUMBERS-INVESTIGATE LEAK IN LOBBY CEILING BY ROOM 100 MED PRIORITY							
FO-274839	2/5/2014	84	Created	trade plummers,Priority meduim.Theirs no hot water in this area.Check unit under sink n							
FO-276217	2/20/2014	69	Created	Plumber repair leaking RO water faucet.,,,,,,,,,,,,,, MM/2-21-14, DUE 3-6-14							
FO-276736	2/26/2014	63	Created	Trade: Plumber Priority: Medium							
FO-276825	2/27/2014	62	Created	Med Priority							
FO-276992	2/28/2014	61	Created	Repair sink drip in Women and Men bathrooms on the 1st floor.							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-277928	3/7/2014	54	Created	(**) P.O. Req DK						
FO-278544	3/17/2014	44	Created	R/R RM 2237/WOMENS RR ONE OF THE STALLS IS PLUGGED UP, MP/D						
FO-278904	3/19/2014	42	Created	Trade: Plumber Priority: Medium						
FO-278975	3/20/2014	41	Created	Plumber						
FO-279021	3/20/2014	41	Created	(**) P.O. Req DK						
FO-279022	3/20/2014	41	Created	Plumbers, please install by-pass piping and valving around Hot water heater.						
FO-279057	3/20/2014	41	Created	Plumber' Medium						
FO-279170	3/22/2014	39	Created	(**) P.O. Req DK						
FO-279171	3/22/2014	39	Created	R/R RM 00187.01 Replace pump seals on #1 City Water Booster Pump, MM						
FO-279511	3/26/2014	35	Created	PLUMBERS-PLEASE REPAIR BACKFLOW PREVENTER ON WATER SOFTNER LIN						
FO-279648	3/27/2014	34	Created	SINK LEAKING UNDERNEATH. ROOM 2131....., MM/3-28-13, DUE						
FO-280074	4/1/2014	29	Created	Plumbers: Please disconnect water softener water supply remove softener off deteriorati						
FO-280079	4/1/2014	29	Created	Plumbing: Please install emergency eye wash station next to chemical feed station locat						
FO-280622	4/3/2014	27	Created	Plump Med. Priority						
FO-280706	4/4/2014	26	Created	Trade: Plumber Priority: MediumR/R RK 4116/PENTHOUSE Please clear floor drain it						
FO-280784	4/4/2014	26	Created	3rd floor ladies restroom has a broken toilet seat in the handicapped stahl.						
FO-280787	4/6/2014	24	Created	Repair leaks in 1/2 inch copper water line serving the hose bibb near outside exit door 0						
FO-281129	4/9/2014	21	Created	** This FO# is for processing payment for service provided from FO#267326. P.O. was						
FO-281134	4/9/2014	21	Created	R/R BSMT MENS RR URINAL (BAGGED) IS STOPPED UP, MP/DB 4-10-14						
FO-281143	4/9/2014	21	Created	WOMENS RM LEFT STALL, TOILET RUNS TOO LONG, RB / 4-10-14						
FO-281285	4/10/2014	20	Created	Plumber; Medium						
FO-281466	4/14/2014	16	Work in progress	R/R RM 3101 REPLACE DIAPHRAM ON TOILET CONTINUOUSLY FLUSHING. ROOM						
FO-281667	4/15/2014	15	Created	Plumbers: \						
FO-281745	4/16/2014	14	Created	Backflow preventer in the boiler rm leaking.....,DB/ 4-16-14, DUE 4-29-						
FO-281815	4/16/2014	14	Open to Shops	LOW WATER PRESSURE. ROOM 1200.						
FO-281824	4/17/2014	13	Created	Trade: Plumber Priority: Medium						
FO-281841	4/17/2014	13	Created	HOT WATER IS WARM. 1ST FLOOR EMPLOYEE LOUNGE. ROOM 1349.....						
FO-281967	4/18/2014	12	Created	R/R #2 booster pump / check tank fill for obstruction, RB/ 4-18-14, D						
FO-281973	4/19/2014	11	Created	Please unplug floor drain in penthouse near chilled water pumps.						
FO-281979	4/19/2014	11	Created	Repair sanitary pit sump pump. One pump is out of service and the cover is out of place						
FO-282040	4/21/2014	9	Created	Plumbers:						
FO-282321	4/22/2014	8	Created	R/R 7TH FLR SOUTHEND NEAR RM 7802 UNISEX RR ONLY TOILET CONSTANTLY						
FO-282354	4/22/2014	8	Parts on Order	Plumbers -- 1st floor women's restroom water leaking into stall						
FO-282399	4/23/2014	7	Created	Restroom 210: toilet seat is loose, and toilet appears to be detaching from wall.....						
FO-282544	4/25/2014	5	Created	trade plummers,priority meduium,						
FO-282608	4/25/2014	5	Created	R/R RM 3390/WOMENS RR 1ST STALL TOILET IS LKNG @ FLUSH HANDLE						
FO-282620	4/25/2014	5	Created	R/R 1ST FLR Ladies rest room across R0129 has a ceiling leak.						
FO-282624	4/26/2014	4	Created	PLUMBERSR/R RM 108/WOMENS LOCKER RM Please replace or repair sloan valve						
FO-282629	4/27/2014	3	Created	PLUMBERS,R/R RM 0100/MECH RM PLEASE REPAIR FLANGE LEAK ON DOMES						
FO-282689	4/28/2014	2	Created	R/R RM 440/LAB SINK ACROSS FROM FUMEHOOD #2 IS PLUGGED NEED TO BE						
FO-282902	4/30/2014	0	Created	DRINKING FOUNTAIN NEAR VENDING MACHINE, DRAIN PLUGGED, DOES NOT R						
FO-282913	4/30/2014	0	Created	Plumbers:						
FO-282918	4/30/2014	0	Created	Right-hand sink does not work. Replace battery?						
FO-282919	4/30/2014	0	Created	Restroom 211: Sink works intermittently - replace battery?						
FO-282936	4/30/2014	0	Created	Repair leaking handle on whirl pool. New spigot may be needed. Please see Bob Ostro						
T - Roofing			4	3	1	0	0	0	0	
FO-278467	3/14/2014	47	Created	Found leak above ceiling tile, believe it is coming from roof area due to snow meltin						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-280698	4/3/2014	27	Created	Please check on roof leak in rooms 337, and 359, this is for work orders, 280672 and						
FO-281771	4/16/2014	14	Created	Roofers: please repair roof leak in room 238. priority: med. AL IDENTIFIED THAT IT IS						
FO-282838	4/29/2014	1	Created	NEAR RM 335 ON THE PORCH CEILING LEAK						
Low			290	186	62	27	14	1	0	104
T - Carpenter			41	14	20	7	0	0	0	
FO-275094	2/3/2014	86	Created	R/R RM 150/POOL Broken drain tiles in the pool area...Please See Bob Ostrowski on s						
FO-274443	2/3/2014	86	Created	R/R Second, Third and Fourth floors - Floor tiles in back hallways leading to emergenc						
FO-274853	2/5/2014	84	Created	CARPENTERS,						
FO-276114	2/19/2014	70	Open to Shops	R/R RM 0034 SEAL WALLS THAT ARE OOZING WATER						
FO-282397	2/24/2014	65	Created	Convert locks on restrooms (120, 124, 220, 224) to storeroom function.						
FO-277821	2/28/2014	61	Created	R/R ENT DOOR #039-07W Please send to Doug O'Brien in Carpenter's Shop. Please						
FO-276975	2/28/2014	61	Created	R/R RM 0034 SEAL WALLS THAT ARE OOZING WATER						
FO-277067	3/3/2014	58	Created	Carpenters: please install the broken window shade on west window. Priority; low.						
FO-277620	3/4/2014	57	Created	R/R BLDG Stairwell A - which is by State Hall has floor tiles that are cracking and are lo						
FO-277623	3/4/2014	57	Created	R/R RM 121 tiles in front of whiteboard room 121.						
FO-277624	3/4/2014	57	Created	R/R 4th floor REPLACE DAMAGED FLR TILES IN hallway behind room 421 leading to						
FO-277660	3/5/2014	56	Created	R/R 2ND FLR replace tiles in back hallway near room 225.						
FO-277661	3/5/2014	56	Created	R/R RM 311 3rd floor Repair tiles in room 311.						
FO-277662	3/5/2014	56	Created	R/R 3RD FLR replace all tiles past room 313 to the emergency exit.						
FO-277663	3/5/2014	56	Created	R/R RM 325 3rd floor replace broken tiles in Restorative arts room 325.						
FO-277784	3/6/2014	55	Created	SHEETMETAL						
FO-277947	3/7/2014	54	Created	R/R RM 2125/CLASS RM FLR TILES IN THE MIDDLE OF CLASS RM ARE CRACKIN						
FO-277948	3/7/2014	54	Created	R/R RM 2133/CLASS RM FLR TILES IN THE MIDDLE OF CLASS RM ARE CRACKIN						
FO-278241	3/12/2014	49	Created	CARPENTER TO ESTIMATE JOBS FOR THE TEAM LEADER						
FO-278312	3/12/2014	49	Created	R/R room 26 along the McGregor Pond level have windows that are leaking again. Som						
FO-278307	3/12/2014	49	Created	Roof Drain on Northwest stair tower may be clogged. Major water and icing below drain.						
FO-278317	3/12/2014	49	Created	R/R room 30 along the McGregor Pond level have windows that are leaking again. Som						
FO-278318	3/12/2014	49	Created	R/R room 36 along the McGregor Pond level have windows that are leaking again. Som						
FO-278324	3/12/2014	49	Created	The Mullion between doors 038-06 W and 038-07 W is broke and we would like to be ab						
FO-278364	3/13/2014	48	Created	R/R Transformer room bay door 612-28NB Won't close flush. 28NB may need lower lat						
FO-278365	3/13/2014	48	Created	R/R Transformer room bay door #612-29NB don't close flush CAUSING false alarms.						
FO-279395	3/25/2014	36	Created	CARPENTERS TO PURCHASE INTERMEDIATE PIVOT HINGES TO SERVICE EXTE						
FO-279860	3/31/2014	30	Created	Place wooden cover box over area where old style drinking fountain use to be. 3rd floor						
FO-280554	4/2/2014	28	Created	Locksmith training for Jeff Hammell. For the month of April						
FO-280659	4/3/2014	27	Created	KEYS & CORES (APRIL 2014)						
FO-280852	4/7/2014	23	Created	CARPENTERS TO REPAIR FIRE SAFETY LANE 2ND FLOOR OUTSIDE PIPE SHOP						
FO-281138	4/9/2014	21	Created	R/R RM 150/AUD RE-HANG FLAGS THAT HAVE FALLEN FROM THE WALLS ALSO						
FO-281141	4/9/2014	21	Created	R/R RM 150.80 The door that leads from the spectator seats to the pool balcony will not						
FO-281229	4/10/2014	20	Created	Carpenters, please build scaffolding outside cooling tower for access to change fan belt						
FO-281711	4/15/2014	15	Created	Room 1233 and 1241 has many white tiles that are cracked and buckling. Please fix. T						
FO-281931	4/16/2014	14	Created	This request is for Parking Structure # 6 @ 61 Putnam St. Sheet metal is missing off of						
FO-282450	4/24/2014	6	Created	Kresge Library, 1st Floor, Near Stair #4						
FO-282545	4/25/2014	5	Created	CARPENTERS, R/R BSMT PLEASE REPLACE MISSING & WATER DAMAGED CEI						
FO-282690	4/28/2014	2	Created	R/R BATH RM THAT SVCS' THE LOUNGE The actual space is room 35 and it's the me						
FO-282825	4/29/2014	1	Created	Purdy Library 1st Floor, Main EntranceR/R BLDG Interior Handicap door 026 01S - hin						
FO-282889	4/30/2014	0	Created	CARPENTER TO REPAIR CABINET DOOR						
T - Electrician			89	73	14	2	0	0	0	
FO-275168	2/10/2014	79	Created	Adding Electrician: Check to see if floats for sewage ejectors are working properly room						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-276164	2/20/2014	69	Created	I need 7 light covers for the Skillman Building.						
FO-277843	3/6/2014	55	Created	ELECTRICALR/R RM 253. replace motor on unit #15 for circulating perimeter heating						
FO-278386	3/13/2014	48	Created	light bulb out, 1st floor, room# 1151						
FO-278413	3/14/2014	47	Not Finished	Replace bulb in ceiling fixture. It shorts out from time to time. 1 electrical problem.						
FO-278428	3/14/2014	47	Created	Repair bad clock in room135.						
FO-278429	3/14/2014	47	Created	Repair bad clock on 1st floor vending area.						
FO-278431	3/14/2014	47	Created	Repair bad clock in room 315.						
FO-278434	3/14/2014	47	Created	Repair clock in hallway near room 323.						
FO-278541	3/17/2014	44	Created	there is a missing light fixture across from room 138 (1st floor)						
FO-278897	3/19/2014	42	Created	Relamp light fixture in room 247. lamp burned out. There is 1 electrical problem.						
FO-279399	3/25/2014	36	Created	ELECTRICIANS, R/R FOR RM 3317 PLEASE REPAIR BAD MOTOR BRACKETS ON						
FO-279428	3/25/2014	36	Created	There was a power surge in the building and all of the back up lighting has been out for						
FO-279681	3/27/2014	34	Created	bulbs need to be replaced in fixtures on the third						
FO-279778	3/29/2014	32	Created	The light fixture in the Dispatch break room						
FO-279779	3/29/2014	32	Created	There are a few exterior lights around the						
FO-279844	3/31/2014	30	Created	Time for Team Leader for month of April.						
FO-280110	4/1/2014	29	Created	Time to rebuild clocks, check clocks, and order parts for the month of April.						
FO-280153	4/1/2014	29	Created	2 EPs. Women's locker room.						
FO-280157	4/1/2014	29	Created	1 EP on bridge (4th floor)						
FO-280158	4/1/2014	29	Created	1 EP. Elevator.						
FO-280161	4/1/2014	29	Created	1 EP in lobby. Light fixture is over the main sw and is too high.						
FO-280527	4/2/2014	28	Created	light bulb out in room 2800...just as you come in the suite.... this is tagged..2/2014						
FO-280570	4/2/2014	28	Created	Room 141 - Margherio Conference Center - Several spotlights on the stage and in perim						
FO-281043	4/8/2014	22	Created	Pleas have Dennis deliver 25 bags of softener salt for the boilers to 3rd floor mechanical						
FO-281125	4/9/2014	21	Created	To cover the cost for WSU Electricians for electrical preventative maintenance work at S						
FO-281148	4/9/2014	21	Created	Please have Maintenance Labored take wooden pallates from FP&M stockroom to Hold						
FO-281265	4/10/2014	20	Created	EP :						
FO-281269	4/10/2014	20	Created	R/R RM 425/MECH-BLR RM Boiler #1 continues to trip off on Hi gas pressure cut out. T						
FO-281402	4/11/2014	19	Created	R/R BLDG Rooms 3305, 3307, and 3129 - Please repair fire alarm devices that were sh						
FO-281530	4/14/2014	16	Created	Office 1150 and 1151 have lights that are broke and burnt out. Thank you.						
FO-281721	4/15/2014	15	Created	At WDET there are 15 EPs in the MCR. They want to swap out all cfl floods in MCR with						
FO-281723	4/15/2014	15	Created	please deliver gondolla with no holes or cracks in it, (waterproof) to 1st floor old wing ne						
FO-281751	4/15/2014	15	Created	Three additional light bulbs burned out. Please replace. There are 3 electrical problems.						
FO-281760	4/16/2014	14	Created	Electrician repair ceiling light above chiller.						
FO-281777	4/16/2014	14	Created	Fluorescent light bulb needs to be replaced in the copier room near the reception area.						
FO-281799	4/16/2014	14	Created	Lights are out in room 170.						
FO-281873	4/17/2014	13	Created	1 EP in room 610 (basement)						
FO-281889	4/17/2014	13	Created	LABORERS (HIGH)						
FO-281881	4/17/2014	13	Created	3 EP's in the lobby. In need of electricians service; getting dark.						
FO-281890	4/17/2014	13	Created	LABORER (HIGH)						
FO-281892	4/17/2014	13	Created	LABORER (HIGH)R/R PH DELIVER:1) 15 PAILS OF NITROKLENZ TO PENTHOUS						
FO-281982	4/19/2014	11	Created	Install 7-Day programmable timer on Supply Air fan AC-5, serving the African Heritage r						
FO-282029	4/21/2014	9	Created	There are 3 EP's.						
FO-282061	4/21/2014	9	Created	room 16 mechanical room						
FO-282067	4/21/2014	9	Created	Motorist ran over a light pole at Gullen Mall @ Warren early Sunday morning around 1:3						
FO-282407	4/23/2014	7	Created	in room 152, copy room there is 1 EP. The light is strobbing.						
FO-282410	4/23/2014	7	Created	1 fixture out in the hallway by the pool						

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282412	4/23/2014	7	Created		1		fixture out in room 1367			
FO-282416	4/23/2014	7	Created				Electric wall heater in parking structure office not working.			
FO-282418	4/23/2014	7	Created				6 FIXTURES OUT IN ROOM 4654, 4671, 4802.			
FO-282422	4/23/2014	7	Created				Trade: Laborer			
FO-282428	4/23/2014	7	Created				Electrician; LowR/R RM 195/MECH RM Please repair the bad light bulbs located on th			
FO-282432	4/23/2014	7	Created				Deliver duct hoist to Scott Hall Penthouse, and bring it back when they finish using it.			
FO-282434	4/23/2014	7	Created				Deliver the One Man Lift to Applebaum, and bring it back when job is complete.			
FO-282506	4/24/2014	6	Created				Relamp Mall Lights.			
FO-282528	4/24/2014	6	Created				2 EPs. Records 4th floor.			
FO-282529	4/24/2014	6	Created				1 EP hallway outside of room 212.06			
FO-282531	4/24/2014	6	Created				2 EPs. The fixtures are located in the center study area next to the center building supp			
FO-282532	4/24/2014	6	Created				2 EPs. The fixtures are located in the center study area next to the center building supp			
FO-282559	4/25/2014	5	Created				please pick-up heat exchanger, spence valve, trap assembly etc, located in 1st floor me			
FO-282582	4/25/2014	5	Created				EXIT sign outside of room 060.5. has 1 electrical problem.			
FO-282583	4/25/2014	5	Created				1 of the switches next to room 063 isn't working.			
FO-282584	4/25/2014	5	Created				EXIT sign near room 037 is an electrical problem.			
FO-282621	4/26/2014	4	Created				ELECTRICIANS:R/R OUTSIDE The east pole lights are out of service at Old Main, ple			
FO-282622	4/26/2014	4	Created				ELECTRICIAN: R/R OUTSIDE @ SCB The lighting is very poor at the south exit of SC			
FO-282651	4/28/2014	2	Created				ADDING PAINTERS			
FO-282688	4/28/2014	2	Created				Connect Condesate pump.			
FO-282698	4/28/2014	2	Created				2 EPs room 208. The bulbs have been replaced.			
FO-282699	4/28/2014	2	Created				1 EP in 114. First fixture over the entrance of the room inside the office.			
FO-282700	4/28/2014	2	Created				1 EP. 1st floor student academic success services. The fixture is at the right of the infor			
FO-282701	4/28/2014	2	Created				1 EP in 3rd floor men's restroom. can't open fixture to change bulbs.			
FO-282702	4/28/2014	2	Created				2 EPs in room 160. 2 EXIT signs are out.			
FO-282703	4/28/2014	2	Created				1 EP. pole light (1st floor). It's a mercury bulb.			
FO-282707	4/28/2014	2	Created				**Adding Laborer: Provide scaffold for Plumbing repair to be made in basement mechan			
FO-282709	4/28/2014	2	Created				Adding Laborer: Transport lift to Stadium to make Plumbing repair and return lift. See Mik			
FO-282710	4/28/2014	2	Created				**Adding Electrician: Verify heat trace on water supply to Stadium bathrooms is working			
FO-282796	4/29/2014	1	Created				R/R RM 00051/MECH RM labor remove material from mech room 51low pr			
FO-282804	4/29/2014	1	Created				R/R 150 SUPERVISORS' OFC WE NEED 2 BOXES OF COPY MACHINE PAPER			
FO-282859	4/29/2014	1	Created				Trade: Laborer			
FO-282909	4/30/2014	0	Created				Time for Team Leader.			
FO-282910	4/30/2014	0	Created				Time for Laborer to clean Trades Shops.			
FO-282911	4/30/2014	0	Created				Time to rebuild clocks to replace when needed.			
FO-282949	4/30/2014	0	Created				2 EPs. West end carriage house has 2 EXIT signs that are out (1st floor) President con			
FO-282950	4/30/2014	0	Created				8 mercury bulbs over the basketball court. A lift may be needed.			
FO-282951	4/30/2014	0	Created				1 EP. Stair D between the 8th & 9th floor. Very high. A scaffold may be needed.			
FO-282952	4/30/2014	0	Created				There is a light switch missing in the room, the switch turns on all the middle lights in th			
FO-282954	4/30/2014	0	Created				1 EP. Room 3149 staff conference room. bulbs replaced won't light up.			
FO-282955	4/30/2014	0	Created				5 EPs. room 508.3. room totally dark. 4 fixtures out in 508			
T - Laborer			3	1	1	1	0	0	0	
FO-275823	2/17/2014	72	Created				Dispose of sewage pump. See John for location			
FO-278852	3/18/2014	43	Created				adding laborer""please insulate new piping from backflow preventor located in the mec			
FO-279846	3/31/2014	30	Created				Time for Laborer to clean shop for trades.			
T - Locksmith			9	7	1	1	0	0	0	
FO-275000	2/6/2014	83	Created				"Just do it", "see Mike Pines for details", the combination safe located in the Adamany li			
FO-279653	3/27/2014	34	Created				#75472 3 Keys 2 Cores Room 329			

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-280646	4/3/2014	27	Created	Please supply a new key duplicator from IDN Door Hardware and Sales QUOTE NO.							
FO-280658	4/3/2014	27	Created	Please replace the Grinder/brush in the lockshop. Grainger Quote Number 2020849454							
FO-282807	4/29/2014	1	Created	#75520 2 Keys and 2 Cores Room 1507							
FO-282808	4/29/2014	1	Created	#73323 2 Keys Room 3117							
FO-282871	4/29/2014	1	Created	75521 10-KEYS							
FO-282942	4/30/2014	0	Created	75523 4-KEYS							
FO-282957	4/30/2014	0	Created	#75524 4 Keys							
T - Painter				27	24	2	0	1	0	0	
FO-272402	1/9/2014	111	Created	Painter plaster repair large hole in garage ceiling. Pipes frozen.* WAITING ON THE WE							
FO-279465	3/26/2014	35	Created	Due to humidity issues rooms these areas need painting : Ladies bathroom, tile grids ru							
FO-279466	3/26/2014	35	Created	These doors need painting due to humidity issues. 2317,2319,2321,2323,2329,2332,23							
FO-279796	3/31/2014	30	Created	Painters please paint the air registers in all of the animal rooms on the second floor. Hi							
FO-280128	4/1/2014	29	Created	CLEAN OFF OR PAINT OVER GRAFFITI ON CAMPUS.							
FO-281115	4/9/2014	21	Created	HANDYMAN TIME.							
FO-281116	4/9/2014	21	Created	MTL TIME.							
FO-281160	4/9/2014	21	Created	please repair wall 1st stall trades restroom.....							
FO-281325	4/11/2014	19	Created	451-B paint and patch crack in ceiling							
FO-281683	4/15/2014	15	Created	PAINT AS NEEDED IN STAIRWAY-S							
FO-282109	4/21/2014	9	Created	Clean crystal chandeliers in office, one large and one small. This is a "just do it" reques							
FO-282110	4/21/2014	9	Created	Clean crystal chandelier in office. This is a "just do it" request. Authorization and index							
FO-282317	4/21/2014	9	Created	Paint the WSU standard W on the front drive of UT facing the building centered on the I							
FO-282562	4/25/2014	5	Created	PATCH AND PAINT WALL WHERE EBU'S WERE REMOVED.							
FO-282651	4/28/2014	2	Created	ADDING PAINTERS							
FO-282799	4/29/2014	1	Created	CAP-3 #160 PAINT TOUCH UP.							
FO-282800	4/29/2014	1	Created	CAP-3 #167 PAINT TOUCH UP.							
FO-282801	4/29/2014	1	Created	CAP-3 #297 PAINT TOUCH UP.							
FO-282802	4/29/2014	1	Created	CAP-3 #19 PAINT TOUCH UP.							
FO-282803	4/29/2014	1	Created	CAP-3 #25 PAINT TOUCH UP.							
FO-282844	4/29/2014	1	Created	SAFETY TIME FOR THE MONTH OF APRIL 2014.							
FO-282847	4/29/2014	1	Created	Painter R/R 3RD FLR HALLWAY IN FRONT OF RM 3087.10 DOORS repair water da							
FO-282848	4/29/2014	1	Created	CAP-3 # 840 PAINT ACCESS PANEL TO MATCH CEILING.							
FO-282849	4/29/2014	1	Created	CAP-3 # 841 PATCH AND PAINT HOLES.							
FO-282963	4/30/2014	0	Created	CAP-3 # 844 PATCH AND PAINT STRESS CRACK IN THE CEILING.							
FO-282966	4/30/2014	0	Created	CAP-3 # 833 PATCH AND PAINT STRESS CRACK AT DOOR OPENING.							
FO-282971	4/30/2014	0	Created	CAP-3 R/R WALL BY HEATER ON THE FIRST FLOOR.							
T - Pipefitter				58	33	11	8	6	0	0	
FO-268444	11/26/2013	155	Created	Steam Trap Replacement Program PFA: To cover the cost for Steam Trap Testing, Insp							
FO-268445	11/26/2013	155	Created	Steam Trap Replacement Program PFA: To cover the cost for Steam Trap Testing, Insp							
FO-271450	12/26/2013	125	Created	*To be Scheduled in March JWT							
FO-272029	1/4/2014	116	Created	to pipe fitter plz repair steam leaking by rm 0221,0225 in the hallway.							
FO-272341	1/9/2014	111	Created	(**) P.O.Req D.K.							
FO-274079	1/29/2014	91	Created	**Awaiting Direction JWT 4-1-14							
FO-274258	1/30/2014	90	Created	Heating unit at main entrance has no water flow to unit. ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, EA/RC 1-31-14 ,, ,, ,,							
FO-274462	2/3/2014	86	Created	(**) P.O. Req DK							
FO-274948	2/6/2014	83	Created	(**) P.O. Req DK							
FO-275525	2/12/2014	77	Created	please repair/replace steam control valve leaking in room 25...Abatement is being sche							
FO-275728	2/14/2014	75	Created	3 way valve on hot water perimeter heat is leaking thru, needs rebuilt or replaced ,, ,, ,, ,, ,,							
FO-276176	2/20/2014	69	Created	(**) P.O. Req DK							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-276671	2/26/2014	63	Created	Fabricate ladder for sump to replace exsisting rusted ladder rungs that have rusted. See						
FO-276759	2/26/2014	63	Created	(**) P.O. Req DK						
FO-277042	3/3/2014	58	Created	Repairs to Pipe Shop Oxy regulator ,,,,,,,,,,,,,, JH/ 3-3-14 ,,,,,,,,,,,,,, DUE 4-3-14						
FO-277712	3/5/2014	56	Created	Trade: Pipefitters						
FO-277846	3/6/2014	55	Created	(**) P.O. Req DK						
FO-278261	3/12/2014	49	Created	(**) P.O. Req DK						
FO-278268	3/12/2014	49	Not Finished	(**) P.O. Req DK MCP Service JWT						
FO-278888	3/14/2014	47	Created	Install power assisted condasate controler to sub-basement heat exchangers ,,,,,,,,,,,,,,						
FO-279051	3/20/2014	41	Created	Provide check valves in steam supply lines for heat exchanger #1 and #2 to complete p						
FO-279218	3/24/2014	37	Created	Trade: Pipefitter						
FO-279220	3/24/2014	37	Created	Trade: Pipefitter						
FO-279771	3/29/2014	32	Created	**Valve now recieved from FO#265511 / Please Install						
FO-279774	3/29/2014	32	Created	**Evaluate / billable to follow JWT						
FO-279861	4/1/2014	29	Created	(**) Coil Delivery expected 4-7-14 JWT						
FO-280708	4/4/2014	26	Created	Pipefitters-R/R RM 0001/CENTRAL COMPUTER OR TELECOMM please install pipe						
FO-280871	4/7/2014	23	Created	R/R RM 0025/MECH RM Repair or replace chilled water coil on SF-4 for Community Art						
FO-280874	4/7/2014	23	Created	R/R RM 00025/MECH RM Repair or replace cooling coil for SF-8.,,,,,,,,,,,,,, CB/4-8-14 ,,						
FO-281156	4/9/2014	21	Created	Fitters,R/R PENTHOUSE please repair leaks in steam coil on AHU-1.						
FO-281157	4/9/2014	21	Created	Fitters,R/R PENTHOUSE please repair leaks in steam coil on AHU-2.						
FO-281168	4/9/2014	21	Created	Assist Eletricians with Hot water heater controller and settings ,,,,,,,,,,,,,, EA / 4-9-14 ,,,,						
FO-281367	4/11/2014	19	Created	Work Order to purchase Hilti power tools for Pipe Shop ,,,,,,,,,,,,,, JT / 4-11-14 ,,,,,,,,,,,,,,						
FO-281414	4/12/2014	18	Created	R/R smaller steam relief valve near chiller in basement mechanical room ,,,,,,,,,,,,,, JH/4						
FO-281415	4/12/2014	18	Created	Mount all thread container and hook for hose to clean snakes . See John for location ,,,,,						
FO-281440	4/14/2014	16	Created	Fitter replace leaking steam valve for humidifier on AH-1 & 1A.,,,,,,,,,,,,,, ME/4-14-14 ,,,						
FO-281544	4/14/2014	16	Created	Fitter, install drain lines at energy recovery coils for AH-1, 2, 4, and 5 so engineer can cl						
FO-281779	4/16/2014	14	Created	PIPEFITTERS please r/r leaking valve at blowdown for water column. leaking at packing						
FO-281781	4/16/2014	14	Created	PIPEFITTERS please replace seals on both condensate pumps in the basement at 543						
FO-281953	4/18/2014	12	Created	Fitter repair large condensat leak under steel plate in floor. ,,,,,,,,,,,,,, JH/ 4-18-14 ,,,,,,,,,,						
FO-282327	4/21/2014	9	Created	Clinic Visit for Injury 4-21-14 ,,,,,,,,,,,,,, JH/ 4-21-14 ,,,,,,,,,,,,,,						
FO-282045	4/21/2014	9	Created	FITTERS: Please repair leaking steam regulator on Domestic Hot Water Tank #3						
FO-282274	4/22/2014	8	Created	Pf Med Priorityy						
FO-282275	4/22/2014	8	Created	Pf Med Priorityy						
FO-282598	4/25/2014	5	Created	processing time for hot work permits...CB.4-25-14						
FO-282599	4/25/2014	5	Created	processing time for e-mails, paperwork,phone calls etc.....CB...4-25-14						
FO-282788	4/28/2014	2	Created	processing time hot work permits..CB.....4-28-14						
FO-282789	4/28/2014	2	Created	processing time e-mails, phone calls,paperwork, etc.....CB..4-28-14						
FO-282792	4/28/2014	2	Created	start prepping for abatement removal, notifications, bills of lading, postings, etc.....C						
FO-282793	4/28/2014	2	Created	visit with Bob O from Mathaeii for this weeks scheduled job, go over details, etc.....CB..						
FO-282866	4/29/2014	1	Created	processing time for paperwork, e-mails, phone calls.....cb...4-29-14						
FO-282868	4/29/2014	1	Created	take coil vendor to 4 different buildings and looked at about a dozen coils.CB.4-29-14						
FO-282870	4/29/2014	1	Created	set up project notification for shutdown, collect all signatures, copy and return.....CB...						
FO-282875	4/29/2014	1	Created	get bills of lading and asbestos notifications from OEHS and prepare them for posting....						
FO-282946	4/30/2014	0	Created	take 2 seperate contractors to state hall to look at asbestos job.....CB...4-30-14						
FO-282959	4/30/2014	0	Created	processing time for numerous coil assesments.....CB...5-30-14						
FO-282961	4/30/2014	0	Created	processing time for hot work permits.....CB.4-30-14						
FO-282962	4/30/2014	0	Created	processing time e-mails,paperwork, phone calls etc.....CB.4-30-14						
T - Plumber			59	32	13	7	6	1	0	

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-266020	10/31/2013	181	Created	please R & R as needed the RPZ backflow device on the 2-1/2 " boiler make up feed lin							
FO-268319	11/25/2013	156	Open to Shops	RM 166/BATH RM SINK DRAINS HAVE A SEWAGE SMELL (BLEACH/DEODERIZER							
FO-268797	12/3/2013	148	Created	(**) P.O. Req DK *12-30-13 / 2-26-14 / 3-10-14 for Galv material to install new pumps J							
FO-272251	1/8/2014	112	Created	Piercing valve request to avoid domestic water bld. shut down for: RM 9320 NEED WAT							
FO-273970	1/28/2014	92	Created	Evaluate seperating domestic water supply in Life Science to provide Science Hall indep							
FO-274090	1/29/2014	91	Created	Water fountain on 3rd floor need to be repaired/replaced / No water making it to fountain							
FO-274148	1/29/2014	91	Created	*Plumbers*							
FO-274384	2/1/2014	88	Created	(**) P.O. Req DK							
FO-274970	2/6/2014	83	Created	R/R sump pump in mechanical room 0520. (This was misidentified as room 00346 on F							
FO-275132	2/7/2014	82	Created	R/R RM 3028/LAB This is a low priority request for lab 3028: Lab needs plumbing maint							
FO-275133	2/7/2014	82	Created	(**) P.O. Req DK							
FO-276165	2/20/2014	69	Created	(**) P.O. Req DK							
FO-276642	2/25/2014	64	Created	R & R drinking fountain (1st floor) filter change....., MP/DB 2-26-14 DU							
FO-276776	2/27/2014	62	Created	Reroute floor drain in front of Carpenter shop to 1st floor basin near stock room							
FO-277721	3/4/2014	57	Created	R/R RM 055 THEY'RE SEVERAL PIPES IN THE CEILING ONE OR MORE ARE LEAKI							
FO-277977	3/8/2014	53	Created	R/R all faucets in labs 1027,1039,1028,1038 MP/DB 3-9-14 DUE ASA							
FO-278306	3/12/2014	49	Created	(**)P.O. Req DK							
FO-278335	3/13/2014	48	Created	**Work in Progress / Warmer weather needed to plug drain and flood area to locate sou							
FO-278400	3/13/2014	48	Created	R/R shower diverter in girls basketball locker room MP/DB 3-13-14							
FO-278409	3/14/2014	47	Work in progress	EMERGENCY Isolated / Abatement in progress / Priority lowered JWT							
FO-279103	3/21/2014	40	Created	(**) P.O. Req DK							
FO-279418	3/24/2014	37	Created	We have a broken drain pipe on the second							
FO-279361	3/25/2014	36	Created	R/R 5TH FLR Drinking fountain outside mens restroom leaking at bubbler.Fountain is i							
FO-279534	3/26/2014	35	Created	The drinking fountain (near the nFab lab) on the 3rd floor cannot be repaired please repl							
FO-279676	3/28/2014	33	Created	Broken water fountain on on second floor north side of the building....., MP/DB 3-							
FO-279772	3/29/2014	32	Created	In room 13 in the basement my back-up sink leaking hot water like crazy.Needs to be fix							
FO-279773	3/29/2014	32	Created	** Domestic water building shut down required for 2 hours.Toilet stop valve to be replace							
FO-280561	4/1/2014	29	Created	Administrative Time for April 2014							
FO-280509	4/2/2014	28	Created	Plumbers: please unplug north and south ponds drain lines. Priority: low....., MP							
FO-280515	4/2/2014	28	Created	** Work in Progress / Abatement Requested 4-2-14 . Access Denied at this time to Ab							
FO-280648	4/3/2014	27	Created	R/R RM 2312 Sink is dripping - will not turn completely off., MM/ 4-3-14							
FO-281038	4/8/2014	22	Created	**Lowered Priority / Work in Progress / Emergency Corrected JWT							
FO-281149	4/9/2014	21	Created	(**) P. O. Req DK							
FO-281413	4/12/2014	18	Created	Service Propress Gun Locking Pin JT 4-12-14 DUE 5-12-14							
FO-281485	4/14/2014	16	Created	Research leak in ceiling near room 272. See Alex for detailsMP/DB 4-14-14							
FO-281488	4/14/2014	16	Created	** !st booster pump is beyond repairs. Please replace before service from Macomb can							
FO-281650	4/14/2014	16	Created	R/R RM 344/LAB Sink is clogged in room 344. Has standing water....., RB / 4-16							
FO-281704	4/15/2014	15	Created	Please clear the two floor drains in the boiler room nearest the boiler blowdown line disc							
FO-281758	4/16/2014	14	Created	Plumber replace damaged water filter for ice maker in room 012....., MM/4-16-14							
FO-281764	4/16/2014	14	Created	** Lowered Priority / Work In Progress Emergency Corrected JWT							
FO-281811	4/16/2014	14	Created	Ladies room - Handicapped stall - toilet seat is broken - please fix/replace., M							
FO-281937	4/18/2014	12	Created	3rd floor restroom 332 toilet seat broke MP/DB 4-18-14 DUE 5-18-1							
FO-281940	4/18/2014	12	Created	** Priority lowered / part on order JWT							
FO-281955	4/18/2014	12	Created	Plumber repair toilet 1st floor women center MM/ 34-18-14 DUE 5-							
FO-282316	4/22/2014	8	Created	R/R 1st floor men's room, near classroom #1108, (there is no room number) the sink on							
FO-282340	4/22/2014	8	Created	PVC glue shop stock MP/DB 4-22-14 DUE 5-22-14							
FO-282351	4/22/2014	8	Created	please order sloan parts for stock in piperoom.....							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-282352	4/22/2014	8	Created	**Lowered Priority / Temporary in Place JWT						
FO-282371	4/23/2014	7	Created	The women's restroom sink on the 5th floor leaking faucet need to replace..... M						
FO-282401	4/23/2014	7	Cancelled	R/R Restroom 211: toilet appears to be detaching from the wall..... MM/ 4-25-14						
FO-282452	4/24/2014	6	Created	faucet leaking MM/ 4-25-14DUE 5-24-14						
FO-282593	4/25/2014	5	Created	R/R KITCHEN In the room off of the cold kitchen next to the walk in refrigerator are con						
FO-282617	4/26/2014	4	Created	**Install pump when it is returned from being serviced from FO#273692 JWT						
FO-282645	4/28/2014	2	Created	CAP-3 #305, ada toilet basement mensroom replace sloan valve.....DB...4-28-14						
FO-282647	4/28/2014	2	Created	CAP-3 (material for CAP # 3)...						
FO-282652	4/28/2014	2	Created	CAP-3 #40, outside cap cleanout....MM...4-28-14						
FO-282708	4/28/2014	2	Created	R/R water supply and Turn water back on to Stadium bathrooms. See Bob when comple						
FO-282886	4/30/2014	0	Created	3rd floor men's & women's restrooms the handicap stalls the toilet seat are loose. Pleas						
FO-282934	4/30/2014	0	Created	Regarding: 155-235729 Manoogian 2nd Floor Renovation Project. Per D&CS the followi						
T - Roofing			4	2	0	1	1	0	0	
FO-269275	12/9/2013	142	Created	ROOFER:						
FO-276162	2/19/2014	70	Created	Roofers. Investigate roof leak In lavatory ceiling. Priority:Medium. Softball Building. See						
FO-281016	4/8/2014	22	Created	** Changing to Roofer. CB seen Tim on this 4-8-14 JWT / Lowered priority per Tim						
FO-282305	4/22/2014	8	Created	Replace/Repair a piece of roof material that fell off the roof of Old Main. The piece that						
Routine			18	8	10	0	0	0	0	10
T - Electrician			16	8	8	0	0	0	0	
FO-278017	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278018	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278019	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278020	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278021	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278022	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-278023	3/10/2014	51	Open to Shops	ROUTINE CHECK 3/10 THRU 3/14/14						
FO-279261	3/24/2014	37	Open to Shops	ROUTINE CHECK 3/24 THRU 3/28/14						
FO-279792	3/31/2014	30	Open to Shops	ROUTINE CHECK 3/31 THUR 4/4/14						
FO-282675	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282676	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282677	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282678	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282679	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282680	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
FO-282681	4/28/2014	2	Open to Shops	ROUTINE CHECK 4/28 THRU 5/2/14						
T - Pipefitter			2	0	2	0	0	0	0	
FO-278000	3/10/2014	51	Created	Quote for Confined Space Rescue System (tri-pod lift), as asked for by Dave Kuffner pe						
FO-278473	3/15/2014	46	Created	Repair leaking drain coupling in stainless spool piece (Pool Heater)..... EA/RC 3-1						

Total: 1125