

# Facilities Operations Maint. "Work Not Done" Report 3/1/2015 through 3/31/2015

			Total per Trade		Emergency 1 day		High 3 <= days		Medium <=14 days		Low <=30 days		Routine
Engineering			1 of 2	50%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0 of 1	0%	0
E - Command Center			0 of 1	0%	0 of 0	#Num!	0 of 0	#Num!	0 of 0	#Num!	0 of 1	0%	0
4	FO-302324	Maint. Work Order	11/20/2014	3/19/2015	119	Low	HONEYWELL please r/r control valve that is stuck in closed position for south half of room 121/122 at Mort Sci. The discharge is 60 degrees w/ no reheat. valve type M6410A1029 9938.			Completed by Honeywell via P0692055			
E - South			1 of 1	100%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
2	FO-311444	Maint. Work Order	3/16/2015	3/16/2015	0	High	RM 00040 IS TOO HOT						
Trades			7 of 11	64%	0 of 0	#Num!	0 of 0	#Num!	1 of 3	33%	6 of 8	75%	0
T - Electrician			7 of 11	64%	0 of 0	#Num!	0 of 0	#Num!	1 of 3	33%	6 of 8	75%	0
3	FO-306181	Maint. Work Order	1/15/2015	3/3/2015	47	Medium	Scott Hall, north east corridor, clock (on master system) not keeping time						
						Incomplete 3-3-2015 SRP							
3	FO-308172	Maint. Work Order	2/9/2015	3/3/2015	22	Medium	ANATOMY LABS 310,320,329,340 CLOCKS NEED TO BE SET						
						Incomplete 3-3-2015 SRP							
3	FO-310408	Maint. Work Order	3/2/2015	3/3/2015	1	Medium	2nd Fl. -Reset clock West end North hallway; reset clock west corridor. 1st. Fl. - north hallway, west end reset clock (both faces); central halway (west side ) North face clock not running. Basemnt - Central halway - set clock; West corridor reset clock. These clocks need to be reading correct time for accreditation team by next week.						
						Incomplete 3-3-2015 SRP							
4	FO-306569	Maint. Work Order	1/21/2015	3/3/2015	41	Low	Repair clock in DLAR located in the basement.						
						Incomplete 3-3-2015 SRP							
4	FO-306570	Maint. Work Order	1/21/2015	3/3/2015	41	Low	Repair clock in the basement near loading dock.						
						Incomplete 3-3-2015 SRP							
4	FO-309297	Maint. Work Order	2/18/2015	3/18/2015	28	Low	Room 105. It's a spot light.						
4	FO-308107	Maint. Work Order	2/6/2015	3/3/2015	25	Low	R/R RM 2343/MD LAB Clock not working in MD LAB 2343.						
						Incomplete 3-3-2015 SRP							
4	FO-309349	Maint. Work Order	2/18/2015	3/3/2015	13	Low	ground floor, across from room 0512 there's a 2 sided clock, and one side isn't working. Please repair.						
						Incomplete 3-3-2015 SRP							
4	FO-310340	Maint. Work Order	3/2/2015	3/3/2015	1	Low	R/R BLDG Reset Buildings clocks for day light Savings in time for next Monday's, March 9, arrival of Medical School Accrediation team. VERY IMPORTANT!!						
						Incomplete 3-3-2015 SRP							

Total per Trade					Emergency 1 day	High 3 <= days	Medium <=14 days	Low <=30 days	Routine
4	FO-310377	Maint. Work Order	3/2/2015	3/3/2015	1	Low	R/R RM 525 Please set clock to proper time in room 525		
							Incomplete 3-3-2015 SRP		
4	FO-310379	Maint. Work Order	3/2/2015	3/3/2015	1	Low	R/R RM 321 Please set clock to proper time in room 321		
							Incomplete 3-3-2015 SRP		

**Total:**    **8 of 13   62%**    **0 of 0   #Num!**    **1 of 1   #Num!**    **1 of 3   33%**    **6 of 9   75%**    **0**