

# Facilities Operations Backlog as of 5/31/16

				Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
<b>Maint. Work Order</b>				<b>37</b>	<b>8</b>	<b>10</b>	<b>13</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>29</b>
<b>Engineering</b>				<b>7</b>	<b>1</b>	<b>3</b>	<b>2</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>6</b>
<b>Emergency</b>				<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>
<b>E - MedPharm</b>				<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-348218	5/24/2016	7	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING							
<b>E - South</b>				<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-344868	4/15/2016	46	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
<b>High</b>				<b>2</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>
<b>E - Command Center</b>				<b>2</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-341941	3/10/2016	82	Hold for Funds	Trade: Command Center							
FO-344878	4/15/2016	46	Hold for Funds	Refr.crew:							
<b>Medium</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>
<b>E - Command Center</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-343471	3/30/2016	62	Hold for Funds	boilers 1 2 3 have trouble maintaining loop temp,below set point, reset flame failure alar							
<b>Low</b>				<b>2</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>2</b>
<b>E - Command Center</b>				<b>2</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
FO-337648	1/22/2016	130	Hold for Funds	REPAIR LOW WATER CUT OUT. MAKE UP TANK.							
FO-344746	4/13/2016	48	Hold for Funds	ac/burner crew-							
<b>Trades</b>				<b>30</b>	<b>7</b>	<b>7</b>	<b>11</b>	<b>4</b>	<b>1</b>	<b>0</b>	<b>23</b>
<b>Emergency</b>				<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>
<b>T - Electrician</b>				<b>2</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-344868	4/15/2016	46	Hold for Funds	4MECH RM 430 FAN MOTOR IS BURNED OUT							
FO-348218	5/24/2016	7	Hold for Funds	RM 2105 UPS PANEL ALARM SOUNDING							
<b>High</b>				<b>8</b>	<b>2</b>	<b>1</b>	<b>3</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>6</b>
<b>T - Carpenter</b>				<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-336514	1/8/2016	144	Hold for Funds	Follow up on work order - FO 334978 from December. I have received another request/							
FO-339303	2/10/2016	111	Hold for Funds	Replace broken floor tiles in hallway outside room							
<b>T - Electrician</b>				<b>6</b>	<b>2</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-342136	3/15/2016	77	Hold for Funds	lollipop type lights around building and in front of structure #2 not working please check							
FO-342874	3/22/2016	70	Hold for Funds	Electricians-							
FO-343192	3/25/2016	67	Hold for Funds	trade electricians priority high							
FO-344409	4/7/2016	54	Hold for Funds	R/R RM 2301/RESTROOM Hand dryer is not functioning. there was a report of a burnin							
FO-347029	5/9/2016	22	Hold for Funds	MENS RM 2301 HAND DRYER NOT WORKING							
FO-348530	5/26/2016	5	Hold for Funds	repair trash pump. only one working.							
<b>Medium</b>				<b>3</b>	<b>1</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2</b>
<b>T - Carpenter</b>				<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-347481	5/17/2016	14	Hold for Funds	pls build elevated cat walk around the dearator in the bsmt of usb/fpm 2"-3" of standing							
<b>T - Electrician</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-341930	3/10/2016	82	Hold for Funds	Check Community Arts, and other buildings for Emergency Lighting.							
<b>T - Plumber</b>				<b>1</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-342830	3/22/2016	70	Hold for Funds	**WILL REVISIT IN SUMMER WHEN STEAM IS OFF AND CONDENSATE ID DRY ON							
<b>Low</b>				<b>16</b>	<b>3</b>	<b>5</b>	<b>6</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>13</b>
<b>T - Carpenter</b>				<b>8</b>	<b>3</b>	<b>4</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	
FO-341794	3/9/2016	83	Hold for Funds	**ADDING CARPENTER : Please replace or reset all loose tites in bathroom of office 29							

			Total	<=30	31- 60	61-90	91-180	181-365	>365	>30
FO-344995	4/18/2016	43	Hold for Funds	REPAIR GUTTER ON SOUTHWEST CORNER.						
FO-345016	4/18/2016	43	Hold for Funds	Carpenters: please repair roof gutters on north side of the building. priority: low.						
FO-345767	4/21/2016	40	Hold for Funds	R/R BLDG The latches on the windows are broken or missing in several rooms and they						
FO-346341	4/29/2016	32	Hold for Funds	R/R all damaged and missing ceiling tiles in hallways on 1st, 2nd and 3rd floors.						
FO-346848	5/4/2016	27	Hold for Funds	Room 4235, Replace broken, loose and missing floor						
FO-346882	5/5/2016	26	Hold for Funds	Ceiling tiles are falling down. Entire ceiling should be repaired. Currently occupied by 3r						
FO-346921	5/5/2016	26	Hold for Funds	please replace severely damaged floor tiles just outside the elevator on 4th floor of COE						
<b>T - Electrician</b>			<b>8</b>	<b>0</b>	<b>1</b>	<b>5</b>	<b>2</b>	<b>0</b>	<b>0</b>	
FO-340735	2/29/2016	92	Hold for Funds	pls repair rest room exh fan motor circuit not running						
FO-340878	3/1/2016	91	Hold for Funds	Replace faulty blower motor on Exhaust Fan #14 at Bio-Science.						
FO-341792	3/9/2016	83	Hold for Funds	Light out in the Grounds' dept. I had to remove the bulb because it wouldn't stop flickerin						
FO-342204	3/16/2016	76	Hold for Funds	Replace Emergency light Batteries in Auditorium.						
FO-342943	3/23/2016	69	Hold for Funds	EMERGENCY ELEC						
FO-343295	3/28/2016	64	Hold for Funds	Extreme Air Hand Dryer is not working in Ladies Bathroom, UGL Room 2432.						
FO-343434	3/29/2016	63	Hold for Funds	the 2nd floor heating hot water pump trips off, pls repair						
FO-344767	4/13/2016	48	Hold for Funds	The hand drier in the women's bathroom does not						
<b>Routine</b>			<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>
<b>T - Plumber</b>			<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>0</b>	
FO-332597	11/15/2015	198	Hold for Funds	(HFF) PER DK 3/30						

**Total: 37**