

DRAFT Facilities Operations PM Analysis from 7/1/16 through 7/31/16

Requested Finished Open WND										% Finished
Engineering		562		305		251		6		54%
E - Auxiliary		42		18		24		0		43%
FO-350467	Finished	034-AHU-001	7/1/2016	7/20/2016		False	3.00	PM - Air Handling Unit		
Changed pre-filters, checked belts and adjustment, lubed motor and bearings, checked damper operation.										
FO-350468	Finished	034-AHU-002	7/1/2016	7/19/2016		False	3.00	PM - Air Handling Unit		
Changed pre-filters, checked belts and adjustment, lubed motor and bearings, checked damper operation.										
FO-350469	Finished	034-AHU-003	7/1/2016	7/27/2016		False	0.25	PM - Air Handling Unit		
AHU#3 has been removed and is being replaced by a new unit during renovations.										
FO-350470	Finished	034-AHU-004	7/1/2016	7/25/2016		False	1.00	PM - Air Handling Unit		
Changed filters, checked belts and alignment, lubed motor and bearings, checked damper operation.										
FO-350471	Finished	034-AHU-005	7/1/2016	7/27/2016		False	0.25	PM - Air Handling Unit		
AHU#5 has been removed and is being replaced by a new unit during renovations.										
FO-350472	Finished	034-SP-001	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lube motor, checked float operation and rate of discharge.										
FO-350473	Finished	034-SP-002	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lubed motor, checked float and pump operation. Cleaned area.										
FO-350474	Finished	034-SP-003	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lubed motor and float rods, checked units operation. Cleaned area.										
FO-350475	Completed	034-SP-004	7/1/2016			False	0.50	PM - Sump Pump		
Lubed motor and float rod, checked float and pump operation. Cleaned area.										
FO-350490	Created By PM Schedule	104-MUA-001	7/1/2016			False		PM - Air Handling Unit		
FO-350491	Created By PM Schedule	104-MUA-002	7/1/2016			False		PM - Air Handling Unit		
FO-350492	Created By PM Schedule	115-MUA-001	7/1/2016			False		PM - Air Handling Unit		
FO-350493	Created By PM Schedule	115-MUA-002	7/1/2016			False		PM - Air Handling Unit		
FO-350494	Created By PM Schedule	115-MUA-003	7/1/2016			False		PM - Air Handling Unit		
FO-350497	Finished	136-HWP-003	7/1/2016	7/15/2016		False	0.50	PM - Water Booster Pump		
Lubed motor and bearing, checked coupler and pump operation.										
FO-350498	Created By PM Schedule	134-HWP-003	7/1/2016			False		PM - Water Booster Pump		
FO-350499	Created By PM Schedule	507-AIR-001	7/1/2016			False		PM - Air Compressor, Reciprocating 5-40 H.P.		
FO-350500	Finished	992-ES-001*	7/4/2016	7/8/2016		False		PM - Emergency Shower/Eyewash Station		
FO-350501	Created By PM Schedule	134-DWBP-001	7/1/2016			False		PM - Water Booster Pump		
FO-350502	Created By PM Schedule	134-DWBP-002	7/1/2016			False		PM - Water Booster Pump		
FO-350503	Created By PM Schedule	134-DWBP-003	7/1/2016			False		PM - Water Booster Pump		
FO-350504	Created By PM Schedule	134-CRS-001	7/1/2016			False		PM - Condensate Return Pump		
FO-350505	Created By PM Schedule	134-CRS-002	7/1/2016			False		PM - Condensate Return Pump		
FO-350517	Finished	134-ACU-001	7/1/2016	7/15/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-350527	Finished	507-ACU-001	7/1/2016	7/15/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-350529	Created By PM Schedule	134-FP-001	7/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350530	Created By PM Schedule	127-FP-001	7/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350531	Created By PM Schedule	115-FP-001	7/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350532	Created By PM Schedule	104-FP-001	7/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test		

FO-350533	Created By PM Schedule	507-FP-001	7/1/2016		False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-350889	Finished	501-GEN-001	7/12/2016	7/13/2016	False	Generator Maintenance, Monthly	
FO-350891	Finished	507-GEN-001	7/13/2016	7/14/2016	False	Generator Maintenance, Monthly	
FO-350897	Finished	536-GEN-001	7/20/2016	7/20/2016	False	Generator Maintenance, Monthly	
FO-350917	Finished	034-GEN-001	7/7/2016	7/7/2016	False	Generator Maintenance, Monthly	
FO-351081	Finished	992-ES-001*	7/11/2016	7/15/2016	False	PM - Emergency Shower/Eyewash Station	
FO-351403	Finished	992-ES-001*	7/18/2016	7/22/2016	False	PM - Emergency Shower/Eyewash Station	
FO-351998	Created By PM Schedule	104-GEN-001	7/26/2016		False	Generator Maintenance, Monthly	
FO-352000	Created By PM Schedule	127-GEN-001	7/26/2016		False	Generator Maintenance, Monthly	
FO-352002	Created By PM Schedule	127-GEN-002	7/26/2016		False	Generator Maintenance, Monthly	
FO-352004	Created By PM Schedule	127-GEN-003	7/26/2016		False	Generator Maintenance, Monthly	
FO-352006	Created By PM Schedule	127-GEN-004	7/26/2016		False	Generator Maintenance, Monthly	
FO-352007	Created By PM Schedule	992-ES-001*	7/25/2016		False	PM - Emergency Shower/Eyewash Station	
E - MedPharm			35	0	35	0	0%
FO-350287	Created By PM Schedule	629-DHW-001	7/1/2016		False	PM - Domestic Water Heater, Steam	
FO-350288	Created By PM Schedule	629-DHW-002	7/1/2016		False	PM - Domestic Water Heater, Steam	
FO-350289	Created By PM Schedule	629-DHW-003	7/1/2016		False	PM - Domestic Water Heater, Steam	
FO-350290	Created By PM Schedule	629-SP-001	7/1/2016		False	PM - Sump Pump	
FO-350291	Created By PM Schedule	612-WSS-001	7/1/2016		False	PM - Water Softener	
FO-350292	Created By PM Schedule	603-ES-001*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350293	Created By PM Schedule	603-ES-003*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350294	Created By PM Schedule	603-ES-004*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350295	Created By PM Schedule	603-ES-005*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350296	Created By PM Schedule	603-ES-006*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350297	Created By PM Schedule	603-ES-007*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350298	Created By PM Schedule	603-ES-008*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350299	Created By PM Schedule	603-ES-009*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350300	Created By PM Schedule	603-ES-010*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350301	Created By PM Schedule	603-ES-011*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350302	Created By PM Schedule	603-ES-012*	7/1/2016		False	PM - Emergency Shower/Eyewash Station	
FO-350303	Created By PM Schedule	608-GEN-001	7/5/2016		False	Generator Maintenance, Monthly	
FO-350304	Created By PM Schedule	629-ACU-002	7/1/2016		False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	
FO-350305	Created By PM Schedule	629-ACU-001	7/1/2016		False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	
FO-350306	Created By PM Schedule	612-ACU-003	7/1/2016		False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	
FO-350307	Created By PM Schedule	612-ACU-002	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350308	Created By PM Schedule	612-ACU-001	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350309	Created By PM Schedule	611-ACU-002**	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350310	Created By PM Schedule	611-ACU-001**	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350311	Created By PM Schedule	608-ACU-001	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350312	Created By PM Schedule	603-ACU-002	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350313	Created By PM Schedule	603-ACU-001	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-350314	Created By PM Schedule	608-ACU-002	7/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	

Requested Finished Open WND

% Finished

FO-350315	Created By PM Schedule	603-GEN-001	7/5/2016		False		Generator Maintenance, Monthly
FO-350885	Created By PM Schedule	612-GEN-001	7/12/2016		False		Generator Maintenance, Monthly
FO-350887	Created By PM Schedule	612-GEN-002	7/12/2016		False		Generator Maintenance, Monthly
FO-350900	Created By PM Schedule	609-GEN-001	7/19/2016		False		Generator Maintenance, Monthly
FO-351077	Created By PM Schedule	603-ES-002*	7/10/2016		False		PM - Emergency Shower/Eyewash Station
FO-351980	Created By PM Schedule	611-GEN-001	7/26/2016		False		Generator Maintenance, Monthly
FO-351981	Created By PM Schedule	629-GEN-001	7/26/2016		False		Generator Maintenance, Monthly
E - North			34	23	11	0	
							68%
FO-350316	Finished	130-DWBP-001	7/1/2016	7/26/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-350317	Finished	130-DWBP-002	7/1/2016	7/26/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-350318	Created By PM Schedule	025-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350319	Created By PM Schedule	025-HEX-001	7/1/2016		False		PM - Heat Exchanger and Economizer
FO-350320	Created By PM Schedule	025-HEX-002	7/1/2016		False		PM - Heat Exchanger and Economizer
FO-350321	Finished	046-AIR-001	7/1/2016	7/27/2016	False	0.78	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350322	Finished	049-AIR-001	7/1/2016	7/26/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350323	Finished	049-DHW-001	7/1/2016	7/27/2016	False	0.65	PM - Domestic Water Heater, Electric
FO-350324	Finished	049-DHW-002	7/1/2016	7/27/2016	False	0.68	PM - Domestic Water Heater, Electric
FO-350325	Finished	038-AIR-001	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM on air compressor, checked operation.							
FO-350326	Finished	039-AIR-001	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM, replaced air filter on this compressor, checked operation.							
FO-350327	Finished	039-AIR-002	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM, checked operation of air compressor.							
FO-350328	Created By PM Schedule	026-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350329	Created By PM Schedule	027-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350330	Created By PM Schedule	036-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350331	Created By PM Schedule	026-SSF-001	7/1/2016		False		PM - Harmsco Side Stream Filter
FO-350332	Created By PM Schedule	036-SSF-001	7/1/2016		False		PM - Harmsco Side Stream Filter
FO-350333	Finished	048-AIR-001	7/1/2016	7/12/2016	False	0.68	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350334	Finished	048-AIR-002	7/1/2016	7/14/2016	False	0.70	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350335	Created By PM Schedule	048-ACU-207	7/1/2016		False		Vendor or Contractor Work
FO-350336	Finished	140-ACU-002	7/1/2016	7/11/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350337	Finished	140-ACU-001	7/1/2016	7/13/2016	False	2.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350338	Finished	050-ACU-001	7/1/2016	7/11/2016	False	2.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350339	Finished	049-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350340	Finished	048-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350341	Finished	046-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350342	Finished	039-ACU-002	7/1/2016	7/18/2016	False	8.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Chiller inspected, upgrades and improvements made to controls, back in operation.							

Requested Finished Open WND

% Finished

FO-350343	Finished	039-ACU-001	7/1/2016	7/18/2016	False	8.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350344	Finished	026-ACU-003	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350345	Finished	026-ACU-002	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350346	Finished	026-ACU-001	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350347	Created By PM Schedule	043-ACU-001	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350902	Finished	048-GEN-001	7/12/2016	7/12/2016	False	0.65	Generator Maintenance, Monthly
FO-352461	Created By PM Schedule	130-GEN-001	7/27/2016		False		Generator Maintenance, Monthly
E - Northeast			59	39	20	0	66%
FO-350348	Finished	062-DWBP-001	7/1/2016	7/11/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350349	Finished	062-DWBP-002	7/1/2016	7/8/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350350	Created By PM Schedule	067-ACU-109	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350351	Finished	509-AIR-001	7/1/2016	7/11/2016	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
changed oil checked belt. cleaned air inlet filter, checked operation of control switch, checked operation of auto drain							
FO-350352	Completed	065-HWP-006	7/1/2016	7/14/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350353	Completed	065-DWBP-001	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350354	Completed	065-DWBP-002	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350355	Completed	067-DWBP-002	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350356	Finished	510-AIR-001	7/1/2016	7/19/2016	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
inspected belts drained oil topped off each checked operation							
FO-350357	Created By PM Schedule	065-ACU-001	7/1/2016		False	0.00	PM - Water/Air Cooled Condenser
FO-350358	Created By PM Schedule	065-ACU-002	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350359	Created By PM Schedule	065-ACU-003	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350360	Created By PM Schedule	065-ACU-005	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350361	Created By PM Schedule	065-ACU-007	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350362	Created By PM Schedule	065-ACU-009	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350363	Created By PM Schedule	065-ACU-010	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350364	Created By PM Schedule	066-ACU-001	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350365	Created By PM Schedule	066-ACU-002	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350366	Created By PM Schedule	066-ACU-003	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350367	Created By PM Schedule	067-ACU-001	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350368	Created By PM Schedule	067-ACU-002	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350369	Created By PM Schedule	067-ACU-003	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350370	Created By PM Schedule	067-ACU-109	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350371	Created By PM Schedule	509-ACU-001	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350372	Created By PM Schedule	509-ACU-002	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350373	Created By PM Schedule	510-ACU-001	7/1/2016		False		PM - Water/Air Cooled Condenser
FO-350374	Finished	060-DWBP-001	7/1/2016	7/1/2016	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-350375	Finished	193-ACU-001	7/1/2016	7/11/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

Requested Finished Open WND

% Finished

FO-350376	Finished	062-ACU-002	7/1/2016	7/27/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350377	Finished	062-ACU-001	7/1/2016	7/26/2016	False	4.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350378	Finished	067-ACU-109	7/1/2016	7/6/2016	False	3.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350379	Finished	193-ACU-002	7/1/2016	7/6/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350380	Finished	203-ACU-001	7/1/2016	7/6/2016	False	2.00	Clean condenser coils
FO-350381	Finished	203-ACU-002	7/1/2016	7/7/2016	False	1.50	Clean condenser coils
FO-350382	Finished	203-ACU-003	7/1/2016	7/7/2016	False		Clean condenser coils
FO-350383	Finished	209-AHU-005	7/1/2016	7/28/2016	False	3.00	Replace PRE-filters
FO-350384	Finished	209-AHU-004B	7/1/2016	7/26/2016	False	2.50	Replace PRE-filters
FO-350385	Finished	209-AHU-004A	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350386	Finished	209-AHU-003	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350387	Finished	209-AHU-002	7/1/2016	7/27/2016	False	2.50	Replace PRE-filters
FO-350388	Finished	209-AHU-001	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350893	Finished	203-GEN-001	7/19/2016	7/19/2016	False	1.50	Generator Maintenance, Monthly
FO-350899	Finished	527-GEN-001	7/21/2016	7/21/2016	False	2.00	Generator Maintenance, Monthly
performed test, checked fluid levels and lower operation							
FO-350903	Finished	193-GEN-001	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350907	Finished	GEN-001 (Towa	7/13/2016	7/8/2016	False	1.00	Generator Maintenance, Monthly
FO-350911	Finished	193-GEN-002	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350913	Finished	193-GEN-003	7/1/2016	7/1/2016	False	1.00	Generator Maintenance, Monthly
FO-350915	Finished	193-GEN-004	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350926	Finished	209-GEN-001	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350928	Finished	209-GEN-003	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350930	Finished	209-GEN-004	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350933	Finished	209-GEN-002	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350934	Finished	211-GEN-001	7/1/2016	7/6/2016	False	1.50	Generator Maintenance, Monthly
FO-350935	Finished	211-GEN-002	7/1/2016	7/6/2016	False	1.00	Generator Maintenance, Monthly
FO-351078	Finished	062-ACU-003	7/7/2016	7/7/2016	False	1.00	PM - Semi Anual Air Handling Unit Inspection
FO-351398	Created By PM Schedule	510-HEX-001	7/15/2016		False		PM - Heat Exchanger and Economizer
FO-352477	Created By PM Schedule	066-GEN-001	7/27/2016		False		Generator Maintenance, Monthly
FO-352480	Finished	060-GEN-001A	7/28/2016	7/28/2016	False	1.00	Generator Maintenance, Monthly
FO-352481	Finished	060-GEN-001B	7/28/2016	7/29/2016	False	1.00	Generator Maintenance, Monthly

E - Preventative Maintenance

224

168

51

5

75%

FO-338420	Created By PM Schedule	608-EXF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338421	Created By PM Schedule	608-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338422	Created By PM Schedule	608-EXF-004	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338426	Created By PM Schedule	608-EXF-010	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344078	Finished	612-AHU-005C	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-344079	Finished	612-AHU-005B	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-344080	Finished	612-AHU-005A	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-346533	Created By PM Schedule	067-EXF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346534	Created By PM Schedule	067-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-346535	Created By PM Schedule	067-EXF-003	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346536	Created By PM Schedule	067-EXF-004	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346662	Cancelled	499-AHU-006	7/1/2016		True		Replace PRE-filters
Unit not currently being run. Unit deactivated on 6-31-16.							
FO-346667	Created By PM Schedule	067-AHU-003	7/1/2016		False		Replace PRE-filters
FO-346668	Created By PM Schedule	067-AHU-001	7/1/2016		False		Replace PRE-filters
FO-346675	Finished	067-EXF-005	7/1/2016	5/23/2016	False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346676	Created By PM Schedule	067-EXF-006	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348743	Finished	096-EXF-001	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348744	Finished	096-EXF-002	7/1/2016	7/19/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348745	Finished	096-EXF-003	7/1/2016	7/19/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348746	Finished	096-EXF-021	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348747	Finished	096-EXF-022	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348748	Finished	096-EXF-023	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348749	Finished	096-EXF-020	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348750	Finished	193-EXF-001	7/1/2016	7/13/2016	False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348751	Created By PM Schedule	612-RAF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348752	Created By PM Schedule	612-RAF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348753	Created By PM Schedule	612-RAF-003	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348754	Created By PM Schedule	612-RAF-004	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348755	Created By PM Schedule	612-RAF-005	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348756	Created By PM Schedule	612-RAF-006	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348757	Created By PM Schedule	612-RAF-008	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348758	Finished	003-EXF-001	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348759	Finished	003-EXF-002	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348760	Finished	003-EXF-003	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348761	Finished	003-EXF-004	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348762	Finished	003-EXF-005	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348763	Finished	003-EXF-006	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348764	Finished	003-EXF-007	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348765	Finished	003-EXF-008	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348766	Finished	003-EXF-009	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348767	Finished	003-EXF-010	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348768	Finished	003-EXF-011	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348769	Finished	003-EXF-013	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348770	Finished	167-EXF-001	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348771	Finished	167-EXF-002	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348772	Finished	167-EXF-003	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348773	Finished	096-EXF-018	7/1/2016	7/19/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348774	Finished	096-EXF-019	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348775	Finished	096-EXF-025	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348776	Finished	096-EXF-026	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348777	Finished	096-EXF-027	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348778	Finished	499-EXF-001	7/1/2016	7/16/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-348779	Finished	169-EXF-005	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348780	Finished	169-EXF-001	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348781	Finished	169-EXF-002	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348782	Finished	169-EXF-003	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348783	Finished	169-EXF-004	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348784	Finished	169-EXF-005	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348785	Finished	169-EXF-006	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348786	Finished	080-EXF-003	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348787	Finished	080-EXF-004	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348788	Finished	080-EXF-007	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348789	Finished	080-EXF-201	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348790	Finished	080-EXF-253	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348791	Finished	080-EXF-269	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348792	Finished	080-EXF-274	7/1/2016	7/7/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348793	Finished	166-EXF-001	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348794	Finished	166-EXF-002	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348795	Finished	166-EXF-003	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348796	Finished	166-EXF-004	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348797	Finished	166-EXF-005	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348798	Finished	166-EXF-006	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348799	Finished	166-EXF-007	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348800	Finished	166-EXF-008	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348801	Finished	166-EXF-009	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348802	Finished	166-EXF-010	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348803	Finished	166-EXF-011	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348804	Finished	166-EXF-012	7/1/2016	7/27/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348805	Finished	166-EXF-013	7/1/2016	7/27/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348806	Finished	046-FAP-001	7/1/2016	7/20/2016	False	0.20	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348807	Finished	048-FAP-001	7/1/2016	7/13/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348808	Finished	049-FAP-001	7/1/2016	7/20/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348809	Finished	003-EXF-014	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348810	Finished	003-EXF-015	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348811	Finished	156-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348812	Finished	499-FAP-001	7/1/2016	7/21/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348813	Finished	620-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348814	Finished	036-FP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348815	Finished	025-FP-001	7/1/2016	7/14/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348816	Finished	007-FP-001	7/1/2016	7/29/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348817	Finished	001-FP-001	7/1/2016	7/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348818	Finished	005-FAP-001	7/1/2016	7/29/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348819	Finished	040-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348820	Finished	038-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348821	Finished	028-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348822	Finished	026-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-348823	Finished	022-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348824	Finished	017-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348825	Finished	016-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348826	Finished	003-FAP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348827	Finished	006-FP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348828	Finished	050-FAP-001	7/1/2016	7/14/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348829	Finished	043-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348830	Finished	042-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348831	Finished	062-FP-001	7/1/2016	7/14/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348832	Finished	065-FP-001	7/1/2016	7/13/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348833	Finished	068-FAP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348834	Finished	067-FP-001	7/1/2016	7/13/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348835	Finished	089-FP-001	7/1/2016	7/28/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348836	Finished	082-FP-001	7/1/2016	7/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348837	Finished	080-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348838	Created By PM Schedule	090-FP-001	7/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348839	Finished	155-FP-001	7/1/2016	7/20/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348840	Finished	150-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348841	Finished	167-FAP-001	7/1/2016	7/29/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348842	Finished	166-FP-001	7/1/2016	7/29/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348843	Finished	140-FAP-001	7/1/2016	7/14/2016	False	35.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348844	Finished	130-FP-001	7/1/2016	7/14/2016	False	39.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348845	Created By PM Schedule	193-FAP-001	7/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348846	Finished	189-FP-001	7/1/2016	7/14/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348847	Finished	510-FAP-001	7/1/2016	7/12/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348848	Finished	509-FAP-001	7/1/2016	7/12/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348849	Finished	504-FAP-001	7/1/2016	7/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348850	Finished	629-FP-001	7/1/2016	5/17/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348851	Finished	612-FP-001	7/1/2016	5/13/2016	False	3.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348852	Finished	611-FP-001	7/1/2016	5/20/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348853	Finished	609-FP-001	7/1/2016	5/26/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348854	Finished	603-FP-001	7/1/2016	5/24/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348855	Finished	608-FP-001	7/1/2016	5/23/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348856	Created By PM Schedule	612-AHU-014	7/1/2016		False		Replace PRE-filters
FO-348857	Finished	612-AHU-013	7/1/2016	7/28/2016	False	10.00	Replace PRE-filters
FO-348858	Created By PM Schedule	612-AHU-012	7/1/2016		False		Replace PRE-filters
FO-348859	Created By PM Schedule	612-AHU-011	7/1/2016		False		Replace PRE-filters
FO-348860	Created By PM Schedule	612-AHU-010	7/1/2016		False		Replace PRE-filters
FO-348861	Created By PM Schedule	612-AHU-009	7/1/2016		False		Replace PRE-filters
FO-348862	Created By PM Schedule	612-AHU-008	7/1/2016		False		Replace PRE-filters
FO-348863	Created By PM Schedule	612-AHU-007	7/1/2016		False		Replace PRE-filters
FO-348864	Created By PM Schedule	612-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348865	Created By PM Schedule	612-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348866	Created By PM Schedule	612-AHU-001	7/1/2016		False		Replace PRE-filters

Requested Finished Open WND

% Finished

FO-348867	Finished	074-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348868	Finished	167-AHU-002	7/1/2016	7/7/2016	False	2.00	Replace PRE-filters
FO-348869	Finished	167-AHU-001	7/1/2016	7/7/2016	False	2.00	Replace PRE-filters
FO-348870	Finished	003-AHU-008	7/1/2016	7/20/2016	False	0.75	Replace PRE-filters
FO-348871	Completed	003-AHU-007	7/1/2016		True		Replace PRE-filters
FO-348872	Finished	003-AHU-006	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348873	Finished	003-AHU-005	7/1/2016	7/27/2016	False	1.50	Replace PRE-filters
FO-348874	Finished	003-AHU-004	7/1/2016	7/14/2016	False	1.50	Replace PRE-filters
FO-348875	Finished	003-AHU-003	7/1/2016	7/11/2016	False	1.50	Replace PRE-filters
FO-348876	Finished	003-AHU-002	7/1/2016	7/13/2016	False	1.00	Replace PRE-filters
FO-348877	Completed	003-AHU-001	7/1/2016		True		Replace PRE-filters
FO-348878	Created By PM Schedule	141-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348879	Created By PM Schedule	074-AHU-004	7/1/2016		False		Replace PRE-filters
FO-348880	Created By PM Schedule	074-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348881	Created By PM Schedule	074-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348882	Created By PM Schedule	074-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348883	Created By PM Schedule	193-AHU-004	7/1/2016		False		Replace PRE-filters
FO-348884	Created By PM Schedule	193-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348885	Created By PM Schedule	193-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348886	Created By PM Schedule	193-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348887	Finished	096-SAF-FC1	7/1/2016	7/28/2016	False	0.50	Replace PRE-filters
FO-348888	Finished	096-SAF-00E	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348889	Finished	096-SAF-001	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348890	Finished	096-RAF-010	7/1/2016	7/28/2016	False	1.00	Replace PRE-filters
FO-348891	Finished	096-RAF-00B	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348892	Finished	096-RAF-009	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348893	Finished	096-RAF-008	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348894	Finished	096-RAF-007	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348895	Finished	096-RAF-006	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348896	Finished	096-RAF-005	7/1/2016	7/26/2016	False	1.50	Replace PRE-filters
FO-348897	Finished	096-RAF-004	7/1/2016	7/26/2016	False	2.75	Replace PRE-filters
FO-348898	Finished	096-RAF-003	7/1/2016	7/26/2016	False	2.25	Replace PRE-filters
FO-348899	Finished	096-RAF-002	7/1/2016	7/26/2016	False	2.00	Replace PRE-filters
FO-348900	Finished	155-AHU-005	7/1/2016	7/14/2016	False	1.50	Replace PRE-filters
FO-348901	Finished	155-AHU-004	7/1/2016	7/14/2016	False	3.50	Replace PRE-filters
FO-348902	Finished	155-AHU-003	7/1/2016	7/13/2016	False	3.50	Replace PRE-filters
FO-348903	Finished	155-AHU-002	7/1/2016	7/12/2016	False	3.50	Replace PRE-filters
FO-348904	Finished	155-AHU-001	7/1/2016	7/12/2016	False	3.50	Replace PRE-filters
FO-348907	Finished	499-AHU-007	7/1/2016	7/15/2016	False	3.00	Replace PRE-filters
FO-348908	Finished	499-AHU-005	7/1/2016	7/19/2016	False	2.00	Replace PRE-filters
FO-348909	Finished	499-AHU-004	7/1/2016	7/19/2016	False	3.00	Replace PRE-filters
FO-348911	Finished	080-EXF-006	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348912	Finished	080-EXF-005	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348913	Finished	080-EXF-001	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-348914	Finished	150-EXF-002	7/1/2016	7/8/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348915	Created By PM Schedule	612-HVU-001	7/1/2016		False		Replace PRE-filters
FO-348916	Finished	096-FP-001	7/1/2016	7/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348917	Completed	150-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348918	Completed	150-AHU-002	7/1/2016		True		Replace PRE-filters
FO-348919	Completed	150-AHU-001	7/1/2016		True		Replace PRE-filters
FO-348920	Finished	169-FAP-001	7/1/2016	7/28/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348921	Created By PM Schedule	608-AHU-004	7/1/2016		False		Replace PRE-filters
FO-348922	Created By PM Schedule	608-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348923	Created By PM Schedule	608-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348924	Created By PM Schedule	608-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348925	Finished	499-AHU-008	7/1/2016	7/16/2016	False	2.50	Replace PRE-filters
FO-348926	Created By PM Schedule	074-AHU-005	7/1/2016		False		Replace PRE-filters
FO-348928	Finished	637-FP-001	7/1/2016	7/20/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348956	Finished	499-AHU-003	7/1/2016	7/15/2016	False	0.75	Replace PRE-filters
FO-348957	Finished	499-AHU-002	7/1/2016	7/14/2016	False	0.75	Replace PRE-filters
FO-348959	Finished	499-AHU-001	7/1/2016	7/14/2016	False	0.75	Replace PRE-filters
FO-348960	Finished	096-EXF-028	7/1/2016	7/22/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348961	Created By PM Schedule	096-EXF-024	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348962	Finished	096-EXF-017	7/1/2016	7/22/2016	False	1.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348963	Created By PM Schedule	096-EXF-016	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348964	Created By PM Schedule	096-EXF-015	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348965	Finished	096-EXF-014	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348966	Finished	096-EXF-013	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348967	Finished	096-EXF-012	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348968	Finished	096-EXF-011	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348969	Finished	096-EXF-010	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348970	Finished	096-EXF-009	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348971	Finished	096-EXF-008	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348972	Finished	096-EXF-007	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348973	Finished	096-EXF-006	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348974	Finished	096-EXF-005	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348975	Finished	096-EXF-004	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348980	Finished	080-ACU-004	7/1/2016	7/21/2016	False	0.75	Replace PRE-filters
FO-348981	Finished	080-ACU-003	7/1/2016	7/6/2016	False	1.50	Replace PRE-filters
FO-348982	Finished	080-ACU-002	7/1/2016	7/6/2016	False	1.00	Replace PRE-filters
FO-348983	Finished	080-ACU-001	7/1/2016	7/6/2016	False	1.00	Replace PRE-filters
FO-350153	Finished	096-00600.00	7/1/2016	7/28/2016	False	1.00	UBW-001-600 (Need to add to TMA Equipment Inventory) Replace PRE-filters
FO-351573	Created By PM Schedule	499-EXF-006	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-353335	Created	074-AHU-002	7/27/2016		False		Belt Order: AHU-2 B50 Qty: 2

E - South

39

34

4

1

87%

Requested Finished Open WND

% Finished

FO-350389	Finished	090-AIR-001	7/1/2016	7/25/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350390	Finished	090-AIR-002	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350393	Finished	090-AIR-004	7/1/2016	7/29/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350397	Finished	089-DWBP-001	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350398	Finished	089-DWBP-002	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350399	Finished	089-DWBP-003	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350452	Finished	090-SP-002	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350453	Finished	090-SP-003	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350454	Finished	090-SP-006	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350455	Finished	006-VPS-001	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350456	Finished	006-VPS-002	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350457	Finished	006-DWBP-001	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350458	Finished	006-DWBP-002	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350466	Finished	090-ACU-CR1	7/1/2016	7/8/2016	True	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
Cancelled. Changed from monthly to quarterly PM.							
Last PM: June 2016							
Next PM: September 2016							
FO-350495	Created By PM Schedule	127-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350496	Created By PM Schedule	127-EXF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350506	Finished	090-AIR-541	7/1/2016	7/14/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350507	Finished	090-SSF-541	7/1/2016	7/12/2016	False	1.00	PM - Harmsco Side Stream Filter
FO-350513	Finished	089-ACU-001	7/1/2016	7/19/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350514	Created By PM Schedule	016-ACU-004	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350515	Finished	006-ACU-001	7/1/2016	7/13/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
UNIT IS NO LONGER IN SERVICE.							
FO-350518	Finished	090-ACU-403	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350519	Finished	090-ACU-402	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350520	Finished	090-ACU-401	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350521	Created By PM Schedule	022-ACU-001	7/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350522	Finished	007-ACU-002	7/1/2016	7/27/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Contractors checked machine. Oil samples taken.							
FO-350523	Finished	007-ACU-001	7/1/2016	7/27/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Contractor performed PM. Oil samples taken.							
FO-350871	Finished	007-GEN-001	7/14/2016	7/14/2016	False	0.50	Generator Maintenance, Monthly
FO-350873	Finished	007-GEN-002	7/7/2016	7/14/2016	False	0.50	Generator Maintenance, Monthly
FO-350875	Finished	090-GEN-001	7/14/2016	7/20/2016	False	1.00	Generator Maintenance, Monthly
FO-350877	Finished	089-GEN-001	7/20/2016	7/26/2016	False	1.00	Generator Maintenance, Monthly
FO-350896	Finished	090-GEN-002	7/14/2016	7/14/2016	False	1.00	Generator Maintenance, Monthly
FO-350909	Finished	006-GEN-001	7/21/2016	7/21/2016	False	0.40	Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-350919	Created By PM Schedule	003-GEN-001	7/6/2016		False		Generator Maintenance, Monthly
FO-350921	Finished	005-GEN-001	7/6/2016	7/7/2016	False	0.50	Generator Maintenance, Monthly
FO-350923	Finished	090-GEN-003	7/14/2016	7/14/2016	False	1.00	Generator Maintenance, Monthly
FO-351079	Finished	090-ACU-CR2	7/8/2016	7/7/2016	False	0.50	Monthly AHU Inspection Clean Room Unit 2
FO-351080	Finished	090-ACU-CR2	7/8/2016	7/7/2016	False	0.50	PM - Semi Anunal Air Handling Unit Inspection
FO-351083	Finished	090-EW-001	7/9/2016	7/6/2016	False	1.00	PM - Emergency Shower/Eyewash Station - Annual Flow Test

E - Southeast

92

0

92

0

0%

FO-350391	Created By PM Schedule	022-HEX-001	7/1/2016		False		PM - Heat Exchanger and Economizer
FO-350392	Created By PM Schedule	001-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350400	Created By PM Schedule	001-FCU-0159-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350401	Created By PM Schedule	001-FCU-0159-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350402	Created By PM Schedule	001-FCU-0162-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350403	Created By PM Schedule	001-FCU-0162-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350404	Created By PM Schedule	001-FCU-0162-3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350405	Created By PM Schedule	001-FCU-0165-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350406	Created By PM Schedule	001-FCU-0165-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350407	Created By PM Schedule	001-FCU-0165-3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350408	Created By PM Schedule	001-FCU-0168-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350409	Created By PM Schedule	001-FCU-0168-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350410	Created By PM Schedule	001-FCU-0168-3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350411	Created By PM Schedule	001-FCU-0171-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350412	Created By PM Schedule	001-FCU-0171-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350413	Created By PM Schedule	001-FCU-0174-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350414	Created By PM Schedule	001-FCU-0174-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350415	Created By PM Schedule	001-FCU-0174-3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350416	Created By PM Schedule	001-FCU-3210-1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350417	Created By PM Schedule	001-FCU-3210-2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350418	Created By PM Schedule	001-FCU-3214	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350419	Created By PM Schedule	001-FCU-3216	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350420	Created By PM Schedule	001-FCU-3225.1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350421	Created By PM Schedule	001-FCU-3225.1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350422	Created By PM Schedule	001-FCU-3225.2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350423	Created By PM Schedule	001-FCU-3225.3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350424	Created By PM Schedule	001-FCU-3225.4	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350425	Created By PM Schedule	001-FCU-3225.5	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350426	Created By PM Schedule	001-FCU-3225.6	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350427	Created By PM Schedule	001-FCU-3225.7	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350428	Created By PM Schedule	001-FCU-3225.8	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350429	Created By PM Schedule	001-FCU-3225.1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350430	Created By PM Schedule	001-FCU-3226.1	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350431	Created By PM Schedule	001-FCU-3226.2	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350432	Created By PM Schedule	001-FCU-3226.3	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350433	Created By PM Schedule	001-FCU-3226.4	7/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-350434	Created By PM Schedule	001-FCU-3226.5	7/1/2016		False		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-350435	Created By PM Schedule	001-FCU-3226.6	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350436	Created By PM Schedule	001-FCU-3226.7	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350437	Created By PM Schedule	001-FCU-3303-1	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350438	Created By PM Schedule	001-FCU-3303-2	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350439	Created By PM Schedule	001-FCU-3303-3	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350440	Created By PM Schedule	001-FCU-3337	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350441	Created By PM Schedule	001-FCU-3347	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350442	Created By PM Schedule	001-FCU-3349	7/1/2016	False	1.50 PM - Fan Coil/HV/AC Unit
FO-350443	Created By PM Schedule	001-FCU-3357	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350444	Created By PM Schedule	001-FCU-3361	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350445	Created By PM Schedule	001-FCU-3365	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350446	Created By PM Schedule	001-FCU-3384-1	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350447	Created By PM Schedule	001-FCU-3384-2	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350459	Created By PM Schedule	071-HWP-024	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350460	Created By PM Schedule	071-HWP-025	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350461	Created By PM Schedule	071-HWP-026	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350462	Created By PM Schedule	189-AIR-001	7/1/2016	False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350463	Created By PM Schedule	499-AIR-001	7/1/2016	False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350465	Created By PM Schedule	001-FCU-3225	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350480	Created By PM Schedule	071-ACU-012	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350481	Created By PM Schedule	071-ACU-013	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350482	Created By PM Schedule	071-HWP-217	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350483	Created By PM Schedule	071-HWP-218	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350484	Created By PM Schedule	071-HWP-219	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350485	Created By PM Schedule	071-HWP-221	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350486	Created By PM Schedule	071-HWP-220	7/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-350487	Created By PM Schedule	071-ACU-014	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350488	Created By PM Schedule	071-ACU-015	7/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-350508	Created By PM Schedule	637-ACU-003	7/1/2016	False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350509	Created By PM Schedule	637-ACU-002	7/1/2016	False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350510	Created By PM Schedule	499-ACU-001	7/1/2016	False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350516	Created By PM Schedule	082-ACU-003	7/1/2016	False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350524	Created By PM Schedule	001-ACU-003	7/1/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350525	Created By PM Schedule	001-ACU-002	7/1/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350526	Created By PM Schedule	001-ACU-001	7/1/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350528	Created By PM Schedule	189-ACU-003	7/1/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350881	Created By PM Schedule	637-GEN-001	7/19/2016	False	Generator Maintenance, Monthly
FO-350883	Created By PM Schedule	637-GEN-002	7/19/2016	False	Generator Maintenance, Monthly
FO-351082	Created By PM Schedule	001-EW-004	7/9/2016	False	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-351399	Created By PM Schedule	499-CFP-001	7/15/2016	False	PM - Chemical Feed/Metering Pump/Controller
FO-351400	Created By PM Schedule	499-CFP-002	7/15/2016	False	PM - Chemical Feed/Metering Pump/Controller

Requested Finished Open WND

% Finished

FO-351401	Created By PM Schedule	499-CFP-003	7/15/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-351402	Created By PM Schedule	499-CFP-004	7/15/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-351983	Created By PM Schedule	082-HWH-001	7/23/2016		False	PM - Domestic Water Heater, Gas
FO-351985	Created By PM Schedule	071-EXF-006	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351986	Created By PM Schedule	071-EXF-007	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351987	Created By PM Schedule	071-EXF-008	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351988	Created By PM Schedule	071-EXF-009	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351989	Created By PM Schedule	071-EXF-010	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351990	Created By PM Schedule	071-EXF-011	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351991	Created By PM Schedule	071-EXF-012	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351992	Created By PM Schedule	071-EXF-013	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351993	Created By PM Schedule	071-EXF-014	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351994	Created By PM Schedule	071-EXF-015	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351995	Created By PM Schedule	071-EXF-016	7/24/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - West

37

23

14

0

62%

FO-350394	Created By PM Schedule	155-AIR-001	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350395	Created By PM Schedule	155-SRS-001	7/1/2016		False	PM - Unspecified
FO-350396	Created By PM Schedule	155-SRS-002	7/1/2016		False	PM - Unspecified
FO-350448	Created By PM Schedule	003-AIR-001	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350449	Created By PM Schedule	003-AIR-003	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350450	Created By PM Schedule	003-AIR-004	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350451	Created By PM Schedule	167-AIR-001	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350464	Created By PM Schedule	150-AIR-001	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350476	Finished	080-SP-001	7/1/2016	7/11/2016	False	1.00 PM - Sump Pump

Preventive maintenance perform

FO-350477	Finished	080-SP-002	7/1/2016	7/11/2016	False	1.00 PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	---------------------

preventive maintenance perform

FO-350478	Created By PM Schedule	166-AIR-001	7/1/2016		False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350479	Finished	156-AIR-001	7/1/2016	7/29/2016	False	0.75 PM - Air Compressor, Reciprocating 5-40 H.P.

eng completed pm on compressor

FO-350511	Created By PM Schedule	155-ACU-002	7/1/2016		False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350512	Created By PM Schedule	155-ACU-001	7/1/2016		False	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

FO-350534	Finished	080-SAF-02A	7/1/2016	7/7/2016	False	1.00 Replace PRE-filters
-----------	----------	-------------	----------	----------	-------	--------------------------

Replace filters

FO-350535	Finished	080-SAF-01A	7/1/2016	7/7/2016	False	1.00 Replace PRE-filters
-----------	----------	-------------	----------	----------	-------	--------------------------

Replace filters

FO-350536	Finished	080-SAF-018	7/1/2016	7/7/2016	False	1.00 Replace PRE-filters
-----------	----------	-------------	----------	----------	-------	--------------------------

replace filters

FO-350537	Finished	080-SAF-017	7/1/2016	7/7/2016	False	1.00 Replace PRE-filters
-----------	----------	-------------	----------	----------	-------	--------------------------

replace filters

FO-350538	Finished	080-SAF-016	7/1/2016	7/7/2016	False	1.00 Replace PRE-filters
-----------	----------	-------------	----------	----------	-------	--------------------------

replace filters

Requested Finished Open WND

% Finished

FO-350539	Finished	080-SAF-015	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350540	Finished	080-SAF-014	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350541	Finished	080-SAF-013	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350542	Finished	080-SAF-012	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350543	Finished	080-SAF-011	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350544	Finished	080-SAF-010	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350545	Finished	080-SAF-009	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350546	Finished	080-SAF-008	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350547	Finished	080-SAF-007	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350548	Finished	080-SAF-006	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350549	Finished	080-SAF-005	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350550	Finished	080-SAF-004	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350551	Finished	080-SAF-003	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350552	Finished	080-SAF-002	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350553	Finished	080-SAF-001	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
replace filters							
FO-350905	Created By PM Schedule	001 SPARE from	7/12/2016		False		Generator Maintenance, Monthly
FO-351984	Created By PM Schedule	155-SP-001	7/24/2016		False		PM - Sump Pump
FO-352611	Created By PM Schedule	169-GEN-001	7/28/2016		False		Generator Maintenance, Monthly

Trades	112	76	36	0		68%
---------------	------------	-----------	-----------	----------	--	------------

T - Electrician	71	47	24	0		66%
------------------------	-----------	-----------	-----------	----------	--	------------

FO-350489	Finished	608-GEN-001	7/5/2016	7/5/2016	False	4.00	Generator Test
FO-350554	Finished	603-GEN-001	7/5/2016	7/5/2016	False	4.00	Generator Test
FO-350555	Finished	051-SP-001	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump
FO-350556	Finished	051-SP-002	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump
FO-350557	Finished	051-SP-003	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump
FO-350558	Finished	051-SP-004	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump
FO-350559	Finished	051-SP-005	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump
FO-350560	Finished	051-SP-006	7/4/2016	7/18/2016	False	0.25	PM - Sump Pump

Requested Finished Open WND

% Finished

FO-350870	Finished	609-GEN-001	7/19/2016	7/19/2016	False	4.00	Generator Test
FO-350872	Created By PM Schedule	007-GEN-001	7/14/2016		False	2.00	Generator Test
FO-350874	Created By PM Schedule	007-GEN-002	7/14/2016		False	2.00	Generator Test
FO-350876	Finished	090-GEN-001	7/14/2016	7/19/2016	False	4.00	Generator Test
FO-350878	Finished	089-GEN-001	7/20/2016	7/20/2016	False	4.00	Generator Test
FO-350879	Finished	193-GEN-001	7/1/2016	7/8/2016	False	1.00	Generator Test
FO-350880	Finished	637-GEN-001	7/19/2016	7/19/2016	False	2.00	Generator Test
FO-350882	Finished	637-GEN-002	7/19/2016	7/19/2016	False	2.00	Generator Test
OUT OF SERVICE							
FO-350884	Finished	612-GEN-001	7/12/2016	7/12/2016	False	2.00	Generator Test
Fault alarm light blinking							
FO-350886	Finished	612-GEN-002	7/12/2016	7/12/2016	False	2.00	Generator Test
FO-350888	Finished	501-GEN-001	7/12/2016	7/12/2016	False	4.00	Generator Test
FO-350890	Finished	507-GEN-001	7/13/2016	7/13/2016	False	4.00	Generator Test
FO-350892	Finished	203-GEN-001	7/19/2016	7/19/2016	False	4.00	Generator Test
FO-350894	Finished	536-GEN-001	7/20/2016	7/20/2016	False	8.00	Generator Test
FO-350895	Finished	090-GEN-002	7/14/2016	7/14/2016	False	2.00	Generator Test
FO-350898	Finished	527-GEN-001	7/21/2016	7/21/2016	False	4.00	Generator Test
FO-350901	Finished	048-GEN-001	7/12/2016	7/12/2016	False	5.00	Generator Test
FO-350904	Finished	001 SPARE from	7/12/2016	7/12/2016	False	4.00	Generator Test
FO-350906	Finished	-GEN-001 (Towa	7/13/2016	7/13/2016	False	4.00	Generator Test
FO-350908	Finished	006-GEN-001	7/21/2016	7/21/2016	False	4.00	Generator Test
FO-350910	Finished	193-GEN-002	7/1/2016	7/8/2016	False	1.00	Generator Test
FO-350912	Finished	193-GEN-003	7/1/2016	7/8/2016	False	1.00	Generator Test
FO-350914	Finished	193-GEN-004	7/1/2016	7/8/2016	False	1.00	Generator Test
FO-350916	Finished	034-GEN-001	7/7/2016	7/7/2016	False	4.00	Generator Test
FO-350918	Finished	003-GEN-001	7/6/2016	7/6/2016	False	4.00	Generator Test
FO-350920	Finished	005-GEN-001	7/6/2016	7/6/2016	False	4.00	Generator Test
FO-350922	Finished	090-GEN-003	7/14/2016	7/14/2016	False	2.00	Generator Test
FO-350924	Finished	209-GEN-002	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350925	Finished	209-GEN-001	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350927	Finished	209-GEN-003	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350929	Finished	209-GEN-004	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350931	Finished	211-GEN-001	7/1/2016	7/8/2016	False	2.00	Generator Test
FO-350932	Finished	211-GEN-002	7/1/2016	7/8/2016	False	2.00	Generator Test
FO-351084	Created By PM Schedule	051-SP-001	7/11/2016		False		PM - Sump Pump
FO-351085	Created By PM Schedule	051-SP-002	7/11/2016		False		PM - Sump Pump
FO-351086	Created By PM Schedule	051-SP-003	7/11/2016		False		PM - Sump Pump
FO-351087	Created By PM Schedule	051-SP-004	7/11/2016		False		PM - Sump Pump
FO-351088	Created By PM Schedule	051-SP-005	7/11/2016		False		PM - Sump Pump
FO-351089	Created By PM Schedule	051-SP-006	7/11/2016		False		PM - Sump Pump
FO-351404	Created By PM Schedule	051-SP-001	7/18/2016		False		PM - Sump Pump
FO-351405	Created By PM Schedule	051-SP-002	7/18/2016		False		PM - Sump Pump
FO-351406	Created By PM Schedule	051-SP-003	7/18/2016		False		PM - Sump Pump

Requested Finished Open WND

% Finished

FO-351407	Created By PM Schedule	051-SP-004	7/18/2016		False		PM - Sump Pump
FO-351408	Created By PM Schedule	051-SP-005	7/18/2016		False		PM - Sump Pump
FO-351409	Created By PM Schedule	051-SP-006	7/18/2016		False		PM - Sump Pump
FO-351996	Finished	611-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-351997	Finished	104-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-351999	Finished	127-GEN-001	7/26/2016	7/26/2016	False	1.00	Generator Test
FO-352001	Finished	127-GEN-002	7/26/2016	7/26/2016	False		Generator Test
FO-352003	Finished	127-GEN-003	7/26/2016	7/26/2016	False		Generator Test
FO-352005	Finished	127-GEN-004	7/26/2016	7/26/2016	False		Generator Test
FO-352008	Created By PM Schedule	051-SP-001	7/25/2016		False		PM - Sump Pump
FO-352009	Created By PM Schedule	051-SP-002	7/25/2016		False		PM - Sump Pump
FO-352010	Created By PM Schedule	051-SP-003	7/25/2016		False		PM - Sump Pump
FO-352011	Created By PM Schedule	051-SP-004	7/25/2016		False		PM - Sump Pump
FO-352012	Created By PM Schedule	051-SP-005	7/25/2016		False		PM - Sump Pump
FO-352013	Created By PM Schedule	051-SP-006	7/25/2016		False		PM - Sump Pump
FO-352014	Finished	629-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-352566	Created By PM Schedule	066-GEN-001	7/27/2016		False	12.00	Generator Test
FO-352567	Finished	130-GEN-001	7/27/2016	7/27/2016	False	4.00	Generator Test
FO-352610	Created By PM Schedule	169-GEN-001	7/28/2016		False	4.00	Generator Test
FO-352613	Created By PM Schedule	060-GEN-001A	7/28/2016		False	2.00	Generator Test
FO-352614	Created By PM Schedule	060-GEN-001B	7/28/2016		False	2.00	Generator Test
T - Plumber			41	29	12	0	71%
FO-349097	Created By PM Schedule	042	7/1/2016		False	0.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/7/1 ,,,,,,,,,,
FO-349098	Finished	527	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Main Drain with Copper Sulfate
FO-349099	Finished	608	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Waterless Urinals
FO-349100	Finished	049	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Waterless Urinals
FO-349101	Finished	090	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Waterless Urinals
FO-351329	Created By PM Schedule	629-RPZ-001	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351330	Finished	629-RPZ-002	7/1/2016	7/21/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351331	Finished	629-RPZ-003	7/1/2016	7/21/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351332	Finished	629-RPZ-004	7/1/2016	7/26/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351333	Finished	629-RPZ-005	7/1/2016	7/21/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16.
FO-351334	Finished	629-RPZ-006	7/1/2016	7/21/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351335	Finished	629-RPZ-007	7/1/2016	7/22/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351336	Created By PM Schedule	629-RPZ-008	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351337	Created By PM Schedule	629-RPZ-009	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351338	Created By PM Schedule	629-RPZ-010	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351339	Created By PM Schedule	629-RPZ-011	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16

Requested Finished Open WND

% Finished

FO-351340	Created By PM Schedule	629-RPZ-012	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351341	Created By PM Schedule	629-RPZ-013	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351342	Created By PM Schedule	629-RPZ-014	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351343	Finished	629-PVB-001	7/1/2016	7/22/2016	False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351344	Finished	611-PVB-001	7/1/2016	7/14/2016	False	3.00	PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351345	Finished	611-RPZ-001	7/1/2016	7/15/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351346	Finished	611-RPZ-003	7/1/2016	7/15/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351347	Finished	611-RPZ-002	7/1/2016	7/12/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351348	Finished	611-RPZ-004	7/1/2016	7/15/2016	False	2.50	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351349	Finished	611-RPZ-005	7/1/2016	7/12/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351350	Finished	611-RPZ-006	7/1/2016	7/11/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351351	Finished	611-RPZ-007	7/1/2016	7/12/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351352	Finished	611-RPZ-008	7/1/2016	7/11/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351353	Finished	193-RPZ-001	7/1/2016	7/7/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351354	Finished	193-RPZ-002	7/1/2016	7/8/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351355	Finished	193-RPZ-003	7/1/2016	7/11/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351356	Finished	193-RPZ-004	7/1/2016	7/7/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351357	Finished	620-RPZ-001	7/1/2016	7/7/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351358	Finished	203-RPZ-001	7/1/2016	7/7/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351851	Finished	193-RPZ-005	7/1/2016	7/8/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/7/16
FO-352984	Finished	629-RPZ-015	7/1/2016	7/26/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB7/25/16
FO-352985	Created By PM Schedule	629-RPZ-018	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352986	Created By PM Schedule	629-RPZ-017	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352987	Finished	629-RPZ-016	7/1/2016	7/26/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352988	Created By PM Schedule	629-RPZ-019	7/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16

Report Total

674 381 287 6

57%