

# Facilities Operations Work Orders Received 1/1/16 through 1/31/16

WO	Received	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1859</b>	
<b>Custodial</b>			<b>233</b>	
<b>High</b>			<b>2</b>	
<b>C-Sector 04</b>			<b>1</b>	
FO-338153	1/28/2016			WATER ON FLOOR. 2ND FLOOR MEN'S RESTROOM NEAR ROOM 2506.
<b>Pest Controller</b>			<b>1</b>	
FO-338125	1/28/2016			RM 12002.3 PLEASE SET MECH TRAPS
<b>Medium</b>			<b>6</b>	
<b>C-Materials</b>			<b>1</b>	
FO-337285	1/19/2016			Emmanuel, move all chemicals from cage storage area and office 015 to room .057 of the Student Center Building. (Lower level cage area).
<b>C-Repair</b>			<b>1</b>	
FO-336388	1/7/2016	1/7/2016		PIPESHOP: PLEASE INSTALL SOAP DISPENSER
<b>C-Sector 06</b>			<b>1</b>	
FO-336520	1/8/2016	1/15/2016		COMPUTER LAB RM 257 NEEDS CLEAN UP, SQUIRRELS WERE TRAPPED IN RM LEFT BEHIND SQUIRREL FECES. LAB OPENS AT 7AM Mon
<b>Pest Controller</b>			<b>3</b>	
FO-335832	1/4/2016	1/6/2016	1/6/2016	RM 4224 PLEASE SET MICE TRAPS
FO-336256	1/6/2016	1/14/2016	1/14/2016	Pest control needed- large cockroach in office
FO-336268	1/6/2016	1/6/2016		2ND FL RAT SITED..
<b>Low</b>			<b>225</b>	
<b>C-Lighting</b>			<b>83</b>	
FO-335838	1/4/2016	1/4/2016		Light above sink in second floor unisex bathroom is not working. Please repair or replace.
FO-335830	1/4/2016	1/4/2016		Light out in custodian closet room 251.
FO-335841	1/4/2016	1/5/2016		Light bulb is out in the 2nd floor hallway of the Prentis Bldg outside of room 200
FO-335900	1/4/2016	1/4/2016		Light bulb needs to be changed.
FO-336107	1/5/2016	1/5/2016		In 2190 a ceiling light fixture in the lobby area of the suite has two bulbs burnt out and the third one flickers. Please repair.
FO-336157	1/5/2016	1/6/2016		The Elaine L. Jacob Gallery (room 0402, Old Main) needs approximately 40 light bulbs for our next exhibition. The light bulbs needed are Sylvania flood 90W 130V. Thank you!
FO-336195	1/5/2016	1/6/2016		Overhead lighting fixture between UGL Study Rooms 2543 and Room 2540 on second floor has frame/casing hanging from one corner.
FO-336227	1/6/2016	1/7/2016		Light out in hallway, 2nd floor, near custodian closet. (in hallway left of the elevator).
FO-336241	1/6/2016	1/6/2016		Light bulb needs to be replaced in stock room 021 in the basement.
FO-336306	1/6/2016	1/7/2016		Light bulb outside of office, in hallway, needs to be replaced.
FO-336310	1/6/2016	1/6/2016		Room 220 - 1 set (est. 3 lights total) of lights are out.
FO-336311	1/6/2016	1/7/2016		Basement Stairwell C - 3 LO
FO-336312	1/6/2016	12/31/2015		Basement Stairwell B - 1 LO
FO-336313	1/6/2016	1/7/2016		Room 128 - 1 LO
FO-336314	1/6/2016	1/7/2016		Room 125 - 2 LO
FO-336324	1/6/2016	1/8/2016		Room 20 - 1 LO
FO-336325	1/6/2016	1/7/2016		Room 008 - 2 LO
FO-336326	1/6/2016	1/7/2016		Room 31 - 2 LO
FO-336328	1/6/2016	1/8/2016		I need several banks of fluorescent light bulbs changed in room 123 and room 124.
FO-336370	1/7/2016	1/8/2016		Several bulbs burnt out. Please replace.

WO	Recieved	Finished	Total	Request
FO-336374	1/7/2016	1/7/2016		BSMNT MENS RM LIGHT NEEDS REPLACING ASAP
FO-336401	1/7/2016	1/8/2016		Scott Hall - relamp light fixtures in room 7207, inside room 7205.
FO-336405	1/7/2016	1/8/2016		Strairwell "C" on the first floor. Inside the door to the stairweel going down light bulb is burnt out. Very dark in the staiway. Please replace ASAP.
FO-336428	1/8/2016	1/11/2016		Light Changers, please replace bulbs in basement hallway near room 12
FO-336465	1/8/2016	1/13/2016		Light bulb needs to be replaced. 1st floor near elevator on Second entrance near room elevator room 1122.
FO-336469	1/8/2016	1/8/2016		Rm. 2600 (the dean's conference room) has fluorescent lights that need to be checked. They flicker off and on.
FO-336513	1/8/2016	1/13/2016		Please replace burned out lights in the Auditorium.
FO-336552	1/11/2016	1/11/2016		LIGHT BULB REPLACEMENT. PRESIDENT'S OFFICE. ROOM 4200.
FO-336590	1/11/2016	1/11/2016		2nd fl, W R/R - Round Light is out
FO-336645	1/11/2016	1/12/2016		In Suite 206, the mens rooms has several lights out. 5 to be exact.
FO-336646	1/11/2016	1/12/2016		In Suite 206, back hallway light is out, directly in front of "idf room 223"
FO-336647	1/11/2016	1/12/2016		There's a ceiling light outside of office 313 in Mazurek that needs a replacement bulb
FO-336650	1/11/2016	1/12/2016		Relamp recessed light fixture in office 5374.
FO-336727	1/12/2016	1/14/2016		lite out womens rr next to janitors closet (2504) and 2204 4 lites out
FO-336752	1/12/2016	1/13/2016		Overhead light out in handicap stall in ladies bathroom, Room 2234 ... at least two tubes.
FO-336767	1/12/2016	1/14/2016		rm 487 lite fixture buzzing
FO-336801	1/13/2016	1/13/2016		Ceiling lights are out in rooms 4223 and 4224. Music practice rooms, Old Main Building.
FO-336825	1/13/2016	1/13/2016		Rm. 2609 has 6 fluorescent light bulbs out that need replacing.
FO-336828	1/13/2016	1/13/2016		Rm. 2625 (Dean's office) has 2 fluorescent light bulbs out that need replacing.
FO-336835	1/13/2016	1/13/2016		Kitchen light is out.
FO-336850	1/13/2016	1/14/2016		2nd floor, Room 2204, Center for Urban Studies - 2 LO. Second Request
FO-336851	1/13/2016	1/14/2016		2nd floor, W R/R, Center for Urban Studies - 2 LO Second Request
FO-336870	1/13/2016	1/14/2016		R/R ELEVATORS #4 & #5 NEED LITES REPLACED
FO-336880	1/13/2016	1/14/2016		Light bulbs out in hallway between office numbers 13001.3 and 13001.4. Thank you for your help!
FO-336892	1/14/2016	1/14/2016		Light crew: please replace burned out lights on north mezzanine level. Priority: med.
FO-336902	1/14/2016	1/14/2016		lite out over desk rm 230.
FO-336971	1/14/2016	1/19/2016		The two halogen 220v work lights on the south side of the stage are burned out. At least one of them has broken porcelain contacts and need to be replaced. Thanks
FO-336996	1/15/2016	1/15/2016		1 EP - Hallway 3rd Fl - The fixture is on the wall next to the elevator.
FO-337009	1/15/2016	1/15/2016		In front of room 034 (Hallway) - 1 LO
FO-337035	1/15/2016	1/21/2016		Outside the main entrance of the Engineering building at 5050 Anthony Wayne Drive there is an outside light burnt out right by the card reader. Once you enter the glass doors in the lobby area there is another light burnt out also. Thank you.
FO-337296	1/19/2016	1/27/2016		lights out
FO-337432	1/20/2016	1/21/2016		Replace burned out lights inn W. Restroom on the north end of the Matthaei Building - Room # 107
FO-337445	1/20/2016			Lab 440 - 3 Lights out
FO-337503	1/20/2016	1/21/2016		2 lights are out in freight elevator near loading dock.
FO-337534	1/20/2016	1/21/2016		Relamp three (3) recessed light fixtures over the vending area.
FO-337535	1/20/2016	1/21/2016		Relamp light fixture in front of stalls
FO-337537	1/20/2016	1/21/2016		On the Third Floor, 5057 Woodward, by the main elevators, there are three light fixtures in the ceiling. Between all three fixtures there a 10 lightbulbs burned out.
FO-337563	1/21/2016	1/22/2016		There are several fluorescent tubes (in some cases groups of tubes) that are out in labs 2542/2554 and rooms 1103/1119.

WO	Recieved	Finished	Total	Request
FO-337590	1/21/2016	1/21/2016		Lighting Dept. Please replace all lights in unisex bathroom, located near TV Studio 1st floor-- 3 fixtures. High priority
FO-337656	1/22/2016	1/22/2016		Lights are out in the hallway near room 3216 in the Maccabees building
FO-337658	1/22/2016			Room 243 - 6 LO
FO-337663	1/22/2016	1/25/2016		Lower level - at least 3 canister lights are out.
FO-337664	1/22/2016	1/22/2016		Room 154 - 2 LO
FO-337690	1/22/2016	1/25/2016		Light Changers, please replace bulbs in basement hallway outside room 0201.
FO-337720	1/23/2016			The Fluorescent lights in the stairwell to the second floor are out and/or flickering and need repair. Additionally a number of the interior perimeter light are out and need replacement.
FO-337730	1/25/2016	1/26/2016		Replace lights in room 240 Burned out bulbs were found: 1 right, middle / 1 right, front / 1 left, middle
FO-337731	1/25/2016	1/26/2016		Replace lights in room 242 and 243 242 Burned out bulb was found: 1 left, middle 243 Burned out bulbs were found: 1 right, middle / 1 right, front / 1 left, front
FO-337732	1/25/2016	1/26/2016		Replace bulbs in room 303 and 304 303 Burned out bulb was found: 1 left, middle 304 Burned out bulbs found: 1 right, front / 1 left, rear / 1 left, middle / 1 left, front
FO-337733	1/25/2016	1/26/2016		306 Burned out bulbs found: 3 left, front
FO-337734	1/25/2016	1/26/2016		Classroom 308, needs replacement light bulb 308 Burned out bulb found: 1 right, middle
FO-337775	1/25/2016	1/25/2016		Room 0213 - 2 LO
FO-337780	1/25/2016	1/27/2016		Replace light bulb, 1st floor near elevators.
FO-337808	1/25/2016	1/26/2016		Please replace burned out lights.
FO-337906	1/26/2016	1/26/2016		LIGHT BULB REPLACEMENT. WOMEN'S RESTROOM IN BASEMENT NEAR DRINKING FOUNTAIN ALSO ROOM 239.
FO-338026	1/27/2016			Room 206 - Exam Room - 3 LO - Please ask Conrad Hunt to show where fixtures are.
FO-338043	1/27/2016	1/27/2016		R/R FRONT HALLWAY & MASTER BATH NEED TO HAVE LITES REPLACED
FO-338084	1/27/2016	1/28/2016		Replace burnt out lights in cold room. Almost all are out.
FO-338119	1/28/2016	1/29/2016		Need light bulbs replaced as soon as possible. Students utilize this room for costume changes in Dance please replace by 1/29/2016. Thanks.
FO-338210	1/29/2016			Lounge - 10 LO
FO-338208	1/29/2016			Replace light bulbs
FO-338219	1/29/2016			Hallway, near Room # 357 - 1 LO
FO-338227	1/29/2016			Hallway, near room 487 - 2 panels, 2 LO.
FO-338228	1/29/2016			Requesting to have a bulb replaced in a ceiling light in front of the ladies restroom on the 3rd Floor of the Prentis Building. This is the only women's restroom on that floor.
<b>C-Materials</b>			<b>6</b>	
FO-336365	1/7/2016			Room 2361 - Recycling bin request
FO-336768	1/12/2016			2108 and 3100 one bin each
FO-337027	1/15/2016			Custodial Request: Please remove large recycle bin (full) from Student Affairs Office.
FO-337031	1/15/2016			Custodial: Please remove and replace large recycle bin inside suite 2209.
FO-337765	1/25/2016			Custodial: Please remove large gray recycle bin. The container is extremely full.
FO-338232	1/29/2016			Room 2155 - Recycling bin picked up and replaced.
<b>C-Projects</b>			<b>1</b>	
FO-338130	1/28/2016			In Rm. 5148 (new faculty professor) Please have custodial services clean the file cabinets; ssentially all sets of the metallic filing cabinets (the 2 standard upright, and the 2 sets of lateral style filing cabinets).
<b>C-Repair</b>			<b>42</b>	

WO	Recieved	Finished	Total	Request
FO-335868	1/4/2016	1/5/2016		Please repair paper towel dispenser in 1st floor Men's restroom - new. The wire hook that holds the paper towels has broken off.
FO-336160	1/5/2016	1/5/2016		Ladies Room - Soap dispenser is broken. Please fix/replace as necessary.
FO-336224	1/5/2016	1/7/2016		In the Men's faulty lookerroom next to the training room. The paper towel dispenser needs to be replaced.
FO-336225	1/5/2016	1/8/2016		Women's restroom near room 1515. The tissue holder needs to be replaced.
FO-336327	1/6/2016			Room 072 - R/R - 2 broken toilet dispensers (Handicap stall, and stall next to it.)
FO-336368	1/7/2016	1/7/2016		Room 154.1, Officials Locker Room - Broken Roll Towel Dispenser. Requester needs it done on 1/7/16 for upcoming game.
FO-336420	1/8/2016	1/8/2016		3rd Floor Womens restroom, 2nd stall from the door toilet paper holder is broken.
FO-336438	1/8/2016	1/8/2016		A REQUEST FROM THE CUSTOD. WORKER FOR SERVICE REPAIRS ABOUT THE HANDLE BROKEN ON VACUUM CLEANER THAT WAS TRANSFER BY WOKER ON 11-11-15. (SANITAIRE/SC882-A1/SER.#12480013320
FO-336461	1/8/2016			Vacuum located in room 015. Sanitaire. Serial number 060400206. Vacuum stopped working while in used.
FO-336463	1/8/2016			Vacuum located in room 015. Sanitaire. Serial number 06290011772. Vacuum was used on wet carpet by staff members and the vacuum stopped working.
FO-336471	1/8/2016			Auto scrubber located in basement room 051 has a broken pad holder clamp.
FO-336624	1/11/2016	1/12/2016		R/R RM 7101/MENS RR SOAP DISPENSER IS BROKEN
FO-336653	1/11/2016	1/15/2016		Broken vacuum (2) need to be repaired. Not picking up.
FO-336670	1/12/2016	1/19/2016		Vacuum stopped working while in use. Sanitaire Model SC 887 Serial # 1349011527 Located in #1407
FO-336676	1/12/2016	1/15/2016		Please repair broken towel dispensers in the following areas at Matthaei Room 175 W. Basketball Locker Room Room 176 W. Locker Room  Please contact Bob Ostrowski. Thank You.
FO-336731	1/12/2016	1/14/2016		5th floor womens rr dispenser walling off wall
FO-336796	1/13/2016	1/14/2016		1st floor men's restroom (not locker room)has two broken towel dispensers that need repair.
FO-336883	1/14/2016	1/19/2016		The Converamatic, in the basement is not letting out enough water to do the job. You fixed it before and don't know what happen to it since then.
FO-337030	1/15/2016	1/22/2016		Custodial: Please fix toilet paper dispenser in handicap bathroom inside room 1111.
FO-337329	1/19/2016	1/19/2016		A REQUEST FOR A ADVANCE AUTO, SCRUBBER (Key) FOR (CONV. X26D-C) TIME: 719.6 01-15-16
FO-337336	1/19/2016	1/20/2016		Please move Key storage box to office 057.1 of the Student Center Building.
FO-337339	1/19/2016	1/20/2016		Please move cork board from room .015 to room 57.1 of Student Center Building.
FO-337340	1/19/2016	1/20/2016		Please move white board from room .015 to room 57.1 of Student Center Building.
FO-337353	1/19/2016			The hose on the auto scrubber has a huge hole in it and the machine itself will not hold a charge.
FO-337495	1/20/2016			Please repair Advance Adfinity 20D auto scrubber. Not taking a charge, Instrument panel not lighting up. Scrubber in basement closet
FO-337496	1/20/2016			Please repair squeegee on boost auto scrubber
FO-337538	1/21/2016			Auto scrubber model X26D-C serial #1955712. The machine does not hold a charge.
FO-337539	1/21/2016			Auto scrubber,Model amphibian Serial # 1000000479. The machine spits water out the front when its being ran,
FO-337540	1/21/2016			The soap dispenser in the restroom in suite 249 in the Simons building is broken.
FO-337582	1/21/2016	1/22/2016		3rd floor women's restroom, broken roll towel dispenser.
FO-337586	1/21/2016			Auto scrubber located under stairs near Anthony Wayne entry door.  Machine isn't releasing water.

WO	Recieved	Finished	Total	Request
FO-337601	1/21/2016	1/20/2016		I WAS LOOKING FOR A BROKEN DISPENSER AND CHECK THIS RESTROOM TO FIND THE TISSUE DISPENSER WAS BRKEN IN THE HANDICAP STALL. THE (FO-337030) IS THE ONE I WAS LOOKING FOR.
FO-337642	1/22/2016			5th floor women soap dispenser off the wall need too replace it.
FO-337687	1/22/2016	1/25/2016		HE SAID THE AUTO SCRUBBER SQUEEGEE NEEDS SOME SERVICE REPAIRS.  Made Out By: HANDYMAN ALP
FO-337691	1/22/2016	1/22/2016		EQUIPMENT TRANSFER: A REQUEST TO MOVE A (FLOOR, MACHINE and CARPET, MACHINE) From: Applebaum To: Scott, Hall Made Out BY: Handyman ALP
FO-337782	1/25/2016			Vacuum is not collecting and bag won't inflate. (Call Supervisor for elevator access)  Sanitaire - serial# 1503000160
FO-337784	1/25/2016			Wet vac not picking up water. Located Anthony Wayne entry door, under stairs. Noble. Serial #100256-102188131
FO-337828	1/25/2016			The ladies restroom on the lowest level (closest to the Mack side of the building) has two broken paper towel dispensers that need repair.
FO-337893	1/26/2016	1/25/2016		SUPPLIES TRANSFER: A REQUEST FROM (A.D.) TO DELIVERY CUSTODIAL DEPARTMENT TO (AAB) BACK DOOR DECK AREA.
FO-337894	1/26/2016			SUPPLIES TRANSFER: A REQUEST FROM THE (A.D.) TO TRANSFER SUPPLIES FROM (FPM/STOCKROOM) TO (PUBLIC SAFETY) BLD.
FO-337910	1/26/2016			MENS RM ON RAMP TOILET PAPER HOLDER BROKEN
FO-337987	1/27/2016			Please repair shower power washer. In fitness center. It leaks.
<b>C-Sector 01</b>			<b>6</b>	
FO-335929	1/4/2016	1/8/2016		This undergrad teaching lab needs to be mopped before the classes start on the 11th.  Task is complete
FO-336569	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336570	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336571	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336572	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336574	1/11/2016	1/12/2016		2 cases of dial soap.
<b>C-Sector 02</b>			<b>15</b>	
FO-336114	1/5/2016	1/8/2016		Request from Physical Therapy faculty: On Friday Jan 8th from 12p to 4p we will conduct interviews. Could you please ensure that the above rooms are clean so that they can present a welcoming environment to the applicants? This is in the LRC study rooms,
FO-336115	1/5/2016	1/7/2016		Office-Rm. 1341. Please ensure it is clean prior Jan 8th for Physical Therapy interviews.
FO-336213	1/5/2016	1/15/2016		Rm. 5148 needs dusting and carpet shampooed before January 18th, the arrival of the new Dean.
FO-336214	1/5/2016	1/15/2016		Rm. 5144 needs dusting and carpet shampooed before January 18th, the arrival of the new Dean.
FO-336215	1/5/2016	1/14/2016		Rm. 4116 needs dusting and carpet shampooed before January 18th, the arrival of the new Dean.
FO-336216	1/5/2016	1/14/2016		Rm. 4230 needs dusting, counters cleaned and floor stripped and waxed before January 18th, the arrival of the new Dean.
FO-336217	1/5/2016	1/13/2016		Rm. 2625 needs dusting after this Friday, January 8th. This is the new Dean's office. The dean is arriving January 18th.
FO-337584	1/21/2016	1/25/2016		Rm. 4461 - Clean and Mop floor prior to Wednesday, January 27, 2016. They would like this done before new equip. arrives. Note: It is not a tiled floor.
FO-337697	1/22/2016			Please have the 1st floor men's locker room walls in the 1st stall cleaned.
FO-337698	1/22/2016			5th floor men's restroom handicapped stall walls need cleaning.
FO-338243	1/29/2016			6 cases of dial soap.
FO-338245	1/29/2016			4 cases of dial soap.

WO	Recieved	Finished	Total	Request
FO-338246	1/29/2016			4 cases of dial soap.
FO-338247	1/29/2016			4 cases of dial soap.
FO-338248	1/29/2016			60 W. Hancock & 90 W. Hancock - 4 cases of dial soap.
<b>C-Sector 03</b>			<b>7</b>	
FO-336307	1/6/2016	1/8/2016		please clean room 312 before winter classes begin-(before the holiday, there was water back up problems. thank you
FO-336331	1/6/2016	1/11/2016		Please deep clean the auditorium, stage and backstage area before tuesday January 12th, 2015. Please vaccum and clean the stains carpet, ensuring the auditorium seating is cleaned underneath. Additionally, the control room floor needs to be mopped
FO-337010	1/15/2016	1/28/2016		1 case of dial soap.
FO-337012	1/15/2016	1/28/2016		1 case of dial soap.
FO-337013	1/15/2016	1/28/2016		1 case of dial soap.
FO-337014	1/15/2016	1/28/2016		1 case of dial soap.
FO-337016	1/15/2016	1/28/2016		1 case of dial soap.
<b>C-Sector 04</b>			<b>8</b>	
FO-336257	1/6/2016	12/8/2015		4 Bottles of Hand Soap.
FO-337428	1/20/2016	1/21/2016		2 cases of dial soap.
FO-337431	1/20/2016	1/21/2016		1 case of dial soap.
FO-337437	1/20/2016	1/21/2016		1 case of dial soap.
FO-337439	1/20/2016	1/21/2016		1 case of dial soap.
FO-338249	1/29/2016			2 cases of dial soap.
FO-338250	1/29/2016			2 cases of dial soap.
FO-338251	1/29/2016			University daycare/Knapp - 2 cases of dial soap.
<b>C-Sector 05</b>			<b>6</b>	
FO-336556	1/11/2016	1/15/2016	1/15/2016	3 cases of dial soap.
FO-336557	1/11/2016	1/15/2016	1/15/2016	3 cases of dial soap.
FO-336558	1/11/2016	1/15/2016	1/15/2016	3 cases of dial soap.
FO-336560	1/11/2016	1/15/2016	1/15/2016	2 cases of dial soap.
FO-336564	1/11/2016	1/15/2016	1/15/2016	Danto - 2 cases of dial soap.
FO-336565	1/11/2016	1/15/2016	1/15/2016	2 boxes of white rags.
<b>C-Sector 06</b>			<b>5</b>	
FO-335934	1/4/2016	1/5/2016		Would like to have the carpet cleaned in room 2233 FAB. The office has just been vacated by the previous department chair and the carpet is pretty dirty. The new department chair will be coming in on Mon. Jan. 11th, therefore we would like the carpet clea
FO-336383	1/7/2016	1/12/2016		The main entry at Cass Ave (east side of bldg.)The inside doorway rug/carpet/runner has raised budes at the edges that trip folk and is in generally bad condition.  (on 1/12/16) Request given to Associate Director David Houle for repairs/ & or replacem
FO-336885	1/13/2016	1/28/2016		clean carpet near doorway of room 114 Cohn
FO-337639	1/21/2016			Custodial Request (High Priority): I am requesting the stripping and waxing of the floor in suite 2209. We also need the 15 large windows cleaned and the entire room needs to be dusted/wiped down, as we have just removed long standing furniture fro
FO-337923	1/26/2016			Floor needs waxing
<b>C-Sector 07</b>			<b>13</b>	
FO-336162	1/5/2016	1/15/2016		The floors in the Elaine L. Jacob Gallery, room 0402 of Old Main, will need to be cleaned and washed. We have a reception Friday, January 15 at 5pm. The floors will need to be cleaned either that Thursday night or Friday morning. Thank you!
FO-336575	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336577	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336578	1/11/2016	1/12/2016		2 cases of dial.
FO-336579	1/11/2016	1/12/2016		2 cases of dial soap.

WO	Recieved	Finished	Total	Request
FO-336580	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336583	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336584	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336585	1/11/2016	1/12/2016		2 cases of dial soap.
FO-336838	1/13/2016			4 boxes of white rags.
FO-336839	1/13/2016			4 cases of gojo soap.
FO-337751	1/25/2016			This room has not received any janitorial services, and is filthy. It is alleged that the room cannot be cleaned because Geology requires that someone be in the room for security purposes. I volunteer to be that person if necessary. I spent Saturday picki
FO-337934	1/26/2016			Purdy Library 1st FloorStaff Men's room: out of paper towel. Please fill dispenser. Thank you.
<b>C-Sector 08</b>			<b>7</b>	
FO-336259	1/6/2016	1/13/2016		2 cases of dial soap.
FO-336260	1/6/2016	1/13/2016		6 cases of dial soap.
FO-336261	1/6/2016	1/13/2016		6 cases of gojo soap.
FO-336269	1/6/2016	1/6/2016		Social Work Building - 3 cases of dial soap.
FO-336406	1/7/2016	1/7/2016		Please vacuum my office.
FO-336899	1/14/2016			Custodian Rhoda Lloyd said that both vacuums in the building are not working so she cannot sweep the floors. Please deliver a working vacuum to the building and take away the two broken ones.
FO-338224	1/27/2016			Grounds floor - mopped and waxed.
<b>C-Sector 09</b>			<b>7</b>	
FO-337017	1/15/2016			2 cases of dial soap.
FO-337018	1/15/2016			2 cases of dial soap.
FO-337019	1/15/2016			2 cases of dial soap.
FO-337020	1/15/2016			2 cases of dial soap.
FO-337022	1/15/2016			2 cases of dial soap.
FO-337025	1/15/2016	1/19/2016		2 cases of dial soap.
FO-337988	1/27/2016			Please repair tile in room 311 in State Hall. It's coming up from the floor.
<b>C-Sector 10</b>			<b>2</b>	
FO-336652	1/11/2016			Repair 3 vacuum cleaners. Not picking up.
FO-338079	1/27/2016			Please deliver to either a janitor's closet in C&IT OR a custodian in C&IT, per David Houle's request: 2 cases of dial 4 cases of gojo Thank you very much for your help!
<b>Pest Controller</b>			<b>17</b>	
FO-335865	1/4/2016	1/6/2016	1/6/2016	PEST CONTROL-PLEASE CHANGE LOADED PEST GLUE TRAPS IN MECH RMS 5 & 1 PRIORITY MED
FO-336120	1/5/2016	12/26/2015	12/26/2015	EXTERMINATION FOR BED BUGS. TREATED ON 12/26/15.
FO-336122	1/5/2016	12/27/2015	12/27/2015	EXTERMINATION FOR BED BUGS. TREATED ON 12/27/15.
FO-336123	1/5/2016	12/28/2015	12/28/2015	EXTERMINATION FOR BED BUGS. BASEMENT. TREATED ON 12/28/15.
FO-336289	1/6/2016	1/12/2016	1/12/2016	Bed bugs were spotted in the lounge 119 on the 1st floor of State Hall.
FO-336291	1/6/2016	1/7/2016	1/7/2016	Roaches were spotted on in the men's & women's restrooms in on the 1st floor and basement areas of Life Science.
FO-336321	1/6/2016	1/22/2016	1/22/2016	EXTERMINATION FOR ROACHES. ROOM 184 AND 1ST FLOOR RECEPTION AREA.
FO-336361	1/7/2016	1/14/2016	1/14/2016	R/R 1ST FLR WOMENS RR HAS AN ANT PROBLEM ALSO critter problem - just last week I saw a WOLF SPIDER with a sack of babies on her back. This morning I saw another WOLF SPIDER (minus babies) in the atrium. A few weeks ago there was a huge cockroach on the
FO-336366	1/7/2016	1/7/2016		Room 251 - Squirrels in the classroom.
FO-336769	1/12/2016	1/14/2016	1/14/2016	MOUSE eating their bag of popcorn rm3301 come after 10am

WO	Recieved	Finished	Total	Request
FO-336793	1/13/2016	1/14/2016	1/14/2016	Flies in Matthaai Concession Area - Please contact Pest Control As soon as possible... Thank You. Bob Ostrowski
FO-336874	1/13/2016	1/27/2016	1/27/2016	Mice problem in gym 110.2. Please contact pest control. Thank You. Bob Ostrowski
FO-337373	1/19/2016	1/22/2016	1/22/2016	There appears to be a mouse problem in room 1305. Mouse droppings are appearing on desks. Please contact Abdel at 734-431-0975 with any questions. Thank you.
FO-337752	1/25/2016	1/26/2016	1/26/2016	Please treat for roach infestation.
FO-337814	1/25/2016	1/26/2016	1/26/2016	EXTERMINATION FOR MICE. (MICE RUNNING AROUND IN OFFICE) ROOM 3008.
FO-338234	1/29/2016			Warren side, rat holes in the flowerbeds.
FO-338239	1/29/2016			Removed dead squirrel.
<b>Engineering</b>			<b>799</b>	
<b>Emergency</b>			<b>29</b>	
<b>E - Auxiliary</b>			<b>1</b>	
FO-336679	1/12/2016	1/12/2016		FIRE ALARM. 9TH FLOOR.
<b>E - Command Center</b>			<b>5</b>	
FO-335833	1/4/2016	1/11/2016		RM 114,116,120, 124, 123 & 136. TOO COLD, HEAT NOT WORKING ROOF TOP UNIT #3 AND #4 WONT START Tony Antoszewski-Contacted Dannon - he indicated the units were buzzing. I asked if he had done the basics, such as check voltage, assure belts were on and tig
FO-336091	1/5/2016		1/5/2016	Building experienced power bump, emergency shut-off to boilers will not reset. Building without heat
FO-336779	1/13/2016	1/14/2016		AIR HANDLER #10 WON'T RUN. PENTHOUSE
FO-337456	1/20/2016	1/20/2016		DOMESTIC HOT WATER HEATER NOT KEEPING TEMPERATURE. ROOM 100.
FO-338196	1/29/2016	1/29/2016		ADJUST EXHAUST FLOW TO SPECTRUM ANALYER. LAB. 30. CONTACT ENGINEER FOR DETAILS.
<b>E - MedPharm</b>			<b>3</b>	
FO-336908	1/14/2016	1/19/2016		ACTIVE FIRE ALARM
FO-337514	1/20/2016	1/21/2016		STRONG GAS SMELL. BASEMENT ROOM 525.
FO-337548	1/21/2016	1/22/2016		BOILER #3 WILL NOT START. TRIPPING ON FLAME FAILURE. ONLY HALF OF THE IGNITOR RING WILL LIGHT. BOILER ROOM.
<b>E - Northeast</b>			<b>3</b>	
FO-336864	1/13/2016	1/13/2016		NO POWER TO BLDG
FO-337435	1/20/2016	1/27/2016		STE 3300 VARIOUS OUTLETS NOT WORKING ALSO STE 3600, PLEASE RESET BREAKER
FO-337747	1/25/2016			2ND FL MRS WILSON'S AREA OUTLETS NOT WORKING, UNABLE TO USE PHONE PLEASE FIX ASAP
<b>E - Preventative Maintenance</b>			<b>6</b>	
FO-337074	1/15/2016	1/15/2016		IN BTWN SKILLMAN/KNAPP IN THE TUNNEL THERE'S AN ELECTRICAL BURNING SMELL
FO-337075	1/15/2016	1/15/2016		IN BTWN SKILLMAN/KNAPP IN THE TUNNEL ALSO LOUD RUNNING WATER NEAR ELEV NEAR THE SEWAGE DRAIN CAP
FO-337377	1/19/2016	1/20/2016		BACK ENTRANCE RECEIVING RM DOOR HANDLE FELL OFF UNABLE TO SECURE BLDG
FO-337704	1/22/2016	1/29/2016		GAS SMELL IN ROOM 200.
FO-337827	1/25/2016	1/26/2016		ACTIVE FIRE ALARM
FO-338155	1/28/2016	1/29/2016		GAS SMELL NEAR DELILAH's CAFE
<b>E - South</b>			<b>4</b>	
FO-335843	1/4/2016	1/4/2016		SAYS THAT THEY HAD A POWER BUMP & NOW THE FAP ALARM IS ACTIVE
FO-336464	1/8/2016	1/11/2016		FRONT OFFICES LOSS POWER
FO-338001	1/27/2016	1/29/2016		1ST FLR NEAR DELILAH RESTRAUNT SMELL NAT GAS
FO-338178	1/29/2016	1/29/2016		GAS SMELL. 1ST FLOOR LOADING DOCK AND STUDENT LOUNGE AREAS.



WO	Recieved	Finished	Total	Request
<b>E - Southeast</b>			<b>6</b>	
FO-335833	1/4/2016	1/11/2016		RM 114,116,120, 124, 123 & 136. TOO COLD, HEAT NOT WORKING ROOF TOP UNIT #3 AND #4 WONT START Tony Antoszewski-Contacted Dannon - he indicated the units were buzzing. I asked if he had done the basics, such as check voltage, assure belts were on and tig
FO-336720	1/12/2016	1/14/2016		RM 114,116,120, 124, 123 & 136. TOO COLD, HEAT NOT WORKING ROOF TOP UNIT #3 AND #4 WONT START Tony Antoszewski-Contacted Dannon - he indicated the units were buzzing. I asked if he had done the basics, such as check voltage, assure belts were on and tig
FO-336720	1/12/2016	1/14/2016		RM 114,116,120, 124, 123 & 136. TOO COLD, HEAT NOT WORKING ROOF TOP UNIT #3 AND #4 WONT START Tony Antoszewski-Contacted Dannon - he indicated the units were buzzing. I asked if he had done the basics, such as check voltage, assure belts were on and tig
FO-336785	1/13/2016	1/13/2016		4TH FL SAR RM 422 LOST POWER TO OUTLETS
FO-337603	1/21/2016	1/21/2016		VERY LOUD GAS SMELL IN FRONT OF ROOM 7908.
FO-337761	1/25/2016	1/25/2016		3RD FL SMELLS SMOKE
<b>E - West</b>			<b>1</b>	
FO-338014	1/27/2016	1/27/2016		BLDG ALL THE FANS STOPPED WORKING
<b>High</b>			<b>371</b>	
<b>E - Auxiliary</b>			<b>34</b>	
FO-335801	1/4/2016			WATER LEAK COMING FROM THE CHILD DEVELOPMENT BUILDING.
FO-335848	1/4/2016	1/4/2016		SAYS THAT THEY HAD A POWER BUMP & NOW FIRE TROUBLE ALARM
H-56497	1/5/2016			Heating authenticated user: Christopher Shah - fs2253 requester ip address: 141.217.228.232
FO-336135	1/5/2016	1/5/2016		APT 207 TOO COLD
FO-336187	1/5/2016	1/5/2016		FAP IS BEEPING IN ALARM
H-56533	1/5/2016			water leak in kitchen sink and bathroom shower.Also, kitchen sink floods when used.Shower is hard to adjust either water cold or very hot.authenticated user: Afnan Abduljaber - ft6597requester ip address: 35.16.79.81
H-56530	1/6/2016			Kitchen Sink is leaking. The leak almost over flowed the sink.authenticated user: Deja Moore-Grant - eo2406requester ip address: 35.16.71.103
H-56537	1/6/2016			Bedroom heat is low-- room remains very cold despite engineers fixing heat issue from 2 days agoauthenticated user: Elijah Baker - fh0812requester ip address: 141.217.23.173
H-56548	1/6/2016			Some heating radiators throughout the apartment are not functioning properly.authenticated user: Jaipal Singh - ez1536requester ip address: 141.217.232.175
H-56545	1/6/2016			The heat in room 709 is not workingauthenticated user: Ni'Esha Wright - fh3756requester ip address: 141.217.23.173
H-56569	1/7/2016			There is no heat coming from the heaters in the bathroom and the bedroom. Resident is unable to turn the knob to turn the heaters on or off in order to adjust them. authenticated user: Najamah Allah - ej2633requester ip address: 141.217.23.175
H-56573	1/7/2016			Toilet Leaking at Bottomauthenticated user: Rijil John - fx3166requester ip address: 141.217.23.173
H-56585	1/9/2016			The thermostat is not working properly. authenticated user: Jaquan Frierson - fv8261 requester ip address: 35.16.110.219
H-56586	1/10/2016			Leaky shower head is causing mold in the shower, also the drain in the shower constantly gets clogged. authenticated user: Michael Marion - fv4596 requester ip address: 35.16.98.153
H-56600	1/11/2016			Kitchen sink pipe leaking very severely. Pipe underneath SINK NOT VACUUM PLEASE.authenticated user: Allison Zhang - ed4262requester ip address: 146.9.59.15
H-56640	1/11/2016			Faucet in the bath tub keeps running. It does not shut off. authenticated user: Amari McGee - ev1977requester ip address: 35.16.77.179
H-56627	1/11/2016			Our furnace/thermostat is not working, when the thermostat is set to heat only cool air comes out. authenticated user: Lindsey Wortley - fo8919 requester ip address: 35.16.96.194
FO-336845	1/13/2016			APT 203 NO HEAT

WO	Recieved	Finished	Total	Request
H-56746	1/15/2016			The sink is leaking below for about a month. I put a bowl below is so that leaking water drops there. When he fixed the draining problem 3 days ago, he said I also need to do a service request for an engineer to fix it.authenticated user: Mehmet Ondur
FO-337076	1/15/2016			FAP FIRE TROUBLE ALRM
H-56777	1/18/2016			The outlet to the left of the window in my living room broke. When I removed a plug from it, sparks flew and the circuit breaker broke. I tried to reset the circuit in the hallway, but if flips back to off. Could you fix my outlet and the circuit breaker.
H-56794	1/19/2016			AC/ heater isn't working authenticated user: Marina Mikhail - fv2548 requester ip address: 141.217.230.173
H-56778	1/19/2016			The heating system is not working properly in my apartment. It is freezing. Please, take care of it ASAP. Thank you.authenticated user: Mardheya Alsamadani - ft7392requester ip address: 141.217.232.211
H-56826	1/20/2016			Heater is malfunctioning, blowing out cool and warm air when turned to high heat settings authenticated user: Dijon Williams - fk3806 requester ip address: 35.16.99.243
H-56827	1/20/2016			heat blowing out cold air authenticated user: Rheana Allen - fh1699 requester ip address: 35.16.108.210
H-56870	1/21/2016			Heaters not working properlyauthenticated user: Rushabh Vasani - fx9797requester ip address: 141.217.233.26
H-56882	1/21/2016			There is a leak in the bath tub. Please be kind enough to repair it ASAP. Thank youauthenticated user: Madusha Lakshani Watuthanthrige Perera - fp1089requester ip address: 141.217.232.171
H-56921	1/22/2016	1/27/2016		I think there is a leak in the radiator in my bedroom, or in the plumbing that is in the wall between my bathroom and bedroom. Either way, the carpet in the corner is soaked and I'm worried there could be mold underneath it. authenticated user: Robert M
H-56922	1/23/2016	1/25/2016		Kitchen sink is draining very slowly. Has been having problems with it since 1/22/16. Water drains out after about 2 hours. authenticated user: Vivien Okechukwu - fh2758 requester ip address: 141.217.23.175
FO-337756	1/25/2016			APT 805 RADIATOR LEAKING
FO-337997	1/27/2016			RM 00129 FAP FIRE TROUBLE ALARM
H-56998	1/27/2016	1/29/2016		The water in the bathtub does not stop running. authenticated user: Nour Arafat - ez0913 requester ip address: 35.16.65.118
H-56999	1/28/2016	1/29/2016		Constant sparking noise from the AC vent authenticated user: Naman Chopra - fq7231 requester ip address: 35.16.69.160
H-57000	1/28/2016	1/29/2016		The faucet in the bathroom tub will not stop dripping water even after it is turned off. authenticated user: Ni'Esha Wright - fh3756 requester ip address: 141.217.23.173
<b>E - Command Center</b>			<b>18</b>	
FO-335815	1/4/2016	1/12/2016		Trade: Refer Crew Priority: High Tag#090-RAD-541 R/R RM 4505/MECH RM Refrigerated air dryer is not working please repair. Dryer is located in the EDC penthouse mechanical room.
FO-336147	1/4/2016		1/7/2016	Boiler 1 still having problems after power bump.
FO-335864	1/4/2016		1/11/2016	Feedwater pump on boiler # 2 not working
FO-336138	1/5/2016		1/5/2016	Repair #1 boiler is dead. No power to controls. #2 is on line.
FO-336194	1/5/2016	1/6/2016		CONTROLS R/R RM 4616 TROUBLESHOOT SYSTEM ENG KEEPS CKNG SYSTEM HOWEVER OCCUPANT KEEPS COMPLAINING TOO COLD
FO-336416	1/7/2016	1/22/2016		Trade: Command Center Priority: High R/R RM 00018/MECH RM Please provide one pneumatic averaging air temperature sensor for the DA on AHU #1. Range is 35 to 135 degf. Siemans product number: 184-0004.
FO-336456	1/8/2016			AC Shop: High; Heat pumps not working in Lobby Area. Please repair as necessary.
FO-336749	1/12/2016			check test calibrate hot deck control not working in auto sf1 on 2nd floor comp center BY pass open

WO	Recieved	Finished	Total	Request
FO-336826	1/13/2016		1/15/2016	pls repair the mod motor linkage on boiler 2 a spring has broken
FO-336950	1/14/2016			HVAC unit for Peacock room located in the basement needs repair. The heating valve is not opening.
FO-337513	1/20/2016			AC Shop-please replace 5 ton vertical Heat Pump in Lobby. Lobby Very cold.Trane brand preferred. High Priority
FO-337542	1/21/2016	1/21/2016		controls- high priority- Office space and hallway areas on third floor are running too hot. Many spaces are 90 degrees and the hallway is 80 degrees. All fans in operation and showing reasonable hot deck/ Cold deck temperatures. Thermostat for room 313 no
FO-337727	1/25/2016	1/28/2016		Repair or replace actuators/pilot positioners on HV1
FO-337728	1/25/2016	1/28/2016		Repair or replace actuators/pilot positioners on HV2
FO-338033	1/27/2016			The Honeywell controller for room 3333 needs to be replaced. See engineer Dan K. for location. He put his aspirator on 3 way to open manually to get some heat to the areas effected.
FO-338097	1/28/2016			Refg. crew: Please repair vav-04 controller for suite 1215. Wall stat in room1207 is set to 75 degrees but room temperature is 65. Placing Honeywell computer set-point to 75 does nothing to raise temperature. High Priority.
FO-338120	1/28/2016			Repair or replace pilot positioner on HV2.  Vortex Dampers now working via Siemens. Graphics have been updated.  The pilot positioner on this unit is not working. Pneumatic ctrl signal is currently bypassing pilot positioner.  Please repair/repl
FO-338194	1/29/2016			Refg. Crew:Room 1201 inside suite 1215 wall stat is set for 75 degrees. Honeywell computer shows room set-point is 76 degrees. However, actual room temperature is 63 degrees. Please repair vav box #05 to control proper room temperature. High Priority
<b>E - MedPharm</b>			<b>92</b>	
FO-335803	1/4/2016	1/4/2016		Low humidity
FO-335823	1/4/2016	1/4/2016		RM 221 IS TOO COLD
FO-335867	1/4/2016	1/4/2016		CEILING VENT IS OPEN. ROOM 0514.
FO-335905	1/4/2016	1/4/2016		RM 411/DLAR HAS LOW HUMIDITY
FO-336103	1/5/2016	1/6/2016		AIR FLOW IS POSITIVE AND SHOULD BE NEGATIVE, ROOMS 0225, 0507, 0510, 0513, 0514, 0522 & 0501.
FO-336113	1/5/2016	1/5/2016		AUTOCCLAVE IS NOT WORKING. ROOM 0305.
FO-336143	1/5/2016	1/5/2016		RM 1320 IS TOO COLD
FO-336144	1/5/2016	1/5/2016		RM 0217 NO STEAM TO AUTO CLAVES
FO-336146	1/5/2016	1/5/2016		RM 9272 IS TOO COLD
FO-336155	1/5/2016	1/5/2016		RM 2238 TOO COLD
FO-336253	1/6/2016	1/7/2016		LOW HUMIDITY. ROOM 200.06.
FO-336275	1/6/2016	1/6/2016		RM 1209 FAN RUNNING TOO HIGH AND STRONG, RM TOO COLD FOR RATS
FO-336304	1/6/2016	1/7/2016		FIRE ALARM IS SOUNDING.
FO-336378	1/7/2016	1/12/2016		RM 2205 IS TOO COLD
FO-336419	1/7/2016	1/7/2016		RM 1230 IS TOO COLD (scheduling for Friday morn per Bldg Eng)
FO-336434	1/8/2016	1/8/2016		CEILING HUMIDIFIER LEAK. ROOM 5449.
FO-336445	1/8/2016	1/13/2016		9TH FLOOR COLD ROOM IS NOT COOLING.
FO-336454	1/8/2016	1/8/2016		RM 7341 WATERLINE BLEW
FO-336541	1/11/2016	1/12/2016		ROOMS 0225, 0513, 0514 & 0522 ARE READING POSITIVE - THEY SHOULD BE NEGATIVE.
FO-336600	1/11/2016	1/11/2016		Office is very cold
FO-336609	1/11/2016	1/11/2016		ALL ANIMAL RM'S TOO HOT
FO-336704	1/12/2016	1/12/2016		HIGH TEMP. ROOM 0243.

WO	Recieved	Finished	Total	Request
FO-336711	1/12/2016	1/12/2016		RM 00032 THERE WAS A LOUD BANG & LIGHTS FLICKER ON/OFF PLS CK & ADVISE
FO-336724	1/12/2016	1/12/2016		INSIDE STE 206 - RM 207 IS TOO COLD
FO-336773	1/13/2016	1/13/2016		WATER LEAK. ROOM 7341.
FO-336799	1/13/2016	1/13/2016		RM 310 IS TOO HOT
FO-336841	1/13/2016	1/13/2016		RM 5351 LOW HUMIDITY
FO-336842	1/13/2016	1/13/2016		HALLWAY NEAR 5520/5530 TOO COLD
FO-336849	1/13/2016	1/19/2016		RM 310,320,330,340 TOO COLD
FO-336906	1/14/2016	1/19/2016		FIRE ALARM.
FO-336919	1/14/2016	1/14/2016		RM 324 TOO HOT
FO-336939	1/14/2016	1/14/2016		COLD RM 5332 HIGH TEMP
FO-336949	1/14/2016	1/14/2016		POSSIBLE POWER BUMP, EVERYTHING RESET
FO-336989	1/15/2016	1/15/2016		RM 00414/DLAR HI TEMP
FO-336991	1/15/2016	1/25/2016		RUNNING WATER SOUND IN CEILING. ROOM 2375.
FO-337037	1/15/2016	1/15/2016		COLD ROOM IS WARM. ROOM 3210.
FO-337277	1/19/2016	1/23/2016		TOO COLD. ROOM 416.
FO-337278	1/19/2016	1/19/2016		ROOMS ARE POSITIVE AND THEY SHOULD BE NEGATIVE. ROOMS 0225, 0513, 0514, 0522 & 0501.
FO-337302	1/19/2016	1/19/2016		ANIMAL RM 243 TOO HOT, DOGS WITHIN RM
FO-337320	1/19/2016	1/19/2016		RM 5451 TOO COLD
FO-337322	1/19/2016	1/19/2016		RM 5449, 5451, 5455 LOW HUMIDITY
FO-337324	1/19/2016	1/19/2016		RM 5351 LOW HUMIDITY
FO-337326	1/19/2016	1/23/2016		RESET TRASH COMPACTOR CIRCUIT.
FO-337342	1/19/2016	1/19/2016		RM 315 TOO HOT
FO-337349	1/19/2016	1/19/2016		LOBBY CONTROL PANEL (FAP) IS BEEPING
FO-337350	1/19/2016	1/19/2016		DOCK AREA NEED TO RESET TRASH COMPACTOR CIRCUIT AGAIN
FO-337359	1/19/2016	1/19/2016		RM 411 HAS LOW HUMIDITY
FO-337395	1/20/2016	1/20/2016		Day Engineer - hi priority- diagnose and repair domestic hot water heater discharging hot water from solenoid. High temperature relief?
FO-337411	1/20/2016	1/20/2016		red light on showing low humidity
FO-337412	1/20/2016	1/20/2016		red light on showing low humidity
FO-337413	1/20/2016	1/20/2016		red light showing low humidity
FO-337418	1/20/2016	1/23/2016		NO HOT WATER IN SHOWERS IN BASEMENT.
FO-337423	1/20/2016	1/20/2016		Low temp and very cold in room
FO-337447	1/20/2016	1/20/2016		In the basement room 229 has a low humidity of 28 % it should be at least 30 % or above.
FO-337452	1/20/2016	1/20/2016		RM 310 TOO HOT
FO-337471	1/20/2016	1/20/2016		RM 411 LOW HUMIDITY 3RD REQUEST
FO-337493	1/20/2016	1/20/2016		LOW TEMP. ALARM. ROOM 216.2.
FO-337499	1/20/2016	1/27/2016		CEILING LEAK. SOUTH CORNER OF ROOM 3375.
FO-337555	1/21/2016	1/21/2016		5550 AIR FLOW SHOULD BE POSITIVE, CURRENTLY NEGATIVE SEE ANDREA
FO-337576	1/21/2016	1/23/2016		INSIDE DOOR NOT CLOSING. ELEVATOR IN KITCHEN.
FO-337614	1/21/2016	1/21/2016		RM 6238 HIGH TEMP ALARM
FO-337666	1/22/2016	1/22/2016		RM 414 HIGH TEMP
FO-337667	1/22/2016	1/22/2016		RM 412 LOW HUMIDITY
FO-337669	1/22/2016	1/22/2016		The heater on the dock does not appear to be working which is making the hallways/offices near it cold.
FO-337668	1/22/2016	1/22/2016		RM 200.06 LOW HUMIDITY
FO-337671	1/22/2016	1/22/2016		RM 0229 CHECK AIR PRESSURE
FO-337672	1/22/2016	1/22/2016		RM 2268 TOO COLD

WO	Recieved	Finished	Total	Request
FO-337681	1/22/2016	1/25/2016		RM 9133 HAS A VERY LOUD NOISE COMING FROM AIR VENTS
FO-337682	1/22/2016	1/22/2016		RM 9135 HAS A VERY LOUD NOISE COMING FROM AIR VENTS
FO-337695	1/22/2016	1/22/2016		BLDG VARIOUS AREAS HAVE NO HOT WATER & THE WATER IS COMING OUT ICE COLD
FO-337738	1/25/2016	1/25/2016		RM 8337 HIGH TEMP
FO-337748	1/25/2016	1/25/2016		RM 00222/DLAR AIR PRESSURE IS SHOWING POSITIVE WHEN IT SHOULD READ NEGATIVE
FO-337749	1/25/2016	1/25/2016		RM 00225/DLAR AIR PRESSURE IS SHOWING POSITIVE WHEN IT SHOULD READ NEGATIVE
FO-337750	1/25/2016	1/25/2016		RM 00514/DLAR AIR PRESSURE IS SHOWING POSITIVE WHEN IT SHOULD READ NEGATIVE
FO-337753	1/25/2016	1/27/2016		FIRE TROUBLE ALARM.
FO-337759	1/25/2016	1/25/2016		TOO HOT. ROOM 100.
FO-337777	1/25/2016	1/27/2016		FIRE ALARM SOUNDING.
FO-337806	1/25/2016	1/25/2016		RM 8337 WALK IN COLD RM BOX HAS A HI TEMP ALARM
FO-337807	1/25/2016	1/25/2016		RM 3130 IS TOO HOT
FO-338011	1/27/2016	1/27/2016		RM 322.3 NEED BREAKER RESET (note/per requestor error may be in above rm correction made)
FO-338012	1/27/2016	1/27/2016		RM 322.4 NEED BREAKER RESET (note/per requestor error may be in above rm correction made)
FO-338013	1/27/2016	1/27/2016		RM 322.6 NEED BREAKER RESET (note/per requestor error may be in above rm correction made)
FO-338045	1/27/2016	1/27/2016		FUME HOOD ALARM. ROOM 317.
FO-338057	1/27/2016	1/27/2016		RM 412 HAS LOW HUMIDITY
FO-338066	1/27/2016	1/27/2016		RM 200.06 HAS LOW HUMIDITY
FO-338180	1/28/2016	1/28/2016		LOW HUMIDITY. ROOM 412.
FO-338140	1/28/2016	1/28/2016		LOW TEMP. ALARM. ROOM AF12.
FO-338174	1/29/2016	1/29/2016		WATER HAMMERING VIBRATING SOUND COMING FROM CEILING. ROOM 410.
FO-338186	1/29/2016	1/29/2016		HIGH TEMPS. ROOMS 414 AND 200.13.
FO-338190	1/29/2016	1/29/2016		RM 0229 LOW TEMP ALARM
FO-338216	1/29/2016	1/29/2016		RM 2602.1 TOO COLD
FO-338226	1/29/2016	1/29/2016		RM 411 LOW HUMIDITY
<b>E - North</b>			<b>39</b>	
FO-335816	1/4/2016	1/4/2016		TOO COLD. ROOM 3198.
FO-335817	1/4/2016	1/4/2016		RM 1183 IS TOO COLD
FO-335820	1/4/2016	1/4/2016		RM 2226 TOO COLD
FO-335822	1/4/2016	1/4/2016		1276/1279 TOO COLD
FO-335825	1/4/2016	1/4/2016		BEEPING NOISE COMING FROM 4TH FLOOR COMPUTER ROOM CLOSET. NEAR ROOM 4092.
FO-335828	1/4/2016	1/4/2016		FIRE ALARM.
FO-335842	1/4/2016	1/4/2016		ENG NEEDED AT CIRCULATION DESK TO ASSIST C&IT
FO-335847	1/4/2016	1/4/2016		SAYS THAT THEY HAD A POWER BUMP & NOW FIRE TROUBLE ALARM
FO-335849	1/4/2016	1/4/2016		POWER FAILURE ALARM
FO-335863	1/4/2016	1/4/2016		My office is very cold. My hands are hurting from the cold which makes typing difficult. Could you please turn up the temperature?
FO-335860	1/4/2016	1/4/2016		RM 241 NEED BREAKER RESET/LOST POWER IN OUTLETS
FO-335861	1/4/2016	1/4/2016		RM 243 NEED BREAKER RESET/LOST POWER IN OUTLETS
FO-335862	1/4/2016	1/4/2016		RM 245 NEED BREAKER RESET/LOST POWER IN OUTLETS
FO-335878	1/4/2016	1/4/2016		RM 117 TOO WARM
FO-336250	1/6/2016	1/6/2016		WALL OUTLETS ARE NOT WORKING. ROOMS 4129 AND 4127.
FO-336356	1/7/2016	1/7/2016		RM 4143 BLOWER TOO LOUD

WO	Recieved	Finished	Total	Request
FO-336372	1/7/2016	1/8/2016		BSMNT COOK LINE ALL LIGHTS WENT OUT, POSSIBLE CIRCUIT ISSUE
FO-336488	1/8/2016	1/8/2016		RM 4129 OUTLETS NOT WORKING
FO-336591	1/11/2016	1/11/2016		RM 4092 TOO COLD
FO-336619	1/11/2016	1/11/2016		RM 4339 IS TOO COLD
FO-336689	1/12/2016	1/13/2016		RM 106 IS TOO HOT
FO-336873	1/13/2016	1/13/2016		RM 134 IS TOO HOT
FO-336893	1/14/2016	1/14/2016		RM 134 IS TOO HOT
FO-337057	1/15/2016	1/15/2016		Once again the heat on the 4th floor in my area is out of control - right now it's 78.3 degrees in my office which is a waste of \$\$\$ for WSU to keep a building heated this high. The last time I submitted the request I believe you ended up turning off the
FO-337325	1/19/2016	1/19/2016		RM 2077 TOO COLD
FO-337429	1/20/2016	1/20/2016		RM 1309 TOO COLD, TEMP IS BELOW 60. PLEASE CONSIDER AN EMERGENCY PER LERONIA
FO-337430	1/20/2016	1/20/2016		ALL STUDY LABS ARE EXTREMELY COLD, STUDENTS ARE VERY CONCERNED WITH LOW TEMPS
FO-337562	1/21/2016	1/21/2016		BLDG TOO HOT
FO-337735	1/25/2016	1/25/2016		FAINT SEWAR SMELL. BASEMENT.
FO-337754	1/25/2016	1/25/2016		Reports of leaves and bird feathers coming from the vents in this classroom. Please inspect.
FO-337783	1/25/2016	1/26/2016		RM 134 TOO HOT
FO-337800	1/25/2016	1/25/2016		RM 2153 NEED BREAKER RESET
FO-337801	1/25/2016	1/25/2016		RM 2157 NEED BREAKER RESET
FO-337803	1/25/2016	1/25/2016		RM 4020 NEED BREAKER RESET
FO-337912	1/26/2016	1/26/2016		WALL OUTLETS ARE NOT WORKING. ROOMS 391 AND 393.
FO-338193	1/29/2016			317 TOO COLD
FO-338195	1/29/2016	1/29/2016		1ST FL FIRE ALARM PANEL SOUNDING
FO-338214	1/29/2016	1/29/2016		TOO COOL. ROOM J.
FO-338229	1/29/2016			BSMNT AND 1ST FL COLD AIR BLOWING FROM VENTS, PLEASE CHECK TEMP
<b>E - Northeast</b>			<b>42</b>	
FO-335836	1/4/2016	1/4/2016		1ST FLR STAFF LOUNGE NEED BREAKER RESET
FO-335854	1/4/2016	1/4/2016		Dawn Aziz needs help with an electrical outlet in her office that doesn't appear to be working. When things are plugged in, they don't get a charge.
FO-335850	1/4/2016	1/4/2016		COLD RM HAS LOW TEMP ALARM
FO-335873	1/4/2016	1/27/2016		SUB BSMT IS EXTREMELY COLD APPROX. 60degrees
FO-335875	1/4/2016	1/27/2016		RM 113 IS EXTREMELY COLD APPROX. 60degrees
FO-335906	1/4/2016	1/27/2016		1ST FLR IS STILL IS EXTREMELY COLD APPROX. 60degrees
FO-336117	1/5/2016	1/5/2016		RM 4616 IS TOO COLD
FO-336118	1/5/2016	1/5/2016		RM 4618 IS TOO COLD
FO-336121	1/5/2016	1/27/2016		BSMT IS STILL EXTREMELY COLD APPROX. 60degrees
FO-336125	1/5/2016	1/27/2016		RM 113 IS STILL EXTREMELY COLD APPROX. 60degrees
FO-336129	1/5/2016	1/27/2016		1ST FLR IS STILL EXTREMELY COLD APPROX. 60degrees
FO-336136	1/5/2016	1/5/2016		2 WALL OUTLETS ARE NOT WORKING. ROOM 3324 (INSIDE OF SUITE 3300)
FO-336158	1/5/2016	1/5/2016		BLDG IS TOO COLD
FO-336166	1/5/2016	1/5/2016		ALL LIGHTS ARE OUT POSSIBLE CIRCUIT NEEDS RESETTNG
FO-336173	1/5/2016	1/5/2016		296 & 296.1 TOO COLD
FO-336364	1/7/2016	1/7/2016		RM 3100/LOUNGE HAS NO POWER IN OUTLETS & LIGHTS
FO-336369	1/7/2016	1/7/2016		3RD FLR MENS RM NEAR LABOR RELATIONS (SOUTH SIDE HAS CLNG LEAK FROM PIPE?)
FO-336402	1/7/2016	1/7/2016		1ST FLR UNISEX RR HAS NO HOT WATER
FO-336404	1/7/2016	1/7/2016		2ND FLR UNISEX RR HAS NO HOT WATER

WO	Recieved	Finished	Total	Request
FO-336549	1/11/2016	1/11/2016		FRONT ENTRANCE SLIDING DOOR NOT WORKING, DOOR DOESNT SLIDE OPEN
FO-336581	1/11/2016	1/11/2016		DESIGN SERVICE SANDY YARRINGTONS AREA TOO HOT
FO-336602	1/11/2016	1/11/2016		1ST FL TOO COLD
FO-336625	1/11/2016	1/11/2016		RM 236 IS TOO COLD
FO-336627	1/11/2016	1/11/2016		RM 313 IS TOO COLD
FO-336722	1/12/2016	1/12/2016		RM 214 BODY COOLER IS IN LOW TEMP ALARM
FO-336844	1/13/2016	1/13/2016		#1 ELEVATOR INSIDE 2ND FLOOR CALL BUTTON PERIODICALLY IS NOT LIGHTING UP. PLEASE CHECK.
FO-336846	1/13/2016	1/14/2016		LOW TEMP. ALARM. ROOM 214.
FO-336867	1/13/2016	1/13/2016		RM 100 WINDOW HVAC IS BLOWING OUT COLD AIR ONLY
FO-336920	1/14/2016	12/21/2015		DIANE'S OFFICE IS TOO WARM. WOULD LIKE TEMP BETWEEN 68-70 DEGREES
FO-336938	1/14/2016	1/14/2016		LOW TEMP. ALARM. ROOM 214.
FO-337304	1/19/2016	1/27/2016		3RD FL POSSIBLY RM 303, OUTLETS NOT WORKING
FO-337333	1/19/2016	1/19/2016		COOLER RM 214 LOW TEMP
FO-337351	1/19/2016	1/19/2016		ENTIRE 2ND FLR IS TOO COLD NO HEAT
FO-337472	1/20/2016	1/20/2016		1ST FL TOO HOT
FO-337477	1/20/2016	1/20/2016		RM 214 LOW TEMP ALARM
FO-337564	1/21/2016	1/21/2016		Electrical outlet in room 1218 in the clinic is not functioning
FO-337636	1/21/2016	1/25/2016		Please check the window AC unit due to not blowing cold air...
FO-337960	1/26/2016	1/26/2016		2ND FLR HALLWAY & RM 239 HAS A BURNING SMELL
FO-338032	1/27/2016	1/29/2016		1ST FLR IS TOO HOT
FO-338038	1/27/2016			RM 214 BODY COOLER LOW TEMP ALARM
FO-338139	1/28/2016			BLOWN FUSE. ROOM 405.
FO-338217	1/29/2016			214 LOW TEMP ALARM
<b>E - Preventative Maintenance</b>			<b>62</b>	
FO-335920	1/4/2016	1/5/2016		BSMNT HALLWAY OUTSIDE RM 32 ACTIVE CEILING LEAK
FO-335922	1/4/2016			CEILING LEAK. ROOM 2001.
FO-335923	1/4/2016	1/5/2016		RM 2212 NO HEAT ALSO OUTLETS NEAR DOOR NOT WORKING
FO-335924	1/4/2016	1/8/2016		MAIN PLAYING AREA (TENNIS COURT AREA) TOO COLD
FO-335928	1/4/2016	1/29/2016		4092 OUTLETS NOT WORKING
FO-335932	1/4/2016			RM 207 AND OTHER 2ND & 3RD FL RESIDENTS HAVE COMPLAINED TEMP IS TOO COLD
FO-336131	1/5/2016	1/5/2016		RM 4092 BLEW CIRCUIT AGAIN 1/4/15 NEED BREAKER RESET
FO-336209	1/5/2016	1/6/2016		RM 5018 TOO COLD
FO-336320	1/6/2016	1/7/2016		RM 2109-2117 TOO COLD
FO-336329	1/6/2016	1/7/2016		2ND FL CONFERENCE RM TOO COLD
FO-336637	1/11/2016			VERY COLD ON THE 7TH FLOOR. STATES IT COULD BE DUE TO A VERY LOUD NOISE ON ROOF YESTERDAY. SOUND LIKE SOMETHING FELL OVER.
FO-336641	1/11/2016	1/12/2016		LOW TEMP. ALARM. ROOM 214.
FO-336642	1/11/2016	1/12/2016		1ST FLR IS TOO COLD
FO-336649	1/11/2016	1/12/2016		RM 3324 OUTLET NOT WORKING
FO-336762	1/12/2016	1/13/2016		RM 1209 IS TOO COLD
FO-336763	1/12/2016	1/29/2016		CK BONSTELLE SOMEWHERE THERE'S NO POWEER
FO-336764	1/12/2016	1/13/2016		CANCEL CALL FOR RESETTING BREAKER @ RM 031
FO-336879	1/13/2016	1/14/2016		3RD FL NEAR 3638, MENS RM LIGHTS NOT WORKING
FO-336968	1/14/2016	1/15/2016		RM 206 TOO HOT
FO-336970	1/14/2016	1/15/2016		The knob on the radiator is broken. The valve may also may need repair. There is no temperature control in that room. Thanks

WO	Recieved	Finished	Total	Request
FO-336977	1/14/2016	1/15/2016		COLD RM 3210 IS NOT COLD ENOUGH. PLEASE CHECK TEMP
FO-337070	1/15/2016	1/16/2016		INSIDE STE 6000 RMS 6402.3, 6402.4, 6402.5, 6402.6, 6402.11, 6402.12 ARE TOO COLD
FO-337071	1/15/2016	1/16/2016		RM 6238 HIGH TEMP ALARM
FO-337082	1/15/2016	1/16/2016		RM 163 KEY STUCK IN LOCK
FO-337083	1/15/2016	1/16/2016		RM 100 TOO HOT
FO-337365	1/19/2016	1/20/2016		6305.2 & 6305.3 OUTLETS NOT WORKING, RESET BREAKER
FO-337370	1/19/2016	1/19/2016		2ND FLR IS TOO HOT
FO-337371	1/19/2016	1/20/2016		3RD FLR FANS HAVE STOPPED RUNNING
FO-337372	1/19/2016	1/20/2016		4TH FLR FANS HAVE STOPPED RUNNING
FO-337375	1/19/2016	1/20/2016		RM 10 IS TOO COLD
FO-337376	1/19/2016	1/20/2016		RM 102.7 OUTLETS NOT WORKING
FO-337378	1/19/2016	1/20/2016		MAIN FL SOUTH END OF BLDG COLD AIR BLOWING FROM VENTS
FO-337379	1/19/2016	1/20/2016		ALARM SOUNDING IN ATRIUM
FO-337520	1/20/2016	1/21/2016		FIRE TROUBLE ALARM
FO-337529	1/20/2016	1/21/2016		Rooms 109 and 111 get cold in the afternoon. The radiators seem to be getting no heat in the afternoon. Please investigate and resolve problem. Staff get very cold in the afternoon.
FO-337521	1/20/2016	1/21/2016		RM 113 LIGHT COVER IS HANGING, BULB AND WIRES EXPOSED
FO-337524	1/20/2016	1/21/2016		CEILING LEAK. HALLWAY OUTSIDE OF ROOM 271. MEZZANINE.
FO-337525	1/20/2016	1/21/2016		STE 100 WINDOW HEATING UNIT NOT WORKING PLEASE UPDATE IAN 248-320-0351
FO-337526	1/20/2016	1/20/2016		STE 100 LOUD SCREECHING NOISE
FO-337531	1/20/2016			4TH FL CENTER WING RIGHT SIDE RADIATORS LEAKING
FO-337620	1/21/2016	1/21/2016		The outlet on the West wall of Room 1119 FAB is out.
FO-337621	1/21/2016	1/22/2016		VERY HOT. ITALIAN ROOM.
FO-337630	1/21/2016	1/21/2016		BSMNT RM 30 AND RM 425 TOO HOT
FO-337637	1/21/2016	1/21/2016		High Priority Request: Rooms 1515, 1525, and 1550 are unbearably hot. Please adjust the temperature.
FO-337631	1/21/2016	1/22/2016		RM 3107 HEAT NOT WORKING PLEASE ADJUST TEMP MODELS ARE COLD
FO-337632	1/21/2016			JASON/EXPERT SERVICES NEEDS ACCESS 2ND FL HALLWAY
FO-337703	1/22/2016	1/22/2016		LOW TEMP. ALARM. ROOM 214.
FO-337708	1/22/2016	1/23/2016		RM 315 LIGHTS AND OUTLETS WENT OUT
FO-337709	1/22/2016	1/30/2016		RM 150 PLEASE LEAVE HEAT ON OVER THE WEEKEND EVENT ON SAT
FO-337818	1/25/2016	1/25/2016		RM 149 & 441 TOO COLD
FO-337824	1/25/2016	1/26/2016		SOUTH SIDE ENTRANCE, BROWN BOX KEY NOT WORKING
FO-337974	1/26/2016	1/27/2016		TOO HOT. SUITE 206 OFFICE 209.
FO-337982	1/26/2016	1/27/2016		RM 315 IS TOO HOT
FO-338070	1/27/2016	1/27/2016		RM 405 NEED BREAKE RESET
FO-338077	1/27/2016	1/27/2016		CEILING LEAK. ROOM 1215. NEAR COPIER MACHINE.
FO-338078	1/27/2016	1/30/2016		SWIMMING POOL IS LOOSING WATER.
FO-338080	1/27/2016	1/27/2016		To check outlets in wall. Outlets are not receiving power
FO-338083	1/27/2016	1/27/2016		To check outlets in wall. Outlets are not receiving power.
FO-338242	1/29/2016	1/29/2016		There is a leaking copper pipe in the alcove off of Corridor X0162. It appears to be an incorrectly sealed connection to the hose connected to the water heater flue above. I have images taken at the site if needed.
FO-338235	1/29/2016	1/30/2016		LOUNGE AREA EXPOSED WIRING ON THERMOSTAT
FO-338254	1/29/2016	1/29/2016		High Priority: Fuse blown in suite 1215, power out at some computer terminals. Please reset.



WO	Recieved	Finished	Total	Request
FO-338255	1/29/2016	1/29/2016		Please drain water from overhead light fixture in suite 1215. Water pool due to leak in radiator from suite above. The water in the carpet may need to be extracted as well.
<b>E - South</b>			<b>35</b>	
FO-335793	1/4/2016	1/4/2016		FIRE ALARM PANEL SOUND. 1ST FLOOR BEHIND CIRCULATION DESK.
FO-335805	1/4/2016	1/4/2016		FIRE ALARM PANEL SOUNDING. ROOM 1600.
FO-335821	1/4/2016	1/29/2016		RM 1520/SHIPPING REC AREA WEST WALL NO POWER TO WALL OUTLET
FO-335907	1/4/2016	1/11/2016		NO POWER IN CUBICLE INSIDE OF ROOM 3100.
FO-336254	1/6/2016	1/11/2016		NO POWER IN CUBICLE INSIDE OF ROOM 3100.
FO-336352	1/7/2016	1/13/2016		RM 209 IS TOO COLD
FO-336474	1/8/2016	1/11/2016		PLEASE MEET DTE IN BSMNT, DOOR PAD LOCKED UNABLE TO READ METER
FO-336537	1/11/2016	1/11/2016		FIRE ALARM.
FO-336561	1/11/2016	1/11/2016		FIRE TROUBLE ALARM.
FO-336588	1/11/2016	1/11/2016		FIRE ALARM PANEL SOUNDING
FO-336589	1/11/2016	1/11/2016		RM 169 TOO COLD
FO-336608	1/11/2016	1/12/2016		CHECK PANEL - BATTERY TROUBLE. FIRE TROUBLE ALARM.
FO-336680	1/12/2016	1/12/2016		BLOWN CIRCUIT. NO POWER IN WALL OUTLETS. ROOM 1360.
FO-336723	1/12/2016	1/29/2016		STE 3107 IS EXTREMELY COLD
FO-336725	1/12/2016			RM 4130 WALK IN COLD RM BOX IS SHOWING +15 WHEN IT SHOW -20
FO-336905	1/14/2016	1/15/2016		BLOWN CIRCUIT. ROOM 1360.
FO-336947	1/14/2016			Both chemical fume hoods have a high face velocity
FO-336962	1/14/2016	1/14/2016		BSMNT SOUTH HALF AND 1ST FL PRESSURE OFF, FUME HOODS NOT WORKING
FO-337011	1/15/2016	1/15/2016		FIRE ALARM.
FO-337046	1/15/2016	1/19/2016		Cold Room is very cold - everything is frozen.
FO-337275	1/19/2016	1/29/2016		STE 1210 IS TOO COLD 53degrees
FO-337317	1/19/2016	1/19/2016		RM 504 AFTER LAST POWER BUMP/SHUT DOWN WHEN POWER WAS UP DOOR BELL STARTED RINGING CONSTANTLY
FO-337318	1/19/2016	1/19/2016		RM 143 THE SOUTH WALL OUTLET ISN'T WRKNG
FO-337424	1/20/2016	1/20/2016		There is a smell in the lobby/waiting area in Chemical Engineering. Requesting the building engineer to come and evaluate the ventilation of that area.
FO-337488	1/20/2016	1/20/2016		LAB 130 AND 140 FUME HOOD NOT WORKING
FO-337597	1/21/2016	1/22/2016		AIR VENT HEATER IS VERY LOUD. ROOM 409.
FO-337771	1/25/2016			RM 359 TOO HOT
FO-337954	1/26/2016	1/27/2016		LAB 311 TOO COLD
FO-337968	1/26/2016			RM 130/LAB NEAR FUMEHOOD #8 DUST IS FALLING OUT OF CLNG AIR VENTS
FO-338002	1/27/2016	1/27/2016		02 ALARM IN LUMIGIN CENTER - BASEMENT.
FO-338008	1/27/2016	1/27/2016		FUME HOODS HAVE LOW FLOW RATE. ROOM 170.
FO-338041	1/27/2016			Trade: Command Center Priority: High Follow up to FO 338002 R/R BSMT Oxygen sensor panel was in alarm on channel 4. Unit appears to need calibration. Please have routine PM completed.
FO-338040	1/27/2016			VACUUM LINE IS NOT WORKING. ROOM 2159.
FO-338177	1/29/2016	1/29/2016		RM 313 TOO HOT
FO-338209	1/29/2016			RM 359 TOO HOT
<b>E - Southeast</b>			<b>40</b>	
FO-335859	1/4/2016	1/4/2016		RM 2155.1 & 2155.26 OUTLETS NOT WORKING
FO-335866	1/4/2016	1/4/2016		FRONT LOBBY AND FIRST FEW OFFICES TOO COLD, PLEASE UPDATE ANDREW 577-3671 ON STATUS
FO-335889	1/4/2016	1/4/2016		1st flr Handicap RR is too cold

WO	Recieved	Finished	Total	Request
FO-336566	1/11/2016	1/11/2016		RM 14200.10 HAS NO HEAT COMING FROM AIR VENTS
FO-336683	1/12/2016	1/12/2016		BLOWN FUSE. ROOM 3226.
FO-336694	1/12/2016	1/12/2016		1ST FLR LOUNGE/STUDIO AREA NEED TO RESET BREAKER FOR THE DISTRIBUTION BOX/EQUIP
FO-336695	1/12/2016	1/12/2016		STE 4000 IS TOO COLD
FO-336735	1/12/2016	1/12/2016		RM 14101.3 IS TOO HOT
FO-336829	1/13/2016	1/13/2016		RM 6000 IS TOO COLD
FO-336830	1/13/2016	1/13/2016		RM 6402.3 IS TOO COLD
FO-336832	1/13/2016	1/13/2016		RM 6402.4 IS TOO COLD
FO-336834	1/13/2016	1/13/2016		RM 6402.5 IS TOO COLD
FO-336837	1/13/2016	1/13/2016		ALARM IN SERVER ROOM 2235.
FO-336855	1/13/2016	1/13/2016		The heater in 3207 only blows heat about half the time. Many times it is blowing cold air. It seems as if the heating portion is having difficulty engaging. The room has been much colder than the surrounding rooms for the past week. Please address. Than
FO-336852	1/13/2016	1/13/2016		RM 5102 NO HEAT
FO-336956	1/14/2016	1/14/2016		RM 2134 HAS A CLNG LEAK WHEN HVAC IS ON/DUE TO LEAK THERE IS BLACK MOLD & WATER DAMAGE
FO-337286	1/19/2016	1/19/2016		BLOWN FUSE. NO POWER IN WALL OUTLETS. ROOMS 6305.5 & 6305.4.
FO-337312	1/19/2016	1/19/2016		6305.6 BLOWN FUSE
FO-337335	1/19/2016	1/20/2016		RM 3209 TOO COLD
FO-337345	1/19/2016	1/19/2016		RM 4200 PLEASE GIVE HEELY CO ACCESS TO CLOSET WITHIN RM 4200
FO-337417	1/20/2016	1/20/2016		ENTIRE BLDG TOO COLD 1ST AND 3RD FL ARE FREEZING, ALARMS SOUNDING
FO-337453	1/20/2016	1/20/2016		WALL OUTLETS ARE NOT WORKING. ROOMS 101.1, 101.2 & 101.3.
FO-337461	1/20/2016	1/20/2016		RM 101 NO POWER TO OUTLETS, SEVERAL COMPUTERS, PRINTERS AND LARGE COPIER NOT WORKING
FO-337500	1/20/2016	1/20/2016		NO HEAT IN LOBBY AND 1ST FLOOR HANDICAP RESTROOM.
FO-337599	1/21/2016	1/21/2016		NO HEAT IN HANDICAP RESTROOM. PLEASE SEE MICHAEL IN THE BOX OFFICE.
FO-337654	1/22/2016	1/22/2016		RM 6203.1 BREAKER NEEDS RESETTING
FO-337655	1/22/2016	1/22/2016		RM 6203.2 BREAKER NEEDS RESETTING
FO-337791	1/25/2016	1/25/2016		RM 6201/CONF RM IS TOO COLD PLS GO TO RM 6203 FIRST BEFORE GOING TO CONF RM
FO-337792	1/25/2016	1/25/2016		RM 6202/CONF RM IS TOO COLD PLS GO TO RM 6203 FIRST BEFORE GOING TO CONF RM
FO-337793	1/25/2016	1/25/2016		RM 6307.6/CONF RM IS TOO COLD PLS GO TO RM 6203 FIRST BEFORE GOING TO CONF RM
FO-337794	1/25/2016	1/25/2016		RM 6203 IS TOO COLD
FO-337796	1/25/2016	1/25/2016		RM 6409.3 IS TOO COLD
FO-337805	1/25/2016	1/25/2016		RM 6305.3 NEED BREAKER RESET
FO-337905	1/26/2016	1/26/2016		FIRE ALARM.
FO-337927	1/26/2016	1/27/2016		RM 2317 TOO HOT
FO-337967	1/26/2016	1/26/2016		RM 201.6 NEED BREAKER RESET
FO-338131	1/28/2016	1/28/2016		RM 3107 SIDE HEATERS NOT WORKING PLEASE CONTACT MEL ROSAS 248-808-9054 WITH UPDATE
FO-338183	1/29/2016	1/29/2016		RM 14200.10 NO HEAT
FO-338201	1/29/2016	1/29/2016		6000 and 6203 COLD AIR BLOWING FROM VENTS
FO-338202	1/29/2016	1/29/2016		RADIATOR IS MAKING A VERY LOUD NOISE. ROOM 1119.
<b>E - West</b>			<b>9</b>	
FO-335846	1/4/2016	1/4/2016		SAYS THAT THEY HAD A POWER BUMP & NOW FIRE TROUBLE ALARM
FO-335870	1/4/2016	1/4/2016		TRIPPED CIRCUIT. ROOM 385.
FO-336744	1/12/2016	1/15/2016		1ST FLR IS TOO COLD
FO-336809	1/13/2016			1ST FLR IS STILL TOO COLD

WO	Recieved	Finished	Total	Request
FO-337291	1/19/2016	1/19/2016		1ST FL TOO COLD
FO-337487	1/20/2016	1/22/2016		RM 385 FANS STOPPED BLOWING
FO-337613	1/21/2016	1/22/2016		Corridors, the entire building is cold
FO-337696	1/22/2016	1/26/2016		PLEASE LET CONTRACTORS IN RM 2140
FO-337956	1/26/2016	1/27/2016		Wall outlets on left side of room are dead.
<b>Medium</b>			<b>129</b>	
<b>E - Auxiliary</b>			<b>4</b>	
H-56542	1/6/2016			Garbage disposal is leaking from under the sink. It seems that the leak has been going on for about a month of two based on the damages. The pipe under has a wet spot in one place specifically with mold gathering a ring around the pipe. authenticated use
FO-336992	1/15/2016			Engineer, Medium: R/R RM 00010/MECH RM Repair as needed and return to service HHWP-6. EQUIP NOT AVAIL IN TMA SYSTEM
H-56859	1/20/2016			The toilet is constantly running and flushing water authenticated user: Alexandra Mckinzie - fo7857requester ip address: 35.16.74.243
H-56860	1/20/2016			Sink drain switch is broken and will not turn on. needs to be fixed, pleaseauthenticated user: Elijah Baker - fh0812requester ip address: 141.217.23.174
<b>E - Command Center</b>			<b>34</b>	
FO-335795	1/1/2016	1/5/2016		Trade: Command Center Priority: Medium Please add hour meter and "last 24" hour meter to the graphics for the emergency generator serving Science Hall.
FO-335855	1/4/2016	1/21/2016		Controls -- Priority Medium R/R RM 00045/MECH RM # 3 boiler will not start. The boiler doesn't get a indication as to why.
FO-335894	1/4/2016			Perform tune-up on Boiler "B"
FO-336101	1/5/2016	1/5/2016		BAS Med. Priority R/R RM 00057/MECH RM Repair controls on AHU #4 and 6. Set point goes to 100+deg. when switched from Operator to None. Unit is currently running in operator sp 72
FO-336105	1/5/2016	1/5/2016		BAS Med Priority R/R RM 00033/MECH RM AHU #7 will not start in none position
FO-336153	1/5/2016	1/5/2016		BAS Med. Priority R/R RM 00057/MECH RM Repair controls on AHU #6. Set point goes to 100+deg. when switched from Operator to None. Unit is currently running in operator sp 72
FO-336189	1/5/2016	1/14/2016		COMMAND CTR, R/R E ROOF 3-WAY VALVE FOR COOLING TOWER NOT RESPONDING, CONDENSING WATER TEMPS TOO LOW WHEN IN FREE COOLING, PLEASE TROUBLESHOOT. PRIORITY-MEDIUM
FO-336453	1/8/2016			PLEASE REPLACE THERMOSTAT IN TRAINING ROOM STADIUM
FO-336457	1/8/2016	1/22/2016		REF -SHOP #3 BOILER WILL NOT START MEDIUM PR ATT AUBREY WALLER
FO-336458	1/8/2016	1/11/2016		REF SHOP PLEASE REPLACE E.P SWITCH ON #3 AHU MEDIUM PR ATT AUBREY WALLER
FO-336486	1/8/2016	1/8/2016		REF SHOP R/R PLEASE CHECK MODULE ON SEIMAN CONTROL PANEL FOR AHU #1,2 NOT WORKING MEDIUM PR 1/8/16 lps: EQ NOT AVAIL IN TMA SYS
FO-336605	1/11/2016			trade siemens priority medium R/R BSMT please service unit #1 ahu#1 in basement of ugl mix air temp to low unit will not run and damper positions are out of calibration EQUIP NOT AVAIL IN TMA SYS
FO-333667	1/11/2016			#2 - 2 stage unit not working.
FO-333668	1/11/2016			AHU 3 not working.
FO-336712	1/12/2016	1/14/2016		Trade: Command Center Priority: Medium R/R 2ND FLR There are two rooms labeled 209. Please change the one in the SOUTH half of the building to 215 (F007.04.A05.307:ROOM TEMP).

WO	Recieved	Finished	Total	Request
FO-336786	1/13/2016	1/14/2016		BAS, Medium; R/R room 322 in ovrd cooling mode at 8:30 AM room temp. 63 degrees. Also please release room stat and LEAVE in none. 3rd request for that. Booster coil valve not opening despite control actuator working. WO has been sent in to fitters for r
FO-336901	1/14/2016	1/15/2016		Bas Controls Med. Priority R/R RM 00035/MECH RM AHU #5 does not respond to start or stop commands. In order to shut down this unit we must go to the main MCC panel and switch the HOA switch to off.
FO-336958	1/14/2016			pls repair boiler 2 phantom low water trips, with normal water level and b.f.p. running fine ?
FO-336958	1/14/2016			pls repair boiler 2 phantom low water trips, with normal water level and b.f.p. running fine ?
FO-336983	1/15/2016		1/15/2016	Boiler "B" trips on flame failure.
FO-336984	1/15/2016	1/18/2016		Boiler "D" fails in purge cycle, needs a tune-up
FO-337319	1/16/2016			controls- medium priority- thermostat shows intermittently as failed. room is running cold. Diagnose, repair or replace thermostat for proper temperature control.
FO-337515	1/20/2016	1/22/2016		trade siemens priority medium please service office 2109 to cold only gets up to 69 degrees office is cold box is not tracking
FO-337647	1/22/2016	1/22/2016		Trade: Command Center Priority: Medium R/R BLDG Please modify generator run time report to provide information for 3 days. (It is presently set up for 1 day.)
FO-337786	1/25/2016			BAS Section: Please rewire LTD detector downstream of heating coils. Current location is incorrect and causing nuisance trips.
FO-337787	1/25/2016			BAS Section: Please rewire LTD detector downstream of heating coil. Current location is incorrect/causing nuisance trips.
FO-337789	1/25/2016			Control shop-Office is to warm. Damper motor not responding. Please repair or replace.
FO-337953	1/26/2016		1/28/2016	Trade: Command Center Priority: Medium Please supply R/R 1ST FLR: 1) 6 - 680 white thermostats 2) 6 - 81-U valve actuators
FO-338017	1/27/2016	1/27/2016		BAS Section: R/R PENTHOUSE Please correct PPCL for UGL ahu 7: MA setpoint control, RF control, ramp, and co2 control need updating. Update graphics to reflect changes.
FO-338020	1/27/2016	1/27/2016		BAS Section: R/R PENTHOUSE Please update PPCL for ahu 8, UGL. MA setpoint, RF control, ramp, and co2 need correction. Update graphics to reflect any changes.
FO-338021	1/27/2016			controls R/R RM 1005 please troubleshoot classroom 1005. room cold appears pneumatic terminal vav box not responding properly
FO-338022	1/27/2016			controls R/R RM 1000 please troubleshoot PNEUMATIC terminal vav box not responding area cold inside main entrance area
FO-338023	1/27/2016			controls R/R RM 2037 please troubleshoot PNEUMATIC terminal vav box to room 2037 room cold
FO-338138	1/28/2016			Combustion Damper Safety interlock wiring jumpered out.  Dampers not working.  Please restore damper operation and safety interlock wiring.
<b>E - MedPharm</b>			<b>18</b>	
FO-335877	1/4/2016	1/7/2016		BACKFLOW PREVENTER FAUCET LEAK. ROOM 7320.
FO-335879	1/4/2016	1/7/2016		LIGHT OUT IN FUME HOOD. ROOM 7320.  *See Results*
FO-335881	1/4/2016	1/7/2016		TOO WARM. ROOM 2105.
FO-336270	1/6/2016	1/7/2016		TOO COLD. ROOM 2268.
FO-336607	1/11/2016	1/13/2016		TOO HOT. ROOM 5215. (PHYSIOLOGY DEPT.)
FO-336800	1/13/2016	1/13/2016		TOO COLD. ROOM 2156.

WO	Recieved	Finished	Total	Request
FO-336866	1/13/2016			RM 2268/CLASS RM IS TOO COLD
FO-336868	1/13/2016			RM 3125/CLASS RM IS TOO COLD
FO-337293	1/19/2016	1/23/2016		TOO HOT. ROOM 310.
FO-337344	1/19/2016			VERY COLD. ROOMS 34 AND 36 (BASEMENT)
FO-337442	1/20/2016	1/23/2016		TOO COLD. ROOM 2248.
FO-337505	1/20/2016	1/23/2016		TOO COLD. ROOMS 2323, 2333 & 2343.
FO-337552	1/21/2016	1/21/2016		TOO HOT. ROOM 313.
FO-337571	1/21/2016	1/21/2016		TOO COLD. ROOMS 334 AND 317.
FO-337587	1/21/2016			RM 6137 PLEASE CHECK AIR FLOW, OCCUPANTS EYES ARE RUNNING
FO-337945	1/26/2016	1/27/2016		TOO HOT. ROOM 9374.
FO-338035	1/27/2016			GARAGE/DOCK (BAY AREA) CLNG UNIT HEATER IS LEAKING CAUSING FLOODING IN AREA
FO-338220	1/29/2016			TOO HOT. ROOMS 5229 AND 5234.
<b>E - North</b>			<b>21</b>	
FO-335811	1/4/2016	1/4/2016		TOO COLD. 3RD FLOOR NORTH.
FO-335824	1/4/2016	1/4/2016		TOO COLD. PROVOST OFFICE AND THE 4TH FLOOR HALLWAY.
FO-335827	1/4/2016	12/28/2015		TOO COLD. ROOM 2074.
FO-335853	1/4/2016	1/4/2016		TOO WARM. BUILDING INCLUDING THE 3RD FLOOR.
FO-335858	1/4/2016	1/4/2016		TOO COLD. ROOM 3054 AND HALLWAY.
FO-336389	1/7/2016	1/7/2016		COLD AIR BLOWING FROM VENTS. ROOM 3502 AND SURROUNDING AREAS.
FO-336484	1/8/2016	1/8/2016		RM 351 PIPE ON MACHINE IS MISSING A TOP, BRINGING MOISTURE IN RM
FO-336592	1/11/2016	1/11/2016		TOO COLD. ROOM 2023.
FO-336701	1/12/2016	1/12/2016		TOO HOT. ROOM 110.
FO-336935	1/14/2016	1/14/2016		Room is too cold.
FO-336998	1/15/2016	1/15/2016		Room is extremely warm.
FO-337062	1/15/2016	1/15/2016		TOO COLD. ROOM 317.
FO-337295	1/19/2016	1/19/2016		TOO COLD. 1ST FLOOR INSIDE ENTRANCE DOOR ON ANTHONY WAYNE DRIVE SIDE AND LOADING DOCK.
FO-337358	1/19/2016	1/19/2016		TOO COLD. 3RD FLOOR OFFICES SOUTHWEST SIDE.
FO-337433	1/20/2016	1/20/2016		It's very cold in this office. This office is located within the Teaching Commons by the elevator. Actually its chilly in this entire department.
				Thank you.
FO-337557	1/21/2016	1/21/2016		WALL OUTLETS ARE NOT WORKING. ROOM 283.
FO-337605	1/21/2016	1/21/2016		TOO HOT. ROOM 134.
FO-337739	1/25/2016	1/25/2016		IT suite is extremely warm. Please adjust temp.
FO-337776	1/25/2016	1/26/2016		Purdy Library 1st Floor, Office Suite 134
				Staff working in area report that area is rather warm. Please adjust the temperature.
				Thank you.
FO-338047	1/27/2016	1/27/2016		TOO COLD. ROOM 2074.
FO-338218	1/29/2016	1/29/2016		TOO COLD. ROOM F, G, H.
<b>E - Northeast</b>			<b>14</b>	
FO-335840	1/4/2016	1/4/2016		light bulbs & cleaning supplies for bsmt equipment room
FO-336472	1/8/2016	1/8/2016		PLEASE CONTACT JOE FROM C & IT 577-7919 HE LEFT HIS GLOVES IN YOUR OFFICE
FO-336555	1/11/2016	1/11/2016		RM 120 TOO COLD
FO-336573	1/11/2016	1/27/2016		VERY COLD. ROOMS 222 AND 224.
FO-336674	1/12/2016	1/27/2016		TOO HOT. ROOMS 216 & 218.
FO-336675	1/12/2016	1/27/2016		TOO COLD. ROOMS 222 & 224.
FO-336686	1/12/2016	1/12/2016		TOO COLD. ROOM 313.

WO	Recieved	Finished	Total	Request
FO-336703	1/12/2016	1/27/2016		TOO COLD. ROOM 113.
FO-336747	1/12/2016	1/12/2016		AIR COMING IN THRU WINDOW. ONLY OCCUPIED OFFICE ON THE 3RD FLOOR COULD BE ROOM 301.
FO-336857	1/13/2016	1/14/2016		TOO COLD. ROOM 173.
FO-336896	1/14/2016	1/27/2016		TOO HOT. ROOM 56.
FO-337003	1/15/2016	1/15/2016		TOO HOT. ROOM 313.
FO-337416	1/20/2016	1/27/2016		TOO COLD. ROOMS 113, 224 252.
FO-337464	1/20/2016	1/20/2016		COLD AIR COMING THRU WINDOWS. 3RD FLOOR.
<b>E - Preventative Maintenance</b>			<b>15</b>	
FO-335931	1/4/2016	1/12/2016		Heater in faculty office is making loud noises.
FO-336648	1/11/2016	1/27/2016		Rooms 3141 & 3126 Elliman have debris falling from the vents. Please install or replace filters to prevent the dirt contamination in the lab and office.
FO-336651	1/11/2016	1/12/2016		Room is way too cold, its freezing. Please heat up!
FO-337069	1/15/2016	1/16/2016		TOO COLD. ROOM 231.
FO-337072	1/15/2016	1/16/2016		RM 322 IS TOO HOT
FO-337073	1/15/2016	1/16/2016		RM 324 IS TOO HOT
FO-337382	1/19/2016	1/21/2016		In Basement room 0225 dirty cagewash, 0513, 0514, 0522, and 0501 has positive vaneometer airflow readings. It should be a negative flow. Called in earlier with FO#0337278
FO-337522	1/20/2016	1/21/2016		TOO HOT. ROOM 313.
FO-337626	1/21/2016	1/21/2016		The power outlet suddenly stopped working. It is the one on the right when you enter the room which is connected to the refrigerator.
FO-337635	1/21/2016			Water leak in the left side of hood W6. There are two pipes and both are leaking
FO-338067	1/27/2016	1/28/2016		Rooms 3141 & 3126 Elliman have debris falling from the vents. Please install or replace filters to prevent the dirt contamination in the lab and office.
FO-338069	1/27/2016	1/28/2016		Room 3329.20 - No air circulating in room.
FO-338072	1/27/2016	1/28/2016		NO HEAT - MID CITY GRILL.
FO-338076	1/27/2016	1/28/2016		TOO COLD. ROOM 315.7
FO-338233	1/29/2016	1/30/2016		TOO HOT. THEATRE.
<b>E - South</b>			<b>7</b>	
FO-336392	1/7/2016	1/7/2016		Temperature adjustment needed in P/K Library room 134. Complaints that the temperature is too high.
FO-336481	1/8/2016	1/8/2016		P/K Library room 134 - temperature adjustment needed. Complaints that the heat is too high.
FO-336576	1/11/2016	1/11/2016		No heat in room 14200.10. Please help to check it. Thanks!
FO-336941	1/14/2016			Chemical fume hood has a low face velocity (4 fpm)
FO-337276	1/19/2016	1/19/2016		TOO COLD. BUILDING.
FO-337736	1/25/2016	1/26/2016		TOO HOT. 4TH FLOOR OFFICES. EAST SIDE OF BUILDING.
FO-338006	1/27/2016			Trade: Controls Priority: Medium R/R EDC Natural gas water heater is not working properly it is cycling on and off rapidly.
<b>E - Southeast</b>			<b>10</b>	
FO-335837	1/4/2016	1/4/2016		TOO COLD. ROOM 5018.
FO-336232	1/6/2016	1/6/2016		TOO COLD. 1ST FLOOR LOBBY.
FO-336267	1/6/2016	1/11/2016		NO HEAT. ROOMS 124, 123 & 136.
FO-336475	1/8/2016	1/8/2016		TOO HOT. ROOM 14101.3.
FO-336582	1/11/2016	1/11/2016		VERY COLD. ROOMS 123, 124 & 126.
FO-336748	1/12/2016	1/12/2016		TOO COLD. ROOM 9304.5
FO-336923	1/14/2016	1/14/2016		TOO COLD. ROOMS 123, 124 & 126.
FO-336924	1/14/2016			TOO HOT. ROOM 2317.
FO-337451	1/20/2016	1/21/2016		TOO COLD. ROOM 2207.

WO	Recieved	Finished	Total	Request
FO-338145	1/28/2016			TOO COLD. 6000 SUITE INCLUDING ROOM 6402.9
<b>E - West</b>			<b>6</b>	
FO-335831	1/4/2016	1/4/2016		TOO COLD. ROOM 137.
FO-336780	1/13/2016			Repair the following exhaust fans at the football stadium building...Room 110 & Room 120 - This is the 2nd request. Thank You. Bob Ostrowski
FO-337053	1/15/2016	1/15/2016		TOO WARM. ROOM 100.
FO-337444	1/20/2016	1/20/2016		VERY COLD. ROOM 563.
FO-337577	1/21/2016	1/29/2016		Office is too cold! Please check on heat.
FO-337612	1/21/2016	1/29/2016		Extremely cold in all the labs, particularly Rm 2037 and 1005 MEB
<b>Low</b>			<b>270</b>	
<b>E - Auxiliary</b>			<b>101</b>	
H-56470	1/2/2016			The garbage disposal in the kitchen sink is not working. authenticated user: Isabell Groves - fb2096requester ip address: 141.217.23.173
H-56480	1/3/2016			First room (nearest kitchen) - hot air vent does not open. Room is not getting heated.authenticated user: Perani Chander - fm3607requester ip address: 141.217.220.133
H-56472	1/3/2016			ENGINEERING--Please replace kitchen faucet. Occasionally leaks from base.authenticated user: Prentis Gipson - bq7019requester ip address: 141.217.23.219
H-56479	1/4/2016			Heater is not working. The air is not even warm tough the knob is set at the maximum.authenticated user: Santosh Miraskar - fq9811requester ip address: 141.217.220.248
H-56489	1/4/2016			Garbage disposal will not turn on. authenticated user: Psocrates Stansberry - cl5547requester ip address: 141.217.23.173
H-56485	1/4/2016			The air condition blows cold weather instead of warm weather. Now the apartment is getting so cold. It would be great if you can fix it as soon as possible. authenticated user: Nafiseh Saberian - fj7048requester ip address: 146.9.110.184
H-56514	1/4/2016			The showerhead in the 2nd bathroom of the hallway (furthest from the front door to the apt) is not ejecting water fully. Most of it does not make it to the showerhead and comes out of the faucet instead.authenticated user: Tasneem Ahmed - ec3943requeste
H-56503	1/4/2016			Warmer is not working.Room is so cold to liveauthenticated user: Sri Lakshmi Vengala - fo9759requester ip address: 35.16.67.31
H-56494	1/4/2016			The kitchen sink faucet is leaking even after closing it properly. authenticated user: Sai Prashanth Kamble - fx3340requester ip address: 35.16.70.61
H-56495	1/5/2016			The in-sink-erator is really loud.authenticated user: Yinan Hu - fs5434requester ip address: 35.16.73.222
H-56498	1/5/2016			Heating/Cooling unit in the back room (largest one with two windows) does not heat. The heat may come on for a little bit, but eventually turns into cool air, even if the control is turned up to the warmest setting. Heating/Cooling unit in the living room
H-56515	1/5/2016			Bathroom Tub Running
H-56517	1/5/2016			Toilet will not stop flushing, needs to be fixed authenticated user: Anthony Kurcz - ez7811 requester ip address: 141.217.23.177
H-56519	1/5/2016			The heat in my room doesn't work. It's a ice box in here. I've reset the thermostat twice and it's still not producing heat. Also there is an electrical issue with an outlet near the shower. It doesn't work at all.authenticated user: Lexus Dennis - fa344
H-56518	1/5/2016			Heat is not working in the trash room.
H-56539	1/6/2016			Needs new light fixture over kitchen sink-To engineersauthenticated user: Elijah Baker - fh0812requester ip address: 141.217.23.173
H-56536	1/6/2016			Light fixture broke.
H-56540	1/6/2016			Garbage disposal is cracked and needs to be replaced
H-56549	1/6/2016			Shower and Tap in the Bathtub for second bathroom are not working properly. The switching knob probably might have some problem which makes the water flow through shower from the tap.authenticated user: Swapnil Chouknis - fy4968requester ip address: 141
H-56557	1/6/2016			Heat settings on air conditioning do not work.authenticated user: Bianca Dean - fo1867requester ip address: 141.217.23.172
H-56544	1/6/2016			The air filter needs to be changed. The quality of the air is poor. There is some dust coming out of vent as well. authenticated user: Amyra Woods - eh3128requester ip address: 35.16.78.103

WO	Recieved	Finished	Total	Request
H-56551	1/7/2016			Light hanging in the janitors closet on the first floor.
H-56554	1/7/2016			Leaking sprinkler headauthenticated user: John Kastler - fp1072requester ip address: 35.16.98.219
H-56574	1/7/2016			The shower in the bathroom(One with the tub) is not working properly please fix it urgentauthenticated user: Saad Alshahrani - fp4858requester ip address: 141.217.59.12
H-56567	1/7/2016			kitchen sink leakingauthenticated user: Meyyappan Nachiappan - fy7781requester ip address: 141.217.23.175
H-56578	1/8/2016			Kitchen faucet leaking
H-56579	1/8/2016			Sink is leaking.
H-56593	1/8/2016			Temperature control switch doesn't work.authenticated user: Thomas Wolf - fj0736requester ip address: 141.217.23.231
H-56596	1/8/2016			There is very little heat coming into the room. authenticated user: Najjamah Allah - ej2633requester ip address: 141.217.23.173
H-56595	1/11/2016			Toilet will not stop flushing at all. It is noisy and is causing us to not be able to get sleep.  authenticated user: William Alexander - ew0056requester ip address: 141.217.23.178
H-56622	1/11/2016	1/12/2016	1/12/2016	So I recently moved into my new room this weekend and I noticed a few problems with the room at first glance and the only thing that was fixed was the broken shower. And now the thermostat doesn't work, the window in 514 CD room wont close and theres a re
H-56632	1/11/2016			The heat in my dorm room is no longer working. No matter how high I put it, the room stays at a freezing 65 degrees. I have made sure it is on heat but, it is still way too cold. My parents know because I was complaining last night and have concerns for
H-56636	1/11/2016			Vent in the third room between the windows has no air coming out. authenticated user: Atika Singh - ez6430requester ip address: 35.16.72.149
H-56647	1/11/2016			I need someone to take a look at the thermostat because my room isn't warming up the way I think it should.authenticated user: Ashleigh Anderson - fo1351requester ip address: 35.16.98.219
H-56637	1/12/2016			Fire alarm panel reads failure for smoke detector in basement storage 19authenticated user: David Johnson - fn9187requester ip address: 141.217.23.175
H-56646	1/12/2016			Heat does not work, room is freezing authenticated user: Tiffany Jones - fg9236requester ip address: 35.16.98.219
H-56651	1/12/2016			OUR ROOM IS FREEZING!!!! NO HEAT!!!authenticated user: Faezeh Babaieasl - fc1002requester ip address: 35.16.73.68
H-56654	1/12/2016	1/12/2016	1/12/2016	lots of ligts are dead the air conditioning system(heating, cooling):no wind comes out when the fan is set "auto" authenticated user: Jongwoo Son - fz3808 requester ip address: 141.217.224.219
H-56656	1/12/2016			Garbage disposal is broken.
H-56657	1/12/2016			Garbage disposal is broken.
H-56658	1/12/2016			My air conditioner doesn't work. It's cold there. My room is 723 B.authenticated user: Patrycja Palczynska - fx9265requester ip address: 35.16.98.219
H-56675	1/12/2016			Heat and AC is not working. The unit makes a constant buzzing sound but never kicks on.  authenticated user: Andrew Wilkinson - fj8526requester ip address: 141.217.230.228
H-56676	1/12/2016			Faucet leaks in my room. It acts as if it is on all the time but it is shut off.authenticated user: Thomas Wolf - fj0736requester ip address: 35.16.98.75
H-56677	1/12/2016			Thermostat is inoperable. Seems to not function on any combination of settings. Looks like internal problem; hardware seems to be in one piece.authenticated user: Jack Mullen - ga3125requester ip address: 35.16.102.173
H-56678	1/12/2016			4th floor and 6th floor lounge heater doesn't workauthenticated user: Jack Mullen - ga3125requester ip address: 35.16.102.173
H-56670	1/13/2016			Thermostat is brokenauthenticated user: Harmony Kegley - fo2794requester ip address: 35.16.100.186
H-56687	1/13/2016			Blades of the garbage disposer are dull and are not disposing all the food items. Blades need to be replaced.authenticated user: Aniruddha Paranjpe - ew2356requester ip address: 35.16.66.84
H-56671	1/13/2016			Heat doesn't work in the roomauthenticated user: Eric Blakey - fa9588requester ip address: 35.16.102.48



WO	Recieved	Finished	Total	Request
H-56725	1/13/2016			Heater is not working in the bedrooms but they are working in the remaining rooms. its freezing cold in the rooms.authenticated user: Siddhartha Annavajhula - fq1614requester ip address: 141.217.233.228
H-56681	1/13/2016			The heat in my room does not really work. I can't set the heat higher than 65 and even then it feels so cold in my room. Can someone please look at it? Thank you! authenticated user: Elizabeth Diviney - fh6923requester ip address: 35.16.49.51
H-56711	1/13/2016			The heat is broken. Setting the thermostat to any warm temperature (70 and above) and the fan to auto causes the vent to blow a constant stream of mildly cool air. authenticated user: Kevin Brunner - fo9662 requester ip address: 141.217.228.190
H-56718	1/13/2016			engineer-tub won't shut offauthenticated user: Vivien Okechukwu - fh2758requester ip address: 141.217.23.173
H-56719	1/13/2016			Button that turns shower on will not turn shower on. It also occasionally pushes back out while shower is on.authenticated user: Vivien Okechukwu - fh2758requester ip address: 141.217.23.173
H-56722	1/13/2016			Resident says that there is no heat coming into the smaller bedroom of apartment 1301. The rest of the apartment seems to receive heat just fine. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.173
H-56715	1/14/2016	1/15/2016		Problem pertaining to bathroo:m (furthest from the enterence of the house/ bathroom w/ tub), tub is slow to drain the water... water overflows b/c drain is too slow. authenticated user: Sheham Saif - fw2225requester ip address: 35.16.70.150
H-56742	1/14/2016			Heater is not working at all its hard to work around hall and kitchen it has been 4 days almost. It would be great if you could take a look at it as early as possible.Thank you.authenticated user: Apurav Patil - fl4162requester ip address: 198.208.72.9
H-56752	1/14/2016			Change of Air vent filter and new screw holes. Previously screwed into drywall, in which the holes dont stick. Resubmitting request. Repair person came today, without knowing the problem. Was turned away since he came to fix the wrong issue (bathroom
H-56807	1/15/2016			The water knob in the bathroom of the tub to control hot and cold doesn't moderate the temperature and thus the water is extreme temperatures.***PRIORITY*** 1 Bath apartmentauthenticated user: Ankita Ghosh - fp9957requester ip address: 146.9.153.189
H-56764	1/16/2016			The thermostat in the room doesn't work. The room is beginning to get really cold. Could someone come check it out? Please and thank you.authenticated user: Janae Coleman - fw3250requester ip address: 35.16.110.165
H-56789	1/18/2016			The air conditioner/ heater is making a loud whistling sound. authenticated user: Vineeth Rakesh Mohan - ed3424requester ip address: 35.16.79.66
H-56793	1/18/2016			Air conditioning fan not functionalauthenticated user: Vaibhav Sidarala - fc9716requester ip address: 146.9.150.63
H-56766	1/18/2016			Our thermostat says it is set for 78 degrees however it is only getting up to 70 degrees in the main living area,and is even colder in each individual room. We have made a request before and someone came out to fix it however they told us it was only a te
H-56790	1/18/2016			the toilet flashing handle is badly rusted/damagedkindly come and assist us.Thanksauthenticated user: Philip Adero - fc3858requester ip address: 35.16.71.217
H-56812	1/19/2016			Bathroom fan is not working (1st bathroom. without tub); smell a burning sent authenticated user: Anthony Eid - eh2083requester ip address: 141.217.59.12
H-56772	1/19/2016			When you switch the heater on, the heat only works for 5-10 minutes then starts to blow cold air. authenticated user: Andrew Moore - fh0457 requester ip address: 141.217.23.177
H-56813	1/19/2016			Heat comes out as cool air.authenticated user: Taylor Hall - eq7319requester ip address: 141.217.83.124
H-56773	1/19/2016			The heater is making a making a burning plastic smell. The smell goes away once you turn the heater off. There may be a blown circuit or something. authenticated user: Anthony Kurcz - ez7811 requester ip address: 141.217.23.177
H-56809	1/19/2016			Emergency repair needed for active leak in toilet inside classroom 185; right stall. Water is puddling on floor and children are present today so a repair is needed as soon as possible.authenticated user: Placidia Frierson - ac5011requester ip address:
H-56829	1/19/2016			Shower makes a very loud noise, unable to useauthenticated user: Sonal Joshi - ec9262requester ip address: 35.16.85.199
H-56837	1/19/2016			Heat in the third room still isn't working. Literally, just air is blowing through only one vent and no air in the vent between the windows. There's no heat whatsoever. We've been having this problem every other week. Our room is freezing cold. authentic

WO	Recieved	Finished	Total	Request
H-56821	1/19/2016			Air conditioner not displaying anything. Cold in room (3rd time breaking after being see.authenticated user: Hope-Zenobia Adams - fw6174requester ip address: 35.16.228.115
H-56847	1/20/2016			Dorm room is very cold due to wind blowing through the closed window at night, and the heating unit is not making up for the loss of heat. All roommates have the same issue.  authenticated user: Annette Hanson - fz3300requester ip address: 35.16.98.126
H-56858	1/20/2016			heater not working in hall please take immediate action we are freezing in the night.its been two weeks please do take action asapauthenticated user: Shivanand Kammara - fy6430requester ip address: 141.217.233.172
H-56865	1/21/2016			The exhaust fan in the first bathroom will not work. authenticated user: Zenab Rashid - fn9644requester ip address: 35.16.65.252
H-56854	1/21/2016	1/27/2016		The shower head keeps dripping water, leaving mold on the shower floor. authenticated user: Blake Bowe - fx0477 requester ip address: 35.16.98.50
H-56877	1/21/2016			heater is not working in our suite its always freezing cold even after raising the heat to 80 degreesauthenticated user: Amritha Gowda - fn9920requester ip address: 35.16.110.111
H-56883	1/21/2016			Resident says that knob on vent is broken in the bedroom and the knob in the kitchen is stuck. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.175
H-56878	1/22/2016			Our heater seems to be underperforming. Could someone come and check it?authenticated user: Kate Haworth - fi1149requester ip address: 141.217.225.227
H-56879	1/22/2016			My room feels very cold at night, so I have been trying to turn on the heater. However, the heater does not go above 22C. Please come fix!authenticated user: Tri Pham - fy4963requester ip address: 141.217.225.81
H-56914	1/22/2016			Bathroom shower not workingauthenticated user: Ezhil Nambi Vijayan Ambika - fs3124requester ip address: 141.217.221.30
H-56899	1/22/2016			heat is broken.authenticated user: Jala Agnew - fv6539requester ip address: 35.16.97.34
H-56908	1/24/2016			The second shower at the end does not have a warm setting for the water. I can only change it from scolding Hot water to cold water. It has been like this for the past couple weeks but I figured it was just the water and it would be fixed however it has n
H-56906	1/25/2016			Shower diverter needs to be changed - requested by Rick.authenticated user: Julie Malear - fg9040requester ip address: 141.217.23.229
H-56935	1/25/2016	1/27/2016		While doing my RA rounds, I noticed the light above the doors of rooms 245 and 247 were out. I talked to the resident living in 247 and he said that the lights have been out for some time now. authenticated user: Jake Clor - ff6066 requester ip address:
H-56945	1/25/2016		1/27/2016	Please clean for new arrival. authenticated user: Carlos Northern - ek8178 requester ip address: 141.217.83.79
H-56956	1/26/2016	1/27/2016		Garbage disposal in the kitchen sink is broken authenticated user: Ni'Esha Wright - fh3756 requester ip address: 141.217.23.173
H-56936	1/26/2016	1/27/2016		The heat in my room is not working. It turns on and the fan blows, but it does not blow out hot air. It sounds like the actual furnace is trying to click on but not catching if that helps. authenticated user: Kathleen Tomaszewski - fi8194 requester ip a
H-56958	1/26/2016			There is a leak under the sink due to rust. The water is leaking and stagnated and brings foul smell. Kindly look after it as soon as possible authenticated user: Sushil Subramanian - fq7893requester ip address: 70.210.76.57
H-56971	1/26/2016			The garbage disposal is still broken. Someone came here last on the 15th of January saying that he would try to find one;but he never came back. authenticated user: Shivali Patel - eh4417requester ip address: 35.16.74.171
H-56988	1/26/2016	1/28/2016		Kitchen sink dripping (urgent) authenticated user: Laura Lam Lau - fg3812 requester ip address: 141.217.233.64
H-56983	1/26/2016	1/27/2016		The circuits blew in my room when I changed the lightbulb to my lamp and now only 3 outlets are working. Need to reset circuits authenticated user: Shae-lyn Grubb - fw2534 requester ip address: 70.210.65.38
H-56985	1/26/2016			hi,we submitted problem regarding erator and we are waiting for the engineering operator to repplace it so we request you to replace it as soon as possiblethank youauthenticated user: Varun Kandukuri - fi9707requester ip address: 141.217.220.85

WO	Recieved	Finished	Total	Request
H-56977	1/26/2016	1/28/2016		The kitchen sink drain needs to be fixed. The garbage disposal is stuck. authenticated user: Danielle Henry - ew4467 requester ip address: 141.217.23.173
H-56980	1/26/2016	1/27/2016		The water tap handle for the kitchen sink is broken. The resident would like for it to be repaired. authenticated user: Danielle Henry - ew4467 requester ip address: 141.217.23.173
H-56976	1/27/2016			Shower head in the first bathroom (the small one near the entrance) is draining slowly and has become very loose. Please replace it with a new one. Thank you!authenticated user: Fei Fang - fy6516requester ip address: 35.16.76.157
H-57008	1/29/2016	1/29/2016		The central air isn't working properly authenticated user: Cale Scott - fr1507 requester ip address: 35.16.98.122
H-57018	1/29/2016			Water is leaking out of the bottom of sink disposalauthenticated user: Lu Zhang - eu4347requester ip address: 35.16.9.129
H-57019	1/29/2016			The fan in the kitchen is not workingauthenticated user: Lu Zhang - eu4347requester ip address: 35.16.9.129
H-57012	1/29/2016	1/29/2016		The heat is broken so it's very cold in the room. authenticated user: Amber Epperson - fw6276 requester ip address: 35.16.111.103
H-57027	1/29/2016	1/29/2016		Replace garbage disposal authenticated user: Jasmine Kendrick - eu6470 requester ip address: 141.217.23.173
H-57028	1/29/2016	1/29/2016		Replace lights fixtures in bathroom and above kitchen sink authenticated user: Jasmine Kendrick - eu6470 requester ip address: 141.217.23.173
<b>E - Command Center</b>			<b>38</b>	
FO-335874	1/4/2016	1/5/2016		BAS- R/R BLDG REWRITE MIN ROOM TEMP PROGRAMS CAMPUS WIDE WITH MODE AND SAMPLE TO REDUCE FLN TRAFFIC
FO-336093	1/5/2016	1/21/2016		No heat in tennis court. RTU won't fired up. Trade: Control High priority
FO-336099	1/5/2016	1/5/2016		BAS Section: R/R 4TH FLR please Repair/replace TEC APF 427 (West wall, central). TEC going in and out of failure.
FO-336119	1/5/2016	1/6/2016		CONTROLS R/R RM 1139/MECH RM please replace fire eye on boiler #3. Experienced numerous flame fails and eye shows signs of corrosion.
FO-336154	1/5/2016		1/26/2016	R/R BSMT This work order goes to refrigeration crew. Run new low voltage wiring, install new low voltage transformer and thermostat for PRV solenoid valve in basement.
FO-336186	1/5/2016	1/6/2016		CONTROLS (tony/Lloyd)please R/R RM 00187.10/MECH RM FWV on Boiler #2 which does not appear to be closing positively. Boiler OOS due to water leaking by and overfilling.
FO-336203	1/5/2016	1/19/2016		R/R BLDG Check boiler #1 control not showing on
FO-336334	1/7/2016	1/11/2016		Trade: Controls Priority: Low On the graphic page for AHU1 I would like you to remove the space static pressure point next to the static pressure set point and put in its place the duct static pressure because this is what the system is using for a contr
FO-336335	1/7/2016	1/22/2016		Controls repair steam control valve for AH-5 preheat coil.
FO-336357	1/7/2016	1/11/2016		BAS Controls, R/R 3RD FLR please troubleshoot thermostat F611.11.VAV.1.4, 3rd floor SE hallway.
FO-336359	1/7/2016	1/11/2016		BAS Controls, R/R RM 0058 please troubleshoot thermostat TEC 9, in room 58
FO-336400	1/7/2016	1/6/2016		VAV Box not working properly.
FO-336414	1/7/2016			Replace thermostat in Coaches Office, Digital display is not working properly.
FO-336447	1/8/2016			please have Honeywell check this vb -1042 for proper operation no signal. was able to slow the air volume to the customer. but the signal to the split volume box is not responding.

WO	Recieved	Finished	Total	Request
FO-336528	1/9/2016	1/11/2016		Please program graphics to show the following: On "Heat Exchanger" screen, add the info for, "P.TMPWTR.SUP", on the top grey bar perhaps. Also change the name of the "Heat Exchanger" screen to denote that it is, "temper water". also, Add the point, "P.
FO-336713	1/12/2016	1/12/2016		BAS (David)- R/R RM 00253.10/MECH RM please review Graphics for Elliman AHU3 (and steam valves Other AHUs). Clarify two CFM readings for S. discharge AHU3, etc.
FO-336739	1/12/2016	1/20/2016		BAS engineers: R/R RM 00001/MECH RM Please put building heating loop temperatures ( supply and return ) on Insight. Priority:low
FO-336736	1/12/2016	1/21/2016		Trade: Command Center Please order  Siemens Part # 195-100 - Receiver Controller Simulator Qty: 1
FO-336930	1/14/2016			Leaking control air PRV Please replace Powers product # 201-1001 1/4' npt in/out
FO-336957	1/14/2016			Women's Softball Facility Bldg #099 (Not in TMA) -Unable to get burners working on batting cage heaters
FO-336980	1/15/2016	1/15/2016		In the Italian Room the temp is close to 105 degrees and need to be looked at. It is not a safe environment for the workers or students. It's way too hot in there.
FO-336994	1/15/2016			To refrig. group. R/R RM 0004.10/MECH (pls note: see Engineer for specific eq)The return water temperature sensor on the hot water heating system is reading higher than the discharge temp. Please repair or replace.
FO-337300	1/19/2016	1/20/2016		Please have controls look at the program for insight at medical education commons. I cannot log on to insight at building #608. I will try to make changes to library at scott hall.
FO-337470	1/20/2016	1/20/2016		Vendor: Young Supply Magnetic Jumpers for campus wide Refrig Crew use. Qty: 3 Order total: \$32.70
FO-337648	1/22/2016			REPAIR LOW WATER CUT OUT. MAKE UP TANK.  Checked with Day Shift AD. There is an intermediate condensate return tank that has a float controlled solenoid valve that makes up water when tank is low. Solenoid and/or float may not be working OR float nee
FO-337745	1/25/2016	1/27/2016		Vendor Purchase Three(3) replacement glass & gasket sets for Kewanee Boiler burner viewport.
FO-337774	1/25/2016			Please provide and install Insight workstation in boiler rm.
FO-337821	1/25/2016	1/25/2016		Process Cooling Tower Fan only runs in low speed\.
FO-337914	1/26/2016			Please provide and install Insight and Honeywell on workstation in Room 065, engineers office.
FO-337943	1/26/2016			AC Shop-R/R RM 6203 -please relocate room sensor to adjacent wall within suite. Sensor is picking up heat from a copy machine, running in cooling only. See Engineer for more details.
FO-338037	1/26/2016	1/28/2016		R/R BLDG WRITE ALARM PROGRAM FOR ALL FAN UNITS IN ORDER TO MONITOR ON HOME SCREEN 1/26/16 lps: Note: Reinstalling req due to accidently rejecting req #279565  Loretta Small(01/26/2016 13:51)-- 1/26/16 lps: wrkng on req 1/27/16 lps: Spoke w/Carol says
FO-337966	1/26/2016			DUCTWORK INSTALLATION Reference FO-320557  Loading dock heat Pump replacement. Installation The replacement unit will require sheet metal & piping rework.
FO-337972	1/26/2016	1/26/2016		Controls - Repair diaphragm to steam valve
FO-338031	1/27/2016	1/27/2016		BAS Section: R/R PENTHOUSE Please modify ahu 6 PPCL to correct ramp, co2 control, ma temp control, and rf control. Update graphics to reflect changes.

WO	Recieved	Finished	Total	Request
FO-338071	1/27/2016			BAS Section: R/R PENTHOUSE Please Troubleshoot/repair/replace HV control on ahu 8: not responding to commands.
FO-338106	1/28/2016			Parts & Brombach's labor to construct electrical testing demonstration panel to train engineers on troubleshooting RTU's/Circuit Diagrams.
FO-338211	1/29/2016			Troubleshoot unit not heating
FO-338222	1/29/2016			To Honeywell technicians. The following problems need to be corrected. TU-18 air flow sensor not functioning. TU-4 heating valve leaks by over heating space. TU-7 heating valve leaks by. TU-32 heating valve actuator is non functional not responding to com
<b>E - MedPharm</b>			<b>19</b>	
FO-336393	1/7/2016			in room 3220, the chemical fume hood has a high face velocity (305 fpm). Please have engineer contact me when adjustments are ready to be made.
FO-336394	1/7/2016			Fume hood #3 has a high face velocity (198 fpm). Please have engineer contact me when adjustments are ready to be made.
FO-336395	1/7/2016			Fume hood #2 has a high face velocity (179 fpm). Please have engineer contact me when adjustments are ready to be made.
FO-336396	1/7/2016			Fume hood #10 has a high face velocity (162 fpm). Please have engineer contact me when adjustments are ready to be made.
FO-336397	1/7/2016			Fume hood #12 has a high face velocity (144 fpm). Please have engineer contact me when adjustments are ready to be made.
FO-336418	1/7/2016	1/8/2016		Low water pressure in ladies restroom and no hot water.
FO-336827	1/13/2016	1/13/2016		East end of the 3rd floor is cold, staff are complaining that they feel cool air coming in through the vents, please adjust temp.
FO-336871	1/13/2016			Fume hood #11 in this lab is running too low (68 fpm). Please have the building engineer contact me before adjustments are made so I can take readings.
FO-337301	1/19/2016			Refrig crew. Boiler no. 2 keeps tripping on flame failure. Priority high.
FO-337338	1/19/2016	1/19/2016		In basement room 0413 has a temperature of 68 degrees Fahrenheit. It should be at least at 70-74. The temperature in this room needs to be increased.
FO-337574	1/21/2016			Air filters need to be changed in rooms 404,411,412,413,414,415,416,417,419,423
FO-337585	1/21/2016			LAB 9327 FUME HOOD NOT OPERATING PROPERLY
FO-337677	1/22/2016	1/22/2016		Lab is cold. For further information contact Dr. Holt at 577-5073.
FO-337769	1/25/2016	1/25/2016		AIR FILTER NEED REPLACING - DEBRIS FALLING FROM CEILING. ROOM 30.
FO-338054	1/25/2016			Filters in kitchen need to be changed. There are approximately 21 on the wall. The unit appears to be some type of exhaust. I have submitted pictures to Rick Massa.
FO-337904	1/26/2016	1/27/2016		HIGH TEMPS. ANIMAL QUARTERS - 400 SUITES.
FO-337959	1/26/2016			RM 1348/KITCHEN AREA VERIFY THE STANDARD REFRIGERATOR PROBLEM IT IS GETTING WARM? (see David Barnett after ckng)
FO-338093	1/28/2016			The thermostat on the back side of the proscenium on the south side of the stage has dislodged from the wall. It is hanging too close to our fire curtain purchase line. Please reattach to the wall
FO-338095	1/28/2016			The battery backup system is reading "Output is on bypass". Is this normal? Please reply.  Thanks
<b>E - North</b>			<b>21</b>	
FO-335852	1/4/2016	1/12/2016		Room 225 (2nd floor north) is too warm. Temp is 80 degrees and doesn't respond to manual movement of thermostat.
FO-336130	1/5/2016	1/5/2016		Woodshop area is cold.
FO-336242	1/6/2016	1/7/2016		Once again the heat on the 4th floor on FAB (at least in my area) is out of control - it was over 75 degrees in my office when I arrived at 8:30! This means by the afternoon it will be almost 80 or higher (that's usually what happens - if it's too high i

WO	Recieved	Finished	Total	Request
FO-336262	1/6/2016	1/6/2016		Purdy Library 2nd Floor, Room 231 Staff report that area is rather cold. Please adjust the temperature.  Thank you.
FO-336559	1/11/2016	1/11/2016		Urgent Request: Development suite is very cold. Two drop ceilings have already been installed, but the air that is blowing from the vents is extremely cold. Rooms 3501-3505.
FO-336718	1/12/2016	1/12/2016		Temperature adjustment need in the Kresge Library study area/lobby. Complaints that the temperature is too high.
FO-337028	1/15/2016	1/15/2016		Lecture Hall is extremely warm.
FO-337466	1/20/2016	1/20/2016		NEED ACCESS TO READ METER. SEE ROB LATVA.
FO-337617	1/21/2016	1/21/2016		The power outlet on the east wall of Room 1105 FAB is not working. The occupant of that office tried several different devices to check it and gets no power from either port on that outlet.
FO-337657	1/22/2016	1/22/2016		The air vent over my office sounds like a train is going overhead. Normally, something is closed up in the ceiling so I don't get any air at all, which is what I prefer, but apparently it has been opened somewhere and the noise is quite loud.
FO-337659	1/22/2016	1/22/2016		I have submitted this request yesterday (Request # 279304) and was accepted as work order FO-337626. I received an email the evening of the same day stating that the Work Order is Finished. I came in this morning and found out that the power outlet is sti
FO-337678	1/22/2016	1/22/2016		The heat on the 4th floor of FAB in my area is way too hot - my office is 77.1!! Please turn the heat off or down to something very very low so the natural heat of equipment, people, etc.. can warm up the building without the need to spend so much \$\$\$ he
FO-337721	1/23/2016	1/25/2016		The emergency gas was shut off to this room due to a minor gas smell . Please check the bunsen burners for the area in question.
FO-337741	1/25/2016	1/25/2016		Office too cool. Please adjust temp.
FO-337742	1/25/2016	1/25/2016		Offices 3501-3505 have poor circulation. Please inspect.
FO-337911	1/26/2016	1/26/2016		Kresge Library 3rd Floor Room 315 is cold. Please adjust temperature.  Thank you.
FO-337935	1/26/2016			Purdy Library 3rd FloorWindow ledges over vents 3-5-N, 3-7-N, 3-15-N, 3-17-N: ledge surface is bubbling up and cracking. Areas covered with white powder: concerned it might be mold!Please repair. Contact me with results.Thank you.
FO-338029	1/27/2016	1/27/2016		COLD AIR IS BLOWING FROM VENT. ROOM 2095.
FO-338049	1/27/2016	1/27/2016		Leaves, feathers, and black debris coming into rooms 1515, 1525, and 1545 from the vents. Black soot left on desks.
FO-338050	1/27/2016	1/27/2016		Suite is extremely cold. Please adjust temp.
FO-338114	1/28/2016			The vent in my office has been on for several months. It is very loud and consequently, it is hard to hold conversations with my students. It also throws out quite a bit of dust.
<b>E - Northeast</b>			<b>28</b>	
FO-335886	1/4/2016	1/5/2016		Baseboard heaters not producing heat.
FO-335888	1/4/2016	1/4/2016		Henry Ford Lab door lock mechanism is not broken and the frame around the lock has came off. The lab door number is 1320 Lab entry 1-2 on the Northwest side of the building.
FO-336139	1/5/2016	1/5/2016		Cold Call room 3022
FO-336190	1/5/2016	1/8/2016		Wiring hanging DLAR room 0149.1
FO-336192	1/5/2016	1/8/2016		Electrical outlet needs cover to be replaced in cage wash room 0152
FO-336193	1/5/2016	1/7/2016		DLAR's cage wash rooms have reverse air flow for both rooms Room 0152 is supposed to have Positive air flow to the hallway & Room 0142 is supposed to have Negative air flow to the hallway
FO-336382	1/7/2016	1/27/2016		Please install quick disconnect on air compressor.
FO-336407	1/7/2016	1/7/2016		Please have Engineer check overflow of water , cage area , FP&M Stockroom. Water is draining three times a day , slip hazard.
FO-336719	1/12/2016	1/13/2016		Cold call 1st & 2nd floor open area, eastside of building

WO	Recieved	Finished	Total	Request
FO-336743	1/12/2016	1/12/2016		The stopper on the Henry Ford door by the Cass entrance is falling off.
FO-336782	1/13/2016	1/27/2016		ENTIRE BLDG IS FREEZING WINDOWS ARE ICED UP (Cell #313-980-0808)
FO-336862	1/13/2016	1/13/2016		NO POWER TO BLDG
FO-336907	1/14/2016	1/27/2016		1st flr know wrkng on a problem w/equip however is there anything else that can be done due to the cold
FO-336909	1/14/2016	1/27/2016		2nd flr know wrkng on a problem w/equip however is there anything else that can be done due to the cold
FO-336910	1/14/2016	1/27/2016		Sub-bsmt even though 1st/2nd flrs are cold the sub bsmt is extremely hot
FO-336955	1/14/2016	1/14/2016		RM 149 IS EXTREMELY COLD
FO-337005	1/15/2016	1/15/2016		1st flr know wrkng on a problem w/equip however is there anything else that can be done due to the cold *same req*
FO-337006	1/15/2016	1/15/2016		2nd flr know wrkng on a problem w/equip however is there anything else that can be done due to the cold *same req*
FO-337321	1/19/2016	1/19/2016		RM 125/KITCHEN AREA ACROSS FROM WOMENS RR IN BUS SVCS SECTION HAS NO HOT WATER
FO-337330	1/19/2016	1/19/2016		Room 1202 in the clinic lights are randomly turning off when people are in the room and moving.
FO-337363	1/19/2016	1/19/2016		No power is coming to the outlet behind the printer at the from of suite 1200 in AAB.
FO-337462	1/20/2016	1/20/2016		Our entire building is cold. Please warm it up.
FO-337746	1/25/2016	1/25/2016		Room 109 is COLD. No heat coming from the radiator and the room has many windows. Please send the engineer out ASAP.
FO-337909	1/26/2016	1/27/2016		Cass door is not closing properly.
FO-337922	1/26/2016			Please check again the FP&M Stockroom cage area. Water leaking from heating unit causing a slip and fall hazard. 2nd request.
FO-338133	1/28/2016			Outlet is not receiving power on the back wall under the window as well as the wall on the right hand side. The orange outlets are working on this wall, but the white outlets are not.
FO-338134	1/28/2016			Outlet is not receiving power on the back wall under the window.
FO-338135	1/28/2016			Outlet is not receiving power on the back wall under the window.
<b>E - Preventative Maintenance</b>			<b>22</b>	
FO-333952	1/1/2016	1/29/2016		Boiler Rm CA Damper Filters  12x12x1 Qty: 2 12x24x2 Qty: 2
FO-333982	1/1/2016			Matthaei Filters for OA Intakes in Mech Rms
FO-335925	1/4/2016	1/5/2016		Basement Men's Restroom (Labeled Vacant)  Staff member heard continuous water gushing sound coming from restroom.
FO-336286	1/6/2016			Filter Order for DLAR Labs  20x20x1 Qty: 36
FO-336292	1/6/2016			Filter order for seminar rooms 10x36x1 Qty: 10
FO-336517	1/8/2016	1/8/2016		Water leak coming out the light fixture in the ceiling room 2032
FO-336643	1/11/2016	1/12/2016		office is too cold
FO-336754	1/12/2016	1/12/2016		Received Public Safety call during PM shift on 1-11-16 indicating leak in HW return system in the Student Center.  Stock withdrawal required:  Pipe clamp & 2 rubber boots.
FO-336756	1/12/2016	1/12/2016		I. T. PERSONNEL NEED ACCESS TO TELEPHONE CLOSET. ROOM 117.
FO-336972	1/14/2016	1/15/2016		The thermostat on the back side of the proscenium on the south side of the stage has dislodged from the wall. It is hanging too close to our fire curtain purchase line. Please reattach to the wall. Thanks

WO	Recieved	Finished	Total	Request
FO-336979	1/14/2016	1/29/2016		Once again the heat on the 4th floor in my area is out of control - right now it's 78.3 degrees in my office which is a waste of \$\$\$ for WSU to keep a building heated this high. The last time I submitted the request I believe you ended up turning off the
FO-337023	1/15/2016	1/15/2016		Belt Order B47 Qty:1
FO-337029	1/15/2016	1/25/2016		Replacement Belt Order B72 Qty:1
FO-337369	1/19/2016	1/20/2016		1005 as well as the IIE student (2nd floor) are really COLD
FO-337530	1/20/2016			Extremely cold in the student service room, which sets between room 2011 and 2017
FO-337536	1/20/2016	1/21/2016		Please cover AC units in rooms 111 and 109 to reduce drafts. Both rooms get cold.
FO-337547	1/21/2016	1/25/2016		Replacement Belt Order A-37 Qty: 1
FO-337975	1/26/2016	1/27/2016		Engineering Room 2204 Tau Beta Pi Room has (3) three electrical outlets that are not working. One is under the main whiteboard on the back wall (North wall), one next to the sink (East wall) and one behind the file cabinets (East wall). Please call 586-
FO-337977	1/26/2016	1/27/2016		Please know that my office space is exceptionally warm. The thermostat has been on 50 for a year and it has not cooled down. I am in the Lande Building, office 312 on the 3rd floor. If you would be able to assist in any way I would greatly appreciate it.
FO-338082	1/27/2016	1/30/2016		Fan in cold room is not working.
FO-338237	1/29/2016			The women's bathroom on the 1st floor in the EDC area has a terrible smell coming from it. The smell is seeping out into the hallway. Thank you.
FO-338238	1/29/2016	1/29/2016		Electrical issues -- the plugs on one of the walls aren't working.
<b>E - South</b>			<b>21</b>	
FO-336196	1/5/2016	1/5/2016		Cold air is coming out of vent. Please make sure there is no problem with the heating. Please see Beth Madigan in the Dean's Office for details.
FO-336197	1/5/2016	1/12/2016		Rooms 109 and 111 are cold. Room 101 is too hot. Please adjust heat settings in both areas. Beecher.
FO-336243	1/6/2016			It's very cold in here today especially in the offices. Would it be possible to have the temperature adjusted? Thank you.
FO-336504	1/8/2016	1/8/2016		Hi, Dories I just went to the lab (3310), but the ventilation still did not turn on. Making it worse is that the left fume hood stopped working. Can you put a request.  Two fume hoods in the lab 3310 did not have ventilation. Therefore, students can
FO-336717	1/12/2016	1/14/2016		Very Cold
FO-336751	1/12/2016	1/14/2016		Room is very cold
FO-336951	1/14/2016			Chemical fume hood has a high face velocity (144 fpm)
FO-336952	1/14/2016			Chemical fume hood has a high face velocity (150 fpm)
FO-337049	1/15/2016	1/15/2016		Power fluctuating. Lights go on and off. Microscope will not turn on.
FO-337050	1/15/2016	1/15/2016		Lab is very hot. Over 80 degrees
FO-337297	1/19/2016			The chemical fume hood in this lab has a high face velocity (175 fpm). Please have the building engineer contact me when adjustments are ready to be made.
FO-337298	1/19/2016			PLEASE NOTE: there is no option for room 3137 and there is also no option for "BLDG-Entire Building". The chemical fume hood in room 3137 has a high face velocity (137 fpm). Please have the building engineer contact me when adjustments are ready to
FO-337299	1/19/2016			The chemical fume hood in this lab has a low face velocity (57 fpm). Please have the building engineer contact me when adjustments are ready to be made.
FO-337307	1/19/2016			This is a correction of WO #: 337298. I put down room 3137 when it was supposed to be 4137. The chemical fume hood in this lab has a high face velocity (137 fpm). Please have the engineer contact me when adjustments are ready to be made.



WO	Recieved	Finished	Total	Request
FO-337308	1/19/2016	1/19/2016		1. The sash of hood W10, left side, can't close the hood. 2. The second door, left to right, doesn't work properly. It's difficult to open it from inside- out.
FO-337327	1/19/2016			Chemical fume hood #1 in this room has a high face velocity (163 fpm). Please have the building engineer contact me when adjustments are ready to be made.
FO-337497	1/20/2016	1/21/2016		Several lamp fixtures are no longer working in the 4th floor hallway and in both stairwells that go from the 3rd to the 4th floor and also the fixture that inside the entrance to the greenhouse.
FO-337498	1/20/2016	1/21/2016		Light fixture just inside Cass entrance to Science Hall is not working
FO-337961	1/26/2016	1/28/2016		No hot water in any of the sinks.
FO-337962	1/26/2016	1/28/2016		No hot water in any of the sinks.
FO-337970	1/26/2016	1/28/2016		No hot water (no water at all coming out of the hot water tap - only air).
<b>E - Southeast</b>			<b>12</b>	
FO-336142	1/5/2016	1/5/2016		Section of vinyl baseboard is missing inside Schaver Music Recital Hall. This is an alarmed area. Please forward to Ken Brandt if possible.
FO-336687	1/12/2016	1/12/2016		The work order seems complete, but there is still no heat. Thanks for checking!
FO-336833	1/13/2016			1st floor women's bathroom has a ceiling leak.
FO-337313	1/19/2016	1/20/2016		NO HEAT INSIDE OF THE LAPITA RESTAURANT.
FO-337334	1/19/2016	1/19/2016		LIGHT OUT IN PROJECTION SCREEN. ROOM 1107. PLEASE CHECK CIRCUITS.
FO-337592	1/21/2016	1/21/2016		bldg. engineer Please tighten toilet seat-very loose
FO-337686	1/22/2016			No air circulation/heat. Please reset HVAC system.
FO-337693	1/22/2016	1/26/2016		No heat in room 3209. Temp is at 67 degrees.
FO-338025	1/27/2016			Engineer --Priority medium 1) 5 gals of Oxykor S1100 and 2) 3 bags of salt for water softener
FO-338117	1/28/2016			The heater does not work today. Last time the staff told me it needs some manual reset if it does not work. Thanks for help!
FO-338143	1/28/2016			RESET HEAT PUMPS.
FO-338172	1/29/2016			3rd floor Ladies restroom has a foul odor coming from floor drain.
<b>E - West</b>			<b>8</b>	
FO-336151	1/5/2016	1/29/2016		South main entry handicap operator, emergency exit sign, electric lock and exterior lamp are not working. No power.
FO-336367	1/7/2016	1/29/2016		The storage room on the 2nd floor near the elevators, the ceiling has been leaking there is evidence of dry water splashes
FO-336740	1/12/2016	1/29/2016		NEED ACCESS TO RM 1300 WOULD LIKE TO TEST CSDAVER ALERT CONTROL SYSTEM THAT NOT ALERTING SPECIFIC PERSONS OF ALARMS REGARDING EQUIP
FO-336783	1/13/2016	1/29/2016		Repair exhaust fan at football stadium building head coaches office. Thank You. Bob Ostrowski
FO-336872	1/13/2016	1/29/2016		Office is extremely cold. Need heat!!
FO-336933	1/14/2016	1/29/2016		Classroom too hot! Can't adjust heat by thermostat in room.
FO-337494	1/20/2016	1/29/2016		The auditorium is too hot. The temp is 76 today. Please lower the heat.
FO-337758	1/25/2016	1/29/2016		PLEASE CALL CIERRA REGARDING LAST WEEK'S FLOOD.
<b>Grounds</b>			<b>4</b>	
<b>High</b>			<b>1</b>	
<b>G - Physical Grounds</b>			<b>1</b>	
FO-336543	1/11/2016			OUTSIDE MAIN ENTRANCE RAMP HAS A SHEET OF ICE
<b>Low</b>			<b>3</b>	
<b>G - Moving/Storage</b>			<b>1</b>	

WO	Recieved	Finished	Total	Request
FO-338223	1/29/2016			Stock Issue Request: 2 bags of Flor-Dri 8 packages of AAA Batteries 3 boxes of rags
<b>G - Physical Grounds</b>			<b>2</b>	
FO-335829	1/4/2016	1/6/2016		Please fill receptacles at front and back of the building with snow melt. The front porch was very slippery last Tuesday with the sleet and freezing rain. Fill with calcium or magnesium chloride only (NO ROCK SALT or rock salt blends) as it will damage
FO-336684	1/12/2016			Ramp to get into the parking lot behind the building is very icy and several people have had difficulty driving their vehicles up the ramp. Please put down more ice melt ASAP. Many people walk up this ramp on their way into the back entrance of Beecher
<b>Trades</b>			<b>823</b>	
<b>Emergency</b>			<b>59</b>	
<b>T - Carpenter</b>			<b>8</b>	
FO-336629	1/11/2016	1/12/2016		REPAIR DOOR LOCK. UNABLE TO OPEN DOOR WITH KEY. ROOM 312.
FO-336634	1/11/2016	1/12/2016		RM 4200 KEY STUCK IN LOCK
FO-336944	1/14/2016	1/21/2016		RM 2503 KEY STUCK IN LOCK, OCCUPANT UNABLE TO GET INTO OFFICE. PLEASE CONTACT 248-760-2549 UPON ARRIVAL
FO-336964	1/14/2016	1/15/2016		RM 474 DOOR WONT CLOSE. ANIMAL RMS NEED TO BE SECURED
FO-337393	1/20/2016	1/19/2016		CALL IN TO SECURE Please repair the door key core ( door on right hand side) it can't be locked due to damage.  Carpentry Dept.
FO-337476	1/20/2016	1/20/2016		BOILER RM DOOR OFF ST WONT CLOSE
FO-337946	1/26/2016	1/26/2016		EMERGENCY CARP R/R RM 4305 UNABLE TO UNLOCK DOOR (Experiment is in progress need ACCESS ASAP !)
FO-337969	1/26/2016	1/27/2016		KEY CORE HAS COME OUT OF DOOR LOCK. 1ST FLOOR EVIDENCE CAGE ROOM.
<b>T - Electrician</b>			<b>28</b>	
FO-335851	1/4/2016	1/4/2016		EMERGENCY ELEC R/R LOBBY EAST-DUE TO A POWER BUMP APPR 10:30am ENG'S UNABLE TO RESET ACTIVE FAP ALARM CONFIGURATION PROCESS ERROR
FO-336087	1/5/2016	1/5/2016		AIR HANDLER #2 IS DOWN ON FREEZE STAT. PENTHOUSE.
FO-336088	1/5/2016	1/5/2016		AIR HANDLER #5 IS DOWN ON FREEZE STAT. PENTHOUSE.
FO-336175	1/5/2016	1/5/2016		SILENCE FIRE TROUBLE ALARM PANEL. (BEEPING) 1ST FLOOR LOBBY.
FO-336204	1/5/2016	1/5/2016		ELECTRICAINS TO CHECK THE POWER SUPPLY TO MAIN ENTRANCE TO THE BUILDING SO THE DOORS SECURE
FO-336231	1/6/2016	1/6/2016		AIR HANDLER #1 IS ON FREEZE STAT. PENTHOUSE.
FO-336276	1/6/2016	1/6/2016		CHECK RECIRCULATING PUMP #1 NOT WORKING. ROOM 51.
FO-336341	1/6/2016	1/6/2016		Meet PM Technology technicians, and put generators in Auto.
FO-336535	1/11/2016	1/11/2016		AHU 1, 2, 5 DOWN ON FREEZE STAT.
FO-336597	1/11/2016	1/11/2016		Repair indoor generator leaking coolant. It is labeled as number 1 and 2. It is the unit on the left.
FO-336598	1/11/2016	1/11/2016		Repair outside generators both in alarm. They serve the freezer farms.
FO-336610	1/11/2016	1/11/2016		Replace/Repair rear stairway light at the Presidents Apartment.
FO-336678	1/12/2016	1/14/2016		control air compressor will not run, please check power supply to unit
FO-336745	1/12/2016	1/12/2016		Generators in Over-Crank fault, put generators in manual, and let run for a few minutes. Then put back in Auto.
FO-336810	1/13/2016	1/13/2016		MECH RM 1530 ELECTRICAL PANEL IS IN ALARM, TRANSFORMER RM
FO-336865	1/13/2016	1/13/2016		EMERGENCY ELEC R/R BLDG LOST POWER TO BLDG
FO-336894	1/14/2016	1/14/2016		MECH RM 51 DISCONNECT HOT WATER CIRCULATING PUMP MOTOR
FO-336915	1/14/2016	1/14/2016		EMERGENCY ELEC R/R RM 5168/LAB 2WAY LITE SWITCH DOESN'T STAY ON (Classes are in however it is very dark)

WO	Recieved	Finished	Total	Request
FO-336917	1/14/2016	1/19/2016		EMERGENCY ELEC R/R 1ST FLR FAP FIRE ALARM SYSTEM AUDIO DID NOT ACTIVE @ 10TH FLR ENGS' OFC ONLY STROBE LITES CAME ON. HOWEVER, FROM BSMT UP THRU 9TH FLR AUDIO COULD BE HEARD
FO-336959	1/14/2016	1/19/2016		Check adequacy of available electrical power in the open area in the rear of the first floor of the building. If adequate, connect the two portable heaters that were in the stairwells of Old Main.
FO-337337	1/19/2016	1/19/2016		Check #3 Boiler as to why it isn't in service, and repair if possible.
FO-337354	1/19/2016	1/19/2016		EMERGENCY ELEC R/R DOCK AREA REPAIR/REPLACE BAD CIRCUIT BREAKER/PANEL KEEPS TRIPPING @ THE TRASH COMPACTOR-TRASH IS PILING UP
FO-337699	1/22/2016	1/22/2016		EMERGENCY ELEC R/R BSMT/MECH RM AIR COMPRESSOR WILL NOT RUN (NO AIR)
FO-337747	1/25/2016			2ND FL MRS WILSON'S AREA OUTLETS NOT WORKING, UNABLE TO USE PHONE PLEASE FIX ASAP
FO-337799	1/25/2016	1/25/2016		R/R INSIDE RM 3301 THE ? CONF RM DOUBLE LITE SWITCH SHOCKS YOU WHEN USED ALSO OUTLET THAT IS ALSO ON LITE SWITCH HAS A PRONG STICKING OUT OF IT
FO-337965	1/26/2016			EMERGENCY ELEC R/R BSMT WTR IS RUNNING OUT OF THE ELECTRICAL CONDUIT
FO-338230	1/29/2016			**ADDING ELECTRICIAN: Please hook up pig tail near Engineers office for 220 welder. Emergency Repair being done by Jim Hill on Saturday morning. Needed by 8:30am
				ADDING: Provide bypass to condensate return to bypass domestic water heat exchanger AS
FO-338261	1/30/2016			R/R light pole located on the mall near Linzell House. Pole was hit a knocked over by an automobile.
<b>T - Pipefitter</b>			<b>12</b>	
FO-335891	1/4/2016	1/4/2016		**DUPLICATE WORK ORDER/WORK IN PROGRESS/ REFER TO FO#322859 JWT  EMERGENCY PIPEFITTERS R/R BSMT (BOILER RM) CONDENSATE PUMP ISN'T WRKING CAUSING BOILERS TO HAVE LOW WATER PRESSURE ,,,,,,,,,,,,,, RC/1-4-16 ,,,,,,,,,,,,,,
FO-336141	1/5/2016	1/5/2016		VERY BAD CEILING LEAK. (WATER IS POURING) ROOM 9200. ,,,,,,,,,,,,,,EA/ 1/5/16 ,,,,,,,,,,,,,
FO-336274	1/6/2016	1/6/2016		R/R #1 RECIRCULATING PUMP, PUMP NOT WORKING ,,,,,,,,,,,,,, RC/1-6-15 ,,,,,,,,,,,,,,
FO-336386	1/7/2016	1/7/2016		CONDENSATE LINE LEAKING ONTO ELECTRICAL PANEL. BOILER ROOM.,,,,,,,,,,,,,, JH/1/7/16 ,,,,,,,,,,,,,,
FO-336596	1/11/2016	1/12/2016		CONDENSATE LINE LEAKING ON TO CONTROL PANEL. BOILER ROOM.,,,,,,,,,,,,,, EA/1-11-16 ,,,,,,,,,,,,,,
FO-336696	1/12/2016	1/12/2016		PREHEAT STEAM COIL LEAK. AIR HANDLER #6. MECHANICAL ROOM. ROOM 3320. EA/1/12/16 ,,,,,,,,,,,,,,
FO-336895	1/14/2016	1/14/2016		MECH RM 51 PLEASE TAKE OUT AND REPLACE CIRCULATING PUMP ,,,,,,,,,,,,,, EA/1-14-16 ,,,,,,,,,,,,,,
FO-337086	1/16/2016	1/16/2016		Repair leak in condensate return line at nipple/tee connection at the feed water heater in the boiler rom a Beecher. Leak is dripping on the controls.,,,,,,,,,,,,,, JT/1-16-16 ,,,,,,,,,,,,,,
FO-337649	1/22/2016	1/22/2016		EMERGENCY PIPE R/R RM 00100/MECH RM DISCH PIPE FOR PIT PUMP/#CRP-001 IS SPRAYING OUT & UNTO THE PUMP MOTOR.....JH/RC....1-22-16
FO-337757	1/25/2016			RM 3266 STEM BROKE LEAVING VALVE IN A CLOSED POSITION STEAM TO VALVE NEAR AUTOCLAVE NOT WORKING ,,,,,,,,,,,,,, EA/1/25/16 ,,,,,,,,,,,,,,
FO-337757	1/25/2016			RM 3266 STEM BROKE LEAVING VALVE IN A CLOSED POSITION STEAM TO VALVE NEAR AUTOCLAVE NOT WORKING ,,,,,,,,,,,,,, EA/1/25/16 ,,,,,,,,,,,,,,
FO-338207	1/29/2016			To pipe fitters. Please replace badly leaking nipple on feed water heater line going to FW pump #1. This will require a plant shut down.,,,,,,,,,,,,,, JH/1-30-16 ,,,,,,,,,,,,,,
<b>T - Plumber</b>			<b>11</b>	
FO-336431	1/8/2016	1/8/2016		REPAIR 1/2 INCH HOT WATER LINE IN MAIN LOBBY. WILL HAVE TO TURN WATER OFF TO BUILDING. CONTACT ENGINEER. ,,,,,,,,,,,,,, DB/1-8-16 ,,,,,,,,,,,,,,
FO-336628	1/11/2016	1/12/2016		2ND FL MENS RM URINAL OVERLOWING AT TOP ,,,,,,,,,,,,,, GS/1/11/16 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-336741	1/12/2016	1/20/2016		(**) PO REQ DK 1/27 EMERGENCY PLUM R/R 1ST FLR MENS RR NEAR RM 134 ONE OUT OF 2 URINALS IS PLUGGED & OVERFLOWING ..... GS/1-12-16 .....
FO-336750	1/12/2016	1/12/2016		TOILET IS PLUGGED. 8TH FLOOR UNISEX RESTROOM..... TT/1-12-16 .....
FO-336777	1/13/2016	1/13/2016		EMERGENCY PLUM R/R RM 7341 RECENTLY REPLACED BACKFLOW PREVENTER ON SINK SPRUNG A LEAK FLOODED AREA (water has been isolated) HOWEVER DAMAGED HAS BEEN DONE TO CERTAIN AREAS ..... DB/1-13-16 .....
FO-337607	1/21/2016	1/21/2016		TOILET OVERFLOWING. 2ND FLOOR WOMEN'S RESTROOM. (POURING INTO HALLWAY).....GS.....1-21-16
FO-337619	1/21/2016	1/22/2016		REPAIR BACK FLOW PREVENTER. ROOM 3320.....3rd floor mechanical room.....DB.....1- 21-16
FO-337813	1/25/2016	1/25/2016		EMERGENCY PLUM R/R RM 240/LAB ONLY SINK IS BACKING UP ..... TT/1-25-15 .....
FO-337888	1/26/2016	1/27/2016		sump pump failure or problem water in boiler room ..... DB/1-26-16 .....
FO-337921	1/26/2016	1/26/2016		SUMP PUMP HAS FAILED. CONTACT ENGINEER FOR DETAILS..... GS/ 1-26-16 .....
FO-338176	1/29/2016	1/29/2016		**ENGINEER IS FOLLOWING UP ON THIS 1/29 JWT
				TOILET WATER IS VERY HOT ALSO TOILET HANDLE IS HOT. WOMEN'S RESTROOM. ROOM 502.
<b>High</b>			<b>235</b>	
<b>T - Carpenter</b>			<b>58</b>	
FO-335845	1/4/2016	1/5/2016		R/R LOBBY The latch on the inner door is broken. The door cannot be opened from the outside. DOOR NEEDS REPAIRING BEFORE CLOSURE BLDG WILL BE OPEN
FO-335880	1/4/2016	1/5/2016		1ST FL WOMENS RM, KEY GETS STUCK IN LOCK
FO-335902	1/4/2016	1/6/2016		CARPENTERS (MED HIGH)
				AHU #1 ROMM 139 SUPPLY HATCH BROKEN CAUSING HEATING ISSUES. REPAIR/REPLACE
FO-335893	1/4/2016	1/5/2016		R/R ENTRY DOORS #S' 006-01; 02; 03; 04; 05; & 06 PLEASE TROUBLESHOOT These exterior doors they are not closing "hard enough" to latch in the evening after the doors are locked for the night. If someone exits the building after they are locked they will n
FO-335917	1/4/2016	1/5/2016		DOOR # 209-01S DOOR SCRAPPING THRESHOLD
FO-336134	1/5/2016	1/6/2016		Door 203-05S does not secure because door doesn't close flush.
FO-336251	1/6/2016	1/6/2016		Repair hole in south exterior wall where rodents are entering the building. Dig down below grade stuff with steel wool and caulk. Hole is where the marble meets the brick.
FO-336288	1/6/2016	1/7/2016		**ADDING CARPENTER: Please install 36"x36" plywood to cover rusted out steel plate at bottom of stairs. This is temporary. See Gerry (Plumber) if needed
				The steel plate cover over the sump pump pit at the base of the basement stairs is rusted through
FO-336293	1/6/2016	1/6/2016		RM 6205 DOOR LOCK NOT WORKING
FO-336385	1/7/2016			LOADING DOCK GARAGE DOOR DOES NOT LIFT
FO-336399	1/7/2016	1/8/2016		HALL ENTRANCE DOOR WILL NOT OPEN WITH KEY. ROOM 178.
FO-336440	1/8/2016	1/11/2016		Purdy Library, 1st Floor, Room 122 (Offices of HR, Region B).
				Door to offices will not close. Security issue for HR. Please repair.
				Thank you.
FO-336514	1/8/2016			Follow up on work order - FO 334978 from December. I have received another request/complaint today since the floor is loose in front of the door that students use....
				Several "asbestos" floor tiles on the first floor are cracked and loose or missing i
FO-336546	1/11/2016	1/12/2016		Key sticking in lock and becoming hard to get out

WO	Recieved	Finished	Total	Request
FO-336550	1/11/2016	1/12/2016		FRONT ENTRANCE DOOR IS NOT OPENING WITH KEY. CONTACT TAQUANDRA AT THE FRONT DESK.
FO-336551	1/11/2016			LOADING DOCK AREA MIDDLE DOOR NOT WORKING, DOOR IS STUCK OPEN
FO-336617	1/11/2016	1/12/2016		**ADDING CARPENTER: Please provide plywood 3/4"x 4'x 4' to cover sump hole. See Gerry (Plumber)
				Please repair or replace sump pump #4. Pump is seized. Pump was previously disconnected electrically. GS/12-10-15 **MATE
FO-336721	1/12/2016	1/13/2016		R/R RM 308.1 INSIDE DOOR KNOB NEEDS TO BE TIGHTEN DUE TO IT IS VERY LOOSE
FO-336794	1/13/2016	1/14/2016		Stairwell J (SW corner) inner stairwell door to basement from 1st floor is hard to open. Handle and latch are broken.
FO-336795	1/13/2016	1/13/2016		DOCK GATE, PADLOCK IS VERY DIFFICULT TO OPEN AND CLOSE POSSIBLY FROZEN
FO-336840	1/13/2016	1/14/2016		RM 5341 DOOR IS HARD TO CLOSE
FO-336953	1/14/2016	1/15/2016		BLOCK OF ROOF VENT TO NUMBER -1 ELEVATOR TO STOP SNOW FROM ENTERING THE ELEVATOR HOISTWAY.
FO-336974	1/14/2016	1/15/2016		Ladies restroom - door handle and lock do not work correctly. Handle is sometimes hard to operate and it is difficult to lock door.
FO-336987	1/15/2016			Women's Softball Facility Bldg #099
				Need to use lift to service a ceiling mounted heating unit. Unit is located above sand pit in batting area.
				Please install plywood supports over sand pit so that lift can be moved in place to provide access to un
FO-337054	1/15/2016	1/19/2016		Doorknob from the inside of room 1320 (old lab wing) is difficult to turn. Please contact Howard Matthew at hmatthew@wayne.edu or 7-5238 for additional information.
FO-337063	1/15/2016	1/19/2016		Locksmith: Please repair mechanical room door handle/hardware. Lock turns without problem, but something is hanging up making door hard to open, especially when trying to exit room. High Priority.
FO-337088	1/16/2016	1/21/2016		**ADDING CARPENTER: Erect 30" wide baker scaffold with wheels in basement room 14. See Gerry (PLUMBER) for location
				EMERGENCY PLUM R/R 1ST FLR MENS RR NEAR RM 134 ONE OUT OF 2 URINALS IS PLUGGED & OVERFLOWING GS/1-12-16
FO-337303	1/19/2016	1/19/2016		KEY WON'T TURN IN DOOR LOCK. DOOR LEADING TO SHIPPING AND RECEIVING. CONTACT EUGENE CARTER.
FO-337314	1/19/2016	1/20/2016		OUTER FRONT ENTRANCE DOOR STICKS OPEN AND WILL NOT CLOSE.
FO-337381	1/19/2016	1/20/2016		Door is not able to open and close. There are two doors to this room, one works, the other does not.
FO-337392	1/19/2016	1/20/2016		Locksmith  Repair broken door handle on 89 08N exterior door for receiving room.  h High Priority
FO-337460	1/20/2016	1/21/2016		trade carpenters priority high please repair entrance door at receiving door handle is broken and its hard to get into the door the handle will come off
FO-337519	1/20/2016	1/21/2016		KEY TURNS IN DOOR LOCK. ROOM 236.
FO-337532	1/20/2016	1/21/2016		RM 122 KEYS GET STUCK IN LOCK
FO-337549	1/21/2016	1/22/2016		The nFab clean room lock is not working with a key. The key cannot rotate in the lock. The door is across from room 3310. Please contact Bill Funk at (586) 216-9128 to meet at door. Thank you.
FO-337567	1/21/2016	1/22/2016		The door knob on the side door of room 2530 needs to be looked at. It does not move from the outside and sometimes it sticks from the inside too.  Please note this is not the main door to the room. It's the side door on the east wall of the room next t

WO	Recieved	Finished	Total	Request
FO-337573	1/21/2016	1/22/2016		RM 324 PROJECTION SCREEN WONT STAY DOWN
FO-337602	1/21/2016	1/21/2016		DOOR #03-EAST (FRONT ENTRANCE DOOR) TOP HINGE SCREWS ARE LOOSE.
FO-337609	1/21/2016	1/22/2016		The key core in study room #1377 is broken. The key will not fin into the lock to secure the door. Law students use this study room daily and need to secure to room. Please consider this an emergency request. Thank you.
FO-337618	1/21/2016	1/22/2016		Rm. 1366's door handle is very loose. It is on the inside and it is about to come off; please repair.
FO-337661	1/22/2016	1/25/2016		FRONT ENTRANCE DOOR HANDICAP BUTTON IS NOT WORKING. DOOR WILL NOT OPEN.
FO-337670	1/22/2016	1/25/2016		The West door (employee) is still not latching correctly, (previous reqs.-250781,257424). It is believed non-university people may be entering the building during off hours.
FO-337673	1/22/2016	1/25/2016		East entrance door to gross anatomy lab is not closing completely by itself. Please adjust. This is a security issue. For questions, contact Marcia Figurski at 7-1198.
FO-337685	1/22/2016	1/22/2016		PLEASE OPEN LOCKER #640 - LOCKER HANDLE IS BROKEN OFF. STUDENT NEED BELONGINGS INSIDE LOCKER. CONTACT SHERYL MCGILLIS.
FO-337694	1/22/2016	1/25/2016		CARP R/R RM 1140 DOUBLE DOORS THE IN-ACTIVE DOOR ISN'T LOCKING
FO-337770	1/25/2016	1/26/2016		Repair leaking window for Arthur on the 3rd floor West window.
FO-337929	1/26/2016	1/29/2016		SOUTH SIDE OF AUDITORIUM, HALLWAY FABRIC WALLS PANEL HAS FALLEN OFF
FO-337952	1/26/2016			Tiles loose - about a 20x20 ft area of the flooring - tiles loose and coming up - TRIP Hazard in the Lab.
FO-337951	1/26/2016	1/27/2016		NEAR FRONT ENTRANCNE, CUSTODIAL CLOSET DOOR DOES NOT CLOSE
FO-337980	1/26/2016	1/27/2016		DOOR 062-03W STAYS AJAR
FO-338015	1/27/2016	1/27/2016		The inside door knob on the west door to Room 1320 (CHE undergrad laboratory) is very hard to turn. Thank you.
FO-338030	1/27/2016			Carpenters:Please repair the lifting floor tiles in the hallway just below the photo of the class of 2010. About four or five tiles are loose.High priority, trip hazard.
FO-338046	1/27/2016			STAIR THREAD COMING UP. 1ST FLOOR STAIRWELL A. 1ST STEP.
FO-338113	1/28/2016	1/28/2016		The double fire doors leading to the ROTC area are unable to close completely.
FO-338144	1/28/2016	1/29/2016		WEST DOOR - Doorknob from the inside of room 1320 (old lab wing) is difficult to turn. Please contact Howard Matthew at hmatthew@wayne.edu or 7-5238 for additional information.
FO-338205	1/29/2016			Carpenters:Please replace the ten or twelve lifting and loose floor tiles due to a heating system pipe leak. High Priority.
FO-338204	1/29/2016			Key pad needs a battery replaced, will not open using code. This urgent!! Thanks
FO-338252	1/29/2016			URGENT REQUEST: The center is due for an accreditation review any day and this issue is a safety violation. The release latch on the emergency exit gate for the enclosed yard space is jammed. We are unable to open the gate in case of fire or other emergen
<b>T - Electrician</b>			<b>61</b>	
FO-335794	1/1/2016	1/4/2016		please have electricians check low battery alarm on fire panel in room 0207. high priority.
FO-335885	1/4/2016	1/6/2016		please have electricians R/R RM 7320 replace lights in fume hood 7320. high priority. NOTE: Eng doesn't have any lites for FH
FO-335918	1/4/2016	1/4/2016		R/R 1ST FLR STAFF LOUNGE TROUBLESHOOT BREAKER UBABKE TO RESET NO LITES & POSSIBLE WALL OUTLETS
FO-336109	1/5/2016	1/8/2016		Elect. High Priority Repair / warranty work. R/R ROOF PRV #3 has not worked correctly since day one. Unit does not run in auto or hand. I must put in by pass and turn the P.O.T. up to 100% and it will only reach .56in water col. SP is 1.5 in wate
FO-336110	1/5/2016	1/8/2016		Elect. High Priority Please repair PRV #2 unit in auto and are putting out only .13 in water col. SP is 1.5 in water col. I can not balance the building and or exhause hood labs at these pressures

WO	Recieved	Finished	Total	Request
FO-336111	1/5/2016	1/8/2016		Elect. High Priority Please repair PRV #4 unit in auto and are putting out only .13 in water col. SP is 1.5 in water col. I can not balance the building and or exhause hood labs at these pressures
FO-336148	1/5/2016			Move box in basement machine room up about 6", enough for the door on the panel next to it to be able to open fully. See Attached Photo
FO-336188	1/5/2016	1/8/2016		R/R STRWL H 1ST FLR please have electricians repair broken thermostat and check motor for operation in stairwell H 1st floor near cafeteria. high priority.
FO-336249	1/6/2016	1/6/2016		Repair light in the north hallway. See Jason for location. Must be done before home game Thursday.
FO-336330	1/7/2016	1/8/2016		Electricians-Remove both timers off the ahu #4 (child care fan) in room 25 (basement). There are two timers on this fan an both are to be removed ASAP. Under no circumstances are these to be allowed to stay. One is on the wall near the sump pumps and t
FO-336413	1/7/2016			Time for Safety Meeting for month of January 2016.
FO-336473	1/8/2016	1/28/2016		There is a light out in the chemical storage room (270.1), and it makes it a poorly lit area. Over 2000 chemical containers are stored in this area, causing it to be a safety concern.
FO-336500	1/8/2016			Please install existing aquastat and so we can put pump back in service. The Fitters (John T) told me that the new pump install is completed.
FO-336554	1/11/2016	1/12/2016		R/R RM 7320 please have electricians replace ballast on fume hood in 7320. high priority
FO-336604	1/11/2016	1/12/2016		ELECTRICAL DEPT- R/R BLDFG EXTERIOR LIGHTS OUT ON NORTH SIDE OF BLDG BOTH SETS OF LIGHTING OUT DARK AT NIGHT AND IN MORNING PRIORITY HIGH
FO-336594	1/11/2016	1/15/2016		**ADDING ELECTRICIAN: Please disconnect 1 hydronic heat pump located in basement on 1/11/16. See Ron Clark for which one to disconnect  (**) PO #2 REQ DK 12/9 (**) PO REQ DK 10/29 Pipefitters to replace heating hot water pumps #4 and 3 located in UG
FO-336608	1/11/2016	1/12/2016		CHECK PANEL - BATTERY TROUBLE. FIRE TROUBLE ALARM.
FO-336759	1/12/2016	1/13/2016		Trade: Electricians Priority: High R/R Please repair space heater in the north overhang. Breaker immediately trips when reset.
FO-336761	1/12/2016	1/27/2016		R/R STRWL H 1ST FLR please have electricians repair broken thermostat and check motor for operation in stairwell H 1st floor near cafeteria. high priority.  Copied work order to have FO number to replace motor.
FO-336770	1/13/2016			The alarm horn for the fire evacuation system DOESN'T work , during fire test the horn inside willn't alert the building staff of a fireThis is for the Electrical Department.
FO-336776	1/13/2016	1/14/2016		pls repair unit heater in boiler room office
FO-336781	1/13/2016			ELECTRICIANS, R/R R, 2155 PLEASE REPAIR BAD MOTOR ON HCFC UNIT. PRIORITY-HIGH
FO-336792	1/13/2016	1/19/2016		2nd floor Women's R/R (next do custodial closet) - All lights are out.
FO-336802	1/13/2016	1/19/2016		BSMNT HALLWAY OUTSIDE 0501, OUTLET COVER KNOCKED OFF THE WALL
FO-336836	1/13/2016	1/13/2016		Please repair light on rear stairway at the Presidents apartment that was repaired Tuesday 1/12/2016. Henrietta says it went out sometime last night.
FO-336876	1/13/2016	1/15/2016		Complete wiring to UPS, and 100amp panel.
FO-336932	1/14/2016			there are (10) fitures in front of rooms 2042 through 2055...this area is used for students that are waiting to see the academic advisors...Paperwork is being filled out in this area...
FO-336966	1/14/2016	1/14/2016		Unplug Chrixtmas lights from tree, coil up, and leave on ledge outside of window.
FO-336976	1/14/2016	1/15/2016		RM 309 CLOCK MAKING A LOUD TICKING NOISE.
FO-337015	1/15/2016			Trade: Electricians Priority: High R/R RM SB47/MECH RM The contactor for condensate pump #1 is tripping. Please repair. Condensate tank is located underneath the surge tank in the Chemistry sub-basement.
FO-337056	1/15/2016			Power fluctuating. Lights go on and off. Microscope will not turn on.

WO	Recieved	Finished	Total	Request
FO-337068	1/15/2016	1/16/2016		<p>**ADDING ELECTRICIAN: Please assist in replacing vacuum switch. See description below</p> <p>trade plumbers priority high please service vacuum pump in basement mech rm only runs up to 15inch and shuts off this should be around 22inch my need new switch in</p>
FO-337085	1/16/2016	1/16/2016		<p>LIFE GUARD TEMPERATURE CONTROL ALARM IS GOING OFF. MECHANICAL ROOM 1530.</p> <p>Time for Electricians to assist Utilities Instrumentation to make repairs.</p>
FO-337087	1/16/2016	1/20/2016		<p>**ADDING ELECTRICIAN: See Jim Hill : Please order replacement float switch for receiver in stockroom 033 and assist install when part is received (PART: SQUARE D CLASS 9038 TYPE DG-8 )</p> <p>Trade: Pipefitter Priority: High Please repair or replace</p>
FO-337271	1/19/2016			Lights in stage area acting funny, lights will not cut off, some they can't get to come on, but check them all.
FO-337356	1/19/2016	1/19/2016		Meet Healy in basement, and bypass fire panel for them, then put it back in re-activate it when the complete their job.
FO-337368	1/19/2016	1/21/2016		RM 3374 CLOCK NOT WORKING
FO-337396	1/20/2016			<p>OPEN UP TO ELECTRICIANS, REMOVE ELECTRICAL HOOK UP LOCATED IN SIDE FOUNTAIN CASE, SEE TROY TAYLOR FOR MORE INFO*****(**) PO REQ DK 1/4</p> <p>R/R 3RD FLR HALLWAY Water is leaking from UNDERNEATH @ WALL NEXT TO the water</p>
FO-337511	1/20/2016	1/21/2016		Electricians: please trouble shoot and restore power to south side of mechanical room light fixtures, it is totally dark. Priority: high.
FO-337512	1/20/2016	1/21/2016		Electricians-please check circuits 1, 3, 5, and 7 in Panel MB-A located in room 107 (suite 100). Circuits losing power without breaker tripping. Breakers also have excessive 'wiggle' within panel.
FO-337610	1/21/2016	1/21/2016		<p>Our fume hood labeled EF-32 is does not turn on when we switch it on. It seems as though the switch is broken. Can we have this looked at?</p> <p>Thanks! Eric</p>
FO-337627	1/21/2016			<p>Cable failure needs immediate repair.</p> <p>Electricians found Cable in opposite cabinet in need of service also.</p>
FO-337633	1/21/2016			Please repair the ground fault in fire the Main fire panel at Bonstelle
FO-337646	1/22/2016	1/25/2016		<p>please have electricians troubleshoot R/R 1ST FLR W. STRWL unh heater on ground floor west stairwell area near loading dock. high priority. see pbj</p>
FO-337700	1/22/2016			Trade: ElectricianPriority: HighR/R The west control air compressor in the Chemistry penthouse has been operating erratically. On 1/20/16 it failed to start resulting in all fume hoods in the north half of the building and AHU 1 & 2 shutting down. On
FO-337737	1/25/2016			<p>**ADDING ELECTRICIAN: Please Reconnect new 1 hydronic heat pump located in basement **Also Disconnect # 2 heat pump. SEE RON CLARK</p> <p>Pipefitters to replace heating hot water pumps #4 and 3 located in UGL basement. The #4 pump leaks and is OOS. The #</p>
FO-337755	1/25/2016			Fire Alarm sounding, and Technician from Simplex onsite. Assist Tech., and make sure he orders the bad card.
FO-337764	1/25/2016	1/25/2016		In the Garage for the Presidents Apartment the Back-Up Alarm has fallen off the wall, please replace it, and also call Henrietta (577-4882)to check the Doorbell.
FO-337790	1/25/2016			Meet at the Bonstelle Theatre Tuesday at 8AM to simulate a power outage at the UPS, check to assure it carries the lighting, and list what else is supported by the UPS.



WO	Recieved	Finished	Total	Request
FO-337890	1/26/2016	1/28/2016		Trade: Electrician Priority: High (a) Fire alarm system not annunciating after pulling pull station. (b) Ground fault alarm IN/OUT. (c) Fire alarm sensor from boiler room (Heat sink) causing active fire alarm at public safety. If no parts then
FO-337931	1/26/2016	1/28/2016		**ADDING ELECTRICIAN: Please disconnect domestic hot water recirculation pump in Plumber lock up near Pipe Shop. See Gerry (Plumber) if needed **Also provide VOLTAGE AND PHASE to John Towle for replacement
				125/KITCHEN AREA ACROSS FROM WOMENS RR I
FO-337933	1/26/2016	1/27/2016		3RD FL OUTSIDE 305 LIGHT MAKING A CHIRPING NOISE
FO-337942	1/26/2016	1/27/2016		STE 3100 CLOCKS HAVE BEEN OUT FOR THE PAST WEEK
FO-337950	1/26/2016	1/28/2016		Light flickering and buzzing in the basement graduate research office. Light is labeled
FO-337964	1/26/2016	1/28/2016		Investigate water leaking into basement on southeast corner of the building. Water entering through electrical conduit.
FO-337971	1/26/2016			Check, and set limit switches on gate so it will close without causing the chain to come off.
FO-338042	1/27/2016			AC-17, investigate and correct cause of faulty motor operation.
FO-338074	1/27/2016	1/28/2016		CORDS ARE VERY LOOSE AND KEEP FALLING OUT OF WALL OUTLET. ROOM 28.
FO-338089	1/27/2016			This is for the elertical Department please drain water out of light in room 1215 due to leak from room 2215 . leak is stopped for now.
FO-338094	1/28/2016			The main circuit breaker labeled "House lights" is off yet the house lights are on. Is this normal? Please reply.
FO-338163	1/29/2016			ADDING ELECTRICIAN : Check switck boxes for sump pumps in basement storage room. When shut off they continue to run. See Gerry (Plumber) if needed *Also check flood alarm *Update Bob O
				(**) PO REQ DK 12/7 Repair #1 sump pump located in Storage Roo
<b>T - Locksmith</b>			<b>8</b>	
FO-336255	1/6/2016	1/6/2016		New Key Lost / Stolen Key #: 101035 Key Holder ID: Derek Donnellon Qty: 1
				action: PLEASE RUSH ONE REPLACEMENT KEY FOR 703 W KIRBY IN TOWERS RESIDENTIAL SUITES Account #: 163311
FO-336699	1/9/2016	1/15/2016		Replacement Lost / Stolen Key #: AA211 Key Holder ID: Juanitta Hill Qty: 4
				action: I would like at least one (1) asap. Thank you.
FO-336698	1/9/2016			ReplacementLost / StolenKey #: SL15Key Holder ID: Juanitta HillQty: 4action: I would like at least one (1) asap. Thank you.
FO-336667	1/12/2016	1/15/2016		113X, X3171, 110X 138X & 10SA-7
FO-337817	1/25/2016	1/26/2016		New Key Lost / Stolen Key #: 6175 Key Holder ID: Linda Mayernik Qty: 2
				action: 2-keys for room 376

WO	Recieved	Finished	Total	Request
FO-337937	1/26/2016	1/27/2016		1-Key # for room 115 Sci & Engineering Library  Key # 28017
FO-337996	1/27/2016			New KeyLost / StolenKey #: 27951, 27832 27834Key Holder ID: Nate CristQty: 2 of eachaction: Please supply 2-keys ea. for rooms 147, 157 & 159
FO-338115	1/28/2016			Please provide 2-Keys #66266
<b>T - Painter</b>			<b>1</b>	
FO-337315	1/19/2016			EAST STAIRWELL BETWEEN 3RD AND 4TH FL CRUMBLING PLASTER FALLING
<b>T - Pipefitter</b>			<b>43</b>	
FO-335814	1/4/2016	1/6/2016		**REFER TO ROOFING WORK ORDER FO#336376 / AND PUMP REPAIR WORK ORDER FO#336349 JWT  (2) ACTIVE CEILING LEAKS ON 4TH FL, ONE IS WITHIN RM 4222 WATER LEAKING DOWN TO 3RD FL ALSO OPPOSITE END OF HALL ACTIVE CEILING LEAK ,,,,,,,,,,,,,,,,,, EA/1-4-15 ,,,,,
FO-335818	1/4/2016	1/5/2016		CEILING LEAK. ROOM 1351. ,,,,,,,,,,,,,,,,,, ME/1-4-15 ,,,,,,,,,,,,,,,,,
FO-335901	1/4/2016	1/6/2016		Pipefitters: Please repair steam radiator leak. Priority: Medium ,,,,,,,,,,,,,,,,,, EA/1-5-16 ,,,,,,,,,,,,,,,,,
FO-335903	1/4/2016	1/5/2016		Pipefitters High, Thaw and correct drain line pitch on cooling tower to eliminate sagging sections from holding water. ,,,,,,,,,,,,,,,,,, ME/1-5-16 ,,,,,,,,,,,,,,,,,
FO-336090	1/4/2016	1/5/2016		**REFER TO ROOFING REQUEST FO#336376/ THIS IS NOT A PIPE REPAIR JWT  The ceiling has leaked for the third time in a year, in room 409, carpeting is soaked, and ceiling tile fell down again. Door is open for inspection. ,,,,,,,,,,,,,,,,,, EA/1/5/16 ,,,,,,
FO-336095	1/5/2016	1/14/2016		Pf High Priority Please repair or blow up Steam coil leaks AHU #7. ,,,,,,,,,,,,,,,,,, ME/1/5/16 ,,,,,,,,,,,,,,,,,
FO-336108	1/5/2016	1/5/2016		*REFER TO ROOF REPAIR REQUEST FO#336376/ THIS IS NOT A PLUMBING ISSUE JWT  **ADDING PLUMBER FOR 1st ceiling leak in room 4222. Possible vent stack. See Eric Adams for location ,,,,,,,,,,,,,,,,,, TT/1-5-16 ,,,,,,,,,,,,,,,,,  ,(2) ACTIVE CEILING LEAKS ON 4
FO-336333	1/6/2016	1/12/2016		Steam Fitters- High Priority- Please replace reheat coil valve stuck in the closed position. in lab 2205. Room is tracking at 64 degrees and occupants are uncomfortable.,,,,,,,,,,,,,,,,,, EA/1-8-16 ,,,,,,,,,,,,,,,,,
FO-336375	1/7/2016	1/13/2016		please have pipefitters repair leaking pre-heat coil on ahu-13 high priority ,,,,,,,,,,,,,,,,,, EA/1/8/16 ,,,,,,,,,,,,,,,,,
FO-336568	1/11/2016	1/13/2016		Fitters, please repair steam coil on AHU-5. Priority: high ,,,,,,,,,,,,,,,,,, ME/1/-11-16 ,,,,,,,,,,,,,,,,,
FO-336626	1/11/2016	1/13/2016		CEILING LEAK. ROOM 3108. ,,,,,,,,,,,,,,,,,, EA/1-11-16 ,,,,,,,,,,,,,,,,,
FO-336706	1/12/2016	1/20/2016		Pipefitters: High, Please replace valve for booster coil for room 322. Valve located outside office above ceiling. ,,,,,,,,,,,,,,,,,, ME/1-12-16 ,,,,,,,,,,,,,,,,,
FO-336710	1/12/2016	1/13/2016		*DUPLICATE / REFER TO FO#336626  CEILING PIPE LEAK. ROOM 3108.
FO-336758	1/12/2016	1/25/2016		Trade: Pipefitters Priority: High R/R RM 00018/MECH RM Please repair leaking in heating coil in AHU 1. ,,,,,,,,,,,,,,,,,, EA/1-15-16 ,,,,,,,,,,,,,,,,,
FO-336853	1/13/2016			Pipe fitters: please repair or replace reheat control valve foe room 212 it is leaking through and the office is hot. the unit is in south side of fish bowl second unit from west. Priority: high. ,,,,,,,,,,,,,,,,,, ME/1-18-16 ,,,,,,,,,,,,,,,,,
FO-336888	1/14/2016	1/19/2016		STEAMFITTERS-PLEASE REPAIR/REPLACE 1" GATE VALVE ON CHEMICAL FEED SYSTEM TO HYDRONICS FOR THE BLDG,STRIPPED CAN TELL IF ITS OPEN OR CLOSED,CAN PUT CHEMICALS IN SYSTEM HIGH PRIORITY ,,,,,,,,,,,,,,,,,, EA/1-14-16 ,,,,,,,,,,,,,,,,,
FO-336926	1/14/2016	1/15/2016		Ceiling is leaking, have had to move prints to keep them dry. ,,,,,,,,,,,,,,,,,, EA/1-15-16 ,,,,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-336975	1/14/2016			102.8 RADIATOR LEAKING  Please address ASAP. Engineer investigated. Leak is damaging carpet. Issued work order FO-335087 Back in December. Problem has gotten worse.  Engineer did not isolate system in an effort to avoid a freeze-up. ,,,,,,,,,,,,,,
FO-336988	1/15/2016	1/19/2016		Steamfitters R/R PH Please replace water regulating valve to hydronic system for 3th floor heating. Priority HIGH !! ,,,,,,,,,,,,,, EA/1-15-16 ,,,,,,,,,,,,,,
FO-336990	1/15/2016			Steamfitters R/R RM 3320/MECH RM Please replace preheat steam regulating valve on AC-6 .Priority High ,,,,,,,,,,,,,, EA/1-18-16 ,,,,,,,,,,,,,,
FO-337007	1/15/2016	1/20/2016		Trade: Pipefitter Priority: High Please repair or replace condensate tank float controls. Pumps are not coming on. Pumps will run in hand or if the level control is manually operated. ,,,,,,,,,,,,,, JH/1-15-16 ,,,,,,,,,,,,,,
FO-337403	1/20/2016			Steam leak in radiator in room 1106-08. Dan foss valve is cracked.....ME....1-21-16
FO-337426	1/20/2016			RM 411/413 ACTIVE CEILING LEAK.....ME...1-20-16
FO-337446	1/20/2016			**WORK IN PROGRESS 1/21 JWT  RM 313 ACTIVE CEILING LEAK.....ME...1-20-16
FO-337473	1/20/2016			leak right above the front desk. Looks like it's coming from the trap.....GS....1-20-16.....Turn over to Fitters...ME.....1-20-16
FO-337478	1/20/2016			Trade: Electricians Priority: High R/R RM SB47/MECH RM The contactor for condensate pump #1 is tripping. Please repair. Condensate tank is located underneath the surge tank in the Chemistry sub-basement.  OPEN TO FITTERS:  Motor seems
FO-337528	1/20/2016	1/21/2016		Trade: Pipefitter Priority: High Please repair leaking steam coils in AHU #1.....ME...1-21-16
FO-337533	1/20/2016	1/21/2016		RM 313 ACTIVE CEILING LEAK, 3 AREAS LEAKING.....EA....1-21-16
FO-337550	1/21/2016			OPEN UP TO FITTERS DON B LOOKED AT AND DETERMINED IT TO BE A FITTER/STEAM ISSUE*** .....JH/RC.....*****Matthaei M. Faculty Locker Room....Room 154.1 - - No hot water in showers or sink - Please rush repair.....DB.....1-21-16 Thank You. Bob Ostrows
FO-337600	1/21/2016	1/22/2016		RADIATOR HANDLE WON'T TURN. LOBBY (CONTACT MICHAEL IN THE BOX OFFICE).....JH/RC.....1-21-16
FO-337608	1/21/2016	1/22/2016		Pipefitters --Priority High Handicap Restroom heater will not get hot. Bad vent valve.....JH/RC...1-21-16
FO-337625	1/21/2016	1/22/2016		Rooms 109 and 111 get cold in the afternoon. Engineer found boilers on line. Traps may be full of water due to the angle of radiator, this is for the fitters for repair.....ME.....1-22-16
FO-337710	1/23/2016	1/25/2016		Trade: Electrician Priority: High R/R The west control air compressor in the Chemistry penthouse has been operating erratically. On 1/20/16 it failed to start resulting in all fume hoods in the north half of the building and AHU 1 & 2 shutting down.
FO-337778	1/25/2016			Trade: Pipefitter Priority: High Domestic hot water is at 190 degf. The tank is heated by the condensate returning from the building. There are presently no controls on this system. Please install an automatically controlled diverting valve that wi
FO-337901	1/26/2016			Steamfitters please tighten all flange connection on hydronic heating system,leaking profusely !! OR- replace-GASKETS. priority HIGH ,,,,,,,,,,,,,, EA/1-26-16 ,,,,,,,,,,,,,,
FO-337917	1/26/2016			High Priority: Water leaking from wall/radiator in suite 2209. Floor tiles are coming up. Trip hazard. ,,,,,,,,,,,,,, ME/1-26-16 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-338036	1/27/2016			PIPEFITTERS R/R GARAGE/DOCK (BAY AREA) CLNG UNIT HEATER IS LEAKING CAUSING FLOODING IN AREA ,,,,,,,,,,,,,, EA/1-27-15 ,,,,,,,,,,,,,,
FO-338055	1/27/2016			Repair steam leak in tunnel from Chatsworth to SCB. Job may require coordinated steam shut down. Must be done asap. See Duane Coplen for details/logistics. ,,,,,,,,,,,,,, JH/1-28- 16,,,,,,,,,,,,,
FO-338109	1/28/2016			In the Learning Resource Center's study room #322, leaking from the ceiling has been reported to the Business Office. Also, ceiling tiles are stained. Please repair/replace. ,,,,,,,,,,,,, JH/1-28-16 ,,,,,,,,,,,,,,
FO-338124	1/28/2016			LAB 60 CEILING LEAK ,,,,,,,,,,,,,, ME/1-28-16 ,,,,,,,,,,,,,,
FO-338156	1/28/2016			ADDING: Provide bypass to condensate return to bypass domestic water heat exchanger ASAP. Pipe so that diversion valve can be installed when it is received from FO#337778JH and Bypass would remain ,,,,,,,,,,,,,, JH/1-18-16 ,,,,,,,,,,,,,,
				Priority:
FO-338170	1/29/2016			Pipefitters: MED HIGH. Location PH. Please install new blr. make-up water meter. New meter is on-site and will be replacing existing bad water meter. Make-up water can be by-passed around meter, no shut down of blr. required. ,,,,,,,,,,,,,, ME/1-29
FO-338188	1/29/2016			0356 HYDRONIC LEAK FROM PIPING ,,,,,,,,,,,,,, EA/1-29-16 ,,,,,,,,,,,,,,
<b>T - Plumber</b>			<b>62</b>	
FO-335796	1/1/2016	1/26/2016		PLUMBERS: PLEASE REPAIR LEAKIG FAUST IN ROOM 6111, PRIORITY HIGH, ISOLATED HOT AND COLD WATER SUPPLY ,,,,,,,,,,,,,, MM/1-4-15 ,,,,,,,,,,,,,,
FO-335806	1/4/2016	1/5/2016		TOILET PIPE LEAK. (WHEN TOILET IS FLUSHED) 2ND FLOOR LADIES RESTROOM. REGULAR STALL,,,,,,,,,,,,, TT/1-4-15 ,,,,,,,,,,,,,,
FO-335819	1/4/2016	1/5/2016		R/R 4TH FLR WOMENS RR 2ND STALL TOILET LEAKS @ FLUSH VALVE WHEN FLUSHING TOILET ,,,,,,,,,,,,,, TT/1-4-15 ,,,,,,,,,,,,,,
FO-335869	1/4/2016	1/4/2016		4TH FL WOMENS RM 3RD STALL TOILET OVERFLOWING ,,,,,,,,,,,,,, TT/1-4-15 ,,,,,,,,,,,,,,
FO-335896	1/4/2016	1/6/2016		RM 7320 please have plumber repair backflow preventer on sink and shut off valves leak will not seal. water dripping, high priority,,,,,,,,,,,,, MM/1-5-16 ,,,,,,,,,,,,,,
FO-335897	1/4/2016	1/6/2016		please have plumbers repair faucet in room 7312 will not shut off. water leaking, high priority,,,,,,,,,,,,, MM/1-5-16 ,,,,,,,,,,,,,,
FO-335898	1/4/2016	1/7/2016		Plumber repair sink drain pipe that is rotted. (High Priority) ,,,,,,,,,,,,,, TT/ 1-5-16 ,,,,,,,,,,,,,,
FO-336116	1/5/2016	1/11/2016		In the main entrance of the Engineering building on the first floor in the ladies bathroom near the first stall there is a slow drip of water coming from the ceiling. Thank you. ,,,,,,,,,,,,,, *TT/JH/1-5-16 ,,,,,,,,,,,,,,
FO-336150	1/5/2016	1/6/2016		PLUGGED SINK. 4TH FLOOR LADIES RESTROOM NEAR OFFICES,,,,,,,,,,,,, TT/1-6-16 ,,,,,,,,,,,,,
FO-336354	1/7/2016	1/8/2016		PLUMBERS \ R/R 1ST FLR PLEASE REPAIR TOILETS LADIES RESTROOM 1ST FLOOR SEE ENGINEER MEDIUM PR ,,,,,,,,,,,,,, TT/1-7-16 ,,,,,,,,,,,,,,
FO-336363	1/7/2016	1/8/2016		RESTROOM 2126 HANDICAP STALL TOILET LEAKING NEAR FLUSH VALVE ,,,,,,,,,,,,,, TT/1-7-16 ,,,,,,,,,,,,,,
FO-336460	1/8/2016			LAB 3240 SINK LEAKING ,,,,,,,,,,,,,, MM/1-8-16 ,,,,,,,,,,,,,,
FO-336485	1/8/2016	1/11/2016		Please have plumbers repair backflow preventer in 7341. high priority ,,,,,,,,,,,,,, DB/1-9-16 ,,,,,,,,,,,,,
FO-336519	1/8/2016	1/11/2016		SINK 7222 HOT WATER FAUCET WONT AND COLD WATER WONT TURN ON ,,,,,,,,,,,,, MM/1-11-16 ,,,,,,,,,,,,,,
FO-336562	1/11/2016	1/13/2016		Purdy Library, 2nd Floor, Room 240 - Men's Room located in Stair #1  1st Urinal continuously flushing. Please repair ,,,,,,,,,,,,,, TT/1/11/16 ,,,,,,,,,,,,,,
FO-336630	1/11/2016	1/12/2016		3RD FL OLD MAIN DRINKING FOUNTAIN WATER IS BROWN AND YELLOW ,,,,,,,,,,,,,, GS/1-12-16 ,,,,,,,,,,,,,,
FO-336682	1/12/2016	1/13/2016		PLUMBERS, R/R RM 3128 VACUUM BREAKER ON SINK LEAKING , PLEASE REPAIR. PRIORITY-HIGH ,,,,,,,,,,,,,, TT/1-12-16 ,,,,,,,,,,,,,,
FO-336693	1/12/2016			LOADING DOCK IS FLOODED AND VERY ICY.

WO	Recieved	Finished	Total	Request
FO-336804	1/13/2016	1/22/2016		Fitters: Please install a by-pass line and ball valves on the lab air piping before the desiccant drier. See Engineer for proper location of by-pass. High Priority. GS/1-14-16
FO-336854	1/13/2016			The water faucet in the 1st floor ladies room is spraying out water. The faucet turns on but sprays water out around the sink and onto the floor. GS/1-13-16
FO-336973	1/13/2016	1/15/2016		R/R RM 3210/UGL Community Room-RM 3210.01/Kitchen has sink leak (GARBAGE DISPOSAL). Water is on floor outside of cabinet below sink. Appears to be brown water at bottom of inside of cabinet. MM/1-15-16
FO-336916	1/14/2016	1/14/2016		MENS RM 1ST FL FAUCET WATER NOT TURNING ON MM/1-14-16
FO-336921	1/14/2016	1/14/2016		4TH FL 3RD STALL LEAKING FROM BACK OF TOILET TT/1-14-16
FO-337038	1/15/2016	1/16/2016		trade plumbers priority high please service vacuum pump in basement mech rm only runs up to 15inch and shuts off this should be around 22inch my need new switch installed DB/1-15-16
FO-337288	1/19/2016	1/25/2016		The sink is stopped up. TT/1/25/16
FO-337346	1/19/2016	1/27/2016		Automatic faucet in ladies restroom takes too long to shut off. MM/1-26-16
FO-337380	1/19/2016			Plumbers -- Priority High Water pipe or fire system water line leaking in boiler room from two spots. Pipe leak location: about five feet outside boiler room entrance TT/1-26-16
FO-337399	1/20/2016	1/21/2016		PIPE IS LOOSE UNDERNEATH SINK. UNISEX RESTROOM. ROOM 14100.3.....TT.....1- 21-16
FO-337436	1/20/2016	1/21/2016		Please rush - Drinking fountain on the 2nd floor of Matthaei leaking badly when it is running/being used.....TT...1-20-16 Thank You. Bob Ostrowski
FO-337458	1/20/2016	1/20/2016		LAB 6321 CORNER SINK WATER WONT TURN OFF.....MM...1-20-16
FO-337467	1/20/2016	1/20/2016		3RD FL MENS RM TOILET RUNNING OVER.....TT....1-20-16
FO-337468	1/20/2016	1/20/2016		MENS RM NEAR 0120 TOILET OVERFLOWING,.....TT....1-20-16
FO-337475	1/20/2016			east end of basement drinking fountain is dispensing bad water. Color is green. I have a picture.....DB.....1-21-16
FO-337491	1/20/2016	1/21/2016		Plumbers: Please repair handy-cap toilet on the third floor men's restroom. toilet runs-on when flushing. Shut supply valve just before the sloan valve. High priority....TT.....1-21-16
FO-337492	1/20/2016	1/21/2016		Plumbers: Please repair the men's restroom first toilet. Spud is leaking when flushing. High Priority.....TT.....1-21-16
FO-337508	1/20/2016	1/21/2016		WATER FOUNTAIN IS CONTINUOUSLY RUNNING. 2ND FLOOR NEAR ROOM 2140.....MM.....1-21-16
FO-337559	1/21/2016	1/21/2016		Sections of the drain pipe for first floor kitchen sink have separated, causing water to go all over the floor. Repair needed ASAP.....DB....1-21-16
FO-337560	1/21/2016			The shower in the first floor womens restroom does not have hot water.....GS.....1-21-16
FO-337556	1/21/2016	1/21/2016		WATER LEAK ON THE WEST SIDE OF BUILDING. ANTHONY WAYNE DRIVE SIDE.....DB...1-21-16
FO-337561	1/21/2016	1/21/2016		WATER COMING UP THROUGH MIDDLE OF LAWN BETWEEN MANUFACTURING ENGINEERING & BIOENGINEERING BUILDINGS.....DB.....1-21-16
FO-337606	1/21/2016	1/22/2016		FAUCET CONTINUOUSLY RUNNING. BASEMENT WOMEN'S RESTROOM.....TT....1-21-16
FO-337662	1/22/2016	1/22/2016		PLUMBER R/R RM 13100.10 MENS RR ONLY TOILET CON'T RUNS.....TT....1-22-16
FO-337665	1/22/2016			ENTIRE ANIMAL QUARTERS NO COLD WATER.....DB.....1-22-16
FO-337692	1/22/2016	1/25/2016		PLUMBER R/R 1ST FLR HALLWAY BACKSTAGE MENS RR ONLY TOILET IS PLUGGED TT/1/25/16
FO-337705	1/22/2016	1/26/2016		Several of the faucets are leaking water onto the bench top when they are on. The leak is coming from the top of the faucet just before the goose neck. TT/1/25/16
FO-337767	1/25/2016	1/26/2016		Toilets in ladies restroom are not flushing. TT/1-25-16

WO	Recieved	Finished	Total	Request
FO-337768	1/25/2016	1/26/2016		R/R RM 472/WOMENS RR ONLY TOILET IS PLUGGED UP ..... TT/1-25-16 .....
FO-337804	1/25/2016	1/26/2016		3RD FL MENS RM 1ST SINK FAUCET NOT WORKING ..... TT/1-25-16 .....
FO-337829	1/25/2016	1/26/2016		The ladies restroom on the lower level (closest to Mack) has an odor like the smell of sewage emitting from it..... MM/1-26-16 .....
FO-337936	1/26/2016			Replace 2 rusted galvanized nipples in room 1311 that appear could fail anytime Repair ASAP ..... GS/1-26-16 .....
FO-337948	1/26/2016	1/27/2016		URINAL CONTINUOUSLY RUNNING. 1ST FLOOR MEN'S RESTROOM NEAR AUDITORIUM. .... TT/1-26-16 .....
FO-337963	1/26/2016			Investigate water leaking into basement on southeast corner of the building..... DB/1-26-156 .....
FO-337973	1/26/2016	1/27/2016		4TH FL MENS RM URINAL NOT DRAINING ..... TT/1-26-16 .....
FO-337985	1/26/2016	1/27/2016		MENS RM 8101 URINAL CONTINUOUSLY RUNNING ..... MM/1-27-16 .....
FO-338018	1/27/2016			R/R RM 4101/MENS RR ONLY SINK IS PLUGGED UP ..... MM/1-27-15 .....
FO-338051	1/27/2016			PLUMBERS, PLEASE REPLACE BAD SANITARY SUMP PUMP & FLOAT ASSEMBLY. PRIORITY-HIGH. .... GS/1-27-16 .....
FO-338116	1/28/2016			Trade: Plumber Priority: High Please repair drinking fountain on the 1sst floor. Water is leaking on the carpeted floor. Drinking fountain is located in the hallway near the men's rest room. .... TT/1-28-16 .....
FO-338128	1/28/2016			JANITOR CLOSET 172 SINK DRAINS SLOWLY ..... TT/1-28-16 .....
FO-338129	1/28/2016			JANITOR CLOSET 286 SINK HAS STANDING WATER ..... TT/1-28-16 .....
FO-338132	1/28/2016			Rm. 3112 has a backed up garbage disposal that needs repair..... MM/1-28-16 .....
FO-338148	1/28/2016	1/29/2016		**WORK IN PROGRESS/ REFER TO FO#338156 JWT **PIPE SHOP WILL TRY TO INSTALL BYPASS ON 1-30-16 PROVIDING MATERIAL IS ACCESSIBLE JWT  Hot water too hot on all floors. In my room it's @ 136 degrees. First floor mens room @ 140 degrees. I have had stu
FO-338159	1/28/2016			The custodian said that the "new" toilet that was installed in the womans rest room is leaking..... GS/1-30-16 .....
<b>T - Roofing</b>			<b>2</b>	
FO-336229	1/5/2016			RoofersRepair roof leak in room 2001.High priority
FO-337093	1/17/2016			Repair roof leak at Purdy Library, 4th floor near Room 439. Water is leaking in near the seam of the penthouse mechanical room wall and roof line. Dripping on to book shelves. Sheathing is protecting books. Light fixture also affected.
<b>Medium</b>			<b>101</b>	
<b>T - Carpenter</b>			<b>20</b>	
FO-335797	1/1/2016	1/7/2016		CARPENTERS: PLEASE REPAIR LOOSE AND CHIPPED FLOOR TILES PRIORITY MED
FO-335798	1/1/2016	1/11/2016		CARPENTERS PLEASE REPAIR BROKEN AND CHIPPED FLOOR TILE IN THE HALLWAY NEAR RM 4320, PRIORITY MED
FO-335899	1/4/2016	1/28/2016		Carpenters: please repair loose floor tiles in basement of north stairway. priority: med.
FO-336221	1/5/2016	1/6/2016		my window is leaking again. i missplaced the cards i had from the project manager over the summer when they repaired our windows.
FO-336284	1/6/2016	1/7/2016		**ADDING CARPENTERS: Replace missing ceiling tiles room 1351 JH  CEILING LEAK. ROOM 1351. .... ME/1-4-15 .....
FO-336336	1/7/2016			CARPENTERS: Please replace bad floor tiles outside of room 4320 due to water damage.MED.

Page 47 of 87

WO	Recieved	Finished	Total	Request
FO-336384	1/7/2016	1/12/2016		**ADDING ELECTRICIAN: Basement mechanical room dewire un-piped condensate return pump 001 and reconnect to new installed pump*See Ron Clark so old pump can be picked up
				(**) PO REQ DK Pipe Fitter; Medium Please repair the seals on the two condens
FO-336436	1/8/2016	1/21/2016		Elect Med Priority Replace lights on boiler rm. Street lights are out in area and these would help for safety. Fixture over BR door facing South and fixture on BR facing S near street goes on and off.
FO-336510	1/8/2016			repair heater at Manufacturing Engineering large room.
FO-336545	1/11/2016	1/14/2016		Repair #2 boiler feed pump circuit
FO-336692	1/12/2016	1/21/2016		**ADDING ELECTRICIAN: Disconnect condensate pump #1. Reconnect after rebuild is complete. See Ron Clark for location
				(**) PO REQ DK 11/23 Fitters: Condensate return pump #1 is leaking at the shaft seal. Please repair. High Priority.....RC.
FO-336709	1/12/2016	1/13/2016		Electricians. Low, R/R 3RD FLR HALLWAY Repair or replace as necessary wall mounted hall clock, east end rear hallway near room 309.
FO-336847	1/13/2016			unit heater behind DA tank, motor will not run, there are two in the boiler room
FO-336859	1/13/2016			Electricians; Medium: R/R RM 00502/MECH RM Repair VFD on Pump CP-1. Shows short circuit on display screen. Pump now running in bypass mode
FO-336863	1/13/2016	1/22/2016		Electricians, Medium : R/R BLDG Repair as needed Building Exhaust Fan 2. Fan located in mechanical room in the west end of attic over main auditorium. EQ NOT AVAIL IN TMA SYS
FO-336869	1/13/2016			**ADDING ELECTRICIAN: DEWIRE #1 condensate pump, Rewire when it is reinstalled in mechanical room 1001. See Ron Clark
				(**) PO REQ DK 2ND 11/23 (**) PO REQ DK #2 6-10-15 (**) PO REQ DK 5-8-15 (**) PO REQ DK MOTOR 7-13  Steamfitter -High Priority
FO-337021	1/15/2016			Elect. Med priority R/R RM 00035/MECH RM - AHU #5 will not start or stop per command from Siemens. The check their end of the Siemens circuit and claim it to be working.
FO-337098	1/17/2016	1/21/2016		Replace faulty 3 hour timer controlling Exhaust Fan #9, serving the foundry in the Hammer Room #050 Art Building. The timer spring is not turning off the exhaust fan and it is running continuously unless manually turned off.
FO-337485	1/20/2016	1/20/2016		ELECTRICAINS TO CHECK THE POWER SUPPLY TO MAIN ENTRANCE TO THE BUILDING SO THE DOORS SECURE  Install locks on breakers so students can't turn them off.
FO-337541	1/21/2016			Electrician, medium, Please replace smoke detector next to basement mechanical room, receiving trouble alarm due to dirty smoke detector.
FO-337622	1/21/2016			Trade: ElectriciansPriority: MediumFollow up to FO 337497Hallway lights are not working. There is no power at the switches. Breakers are not tripped.
FO-337624	1/21/2016	1/22/2016		Repair Clock in room 308
FO-338146	1/28/2016			To electricians. Replace defective toggle switch on Alumni Kitchen exhaust fan and, defective E/P's on both The Alumni Kitchen exhaust fan and toilet exhaust fan.
FO-338206	1/29/2016			Repair bad clock in room #3372

T - Locksmith

2



WO	Recieved	Finished	Total	Request
FO-336476	1/8/2016	1/20/2016		Tonya Jones 01/08/2016 16:23 - Received approval via email from Sheila Primas to charge index 228400. Sent email to Mike Pines with this information. Tonya Jones 01/08/2016 13:04 - Email sent to Sheila Primas requesting approval to charge 228400. Cor
FO-336505	1/8/2016	1/13/2016		New Key New Staff Member Key #: 31DA Key Holder ID: Juanitta Qty: 8  action: I need 10 copies of this Sub-Master key. Thank you.
<b>T - Painter</b>			<b>1</b>	
FO-336410	1/7/2016	1/19/2016		Chalk and seal around concrete pad in elevator machine room (Penthouse)that cross over pump is mounted to. Water gets under concrete pad and leaks below See Marty Elwart for location if needed
<b>T - Pipefitter</b>			<b>23</b>	
FO-335826	1/4/2016	1/6/2016		Fitters, please repair leak in steam coil on AHU-1....., ME/1-4-15 .....
FO-335871	1/4/2016	1/4/2016		Fitters tighten or replace head gaskets HX-2 they were recently replaced and are now leaking priority medium ....., JH/1-4-15 .....
FO-335919	1/4/2016			Trade: Pipefitters Priority: Medium Please repair or replace strainers in condenser pumps 1, 2 & 3. ...., JH/1-5-16 .....
FO-336171	1/5/2016	1/6/2016		Trade: Pipe Fitter Priority: Medium Victaulic fitting is leaking on EDC Energy Recovery Loop, please repair. See Rocky for leak location....., JH/1-5-16 .....
FO-336317	1/6/2016	1/8/2016		To pipe fitters. Run 1-1/2" vent line from condensate receiver by AHU-3 up to vent piping system for fume removal. See building engineer regarding second receiver venting....., JH/1-8-16 .....
FO-336432	1/8/2016			Pf. Med priority Please remove approx 3 ft. of pipe insulation off of chilled water line above Return fan # 3. Work needs to be done to replace leaking fittings. ...., CB/1-9-15 .....
FO-336437	1/8/2016	1/8/2016		Replace radiator valve assembly room 2206. Room severely overheats....., JH/1-8-16 .....
FO-336451	1/8/2016	1/11/2016		To pipe fitters. Install drain line with ball valve on blow down tank in boiler room....., ME/1-8-16 .....
FO-336527	1/9/2016			Please repair the seals on the two Replace seals in spare condensate return pumps, 071-CRS-001, located in the basement ....., RC/1-11-16 .....
FO-336665	1/12/2016	1/19/2016		Pipe fitters. Please repair or replace reheat control valve for north unit. It is leaking through, had to isolate the unit. priority: med....., JH/1-12-16 .....
FO-336733	1/12/2016			EMERGENCY PIPEFITTERS R/R PENTHOUSE REPATCH LEAK IN STM COIL FOR SAF #2 ....., *ME/JH/1-12-16 ..... PRIORITY CHANGED TO MEDIUM PER TIM HERR, NEW COIL IS ON ORDER, ALL INVOLVED HAVE BEEN INFORME....1-22-16
FO-336891	1/14/2016			off campus fan, trap issue or possibly plugged strainer ....., EA/1-18-16 .....
FO-336940	1/14/2016	1/20/2016		Fitter extend fire pump test drain line over to the floor drain. See engineer ....., JH/1-18-16 .....
FO-336963	1/14/2016	1/25/2016		FITTERS, R/R RM 3134 PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #4 FFC UNIT. PRIORITY-LOW ....., JH/RC....., 1-21-16
FO-337048	1/15/2016	1/22/2016		HVAC unit for Peacock room located in the basement needs repair. The heating valve is installed backward ....., ME/1-16-16 .....
FO-337067	1/15/2016	1/25/2016		To pipe fitters. Please check operation of check valve and steam trap on line for flash tank located against North wall of rm. 23 behind condensate tank. Repair or replace as needed....., ME/1-18-16 .....
FO-337270	1/19/2016			The 1" tee located on the condensate return line to the feed water heater at Beecher is cracked and needs to be replaced. Minor amount of water escaping at this time. There is also a small drip at the nearby union. Pipe fitters just replaced the conne
FO-337306	1/19/2016			To pipe fitters. The hot water coil bypass valve on AHU-1 is leaking by causing DA to overheat. Please repair or replace....., JH/1-25-16 .....

WO	Recieved	Finished	Total	Request
FO-337762	1/25/2016	1/26/2016		Pipe fitters: please install a drain valve on absorber head. priority: med..... JH/1-26-16 .....
FO-337802	1/25/2016			Pipe fitters: please check all steam traps on the building heating system to locate and replace the ones that are blowing by. Priority: med.
FO-337891	1/26/2016			Trade: fitters Priority: Medium Center wall unit has leaking valve on the return side of the hot water coil. At present isolated INLET & OUTLET to the coil..... ME/1-28-16 .....
FO-338010	1/27/2016			Trade: Pipe Fitters Priority: Medium Repair leak on steam coil on fresh air intake for east basement..... ME/1-28-16 .....
FO-338179	1/29/2016			PIPEFITTER PLEASE REPLACE RELIEF VALVE #2 BOILER LEAKING. MEDIUM PR ..... ME/1-29-16 .....
<b>T - Plumber</b>			<b>32</b>	
FO-335876	1/4/2016	1/6/2016		FAUCET LEAK. ROOM 7312..... MM/1-4-15 .....
FO-336102	1/5/2016	1/5/2016		R/R RM 1328/WOMENS RR CTR STALL NEWLY INSTALLED TOILET IS LKNG BEHIND TOILET BTWN TOILET & WALL ..... MM/1/5/16.....
FO-336104	1/5/2016	1/6/2016		Plumb Med Priority Repair leak at urinal flush valve, basement near custodial office. .... TT/1-5-16 .....
FO-336417	1/7/2016	1/12/2016		FAUCET LEAKS WHEN TURNED ON. ROOM 3109. .... MM/1-8-16.....
FO-336425	1/8/2016	1/12/2016		Plumbers- Medium Priority- Please repair malfunctioning sloan valves and clean faucet strainers in Women's and Men's Lavatory. rm 350 and 352 on Third Floor of Lande. ..... MMN/1-9-16 .....
FO-336452	1/8/2016			Plumbers PLEASE INSTALL WATER FILTERS ON FOUNTAINS IN MULTIPURPOSE.
FO-336455	1/8/2016	1/13/2016		Please remove the toilet bowl and cap and seal all water lines feeding it, as well as capping the sewer. The room will be re-purposed to accommodate a regulatory device in the near future. Corey Blair can elaborate. .... MM/1-11-16 .....
FO-336468	1/8/2016	1/11/2016		LEFT URINAL PIPE LEAK AT TOP. 2ND FLOOR MEN'S RESTROOM. NEAR ROOM 2506..... TT/1-11-16 .....
FO-336470	1/8/2016	1/11/2016		Toilet in unisex restroom is not functioning properly. .... TT/1-9-16 .....
FO-336487	1/8/2016	1/12/2016		Trade: Plumbers Priority: Medium  Please repair a leak from Fume Hood #6's drain line in Lab 160. .... TT/1-11-16 .....
FO-336509	1/8/2016	1/13/2016		RM 351 PIPE ON MACHINE IS MISSING A TOP, BRINGING MOISTURE IN RM Needs 1.5" cap ..... *TTJH/1-11-16 .....
FO-336540	1/11/2016			(**) PO REQ DK 1/11/16  Replace Sump pump #2 located in fan room #2 new pump replacement is not pumping ..... GS/1-11-16.....
FO-336606	1/11/2016	1/12/2016		TOILET LEAK. BASEMENT LADIES RESTROOM. ROOM 118..... MM/1-11-16 .....
FO-336631	1/11/2016	1/20/2016		WATER FOUNTAIN WATER IS YELLOW ..... GS/1-12-16 .....
FO-336632	1/11/2016	1/15/2016		PLUMBERS: Please pump out standing from Loading Dock area. MED. .... GS/ 1-12-16 .....
FO-336659	1/12/2016	1/13/2016		Plumbers- medium Priority- Repair or replace leaking stop valve on sloan valve in womens Lavatory Rm 118. Placed stall out of service. Water on the floor..... MM/1-12-16 .....
FO-336691	1/12/2016	1/13/2016		R/R RM 1378/WOMENS RR MIDDLE STALL TOILET WILL NOT FLUSH ..... MM/1-12-16 .....
FO-336806	1/13/2016			Plumbers: Please repair the leaking back-flow preventer located above chill water pump #2 and next to the main city water supply piping. Medium Priority. .... GS/1-14-16 .....
				**UPDATE DON BEAR
FO-337407	1/20/2016	1/21/2016		Plumber: Please repair third floor women's restroom second toilet (is bagged). When flushing, water comes out of the base of the toilet at the rear. Medium priority.....TT.....1-21-16
FO-337469	1/20/2016	1/26/2016		Plumbers please repair/replace back flow preventer for water purifier in room 14.....DB....1-20-16

WO	Recieved	Finished	Total	Request
FO-337463	1/20/2016	1/22/2016		repair leaking back flow preventer in the boiler room....DB...1-20-16
FO-337490	1/20/2016	1/21/2016		Plumbers-please remove toilet and snake waste line, and remount same in Men's room on Rear Mezzanine. Toilet has been 'bagged' for months?.....TT.....1-21-16
FO-337589	1/21/2016	1/22/2016		TOILET LEAKS AT BASE WHEN FLUSHED. BASEMENT MEN'S RESTROOM NEAR ELEVATOR.....TT.....1-21-16
FO-337634	1/21/2016	1/22/2016		On the 1st floor of FAB in the large men's restroom the toilet seat cover is loose.....TT.....1-22-16
FO-337889	1/26/2016	1/27/2016		Trade: Plumber Priority: Medium Sloan valve malfunction and toilet plugged..... TT/1-26-16 .....
FO-337955	1/26/2016	1/27/2016		Plumber repair leaking flush valve in woman rest room basement ..... MM/1-26-16 .....
FO-338007	1/27/2016			TOILET NOT FLUSHING. MEN'S RESTROOM. 1ST STALL. ROOM 1302. .... MM/1-27-16 .....
FO-338019	1/27/2016			Plumbers -- priority medium 2nd floor shower does not have hot water. The request is needed to facilitate part of a Med School grant. .... GS/1-28-16 .....
FO-338068	1/27/2016			PLUGGED SINK. KITCHEN. ROOM 385..... TT/1-28-16 .....
FO-338213	1/29/2016			The sink in lab room 1320 is plugged up and the eye wash station is draining onto the floor..... TT/1-30-16 .....
FO-338256	1/29/2016			Please tighten all toilet seats..... TT/1-30-16 .....
FO-338257	1/29/2016			Please tighten all toilet seats..... TT/1-30-16 .....
<b>Low</b>			<b>421</b>	
<b>T - Carpenter</b>			<b>73</b>	
FO-335789	1/1/2016	1/4/2016		The right side double door at Merrill Palmer, (Knapp), near room 166 has thrown hinges, causing the door to strike the mullion and not close properly.
FO-335804	1/4/2016	1/4/2016		CARPENTER TO REPLACE DAMAGED CEILING TIM HERR'S OFFICE
FO-335835	1/4/2016	1/20/2016		R/R RM 4135 RE-ATTACHED FLR TILES Our Media Arts Equipment Room (4135 Old Main) has rubber tiles that are starting to pop up. Can we have them glued back down before the term starts. These are creating tripping hazards for the student staff workin
FO-335834	1/4/2016	1/4/2016		Shelves needed in the custodian closet on the 13th floor (no room number). The closet is located upon the exit off the freight elevator. Shelves were stolen over Christmas closure.
FO-335839	1/4/2016	1/5/2016		rooms 217 AND 219 need ceiling tiles replaced
FO-335904	1/4/2016	1/4/2016		CARPENTERS: Please replace several damaged floor tiles in room 4365. MED.
FO-336098	1/5/2016			TEAM LEADER TIME ( January 2016 )
FO-336198	1/5/2016	1/6/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY ( 3RD FLR NEAR STAIRWELL-F. PRIORITY-LOW
FO-336201	1/5/2016	1/13/2016		CARPENTERS, PLEASE REPLACE MISSING & DAMAGED COVE BASE IN RECITAL HALL. PRIORITY-LOW
FO-336207	1/5/2016	1/5/2016		PROVIDE KEY TO NEW ADA OPERATOR DOOR 016-01-E
FO-336208	1/5/2016	1/5/2016		CARPENTERS TO TAKE DOWN CHRISTMAS LIGHTS & PUT BACK IN STORAGE
FO-336210	1/5/2016			In room 4363 the floor tiles that are stained or damaged need to be replaced.
FO-336211	1/5/2016			In room 4365 the floor tiles that are stained or damaged need to be replaced.
FO-336212	1/5/2016			In room 4367 the floor tiles that are stained or damaged need to be replaced.
FO-336219	1/5/2016			In Rm. 4369 replace stained or damaged tiles.
FO-336223	1/5/2016	1/20/2016		Please repair molding in rooms 106 and 129. Also blinds in room 171 are broken.
FO-336226	1/6/2016	1/6/2016		CARPENTERS TO REPAIR EXTERIOR GATE EXIT DEVICE LATCH CHILDHOOD CENTER ( SEE PLAICIDIA FRIERSON 7-1686 )

WO	Recieved	Finished	Total	Request
FO-336272	1/6/2016	1/12/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR ROOMS 4228 & 4218. PRIORITY-LOW.
FO-336308	1/6/2016	1/14/2016		area around faucet has hole in wall that needs to be filled. faucet also needs to be calked
FO-336323	1/6/2016	1/7/2016		CARPENTERS, PLEASE REPAIR DAMAGED WALL IN HALLWAY @ STAIRWELL-F , 3RD FLR. PRIORITY-LOW
FO-336358	1/7/2016	1/7/2016		R/R 1ST FLR Women's restroom next to the food cart. Handicap stall replace door hook that you can use to hang a purse/coat is missing
FO-336391	1/7/2016	1/19/2016		1 EP - landing between 2nd & 3rd floor - This is the stairwell exit 4, next to Science Hall. The fixture was tagged 9/18/15.  OPEN to CARPENTERS:  Build scaffold for Electricians, and tear down when job is complete.
FO-336441	1/8/2016			CARPENTERS TO PROVIDE 30 EACH 2"X4"X12' LUMBER FOR FUTURE BOARD-UPS 2016
FO-336459	1/8/2016	1/11/2016		PLEASE REPAIR DOOR LOCK ,BACK OF BLDG WHERE HEATING UNITS ARE. DOOR LOCK WILL NOT WORK WITH KEY FROM OUTSIDE
FO-336467	1/8/2016	1/8/2016		CARPENTERS TO REPAIR DESK & HANG OFFICE ITEMS @ 11.00AM SHARP MRS WILSON
FO-336477	1/8/2016	1/11/2016		The door lock on lab (2554 EDC) has been tricky for a few months and seems to have gotten much worse in the last couple weeks. Specifically, keys that used to work fine now need to be jiggled and reinserted several times before the lock can be turned. PI
FO-336496	1/8/2016	1/11/2016		Carpenter repair sticking door lock cylinder to north lab located next to men's room.
FO-336521	1/9/2016	1/22/2016		The lights over the stairwell has an electrical problem. A scaffold will be needed. It's next to room 365.  OPEN TO CARPENTERS:  Build scaffold so Electricians can repair fixture, and remove when job is done.
FO-336523	1/9/2016	1/22/2016		Raise shelf in Pipe shop cabinet to accommodate air compressor. See John for location
FO-336524	1/9/2016	1/22/2016		Replace bathroom stall partitions in basement mens room. Ceiling leak is now complete. See Don Bear if needed
FO-336536	1/11/2016	1/11/2016		CARPENTERS TO INSTALL FIRST AID BOX FROM STOCKROOM TO SERVICE CENTER
FO-336738	1/12/2016	1/13/2016		R/R RM 100 SEAL AROUND WINDOW/WINDOW FRAME We have a window here in the Accounting office where a lot of air is coming through. The window is closed, however, we tried to make sure it is closed all the way and it appears to be closed but a large amount o
FO-336925	1/13/2016	1/29/2016		Carpenter R/R BLDG replace broken convex mirror attached to building on the south east corner. (Per specifications discussed btwn AI & Doug) SAFETY.
FO-336775	1/13/2016			CARPENTER TO REPLACE DAMAGE CEILING TILES 3RD FLOOR NEAR ROOM 3410
FO-336778	1/13/2016		1/13/2016	Please repair the following (lower)locker hinges at the football locker room... #2,4,9,12,19,21,22,30,42,44,62,64,89,& 92. Also repair the following upper hinges of the locker (lock box)... #84, 85, 86, 87, 88, 89, & 90. Thank You. Bob Ostrowski
FO-336784	1/13/2016	1/14/2016		Matthaei - Repair south lobby door - broken closure... Thank You. Bob Ostrowski
FO-336881	1/13/2016	1/25/2016		DOOR SQUEAKS VERY BAD. INSIDE ENTRANCE TO BUILDING DOOR (LEFT OF HANDICAP DOOR).
FO-336928	1/14/2016	1/21/2016		CARPENTERS TO SCREW SHUT THE OPEN CASEMENT WINDOW ACROOS FROM THE URNAL ASAP
FO-336936	1/14/2016	1/15/2016		Carpenter repair door latch. Doesn't lock unless it is slammed. Rm.104.1
FO-336937	1/14/2016	1/15/2016		Carpenter repair door latch. Doesn't lock unless it is slammed. Rm. 144
FO-337034	1/15/2016			CARPENTERS, PLEASE REPAIR DAMAGED DRYWALL IN CEILING OF WINDOW COVE.PRIORITY-LOW

WO	Recieved	Finished	Total	Request
FO-337036	1/15/2016	1/21/2016		R/R 2ND FLR Male officer's locker #44 will not secure. Floor 2 east side of building. *Contact Sgt. Voight at 577-6078 to schedule repair time. He will have the combination to open the locker.
FO-337055	1/15/2016	1/22/2016		Carpenters- please rebuild grid and ceiling in 10th floor hallway. Heat Pump repair complete. From FO 334824
FO-337309	1/19/2016	1/20/2016		R/R RM 3040 The second door, left to right, doesn't work properly. It's difficult to open it from inside- out.
FO-337348	1/19/2016	1/19/2016		R/R ENTRY doors 512-04S to carriage house (freer) are not closing...staying ajar. 512.04S and 512.01N
FO-337389	1/20/2016	1/20/2016		ROOM # 437 ONE ARM IS OFF A CHAIR, THE ARM IS LAYING ON THE WINDOW SILL
FO-337390	1/20/2016	1/20/2016		ROOM # 433 ONE BLIND IS BROKEN & SEVERAL ARMS OFF CHAIRS.
FO-337398	1/20/2016	1/21/2016		CARPENTERS TO INSTALL DRY WALL PATCH 4TH FLOOR RECEPTION AREA ( SEE BILL MACDONALD )
FO-337415	1/20/2016	1/27/2016		CARPENTER TO MAKE FRAME & PLEXI BLUE LIGHT LOCATION MAP PER DAVID KUFFNER
FO-337419	1/20/2016	1/28/2016		DEMO ALL OLD HARDWARE OF 7TH FLOOR DOORS ( BRENCAL CONTACT: BRIAN BRICKLE 810-650-6147 )
FO-337516	1/20/2016	1/21/2016		Trade: Carpenter Priority: Low The door leading to the lab wing basement on the 1st floor by the freight elevator is not closing and latching, needs adjustment.
FO-337583	1/21/2016	1/25/2016		a desk top needs to be repair in Room 2 of Prentis. Please see Richard Lerman in rm 06 of Prentis to get the desktop for repair.
FO-337578	1/21/2016	1/22/2016		REATTACH COAT RACK TO WALL. 8TH FLOOR UNISEX RESTROOM NEAR WINDOW.
FO-337591	1/21/2016			The carpet tiles around the One Card machine are coming up and causing a trip hazard. Please re-glue to floor.
FO-337616	1/21/2016			CARPENTERS,PLEASE REPAIR BAD CERAMIC FLOORING IN HALLWAY AT DOUBLE DOORS.PRIORITY-LOW
FO-337640	1/21/2016	1/26/2016		Please repair silver plate on floor next to instructors podium.
FO-337650	1/22/2016	1/25/2016		Northeast pedestrian door intermittently stays ajar; lock cylinder is sideways.
FO-337688	1/22/2016	1/27/2016		REINSTALL GROUNDS PADLOCK ON THE GATE BETWEEN BONSTELLE & MSU
FO-337689	1/22/2016	1/26/2016		CARPENTERS TO DRILL HOLES IN WALLS TO GAIN ACCESS FOR THE FIRE ALARM STROBES ( CONTACT CHAD REEDY @ 248-331-3939 )
FO-337797	1/25/2016	1/26/2016		R/R RM 111/ASSEMBLY Please repair on the right side the door to the Auditorium, screws have pulled out of the wood door.
FO-337810	1/25/2016	1/27/2016		CEILING PROJECTION SCREEN WILL NOT GO UP OR DOWN. ROOM 213.
FO-337815	1/25/2016	1/26/2016		Conference room 2145 door needs to be looked at. It appears that something is stick in the lock preventing anyone from locking and unlocking the door.
FO-337892	1/26/2016			Trade: Carpenters Priority: LowReplace stained ceiling tile in suite 3100, it located just inside the door to this suite in the hallway.
FO-337913	1/26/2016			CARPENTERS,PLEASE INSTALL CARPET TRANSITION STRIP IN HALLWAY RAMP NEAR ROOM 3349.PRIORITY-LOW
FO-337940	1/26/2016			CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES.PRIORITY-LOW
FO-337941	1/26/2016	1/28/2016		CARPENTERS, PLEASE SECURE FFC UNIT TO WALL, WEST ROOM. PRIORITY-LOW
FO-337957	1/26/2016			R/R 1ST FLR HALLWAY OUTSIDE OF RM 1024 Two bulletin boards have fallen from the wall outside of room 1024, main hallway located on the first floor. Boards need to be secured back to the wall. (Note: bulletin boards are leaning against wall)
FO-337984	1/26/2016			R/R 2ND FLR Office Identifier Plate needs to be reattached to wall outside Staff Office Number 2722. Other TRiO Educational Opportunity Center staff office plates require securing to wall. Plate is secured with some type of adhesive.
FO-338028	1/27/2016	1/27/2016		Repair broken shelve in Pipe Shop. See John for location

WO	Recieved	Finished	Total	Request
FO-338056	1/27/2016	1/28/2016		R/R RM 2301/STUDY RM The key will not fit into the core to lock or unlock the study room door. Students are waiting to use this study room. Thanks much
FO-338158	1/28/2016	1/29/2016		CARPENTERS TO REPAIR DOOR ROOM #256 DOOR WIIL NOT CLOSE
FO-338191	1/29/2016			Repair door to control room in boiler room. Door will not close.
FO-338221	1/29/2016			The latch bolt on door 629-01S intermittently fails to extend into the strike plate's pocket. Door isn't closing flush with door stops. Causes alarms at WSUPD dispatch.
<b>T - Electrician</b>			<b>111</b>	
FO-335802	1/4/2016	1/6/2016		AIR HANDLER #3 IS DOWN ON FREEZE STAT. PENTHOUSE.
FO-335809	1/4/2016			Time for Team Leader for the month of January, 2016.
FO-335810	1/4/2016			Time for Electricians to work on/rebuild Clocks throughout campus.
FO-335887	1/4/2016			Ceiling lights are out. Please Replace. It's an electrical problem.
FO-335912	1/4/2016	1/5/2016		Repair bad clock located in room #338.
FO-335933	1/4/2016			There are 3 cabinet lights that need to be replaced. 3 electrical problems. ***THIS IS A REIMBURSEABLE REQUEST NEED TO RESUBMIT REQ ON ISERV/EST FOR MAIN***
FO-336126	1/5/2016	1/6/2016		Purdy Library, 1st Floor  Clock across from Check Out desk stopped working. Please repair.  Thank you.
FO-336128	1/5/2016	1/6/2016		Kresge Library, 1st Floor Wall clock near elevator 027 01 stopped working. Please repair.  Thank you.
FO-336145	1/5/2016			ELECTRICIANS, R/R 1ST FLR ENTRANCE PLEASE REPLACE BAD MOTOR ON VESTIBULE HEATING UNIT. (HANCOCK ENTRANCE E SECTION). PRIORITY-HIGH
FO-336149	1/5/2016	1/6/2016		Meet Pete Smoleyak, and get numbers off a Square D Motor for the overload relay, and auxiliary contacts.
FO-336163	1/5/2016	1/22/2016		There are 2 spot lights over the mural near room 610 that has 2 electrical problems. (Basement)
FO-336165	1/5/2016	1/22/2016		LAB 3240 LIGHTS OUT. There are 3 electrical problems.
FO-336191	1/5/2016			Ceiling lights out in rooms 0151.1 & 0140. 2 electrical problems. A power drill and t5 lamps are required.
FO-336200	1/5/2016	1/11/2016		ELECTRICIANS: R/R RM 00130/MECH RM Please power up the large space heater in the mechanical room 0130. MED. (LARGE ROLL IN PORTABLE HEATER)
FO-336206	1/5/2016	1/25/2016		Dean's Suite - Several burned out incandescent spot lights and several florescent tubes burnt out. Please change ASAP as this is the Vice President's office. There are 2 electrical problems.
FO-336483	1/5/2016	1/28/2016		SECOND REQUEST - Real Room Number is 237.3. Lights still not working in Dr. Abu-Soud's academic office. THIS IS THE SECOND REQUEST, WAS TOLD THAT THIS WAS COMPLETED - BUT IS NOT - MAYBE THE LIGHTS STOPPED WORKING AGAIN. Loretta Small(01/05/2016 15:36)--
FO-336220	1/5/2016	1/6/2016		Light fixture in room 317 is buzzing when turned on. Please inspect light bulbs and ballast to see if one or both needs to be replaced. 2 electrical problems.
FO-336237	1/6/2016	1/6/2016		Fume hood (right one) in the lab 3310? The vent fan did not turn on, and ventilation stopped working. Lab Contact is Dr. Mark Cheng 313-577-5462
FO-336263	1/6/2016			light bulbs out in lab
FO-336266	1/6/2016			Room 379 - 4 LO
FO-336309	1/6/2016			Room 375 - 2 LO
FO-336315	1/6/2016			Room 121 - 1 LO

WO	Recieved	Finished	Total	Request
FO-336332	1/6/2016			Please switch the start up - position for the Generators at the Computer Center, so if there is a power failure ,the generators will start.
FO-336362	1/7/2016	1/8/2016		Room 029 Basement - 2 EPs - In both the fixtures the tombstones are loose.  Created new work order, Team Leader will set time to have work done.
FO-336373	1/7/2016			Lights are flickering in room 4101. There are 2 electrical problems.
FO-336377	1/7/2016			Room 129 - 2 EPs - These fixtures are ceiling lights behind a locked display area.
FO-336387	1/7/2016			We need many fluorescent bulbs changed in rooms 102, 104, 108, and 112.
FO-336478	1/8/2016	1/22/2016		The lights over the stairwell has an electrical problem. A scaffold will be needed. It's next to room 365.
FO-336502	1/8/2016			remove large cement side walk chunks and other wet construction debris/dirt along walls
FO-336503	1/8/2016			Room 455 - 1 LO... The professor needs this light in office.
FO-336586	1/11/2016			1 EP - HW OS RM 124
FO-336587	1/11/2016			1 EP - conference room 4, light out over the counter - TAPED
FO-336595	1/11/2016	1/12/2016		EMERGENCY ELEC R/R GULLEN MALL BTWN BLDGS SCB/FITNESS/FAB & EDU GULLEN MALL LOLLY POP LIGHT WAS ACCIDENTLY HIT BY SNOW PLOW IS BENT OVER W/WIRES EXPOSED
FO-336599	1/11/2016			The Custodial closet has an electrical problem. The closet is completely dark.
FO-336611	1/11/2016			The 5th light coming towards the Woodward entrance in front of the security desk is out. There is 1 electrical problem.
FO-336616	1/11/2016			ELECTRICIANS, R/R 2ND FLR PLEASE REPLACE BAD EBU'S ON 2ND FLR HALLWAYS. PRIORITY-LOW
FO-336618	1/11/2016			ELECTRICIANS,R/R 2ND FLR PLEASE REPLACE BAD EXIT SIGNS ON 2ND FLR HALLWAYS.PRIORITY-LOW
FO-336620	1/11/2016			There are 5 Lights out on the Elevator at the west entrance of the bldg. This area is extremely dim...
FO-336621	1/11/2016			There is an EP over the sink in the 4th floor mens room...
FO-336623	1/11/2016			VFD's for AHU's 3 & 4 need control cards checked.  BAS engineers inspected units on 1-12-16. Control programming sending proper signal.  VFD's are not sending out correct output to fan. Need to check control boards.
FO-336714	1/12/2016			Electrician R/R 6TH FLR MECH RM blow the dust out of the three VFD's (AHU #2) in the 6th floor penthouse. 1/12/16 lps: Spoke w/Eng says equip wo req for AHU 2,3 & 4
FO-336715	1/12/2016			Electrician R/R 6TH FLR MECH RM blow the dust out of the three VFD's (AHU #3) n the 6th floor penthouse. 1/12/16 lps: Spoke w/Eng says equip wo req for AHU 2,3 & 4
FO-336716	1/12/2016			Electrician R/R 6TH FLR MECH RM blow the dust out of the three VFD's (AHU #4) n the 6th floor penthouse. 1/12/16 lps: Spoke w/Eng says equip wo req for AHU 2,3 & 4
FO-336732	1/12/2016	1/28/2016		EMERGENCY ELEC R/R ACTUAL BLDG #099/WOMENS SOFTBALL LOCKER RM THE CAGE AREA BOTH UNIT HEATERS STOPPED WORKING
FO-336760	1/12/2016	1/21/2016		3rd floor: 2 wall socket lights are out. There is 1 electrical problem. The wall fixture is sticking out of the wall.  Call Dean Dennis before going so he can get you in.
FO-336790	1/13/2016	1/14/2016		1 EP - Room 1134 - Women's R/R (Second Request)
FO-336791	1/13/2016			1 EP - Outside room 237 - This is a wall mounted light. Bulbs have been replaced. (Second Request)
FO-336818	1/13/2016	1/15/2016		R/R RM 3100 The hardwired (central?) clock in the Dean's Office suite is not functioning.
FO-336900	1/14/2016			Room 0333 has an electrical problem.
FO-336903	1/14/2016			Range 170 has an electrical problem.(1st floor)

WO	Recieved	Finished	Total	Request
FO-336904	1/14/2016			The hallway outside of Range 330 has an electrical problem. (2nd floor)
FO-336929	1/14/2016			Clock in the Dean Yee's office has stopped working.
FO-336954	1/14/2016			There are 16 light bulbs out on the first floor of Shapero Hall. There are also bulbs out in the south stairwell by the 2nd floor.
FO-336961	1/14/2016			R/R Exterior lights in "tented" overhang area are not working.
FO-336960	1/14/2016			R/R Inside Suite 206, exam rooms 4 and 5 are having problems with the lights, they cut of for random periods of time. It might be an issue with the motion sensors in the rooms.
FO-336978	1/14/2016			COLD RM 3210 LIGHTS OUT. The switch is not working.
FO-336999	1/15/2016	1/16/2016		Room 1209 - 1 EP - Taped - Emergency  Meet with Plumber at 7:30 AM to make the first job of the day Saturday.
FO-337001	1/15/2016			1 EP - Outside room 487 (Hallway)
FO-337024	1/15/2016	1/20/2016		Overhead light flickering in Dean Gable's office. It's an electrical problem.
FO-337042	1/15/2016			Electrician R/R PENTHOUSE repair VFD for **air handler 4B**
FO-337097	1/17/2016			Classroom 161 at Art building clock is only correct twice a day, as it is stuck on 7:00.
FO-337268	1/19/2016			Replace faulty light switch controlling ceiling lights in the 3rd level library of Tierney Alumni. The switch is the center of four switches in the third floor staircase foyer, near the skylight. Currently covered in tape.
FO-337269	1/19/2016			Replace the tunnel light switch located in mechanical room 27 of Kresge Library with a keyed switch or some other type of switch that will prevent persons from accidentally leaving the tunnel lights on when they act to turn off the mechanical room lights.
FO-337289	1/19/2016	1/20/2016		Custodial/Lighting Request - High Priority Please remove lights or repair overhead light above Dean Gable's desk. Bulbs are flickering. It's an electrical problem.
FO-337287	1/19/2016	1/19/2016		The hallway along side of room 1264 has The bulbs came on 4 hours after I tagged it.
FO-337290	1/19/2016			Hallway between the elevators and the custodial closet has 1 electrical problem. (5th floor)
FO-337310	1/19/2016	1/27/2016		GLYCOL CIRCULATING PUMP IS SMOKING. PENTHOUSE.
FO-337311	1/19/2016			6 out rm 443
FO-337332	1/19/2016			Labs 4320 and 3467 has several lights out. There may be an electrical problem. Please repair. Room 4320 has 1 electrical problem; Room 3467 has 1 electrical problem.
FO-337343	1/19/2016			hallway near 355 1 out
FO-337347	1/19/2016	1/21/2016		Trade: Electrician Priority: Low Tag#090-GEN-001 R/R LAB ROOFTOP UNIT The rooftop clean room generator has low fluid level in the battery.
FO-337394	1/20/2016	1/20/2016		The new Generators is alarming due to crank overload . please check and repair  Elertical Department repair.
FO-337397	1/20/2016	1/21/2016		The new Generators FP&M building is alarming due to crank overload . please check and repair  Eletricial Department.  Elertical Department repair
FO-337434	1/20/2016	1/22/2016		Clock is out of order
FO-337448	1/20/2016			1 EP - 4th floor men's r/r - rear light out. Bulbs have been changed.
FO-337449	1/20/2016			1 EP - Outside 225 - Tagged
FO-337450	1/20/2016			1 EP - Room 209/ Men's R/R - Fixture has a tamper lock on it, can't change bulbs.
FO-337465	1/20/2016	1/22/2016		CLOCK IS NOT WORKING. ROOM 315.
FO-337489	1/20/2016			The hallway outside of room 044 has 2 electrical problems.
FO-337543	1/21/2016			Electrician please repair AHU 8 north fan drive defect
FO-337572	1/21/2016			The entrance light outside of room 130 has an electrical problem.
FO-337623	1/21/2016	1/22/2016		Repair Clock in room 308
FO-337707	1/22/2016			Purdy LibraryR/R BLDG Lamp Replacement requested for exterior lights over exterior door/entrance 026 10E. Opening and Closing staff are concerned about security in the dark walkway behind library.Thank you.



WO	Recieved	Finished	Total	Request
FO-337725	1/25/2016			Assorted lights out on 2nd floor of UGL, approx. 20.
FO-337740	1/25/2016			Custodial/Lighting Request: Multiple overhead lights out and flickering in the second floor clinics suite. There are 3 electrical problems.
FO-337772	1/25/2016			Install regular on/off switch (instead of the 15 min timer switch installed Temp) till new 3 hour timer switch is ordered. In metal working room in basement, exhaust fan #9.
FO-337795	1/25/2016			To electricians. R/R RM 00025/MECH RM Please replace defective E/P on SF-7 for main air on disconnect panel.
FO-337809	1/25/2016			Replace lens in areas lens is missing. Finished 12/4/2013LT  Check building for missing lens, and use the ones in the photo. Then take remaining ones to basement of Purdy/Kreske Library.
FO-337823	1/25/2016	1/25/2016		Tools needed in Electric shop: 1 Volt Meter for Robert Crosby 1 Pack 18V Batteries for Don Brown Milwaukee CAT #48-11-2230
FO-337907	1/26/2016			Trade: ElectricianPriority: LowPlease repair clock in the hallway near room 479.
FO-337908	1/26/2016			Trade: ElectricianPriority: LowPlease repair lighting in the SE basement corridor near 470 - 480 and in the SE stairwell.
FO-337920	1/26/2016			In lab 4545 all of the lights are out. Please repair. The light switch started making a crackle noise when I hit the switch.
FO-337919	1/26/2016	1/27/2016		CLOCK IS NOT WORKING. 3RD FLOOR ROOM 3374.
FO-337949	1/26/2016			2ND FL STAIRWELL LANDING LIGHT FIXTURE IS BLINKING, LONG FLUORESCENT BULB. It's an electrical problem.
FO-337958	1/26/2016			Multiple lights are out in central stairwell, all floors. The lights will be exchanged by the electricians....Very high.
FO-338024	1/27/2016			Room 312 - light shade has fallen down. The Lens cover will be ordered by The Electricians... For the Lamp Changers.
FO-338061	1/27/2016			3rd fl stairway A - 2 LO
FO-338090	1/28/2016			The two halogen 220v work lights on the south side of the stage are burned out. At least one of them has broken porcelain contacts and need to be replaced.
FO-338091	1/28/2016			The two halogen 220v work lights on the south side of the stage are burned out. At least one of them has broken porcelain contacts and need to be replaced.
FO-338092	1/28/2016			There is no power at the outlets under the desk in this control booth. These are needed to power equipment needed for a performance. Please repair. Thanks
FO-338096	1/28/2016			The night time security lights on the north side of the building are not operating after dark. The timer seems to be operating. Please replace the light bulbs or repair. This can be a safety concern to our elderly patrons with icy conditions. Thanks
FO-338122	1/28/2016			RM 201.6 has lights out. Please replace. The room has 1 electrical problem.
FO-338152	1/28/2016	1/28/2016		Time to attend training for the new Generator at Engineering for all the Electricians.
FO-338168	1/28/2016			A number of the house lights over the seats and stage area are out and need replacement. It's an electrical problem. A scaffold may be needed.
FO-338160	1/29/2016			**ADDING ELECTRICIAN: Assist in installing 4 new booster pumps located in mechanical room 100. Disconnect as needed and rewire new panels in. See Don Bear for detail. *Please use this work order for entire project  (**) PO REQ DK 1/4 Transport new b
FO-338192	1/29/2016			Install (wire) emergency shut off relay for steam generators. Engineer has shut-off.
FO-338200	1/29/2016			Time for Contractor to come out, and repair Dimmer Board at the theatre.
FO-338212	1/29/2016			Room 9380 (inside room 9374) - Several light burnt out. Please replace. There is 1 electrical problem in Dr. Sakr's office.
FO-338241	1/29/2016			1 EP - first level, engineering parking space. Bulbs have been changed.
FO-338263	1/30/2016			Time for Team Leader Administrative Time for the month of February 2016.
FO-338264	1/30/2016			Time for Electricians to repair clocks used throughout the University.
<b>T - Locksmith</b>			<b>105</b>	
FO-335792	1/4/2016	1/4/2016		REPLACE CORE MAIN ENTRANCE 3RD FLOOR ROOM # 300

WO	Recieved	Finished	Total	Request
FO-335890	1/4/2016	1/12/2016		<p>New Key Lost / Stolen Key #: 17278 Key Holder ID: Ken Doherty Qty: 3</p> <p>action: The 3 Keys I need are 11LA10-22, stamped as key 17278</p>
FO-335883	1/4/2016	1/12/2016		<p>New Key New Staff Member Key #: 29A2-11 Key Holder ID: College of Engineering, Dean's Office Qty: 3</p> <p>action: This key is for office #1155. Thank you.</p>
FO-335882	1/4/2016	1/12/2016		<p>New Key Lost / Stolen Key #: Desk Key - Knoll Desk Key Holder ID: Daniel Modrich Qty: 2</p> <p>action: Office of Student Financial Aid needs 2 new keys made for new employee. Key#097 for cubicle #341.06. Account #: 147771</p>
FO-336137	1/4/2016	1/12/2016		<p>New Key New Staff Member Key #: 83432--4 Key Holder ID: Ciara Viola Qty: 1</p> <p>action: New key</p>
FO-336089	1/4/2016	1/13/2016		<p>New Key New Staff Member Key #: 106229 Key Holder ID: Anthony Carinci/Lindsay Geibig Qty: 1</p> <p>action: I would like one submaster key to the DOSO suite for their office manager - I have an email from the Dean of Students, Dr. Strauss, approving it</p>
FO-336094	1/4/2016		1/7/2016	<p>New Key New Staff Member Key #: 17818-2 Key Holder ID: Alvin L. Rainey, Jr. Qty: 3</p> <p>action: N/A Account #: 165361</p>
FO-336096	1/4/2016	1/13/2016		<p>New Key Damaged Key #: 17819-5 Key Holder ID: Alvin L. Rainey, Jr. Qty: 3</p> <p>action: N/A</p>
FO-336100	1/5/2016			KEYS & CORES ( JANUARY 2016 )
FO-336106	1/5/2016	1/12/2016		Key needed for Sherry Searcy's Office Key #72049 Qty-1

WO	Recieved	Finished	Total	Request
FO-336169	1/5/2016	1/13/2016		<p>Replacement New Staff Member Key #: um226 Key Holder ID: Ruth Jensen Qty: 2</p> <p>action: New Adm. Assist. for the Mort. Sci. Bldg. overhead cabinet is locked and we don't have a key for it.</p>
FO-336170	1/5/2016	1/12/2016		<p>New Key New Staff Member Key #: 17B AG11 Key Holder ID: Jon Barth Qty: 1</p> <p>action: request 1 key to the above core Account #: 228156</p>
FO-336172	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16ED23 Key Holder ID: Eric Johnson Qty: 3 keys and 2 cores</p> <p>action: 3 keys and 2 cores Account #: 228184</p>
FO-336174	1/5/2016	1/13/2016		<p>Core Change Lost / Stolen Key #: 16EE6 Key Holder ID: Eric Johnson Qty: 5 keys and 2 cores</p> <p>action: 5 keys and 2 cores Account #: 228184</p>
FO-336176	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16EG38 Key Holder ID: Eric Johnson Qty: 5 keys and 2 cores</p> <p>action: 5 keys and 2 cores Account #: 228184</p>
FO-336177	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16EG21 Key Holder ID: Eric Johnson Qty: 3 keys and 2 cores</p> <p>action: 3 keys 2 cores Account #: 228184</p>
FO-336178	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16EG12 Key Holder ID: Eric Johnson Qty: 5 keys and 2 cores</p> <p>action: 5 keys and 2 cores Account #: 228184</p>
FO-336179	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16EH23 Key Holder ID: Eric Johnson Qty: 3 keys and 2 cores</p> <p>action: 3 keys and 2 cores Account #: 228184</p>

WO	Recieved	Finished	Total	Request
FO-336180	1/5/2016	1/12/2016		<p>New Key Lost / Stolen Key #: 16EJ13 Key Holder ID: Eric Johnson Qty: 5 keys and 2 cores</p> <p>action: 5 Keys and two cores Account #: 228184</p>
FO-336168	1/5/2016	1/12/2016		<p>New Key Lost / Stolen Key #: 14772 Key Holder ID: Randy Paquette Qty: 1</p> <p>action: 1-Master Key 14772</p>
FO-336181	1/5/2016	1/12/2016		<p>Core Change Lost / Stolen Key #: 16EL7 Key Holder ID: Eric Johnson Qty: 5 keys and 2 cores</p> <p>action: 5 keys and 2 cores Account #: 228184</p>
FO-336182	1/5/2016	1/12/2016		<p>New Key Lost / Stolen Key #: 9SA1.9 Key Holder ID: Diane Sevigny Qty: 5</p> <p>action: Custodial Supervisors (3), Director, and new Associate Director do not have key to the grounds door. Needed for picking up and bringing vehicles back on af</p>
FO-336228	1/5/2016	1/12/2016		<p>New Key Lost / Stolen Key #: 18910 Key Holder ID: Art Office Qty: 2</p> <p>action: Old Main Graduate Studio "H" room # 0369</p>
FO-336298	1/6/2016	1/13/2016		<p>New Key Lost / Stolen Key #: 72411 Key Holder ID: Dawn Cochrane Qty: 5</p> <p>action: More personnel and faculty are being added to this area. Currently have no keys to pass out to new employees.</p>
FO-336299	1/6/2016	1/13/2016		<p>New Key Lost / Stolen Key #: old master Key Holder ID: Chrystal Camilleri Qty: 3</p> <p>action: Duplicate old Building Master for 5447 Woodward. Retain one in Lock Shop. 2 for Design Services.</p>

WO	Recieved	Finished	Total	Request
FO-336344	1/6/2016	1/14/2016		<p>New Key New Staff Member Key #: ? Key Holder ID: Ambika Mathur Qty: 4</p> <p>action: Please provide (4) Four keys to suite 410 main entry door.</p> <p>Please fell free to call if you have any questions. Account #: N/A</p>
FO-336343	1/6/2016	1/13/2016		<p>Replacement Lost / Stolen Key #: HON 148E &amp; FR 431 Key Holder ID: Jeffrey Kentor and Michelle Matthews Qty: 2 each</p> <p>action: File Cabinet keys for sociology offices 2233 and 2242. Account #: 126911</p>
FO-336449	1/6/2016	1/14/2016		<p>New Key New Staff Member Key #: key Key Holder ID: Leo Lieberman Qty: 1</p> <p>action: Hi Mike, I need a copy made for a mailbox key. I am sending the original and blank via interoffice envelope to your attention, for a copy please.</p> <p>Thanks-</p>
FO-336345	1/6/2016			<p>New Key Lost / Stolen Key #: 66530-25 Key Holder ID: Israel Sexton Qty: 2 action: Key to access mail room on Mezzanine floor of 5057 Woodward. Would like one key for our main office and key as back up if possible.</p>
FO-336346	1/6/2016	1/13/2016		<p>New Key Lost / Stolen Key #: 9zca5 Key Holder ID: Beth Madigan Qty: 4</p> <p>action: Please make 4 keys for core 9zca5.</p>
FO-336448	1/7/2016	1/13/2016		<p>New Key Lost / Stolen Key #: Key Key Holder ID: Leo Lieberman for Undergrad Admissions Qty: 1</p> <p>action: Please copy mail box key #36 which I am sending to you with a blank via interoffice mail. Many thanks - Leo</p>
FO-336446	1/7/2016			<p>New Key New Space Assignment Key #: new core needed Key Holder ID: need 5 five keys for staff assigned to this area Qty: 1 action: Need an internal door within room 221 without a core lock transitioned to a core locked door. Would like 5 keys for this n</p>
FO-336443	1/7/2016	1/15/2016		<p>New Key New Staff Member Key #: 23338.14 Key Holder ID: Debra Eastman Qty: 1</p> <p>action: Need an additional key for this room- new staff member Account #: 135511</p>

WO	Recieved	Finished	Total	Request
FO-336442	1/7/2016	1/13/2016		<p>New Key New Staff Member Key #: 30506 Key Holder ID: College of Engineering, Dean's Office Qty: 2</p> <p>action: This is for room 2545. Thank you.</p>
FO-336423	1/8/2016	1/8/2016		CARPENTERS TO REMOVE CORES & SAVE WHISTLER GALLERY ( SEE ROSE FOSTER 313-664-2500 )
FO-336942	1/8/2016	1/15/2016		<p>New Key New Space Assignment Key #: N/A Key Holder ID: Andrew Brickle &amp; Brian Brickle Qty: 2 copies of each</p> <p>action: Note: Contractor Requests Master Keys for 5th floor, 7th Floor, CAPS and X287 for Mech rooms. Account #: 771871</p>
FO-336506	1/8/2016	1/15/2016		<p>New Key Lost / Stolen Key #: Key # 96582 Key Holder ID: Gerald Burns Qty: 1</p> <p>action: 1 replacement key for Nurse Practitioner, Gerald Burns to his office #453 at Tolan Park Medical Building. Key # 96582, CORE # TPB1-8. Other key was lost.</p>
FO-336663	1/8/2016	1/13/2016		<p>New Key New Staff Member Key #: 18745 Key Holder ID: Art Department Qty: 5</p> <p>action: This key opens (Rooms 60.1-60.6)</p>
FO-336664	1/8/2016	1/13/2016		<p>New Key New Staff Member Key #: 27619 Key Holder ID: Art Department Qty: 5</p> <p>action: This key opens room 60.2</p>
FO-336515	1/8/2016	1/11/2016		<p>New Key Lost / Stolen Key #: 31DA Key Holder ID: Juanitta Qty: 10</p> <p>action: 10 Sub Master Keys</p>
FO-336666	1/8/2016	1/14/2016		<p>New Key New Space Assignment Key #: 7911-2 Key Holder ID: DR Yang Zhe and his assistants Qty: 5</p> <p>action: This is the same core that was move from Dr Yangs old lab to the newly renovated lab 4310. Account #: N/A</p>

WO	Recieved	Finished	Total	Request
FO-336700	1/11/2016	1/15/2016		<p>New Key Lost / Stolen Key #: 7694 15-18 Key Holder ID: Lynette Rae Qty: 4</p> <p>action: Key is actually for lab entry...Room 7130 not 7133 as the drop down menu would not let me enter correct room Account #: 133751</p>
FO-336705	1/11/2016	1/15/2016		<p>New Key New Staff Member Key #: 18924 Key Holder ID: Amy Hays Qty: 4</p> <p>action: 4 keys for Room 378(Studio U) in Old Main graduate Art Studio area.</p>
FO-336662	1/11/2016	1/15/2016		<p>New Key New Staff Member Key #: 16030 Key Holder ID: Martha Qty: 2</p> <p>action: 2 new keys</p>
FO-336661	1/11/2016	1/15/2016		<p>New Key New Staff Member Key #: 19075 Key Holder ID: Amy Hays Qty: 5</p> <p>action: 3106 old main</p>
FO-336660	1/11/2016	1/15/2016		<p>New Key New Staff Member Key #: 64660 Key Holder ID: Paul Bishop Qty: 4</p> <p>action: Keys for room 2371</p>
FO-336824	1/12/2016	1/20/2016		<p>Core Change Lost / Stolen Key #: key 037042, core AB14 Key Holder ID: Angelica Reyna Qty: 2 cores and 4 keys</p> <p>action: 2 cores and 4 keys. **** Emergency core 9 is installed please return to front desk**** Account #: 228156</p>
FO-336823	1/12/2016	1/20/2016		<p>Core Change Lost / Stolen Key #: core number: 22aad4 key code: 61782 Key Holder ID: Xiantria Nichols Qty: 1 core and 2 keys</p> <p>action: 1 core and 2 keys Account #: 228400</p>
FO-336822	1/12/2016	1/25/2016		<p>Core Change Lost / Stolen Key #: core 4874af Key Holder ID: Xiantria Qty: 1 mailbox core and 4 keys</p> <p>action: 1 mailbox core and 4 keys Account #: 228400</p>

WO	Recieved	Finished	Total	Request
FO-336820	1/12/2016	1/20/2016		<p>New Key Damaged Key #: core 4741af Key Holder ID: Xiantria Nichols Qty: 1 key</p> <p>action: cut 1 mailbox key Account #: 228400</p>
FO-336737	1/12/2016	1/19/2016		<p>New Key Lost / Stolen Key #: asst Key Holder ID: Jorge Chinaea Qty: 16</p> <p>action: 3311, 3318, 3321, 3324 &amp; 3326</p>
FO-336819	1/12/2016	1/20/2016		<p>New Key Damaged Key #: 4022po Key Holder ID: Xiantria Nichols Qty: 1 key</p> <p>action: cut 1 mailbox key Account #: 228400</p>
FO-336817	1/12/2016	1/19/2016		<p>New Key New Staff Member Key #: 18719 Key Holder ID: Amy Hays Qty: 7</p> <p>action: Room 157, Art Building</p>
FO-336816	1/12/2016	1/19/2016		<p>New Key Lost / Stolen Key #: 101304 Key Holder ID: Amy Hays Qty: 3</p> <p>action: Room 302 Schaver Music Hall</p>
FO-336815	1/12/2016	1/19/2016		<p>New Key New Staff Member Key #: 19106 Key Holder ID: Amy Hays Qty: 5</p> <p>action: Room 3108 Old Main, Graphic Design Front Door</p>
FO-336814	1/12/2016	1/19/2016		<p>New Key New Space Assignment Key #: Elevator UTB Key Holder ID: Kenneth Doherty Qty: 1</p> <p>action: Procurement would like to order one Elevator Key for the AAB Freight Elevator. The key should access the 4th floor. The key number desired is Key UTB</p>
FO-336813	1/13/2016			<p>Replacement New Staff Member Key #: 882 Key Holder ID: Division of Engineering Technology, Main Office Qty: 3</p> <p>action: Request 3 additional keys for new staff and key box</p>



WO	Recieved	Finished	Total	Request
FO-336812	1/13/2016	1/20/2016		<p>Replacement Lost / Stolen Key #: X422 Key Holder ID: Joe Fiore Qty: 3</p> <p>action: We need keys that we lost for a wall cabinet in room 4364.</p>
FO-336811	1/13/2016	1/20/2016		<p>New Key Lost / Stolen Key #: 110X Key Holder ID: Gjon Thaqi Qty: 10</p> <p>action: 10-Keys 110X</p>
FO-336890	1/13/2016	1/20/2016		<p>Replacement New Staff Member Key #: 874 Key Holder ID: Division of Engineering Technology, Main Office Qty: 4</p> <p>action: Need additional keys for new staff and key box</p>
FO-336856	1/13/2016	1/21/2016		<p>New Key Lost / Stolen Key #: 25296 xoe22 x2426 Key Holder ID: Mike Waker Qty: 1 each</p> <p>action: Keys needed for Skillman Bldg. service team elevator access</p>
FO-336943	1/14/2016			<p>New KeyNew Staff MemberKey #: Key #96645Key Holder ID: Marquetta NorwoodQty: 1 action: Marquetta Norwood is a new Nurse Practitioner for our department and needs an office key for room #481.</p>
FO-336945	1/14/2016	1/21/2016		<p>New Key New Staff Member Key #: 38059 Key Holder ID: Leo T./Llauna Parker Qty: 2</p> <p>action: New office manager for SLIS needs a key. (copy for back up)</p>
FO-336946	1/14/2016	1/21/2016		<p>New Key New Staff Member Key #: #9QF3X Key Holder ID: Louise Dezur Qty: 6</p> <p>action: Keys needed for additional Instructional Assistants Account #: 124961</p>
FO-336948	1/14/2016	1/21/2016		<p>New Key New Staff Member Key #: #9QF1X Key Holder ID: Louise Dezur Qty: 6</p> <p>action: Keys needed for additional Instructional Assistants Account #: 124961</p>
FO-337004	1/14/2016	1/21/2016		<p>New Key New Staff Member Key #: 6846 Key Holder ID: Louise Dezur Qty: 4</p> <p>action: Keys for new research assistants Account #: 124961</p>

WO	Recieved	Finished	Total	Request
FO-337002	1/14/2016	1/25/2016		New Key New Staff Member Key #: 16305 Key Holder ID: Martha Hayward Qty: 2  action: (2) keys please
FO-337000	1/14/2016	1/25/2016		New Key New Staff Member Key #: 16304 Key Holder ID: Martha Hayward Qty: 2  action: (2) keys please
FO-336997	1/14/2016	1/26/2016		New Key New Staff Member Key #: 401 Key Holder ID: John J. Reiners, Jr. Qty: One  action: I want a key that will open room 0413 in the animal quarters of Elliman. I was told by Cathy Kendra to request key #401. I am a professor in the Inst.
FO-337400	1/19/2016	1/27/2016		New Key New Staff Member Key #: 64750 Key Holder ID: Paul Bishop Qty: 4  action: Keys for room 2374, Old Main.
FO-337401	1/19/2016			New KeyNew Staff MemberKey #: Key 7892Key Holder ID: Mark HiskeQty: 1action: Scott Hall DLAR 00200 area
FO-337402	1/19/2016	1/27/2016		New Key Lost / Stolen Key #: FR416 Key Holder ID: Dawn Cochrane Qty: 3  action: An employee was transferred from one area of the department to another area to sit in the last remaining cubicle in the Admin. office. In the course of the years, we h
FO-337404	1/19/2016			ReplacementNew Staff MemberKey #: 104E (Desk Key)Key Holder ID: College of Engineering, Dean's OfficeQty: 2action: This request is for a DESK key (#104E), in room 1155.Thank you, Shannon
FO-337405	1/19/2016			New KeyNew Space AssignmentKey #: 31330. (Core is G-51)Key Holder ID: College of Engineering Dean's OfficeQty: 2action: To fulfill key request for students needing access to Lab 1356.
FO-337501	1/20/2016			New KeyNew Staff MemberKey #: 31 BC2Key Holder ID: Theresa Y. HillQty: 3action: Please duplicate 3 keys for this core. Contact Theresa Y. Hill at 577-1417 with any questions regarding this request. Thank you!
FO-337518	1/20/2016			New KeyLost / StolenKey #: 26118Key Holder ID: George LloydQty: 2action: Ben Madigan, and Darrin Addams. Third floor custodial closet.
FO-337544	1/21/2016			Lock shop training for Jeff Hammell
FO-337581	1/21/2016			New KeyNew Staff MemberKey #: G56Key Holder ID: College of Engineering, Dean's OfficeQty: 2action: This is for room 1520.Thank you
FO-337580	1/21/2016			New KeyNew Space AssignmentKey #: 89659Key Holder ID: Dominic Grillo Qty: 1action: Please provide key for gate lock in order for snow removal contractor to get in and out to remove snow and ice. Send Key to Jon Frederick at PS#8 for distribution.
FO-337579	1/21/2016			New KeyDamagedKey #: 105972-1Key Holder ID: Anthony Carinci, Student Center AdminQty: 1action: The 105972-1 key was damaged during use and has a small crack. We have a temporary key that we will utilize for the time, but need this one repaired

WO	Recieved	Finished	Total	Request
FO-337645	1/21/2016	1/26/2016		<p>New Key New Staff Member Key #: Brown Box Key Key Holder ID: Project Superintendent - Phil Parlovecchio Qty: 1</p> <p>action: Requesting a brown box key for the project superintendent of the Elliman - KCI relocation project. As part of the pr</p>
FO-337644	1/21/2016	1/22/2016		<p>New Key Lost / Stolen Key #: 10AA 2-15 Key Holder ID: Dr. Bonnie Sloane Qty: two</p> <p>action: Please issue a couple of keys to room 6137. Dr. Sloane is the new occupant of this room. Account #: 133601</p>
FO-337724	1/22/2016	1/27/2016		<p>New Key Lost / Stolen Key #: OE31 Key Holder ID: Maureen Kemp Qty: 3</p> <p>action: Provide 3 key:</p> <p>1) OE31 2) Duplicate key for Refrig crew van 3) Tool bin key Account #: 163961</p>
FO-337723	1/22/2016	1/27/2016		<p>New Key New Staff Member Key #: 20030 Key Holder ID: Elizabeth Elder Qty: 1</p> <p>action: One master key Account #: 301039</p>
FO-337722	1/22/2016	1/27/2016		<p>New Key Lost / Stolen Key #: 7AA1J28 Key Holder ID: Vieira-Martinez Qty: 3</p> <p>action: We have a new faculty member in need of a key.</p>
FO-337781	1/25/2016	1/27/2016		<p>New Key New Staff Member Key #: 13311-3 Key Holder ID: Gail Clavenna Qty: 5</p> <p>action: core was recently changed and original number of keys ordered is insufficient</p>

WO	Recieved	Finished	Total	Request
FO-337788	1/25/2016	1/27/2016		<p>New Key New Space Assignment Key #: 21-BA10 Key Holder ID: Gabrielle SiKora Qty: 1</p> <p>action: Please create (1) additional key for 128.2 - the building brown box does not open this door. Customer Approval sent to Mike Pines. Account #: 120</p>
FO-337816	1/25/2016			<p>New KeyLost / StolenKey #: Brown BoxKey Holder ID: Pat Shortel, Susan &amp; JayQty: 3 action: Require Three (3) Brown Box keys for the lighting retrofit crew.</p>
FO-337899	1/25/2016			<p>Core Change Lost / Stolen Key #: core # - 17AAD40, key # - 34037 Key Holder ID: Donnella Johnson Qty: 1 room core, 1 mailbox core, 3 keys</p> <p>action: 1 room core, 1 mailbox core and 3 keys Account #: 228200</p>
FO-337898	1/25/2016			<p>Core Change Lost / Stolen Key #: core # - 17AAC59, key # - 33991 Key Holder ID: Donella Johnson Qty: 1 room core, 1 mailbox core, 3 keys</p> <p>action: 1 room core, 1 mailbox core and 3 keys Account #: 228200</p>
FO-337897	1/25/2016			<p>Core Change Lost / Stolen Key #: core # - 17AAE56, key # - 34118 Key Holder ID: Donnella Johnson Qty: 1 room core, 1 mailbox core, 3 keys</p> <p>action: 1 mailbox core, 1 room core, and 3 keys Account #: 228200</p>
FO-337896	1/26/2016	1/26/2016		<p>New Key Damaged Key #: XOE22 Key Holder ID: Warren Owens Qty: 1</p> <p>action: Need new XOE22 key. It is worn.</p> <p>Also need a key cut for a lift.</p> <p>2 keys</p> <p>Account #: 163961</p>
FO-337993	1/26/2016			<p>New KeyNew Staff MemberKey #: 19 AC2Key Holder ID: Chaoyang ChenQty: 1 action: Need a key for machine shop 1236.</p>
FO-337994	1/26/2016			<p>New KeyNew Staff MemberKey #: 2165Key Holder ID: Sharon (CHERI) MillerQty: 6 action: This is the main office key for the department of economics. I need extras to give to the instructors that teach after 5:00PM -- who need to place the equipment (I</p>
FO-337995	1/26/2016			<p>ReplacementNew Staff MemberKey #: FR 347Key Holder ID: Sharon (CHERI) Miller -- &amp; Ranae HamamaQty: 3 action: We have a new Undergraduate Academic Advisor, Ranae Hamama.She does not have a desk key.We would like her to have oneand to keep two addi</p>

WO	Recieved	Finished	Total	Request
FO-337998	1/26/2016			Core Change Lost / Stolen Key #: core # - 17AAB32, key # - 33899 Key Holder ID: Donnella Johnson Qty: 1 room core, 1 mailbox core, 3 keys  action: 1 room core, 1 mailbox core, and 3 keys Account #: 228200
FO-337989	1/26/2016			Core Change Lost / Stolen Key #: key 101920 Key Holder ID: Sheila Goree Qty: 1 room core, 1 mailbox core, 4 keys Please return temp core 2AB-40  action: 1 room core, 1 mailbox core, and 4 keys Account #: 228300
FO-337999	1/26/2016			Core Change Lost / Stolen Key #: key 101766 Key Holder ID: Sheila Goree Qty: 1 room core, 1 mailbox core, 3 keys  action: 1 room core, 1 mailbox core and 3 keys Account #: 228300
FO-338000	1/26/2016			Core Change Lost / Stolen Key #: key 101624 Key Holder ID: Sheila Goree Qty: 1 room core, 1 mailbox core, 3 keys  action: 1 room core, 1 mailbox core and 3 keys Account #: 228300
FO-337992	1/26/2016			New KeyLost / StolenKey #: 15BN3, 15BJ14-Rm. 4254, 15BS2-Rm. 4116Key Holder ID: Sonya ScottQty: 5 eachaction: I have the same Core 15BN3 for Rm. 4210, 4230, 4240 & 4267. Is it possible to put a rush on this order? This is the new Dean of EACPHS's I
FO-337991	1/26/2016			New KeyNew Space AssignmentKey #: 111365Key Holder ID: Jon BarthQty: 3action: Need three additional submasters for rekeying of Towers cafe, that now falls under Student Center Master. These are submasters for cores 30AD61-30AD64.Account #: NA
FO-337990	1/26/2016			New KeyNew Staff MemberKey #: 66288Key Holder ID: Peter LevanovichQty: 1action: New lab member
FO-338108	1/27/2016			New KeyLost / StolenKey #: 27824Key Holder ID: Large Teaching LabQty: 3action: 3 keys for Room 50 in Science/Engineering Library.
FO-338107	1/27/2016			New KeyLost / StolenKey #: 18290Key Holder ID: LabQty: 3action: 3 keys for State Hall Room 313
FO-338105	1/27/2016			New KeyNew Space AssignmentKey #: 7502-4Key Holder ID: Chacko GeorgeQty: 1action: Please issue a copy of the submaster for Pharmacology. Dr. Sloane wanted to keep her sub master and I gave my sub master to the new chair (Dr. Mattingly). I ne
<b>T - Painter</b>			<b>32</b>	
FO-335800	1/4/2016			Finish, Application of epoxy floor, 4th floor Green House.
FO-335921	1/4/2016	1/7/2016		PAINTERS TO PAINT SHELF FOR THE PIPE SHOP
FO-336381	1/7/2016	1/12/2016		Need Graffiti removed from doors and walls in hallway. Someone sprayed a stencil reading "the things you own end up owning you" on the doors and walls of 3rd floor hallway in Theatre & Dance Dept. (POLICE REPORT #W160070042)
FO-336408	1/7/2016	1/19/2016		Please complete drywall patch with tape/mud and paint wall by receptions desk near training room 3rd floor OEHS. See Corey Blair for location if needed
FO-336415	1/7/2016			HANDYMAN TIME ( JANUARY 2016 )
FO-336421	1/8/2016	1/11/2016		SAFTEY TIME FOR THE MONTH OF JANUARY.

WO	Recieved	Finished	Total	Request
FO-336422	1/8/2016	1/26/2016		Sand, Prime & Paint, all Doors & Jambs, in Green House, on the 4th Floor.
FO-336499	1/8/2016	1/11/2016		scrape leaded or unleaded paint chips repair plaster walls as nesc in bsmnt. and refinish hand rails in stair well to bsmt.
FO-336538	1/11/2016			CLEAN & PAINT OVER GRAFFITI, ENTIRE CAMPUS, FOR THE MONTH OF JANUARY.
FO-336542	1/11/2016	1/19/2016		Please mud and paint wall at entrance near north/west side. See Gerry (PLUMBER) if needed for detail
FO-336601	1/11/2016			PAINTERS,PLEASE PATCH/PAINT DAMAGED STAIRWELL WALLS AND LANDING IN STAIRWELL- B , 5TH FLR.PRIORITY-LOW
FO-336638	1/11/2016	1/14/2016		1st floor Landing, by the men's Bathroom, South Wall, Plaster Repair & Paint to finish.
FO-336640	1/11/2016	1/21/2016		Scrape, Prime & paint North entrance to Green House, Ceilings & Walls, 4th floor
FO-336657	1/12/2016			PAINTERS TO PAINT CEILING IN ROOMS 454 ,456,& 458 ALSO CLEAN LIGHT LENSES
FO-336658	1/12/2016	1/28/2016		PAINTERS TO TOUCH UP RECEPTION SPACE & ROOM 1520 & 1590.2 FOR A FEBUARY EVENT. SEE E-MAIL
FO-336742	1/12/2016			Please check buckling paint patches on walls in east stairwell between 1st thru 4th floors. please check walls in west stairwell also for buckled paint patches. thank you
FO-336877	1/13/2016	1/21/2016		Scrape, Prime & Paint ceiling & walls in South Entrance, 4th floor of Green house.
FO-336965	1/14/2016			Tape/Mud, sand, Prime & Paint new drywall in common area, by the F-stairwell.
FO-337279	1/19/2016	1/27/2016		ROOM # 428 WALLS NEED PAINTING
FO-337281	1/19/2016	1/25/2016		ROOM # 413 WALLS NEED PAINTING
FO-337283	1/19/2016	1/28/2016		FOURTH FLOOR OUTSIDE WOMENS BATHROOM / WALLS NEED PAINTING
FO-337391	1/20/2016			PAINTERS TO PAINT WALLS ROOM # 433
FO-337545	1/21/2016	1/26/2016		PRIME & PAINT TO FINNISH CEILING, WALLS IN NORTH CORRIDORR BY ELEVATOR ON FORTH FLOOR, TO GREEN HOUSE.
FO-337593	1/21/2016			Purdy Library 4th Floor Paint peeling on ceiling next to elevator #2. Please repair.  Thank you.
FO-337604	1/21/2016			PAINTERS TO MUDD & PAINT A DRYWALL PATCH ROOM # 137 & 139
FO-337651	1/22/2016			PAINTERS TO MUD & PAINT RECEIPTION AREA 4TH FLOOR
FO-337826	1/25/2016	1/26/2016		Graffiti written on pedestrian door of 100 Antoinette. Please re-paint. WSU Police report number: W160250076.
FO-338062	1/26/2016	1/28/2016		Trade: Painters Priority: Medium Remove graffiti from inside the passenger elevator car of the office wing elevator. POLICE REPORT #W16020034.
FO-337903	1/26/2016			PAINTERS TO PAINT WALLS, IN ROOMS 454, 456, 457.
FO-338112	1/28/2016			Please paint the walls in the lobby, on the north side of the elevators, from the handicapped entrance to the ROTC entryway.
FO-338149	1/28/2016			PAINTERS TO PAINT COVE BETWEEN CEILING & WINDOW. ROOM # 2134.00 ( SEE STEPHEN CARPENTER FOR LOCATION )
FO-338169	1/29/2016			4th Floor - Window columns, scrape, Patch, Prime & Paint to finish Entire Floor.
<b>T - Pipefitter</b>			<b>38</b>	
FO-335788	1/1/2016	1/4/2016		Repair holes in the large condensate storage tank located at the base of the basement stairs. There are several holes in the tank causing loss of condensate..... ME/1-4-15 .....
FO-335927	1/4/2016			Replacement heating booster coils for locations: #163.2, #166.3, #167.2, #169.2, #171.1, #174.3 all located in the plenum for AHU #2./ Also 2 coils for 11.2, and 1 for 57.3 ..... JH/1/4/16.....  *Hot Work Permit Required / Steam shu
FO-336167	1/5/2016	1/5/2016		processing time for paperwork, e-mails, phone calls, etc....CB.....
FO-336305	1/6/2016	1/6/2016		Move items to stock in Pipe Shop ..... ME/1-6-16 .....
FO-336318	1/6/2016	1/6/2016		processing time for paperwork,e-mails, phone calls, etc.....CB.....1-6-16
FO-336319	1/6/2016	1/6/2016		take insulation contractor to a few buildings on campus to quote some work.....CB...1-6-16
FO-336322	1/6/2016	1/6/2016		meet scaffolding company to gain access for set up.....1-6-16
FO-336342	1/7/2016	1/8/2016		R/R steam leak under stage ..... ME/1-7-16 .....

WO	Recieved	Finished	Total	Request
FO-336349	1/7/2016	1/7/2016		Assist contractor for cross over pump leaking in penthouse ..... ME/1-7-16 .....
FO-336409	1/7/2016	1/7/2016		processing time for paperwork,e-mails, phone calls, etc....CB....1-7-16
FO-336411	1/7/2016	1/7/2016		inspect chilled water pumps in penthouse for asbestos (building Engineer was concerned)....CB.....1-7-16
FO-336412	1/7/2016	1/7/2016		meet scaffolding contractor, abatement contractor, and air monitoring contractor, to gain access and provide location setup.....CB.....1-7-16
FO-336508	1/8/2016	1/8/2016		processing time for paperwork, e-mails, phone calls, etc....CB....1-8-16
FO-336511	1/8/2016	1/8/2016		meet contractor, gain access and supervise scaffolding set up....CB....1-8-16
FO-336522	1/9/2016			Seal boiler room floor penetrations and mount ceiling pans at ceiling cracks in pipe Shop to avoid water leaking in shop. See John for detail ..... EA/1-11-16 .....
FO-336656	1/11/2016	1/11/2016		meet contractor, gain access, watch set-up, and supervise abatement job.....CB...1-11-16
FO-336771	1/12/2016	1/12/2016		processing time for paperwork , e-mails, phone calls, etc.....CB....1-12-16
FO-336697	1/12/2016	1/13/2016		CEILING LEAK. ROOMS 413 AND 415. .... JH/1/12/16 .....
FO-336843	1/13/2016			OFFICE SUPPLYS FOR PIPE SHOP .....JT/1-13-16 .....
FO-336848	1/13/2016			cooling coil nipple rusted off ..... EA/1-14-16 .....
FO-336878	1/13/2016	1/13/2016		processing tme for paperwork, e-mails, phone calls, etc.....CB....1-13-16
FO-336981	1/14/2016	1/14/2016		take contractor to various building s on campus to get quotes on coils....CB.....1-14-16
FO-336982	1/14/2016	1/14/2016		provide access to contractor and supervise entry....CB.....1-14-16
FO-336886	1/14/2016	1/21/2016		R/R RM 00134 Radiator sounds water bound or clogged. Only giving off partial heat. Trap recently replaced, temperature valve recently replaced. Pipe-fitters needed to investigate repair or replacement..... JH/1-14-16 .....
FO-336898	1/14/2016			Insulate duct work in basement vending area that is dripping from condensation. See Troy for location. Hard ceiling may need access for repairs ..... CB/1-14-16 ..... *See Attached email
FO-336993	1/15/2016	1/21/2016		Pipefitters; Medium: Repair piping on HWCP's CP-1,2 ..... JH/RC....1-21-16 .....
FO-337090	1/17/2016	1/15/2016		CONFINDED SPACE TRAINING
FO-337902	1/26/2016			please have pipefitters remove elbow, condenser plate and evaporator plate on absorber #2 ..... ME/1-28-16 .....
FO-337978	1/26/2016	1/26/2016		go with Dave k to look at some pipes that need insulation....CB....1-26-16
FO-337979	1/26/2016	1/26/2016		processing time for paperwork, e-mails, phone calls, etc....CB...1-26-16
FO-338052	1/27/2016			Pipefitters-please replace cracked plastic 't' on cooling tower test station..... ME/1-27-16 .....
FO-338058	1/27/2016			Install water meter from Eldon. See engineer for details ..... RC/1-28-16 .....
FO-338059	1/27/2016			Install blow down controller from Eldon. See engineer for details/location..... RC/1-28-16 .....
FO-338065	1/27/2016			To pipe fitters. R/R RM 00023/MECH RM Please replace defective safety valve on flash tank in rm. 23..... ME/1-28-16 .....
FO-338064	1/27/2016			To pipe fitters. R/R RM 00032/MECH RM Please install a drain line and ball valve on condensate receiver behind AHU-13 ..... ME/1-28-16 .....
FO-338088	1/27/2016			This is for the pipe fitters ,please repair the flow valve in room 1215 perimeter heat line is dripping on floor..... ME/1-28-16 .....
FO-338162	1/29/2016			Repair or replace Honeywell control valve on Hydronic heating system above heating pump #12 ..... EA/1-28-16 .....
FO-338265	1/30/2016			Replace pipe machine dies 1/8" thru 2" ..... JT/ 1-30-16 .....
<b>T - Plumber</b>			<b>61</b>	
FO-335790	1/1/2016			The steel plate cover over the sump pump pit at the base of the basement stairs is rusted through and presents a fall through hazard. Please replace. .... GS/1-4-15 .....
FO-335791	1/2/2016	1/4/2016		There is a very minor drip from the toilet flush valve assembly at the stop valve on the first toilet in the Men's lavatory, 2nd floor of the Law School, near the passenger elevator and room 2209. Reported by custodian Lucy. .... TT/1-4-15 ,,
FO-336097	1/5/2016			Administrative Time for January 2016

WO	Recieved	Finished	Total	Request
FO-336124	1/5/2016	1/8/2016		Purdy Library, 4th Floor, Men's Room #440 (located in stair #1) ..... TT/1-8-16 .....  Toilet plugged and covered with plastic bag. Please repair.  Thank you.
FO-336156	1/5/2016	1/7/2016		R/R 5TH FLR Women's restroom across from 5625 Office. Toilet won't flush. .... MM/1-6-16 .....
FO-336205	1/5/2016	1/7/2016		Rm. 4341 has a clogged sink on the south side of the Rm. that needs repair..... MM/1-6-16 .....
FO-336258	1/6/2016	1/6/2016		Garbage disposal hung up in kitchen. see Jason for location ..... TT/1-6-16 .....
FO-336282	1/6/2016	1/6/2016		P.M all auto flush valve all floors **Write down all failed/repared findings with locations ..... MM/1-6-16 .....
FO-336285	1/6/2016	1/7/2016		R/R leaking delta lav faucet in womens room across from room 296 ..... GS/1/6/16 .....
FO-336337	1/7/2016	1/7/2016		SAFETY MEETING ..... MM/1-7-16 .....
FO-336339	1/7/2016	1/7/2016		R/R domestic water ceiling leak in the landing in front of boiler room..... DB/1-7-16 .....
FO-336403	1/7/2016	1/9/2016		Replace toilet seat on new toilet room 1378. The lid covers the flushing sensor ..... MM/1-7-16 .....
FO-336462	1/7/2016		1/13/2016	desired_date: 04/30/2016 project_description: Please replace the water fountain outside room 121 with a water fountain that has a water bottle dispenser attached. project_name: Water Bottle Filler
FO-336429	1/8/2016			Repair leak on roof gutter ..... GS/1-8-16 .....
FO-336430	1/8/2016	1/8/2016		R/R outside hose bib ..... GS/1-8-16 .....
FO-336482	1/8/2016	1/12/2016		4th floor ladies restroom, 1st stall, toilet is not working - won't flush ..... TT/1-9-16 .....
FO-336525	1/9/2016	1/25/2016		Replace backflow devices on 3rd floor auto valves ..... DB/1-11-16 .....
FO-336526	1/9/2016	1/25/2016		Clear sink drain and repair Chicago faucet in wood shop ..... GS/1-11-16 .....
FO-336529	1/9/2016			REPLACEMENT BATTERIES FOR PROGRESS ..... DB/1-9-16 .....
FO-336530	1/9/2016			CAM ADAPTORS FOR PLUMBERS SUMP PUMPS ..... DB/1-9-16 .....
FO-336548	1/11/2016			Repair domestic supply line to 2nd floor bathroom. Asbestos removal needed north end of sled room 1st floor ..... GS/1-11-16 .....
FO-336553	1/11/2016	1/11/2016		In Rm. 2614 (copy Rm./kitchen) the garbage disposal needs to be repaired. The switch is not working..... MM/1-11-16 .....
FO-336615	1/11/2016	1/11/2016		P.M running flush valves as needed ..... GS/1-11-16 .....
FO-336668	1/12/2016	1/12/2016		Sink in women's restroom stopped up in basement. Next to office rm 015..... TT/1-12- 16 .....
FO-336671	1/12/2016	1/12/2016		#rd floor men's restroom 1st stall. toilet runs, fills to brim once flush, over flows on floor..... TT/1-12-16 .....
FO-336798	1/13/2016	1/14/2016		2nd floor men's restroom - The 2nd urinal is constantly running..... MM/1-14-16 .....
FO-336884	1/14/2016	1/14/2016		Men's restroom on the 1st floor, 1st stall the pipe connected to the bowl is loose. When you flush water shoots out..... TT/1-14-16 .....
FO-336897	1/14/2016			Organize and relocate backflow stock and update records ..... DB/1-14-16 .....
FO-336986	1/15/2016	1/19/2016		Toilet in bathroom (room 402) is still leaking. 1 attempted with plumbers tape was made to correct this (FO#32916), but.... did not work! ..... MM/1-15-16 .....
FO-337026	1/15/2016	1/20/2016		Sink faucets in dean's restroom is hard to turn on and off, especially the cold handle. Please repair..... TT/1-15-16 .....
FO-337089	1/16/2016	1/15/2016		CONFINED SPACE TRAINING
FO-337091	1/17/2016			*Check on dock in the mornings and Keep loading dock free of water and debris as needed *Charge only time for dewatering *If salt is needed advise your Supervisor *Leave Work Order Open *Have Partner work on other work orders when dewatering required



WO	Recieved	Finished	Total	Request
FO-337094	1/17/2016			Repair Delta kitchen faucet leaking at cam packing located in Workroom 122 at 60 W. Hancock.
FO-337095	1/17/2016			Repair Delta faucet located in lavatory near Room 110 is leaking at cam packing. 60 W. Hancock.
FO-337096	1/17/2016			Repair low hot water pressure and flow to the second level of 60 W. Hancock, including shower and sink.
FO-337420	1/20/2016	1/21/2016		1st floor women's restroom the 2nd toilet is stopped up and the 3rd sink has a constant stream from the faucet.....MM....1-21-16
FO-337421	1/20/2016	1/21/2016		2nd floor men's restroom's 1st sink has a clogged causing water to drain slowly.....MM...1-21-16
FO-337474	1/20/2016	1/21/2016		2nd fl, Women's R/R - one of the sinks needs its battery changed.....GS....1-21-16
FO-337504	1/20/2016	1/22/2016		Women's restroom sink -washer is broken on faucet.....GS.....1-21-16
FO-337570	1/21/2016	1/21/2016		Plumbers please look at eye wash station in basement wood shop, temp of water coming out at near 100 degrees....GS.....1-21-16
FO-337575	1/21/2016	1/22/2016		Requesting to have someone look at why there is no hot water coming through the pipes. All water is cold.....GS....1-21-16
FO-337611	1/21/2016	1/22/2016		PLUMBERS, PLEASE REPAIR LEAK AT 1ST URINAL, LEAKING AT ISOLATION VALVE. PRIORITY-LOW.....T....1-21-16
FO-337643	1/22/2016	1/25/2016		5th floor women the sink need service water constantly run or handle broke.....TT.....1-22-16
FO-337652	1/22/2016	1/25/2016		Toilet in bathroom (room 402) is still leaking! I received an email that the work order was completed, I mopped the water up off the floor and 15 minutes later there was a puddle on the floor again!!! This is the 3rd work order request!! FO# 329
FO-337675	1/22/2016	1/25/2016		R/R RM 2103/RR Please have plumbers troubleshoot toilet. Continuous flushing for very long periods of time and splashing water outside of the bowl during flushing process. Also, seems to be flushing with hot water.....MM.....1-22-16
FO-337760	1/25/2016			RM 125/KITCHEN AREA ACROSS FROM WOMENS RR IN BUS SVCS SECTION HAS NO HOT WATER ,,,,,,,,,,,,,, GS/1-25-16,,,,,,,,,,,,,
FO-337918	1/26/2016			please investigate and repair hot water to toilets....(crossover) ,,,,,,,,,,,,,, GS/1-26-16 ,,,,,,,,,,,,,,
FO-337938	1/26/2016			Evaluate replacement of failing domestic galvanized water supply branch's  Debris in old pipe clogging plumbing fixtures on a daily basis ,,,,,,,,,,,,,, GS/1-26-16 ,,,,,,,,,,,,,,
FO-338016	1/27/2016			Far right sink is clogged in ladies restroom.,,,,,,,,,,,,,, MM/1-27-16 ,,,,,,,,,,,,,,
FO-338053	1/27/2016			Plumbers-please replace wax ring men's room toilet.,,,,,,,,,,,,,, MM/1-28-16 ,,,,,,,,,,,,,,
FO-338086	1/27/2016			Drain pipe leaks in anatomy lab when water is turned on.,,,,,,,,,,,,,, MM/1-28-16 ,,,,,,,,,,,,,,
FO-338087	1/27/2016			This is for the Plummer ,there is a trap leak under one of the sinks in the Lab room ,,,,,,,,,,,,, MM/1-28-16 ,,,,,,,,,,,,,,  Please repair.
FO-338102	1/28/2016			Plumber repair long flush on handicap toilet woman's room 2nd floor.,,,,,,,,,,,,,, MM/1-28-16 ,,,,,,,,,,,,,,
FO-338136	1/28/2016			Rm. 4341's sink located at the south end of the room drains very slow and needs repair. ,,,,,,,,,,,,, MM/1-28-16 ,,,,,,,,,,,,,,
FO-338161	1/29/2016			Replace isolation valves and necessary piping to water meter Valves will not hold/ No way to isolate building in an Emergency ,,,,,,,,,,,,,, DB/1-29-16 ,,,,,,,,,,,,,  **CITY WATER SHUT DOWN AND ABATEMENT REQUIRED JWT
FO-338164	1/29/2016			Replace 3 old leaking slone valves on 1st floor ,,,,,,,,,,,,,, GS/1-28-16 ,,,,,,,,,,,,,,  **BLD SHUT DOWN REQUIERED / NO RISER VALVE AVALIBLE
FO-338165	1/29/2016			Rebuild eye wash and install drain hose connection room 263 ,,,,,,,,,,,,,, GS/1-28-16 ,,,,,,,,,,,,,,
FO-338166	1/29/2016			Repair loose toilet on 1st floor at back door ,,,,,,,,,,,,,, GS/1-28-16 ,,,,,,,,,,,,,,
FO-338167	1/29/2016			Assist Lynda in updating Plumbing stock ,,,,,,,,,,,,,, GS/1-28-16 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-338173	1/29/2016			1st floor mens restroom 2nd stahl needs a new toilet seat. Seat is all broken up.,,,,,,,,,,,,,,,,,, TT/1-30-16 ,,,,,,,,,,,,,,,,,
FO-338262	1/30/2016			Administrative Time for FEBUARY 2016
<b>T - Sheetmetal</b>			<b>1</b>	
FO-337594	1/21/2016			Purdy Library Basement Paint peeling from ductwork along east side of the basement. See Richard at the Check Out desk if more detailed information is needed.  Thank you.
<b>Routine</b>			<b>7</b>	
<b>T - Electrician</b>			<b>7</b>	
FO-335909	1/4/2016			PS#1 ROUTINE CHECK 1/1 thru 1/31/16
FO-335910	1/4/2016			PS#2 ROUTINE CHECK 1/1 thru 1/31/16
FO-335911	1/4/2016			PS#3 ROUTINE CHECK 1/1 thru 1/31/16
FO-335913	1/4/2016			PS#4 ROUTINE CHECK 1/1 thru 1/31/16
FO-335914	1/4/2016			PS#5 ROUTINE CHECK 1/1 thru 1/31/16
FO-335915	1/4/2016			PS#6 ROUTINE CHECK 1/1 thru 1/31/16
FO-335916	1/4/2016			VARIOUS LOTS ROUTINE CHECK 1/1 thru 1/31/16
<b>Scheduled Maint. (PM)</b>			<b>573</b>	
<b>Engineering</b>			<b>436</b>	
<b>Routine</b>			<b>436</b>	
<b>E - Auxiliary</b>			<b>41</b>	
FO-335391	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335392	1/1/2016	1/20/2016		PM - Air Handling Unit
FO-335393	1/1/2016	1/20/2016		PM - Air Handling Unit
FO-335394	1/1/2016	1/21/2016		PM - Air Handling Unit
FO-335395	1/1/2016	1/21/2016		PM - Air Handling Unit
FO-335396	1/1/2016	1/21/2016		PM - Air Handling Unit
FO-335397	1/1/2016			PM - Sump Pump
FO-335398	1/1/2016	1/25/2016		PM - Sump Pump
FO-335399	1/1/2016	1/15/2016		PM - Sump Pump
FO-335400	1/1/2016	1/15/2016		PM - Sump Pump
FO-335414	1/1/2016			PM - Air Handling Unit
FO-335415	1/1/2016			PM - Air Handling Unit
FO-335416	1/1/2016			PM - Air Handling Unit
FO-335417	1/1/2016			PM - Air Handling Unit
FO-335418	1/1/2016			PM - Air Handling Unit
FO-335419	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335423	1/1/2016	1/23/2016		PM - Condensate Return Pump
FO-335424	1/1/2016	1/23/2016		PM - Condensate Return Pump
FO-335432	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335434	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335436	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335446	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335448	1/1/2016	1/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335449	1/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335450	1/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-335451	1/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335452	1/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-335421	1/3/2016			Housing - Towers Kitchen Make Up Air PM
FO-335420	1/4/2016			PM - Emergency Shower/Eyewash Station
FO-335454	1/7/2016			Generator Maintenance, Monthly
FO-335756	1/11/2016			PM - Emergency Shower/Eyewash Station
FO-335412	1/12/2016			Generator Maintenance, Monthly
FO-335618	1/13/2016			Generator Maintenance, Monthly
FO-335937	1/18/2016			PM - Emergency Shower/Eyewash Station
FO-335621	1/20/2016			Generator Maintenance, Monthly
FO-336655	1/25/2016			PM - Emergency Shower/Eyewash Station
FO-335610	1/26/2016			Generator Maintenance, Monthly
FO-335611	1/26/2016			Generator Maintenance, Monthly
FO-335612	1/26/2016			Generator Maintenance, Monthly
FO-335613	1/26/2016			Generator Maintenance, Monthly
FO-335614	1/26/2016			Generator Maintenance, Monthly
<b>E - MedPharm</b>			<b>31</b>	
FO-335258	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335259	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335260	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335261	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335262	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335263	1/1/2016	1/29/2016		PM - Domestic Water Heater, Steam
FO-335264	1/1/2016	1/29/2016		PM - Domestic Water Heater, Steam
FO-335265	1/1/2016	1/29/2016		PM - Domestic Water Heater, Steam
FO-335266	1/1/2016			PM - Water Softener
FO-335270	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335271	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335272	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335273	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335274	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335275	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335276	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335277	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335278	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335279	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335280	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335281	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335282	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335283	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335269	1/5/2016	1/5/2016		Generator Maintenance, Monthly
FO-335284	1/5/2016	1/5/2016		Generator Maintenance, Monthly
FO-335267	1/12/2016	1/12/2016		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-335268	1/12/2016	1/12/2016		Generator Maintenance, Monthly
FO-335623	1/19/2016	1/20/2016		Generator Maintenance, Monthly
FO-335608	1/26/2016	1/26/2016		Generator Maintenance, Monthly
FO-335609	1/26/2016		1/1/2016	Generator Maintenance, Monthly
FO-336708	1/26/2016	1/27/2016		Generator Maintenance, Monthly
<b>E - North</b>			<b>30</b>	
FO-334399	1/1/2016	1/21/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-334400	1/1/2016			PM - Heat Exchanger and Economizer
FO-334401	1/1/2016			PM - Heat Exchanger and Economizer
FO-335285	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335286	1/1/2016	1/15/2016		PM - Punch Tubes - Chiller/Absorber
FO-335287	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335288	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335289	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335290	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335291	1/1/2016	1/13/2016		PM - Punch Tubes - Chiller/Absorber
FO-335292	1/1/2016	1/15/2016		PM - Punch Tubes - Chiller/Absorber
FO-335293	1/1/2016	1/21/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335294	1/1/2016	1/19/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335295	1/1/2016	12/16/2015		PM - Punch Tubes - Chiller/Absorber
FO-335296	1/1/2016	1/14/2016		PM - Punch Tubes - Chiller/Absorber
FO-335297	1/1/2016	1/12/2016		PM - Domestic Water Heater, Electric
FO-335298	1/1/2016	1/13/2016		PM - Domestic Water Heater, Electric
FO-335299	1/1/2016	1/25/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335300	1/1/2016	1/25/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335301	1/1/2016	1/25/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335302	1/1/2016	1/26/2016		PM - Punch Tubes - Chiller/Absorber
FO-335303	1/1/2016	1/27/2016		PM - Punch Tubes - Chiller/Absorber
FO-335304	1/1/2016	1/21/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335305	1/1/2016	1/25/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335306	1/1/2016	1/21/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335307	1/1/2016	1/13/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335308	1/1/2016	1/13/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335309	1/1/2016			Vendor or Contractor Work
FO-335624	1/12/2016	1/12/2016		Generator Maintenance, Monthly
FO-335617	1/27/2016	1/27/2016		Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>34</b>	
FO-333890	1/1/2016		1/27/2016	Replace PRE-filters
FO-333892	1/1/2016		1/27/2016	Replace PRE-filters
FO-333893	1/1/2016		1/27/2016	Replace PRE-filters
FO-333894	1/1/2016		1/27/2016	Replace PRE-filters
FO-333895	1/1/2016		1/27/2016	Replace PRE-filters
FO-333896	1/1/2016		1/27/2016	Replace PRE-filters
FO-333897	1/1/2016		1/27/2016	Replace PRE-filters
FO-333898	1/1/2016		1/27/2016	Replace PRE-filters
FO-333899	1/1/2016		1/27/2016	Replace PRE-filters
FO-335310	1/1/2016	1/27/2016		PM - Air Compressor, Reciprocating 5-40 H.P.

WO	Recieved	Finished	Total	Request
FO-335311	1/1/2016	1/29/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335312	1/1/2016	11/30/2015		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335313	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber
FO-335625	1/1/2016	1/4/2016		Generator Maintenance, Monthly
FO-335628	1/1/2016	1/1/2016		Generator Maintenance, Monthly
FO-335629	1/1/2016	1/1/2016		Generator Maintenance, Monthly
FO-335630	1/1/2016	1/5/2016		Generator Maintenance, Monthly
FO-335650	1/1/2016	1/27/2016		Generator Maintenance, Monthly
FO-335651	1/1/2016	1/1/2016		Generator Maintenance, Monthly
FO-335750	1/6/2016	1/6/2016		PM - Chemical Feed/Metering Pump/Controller
FO-335751	1/6/2016	1/4/2016		PM - Chemical Feed/Metering Pump/Controller
FO-335752	1/7/2016	1/7/2016		PM - Semi Anunal Air Handling Unit Inspection
FO-335626	1/13/2016	1/14/2016		Generator Maintenance, Monthly
FO-335642	1/13/2016	1/13/2016		Generator Maintenance, Monthly
FO-335649	1/13/2016	1/13/2016		Generator Maintenance, Monthly
FO-335644	1/13/2016	1/13/2016		Generator Maintenance, Monthly
FO-335646	1/13/2016	1/13/2016		Generator Maintenance, Monthly
FO-335935	1/15/2016	1/29/2016		PM - Heat Exchanger and Economizer
FO-335936	1/16/2016	1/27/2016		PB - B&G Series 100 Pump
FO-335619	1/19/2016	1/20/2016		Generator Maintenance, Monthly
FO-335622	1/21/2016	1/21/2016		Generator Maintenance, Monthly
FO-335607	1/27/2016	1/27/2016		Generator Maintenance, Monthly
FO-335632	1/28/2016	1/29/2016		Generator Maintenance, Monthly
FO-335633	1/28/2016			Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>156</b>	
FO-333782	1/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333783	1/1/2016	1/27/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333784	1/1/2016	1/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333785	1/1/2016	1/27/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333786	1/1/2016	1/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333787	1/1/2016	1/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333788	1/1/2016	1/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333789	1/1/2016	1/27/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333790	1/1/2016	1/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-333791	1/1/2016	1/26/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333792	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333793	1/1/2016	1/26/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333794	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333795	1/1/2016	1/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333796	1/1/2016	1/21/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333797	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333798	1/1/2016	1/26/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333799	1/1/2016	1/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333800	1/1/2016	1/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333801	1/1/2016	1/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333802	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333803	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-333804	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333805	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333806	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333807	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333808	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333809	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333810	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333811	1/1/2016	1/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333812	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333813	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333814	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333815	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333816	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333817	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333818	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333819	1/1/2016	1/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333820	1/1/2016	1/9/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333821	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333822	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333823	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333824	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333825	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333826	1/1/2016	1/21/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333827	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333828	1/1/2016	1/21/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333829	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333830	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333831	1/1/2016	1/8/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333832	1/1/2016	1/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333833	1/1/2016	1/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333834	1/1/2016	1/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333835	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333836	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333837	1/1/2016	1/15/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333838	1/1/2016	1/16/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333839	1/1/2016	1/23/2016		PM - Air Handling Unit (ANNUAL)
FO-333840	1/1/2016	1/13/2016		PM - Air Handling Unit (ANNUAL)
FO-333841	1/1/2016	1/12/2016		PM - Air Handling Unit (ANNUAL)
FO-333842	1/1/2016	1/12/2016		PM - Air Handling Unit (ANNUAL)
FO-333843	1/1/2016	1/13/2016		PM - Air Handling Unit (ANNUAL)
FO-333844	1/1/2016	1/21/2016		PM - Air Handling Unit (ANNUAL)
FO-333845	1/1/2016	1/21/2016		PM - Air Handling Unit (ANNUAL)
FO-333846	1/1/2016	1/14/2016		PM - Air Handling Unit (ANNUAL)
FO-333847	1/1/2016	1/9/2016		PM - Air Handling Unit (ANNUAL)
FO-333848	1/1/2016	1/15/2016		PM - Air Handling Unit (ANNUAL)
FO-333849	1/1/2016	1/15/2016		PM - Air Handling Unit (ANNUAL)
FO-333850	1/1/2016	1/15/2016		PM - Air Handling Unit (ANNUAL)

WO	Recieved	Finished	Total	Request
FO-333851	1/1/2016	1/23/2016		PM - Air Handling Unit (ANNUAL)
FO-333852	1/1/2016	1/23/2016		PM - Air Handling Unit (ANNUAL)
FO-333853	1/1/2016	1/7/2016		PM - Air Handling Unit (ANNUAL)
FO-333854	1/1/2016	1/5/2016		PM - Air Handling Unit (ANNUAL)
FO-333855	1/1/2016	1/21/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333856	1/1/2016	1/27/2016		PM - Air Handling Unit (ANNUAL)
FO-333857	1/1/2016	1/28/2016		PM - Air Handling Unit (ANNUAL)
FO-333858	1/1/2016	1/28/2016		PM - Air Handling Unit (ANNUAL)
FO-333859	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333860	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333861	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333862	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333863	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333864	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333865	1/1/2016	1/8/2016		Replace PRE-filters
FO-333866	1/1/2016	1/8/2016		Replace PRE-filters
FO-333867	1/1/2016	1/8/2016		Replace PRE-filters
FO-333868	1/1/2016	1/29/2016		Replace PRE-filters
FO-333869	1/1/2016	1/29/2016		Replace PRE-filters
FO-333870	1/1/2016	1/29/2016		Replace PRE-filters
FO-333871	1/1/2016	1/29/2016		Replace PRE-filters
FO-333872	1/1/2016	1/29/2016		Replace PRE-filters
FO-333873	1/1/2016	1/29/2016		Replace PRE-filters
FO-333874	1/1/2016	1/29/2016		Replace PRE-filters
FO-333875	1/1/2016	1/29/2016		Replace PRE-filters
FO-333876	1/1/2016	1/12/2016		Replace PRE-filters
FO-333877	1/1/2016	1/14/2016		Replace PRE-filters
FO-333878	1/1/2016	1/14/2016		Replace PRE-filters
FO-333879	1/1/2016	1/16/2016		Replace PRE-filters
FO-333880	1/1/2016	1/26/2016		Replace PRE-filters
FO-333881	1/1/2016	1/27/2016		Replace PRE-filters
FO-333882	1/1/2016	1/12/2016		Replace PRE-filters
FO-333883	1/1/2016	1/12/2016		Replace PRE-filters
FO-333884	1/1/2016	1/12/2016		Replace PRE-filters
FO-333885	1/1/2016	1/12/2016		Replace PRE-filters
FO-333886	1/1/2016	1/30/2016		Replace PRE-filters
FO-333887	1/1/2016	1/8/2016		PM - Air Handling Unit (ANNUAL)
FO-333888	1/1/2016	1/9/2016		PM - Air Handling Unit (ANNUAL)
FO-333889	1/1/2016	1/26/2016		PM - Air Handling Unit (ANNUAL)
FO-333891	1/1/2016			Replace PRE-filters
FO-333900	1/1/2016	1/16/2016		Replace PRE-filters
FO-333901	1/1/2016	1/16/2016		Replace PRE-filters
FO-333902	1/1/2016	1/16/2016		Replace PRE-filters
FO-333903	1/1/2016	1/16/2016		Replace PRE-filters
FO-333904	1/1/2016	1/15/2016		Replace PRE-filters
FO-333905	1/1/2016			Replace PRE-filters
FO-333906	1/1/2016	1/15/2016		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-333907	1/1/2016	1/15/2016		Replace PRE-filters
FO-333908	1/1/2016	1/14/2016		Replace PRE-filters
FO-333909	1/1/2016	1/14/2016		Replace PRE-filters
FO-333910	1/1/2016	1/14/2016		Replace PRE-filters
FO-333911	1/1/2016	1/13/2016		Replace PRE-filters
FO-333912	1/1/2016	1/13/2016		Replace PRE-filters
FO-333913	1/1/2016	1/13/2016		Replace PRE-filters
FO-333914	1/1/2016	1/8/2016		Replace PRE-filters
FO-333915	1/1/2016		12/1/2015	Replace PRE-filters
FO-333916	1/1/2016		12/1/2015	Replace PRE-filters
FO-333917	1/1/2016		12/1/2015	Replace PRE-filters
FO-333918	1/1/2016		12/1/2015	Replace PRE-filters
FO-333919	1/1/2016	1/26/2016		Replace PRE-filters
FO-333920	1/1/2016	1/26/2016		Replace PRE-filters
FO-333921	1/1/2016			Replace PRE-filters
FO-333922	1/1/2016	1/26/2016		Replace PRE-filters
FO-333923	1/1/2016	1/26/2016		Replace PRE-filters
FO-333924	1/1/2016			Replace PRE-filters
FO-333925	1/1/2016	1/16/2016		Replace PRE-filters
FO-333926	1/1/2016	1/15/2016		Replace PRE-filters
FO-333927	1/1/2016	1/16/2016		Replace PRE-filters
FO-333928	1/1/2016	1/16/2016		Replace PRE-filters
FO-333929	1/1/2016			Replace PRE-filters
FO-333930	1/1/2016	1/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333931	1/1/2016	1/12/2016		Replace PRE-filters
FO-333932	1/1/2016	1/8/2016		Replace PRE-filters
FO-333933	1/1/2016	1/8/2016		Replace PRE-filters
FO-333934	1/1/2016	1/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-333935	1/1/2016			Replace PRE-filters
FO-333936	1/1/2016	1/8/2016		PM - Air Handling Unit (ANNUAL)
FO-333937	1/1/2016	1/7/2016		PM - Air Handling Unit (ANNUAL)
FO-333938	1/1/2016	1/5/2016		PM - Air Handling Unit (ANNUAL)
FO-333939	1/1/2016	1/8/2016		PM - Air Handling Unit (ANNUAL)
FO-333940	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333941	1/1/2016	1/29/2016		Replace PRE-filters
FO-333942	1/1/2016		1/1/2016	PM - Air Handling Unit (ANNUAL)
FO-333943	1/1/2016	1/29/2016		Replace PRE-filters
FO-337061	1/1/2016			Replace PRE-filters
FO-336183	1/5/2016		1/5/2016	Multipurpose Bldg AHU-1 Replace PRE-filters
FO-336184	1/5/2016		1/5/2016	Multipurpose Bldg AHU-2 Replace PRE-filters
<b>E - South</b>			<b>40</b>	
FO-335314	1/1/2016	1/12/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335315	1/1/2016	1/19/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335316	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335318	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber



WO	Recieved	Finished	Total	Request
FO-335320	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335327	1/1/2016	1/19/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335352	1/1/2016	1/14/2016		PM - Punch Tubes - Chiller/Absorber
FO-335364	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335408	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335422	1/1/2016	1/15/2016		PM - Punch Tubes - Chiller/Absorber
FO-335425	1/1/2016	1/26/2016		PM - Punch Tubes - Chiller/Absorber
FO-335426	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335427	1/1/2016	1/5/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335428	1/1/2016	1/6/2016		PM - Harmsco Side Stream Filter
FO-335435	1/1/2016	1/13/2016		PM - Punch Tubes - Chiller/Absorber
FO-335437	1/1/2016	1/26/2016		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335438	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335439	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335440	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335441	1/1/2016	1/13/2016		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335442	1/1/2016	1/13/2016		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335356	1/2/2016	1/29/2016		PM - Humidifier
FO-335357	1/2/2016	1/29/2016		PM - Humidifier
FO-335358	1/2/2016	1/29/2016		PM - Humidifier
FO-335359	1/2/2016	1/29/2016		PM - Humidifier
FO-335360	1/2/2016	1/29/2016		PM - Humidifier
FO-335361	1/2/2016	1/29/2016		PM - Humidifier
FO-335362	1/2/2016	1/29/2016		PM - Humidifier
FO-335363	1/2/2016	1/29/2016		PM - Humidifier
FO-335459	1/6/2016	1/6/2016		Generator Maintenance, Monthly
FO-335753	1/8/2016	1/5/2016		Monthly AHU Inspection Clean Room Unit 2
FO-335754	1/8/2016	1/5/2016		PM - Semi Anunal Air Handling Unit Inspection
FO-335755	1/8/2016	1/6/2016		PM - Monthly AHU Inspection Clean Room Unit 1
FO-335603	1/14/2016	1/14/2016		Generator Maintenance, Monthly
FO-335604	1/14/2016	1/14/2016		Generator Maintenance, Monthly
FO-335620	1/14/2016	1/14/2016		Generator Maintenance, Monthly
FO-335634	1/14/2016	1/14/2016		Generator Maintenance, Monthly
FO-335605	1/19/2016	1/19/2016		Generator Maintenance, Monthly
FO-335606	1/20/2016			Generator Maintenance, Monthly
FO-335627	1/21/2016	1/22/2016		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>67</b>	
FO-335317	1/1/2016			PM - Heat Exchanger and Economizer
FO-335319	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335321	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335322	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335323	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335324	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335325	1/1/2016			PM - Water Booster Pump

WO	Recieved	Finished	Total	Request
FO-335326	1/1/2016			PM - Water Booster Pump
FO-335331	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335332	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335333	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335334	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335335	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335336	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335337	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335338	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335339	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335340	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335341	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335342	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335343	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335344	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335345	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335346	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335353	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335354	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335355	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335365	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335366	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335367	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335368	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335369	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335370	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335371	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335372	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335373	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335374	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335375	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335376	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335377	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335378	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335379	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335380	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335381	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335382	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335383	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335384	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335385	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335386	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335387	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335388	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335389	1/1/2016			PM - Fan Coil/HV/AC Unit
FO-335403	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335404	1/1/2016			PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-335405	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335406	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335407	1/1/2016			PM - Heat Pumps (5057 Woodward)
FO-335430	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335431	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335433	1/1/2016			PM - Punch Tubes - Chiller/Absorber
FO-335443	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335444	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335445	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335447	1/1/2016			PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-335615	1/19/2016	1/20/2016		Generator Maintenance, Monthly
FO-335616	1/19/2016	1/20/2016		Generator Maintenance, Monthly
FO-336654	1/23/2016			PM - Domestic Water Heater, Gas
<b>E - West</b>			<b>37</b>	
FO-333959	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber
FO-333960	1/1/2016	1/29/2016		PM - Sump Pump
FO-333961	1/1/2016	1/29/2016		PM - Sump Pump
FO-333962	1/1/2016	1/29/2016		Replace PRE-filters
FO-333963	1/1/2016	1/29/2016		Replace PRE-filters
FO-333964	1/1/2016	1/29/2016		Replace PRE-filters
FO-333965	1/1/2016	1/29/2016		Replace PRE-filters
FO-333966	1/1/2016	1/29/2016		Replace PRE-filters
FO-333967	1/1/2016	1/29/2016		Replace PRE-filters
FO-333968	1/1/2016	1/29/2016		Replace PRE-filters
FO-333969	1/1/2016	1/29/2016		Replace PRE-filters
FO-333970	1/1/2016	1/29/2016		Replace PRE-filters
FO-333971	1/1/2016			Replace PRE-filters
FO-333972	1/1/2016			Replace PRE-filters
FO-333973	1/1/2016			Replace PRE-filters
FO-333974	1/1/2016			Replace PRE-filters
FO-333975	1/1/2016			Replace PRE-filters
FO-333976	1/1/2016			Replace PRE-filters
FO-333977	1/1/2016			Replace PRE-filters
FO-333978	1/1/2016			Replace PRE-filters
FO-333979	1/1/2016			Replace PRE-filters
FO-333980	1/1/2016			Replace PRE-filters
FO-333981	1/1/2016			Replace PRE-filters
FO-335328	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335329	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber
FO-335330	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber
FO-335347	1/1/2016	1/21/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335348	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335349	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335350	1/1/2016	1/29/2016		PM - Punch Tubes - Chiller/Absorber
FO-335351	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.

WO	Recieved	Finished	Total	Request
FO-335390	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335401	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335402	1/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-335456	1/6/2016	1/6/2016		Generator Maintenance, Monthly
FO-335429	1/12/2016	1/12/2016		Generator Maintenance, Monthly
FO-335631	1/28/2016	1/29/2016		Generator Maintenance, Monthly
<b>Trades</b>			<b>137</b>	
<b>Low</b>			<b>1</b>	
<b>T - Plumber</b>			<b>1</b>	
FO-336132	1/5/2016	1/5/2016		**ADDING REPAIR REQUEST: Rebuild failed Backflow device from FO#334809 ,,,,,,,,,,,,,, DB/1-5-16 ,,,,,,,,,,,,,,
				2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,,, DB/1-4-15 ,,,,,,,,,,,,,,
<b>Routine</b>			<b>136</b>	
<b>T - Electrician</b>			<b>120</b>	
FO-335572	1/1/2016	1/8/2016		Generator Test Friday, 1/8/2016 @ 2:15 PM.
FO-335590	1/1/2016	1/8/2016		Generator Test Friday 1/8/2016 @ 2:15 PM.
FO-335591	1/1/2016	1/8/2016		Generator Test Friday 1/8/2015 @ 2:15 PM.
FO-335592	1/1/2016	1/8/2016		Generator Test Friday 1/8/2015 @ 2:15 PM.
FO-335647	1/1/2016	1/7/2016		Generator Test Thursday 1/8/2015 @ 7:15 AM.
FO-335648	1/1/2016	1/7/2016		Generator Test Thursday 1/8/2015 @ 7:15 AM.
FO-335471	1/4/2016	1/4/2016		PM - Sump Pump Monday 1/4/2016 @ 7:30 AM.
FO-335483	1/4/2016	1/4/2016		PM - Sump Pump Monday 1/4/2016 @ 7:30 AM.
FO-335495	1/4/2016	1/4/2016		PM - Sump Pump Monday 1/4/2016 @ 7:30 AM.
FO-335507	1/4/2016	1/4/2016		PM - Sump Pump Monday 1/4/2016 @ 7:30 AM.
FO-335519	1/4/2016	1/4/2016		PM - Sump Pump Monday 1/4/2016 @ 7:30 AM.
FO-335531	1/4/2016			PM - Sump Pump
FO-335413	1/5/2016	1/5/2016		Generator Test Tuesday 1/5/2016 @ 7:15 AM.
FO-335457	1/5/2016	1/5/2016		Generator Test Tuesday 1/5/2016 @ 9:30 AM.
FO-335475	1/6/2016	1/6/2016		PM - Sump Pump Wednesday 1/6/2016 @ 7:30 AM.
FO-335487	1/6/2016	1/6/2016		PM - Sump Pump Wednesday 1/6/2016 @ 7:30 AM.
FO-335499	1/6/2016	1/6/2016		PM - Sump Pump Wednesday 1/6/2016 @ 7:30 AM.
FO-335511	1/6/2016	1/6/2016		PM - Sump Pump Wednesday 1/6/2016 @ 7:30 AM.
FO-335523	1/6/2016	1/6/2016		PM - Sump Pump Wednesday 1/6/2016 @ 7:30 AM.
FO-335535	1/6/2016			PM - Sump Pump
FO-335455	1/6/2016	1/6/2016		Generator Test Wednesday 1/6/2016 @ 7:30 AM.
FO-335458	1/6/2016	1/6/2016		Generator Test Wednesday 1/6/2016 @ 7:30 AM.
FO-335453	1/7/2016	1/7/2016		Generator Test Thursday 1/7/2016 @ 7:30 AM. **Did not run Gen no key to access Generastor for readings/need key for gen enclosure&=**
FO-335467	1/8/2016	1/8/2016		PM - Sump Pump Friday 1/8/2015 @ 7:30 AM.
FO-335479	1/8/2016	1/8/2016		PM - Sump Pump Friday 1/8/2015 @ 7:30 AM.
FO-335491	1/8/2016	1/8/2016		PM - Sump Pump Friday 1/8/2016 @ 7:30 AM.
FO-335503	1/8/2016	1/8/2016		PM - Sump Pump Friday 1/8/2016 @ 7:30 AM.
FO-335515	1/8/2016	1/8/2016		PM - Sump Pump Friday 1/8/2016 @ 7:30 AM.
FO-335527	1/8/2016			PM - Sump Pump
FO-335472	1/11/2016	1/11/2016		PM - Sump Pump
FO-335484	1/11/2016	1/11/2016		PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-335496	1/11/2016	1/11/2016		PM - Sump Pump
FO-335508	1/11/2016	1/11/2016		PM - Sump Pump
FO-335520	1/11/2016	1/11/2016		PM - Sump Pump
FO-335532	1/11/2016	1/11/2016		PM - Sump Pump
FO-335409	1/12/2016	1/11/2016		Generator Test Tuesday, 1/12/2016 @ 7:15 AM.
FO-335410	1/12/2016	1/12/2016		Generator Test Tuesday, 1/12/2016 @ 7:15 AM.
FO-335586	1/12/2016	1/12/2016		Generator Test Tuesday, 1/12/2016 @ 7:15 AM.
FO-335587	1/12/2016	1/12/2016		Generator Test Tuesday, 1/12/2016 @ 1PM.
FO-335411	1/12/2016	1/12/2016		Generator Test Tuesday, 1/12/2016 @ 1PM.
FO-335476	1/13/2016	1/13/2016		PM - Sump Pump
FO-335488	1/13/2016	1/13/2016		PM - Sump Pump
FO-335500	1/13/2016	1/13/2016		PM - Sump Pump
FO-335512	1/13/2016	1/13/2016		PM - Sump Pump
FO-335524	1/13/2016	1/13/2016		PM - Sump Pump
FO-335536	1/13/2016	1/13/2016		PM - Sump Pump
FO-335581	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 1PM.
FO-335588	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 1PM.
FO-335598	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 7:30 AM.
FO-335597	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 7:30 AM.
FO-335643	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 7:30 AM.
FO-335645	1/13/2016	1/13/2016		Generator Test Wednesday, 1/13/2016 @ 7:30 AM.
FO-335565	1/14/2016	1/13/2016		Generator Test Thursday, 1/14/2016 @ 7:15 AM.
FO-335566	1/14/2016	1/14/2016		Generator Test Thursday, 1/14/2016 @ 7:15 AM.
FO-335584	1/14/2016	1/14/2016		Generator Test Thursday, 1/14/2016 @ 7:15 AM.
FO-335596	1/14/2016	1/14/2016		Generator Test Thursday, 1/14/2016 @ 7:15 AM.
FO-335468	1/15/2016	1/15/2016		PM - Sump Pump
FO-335480	1/15/2016	1/15/2016		PM - Sump Pump
FO-335492	1/15/2016	1/15/2016		PM - Sump Pump
FO-335504	1/15/2016	1/15/2016		PM - Sump Pump
FO-335516	1/15/2016	1/15/2016		PM - Sump Pump
FO-335528	1/15/2016	1/15/2016		PM - Sump Pump
FO-335473	1/18/2016			PM - Sump Pump
FO-335485	1/18/2016			PM - Sump Pump
FO-335497	1/18/2016			PM - Sump Pump
FO-335509	1/18/2016			PM - Sump Pump
FO-335521	1/18/2016			PM - Sump Pump
FO-335533	1/18/2016			PM - Sump Pump
FO-335564	1/19/2016	1/20/2016		Generator Test
FO-335567	1/19/2016	1/20/2016		Generator Test, Tuesday 1/19/2016 @ 9:30 AM.
FO-335571	1/19/2016		1/1/2016	Generator Test
FO-335578	1/19/2016	1/20/2016		Generator Test
FO-335579	1/19/2016	1/20/2016		Generator Test
FO-335582	1/19/2016	1/20/2016		Generator Test
FO-335477	1/20/2016	1/20/2016		PM - Sump Pump
FO-335489	1/20/2016	1/20/2016		PM - Sump Pump
FO-335501	1/20/2016	1/20/2016		PM - Sump Pump
FO-335513	1/20/2016	1/20/2016		PM - Sump Pump

WO	Recieved	Finished	Total	Request
FO-335525	1/20/2016	1/20/2016		PM - Sump Pump
FO-335537	1/20/2016	1/20/2016		PM - Sump Pump
FO-335568	1/20/2016	1/21/2016		Generator Test
FO-335583	1/20/2016	1/20/2016		Generator Test
FO-335585	1/21/2016	1/21/2016		Generator Test
FO-335589	1/21/2016	1/21/2016		Generator Test
FO-335469	1/22/2016	1/21/2016		PM - Sump Pump
FO-335481	1/22/2016	1/21/2016		PM - Sump Pump
FO-335493	1/22/2016	1/21/2016		PM - Sump Pump
FO-335505	1/22/2016	1/21/2016		PM - Sump Pump
FO-335517	1/22/2016	1/21/2016		PM - Sump Pump
FO-335529	1/22/2016	1/21/2016		PM - Sump Pump
FO-335474	1/25/2016	1/21/2016		PM - Sump Pump
FO-335486	1/25/2016	1/21/2016		PM - Sump Pump
FO-335498	1/25/2016	1/21/2016		PM - Sump Pump
FO-335510	1/25/2016	1/21/2016		PM - Sump Pump
FO-335522	1/25/2016	1/21/2016		PM - Sump Pump
FO-335534	1/25/2016	1/21/2016		PM - Sump Pump
FO-335570	1/26/2016			Generator Test Tuesday 1/26/2016 @ 7:15 AM.
FO-335573	1/26/2016			Generator Test Tuesday 1/26/2016 @ 10AM.
FO-335574	1/26/2016			Generator Test Tuesday 1/26/2016 @ 8AM.
FO-335575	1/26/2016			Generator Test Tuesday 1/26/2016 @ 8AM.
FO-335576	1/26/2016			Generator Test Tuesday 1/26/2016 @ 8AM.
FO-335577	1/26/2016			Generator Test Tuesday 1/26/2016 @ 8AM.
FO-336707	1/26/2016			Generator Test Tuesday 1/26/2016 @ 2PM.
FO-335478	1/27/2016	1/27/2016		PM - Sump Pump
FO-335490	1/27/2016	1/27/2016		PM - Sump Pump
FO-335502	1/27/2016	1/27/2016		PM - Sump Pump
FO-335514	1/27/2016	1/27/2016		PM - Sump Pump
FO-335526	1/27/2016	1/27/2016		PM - Sump Pump
FO-335538	1/27/2016	1/27/2016		PM - Sump Pump
FO-335569	1/27/2016	1/27/2016		Generator Test Wednesday 1/27/2016 @ 7:15 AM. Also fill Fuel Tank with Diesel Fuel.
FO-335580	1/27/2016	1/27/2016		Generator Test Wednesday 1/27/2016 @ 7:15AM.
FO-335593	1/28/2016	1/28/2016		Generator Test Thursday 1/28/2016 @ 7:15 AM.
FO-335594	1/28/2016	1/28/2016		Generator Test Thursday 1/28/2016 @ 1PM.
FO-335595	1/28/2016	1/28/2016		Generator Test Thursday 1/28/2016 @ 1PM.
FO-335470	1/29/2016			PM - Sump Pump
FO-335482	1/29/2016			PM - Sump Pump
FO-335494	1/29/2016			PM - Sump Pump
FO-335506	1/29/2016			PM - Sump Pump
FO-335518	1/29/2016			PM - Sump Pump
FO-335530	1/29/2016			PM - Sump Pump
<b>T - Plumber</b>			<b>16</b>	
FO-334802	1/1/2016	1/27/2016		PM - Main Drain with Copper Sulfate ,,,,,,,,,,,,,, DB/1-4-15 ,,,,,,,,,,,,,,
FO-334803	1/1/2016	1/1/2016		**CANCELLED JWT
				PM - Main Drain with Copper Sulfate
FO-334804	1/1/2016	1/14/2016		PM - Waterless Urinals ,,,,,,,,,,,,,, MM/1-4-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-334805	1/1/2016	1/4/2016		PM - Waterless Urinals ,,,,,,,,,, TT/1-4-15 ,,,,,,,,,
FO-334806	1/1/2016	1/11/2016		PM - Waterless Urinals ,,,,,,,,,, TT/1-4-15 ,,,,,,,,,
FO-334807	1/1/2016	1/5/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,, **REPAIRS ON FO#336140 JWT
FO-334808	1/1/2016	1/5/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334809	1/1/2016	1/5/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,, *REPAIRS ON FO#336133 JWT
FO-334810	1/1/2016	1/6/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334811	1/1/2016	1/8/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334812	1/1/2016	1/8/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334813	1/1/2016	1/8/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334814	1/1/2016	1/8/2016		2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-334815	1/1/2016	1/5/2016		2016 PM - Preventative Maintenance - Pressure Vacuum Breaker ,,,,,,,,,, DB/1-4-15 ,,,,,,,,,
FO-336202	1/1/2016	1/6/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,,,,,DB1/5/16,,,,,,,,
FO-337924	1/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing

**Total: 2432**