

DRAFT Facilities Operations PM Analysis from 10/1/15 through 10/31/15

Requested Finished Open WND

% Finished

Engineering

748

504

240

4

67%

E - Auxiliary

46

34

12

0

74%

FO-324887	Finished	501-GEN-001	10/6/2015	10/7/2015	False	Generator Maintenance, Monthly
FO-324891	Finished	507-GEN-001	10/14/2015	10/14/2015	False	Generator Maintenance, Monthly
FO-327596	Finished	034-AHU-001	10/1/2015	10/8/2015	False 5.00	PM - Air Handling Unit
Checked operation of unit, belts, dampers and controls. Lubed motor and dampers. Changed box filters and pre filters.						
FO-327597	Finished	034-AHU-002	10/1/2015	10/8/2015	False 5.00	PM - Air Handling Unit
Checked unit operation. Lubed motor ,dampers and checked belts. Changed pre and box filters.						
FO-327598	Created By PM Schedule	034-AHU-003	10/1/2015		False	PM - Air Handling Unit
FO-327599	Finished	034-AHU-004	10/1/2015	10/14/2015	False 2.00	PM - Air Handling Unit
Checked belts, dampers and unit operation. Changed filters and lubed motor.						
FO-327600	Created By PM Schedule	034-AHU-005	10/1/2015		False	PM - Air Handling Unit
FO-327601	Created By PM Schedule	034-COT-001	10/1/2015		False	PM - Cooling Tower, 500 - 1000 Tons
FO-327603	Created By PM Schedule	034-DWBP-001	10/1/2015		False	PM - Water Booster Pump
FO-327604	Created By PM Schedule	034-DWBP-002	10/1/2015		False	PM - Water Booster Pump
FO-327618	Created By PM Schedule	134-AHU-001	10/1/2015		False	PM - Air Handling Unit
FO-327619	Created By PM Schedule	134-AHU-002	10/1/2015		False	PM - Air Handling Unit
FO-327620	Created By PM Schedule	104-MUA-001	10/1/2015		False	PM - Air Handling Unit
FO-327621	Created By PM Schedule	104-MUA-002	10/1/2015		False	PM - Air Handling Unit
FO-327622	Created By PM Schedule	115-MUA-001	10/1/2015		False	PM - Air Handling Unit
FO-327623	Created By PM Schedule	115-MUA-002	10/1/2015		False	PM - Air Handling Unit
FO-327624	Created By PM Schedule	115-MUA-003	10/1/2015		False	PM - Air Handling Unit
FO-327625	Finished	127-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327626	Finished	104-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327627	Finished	115-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327628	Finished	134-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327629	Finished	507-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327630	Finished	992-COT-001	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327631	Finished	992-COT-002	10/1/2015	10/29/2015	False	PM - Cooling Tower, 500 - 1000 Tons
FO-327632	Finished	501-ACU-001	10/1/2015	10/13/2015	False	PM - Water/Air Cooled Condenser
FO-327633	Finished	134-ACU-001	10/1/2015	10/29/2015	False	PM - Absorption Unit
FO-327634	Finished	507-ACU-001	10/1/2015	10/29/2015	False	PM - Absorption Unit
FO-327635	Finished	992-ES-001*	10/5/2015	10/9/2015	False	PM - Emergency Shower/Eyewash Station
FO-327636	Finished	127-GCP-001	10/1/2015	10/29/2015	False	PM - Centrifugal Pump, over 1 H.P.
FO-327637	Finished	127-GCP-002	10/1/2015	10/29/2015	False	PM - Centrifugal Pump, over 1 H.P.
FO-327648	Finished	134-FP-001	10/1/2015	10/29/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test
FO-327649	Finished	127-FP-001	10/1/2015	10/29/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test
FO-327650	Finished	115-FP-001	10/1/2015	10/29/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test
FO-327651	Finished	104-FP-001	10/1/2015	10/29/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test
FO-327652	Finished	507-FP-001	10/1/2015	10/29/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test
FO-328224	Finished	203-GEN-001	10/13/2015	10/13/2015	False	Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-328238	Finished	992-ES-001*	10/12/2015	10/16/2015	False		PM - Emergency Shower/Eyewash Station
FO-328401	Finished	090-GEN-001	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328411	Finished	104-GEN-001	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328413	Finished	127-GEN-001	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328415	Finished	127-GEN-002	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328417	Finished	127-GEN-003	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328419	Finished	127-GEN-004	10/27/2015	10/28/2015	False		Generator Maintenance, Monthly
FO-328427	Finished	536-GEN-001	10/21/2015	10/21/2015	False		Generator Maintenance, Monthly
FO-328808	Finished	992-ES-001*	10/19/2015	10/23/2015	False		PM - Emergency Shower/Eyewash Station
FO-329436	Finished	992-ES-001*	10/26/2015	10/29/2015	False		PM - Emergency Shower/Eyewash Station
E - MedPharm			39	26	13	0	
67%							
FO-325835	Finished	603-UNH-001	10/1/2015	10/27/2015	False	0.50	PM - Unit/Space Heater
Done. reset. ran unit waited for heating							
FO-325836	Finished	603-UNH-002	10/1/2015	10/23/2015	False	2.00	PM - Unit/Space Heater
Done. assisted Fitters busted elbow on coil unit wet/ electrical ok							
FO-325837	Finished	603-UNH-003	10/1/2015	10/22/2015	False	0.50	PM - Unit/Space Heater
Done							
FO-325838	Finished	603-UNH-004	10/1/2015	10/27/2015	False	0.50	PM - Unit/Space Heater
Done. reset							
FO-325839	Finished	603-UNH-005	10/1/2015	10/22/2015	False	0.75	PM - Unit/Space Heater
Done. This Unit Heater is located above the Penthouse Boiler							
FO-326061	Created By PM Schedule	603-UNH-006	10/1/2015		False		PM - Unit/Space Heater
FO-326062	Created By PM Schedule	603-UNH-007	10/1/2015		False		PM - Unit/Space Heater
FO-326063	Created By PM Schedule	603-UNH-008	10/1/2015		False		PM - Unit/Space Heater
FO-326064	Created By PM Schedule	603-UNH-009	10/1/2015		False		PM - Unit/Space Heater
FO-326065	Created By PM Schedule	603-UNH-010	10/1/2015		False		PM - Unit/Space Heater
FO-327358	Finished	609-COT-001	10/1/2015	10/21/2015	False		PM - Cooling Tower, 500 - 1000 Tons
cleaned tower							
FO-327359	Finished	609-COT-002	10/1/2015	10/21/2015	False		PM - Cooling Tower, 500 - 1000 Tons
cleaned tower							
FO-327360	Finished	609-DHW-001	10/1/2015	10/21/2015	False		PM - Domestic Water Heater, Steam
done							
FO-327361	Finished	609-DHW-002	10/1/2015	10/21/2015	False		PM - Domestic Water Heater, Steam
done							
FO-327362	Created By PM Schedule	603-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327363	Created By PM Schedule	603-COT-002	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327364	Finished	603-DHW-001	10/1/2015	10/12/2015	False	0.50	PM - Domestic Water Heater, Steam
DONE. checked all pumps gauges ok cleaned unit							

Requested Finished Open WND

% Finished

FO-327365	Finished	603-DHW-002	10/1/2015	10/12/2015	False	0.50	PM - Domestic Water Heater, Steam
DONE. Checked Pumps cleaned							
FO-327366	Created By PM Schedule	608-HWP-005	10/1/2015		False		PM - Centrifugal Pump, over 1 H.P.
FO-327367	Created By PM Schedule	611-COT-001**	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327368	Finished	629-COT-001	10/1/2015	10/30/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327369	Finished	629-COT-002	10/1/2015	10/30/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327370	Finished	612-COT-001	10/1/2015	10/8/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327371	Finished	612-COT-002	10/1/2015	10/8/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327372	Finished	612-COT-003	10/1/2015	10/7/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327373	Finished	612-COT-004	10/1/2015	10/7/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327374	Finished	612-HWP-016	10/1/2015	10/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-327375	Finished	612-HWP-017	10/1/2015	10/12/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-327376	Finished	612-HWP-026	10/1/2015	10/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-327377	Finished	612-HWP-027	10/1/2015	10/5/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-327378	Finished	612-HWP-028	10/1/2015	10/5/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-327379	Finished	612-WSS-001	10/1/2015	10/15/2015	False	1.00	PM - Water Softener
FO-327380	Finished	603-DHW-003	10/1/2015	10/12/2015	False	0.50	PM - Domestic Water Heater, Steam
DONE. Cleaned pumps good							
FO-327381	Created By PM Schedule	608-COT-002	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327382	Created By PM Schedule	608-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327383	Created By PM Schedule	603-COT-003	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-328222	Finished	608-GEN-001	10/2/2015	10/2/2015	False		Generator Maintenance, Monthly
FO-328407	Finished	611-GEN-001	10/23/2015	10/23/2015	False		Generator Maintenance, Monthly
FO-328409	Created By PM Schedule	629-GEN-001	10/27/2015		False		Generator Maintenance, Monthly
E - North			58	37	21	0	64%
FO-327384	Finished	025-UNH-001	10/1/2015	10/27/2015	False	1.00	PM - Unit/Space Heater
FO-327385	Finished	025-UNH-002	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-327386	Finished	140-COT-001	10/1/2015	10/15/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327387	Finished	026-CFP-001	10/1/2015	10/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-327388	Finished	026-SP-001	10/1/2015	10/9/2015	False	0.50	PM - Sump Pump
FO-327389	Finished	026-SP-002	10/1/2015	10/9/2015	False		PM - Sump Pump
FO-327390	Finished	050-COT-001	10/1/2015	10/15/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327391	Finished	039-COT-001	10/1/2015	10/12/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
Checked operation of cooling tower fans, motors, pumps, and belts. Greased bearings.							
FO-327392	Finished	026-CFP-002	10/1/2015	10/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-327393	Finished	026-CFP-003	10/1/2015	10/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-327394	Finished	026-CFP-004	10/1/2015	10/9/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-327395	Finished	026-COT-001	10/1/2015	10/27/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327396	Finished	026-COT-002	10/1/2015	10/27/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327397	Finished	026-COT-003	10/1/2015	10/27/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327398	Finished	026-COT-004	10/1/2015	10/27/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327399	Created By PM Schedule	036-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons

Requested Finished Open WND

% Finished

FO-327400	Finished	25-ROOF-Z2A3*	10/1/2015	10/12/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-327401	Finished	26-ROOF-Z2A3'	10/1/2015	10/20/2015	False	0.75	PM - Roof Sumps - Zone 2, Area 3
FO-327402	Finished	27-ROOF-Z2A3'	10/1/2015	10/13/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-327403	Finished	036-ROOF-Z2A3	10/1/2015	10/27/2015	False	0.50	PM - Roof Sumps - Zone 2, Area 3
FO-327404	Finished	38-ROOF-Z2A3'	10/1/2015	10/12/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
Cleaned debris from sumps, checked for problems.							
FO-327405	Finished	39-ROOF-Z2A3'	10/1/2015	10/12/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleaned sumps of debris, checked for problems.							
FO-327406	Finished	40-ROOF-Z2A3'	10/1/2015	10/12/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleaned debris from sumps, checked for problems.							
FO-327407	Finished	42-ROOF-Z2A3'	10/1/2015	10/12/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
Cleared roof sumps of debris, checked for damage.							
FO-327408	Finished	43-ROOF-Z2A3'	10/1/2015	10/12/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleared debris from roof sumps, checked for problems.							
FO-327409	Finished	130-DHW-001	10/1/2015	10/14/2015	False	1.50	PM - Domestic Water Heater, Electric
FO-327410	Created By PM Schedule	048-HUM-001	10/1/2015		False		PM - Humidifier
FO-327411	Created By PM Schedule	048-HUM-002	10/1/2015		False		PM - Humidifier
FO-327412	Created By PM Schedule	16-AHU-001-HU	10/1/2015		False		PM - Humidifier
FO-327413	Created By PM Schedule	16-AHU-002-HU	10/1/2015		False		PM - Humidifier
FO-327414	Created By PM Schedule	048-COT-001	10/1/2015		False		PM - Cooling Tower Lay-up - GE Betz
FO-327415	Created By PM Schedule	049-COT-001	10/1/2015		False		PM - Cooling Tower Lay-up - GE Betz
FO-327416	Created By PM Schedule	046-COT-001	10/1/2015		False		PM - Cooling Tower Lay-up - GE Betz
FO-327417	Created By PM Schedule	049-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327418	Created By PM Schedule	048-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327419	Created By PM Schedule	046-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327420	Finished	026-ACU-014	10/1/2015	10/26/2015	False	0.50	Replace PRE-filters
FO-327421	Finished	026-ACU-013	10/1/2015	10/26/2015	False	0.50	Replace PRE-filters
FO-327422	Finished	026-ACU-012	10/1/2015	10/26/2015	False	0.50	Replace PRE-filters
FO-327423	Created By PM Schedule	026-ACU-011	10/1/2015		False		Replace PRE-filters
FO-327424	Created By PM Schedule	026-ACU-010	10/1/2015		False		Replace PRE-filters
FO-327425	Finished	026-ACU-009	10/1/2015	10/26/2015	False	0.50	Replace PRE-filters
FO-327426	Created By PM Schedule	026-ACU-008	10/1/2015		False		Replace PRE-filters
FO-327427	Finished	026-ACU-007	10/1/2015	10/26/2015	False	0.50	Replace PRE-filters
FO-327428	Created By PM Schedule	026-ACU-006	10/1/2015		False		Replace PRE-filters
FO-328421	Finished	130-GEN-001	10/28/2015	10/28/2015	False	1.00	Generator Maintenance, Monthly
FO-328430	Created By PM Schedule	048-GEN-001	10/16/2015		False		Generator Maintenance, Monthly
FO-328789	Created By PM Schedule	046-CRP-002	10/1/2015		False		PM - Condensate Return Pump
FO-328790	Finished	027-CRP-001	10/1/2015	10/28/2015	False	0.75	PM - Condensate Return Pump
FO-328791	Finished	027-CRP-002	10/1/2015	10/28/2015	False	0.50	PM - Condensate Return Pump
FO-328792	Finished	027-CRS-001	10/1/2015	10/28/2015	False	0.50	PM - Condensate Return Pump
FO-328793	Finished	027-CRS-002	10/1/2015	10/28/2015	False	0.50	PM - Condensate Return Pump
FO-328794	Finished	043-AHU-INT	10/15/2015	10/12/2015	False	1.00	PM - Outside/Fresh Air Intake Screens
Cleaned outside air intake of leaves and debris.							
FO-328795	Created By PM Schedule	043-CRS-001	10/1/2015		False		PM - Condensate Return Pump

Requested Finished Open WND

% Finished

FO-328796	Created By PM Schedule	043-CRS-002	10/1/2015		False		PM - Condensate Return Pump
FO-328797	Finished	025-CRS-001	10/1/2015	10/28/2015	False	0.50	PM - Condensate Return Pump
FO-328798	Created By PM Schedule	046-CRS-001	10/1/2015		False		PM - Condensate Return Pump
FO-328799	Created By PM Schedule	046-CRS-002	10/1/2015		False		PM - Condensate Return Pump
E - Northeast			56	19	37	0	34%
FO-324908	Created By PM Schedule	193-GEN-001	10/2/2015		False		Generator Maintenance, Monthly
FO-324919	Finished	193-GEN-002	10/2/2015	10/2/2015	False	1.00	Generator Maintenance, Monthly
FO-324925	Finished	193-GEN-004	10/2/2015	10/2/2015	False	1.00	Generator Maintenance, Monthly
FO-326132	Created By PM Schedule	511-BFAH-001	10/1/2015		False		Replace PRE-filters
FO-326133	Created By PM Schedule	511-AHU-206	10/1/2015		False		Replace PRE-filters
FO-326134	Created By PM Schedule	511-AHU-205	10/1/2015		False		Replace PRE-filters
FO-326135	Created By PM Schedule	511-AHU-204	10/1/2015		False		Replace PRE-filters
FO-326136	Created By PM Schedule	511-AHU-203	10/1/2015		False		Replace PRE-filters
FO-326137	Created By PM Schedule	511-AHU-202	10/1/2015		False		Replace PRE-filters
FO-326138	Created By PM Schedule	511-AHU-201	10/1/2015		False		Replace PRE-filters
FO-326139	Created By PM Schedule	511-AHU-007	10/1/2015		False		Replace PRE-filters
FO-326140	Created By PM Schedule	511-AHU-006	10/1/2015		False		Replace PRE-filters
FO-326141	Created By PM Schedule	511-AHU-005	10/1/2015		False		Replace PRE-filters
FO-326142	Created By PM Schedule	511-AHU-004	10/1/2015		False		Replace PRE-filters
FO-326143	Created By PM Schedule	511-AHU-003	10/1/2015		False		Replace PRE-filters
FO-326144	Created By PM Schedule	511-AHU-002	10/1/2015		False		Replace PRE-filters
FO-326145	Created By PM Schedule	511-AHU-001	10/1/2015		False		Replace PRE-filters
FO-327429	Created By PM Schedule	193-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327430	Created By PM Schedule	193-COT-002	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327431	Created By PM Schedule	193-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-327432	Created By PM Schedule	193-UNH-002	10/1/2015		False		PM - Unit/Space Heater
FO-327433	Created By PM Schedule	193-UNH-003	10/1/2015		False		PM - Unit/Space Heater
FO-327434	Created By PM Schedule	065-AIR-001	10/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-327435	Created By PM Schedule	067-AIR-001	10/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-327436	Created By PM Schedule	065-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-327437	Created By PM Schedule	065-UNH-002	10/1/2015		False		PM - Unit/Space Heater
FO-327438	Created By PM Schedule	065-UNH-003	10/1/2015		False		PM - Unit/Space Heater
FO-327439	Finished	065-UNH-004	10/1/2015	10/29/2015	False	0.50	PM - Unit/Space Heater
FO-327440	Finished	065-UNH-005	10/1/2015	10/29/2015	False	0.50	PM - Unit/Space Heater
FO-327441	Finished	065-UNH-006	10/1/2015	10/29/2015	False	0.50	PM - Unit/Space Heater
FO-327442	Created By PM Schedule	065-UNH-007	10/1/2015		False		PM - Unit/Space Heater
FO-327443	Finished	509-UNH-001	10/1/2015	10/14/2015	False	1.50	PM - Unit/Space Heater
cleaned filter checked operation							
FO-327444	Finished	509-UNH-002	10/1/2015	10/27/2015	False		PM - Unit/Space Heater
Cleaned filter checked belt lubricated motor							
FO-327445	Finished	509-UNH-003	10/1/2015	10/27/2015	False	1.00	PM - Unit/Space Heater
cleaned filter lubricated motor checked belt							
FO-327446	Finished	509-UNH-004	10/1/2015	10/28/2015	False	1.00	PM - Unit/Space Heater
cleaned filter checked belt lubricated motor							

Requested Finished Open WND

% Finished

FO-327447	Finished	509-UNH-005	10/1/2015	10/28/2015	False	1.00	PM - Unit/Space Heater
cleaned coil and filter, lubricated motor,checked belt							
FO-327448	Finished	509-COT-001	10/1/2015	10/26/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
drained cooling tower and related equip. drained AHU's #1, #2, #3, & #4 cooling coils							
FO-327449	Created By PM Schedule	062-FCU-003	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327450	Created By PM Schedule	062-FCU-002	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327451	Created By PM Schedule	062-FCU-001	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327452	Created By PM Schedule	062-FCU-004	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327453	Finished	511-COT-001	10/1/2015	10/27/2015	False	2.50	PM - Cooling Tower, 500 - 1000 Tons
drained sump and coil in the tower rinsed basin isolated tower from system							
FO-327769	Finished	527-AHU-004	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
replaced belt for fan, cleaned external filter screen. Pre- filters inspected but not changed. (non available, they were ordered)							
FO-327770	Finished	527-AHU-003	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
inspected belt, cleaned external screen filter, inspected pre- filters. Did not replace.(none available they were ordered but have not arrived) placed a W.O. to the refrig shop to repair the heat cycle unit does not heat							
FO-327771	Finished	527-AHU-002	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
replaced both drive belts for the fan cleaned external filter screen checked pre filters did not replace. filters have been ordered but have not yet arrived							
FO-327772	Finished	527-AHU-001	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
checked fan belt cleaned external filter screen inspected filters did not replace, none available they were ordered.							
FO-328404	Finished	066-GEN-001	10/28/2015	10/28/2015	False	1.00	Generator Maintenance, Monthly
FO-328429	Finished	527-GEN-001	10/15/2015	10/15/2015	False	1.50	Generator Maintenance, Monthly
checked fluids and operation							
FO-328436	Created By PM Schedule	060-GEN-001A	10/22/2015		False		Generator Maintenance, Monthly
FO-328438	Created By PM Schedule	060-GEN-001B	10/22/2015		False		Generator Maintenance, Monthly
FO-328800	Created By PM Schedule	193-CRP-001	10/1/2015		False		PM - Condensate Return Pump
FO-328801	Created By PM Schedule	193-CRP-002	10/1/2015		False		PM - Condensate Return Pump
FO-328802	Created By PM Schedule	193-CRP-003	10/1/2015		False		PM - Condensate Return Pump
FO-328803	Created By PM Schedule	193-CRP-004	10/1/2015		False		PM - Condensate Return Pump
FO-329432	Finished	067-CWP-001	10/21/2015	10/29/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-329433	Created By PM Schedule	064-DHW-001	10/24/2015		False		PM - Domestic Water Heater, Gas
E - Preventative Maintenance			317	252	61	4	79%
FO-321741	Finished	612-AHU-014	10/1/2015	10/13/2015	False	2.75	Replace PRE-filters
FO-321742	Finished	612-AHU-013	10/1/2015	10/30/2015	False	3.50	Replace PRE-filters
FO-321743	Finished	612-AHU-012	10/1/2015	10/31/2015	False	4.00	Replace PRE-filters
FO-321744	Finished	612-AHU-011	10/1/2015	10/28/2015	False	4.00	Replace PRE-filters
FO-321745	Finished	612-AHU-010	10/1/2015	10/2/2015	False	4.00	Replace PRE-filters
FO-321746	Finished	612-AHU-009	10/1/2015	10/6/2015	False	2.50	Replace PRE-filters
FO-321747	Finished	612-AHU-008	10/1/2015	10/7/2015	False	3.25	Replace PRE-filters
FO-321748	Finished	612-AHU-007	10/1/2015	10/12/2015	False	3.50	Replace PRE-filters
FO-321754	Finished	612-AHU-003	10/1/2015	10/12/2015	False	2.50	Replace PRE-filters
FO-321755	Finished	612-AHU-002	10/1/2015	10/5/2015	False	2.50	Replace PRE-filters
FO-321756	Finished	612-AHU-001	10/1/2015	10/13/2015	False	3.50	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-321821	Finished	612-HVU-001	10/1/2015	10/5/2015	False	2.50	Replace PRE-filters
FO-325831	Finished	082-UNH-001	10/1/2015	10/6/2015	False	1.00	PM - Unit/Space Heater
FO-325832	Finished	082-UNH-002	10/1/2015	10/6/2015	False	1.00	PM - Unit/Space Heater
FO-325833	Finished	082-UNH-003	10/1/2015	10/6/2015	False	1.00	PM - Unit/Space Heater
FO-325834	Finished	082-UNH-004	10/1/2015	10/6/2015	False	1.00	PM - Unit/Space Heater
FO-325840	Finished	608-UNH-001	10/1/2015	10/7/2015	False	0.75	PM - Unit/Space Heater
FO-325841	Finished	608-UNH-002	10/1/2015	10/7/2015	False	0.75	PM - Unit/Space Heater
FO-325842	Finished	608-UNH-003	10/1/2015	10/7/2015	False	0.75	PM - Unit/Space Heater
FO-325843	Finished	611-UNH-001	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325844	Finished	611-UNH-002	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325845	Finished	611-UNH-003**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325846	Finished	611-UNH-004	10/1/2015	10/14/2015	False		PM - Unit/Space Heater
FO-325847	Finished	611-UNH-005	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325848	Finished	611-UNH-006	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325849	Finished	611-UNH-007	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325850	Finished	611-UNH-008	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325851	Finished	611-UNH-009	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325852	Finished	611-UNH-010	10/1/2015	10/19/2015	False	0.75	PM - Unit/Space Heater
FO-325853	Finished	611-UNH-011**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325854	Finished	611-UNH-012**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325855	Finished	611-UNH-013**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325856	Finished	611-UNH-014**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325857	Finished	611-UNH-015**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325858	Finished	611-UNH-016**	10/1/2015	10/14/2015	False	0.75	PM - Unit/Space Heater
FO-325859	Finished	629-UNH-001	10/1/2015	10/28/2015	False	0.75	PM - Unit/Space Heater
FO-325860	Finished	629-UNH-002	10/1/2015	10/28/2015	False	0.75	PM - Unit/Space Heater
FO-325861	Finished	629-UNH-004	10/1/2015	10/28/2015	False	0.50	PM - Unit/Space Heater
FO-325862	Finished	629-UNH-003	10/1/2015	10/28/2015	False	0.50	PM - Unit/Space Heater
FO-325863	Finished	001-UNH-001	10/1/2015	10/29/2015	False	0.45	PM - Unit/Space Heater
FO-325864	Created By PM Schedule	001-UNH-002	10/1/2015		False		PM - Unit/Space Heater
FO-325865	Finished	001-UNH-003	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325866	Finished	001-UNH-004	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325867	Finished	001-UNH-005	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325868	Finished	001-UNH-006	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325869	Finished	001-UNH-007	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325870	Finished	001-UNH-008	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325871	Created By PM Schedule	001-UNH-009	10/1/2015		False		PM - Unit/Space Heater
FO-325872	Finished	001-UNH-010	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325873	Created By PM Schedule	001-UNH-011	10/1/2015		False		PM - Unit/Space Heater
FO-325874	Finished	001-UNH-012	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325875	Created By PM Schedule	001-UNH-013	10/1/2015		False		PM - Unit/Space Heater
FO-325876	Created By PM Schedule	001-UNH-014	10/1/2015		False		PM - Unit/Space Heater
FO-325877	Created By PM Schedule	001-UNH-015	10/1/2015		False		PM - Unit/Space Heater
FO-325878	Created By PM Schedule	001-UNH-016	10/1/2015		False		PM - Unit/Space Heater

Requested Finished Open WND

% Finished

FO-325879	Created By PM Schedule	001-UNH-017	10/1/2015		False		PM - Unit/Space Heater
FO-325880	Created By PM Schedule	001-UNH-018	10/1/2015		False		PM - Unit/Space Heater
FO-325881	Created By PM Schedule	001-UNH-019	10/1/2015		False		PM - Unit/Space Heater
FO-325882	Created By PM Schedule	001-UNH-020	10/1/2015		False		PM - Unit/Space Heater
FO-325883	Created By PM Schedule	001-UNH-021	10/1/2015		False		PM - Unit/Space Heater
FO-325884	Created By PM Schedule	001-UNH-022	10/1/2015		False		PM - Unit/Space Heater
FO-325885	Created By PM Schedule	001-UNH-023	10/1/2015		False		PM - Unit/Space Heater
FO-325886	Finished	001-UNH-024	10/1/2015	10/29/2015	False	0.30	PM - Unit/Space Heater
FO-325887	Created By PM Schedule	001-UNH-025	10/1/2015		False		PM - Unit/Space Heater
FO-325888	Created By PM Schedule	001-UNH-026	10/1/2015		False		PM - Unit/Space Heater
FO-325889	Created By PM Schedule	001-UNH-027	10/1/2015		False		PM - Unit/Space Heater
FO-325890	Created By PM Schedule	001-UNH-028	10/1/2015		False		PM - Unit/Space Heater
FO-325891	Finished	049-UNH-001	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325892	Finished	155-UNH-001	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325893	Finished	155-UNH-002	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325894	Finished	155-UNH-003	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325895	Finished	155-UNH-004	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325896	Finished	155-UNH-005	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325897	Finished	155-UNH-006	10/1/2015	10/20/2015	False	0.50	PM - Unit/Space Heater
FO-325898	Created By PM Schedule	155-UNH-007	10/1/2015		False		PM - Unit/Space Heater
FO-325899	Created By PM Schedule	155-UNH-008	10/1/2015		False		PM - Unit/Space Heater
FO-325900	Created By PM Schedule	155-UNH-009	10/1/2015		False		PM - Unit/Space Heater
FO-325901	Created By PM Schedule	155-UNH-010	10/1/2015		False		PM - Unit/Space Heater
FO-325902	Created By PM Schedule	155-UNH-011	10/1/2015		False		PM - Unit/Space Heater
FO-325903	Created By PM Schedule	155-UNH-012	10/1/2015		False		PM - Unit/Space Heater
FO-325904	Created By PM Schedule	155-UNH-013	10/1/2015		False		PM - Unit/Space Heater
FO-325905	Created By PM Schedule	155-UNH-014	10/1/2015		False		PM - Unit/Space Heater
FO-325906	Finished	048-UNH-001	10/1/2015	10/30/2015	False	0.50	PM - Unit/Space Heater
FO-325907	Finished	048-UNH-002	10/1/2015	10/30/2015	False	0.50	PM - Unit/Space Heater
FO-325908	Finished	048-UNH-003	10/1/2015	10/30/2015	False	0.50	PM - Unit/Space Heater
FO-325909	Created By PM Schedule	195-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-325910	Created By PM Schedule	195-UNH-002	10/1/2015		False		PM - Unit/Space Heater
FO-325911	Created By PM Schedule	195-UNH-003	10/1/2015		False		PM - Unit/Space Heater
FO-325912	Finished	062-UNH-001	10/1/2015	10/19/2015	False	0.50	PM - Unit/Space Heater
FO-325913	Finished	062-UNH-002	10/1/2015	10/19/2015	False	0.50	PM - Unit/Space Heater
FO-325914	Finished	062-UNH-003	10/1/2015	10/19/2015	False	0.50	PM - Unit/Space Heater
FO-325915	Finished	062-UNH-004	10/1/2015	10/19/2015	False	0.50	PM - Unit/Space Heater
FO-325916	Finished	062-UNH-005	10/1/2015	10/19/2015	False	0.50	PM - Unit/Space Heater
FO-325917	Finished	167-UNH-001	10/1/2015	10/20/2015	False	2.00	PM - Unit/Space Heater
FO-325918	Finished	090-UNH-001	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325919	Finished	090-UNH-002	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325920	Finished	090-UNH-003	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325921	Finished	090-UNH-004	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325922	Finished	096-UNH-001	10/1/2015	10/7/2015	False	0.45	PM - Unit/Space Heater

Requested Finished Open WND

% Finished

FO-325923	Finished	096-UNH-002	10/1/2015	10/7/2015	False	0.45	PM - Unit/Space Heater
FO-325924	Finished	096-UNH-003	10/1/2015	10/7/2015	False	0.45	PM - Unit/Space Heater
FO-325925	Finished	096-UNH-004	10/1/2015	10/7/2015	False	0.45	PM - Unit/Space Heater
FO-325926	Finished	096-UNH-005	10/1/2015	10/8/2015	False	0.75	PM - Unit/Space Heater
FO-325927	Finished	096-UNH-006	10/1/2015	10/8/2015	False	0.75	PM - Unit/Space Heater
FO-325928	Finished	096-UNH-007	10/1/2015	10/8/2015	False	0.75	PM - Unit/Space Heater
FO-325929	Finished	096-SAF-0600	10/1/2015	10/30/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325930	Finished	096-SAF-SFA	10/1/2015	10/30/2015	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325931	Finished	141-UNH-001	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325932	Finished	141-UNH-002	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325933	Created By PM Schedule	195-UNH-004	10/1/2015		False		PM - Unit/Space Heater
FO-325934	Created By PM Schedule	195-UNH-005	10/1/2015		False		PM - Unit/Space Heater
FO-325935	Created By PM Schedule	001-UNH-029	10/1/2015		False		PM - Unit/Space Heater
FO-325936	Created By PM Schedule	001-UNH-030	10/1/2015		False		PM - Unit/Space Heater
FO-325937	Finished	080-UNH-201	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325938	Finished	080-UNH-253	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325939	Finished	080-UNH-269	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325940	Finished	080-UNH-274	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325941	Finished	166-UNH-001	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325942	Finished	166-UNH-002	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325943	Finished	166-UNH-003	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325944	Finished	166-UNH-004	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325945	Finished	166-UNH-005	10/1/2015	10/13/2015	False	0.50	PM - Unit/Space Heater
FO-325946	Finished	166-UNH-006	10/1/2015	10/14/2015	False	0.50	PM - Unit/Space Heater
FO-325947	Finished	166-UNH-007	10/1/2015	10/14/2015	False	0.50	PM - Unit/Space Heater
FO-325948	Created By PM Schedule	026-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-325949	Finished	036-UNH-001	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325950	Finished	036-UNH-002	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325951	Completed	062-FPB-101	10/1/2015		True		Maintain Fan Powered Boxes
FO-325952	Completed	062-FPB-102	10/1/2015		True		Maintain Fan Powered Boxes
FO-325953	Completed	062-FPB-103	10/1/2015		True		Maintain Fan Powered Boxes
FO-325954	Completed	062-FPB-104	10/1/2015		True		Maintain Fan Powered Boxes
FO-325955	Finished	603-ACU-005*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325956	Finished	603-ACU-002*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325957	Finished	603-ACU-004*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325958	Finished	603-ACU-006*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325959	Finished	603-ACU-007*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325960	Finished	603-ACU-008*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325961	Finished	603-ACU-010*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325962	Finished	603-ACU-011*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325963	Finished	603-ACU-012*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325964	Finished	603-ACU-013*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325965	Finished	603-ACU-014*	10/1/2015	10/29/2015	False	0.30	Replace PRE-filters
FO-325966	Finished	603-ACU-015*	10/1/2015	10/29/2015	False	0.30	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-325967	Finished	603-ACU-016*	10/1/2015	10/29/2015	False	0.30	Replace PRE-filters
FO-325968	Finished	603-ACU-003*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325969	Finished	603-ACU-001*	10/1/2015	10/20/2015	False	0.75	Replace PRE-filters
FO-325970	Finished	603-ACU-009*	10/1/2015	10/29/2015	False	0.75	Replace PRE-filters
FO-325971	Finished	046-UNH-001	10/1/2015	10/9/2015	False	0.50	PM - Unit/Space Heater
FO-325972	Finished	046-UNH-002	10/1/2015	10/9/2015	False	0.50	PM - Unit/Space Heater
FO-325973	Finished	046-UNH-003	10/1/2015	10/9/2015	False	0.50	PM - Unit/Space Heater
FO-325974	Finished	048-UNH-004	10/1/2015	10/30/2015	False	0.50	PM - Unit/Space Heater
FO-325975	Finished	048-UNH-005	10/1/2015	10/30/2015	False	0.50	PM - Unit/Space Heater
FO-325976	Finished	049-CUNH-001	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325977	Finished	049-CUNH-002	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325978	Finished	049-CUNH-003	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325979	Finished	049-CUNH-004	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325980	Finished	049-CUNH-005	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325981	Finished	049-CUNH-006	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325982	Created By PM Schedule	053-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-325983	Created By PM Schedule	053-UNH-002	10/1/2015		False		PM - Unit/Space Heater
FO-325984	Created By PM Schedule	053-UNH-003	10/1/2015		False		PM - Unit/Space Heater
FO-325985	Finished	049-UNH-002	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325986	Finished	090-UNH-1550	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-325987	Created By PM Schedule	090-EXF-401	10/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325988	Created By PM Schedule	090-EXF-402	10/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325989	Created By PM Schedule	090-EXF-4326	10/1/2015		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325990	Finished	090-UNH-1355	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325991	Finished	090-UNH-1359	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325992	Finished	090-UNH-1361	10/1/2015	10/6/2015	False	0.50	PM - Unit/Space Heater
FO-325993	Finished	090-UNH-401	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-325994	Finished	090-UNH-402	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-325995	Finished	090-UNH-403	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325996	Finished	090-UNH-404	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325997	Finished	090-UNH-EP1	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325998	Finished	090-UNH-EP2	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-325999	Finished	090-UNH-WPH	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-326000	Finished	090-UNH-541	10/1/2015	10/8/2015	False	4.50	PM - Unit/Space Heater
FO-326001	Finished	090-UNH-305.1	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-326002	Finished	090-UNH-305.2	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-326003	Finished	090-UNH-305.3	10/1/2015	10/7/2015	False	0.50	PM - Unit/Space Heater
FO-326004	Finished	049-UNH-003	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-326005	Finished	049-UNH-004	10/1/2015	10/8/2015	False	0.50	PM - Unit/Space Heater
FO-326006	Finished	046-FAP-001	10/1/2015	10/29/2015	False	0.90	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326007	Finished	048-FAP-001	10/1/2015	10/28/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326008	Finished	049-FAP-001	10/1/2015	10/29/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326009	Created By PM Schedule	155-UNH-015	10/1/2015		False		PM - Unit/Space Heater
FO-326010	Created By PM Schedule	155-UNH-016	10/1/2015		False		PM - Unit/Space Heater

Requested Finished Open WND

% Finished

FO-326011	Finished	156-FAP-001	10/1/2015	10/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326012	Finished	499-FAP-001	10/1/2015	10/22/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326013	Finished	620-FAP-001	10/1/2015	10/19/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326014	Finished	036-FP-001	10/1/2015	10/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326015	Finished	025-FP-001	10/1/2015	10/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326016	Finished	007-FP-001	10/1/2015	10/29/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326017	Finished	001-FP-001	10/1/2015	10/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326018	Finished	005-FAP-001	10/1/2015	10/29/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326019	Finished	040-FAP-001	10/1/2015	10/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326020	Finished	038-FAP-001	10/1/2015	10/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326021	Finished	028-FAP-001	10/1/2015	10/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326022	Finished	026-FAP-001	10/1/2015	10/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326023	Finished	022-FAP-001	10/1/2015	10/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326024	Created By PM Schedule	017-FAP-001	10/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326025	Finished	016-FAP-001	10/1/2015	10/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326026	Finished	003-FAP-001	10/1/2015	10/29/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326027	Finished	006-FP-001	10/1/2015	10/29/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326028	Finished	050-FAP-001	10/1/2015	10/27/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326029	Finished	043-FAP-001	10/1/2015	10/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326030	Finished	042-FAP-001	10/1/2015	10/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326031	Finished	062-FP-001	10/1/2015	10/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326032	Finished	065-FP-001	10/1/2015	10/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326033	Finished	068-FAP-001	10/1/2015	10/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326034	Finished	067-FP-001	10/1/2015	10/27/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326035	Finished	089-FP-001	10/1/2015	10/29/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326036	Finished	082-FP-001	10/1/2015	10/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326037	Finished	080-FAP-001	10/1/2015	10/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326038	Finished	090-FP-001	10/1/2015	10/20/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326039	Finished	155-FP-001	10/1/2015	10/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326040	Finished	150-FAP-001	10/1/2015	10/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326041	Finished	167-FAP-001	10/1/2015	10/20/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326042	Finished	166-FP-001	10/1/2015	10/20/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326043	Finished	140-FAP-001	10/1/2015	10/28/2015	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326044	Created By PM Schedule	130-FP-001	10/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326045	Finished	193-FAP-001	10/1/2015	10/15/2015	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326046	Finished	189-FP-001	10/1/2015	10/15/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326047	Finished	510-FAP-001	10/1/2015	10/15/2015	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326048	Finished	509-FAP-001	10/1/2015	10/15/2015	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326049	Finished	504-FAP-001	10/1/2015	10/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326050	Finished	629-FP-001	10/1/2015	10/19/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326051	Finished	612-FP-001	10/1/2015	10/20/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326052	Finished	611-FP-001	10/1/2015	10/19/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326053	Finished	609-FP-001	10/1/2015	10/19/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326054	Finished	603-FP-001	10/1/2015	10/21/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-326055	Finished	608-FP-001	10/1/2015	10/20/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326056	Finished	603-AHU-009	10/1/2015	10/21/2015	False	3.00	Replace PRE-filters
FO-326057	Finished	603-AHU-008	10/1/2015	10/26/2015	False	3.25	Replace PRE-filters
FO-326058	Finished	603-AHU-007	10/1/2015	10/26/2015	False	2.75	Replace PRE-filters
FO-326059	Finished	603-AHU-006	10/1/2015	10/21/2015	False	3.00	Replace PRE-filters
FO-326060	Finished	074-FAP-001	10/1/2015	10/28/2015	False	0.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326066	Finished	003-AHU-007	10/1/2015	10/28/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-326067	Finished	003-AHU-006	10/1/2015	10/12/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-326068	Finished	003-AHU-005	10/1/2015	10/28/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-326069	Finished	003-AHU-004	10/1/2015	10/27/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-326070	Finished	003-AHU-003	10/1/2015	10/12/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-326071	Finished	003-AHU-002	10/1/2015	10/27/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-326072	Finished	003-AHU-001	10/1/2015	10/28/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-326073	Finished	167-AHU-002	10/1/2015	10/20/2015	False	2.00	Replace PRE-filters
FO-326074	Finished	167-AHU-001	10/1/2015	10/20/2015	False	2.00	Replace PRE-filters
FO-326075	Finished	166-HVU-001	10/1/2015	10/9/2015	False	1.00	Replace PRE-filters
FO-326076	Finished	166-AHU-002	10/1/2015	10/9/2015	False	2.00	Replace PRE-filters
FO-326077	Finished	166-AHU-001	10/1/2015	10/9/2015	False	2.00	Replace PRE-filters
FO-326078	Finished	169-AHU-008	10/1/2015	10/28/2015	False	1.00	Replace PRE-filters
FO-326079	Finished	169-AHU-007	10/1/2015	10/28/2015	False	1.00	Replace PRE-filters
FO-326080	Finished	169-AHU-004	10/1/2015	10/24/2015	False	1.50	Replace PRE-filters
FO-326081	Finished	169-AHU-003	10/1/2015	10/24/2015	False	1.50	Replace PRE-filters
FO-326082	Finished	169-AHU-002	10/1/2015	10/23/2015	False	1.50	Replace PRE-filters
FO-326083	Finished	169-AHU-001	10/1/2015	10/23/2015	False	1.50	Replace PRE-filters
FO-326084	Finished	166-UNH-010	10/1/2015	10/16/2015	False	0.50	PM - Unit/Space Heater
FO-326085	Finished	166-UNH-009	10/1/2015	10/15/2015	False	0.50	PM - Unit/Space Heater
FO-326086	Finished	166-UNH-008	10/1/2015	10/15/2015	False	0.50	PM - Unit/Space Heater
FO-326087	Finished	003-AHU-008	10/1/2015	10/27/2015	False	1.00	PM - Air Handling Unit (ANNUAL)
FO-326089	Created By PM Schedule	193-AHU-005	10/1/2015		False		Replace PRE-filters
FO-326090	Created By PM Schedule	193-AHU-004	10/1/2015		False		Replace PRE-filters
FO-326091	Created By PM Schedule	193-AHU-003	10/1/2015		False		Replace PRE-filters
FO-326092	Finished	193-AHU-002	10/1/2015	10/9/2015	False	1.50	Replace PRE-filters
FO-326093	Finished	193-AHU-001	10/1/2015	10/9/2015	False	0.50	Replace PRE-filters
FO-326094	Created By PM Schedule	193-AHU-006	10/1/2015		False		Replace PRE-filters
FO-326095	Created By PM Schedule	193-AHU-007	10/1/2015		False		Replace PRE-filters
FO-326096	Created By PM Schedule	193-AHU-008	10/1/2015		False		Replace PRE-filters
FO-326097	Created By PM Schedule	193-AHU-009	10/1/2015		False		Replace PRE-filters
FO-326098	Created By PM Schedule	193-AHU-010	10/1/2015		False		Replace PRE-filters
FO-326099	Created By PM Schedule	193-AHU-011	10/1/2015		False		Replace PRE-filters
FO-326100	Created By PM Schedule	193-AHU-012	10/1/2015		False		Replace PRE-filters
FO-326101	Created By PM Schedule	193-AHU-013	10/1/2015		False		Replace PRE-filters
FO-326102	Finished	096-SAF-FC1	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters
FO-326103	Finished	096-SAF-B1	10/1/2015	10/16/2015	False	3.00	Replace PRE-filters
FO-326104	Finished	096-SAF-00E	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-326105	Finished	096-SAF-001	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters
FO-326106	Finished	096-RAF-010	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters
FO-326107	Finished	096-RAF-00B	10/1/2015	10/30/2015	False	2.00	Replace PRE-filters
FO-326108	Finished	096-RAF-009	10/1/2015	10/15/2015	False	3.00	Replace PRE-filters
FO-326109	Finished	096-RAF-008	10/1/2015	10/14/2015	False	2.00	Replace PRE-filters
FO-326110	Finished	096-RAF-007	10/1/2015	10/14/2015	False	2.00	Replace PRE-filters
FO-326111	Finished	096-RAF-006	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters
FO-326112	Finished	096-RAF-005	10/1/2015	10/2/2015	False	3.00	Replace PRE-filters
FO-326113	Finished	096-RAF-004	10/1/2015	10/14/2015	False	4.00	Replace PRE-filters
FO-326114	Finished	096-RAF-003	10/1/2015	10/15/2015	False	3.00	Replace PRE-filters
FO-326115	Finished	096-RAF-002	10/1/2015	10/15/2015	False	2.00	Replace PRE-filters
FO-326116	Created By PM Schedule	155-AHU-005	10/1/2015		False		Replace PRE-filters
FO-326117	Created By PM Schedule	155-AHU-004	10/1/2015		False		Replace PRE-filters
FO-326118	Finished	155-AHU-003	10/1/2015	10/27/2015	False	3.00	Replace PRE-filters
FO-326119	Created By PM Schedule	155-AHU-002	10/1/2015		False		Replace PRE-filters
FO-326120	Created By PM Schedule	155-AHU-001	10/1/2015		False		Replace PRE-filters
FO-326121	Finished	078-ACU-003	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-326122	Finished	078-ACU-002B	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-326123	Finished	078-ACU-002A	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-326124	Finished	078-ACU-001	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-326125	Finished	091-AHU-002	10/1/2015	10/21/2015	False	2.50	Replace PRE-filters
FO-326126	Finished	091-AHU-001	10/1/2015	10/21/2015	False	1.00	Replace PRE-filters
FO-326127	Finished	499-AHU-007	10/1/2015	10/24/2015	False	2.00	Replace PRE-filters
FO-326128	Finished	499-AHU-006	10/1/2015	10/23/2015	False	3.00	Replace PRE-filters
FO-326129	Finished	499-AHU-005	10/1/2015	10/24/2015	False	2.00	Replace PRE-filters
FO-326130	Finished	499-AHU-004	10/1/2015	10/27/2015	False	2.50	Replace PRE-filters
FO-326131	Finished	156-SAF-001	10/1/2015	10/23/2015	False	2.00	Replace PRE-filters
FO-326146	Finished	096-FP-001	10/1/2015	10/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326154	Created By PM Schedule	048-SF-004	10/1/2015		False		PM - Air Handling Unit, HV Type
FO-326155	Created By PM Schedule	048-SF-003	10/1/2015		False		PM - Air Handling Unit, HV Type
FO-326156	Finished	150-AHU-003	10/1/2015	10/17/2015	False	2.00	Replace PRE-filters
FO-326157	Finished	150-AHU-002	10/1/2015	10/17/2015	False	2.00	Replace PRE-filters
FO-326158	Finished	150-AHU-001	10/1/2015	10/17/2015	False	1.50	Replace PRE-filters
FO-326159	Finished	169-FAP-001	10/1/2015	10/20/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-326160	Finished	510-UNH-001	10/1/2015	10/12/2015	False	1.50	PM - Unit/Space Heater
FO-326161	Finished	499-AHU-008	10/1/2015	10/27/2015	False	2.00	Replace PRE-filters
FO-326162	Finished	169-AHU-005	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-326163	Finished	169-AHU-006	10/1/2015	10/27/2015	False	1.00	Replace PRE-filters
FO-327788	Finished	090-EXF-555A	10/1/2015	10/30/2015	False	1.50	PM Replace Exhaust Air Filters
FO-327789	Finished	090-EXF-555B	10/1/2015	10/30/2015	False	1.50	PM Replace Exhaust Air Filters
FO-327790	Finished	090-EXF-556A	10/1/2015	10/30/2015	False	1.50	PM Replace Exhaust Air Filters
FO-327791	Finished	090-EXF-556B	10/1/2015	10/30/2015	False	1.50	PM Replace Exhaust Air Filters
E - South			38	31	7	0	
FO-324846	Finished	007-GEN-001	10/8/2015	10/9/2015	False	2.60	Generator Maintenance, Monthly

82%

Requested Finished Open WND

% Finished

FO-324850	Finished	007-GEN-002	10/8/2015	10/9/2015	False	0.60	Generator Maintenance, Monthly
FO-324900	Finished	090-GEN-002	10/8/2015	10/15/2015	False	0.50	Generator Maintenance, Monthly
FO-327454	Finished	090-COT-001	10/1/2015	10/19/2015	False	3.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327455	Finished	090-HWP-010	10/1/2015	10/26/2015	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-327456	Created By PM Schedule	089-COT-002	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327457	Created By PM Schedule	022-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327458	Finished	096-COT-001	10/1/2015	10/19/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327523	Created By PM Schedule	016-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327525	Created By PM Schedule	007-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327592	Finished	096-ROOF-Z2A3'	10/1/2015	10/28/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-327609	Created By PM Schedule	089-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327638	Finished	090-COT-002	10/1/2015	10/30/2015	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-327639	Finished	090-SSF-541	10/1/2015	10/13/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-327640	Finished	090-ACU-541B	10/2/2015	10/13/2015	False	0.10	PM INSPECT AND CLEAN COIL
FO-327641	Finished	090-ACU-542B	10/2/2015	10/13/2015	False	0.10	PM INSPECT AND CLEAN COIL
FO-327642	Finished	090-ACU-543B	10/2/2015	10/15/2015	False	1.00	PM INSPECT AND CLEAN COIL
FO-328226	Finished	090-ACU-CR2	10/8/2015	10/6/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-328227	Finished	090-ACU-CR1	10/8/2015	10/6/2015	False	0.10	PM - Monthly AHU Inspection Clean Room Unit 1
FO-328229	Finished	090-GEN-001	10/20/2015	10/20/2015	False	1.00	Generator Maintenance, Monthly
FO-328239	Finished	090-DHW-003	10/8/2015	10/15/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-328402	Finished	089-GEN-001	10/21/2015	10/22/2015	False	1.00	Generator Maintenance, Monthly
FO-328432	Finished	006-GEN-001	10/15/2015	10/16/2015	False	0.60	Generator Maintenance, Monthly
FO-328809	Finished	090-CFP-541	10/1/2015	10/13/2015	False	0.15	PM - Chemical Feed/Metering Pump/Controller
FO-328810	Finished	090-CFP-542	10/1/2015	10/13/2015	False	0.15	PM - Chemical Feed/Metering Pump/Controller
FO-328811	Finished	090-CFP-543	10/1/2015	10/13/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-328812	Finished	090-CTL-001	10/1/2015	10/13/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-328813	Finished	090-CRP-001	10/1/2015	10/16/2015	False	0.50	PM - Condensate Return Pump
FO-328814	Finished	090-CRP-002	10/1/2015	10/16/2015	False	0.50	PM - Condensate Return Pump
FO-328815	Finished	090-CRP-003	10/1/2015	10/16/2015	False	0.50	PM - Condensate Return Pump
FO-328816	Finished	090-CRP-004	10/1/2015	10/16/2015	False	0.50	PM - Condensate Return Pump
FO-328817	Finished	090-CRP-005	10/1/2015	10/20/2015	False	0.50	PM - Condensate Return Pump
FO-328818	Finished	090-CRP-006	10/1/2015	10/20/2015	False	0.50	PM - Condensate Return Pump
FO-328819	Finished	090-CRP-007	10/1/2015	10/15/2015	False	0.50	PM - Condensate Return Pump
FO-328820	Finished	090-CRP-008	10/1/2015	10/15/2015	False	0.50	PM - Condensate Return Pump
FO-328821	Finished	090-CRP-541	10/1/2015	10/13/2015	False	1.00	PM - Condensate Return Pump
FO-328822	Created By PM Schedule	005-AHU-002	10/17/2015		False		PM INSPECT AND CLEAN COIL
FO-328823	Created By PM Schedule	005-AHU-001	10/17/2015		False		PM INSPECT AND CLEAN COIL
E - Southeast			165	76	89	0	46%
FO-324922	Finished	193-GEN-003	10/2/2015	10/2/2015	False	1.00	Generator Maintenance, Monthly
FO-327459	Created By PM Schedule	001-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327461	Created By PM Schedule	001-FCU-1154	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327466	Finished	071-AHU-001	10/1/2015	10/1/2015	False	2.00	PM - Air Handling Unit
FO-327467	Finished	071-AHU-002	10/1/2015	10/1/2015	False	2.00	PM - Air Handling Unit
FO-327468	Finished	071-COT-001	10/1/2015	10/24/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons

[illegible]

Requested Finished Open WND

% Finished

FO-327513	Finished	071-HWP-140	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327514	Finished	071-HWP-141	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327515	Finished	071-HWP-142	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327516	Finished	071-HWP-143	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327517	Finished	071-HWP-144	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327518	Finished	071-HWP-145	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327519	Finished	071-HWP-146	10/1/2015	10/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327520	Finished	071-HWP-147	10/1/2015	10/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327521	Finished	071-HWP-148	10/1/2015	10/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327522	Finished	071-HWP-149	10/1/2015	10/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-327524	Created By PM Schedule	499-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327526	Created By PM Schedule	001-FCU-0101	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327527	Created By PM Schedule	001-FCU-0102	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327528	Created By PM Schedule	001-FCU-0103	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327529	Created By PM Schedule	001-FCU-0105	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327530	Created By PM Schedule	001-FCU-0106	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327531	Created By PM Schedule	001-FCU-0111	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327532	Created By PM Schedule	001-FCU-0116	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327533	Created By PM Schedule	001-FCU-0121	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327534	Created By PM Schedule	001-FCU-0137	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327535	Created By PM Schedule	001-FCU-0141	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327536	Created By PM Schedule	001-FCU-0143	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327537	Created By PM Schedule	001-FCU-0145	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327538	Created By PM Schedule	001-FCU-0147	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327539	Created By PM Schedule	001-FCU-0151	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327540	Created By PM Schedule	001-FCU-0154	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327541	Created By PM Schedule	001-FCU-0204	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327542	Created By PM Schedule	001-FCU-0205	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327543	Created By PM Schedule	001-FCU-0208	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327544	Created By PM Schedule	001-FCU-0215	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327545	Created By PM Schedule	001-FCU-0224	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327546	Created By PM Schedule	001-FCU-0235	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327547	Created By PM Schedule	001-FCU-0307	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327548	Created By PM Schedule	001-FCU-0318	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327549	Created By PM Schedule	001-FCU-0332	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327550	Created By PM Schedule	001-FCU-0356	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327551	Created By PM Schedule	001-FCU-0358	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327552	Created By PM Schedule	001-FCU-0360	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327553	Created By PM Schedule	001-FCU-0361	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327554	Created By PM Schedule	001-FCU-0362	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327555	Created By PM Schedule	001-FCU-0363	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327556	Created By PM Schedule	001-FCU-0364	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327557	Created By PM Schedule	001-FCU-0365	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327558	Created By PM Schedule	001-FCU-0366	10/1/2015		False		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-327559	Created By PM Schedule	001-FCU-0367	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327560	Created By PM Schedule	001-FCU-0368	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327561	Created By PM Schedule	001-FCU-0369	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327562	Created By PM Schedule	001-FCU-0370	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327563	Created By PM Schedule	001-FCU-0372	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327564	Created By PM Schedule	001-FCU-0373	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327565	Created By PM Schedule	001-FCU-0374	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327566	Created By PM Schedule	001-FCU-0376	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327567	Created By PM Schedule	001-FCU-0377	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327568	Created By PM Schedule	001-FCU-0378	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327569	Created By PM Schedule	001-FCU-0379	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327570	Created By PM Schedule	001-FCU-0380	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327571	Created By PM Schedule	001-FCU-0382	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327572	Created By PM Schedule	001-FCU-0383	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327573	Created By PM Schedule	001-FCU-0384	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327574	Created By PM Schedule	001-FCU-0385	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327575	Created By PM Schedule	001-FCU-0386	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327576	Created By PM Schedule	001-FCU-0387	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327577	Created By PM Schedule	001-FCU-0388	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327578	Created By PM Schedule	001-FCU-0389	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327579	Created By PM Schedule	001-FCU-0390	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327580	Created By PM Schedule	001-FCU-0402	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327581	Created By PM Schedule	504-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327582	Created By PM Schedule	001-FCU-0129	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327583	Created By PM Schedule	001-FCU-0134	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327584	Created By PM Schedule	001-FCU-0149	10/1/2015		False		PM - Fan Coil/HV/AC Unit
FO-327585	Created By PM Schedule	001-COT-001	10/4/2015		False		PM - Cooling Tower Fan (Old Main)
FO-327586	Created By PM Schedule	001-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327587	Created By PM Schedule	116-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327588	Finished	122-ROOF-Z2A3	10/1/2015	10/26/2015	False	0.50	PM - Roof Sumps - Zone 2, Area 3
Checked all roof sumps, they were clean.							
FO-327589	Finished	123-ROOF-Z2A3	10/1/2015	10/27/2015	False	0.50	PM - Roof Sumps - Zone 2, Area 3
Checked all roof sumps, they were all clean.							
FO-327590	Created By PM Schedule	170-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327591	Finished	171-ROOF-Z2A3	10/1/2015	10/6/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
FO-327593	Created By PM Schedule	189-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327594	Created By PM Schedule	199-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327595	Created By PM Schedule	504-ROOF-Z2A3	10/1/2015		False		PM - Roof Sumps - Zone 2, Area 3
FO-327605	Finished	017-DHW-001	10/1/2015	10/9/2015	False		PM - Domestic Water Heater, Electric
Checked operation of the unit, checked for any leaks from the tank and the relief valve, checked water temp., drained sediment from the tank. Cleaned the equipment.							
FO-327606	Finished	074-DHW-001	10/3/2015	10/1/2015	False	0.50	PM - Domestic Water Heater, Gas
FO-327610	Finished	001-AHU-001O	10/2/2015	10/29/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Open (Old Main)
OPEN STEAM VALVES.							

Requested Finished Open WND

% Finished

FO-327611	Finished	001-AHU-002O	10/2/2015	10/29/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Open (Old Main)
OPENED STEAM VALVES							
FO-327612	Finished	001-AHU-003O	10/2/2015	10/29/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Open (Old Main)
OPENED STEAM VALVES							
FO-327613	Finished	001-AHU-004O	10/2/2015	10/29/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Open (Old Main)
OPENED STEAM VALVES.							
FO-327614	Finished	001-AHU-001	10/1/2015	10/29/2015	False	0.25	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
OPENED STEAM VALVES.							
FO-327615	Finished	001-AHU-002	10/1/2015	10/29/2015	False	0.25	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
OPENED STEAM VALVES.							
FO-327616	Created By PM Schedule	504-UNH-001	10/1/2015		False		PM - Unit/Space Heater
FO-327617	Created By PM Schedule	504-GFF-001	10/1/2015		False		Gas Fired Furnace
FO-327643	Created By PM Schedule	504-GFF-003	10/1/2015		False		Gas Fired Furnace
FO-327644	Created By PM Schedule	504-GFF-002	10/1/2015		False		Gas Fired Furnace
FO-327645	Created By PM Schedule	504-GFF-004	10/1/2015		False		Gas Fired Furnace
FO-327646	Finished	637-COT-001	10/1/2015	10/21/2015	False		PM - Cooling Tower, 500 - 1000 Tons
cleaned tower							
FO-327647	Created By PM Schedule	068-COT-001	10/1/2015		False		PM - Cooling Tower, 500 - 1000 Tons
FO-327673	Created By PM Schedule	001-FMB-2402	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327674	Created By PM Schedule	001-FMB-2413	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327675	Created By PM Schedule	001-FMB-3413	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327676	Created By PM Schedule	001-FMB-4402.2	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327677	Created By PM Schedule	001-FMB-4404	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327678	Created By PM Schedule	001-FMB-4406	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327679	Created By PM Schedule	001-FMB-4413-2	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327680	Created By PM Schedule	001-FMB-4413-1	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327681	Created By PM Schedule	001-FMB-4418.6	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-327682	Created By PM Schedule	001-FMB-DOCK	10/1/2015		False		PM - Fan Motor Box (Old Main)
FO-328223	Finished	609-GEN-001	10/20/2015	10/21/2015	False		Generator Maintenance, Monthly
checked fluids							
FO-328225	Finished	071-HWP-001	10/10/2015	10/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-328233	Finished	637-GEN-001	10/20/2015	10/21/2015	False		Generator Maintenance, Monthly
checked fluids							
FO-328235	Finished	637-GEN-002	10/20/2015	10/21/2015	False		Generator Maintenance, Monthly
checked fluids							
FO-328804	Created By PM Schedule	499-CFP-001	10/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-328805	Created By PM Schedule	499-CFP-002	10/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-328806	Created By PM Schedule	499-CFP-003	10/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-328807	Created By PM Schedule	499-CFP-004	10/1/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-329434	Finished	071-HUM-001	10/23/2015	10/23/2015	False	2.00	PM - Humidifier
FO-329435	Finished	504-DHW-001	10/22/2015	10/1/2015	False	0.50	PM - Domestic Water Heater, Gas
E - West			29	29	0	0	100%
FO-324912	Finished	001 SPARE from	10/13/2015	10/13/2015	False		Generator Maintenance, Monthly
FO-327460	Finished	155-COT-001	10/1/2015	10/28/2015	False		PM - Cooling Tower, 500 - 1000 Tons

Requested Finished Open WND

% Finished

FO-327463	Finished	003-COT-001	10/1/2015	10/16/2015	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
Drained cleaned rinsed...ok							
FO-327464	Finished	003-UNH-001	10/1/2015	10/29/2015	False		PM - Unit/Space Heater
FO-327465	Finished	003-UNH-002	10/1/2015	10/29/2015	False		PM - Unit/Space Heater
FO-327602	Finished	080-COT-001	10/1/2015	10/15/2015	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
General shut down for the season.							
FO-327607	Finished	156-DHW-001	10/1/2015	10/29/2015	False		PM - Domestic Water Heater, Electric
FO-327608	Finished	156-DHW-002	10/1/2015	10/29/2015	False		PM - Domestic Water Heater, Electric
FO-327653	Finished	080-SAF-02A	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327654	Finished	080-SAF-01A	10/1/2015	10/29/2015	False		Replace PRE-filters
FO-327655	Finished	080-SAF-018	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327656	Finished	080-SAF-017	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327657	Finished	080-SAF-016	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327658	Finished	080-SAF-015	10/1/2015	10/29/2015	False		Replace PRE-filters
FO-327659	Finished	080-SAF-014	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327660	Finished	080-SAF-013	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327661	Finished	080-SAF-012	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327662	Finished	080-SAF-011	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327663	Finished	080-SAF-010	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327664	Finished	080-SAF-009	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327665	Finished	080-SAF-008	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327666	Finished	080-SAF-007	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327667	Finished	080-SAF-006	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327668	Finished	080-SAF-005	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327669	Finished	080-SAF-004	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327670	Finished	080-SAF-003	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327671	Finished	080-SAF-002	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-327672	Finished	080-SAF-001	10/1/2015	10/28/2015	False		Replace PRE-filters
FO-328434	Finished	169-GEN-001	10/22/2015	10/23/2015	False		Generator Maintenance, Monthly

Trades			42	38	4	0		90%
T - Electrician			37	33	4	0		89%
FO-324848	Finished	007-GEN-001	10/8/2015	10/12/2015	False	7.50	Generator Test, Thursday 10/15/2015 @ 7:15 AM.	
Also fill the Batteries on the rack for the UPS.								
FO-324852	Finished	007-GEN-002	10/8/2015	10/8/2015	False	3.50	Generator Test, Thursday 10/15/2015 @ 7:15 AM.	
Also fill Batteries on the rack for the UPS.								
FO-324885	Finished	501-GEN-001	10/13/2015	10/20/2015	False	2.00	Generator Test, Tuesday 10/20/2015 @ 1PM.	
FO-324889	Finished	507-GEN-001	10/14/2015	10/14/2015	False	6.00	Generator Test, Wednesday 10/14/2015 @ 1PM.	
FO-324898	Finished	090-GEN-002	10/8/2015	10/8/2015	False	5.00	Generator Test, Thursday 10/15/2015 @ 7:15 AM.	
FO-324910	Finished	001 SPARE from	10/13/2015	10/13/2015	False	4.00	Generator Test, Tuesday 10/13/2015 @ 1PM.	
FO-328228	Finished	609-GEN-001	10/13/2015	10/20/2015	False	4.00	Generator Test, Tuesday 10/20/2015 @7:15 AM.	
FO-328230	Finished	090-GEN-001	10/20/2015	10/21/2015	False	4.00	Generator Test, Tuesday 10/20/2015 @ 9:30 AM.	
FO-328231	Finished	193-GEN-001	10/2/2015	10/2/2015	False	1.00	Generator Test, Friday 10/2/2015 @ 2:15 PM.	

Requested Finished Open WND

% Finished

FO-328232	Finished	637-GEN-001	10/13/2015	10/20/2015	False	2.00	Generator Test, Tuesday 10/20/2015 @ 8:15 AM.
FO-328234	Finished	637-GEN-002	10/13/2015	10/20/2015	False	2.00	Generator Test, Tuesday 10/20/2015 @ 8:15 AM.
FO-328236	Finished	203-GEN-001	10/20/2015	10/20/2015	False	4.00	Generator Test, Tuesday 10/20/2015 @ 9:30 AM.
FO-328237	Created By PM Schedule	608-GEN-001	10/9/2015		False	4.00	Generator Test, Tuesday 10/6/2015 @ 7:15 AM.
FO-328240	Finished	048-GEN-001	10/9/2015	10/9/2015	False	4.00	Generator Test, Friday 10/9/2015 @ 7:15 AM.
FO-328241	Finished	193-GEN-002	10/2/2015	10/2/2015	False	1.00	Generator Test, Friday 1-/2/2015 @ 2:15 PM.
FO-328242	Finished	193-GEN-003	10/2/2015	10/2/2015	False	1.00	Generator Test, Friday 1-/2/2015 @ 2:15 PM.
FO-328243	Finished	193-GEN-004	10/2/2015	10/2/2015	False	1.00	Generator Test, Friday 10/2/2015 @ 2:15 PM.
FO-328403	Finished	089-GEN-001	10/21/2015	10/21/2015	False	4.00	Generator Test, Wednesday 10/21/2015 @ 10AM.
FO-328405	Finished	066-GEN-001	10/28/2015	10/28/2015	False	4.00	Generator Test
FO-328406	Finished	611-GEN-001	10/23/2015	10/27/2015	False	4.00	Generator Test, Tuesday 10/27/2015 @ 7:15 AM.
FO-328408	Finished	629-GEN-001	10/27/2015	10/27/2015	False	2.00	Generator Test
FO-328410	Finished	104-GEN-001	10/27/2015	10/27/2015	False	5.50	Generator Test, Tuesday 10/27/2015 @ 10AM.
FO-328412	Finished	127-GEN-001	10/27/2015	10/27/2015	False	1.00	Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328414	Finished	127-GEN-002	10/27/2015	10/27/2015	False	1.00	Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328416	Finished	127-GEN-003	10/27/2015	10/27/2015	False	1.00	Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328418	Finished	127-GEN-004	10/27/2015	10/27/2015	False	1.00	Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328420	Finished	130-GEN-001	10/28/2015	10/28/2015	False	5.00	Generator Test, Wednesday 10/28/2015 @ 7:15 AM.
FO-328422	Finished	612-GEN-001	10/9/2015	10/13/2015	False	2.00	Generator Test, Tuesday 10/13/2015 @ 7:15AM.
FO-328423	Created By PM Schedule	612-GEN-001	10/9/2015		False		Generator Maintenance, Monthly
FO-328424	Finished	612-GEN-002	10/9/2015	10/13/2015	False	2.00	Generator Test, Tuesday 10/13/2015 @ 7:15 AM.
FO-328425	Created By PM Schedule	612-GEN-002	10/9/2015		False		Generator Maintenance, Monthly
FO-328426	Finished	536-GEN-001	10/21/2015	10/21/2015	False	4.00	Generator Test, Wednesday 10/21/2015 @ 7:15 AM.
FO-328428	Created By PM Schedule	527-GEN-001	10/15/2015		False	4.00	Generator Test, Thursday 10/15/2015 @ 7:15 AM.
FO-328431	Finished	006-GEN-001	10/15/2015	10/15/2015	False	4.00	Generator Test, Thursday 10/15/2015 @ 7:15 AM.
FO-328433	Finished	169-GEN-001	10/22/2015	10/22/2015	False	6.00	Generator Test, Thursday 10/22/2015 @ 7:15 AM.
FO-328435	Finished	060-GEN-001A	10/22/2015	10/22/2015	False	2.00	Generator Test, Thursday 10/22/2015 @ 1PM.
FO-328437	Finished	060-GEN-001B	10/22/2015	10/22/2015	False	2.00	Generator Test, Thursday 10/22/2015 @ 1PM.
T - Plumber			5	5	0	0	100%
FO-326459	Finished	042	10/1/2015	10/9/2015	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/10-1-15 ,,,,,,,,,,
FO-326460	Finished	527	10/1/2015	10/1/2015	False		**CANCELLED JWT
							PM - Main Drain with Copper Sulfate
FO-326461	Finished	608	10/1/2015	10/2/2015	False		**CANCELLED JWT
							PM - Waterless Urinals ,,,,,,,,,, MM/10-1-15 ,,,,,,,,,
FO-326462	Finished	049	10/1/2015	10/2/2015	False		*CANCELLED JWT
							PM - Waterless Urinals ,,,,,,,,,, MM/10-1-15 ,,,,,,,,,
FO-326463	Finished	090	10/1/2015	10/2/2015	False		CANCELLED JWT
							PM - Waterless Urinals ,,,,,,,,,, MM/10-1-15 ,,,,,,,,,

Report Total

790

542

244

4

69%