

**\*DRAFT\* Facilities Operations PM Analysis from 4/1/2014 through 4/30/2014**

Request		%	Requested Open WND Finished			
<b>Engineering</b>		<b>62%</b>	<b>862</b>	<b>273</b>	<b>73</b>	<b>535</b>
<b>E - Area 2 Engineer</b>		<b>0%</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>
FO-281902	089-VPS-001	PM Vacuum pump system. Finished 4/4/13LT Changed to low, Laborer didn't receive work order till 7/22/2013.	see results for fo#16406 4/17/2014		False	
<b>E - Auxiliary</b>		<b>38%</b>	<b>40</b>	<b>25</b>	<b>0</b>	<b>15</b>
FO-278719	134-CHWP-003	PM - Centrifugal Pump, over 1 H.P.	4/1/2014		False	
FO-278720	134-CHWP-004	PM - Centrifugal Pump, over 1 H.P.	4/1/2014		False	
FO-278721	134-CWP-001	PM - Centrifugal Pump, over 1 H.P.	4/1/2014		False	
FO-278713	501-GEN-001	Generator Maintenance, Monthly	G. Ray assisted with test. 4/8/2014		False	4/8/2014
FO-279335	507-GEN-001	Generator Maintenance, Monthly	G. Ray checked fluid levels and assisted with test. 4/9/2014		False	4/9/2014
FO-279337	992-ES-001*	PM - Emergency Shower/Eyewash Station	Checked units operation. 4/7/2014		False	4/11/2014
FO-280026	507-BSG-002	Boiler Rear Refractory Inspection - 60 " Boiler	4/13/2014		False	
FO-280029	115-GCP-001	PM - Centrifugal Pump, over 1 H.P.	4/13/2014		False	
FO-280030	127-GCP-001	PM - Centrifugal Pump, over 1 H.P.	4/13/2014		False	
FO-279578	536-GEN-001	Generator Maintenance, Monthly	Monitored test. 4/16/2014		False	4/16/2014
FO-280027	992-ES-001*	PM - Emergency Shower/Eyewash Station	Checked units operation. 4/14/2014		False	4/18/2014
FO-278714	104-MUA-001	PM - Air Handling Unit	4/1/2014		False	
FO-278715	104-MUA-002	PM - Air Handling Unit	4/1/2014		False	
FO-278716	115-MUA-001	PM - Air Handling Unit	4/1/2014		False	
FO-278717	115-MUA-002	PM - Air Handling Unit	4/1/2014		False	
FO-278718	115-MUA-003	PM - Air Handling Unit	4/1/2014		False	
FO-279320	034-AHU-004	PM - Air Handling Unit	Checked units operation. AHU to be replaced during 6th floor renovation this summer. 4/2/2014		False	4/15/2014
FO-279321	034-AHU-005	PM - Air Handling Unit	Lubed motor, fan bearings, dampers and checked belts. Ordered filter for replacement. 4/2/2014		False	4/15/2014
FO-279568	104-GEN-001	Generator Maintenance, Monthly	Assisted with test, checked fluid levels and battery condition. 4/22/2014		False	4/22/2014
FO-279569	127-GEN-001	Generator Maintenance, Monthly	Checked fluid levels, batteries and assisted with test. 4/22/2014		False	4/22/2014
FO-279570	127-GEN-002	Generator Maintenance, Monthly	Checked fluid levels, batteries and assisted with test. 4/22/2014		False	4/22/2014
FO-279571	127-GEN-003	Generator Maintenance, Monthly	Checked fluid levels, batteries and assisted with test. 4/22/2014		False	4/22/2014
FO-279572	127-GEN-004	Generator Maintenance, Monthly	Checked fluid levels, batteries and assisted with test. 4/22/2014		False	4/22/2014
FO-281620	507-BSG-003	Boiler Rear Refractory Inspection - 60 " Boiler Rear refractory inspection not complete until Detroit Boiler takes photo. Will work w/Detroit Boiler on shifting this responsibility. Sledge	4/25/2014		False	4/25/2014
FO-280928	992-ES-001*	PM - Emergency Shower/Eyewash Station	Tested units operation. 4/21/2014		False	4/25/2014
FO-280028	104-CWP-001	PM - Centrifugal Pump, over 1 H.P.	4/13/2014		False	

Request			%	Requested	Open	WND	Finished
FO-278735	134-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		4/1/2014		False	
FO-278736	127-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		Checked start pressure for jockey & Fire pumps. Tested alarm report to the fire panel.	4/1/2014	False	4/28/2014
FO-278737	115-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		4/1/2014		False	
FO-278738	104-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		4/1/2014		False	
FO-278739	507-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		4/1/2014		False	
FO-281621	992-ES-001*	PM - Emergency Shower/Eyewash Station		4/28/2014		False	
FO-280014	034-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280019	127-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280020	104-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280021	115-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280022	134-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280023	507-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280024	992-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-280025	992-COT-002	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
<b>E - Command Center</b>			<b>0%</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>
FO-279338	048-BSG-002	Boiler Rear Refractory Inspection - 60 " Boiler		4/2/2014		False	
<b>E - MedPharm</b>			<b>24%</b>	<b>68</b>	<b>52</b>	<b>0</b>	<b>16</b>
FO-279576	608-GEN-001	Generator Maintenance, Monthly		4/4/2014		False	4/4/2014
FO-279574	612-GEN-001	Generator Maintenance, Monthly		4/11/2014		False	
FO-279575	612-GEN-002	Generator Maintenance, Monthly		4/11/2014		False	
FO-279280	612-WSS-001	PM - Water Softener		4/4/2014		False	
FO-279567	629-GEN-001	Generator Maintenance, Monthly		4/25/2014		False	
FO-279566	611-GEN-001	Generator Maintenance, Monthly		4/25/2014		False	
FO-278601	612-EXF-062	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278602	612-EXF-063	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278603	612-EXF-064	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278604	612-EXF-065	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278605	612-EXF-066	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278606	612-EXF-067	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278607	612-EXF-068	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278608	612-EXF-069	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	

Request			%	Requested	Open	WND	Finished
FO-278609	612-EXF-070	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278610	612-EXF-071	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278611	612-EXF-072	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278612	612-EXF-073	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278613	612-EXF-074	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278614	612-EXF-075	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278615	612-EXF-076	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278616	612-EXF-077	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278617	612-EXF-078	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278618	612-EXF-079	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278619	612-EXF-080	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278620	612-EXF-081	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278621	612-EXF-082	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278622	612-EXF-083	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278623	612-EXF-084	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278624	612-EXF-085	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278625	612-EXF-086	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278626	612-EXF-087	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278627	612-EXF-088	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278628	612-EXF-090	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278629	612-EXF-091	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278630	612-EXF-093	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278631	612-EXF-094	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278632	612-EXF-095	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False
FO-278633	612-EXF-096	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014			False

Request			%	Requested	Open	WND	Finished
FO-278634	612-EXF-098	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278635	612-EXF-6345	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278636	612-EXF-8319	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		4/1/2014		False	
FO-278637	612-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		4/1/2014		False	
FO-280903	609-DHW-001	PM - Domestic Water Heater, Steam	checked heater	4/18/2014		False	4/29/2014
FO-280904	609-DHW-002	PM - Domestic Water Heater, Steam	checked heater	4/18/2014		False	4/29/2014
FO-279278	609-SP-001	PM - Sump Pump		4/4/2014		False	
FO-279279	609-SP-002	PM - Sump Pump	checked coupler and lub pump	4/4/2014		False	4/29/2014
FO-280905	603-DHW-001	PM - Domestic Water Heater, Steam		4/21/2014		False	
FO-280906	603-DHW-002	PM - Domestic Water Heater, Steam		4/21/2014		False	
FO-280907	603-DHW-003	PM - Domestic Water Heater, Steam		4/21/2014		False	
FO-279863	609-COT-001	PM - Cooling Tower, 500 - 1000 Tons	cleaned tower checked fluid	4/15/2014		False	4/29/2014
FO-279864	609-COT-002	PM - Cooling Tower, 500 - 1000 Tons	cleaned tower checked fluid	4/15/2014		False	4/29/2014
FO-279865	603-COT-001	PM - Cooling Tower, 500 - 1000 Tons	cleaned unit, checked fan unit units fill needs to be acid cleans	4/15/2014		False	4/16/2014
FO-279866	603-COT-002	PM - Cooling Tower, 500 - 1000 Tons	north fill need acid cleaning.	4/15/2014		False	4/17/2014
FO-279867	611-COT-001**	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-279868	629-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-279869	629-COT-002	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-279870	612-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Peter Belcher-cleaned cooling tower checked operation oiled and greased bearings	4/15/2014		False	4/21/2014
FO-279871	612-COT-002	PM - Cooling Tower, 500 - 1000 Tons	Peter Belcher-removed covers and cleaned treys oiled motor, greased motor bearings. swept out tower used water hose to clean out tower cleaned area around tower	4/15/2014		False	4/28/2014
FO-279872	612-COT-003	PM - Cooling Tower, 500 - 1000 Tons	Peter Belcher-cleaned sprays swept out tower oiled and greased unit washed out tower	4/15/2014		False	4/21/2014
FO-279872	612-COT-003	PM - Cooling Tower, 500 - 1000 Tons	Peter Belcher-did maintenance on towers for operation	4/15/2014		False	4/21/2014
FO-279873	612-COT-004	PM - Cooling Tower, 500 - 1000 Tons	Peter Belcher-cleaned sprays oiled and greased towers swept out towers losed out towers	4/15/2014		False	4/21/2014
FO-279874	608-COT-002	PM - Cooling Tower, 500 - 1000 Tons	Jonathan Keys-FILL MATERIALS NEED REPLACING. VFD DRIVE MONIOTORS REPLACED	4/15/2014		False	4/29/2014
FO-279875	608-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Jonathan Keys-FILL MATERIAL NEEDS TO BE REPLACED. VFD DRIVE MONITOR REPLACED	4/15/2014		False	4/29/2014
FO-279876	603-COT-003	PM - Cooling Tower, 500 - 1000 Tons	cleaned unit. fills are starting to flake	4/15/2014		False	4/10/2014
FO-281569	612-CRP-001	PM - Condensate Return Pump		4/25/2014		False	
FO-281570	612-CRP-002	PM - Condensate Return Pump		4/25/2014		False	

Request				%	Requested	Open	WND	Finished	
FO-281571	612-CRP-003A	PM - Condensate Return Pump			4/25/2014		False		
E - North					43%	87	46	0	37
FO-279580	048-GEN-001	Generator Maintenance, Monthly			Generator has not been turned-over to me. I have no keys to open generator cabenet doors, or books, info on this unit.	4/11/2014		False	4/30/2014
FO-279292	130-AHU-001	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	Carl Smith-clean mech room ck filter ok changed belts on return fan and order new belts		4/7/2014		False	4/11/2014	
FO-278645	049-CHWP-001	PM - Centrifugal Pump, over 1 H.P.			test ran pump and serviced. No problems.	4/1/2014		False	4/22/2014
FO-278646	049-CWP-001	PM - Centrifugal Pump, over 1 H.P.			test ran pump, needs repair/service on 4-14-14. working on pump, 4-24-14.	4/1/2014		False	4/30/2014
					On 4-25-14 Replaced bottom pump casing drain line. Elections need to look at why pump motor trip's as pump starts to move water (run).				
					On 4-28-14 replaced pressureg gauges on pump piping.				
FO-278647	049-CWP-002	PM - Centrifugal Pump, over 1 H.P.			Test ran pump and greased bearings. No problems.	4/1/2014		False	4/14/2014
FO-279287	046-HEX-001	PM - Heat Exchanger and Economizer			4/2/2014		False		
FO-279288	046-HEX-002	PM - Heat Exchanger and Economizer			Checked for leaks and operation. No problems noted.	4/2/2014		False	4/22/2014
FO-279289	046-HEX-003	PM - Heat Exchanger and Economizer			checked heatexchanger for leaks.	4/2/2014		False	4/25/2014
FO-279290	046-HEX-004	PM - Heat Exchanger and Economizer			Checked for leaks.	4/2/2014		False	4/25/2014
FO-279291	046-HEX-005	PM - Heat Exchanger and Economizer			checked for tube leak, operation	4/2/2014		False	4/28/2014
FO-279282	050-RHC-011	PM - Unspecified	Carl Smith-no leaks		4/4/2014		False	4/2/2014	
FO-279283	050-RHC-012	PM - Unspecified			4/4/2014		False	4/2/2014	
FO-279573	130-GEN-001	Generator Maintenance, Monthly			4/23/2014		False	4/24/2014	
FO-280910	130-AHU-001	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	Carl Smith-check belts ok		4/21/2014		False	4/15/2014	
FO-279910	043-CRS-001	PM - Condensate Return Pump			4/15/2014		False		
FO-279911	043-CRS-002	PM - Condensate Return Pump			4/15/2014		False		
FO-277480	130-AHU-004	Replace PRE-filters	Carl Smith-change filters and grease bearing		4/1/2014		False	4/21/2014	
FO-277481	130-AHU-003	Replace PRE-filters	Michael Fitzgerald-check belt- tension wear and alignment supply fan check belt- tension wear and alignment return fan return fan belt broken- ordering new belt lubricate fan and motor bearings supply fan lubricate fan and motor bearings return fan. lubricate dampers and damper motor points change filters.	Completed by PM Shift. Future PM's remainin assigned to Day shift.	4/1/2014		False	4/9/2014	
FO-277482	130-AHU-002	Replace PRE-filters	Carl Smith-change filters		4/1/2014		False	4/21/2014	

Request		%			Requested	Open	WND	Finished
FO-277483	130-AHU-001	Replace PRE-filters	Michael Fitzgerald-Check belts on supply fan tension wear and alignment. check belts on return fan- tension wear and alignment lubricate fan and motor bearings on supply fan lubricate fan and motor bearings on return fan lubricate dampers and damper motor points change filters. cleaning fan housing	Completed by PM Shift. Future PM's remainin assigned to Day shift.	4/1/2014		False	4/8/2014
FO-279877	130-AHU-001	PM - Air Handling Unit		Reference FO-277483	4/11/2014	4/2/2014	False	
FO-279878	130-AHU-002	PM - Air Handling Unit		Reference FO-277482	4/11/2014	4/2/2014	False	
FO-279879	130-AHU-003	PM - Air Handling Unit			4/11/2014	4/2/2014	False	
FO-279880	130-AHU-004	PM - Air Handling Unit			4/11/2014	4/2/2014	False	
FO-280908	050-RHC-013	PM - Unspecified	Carl Smith-no leak clean mech room		4/18/2014		False	4/9/2014
FO-280909	050-RHC-014	PM - Unspecified	Carl Smith-no leak coil clean mech room		4/18/2014		False	4/9/2014
FO-279284	033-HVU-001	PM - Forced Air Furnace (Jacob House) - Summer			4/3/2014		False	
FO-279285	033-HVU-002	PM - Forced Air Furnace (Jacob House) - Summer			4/3/2014		False	
FO-279286	033-HVU-003	PM - Forced Air Furnace (Jacob House) - Summer			4/3/2014		False	
FO-281574	048-HEX-001	PM - Heat Exchanger and Economizer			4/23/2014		False	
FO-281575	048-HEX-002	PM - Heat Exchanger and Economizer			4/23/2014		False	
FO-281585	130-DHW-001	PM - Domestic Water Heater, Electric			4/23/2014		False	4/24/2014
FO-279891	038-SP-001	PM - Sump Pump			4/11/2014		False	
FO-279892	038-SP-002	PM - Sump Pump			4/11/2014		False	
FO-279893	039-SP-001	PM - Sump Pump			4/11/2014		False	
FO-279894	039-SP-002	PM - Sump Pump			4/11/2014		False	
FO-279895	039-SP-003	PM - Sump Pump			4/11/2014		False	
FO-279896	039-SP-004	PM - Sump Pump			4/11/2014		False	
FO-279897	039-SP-005	PM - Sump Pump			4/11/2014		False	
FO-279898	039-SP-006	PM - Sump Pump			4/11/2014		False	
FO-279899	042-SP-001	PM - Sump Pump			4/11/2014		False	
FO-279900	042-SP-002	PM - Sump Pump			4/11/2014		False	
FO-279901	043-SP-001	PM - Sump Pump			4/11/2014		False	
FO-279902	043-SP-002	PM - Sump Pump			4/11/2014		False	
FO-281586	026-CWP-001	PM - Centrifugal Pump, over 1 H.P.			4/27/2014		False	
FO-279881	140-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Carl Smith-clean tower wrote w.o to repair drain line leak		4/15/2014		False	4/10/2014
FO-279882	050-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Carl Smith-clean no leak		4/15/2014		False	4/9/2014
FO-279903	039-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279904	026-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279905	026-COT-002	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279906	026-COT-003	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279907	026-COT-004	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	

Request			%		Requested	Open	WND	Finished
FO-279908	036-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279909	043-AHU-INT	PM - Outside/Fresh Air Intake Screens			4/15/2014		False	
FO-279913	049-COT-001	PM - Cooling Tower, 500 - 1000 Tons		Final spring cleaning of tower, checked motor and fan drive, and filled tower for use.	4/15/2014		False	4/11/2014
FO-279914	048-COT-001	PM - Cooling Tower, 500 - 1000 Tons		Final spring cleaning, checked fan drive and motor. Filled tower for operation.	4/15/2014		False	4/11/2014
FO-279915	046-COT-001	PM - Cooling Tower, 500 - 1000 Tons		Repaired tower and did final spring cleaning. Closed all drains and filled tower for summer use.	4/15/2014		False	4/21/2014
FO-278640	046-CHWP-001	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings. Noted inboard bearing noise for service.	4/1/2014		False	4/21/2014
FO-278641	046-CHWP-002	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings. No problems noted.	4/1/2014		False	4/21/2014
FO-278642	046-CHWP-003	PM - Centrifugal Pump, over 1 H.P.		test ran pump. Isolated system as chill coil sprang leak and needs repair. W.O. in to fitters.	4/1/2014		False	4/21/2014
FO-278643	046-CWP-001	PM - Centrifugal Pump, over 1 H.P.		Test ran and greased bearings. No issues noted.	4/1/2014		False	4/21/2014
FO-278644	046-CWP-002	PM - Centrifugal Pump, over 1 H.P.		Checked and test ran pump, greased bearings.	4/1/2014		False	4/21/2014
FO-278648	048-CHWP-001	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings. No problems noticed.	4/1/2014		False	4/25/2014
FO-278649	048-CHWP-002	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings. Nom problems noticed.	4/1/2014		False	4/25/2014
FO-278650	048-CWP-003	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings.	4/1/2014		False	4/11/2014
FO-278651	048-CWP-004	PM - Centrifugal Pump, over 1 H.P.		Test ran pump and greased bearings.	4/1/2014		False	4/11/2014
FO-278652	046-COT-001	PM - Cooling Tower Start-up		After repairs to tower, placed tower fill lines in service and filled cooling tower and checked for leaks, issues.	4/1/2014		False	4/21/2014
FO-281576	025-ROOF-Z2A3**	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281577	026-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281578	027-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281579	036-ROOF-Z2A3	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281580	038-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281581	039-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281582	040-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281583	042-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281584	043-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281572	050-SP-001	PM - Sump Pump			4/25/2014		False	4/22/2014
FO-281573	050-SP-002	PM - Sump Pump			4/25/2014		False	4/21/2014
FO-279883	046-CFP-002	PM - Chemical Feed/Metering Pump/Controller			4/15/2014		False	
FO-279884	046-CFP-003	PM - Chemical Feed/Metering Pump/Controller			4/15/2014		False	
FO-279885	048-CFP-002	PM - Chemical Feed/Metering Pump/Controller			4/15/2014		False	
FO-279886	048-CFP-003	PM - Chemical Feed/Metering Pump/Controller			4/15/2014		False	
FO-279887	048-CFP-001	PM - Chemical Feed/Metering Pump/Controller			4/15/2014		False	

Request			%	Requested	Open	WND	Finished
FO-279888	049-CFP-002	PM - Chemical Feed/Metering Pump/Controller		4/15/2014		False	
FO-279889	049-CFP-003	PM - Chemical Feed/Metering Pump/Controller		4/15/2014		False	
FO-279890	049-CFP-004	PM - Chemical Feed/Metering Pump/Controller		4/15/2014		False	
FO-279912	046-CFP-001	PM - Chemical Feed/Metering Pump/Controller		4/15/2014		False	
<b>E - Northeast</b>			<b>20%</b>	<b>49</b>	<b>39</b>	<b>0</b>	<b>10</b>
FO-279297	193-GEN-001	Generator Maintenance, Monthly		4/4/2014		False	4/4/2014
FO-279298	193-GEN-002	Generator Maintenance, Monthly		4/4/2014		False	4/4/2014
FO-279299	193-GEN-003	Generator Maintenance, Monthly		4/4/2014		False	4/4/2014
FO-279300	193-GEN-004	Generator Maintenance, Monthly		4/4/2014		False	4/4/2014
FO-279296	203-GEN-001	Generator Maintenance, Monthly		4/15/2014		False	
FO-279296	203-GEN-001	Generator Maintenance, Monthly		4/15/2014		False	
FO-279579	527-GEN-001	Generator Maintenance, Monthly	Checked fluid levels, damper operation, full load test.	4/17/2014		False	4/17/2014
FO-279293	060-ACU-013	PM - Fan Coil/HV/AC Unit		4/4/2014		False	
FO-279294	060-ACU-014	PM - Fan Coil/HV/AC Unit		4/4/2014		False	
FO-279295	060-ACU-015	PM - Fan Coil/HV/AC Unit		4/4/2014		False	
FO-279565	066-GEN-001	Generator Maintenance, Monthly		4/23/2014		False	
FO-279918	060-ACU-016	PM - Fan Coil/HV/AC Unit		4/11/2014		False	
FO-279919	060-ACU-017	PM - Fan Coil/HV/AC Unit		4/11/2014		False	
FO-279920	060-ACU-018	PM - Fan Coil/HV/AC Unit		4/11/2014		False	
FO-279921	060-ACU-019	PM - Fan Coil/HV/AC Unit		4/11/2014		False	
FO-279923	062-FCU-003	PM - Fan Coil/HV/AC Unit		4/15/2014		False	
FO-279924	062-FCU-002	PM - Fan Coil/HV/AC Unit		4/15/2014		False	
FO-279925	062-FCU-001	PM - Fan Coil/HV/AC Unit		4/15/2014		False	
FO-279926	062-FCU-004	PM - Fan Coil/HV/AC Unit		4/15/2014		False	
FO-278672	065-AIR-001	PM - Air Compressor, Reciprocating 5-40 H.P.		4/1/2014		False	
FO-278673	067-AIR-001	PM - Air Compressor, Reciprocating 5-40 H.P.		4/1/2014		False	
FO-280911	060-ACU-020	PM - Fan Coil/HV/AC Unit		4/18/2014		False	
FO-280912	060-ACU-021	PM - Fan Coil/HV/AC Unit		4/18/2014		False	
FO-281590	064-DHW-001	PM - Domestic Water Heater, Gas		4/24/2014		False	
FO-281587	060-ACU-022	PM - Fan Coil/HV/AC Unit		4/25/2014		False	
FO-281588	060-ACU-023	PM - Fan Coil/HV/AC Unit		4/25/2014		False	
FO-281589	060-ACU-024	PM - Fan Coil/HV/AC Unit		4/25/2014		False	
FO-279916	193-COT-001	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-279917	193-COT-002	PM - Cooling Tower, 500 - 1000 Tons		4/15/2014		False	
FO-279922	509-COT-001	PM - Cooling Tower, 500 - 1000 Tons	cleaned tower, greased bearings filled tower	4/15/2014		False	4/30/2014
FO-279927	511-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Lubricated motor and fan bearings, cleaned sump, checked damper operation.	4/15/2014		False	4/25/2014
FO-278653	062-ACU-001	PM - Water/Air Cooled Condenser		4/1/2014		False	
FO-278654	062-ACU-002	PM - Water/Air Cooled Condenser		4/1/2014		False	

Request				%	Requested	Open	WND	Finished
FO-278658	065-ACU-001	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278659	065-ACU-002	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278660	065-ACU-003	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278661	065-ACU-005	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278662	065-ACU-007	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278663	065-ACU-008	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278664	065-ACU-009	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278665	065-ACU-010	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278666	066-ACU-001	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278667	066-ACU-002	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278668	066-ACU-003	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278669	067-ACU-001	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278670	067-ACU-002	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278671	510-ACU-001	PM - Water/Air Cooled Condenser		acid cleaned condeder coils	4/1/2014		False	4/4/2014
FO-278674	509-ACU-001	PM - Water/Air Cooled Condenser		removed head cleaned tubes	4/1/2014		False	4/30/2014
FO-278675	509-ACU-002	PM - Water/Air Cooled Condenser		removed head cleaned tubes	4/1/2014		False	4/30/2014
E - Preventative Maintenance				72%	373	55	37	268
FO-277338	001-FCU-4113	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277339	001-FCU-4115	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277340	001-FCU-4116	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277341	001-FCU-4119	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277342	001-FCU-4131	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277343	001-FCU-4135	PM - Fan Coil/HV/AC Unit			4/1/2014		False	5/1/2014
FO-277344	001-FCU-4136	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277345	001-FCU-4137	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277346	001-FCU-4138	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277347	001-FCU-4139	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277348	001-FCU-4117	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277349	001-FCU-4130.2	PM - Fan Coil/HV/AC Unit			4/1/2014		False	
FO-277628	043-AHU-001	PM - Air Handling Unit			4/4/2014	4/1/2014	True	
FO-269709	005-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.		4/1/2014		False	4/30/2014
FO-269876	608-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.tested fire protection pumps		4/1/2014		False	4/2/2014
FO-275552	155-AHU-005	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Changed filters. 24x24x2 (3) Lubricated motor and fan bearings in supply and return fans. Checked belts. Lubricated and exercised dampers. Cleaned interior. Closed up unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/4/2014

Request				%	Requested	Open	WND	Finished
FO-275553	155-AHU-004	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Inspected coil, valves, and piping. Checked drip pan. Changed filters 24x24x2 (25). Lubricated fan and motor bearings. Inspected belt. Lubricated and exercised dampers. Cleaned interior. Closed up doors, unlocked, and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/5/2014
FO-275554	155-AHU-003	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Inspected coil, valves, and piping. Checked drip pan. Changed filters 24x24x2 (25). Lubricated fan and motor bearings. Inspected belt. Lubricated and exercised dampers. Cleaned interior. Closed up doors, unlocked, and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/5/2014
FO-275555	155-AHU-002	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Inspected coil, valves, and piping. Cleaned interior. Inspected drip pan. Changed Pre filters 24x24x2 (25). Lubricated motor and fan bearings. Inspected drive belt. Lubricated dampers and exercised. Closed up unit and returned to service. Disposed of dirty filters. and cleaned area.		4/1/2014		False	4/4/2014
FO-275556	155-AHU-001	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Inspected coil, valves, and piping. Cleaned interior. Inspected drip pan. Changed Pre filters 24x24x2 (25). Lubricated motor and fan bearings. Inspected drive belt. Lubricated dampers and exercised. Closed up unit and returned to service. Disposed of dirty filters. and cleaned area.		4/1/2014		False	4/4/2014
FO-275557	096-SAF-FC1	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Lubricated fan and motor bearings. Ckecked belts. Replaced filters 24x24x2 (10). Lubricated and exercised dampers. Cleaned interior. Closed up doors and placed back in service. Disposed of old filters and cleaned area.		4/1/2014		False	4/17/2014
FO-275558	096-SAF-00E	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Lubricated fan and motor bearings. Ckecked belts. Replaced filters 24x24x2 (10). 12x24x2 (5). Lubricated and exercised dampers. Cleaned interior. Closed up doors and placed back in service. Disposed of old filters and cleaned area.		4/1/2014		False	4/17/2014
FO-275559	499-AHU-007	Replace PRE-filters			4/1/2014		False	4/30/2014

Request				%	Requested	Open	WND	Finished
FO-275560	499-AHU-005	Replace PRE-filters	Thomas Townsel-Changed filters, lubricated bearings, and checked belts.		4/1/2014		False	4/30/2014
FO-275561	499-AHU-004	Replace PRE-filters	Thomas Townsel-Checked belts, lubricated bearings, and changed filters.		4/1/2014		False	5/1/2014
FO-275562	499-AHU-003	Replace PRE-filters	Thomas Townsel-Change filters, greased bearings, lubricated dampers, checked belts, and checked motors.		4/1/2014		False	4/26/2014
FO-275563	499-AHU-002	Replace PRE-filters	Thomas Townsel-Changed filters, lubricated fan and motor bearings, checked belts. Unit in stand by.		4/1/2014		False	4/30/2014
FO-275564	499-AHU-001	Replace PRE-filters			4/1/2014		False	
FO-275565	091-AHU-002	Replace PRE-filters	Thomas Townsel-Change filters, checked unit for excessive noise, checked coils, and cleaned area.		4/1/2014		False	4/17/2018
FO-275566	091-AHU-001	Replace PRE-filters	Thomas Townsel-Change filters, checked unit for excessive noise, checked coils, and cleaned area		4/1/2014		False	4/17/2014
FO-275567	078-ACU-003	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Removed access covers. Cleaned interior. Changed filters. Checked motor and fan. Inspected belt. Lubricated and exercised dampers. Ckecked eavaporator drain. Closed up access panels. Test ran and returned to service.		4/1/2014		False	4/3/2014
FO-275568	078-ACU-002B	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Removed access covers. Cleaned interior. Changed filters. Checked motor and fan. Inspected belt. Lubricated and exercised dampers. Ckecked eavaporator drain. Closed up access panels. Test ran and returned to service.		4/1/2014		False	4/3/2014
FO-275569	078-ACU-002A	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Removed access covers. Cleaned interior. Changed filters. Checked motor and fan. Inspected belt. Lubricated and exercised dampers. Ckecked eavaporator drain. Closed up access panels. Test ran and returned to service.		4/1/2014		False	4/3/2014
FO-275570	078-ACU-001	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out unit. Removed access covers. Cleaned interior. Changed filters. Checked motor and fan. Inspected belt. Lubricated and exercised dampers. Ckecked eavaporator drain. Closed up access panels. Test ran and returned to service.		4/1/2014		False	4/3/2014
FO-275571	150-AHU-003	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed pre filters and bags, checked motor and bearings for exessive heat. Checked belts and shives. Lubricated bearings.		4/1/2014		False	4/8/2014

Request				%	Requested	Open	WND	Finished
FO-275572	150-AHU-002	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed pre filters and bags, checked motor and bearings for excessive heat. Checked belts and shives. Lubricated bearings		4/1/2014		False	4/8/2014
FO-275573	150-AHU-001	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed pre filters and bags, checked motor and bearings for excessive heat. Checked belts and shives. Lubricated bearings		4/1/2014		False	4/10/2014
FO-275573	150-AHU-001	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Change filters, checked unit for excessive noise, checked coils, checked belts, greased bearings and cleaned area		4/1/2014		False	4/10/2014
FO-275574	096-SAF-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Checked condition of coil, valves, and piping. Changed pre and bag filters 24x24x2 (10) 12x24x2 (5).Lubricated supply and return fan motor and fan bearings. Checked belts. Lubricated and exercised dampers. Cleaned interior. Closed up unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/18/2014
FO-275575	096-RAF-010	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Changed pre and bag filters 24x24x2 (3) 24x12x2 (3). Lubricated supply and return fan motor and fan bearings. Checked and ordered belts. Lubricated and exercised dampers. Checked drip pan. Cleaned interior. Closed up unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/19/2014
FO-275576	096-RAF-00B	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Lubricated fan and motor bearings. Checked belts. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/19/2014
FO-275577	096-RAF-009	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Changed filters and bags 24x24x2 (10) 24x12x2 (5). Lubricated fan and motor bearings. Checked belts. Lubricated and exercised dampers. Checked drip pan. Cleaned interior. Closed up doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/22/2014

Request				%	Requested	Open	WND	Finished
FO-275578	096-RAF-008	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Changed filters and bags 24x24x2 (10) 24x12x2 (5). Lubricated fan and motor bearings. Checked belts. Lubricated and exercised dampers. Checked drip pan. Cleaned interior. Closed up doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/22/2014
FO-275579	096-RAF-007	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down unit and locked out unit. Opened access doors. Inspected coil, valves, and piping. Changed pre and bag filters 24x24x2 (10). Lubricated fan and motor bearings. Inspected belts. Lubricated and exercised dampers. Cleaned interior. Closed unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/24/2014
FO-275580	096-RAF-006	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down unit and locked out unit. Opened access doors. Inspected coil, valves, and piping. Changed pre and bag filters 24x24x2 (15) 24x12x2 (5). Lubricated fan and motor bearings. Inspected belts. Lubricated and exercised dampers. Cleaned interior. Closed unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/24/2014
FO-275581	096-RAF-005	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Checked coil, valves, and piping. Changed pre and bag filters 24x24x2 (8). Lubricated fan and motor bearings. Inspected and adjusted belt. Checked drip pan. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/26/2014
FO-275582	096-RAF-004	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Checked condition of coil, valves, and piping. Changed pre and bag filters 24x24x2 (15) 24x12x2 (5).Lubricated motor and fan bearings on supply and return fans. Checked belts. Lubricated and exercised dampers. Cleaned interior. Checked drip pan. Closed up access doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/29/2014

Request				%	Requested	Open	WND	Finished
FO-275583	096-RAF-003	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Checked coil, valves, and piping. Changed pre and bag filters 24x24x2 (15) 24x12x2 (5) Lubricated fan and motor bearings. Inspected and adjusted belt. Checked drip pan. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/26/2014
FO-275584	096-RAF-002	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Checked condition of coil, valves, and piping. Changed pre and bag filters 24x24x2 (10) 24x12x2 (5).Lubricated motor and fan bearings on supply and return fans. Checked belts. Lubricated and exercised dampers. Cleaned interior. Checked drip pan. Closed up access doors and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/29/2014
FO-275585	156-SAF-001	Replace PRE-filters	Thomas Townsel-changed filters, greased bearings, checked belts, checked coils and dampers, and cleaned area.		4/1/2014		False	4/11/2014
FO-275949	499-AHU-006	PM - Air Handling Unit (ANNUAL)			4/1/2014		False	
FO-277255	130-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-Check belt- ordering new a33 belt check operation cleaning fan housing no lubrication points restore to operation		4/1/2014		False	4/23/2014
FO-277256	130-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-check operation no belts direct drive no lubrication points cleaning fan housing restore to service		4/1/2014		False	4/23/2014
FO-277257	130-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-check belt- ok check operation cleaning fan housing no lubrication points restore to operation		4/1/2014		False	4/23/2014
FO-277258	130-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-check belt- ok check operation cleaning fan housing no lubrication points restore to operation		4/1/2014		False	4/23/2014
FO-277259	090-EXF-001A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked belt, controls work.		4/1/2014		False	4/29/2014
FO-277260	090-EXF-002A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014
FO-277261	090-EXF-003A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Thomas Townsel-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014

Request				%	Requested	Open	WND	Finished
FO-277262	090-EXF-004A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Thomas Townsel-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014
FO-277263	090-EXF-005A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/18/2014
FO-277264	090-EXF-006A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/18/2014
FO-277265	090-EXF-007A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/18/2014
FO-277266	090-EXF-008A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/18/2014
FO-277267	090-EXF-009A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/19/2014
FO-277268	090-EXF-010A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/19/2014
FO-277269	090-EXF-011A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/19/2014
FO-277270	062-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277271	062-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277272	062-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277273	062-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277274	062-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277275	062-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277276	090-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Thomas Townsel-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014
FO-277277	155-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked fan and motor. Replaced belt (AP-23). Checked bearings. Replaced cover and returned to service.		4/1/2014		False	4/8/2014
FO-277278	155-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked fan and motor. Checked belt. Lubricated bearings. Replaced cover and retuned to service.		4/1/2014		False	4/8/2014
FO-277279	090-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/2/2014
FO-277280	090-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/2/2014
FO-277281	090-EXF-002E	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/2/2014
FO-277282	090-EXF-002W	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings.		4/1/2014		False	4/2/2014
FO-277283	090-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings.		4/1/2014		False	4/2/2014

Request				%	Requested Open WND Finished			
FO-277284	090-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/19/2014
FO-277285	090-EXF-007	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked motor, belt, and fan.		4/1/2014		False	4/18/2014
FO-277286	090-EXF-021	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277287	090-EXF-022	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277288	090-EXF-024	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277289	090-EXF-025	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277289	090-EXF-025	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277290	090-EXF-026	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.		4/1/2014		False	4/9/2014
FO-277291	090-EXF-027	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/10/2014
FO-277292	090-EXF-028	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/10/2014
FO-277293	090-EXF-029	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/10/2014
FO-277294	090-EXF-030	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/11/2014
FO-277295	090-EXF-031	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/11/2014
FO-277296	090-EXF-032	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/11/2014
FO-277297	090-EXF-033	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277298	090-EXF-034	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277299	090-EXF-035	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277300	090-EXF-036	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277301	090-EXF-037	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277302	090-EXF-038	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/12/2014
FO-277303	090-EXF-040	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/15/2014
FO-277304	090-EXF-052	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014
FO-277305	090-EXF-053	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.		4/1/2014		False	4/25/2014
FO-277306	090-EXF-135	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked belt, controls work.		4/1/2014		False	4/29/2014
FO-277307	090-EXF-EB	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/15/2014

Request				%	Requested	Open	WND	Finished
FO-277308	090-EXF-WB	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings and adjusted belt.		4/1/2014		False	4/15/2014
FO-277309	090-SAF-EB	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Thomas Townsel-greased dampers, changed filters, adjusted belt.		4/1/2014		False	4/25/2014
FO-277310	090-SAF-WB	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Thomas Townsel-greased dampers, adjusted belt.		4/1/2014		False	4/25/2014
FO-277311	612-EXF-013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex- fan #13 scotthall bldg.#612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check and change belts if necessary		4/1/2014		False	4/25/2014
FO-277312	612-EXF-014	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #14 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check and change belts as necessary put belt/motor guard back on		4/1/2014		False	4/25/2014
FO-277313	612-EXF-015	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #15 scotthall bldg. #612 remove belt /motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts and replace as necessary put belt guard back on		4/1/2014		False	4/25/2014
FO-277314	612-EXF-026	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #26 scotthal bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belt wear and replace as necessary put belt/motor guard back on		4/1/2014		False	4/25/2014
FO-277315	612-EXF-027	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #27 scotthall bldg. #612 remove belt/motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and replace as necessary put belt/motor guard back on		4/1/2014		False	4/25/2014
FO-277316	612-EXF-028	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #28 scotthall bldg. #612 remove belt/motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and replace as necessary put belt/motor guard back on		4/1/2014		False	4/25/2014

Request				%	Requested	Open	WND	Finished
FO-277317	612-EXF-029	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #29 scotthall bldg. #612 remove belt/motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and tear and replace as necessary put belt/motor guard back on		4/1/2014		False	4/25/2014
FO-277318	612-EXF-030	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #30 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear and replace if necessary put belt /motor guard back on		4/1/2014		False	4/26/2014
FO-277319	612-EXF-031	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan # 31 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear and change if necessary put belt / motor guard back on		4/1/2014		False	4/26/2014
FO-277320	612-EXF-040	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #40 scotthall #612 remove belt/motor guard lubricate motor and fan bearings lubricate dampers and linkages check belts for wear and replace if necessary put belt /motor guard back on		4/1/2014		False	4/29/2014
FO-277321	612-EXF-032	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #32 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear and replace if necessary put belt/motor guard back on		4/1/2014		False	4/26/2014
FO-277322	612-EXF-033	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan # 33 scotthall bldg. # 612 remove belt/motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and reolace as necessary put belt/motor guard back on		4/1/2014		False	4/26/2014
FO-277323	612-EXF-034	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #34 scotthall bldg. #612 remove belt/motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and change as necessary put belt/motor guard back on		4/1/2014		False	4/26/2014

Request				%	Requested	Open	WND	Finished
FO-277324	612-EXF-037	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #37 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate dampers and linkages check belts for wear and replace if necessary put belt/motor guard back on		4/1/2014		False	4/29/2014
FO-277325	612-EXF-038	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #38 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belt for wear and replace if necessary put belt/motor guard back on		4/1/2014		False	4/29/2014
FO-277326	612-EXF-039	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #38 scotthall bldg. #612 remove belt and motor guard lubricate fan and motor bearings lubricate linkages and dampers check belts for wear and replace if necessary put belt/motor guard back on		4/1/2014		False	4/29/2014
FO-277327	612-EXF-041	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #41 scotthall bldg. #612 remove belt/motor guard lubricate fan and motor bearings lubricate dampers and linkages check belts for wear and replace as necessary put belt/motor guard back on		4/1/2014		False	4/29/2014
FO-277328	612-EXF-042	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #42 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear change if necessary put belt/motor guard back on		4/1/2014		False	4/30/2014
FO-277329	612-EXF-043	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #43 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear and replace if necessary put belt/motor guard back on		4/1/2014		False	4/30/2014
FO-277330	612-EXF-044	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #44 scotthall bldg. #612 remove belt/motor guard lubricate motor and fan bearings lubricate dampers and linkages check belts for wear and replace if necessary put motor / fan guard back on		4/1/2014		False	4/30/2014

Request				%	Requested	Open	WND	Finished
FO-277331	612-EXF-089	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #89 scotthall bldg. #612 remove belt /motor guard lubricate fan and motor bearings lubricate dampers and linkages check wear on belts and replace if necessary put belt /motor guard back on		4/1/2014		False	4/30/2014
FO-277332	096-SAF-0600	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Changed filters 24x20x2 (2) 20x20x2 (4). Checked and ordered belts. Lubricated and exercised dampers. Checked drip pan. Cleaned interior. Closed up unit and returned to service. Disposed of old filters and cleaned area.		4/1/2014		False	4/19/2014
FO-277333	096-SAF-SFA	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Inspected fan. Checked belts. Lubricated fan and motor bearings. Test ran to check for noise and vibration. Returned to service.		4/1/2014		False	4/30/2014
FO-277334	509-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	greased bearings inspected belt		4/1/2014		False	4/28/2014
FO-277335	509-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	greased bearings, inspected belt		4/1/2014		False	4/28/2014
FO-277336	509-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Frank Vaught-Checked, belts ,and motor, put back in service.		4/1/2014		False	4/28/2014
FO-277337	509-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Frank Vaught-Checked belts , motor , cleaned area, put unit back in service.		4/1/2014		False	4/28/2014
FO-277350	603-ACU-005*	Replace PRE-filters	Derrick Allen-pm acu #5 pharmacy bldg. #603 inspect fan motor and compressor for noise inspect and change filters as needed		4/1/2014		False	3/28/2014
FO-277351	603-ACU-002*	Replace PRE-filters	Derrick Allen-pm acu#2 pharmacy bldg. #603 check fan motor and compressor for noise inspect and change filters as needed		4/1/2014		False	3/28/2014
FO-277352	603-ACU-004*	Replace PRE-filters	Derrick Allen-pm acu #4 pharmacy bldg. #603 inspect fan motor and compressor for noise inspect and change filters as needed		4/1/2014		False	3/28/2014
FO-277353	603-ACU-006*	Replace PRE-filters	Derrick Allen-pm ahu #6 pharmacy bldg. # 603 lubricate fan and motor bearings lubricate dampers and linkages change filters dispose of dirty filters		4/1/2014		False	3/25/2014
FO-277354	603-ACU-007*	Replace PRE-filters	Derrick Allen-pm ahu #7 pharmacy bldg. # 603 lubricate motor and fan bearings lubricate linkages and dampers change filters dispose of dirty filters		4/1/2014		False	3/25/2014

Request				%	Requested	Open	WND	Finished
FO-277355	603-ACU-008*	Replace PRE-filters	Derrick Allen-pm ahu#8 pharmacy bldg. #603 lubricate fan and motor bearings lubricate dampers and linkages change dirty filters dispose of dirty filters		4/1/2014		False	3/26/2014
FO-277356	603-ACU-010*	Replace PRE-filters	Derrick Allen-pm acu#10 pharmacy bldg. #603 lubricate bearings inspect and change filters inspect for noise and vibration		4/1/2014		False	4/1/2014
FO-277357	603-ACU-011*	Replace PRE-filters	Derrick Allen-pm acu #11 pharmacy bldg. #603 lubricate bearings inspect and change filters inspect and listen for vibration and noise		4/1/2014		False	4/1/2014
FO-277358	603-ACU-012*	Replace PRE-filters	Derrick Allen-pm ahu #12 pharmacy bldg. # 603 inspect and change filters inspect and listen for vibration abd noise lubricate bearings		4/1/2014		False	4/1/2014
FO-277359	603-ACU-013*	Replace PRE-filters	Derrick Allen-pm acu #13 pharmcy bldg. #603 lubricate bearings inspect and change filters inspect and listen for noise and vibration		4/1/2014		False	4/1/2014
FO-277360	603-ACU-014*	Replace PRE-filters	Derrick Allen-pm acu #14 pharmacy bldg.#603 lubricate bearings inspect and listen for noise and vibration inspect and change filters		4/1/2014		False	4/1/2014
FO-277361	603-ACU-015*	Replace PRE-filters	Derrick Allen-pm acu #15 pharmacy bldg.#603 lubricate bearings inspect and change filters inspect and listen for noise and vibration		4/1/2014		False	4/1/2014
FO-277362	603-ACU-016*	Replace PRE-filters	Derrick Allen-pm acu #16 pharmacy bldg. #603 lubricate bearings inspect and change filters inspect and listen for noise and vibration		4/1/2014		False	4/1/2014
FO-277363	603-ACU-003*	Replace PRE-filters	Derrick Allen-pm acu#3 pharmacy bldg. #603 lubricate fan motor bearings check compressors and fan for vibration and noise change and dispose of dirty filters		4/1/2014		False	4/22/2014
FO-277364	603-ACU-001*	Replace PRE-filters	Derrick Allen-pm acu#1 pharmacy bldg. #603 check for noise from fan motor and compressor check and change filter as needed		4/1/2014		False	3/28/2014

Request		%		Requested	Open	WND	Finished
FO-277365	603-ACU-009*	Replace PRE-filters	Derrick Allen-pm ahu #9 pharmacy bldg. # 603 lubricate fan abd motor bearings lubricate dampers and linkages change dirty filters dispose of dirty filters	4/1/2014		False	3/27/2014
FO-277366	090-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-checked belt, controls work.	4/1/2014		False	4/29/2014
FO-277367	090-EXF-041	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277368	090-EXF-042	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277369	090-EXF-044	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277370	090-EXF-045	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277371	090-EXF-046	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277372	090-EXF-048	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277373	090-EXF-049	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277374	090-EXF-B01	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.	4/1/2014		False	4/8/2014
FO-277375	090-EXF-B02	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.	4/1/2014		False	4/8/2014
FO-277376	090-EXF-B04	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.	4/1/2014		False	4/8/2014
FO-277377	090-EXF-B05	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.	4/1/2014		False	4/8/2014
FO-277378	090-EXF-B06	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-lubricated bearings, adjusted belt.	4/1/2014		False	4/8/2014
FO-277379	090-EXF-B07	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belt.	4/1/2014		False	4/25/2014
FO-277380	090-EXF-B08	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belts.	4/1/2014		False	4/3/2014
FO-277381	090-EXF-B09	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belts.	4/1/2014		False	4/3/2014
FO-277382	090-EXF-B10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Timothy Bowman-greased bearings, adjusted belts.	4/1/2014		False	4/3/2014
FO-277383	090-EXF-B11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Linda Schaller-greased bearings, adjusted belts.	4/1/2014		False	4/3/2014
FO-277384	090-EXF-B12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Linda Schaller-greased bearings, adjusted belts.	4/1/2014		False	4/3/2014
FO-277385	046-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the panel and called PS checked pull station ,back in service.	4/1/2014		False	4/19/2014
FO-277386	048-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire panel .called PS. reset system ,back in service.	4/1/2014		False	4/4/2014

Request				%	Requested	Open	WND	Finished
FO-277387	049-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught- tested fire pump and jockey pump , ,and panel, called PS reset abd back in service.		4/1/2014		False	4/19/2014
FO-277388	062-SF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-277389	156-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull station in order for hte test. Reset O.K at public safety. Copied the reading on PM sheet. Report given back to Ms. Carol D		4/1/2014		False	4/5/2014
FO-277390	499-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/23/2014
FO-277391	620-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested panel and pull station , called PS , put system back in service.		4/1/2014		False	4/3/2014
FO-277392	036-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/2/2014
FO-277393	025-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/18/2014
FO-277394	007-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.		4/1/2014		False	4/30/2014
FO-277395	001-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/17/2014
FO-277396	040-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/9/2014
FO-277397	038-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/4/2014

Request				%	Requested	Open	WND	Finished
FO-277398	028-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/4/2014
FO-277399	026-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/2/2014
FO-277400	022-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/11/2014
FO-277401	017-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire panel ccalled PS put system back in service.		4/1/2014		False	4/10/2014
FO-277402	016-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/4/2014
FO-277403	003-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.		4/1/2014		False	4/30/2014
FO-277404	006-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.		4/1/2014		False	4/30/2014
FO-277405	050-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested pull station caled PS. back in service.		4/1/2014		False	4/4/2014
FO-277406	043-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/9/2014
FO-277407	042-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/9/2014
FO-277408	062-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire and jockey pump called PS and checked pull station ,back in service.		4/1/2014		False	4/4/2014
FO-277409	065-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught- Tested he panel and fire , jockey pump, called PS reset the system , back in service.		4/1/2014		False	4/17/2014
FO-277410	068-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.		4/1/2014		False	4/3/2014
FO-277411	067-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Ran fire and jockey pumps ,called PS reset system , and put it back in service.		4/1/2014		False	4/11/2014

Request				%	Requested	Open	WND	Finished
FO-277412	089-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.		4/1/2014		False	4/30/2014
FO-277413	082-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/4/2014
FO-277414	080-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/16/2014
FO-277415	090-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test.		4/1/2014		False	4/30/2014
FO-277416	155-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/23/2014
FO-277417	150-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/4/2014
FO-277418	167-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test.		4/1/2014		False	5/1/2014
FO-277419	166-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test.		4/1/2014		False	5/1/2014
FO-277420	140-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-testeded the panel and the pull station, called PSreset , put system back in service.		4/1/2014		False	4/17/2014
FO-277421	130-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire and jockey ,pump called PS checked pull station, back in service.		4/1/2014		False	4/4/2014
FO-277422	193-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire panel and system, called PS reset , put system back in service.		4/1/2014		False	4/11/2014
FO-277423	189-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/7/2014
FO-277424	510-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tected fire panel and pull station, called PS, put system back in srevice.		4/1/2014		False	4/3/2014
FO-277425	509-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught- Tested the fire panel checked the pull station, called PS , system back in service.		4/1/2014		False	4/3/2014

Request				%	Requested	Open	WND	Finished
FO-277426	504-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/7/2014
FO-277427	629-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.tested fire protection pumps		4/1/2014		False	4/4/2014
FO-277428	611-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.tested fire protection pumps		4/1/2014		False	4/3/2014
FO-277429	609-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.tested fire protection pumps		4/1/2014		False	4/2/2014
FO-277430	603-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Inderjeet Batth-did fire alarm test.tested fire protection pumps		4/1/2014		False	4/3/2014
FO-277431	603-AHU-009	Replace PRE-filters	Derrick Allen-pm ahu #9 pharmacy bldg. #603 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters		4/1/2014		False	3/27/2014
FO-277432	603-AHU-008	Replace PRE-filters	Derrick Allen-pm # 8 ahu pharmacy bldg. #603 lubricate fan and motor bearings inspect and change dirty filters dispose of dirty filters lubricate dampers and linkages		4/1/2014		False	3/27/2014
FO-277433	603-AHU-007	Replace PRE-filters	Derrick Allen-pm ahu # 7 pharmacy bldg. #603 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around ahu housing		4/1/2014		False	3/29/2014
FO-277434	603-AHU-006	Replace PRE-filters	Derrick Allen-pm #6 ahu pharmacy bldg. #603 lubricate fan and motor bearings lubricate linkages and dampers change filters dispose of dirty filters cleanup around ahu housing		4/1/2014		False	3/29/2014
FO-277435	612-AHU-014	Replace PRE-filters	Derrick Allen-pm ahu #3 scott hall bldg. #612 lubricate motor and fan bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing		4/1/2014		False	4/16/2014
FO-277436	612-AHU-013	Replace PRE-filters	Derrick Allen-pm ahu #13 scott hall # 612 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters cleanup around fan housing		4/1/2014		False	4/18/2014

Request				%	Requested Open WND Finished			
FO-277437	612-AHU-012	Replace PRE-filters	Derrick Allen-pm ahu #12 scott hall bldg. #612 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing		4/1/2014		False	4/22/2014
FO-277438	612-AHU-011	Replace PRE-filters	Derrick Allen-pm ahu #11 scott hall bldg. #612 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing		4/1/2014		False	4/23/2014
FO-277439	612-AHU-010	Replace PRE-filters	Derrick Allen-pm ahu # 10 scotthall bldg. #612 lubricate motor and fan bearings lubricate linkages and dampers change dirty filters dispose dirty filters clean up around ahu # 10		4/1/2014		False	4/24/2014
FO-277440	612-AHU-009	Replace PRE-filters	Derrick Allen-pm ahu # 9 scott hall bldg. #612 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing		4/1/2014		False	4/22/2014
FO-277441	612-AHU-008	Replace PRE-filters			4/1/2014		False	
FO-277442	612-AHU-007	Replace PRE-filters	Derrick Allen-pm ahu #7 scott hall bldg. #612 lubricate moyor and fan bearings lubricare dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing		4/1/2014		False	4/17/2014
FO-277448	612-AHU-003	Replace PRE-filters	Derrick Allen-pm ahu #3 scott hall bldg. #612 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around ahu housing		4/1/2014		False	4/16/2014
FO-277449	612-AHU-002	Replace PRE-filters	Derrick Allen-pm ahu #2 scott hall bldg. #612 lubricate fan and motor bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around ahu housing		4/1/2014		False	4/11/2014

Request				%	Requested	Open	WND	Finished
FO-277450	612-AHU-001	Replace PRE-filters	Derrick Allen-pm ahu #1 scott hall bldg. #612 lubricate fan and motor bearings lubricate linkages and dampers change filters dispose of dirty filters		4/1/2014		False	4/12/2014
FO-277451	074-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire panel ,called PS put system back in service.		4/1/2014		False	4/10/2014
FO-277454	008-AHU-005	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277455	008-AHU-004	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277456	008-AHU-003	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277457	167-AHU-002	Replace PRE-filters	Timothy Bowman-greased and lubricated, filters are good. controls work, adjusted belts		4/1/2014		False	4/24/2014
FO-277458	167-AHU-001	Replace PRE-filters	Timothy Bowman-greased and lubricated, filters are good. controls work, adjusted belts		4/1/2014		False	4/24/2014
FO-277459	166-HVU-001	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277460	166-AHU-002	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277461	166-AHU-001	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277462	169-AHU-008	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277463	169-AHU-007	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277464	169-AHU-006	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277465	169-AHU-005	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277466	169-AHU-004	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277467	169-AHU-003	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277468	169-AHU-002	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277469	169-AHU-001	Replace PRE-filters			4/1/2014	4/1/2014	True	
FO-277470	003-AHU-008	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters,lubed bearings and inspected belts.		4/1/2014		False	4/26/2014
FO-277471	003-AHU-007	Replace PRE-filters	Thomas Townsel-Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts.		4/1/2014		False	4/22/2014
FO-277471	003-AHU-007	Replace PRE-filters	Timothy Bowman-Comments: Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts. select  select  Spell Check		4/1/2014		False	4/22/2014

Request				%	Requested	Open	WND	Finished
FO-277471	003-AHU-007	Replace PRE-filters	Morris Mims-vComments: Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts. select		4/1/2014		False	4/22/2014
			select					
			Spell Check					
FO-277472	003-AHU-006	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters and lubed dampers.		4/1/2014		False	4/17/2014
FO-277473	003-AHU-005	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters and lubed dampers.		4/1/2014		False	4/17/2014
FO-277474	003-AHU-004	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters and lubed dampers.		4/1/2014		False	4/17/2014
FO-277475	003-AHU-003	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters,lubed bearings and inspected belts.		4/1/2014		False	4/26/2014
FO-277476	003-AHU-002	Replace PRE-filters	Timothy Bowman-Checked fan operation,changed air filters,lubed bearings and inspected belts.		4/1/2014		False	4/26/2014
FO-277477	003-AHU-001	Replace PRE-filters	Thomas Townsel-Comments: Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts. select		4/1/2014		False	4/22/2014
			select					
			Spell Check					
FO-277477	003-AHU-001	Replace PRE-filters	Timothy Bowman-Comments: Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts. select		4/1/2014		False	4/22/2014
			select					
			Spell Check					
FO-277477	003-AHU-001	Replace PRE-filters	Morris Mims-Comments: Checked fan operation, changed bag and pre filters, lubed bearings and inspected belts. select		4/1/2014		False	4/22/2014
			select					
			Spell Check					

Request				%	Requested	Open	WND	Finished
FO-277478	130-HVU-002	Replace PRE-filters	Michael Fitzgerald-check belts tension wear and alignment sheaves are worn and will need to be replaced soon...ok for this cycle change filters lubricate fan and motor bearings cleaning fan housing cleaning fan room.		4/1/2014		False	4/2/2014
FO-277479	130-HVU-001	Replace PRE-filters	Michael Fitzgerald-check belts tension wear and alignment sheaves are worn and will need to be replaced soon...ok for this cycle change filters lubricate fan and motor bearings cleaning fan housing cleaning fan room.		4/1/2014		False	4/2/2014
FO-277484	193-AHU-005	Replace PRE-filters			4/1/2014		False	
FO-277485	193-AHU-004	Replace PRE-filters			4/1/2014		False	
FO-277486	193-AHU-003	Replace PRE-filters			4/1/2014		False	
FO-277487	193-AHU-002	Replace PRE-filters	Michael Fitzgerald-Check belt- tension wear and alignment change filters lubricate fan and motor bearings lubricate dampers and damper motor points cleaning fan housing cleaning fan room painting fan unit to present a clean and professional appearance.		4/1/2014		False	4/19/2014
FO-277488	193-AHU-001	Replace PRE-filters	Michael Fitzgerald-check belts- tension wear and alignment change filters (very dirty from nearby construction.) lubricate fan and motor bearings lubricate dampers and dampermotor points lubricate all zone dampers. cleaning fan housing cleaning fan room.		4/1/2014		False	4/22/2014
FO-277489	193-AHU-006	Replace PRE-filters			4/1/2014		False	
FO-277490	193-AHU-007	Replace PRE-filters			4/1/2014		False	
FO-277491	193-AHU-008	Replace PRE-filters			4/1/2014		False	
FO-277492	193-AHU-009	Replace PRE-filters			4/1/2014		False	
FO-277493	193-AHU-010	Replace PRE-filters			4/1/2014		False	
FO-277494	193-AHU-011	Replace PRE-filters			4/1/2014		False	
FO-277495	193-AHU-012	Replace PRE-filters			4/1/2014		False	
FO-277496	193-AHU-013	Replace PRE-filters			4/1/2014		False	
FO-277497	155-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked fan and motor. Checked belt. Lubricated bearings. Replaced cover and retuned to service.		4/1/2014		False	4/8/2014

Request				%	Requested	Open	WND	Finished
FO-277498	155-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked fan and motor. Checked belt. Lubricated bearings. Replaced cover and retuned to service.		4/1/2014		False	4/8/2014
FO-277499	155-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked fan and motor. Replaced belt. Lubricated bearings. Replaced cover and retuned to service.		4/1/2014		False	4/8/2014
FO-277951	509-AHU-005	Replace PRE-filters	unit no longer in service.		4/1/2014		False	4/28/2014
FO-277952	509-AHU-004	Replace PRE-filters	Frank Vaught-Changed flters, checked belts , checked motor, unit back in service.		4/1/2014		False	4/28/2014
FO-277953	509-AHU-003	Replace PRE-filters	Frank Vaught-Changed filters and checked belts ,motor greased bearings , unit back in service.		4/1/2014		False	4/28/2014
FO-277954	509-AHU-002	Replace PRE-filters	Frank Vaught-Changed filters bag only, checked belts ,motor cleaned area, unit back in service.		4/1/2014		False	4/28/2014
FO-277955	509-AHU-001	Replace PRE-filters	Frank Vaught-Replaced bag filters material ,checked motor and belts , back in service		4/1/2014		False	4/28/2014
FO-277956	510-AHU-002	Replace PRE-filters	Edward Nisnevich-Changed filter bags,measured filter rack for pre-filters, greased bearings,disposed dirty filters.		4/1/2014		False	5/1/2014
FO-277957	510-AHU-001	Replace PRE-filters	Edward Nisnevich-Delivered pre-filters to mechanical room,installed new pre-filters,replaced filter bags,greased bearings.Disposed dirty filters.		4/1/2014		False	5/1/2014
FO-277958	511-BFAH-001	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277959	511-AHU-206	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277960	511-AHU-205	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277961	511-AHU-204	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277962	511-AHU-203	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277963	511-AHU-202	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277964	511-AHU-201	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277965	511-AHU-007	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277966	511-AHU-006	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277967	511-AHU-005	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277968	511-AHU-004	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277969	511-AHU-003	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277970	511-AHU-002	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277971	511-AHU-001	Replace PRE-filters			4/1/2014	4/2/2014	False	
FO-277972	612-HVU-001	Replace PRE-filters			4/1/2014	4/2/2014	True	

Request				%	Requested	Open	WND	Finished
FO-279862	096-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pulled pull stations. Pressure tested fire pump and jockey pump. Translated reading into PM report. Report given back to Ms Carol D. Reset O.K to public safety.		4/1/2014		False	4/17/2014
FO-282364	130-SAF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			4/1/2014		False	
FO-282365	130-SAF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-check belt ok will need day shift engineer to write up a test procedure. lubricate dampers and damper motor points. dampers are rusty and need some tlc		4/1/2014		False	4/23/2014
FO-282366	130-SAF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-check belt ok will need day shift engineer to write up a test procedure. lubricate dampers and damper motor points. dampers are rusty and need some tlc		4/1/2014		False	4/23/2014
FO-282367	130-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-Check Belt- ok check operation no lubrication on fan and motor bearings cleaning fan housing.		4/1/2014		False	4/23/2014
FO-282368	130-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Michael Fitzgerald-Check Belt- ok check operation no lubrication on fan and motor bearings cleaning fan housing.		4/1/2014		False	4/23/2014
FO-282884	612-EXF-092	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #92 scotthall bldg. #612 remove fan/belt guard lubricate motor and fan bearings lubricate linkages and dampers check belts for wear and replace if necessary put motor/belt guard back on		4/1/2014		False	4/30/2014
FO-278229	042-AHU-001	PM - Air Handling Unit			4/11/2014	4/1/2014	True	
FO-279342	603-UNH-001	PM - Unit/Space Heater			4/20/2014	4/1/2014	True	
FO-279343	001-FCU-2323	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279343	001-FCU-2323	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279344	001-FCU-2325	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279345	001-FCU-2326	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279346	001-FCU-2327	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279347	001-FCU-2329	PM - Fan Coil/HV/AC Unit			4/22/2014		False	
FO-279348	001-FCU-2330	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014

Request				%	Requested	Open	WND	Finished
FO-279349	001-FCU-2332	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279350	001-FCU-2334-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279351	001-FCU-2334-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Checked unit for operation, changed filter, lubricated motor.		4/22/2014		False	5/1/2014
FO-279352	001-FCU-2339-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279353	001-FCU-2339-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279354	001-FCU-2341	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Check unit for operations, lubricated motor, changed filter.		4/22/2014		False	5/1/2014
FO-279355	001-FCU-2343-1	PM - Fan Coil/HV/AC Unit			4/22/2014		False	
FO-279356	001-FCU-2343-2	PM - Fan Coil/HV/AC Unit			4/22/2014		False	
FO-278112	001-FCU-4202	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278113	001-FCU-4204	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278114	001-FCU-4206	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278115	001-FCU-4208	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278116	001-FCU-4210	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278117	001-FCU-4212	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278118	001-FCU-4336	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278119	001-FCU-4337	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278120	001-FCU-4338	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278121	001-FCU-4339	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278122	001-FCU-4340	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278123	001-FCU-4342	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278124	001-FCU-4347	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-278125	001-FCU-4348	PM - Fan Coil/HV/AC Unit			4/8/2014	4/8/2014	True	
FO-280044	001-FCU-2345-1	PM - Fan Coil/HV/AC Unit			4/29/2014		False	
FO-280045	001-FCU-2345-2	PM - Fan Coil/HV/AC Unit			4/29/2014		False	
FO-280046	001-FCU-2347-1	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280047	001-FCU-2347-2	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280048	001-FCU-2354	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014

Request				%	Requested	Open	WND	Finished
FO-280049	001-FCU-2356	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280050	001-FCU-2359-1	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280051	001-FCU-2359-2	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280052	001-FCU-2360	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280053	001-FCU-2362	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280054	001-FCU-2365-1	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280055	001-FCU-2365-2	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-280056	001-FCU-2366	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014

Request				%	Requested	Open	WND	Finished
FO-280057	001-FCU-2372	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Removed cover. Checked coil, valves, and piping. Cleaned interior. Checked drip pan. Lubricated motor. Changed filter 10x43 7/8x1 (1). Replaced cover, test ran and returned to service.		4/29/2014		False	5/1/2014
FO-278740	001-FCU-4351	PM - Fan Coil/HV/AC Unit			4/15/2014	4/8/2014	True	
FO-278741	001-FCU-4353	PM - Fan Coil/HV/AC Unit			4/15/2014	4/8/2014	True	
FO-278742	001-FCU-4402	PM - Fan Coil/HV/AC Unit			4/15/2014		True	
FO-278743	001-FCU-4404	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278744	001-FCU-4406	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278745	001-FCU-4411	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278746	001-FCU-4413	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278747	001-FCU-4416	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278748	001-FCU-4418	PM - Fan Coil/HV/AC Unit			4/15/2014		False	
FO-278872	001-FMB-2402	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278873	001-FMB-2413	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278874	001-FMB-3413	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278875	001-FMB-4402.2	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278876	001-FMB-4404	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278877	001-FMB-4406	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278878	001-FMB-4413-2	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278879	001-FMB-4413-1	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278880	001-FMB-4418.6	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-278881	001-FMB-DOCK	PM - Fan Motor Box (Old Main)			4/17/2014		False	
FO-280059	048-SF-003	PM AHU - Belts & Lubrication			4/29/2014	4/2/2014	True	
FO-280060	048-SF-004	PM AHU - Belts & Lubrication			4/29/2014	4/2/2014	True	
<b>E - South</b>				<b>95%</b>	<b>42</b>	<b>2</b>	<b>0</b>	<b>40</b>
FO-279562	007-GEN-001	Generator Maintenance, Monthly	John Covert-Sisung-Fuel level: +3/4; Oil level: Full Radiator: 1/2 gauge glass Battery Level: satisfactory Door to generator was found unlocked.		4/10/2014		False	4/16/2014
FO-279563	007-GEN-002	Generator Maintenance, Monthly	John Covert-Sisung-Fuel: +3/4 Radiator: 1/4 gauge glass Oil: Full Battery Level: Satisfactory		4/10/2014		False	4/16/2014
FO-279577	090-GEN-002	Generator Maintenance, Monthly	Robert McPherson-Check all fluid levels, belts and batteries.		4/10/2014		False	4/10/2014
FO-279328	090-GEN-001	Generator Maintenance, Monthly	Robert McPherson-Check all fluid levels, check belts and crankcase heater, all good.		4/15/2014		False	4/15/2014
FO-279564	089-GEN-001	Generator Maintenance, Monthly	Darnell Smiley-Completed generator test with electricians,oil level ok ,fule at 3/4 full,anti frezze ok ,new batterys were instaled for this generator,ran unit test ok.		4/16/2014		False	4/16/2014
FO-279581	006-GEN-001	Generator Maintenance, Monthly	Dennis Paul-Completed the PM		4/17/2014		False	4/17/2014

Request				%	Requested	Open	WND	Finished
FO-279317	090-ACU-CR2	Monthly AHU Inspection Clean Room Unit 2	Robert McPherson-Change filters, adjust belt, check ops.		4/8/2014		False	4/10/2014
FO-279339	090-ACU-541B	PM INSPECT AND CLEAN COIL	Robert McPherson-This unit is not operational, needs to be repalced.		4/2/2014		False	4/7/2014
FO-279340	090-ACU-542B	PM INSPECT AND CLEAN COIL	Robert McPherson-This unit is not operational needs to be replaced.		4/2/2014		False	4/7/2014
FO-279341	090-ACU-543B	PM INSPECT AND CLEAN COIL	Robert McPherson-Clean condenser coil.		4/2/2014		False	4/7/2014
FO-280031	090-HWP-543	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease motor bearings. Check operation, all normal.		4/15/2014		False	4/16/2014
FO-280037	090-GP-541	PM - Water Booster Pump	Robert McPherson-check operation, all normal.		4/15/2014		False	4/16/2014
FO-280038	090-GP-542	PM - Water Booster Pump	Robert McPherson-check operation, all normal.		4/15/2014		False	4/16/2014
FO-280039	090-HWP-541	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings, check ops, normal.		4/15/2014		False	4/16/2014
FO-280040	090-HWP-542	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings, check ops, normal.		4/15/2014		False	4/16/2014
FO-280041	090-SSF-541	PM - Harmsco Side Stream Filter	Robert McPherson-Clean screen, check pump operation, all normal.		4/15/2014		False	4/16/2014
FO-279318	090-ACU-CR2	PM - Annual Inspection of Air Handling Unit			4/8/2014		False	
FO-279319	090-ACU-CR1	PM - Monthly AHU Inspection Clean Room Unit 1	Robert McPherson-Change filters, tighten belt, check ops.		4/8/2014		False	4/10/2014
FO-279929	090-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Robert McPherson-Grease motor bearings, change oil on gear reducer, sweep out basin, clean hot deck nozzles.		4/15/2014		False	4/23/2014
FO-279930	089-COT-002	PM - Cooling Tower, 500 - 1000 Tons	Darnell Smiley-Completed task on cooling tower,Greased motor and bearings,cleaned twr,checked belts,filled twr with water,ran all cells,reported problems with twr in work order,both chill water and condensing water loops are filled,ran chiller and all pumps and equipment.		4/15/2014		False	4/17/2014
FO-279934	096-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Darnell Smiley-All matinance has been performed Change oil in gear box to tower,check belts,cleaned inside,flush inside out,completed task.		4/15/2014		False	4/22/2014
FO-279936	090-HEX-003	PM - Heat Exchanger and Economizer	Robert McPherson-Test relief valve, check ops, all normal. Replace leaking 3/4 inch valve on expansion tank.		4/15/2014		False	4/28/2014
FO-279937	090-HEX-004	PM - Heat Exchanger and Economizer	Robert McPherson-Perform leak tests and all was normal, test relief valve, test water loop for corrsion protection, added 2.5 gallons of nitrite to loop.		4/15/2014		False	4/28/2014
FO-279991	007-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	

Request				%	Requested	Open	WND	Finished
FO-280017	089-COT-001	PM - Cooling Tower, 500 - 1000 Tons	Darnell Smiley-Finish task on maintainace for cooling tower,check,belts lube baerings,cleaned twr,filled bothcondencer,and chillwater lines,check for leaks in system,reported problems that twr has hadin a work order.Ran chiller and all pumps		4/15/2014		False	4/17/2014
FO-280036	090-COT-002	PM - Cooling Tower, 500 - 1000 Tons	Darnell Smiley-Clean sump and grease bearings.		4/15/2014		False	4/16/2014
FO-280036	090-COT-002	PM - Cooling Tower, 500 - 1000 Tons	Robert McPherson-Work with Darnell S. clean sump and grease bearings.		4/15/2014		False	4/16/2014
FO-278676	090-CHWP-001	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-New pumps are in the process of being installed.		4/1/2014		False	4/3/2014
FO-278677	090-CHWP-002	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-New pump is being installed.		4/1/2014		False	4/3/2014
FO-278678	090-CWP-003	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-New pump being installed.		4/1/2014		False	4/3/2014
FO-278679	090-CWP-004	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-New pump is being installed.		4/1/2014		False	4/3/2014
FO-278723	090-CHWP-541	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings.		4/1/2014		False	4/2/2014
FO-278724	090-CHWP-542	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings.		4/1/2014		False	4/2/2014
FO-278725	090-CWP-543	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings.		4/1/2014		False	4/2/2014
FO-278726	090-CWP-544	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease bearings.		4/1/2014		False	4/2/2014
FO-278727	090-PWP-001	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Grease Bearings.		4/1/2014		False	4/3/2014
FO-281610	096-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3	Darnell Smiley-Cleaned roof sumps removed cover strainer swept out drain area and cleaned cover strainer,all clear for draining.		4/24/2014		False	4/28/2014
FO-279945	005-ACU-002	PM - Water/Air Cooled Condenser	Dennis Paul-Completed the PM, no evidence of any leaks High Low Circuit # 1 168 93  Circuit # 2 163 93		4/15/2014		False	4/28/2014
FO-280032	090-CFP-541	PM - Chemical Feed/Metering Pump/Controller	Robert McPherson-Check operation, all normal.		4/15/2014		False	4/25/2014
FO-280033	090-CFP-542	PM - Chemical Feed/Metering Pump/Controller	Robert McPherson-Check operation, all normal.		4/15/2014		False	4/25/2014
FO-280034	090-CFP-543	PM - Chemical Feed/Metering Pump/Controller	Robert McPherson-Check operation, all normal		4/15/2014		False	4/25/2014
FO-280035	090-CTL-001	PM - Chemical Feed/Metering Pump/Controller	Robert McPherson-Check ops, all normal.		4/15/2014		False	4/25/2014
<b>E - Southeast</b>				<b>79%</b>	<b>140</b>	<b>30</b>	<b>36</b>	<b>110</b>
FO-279325	001-SSF-001	PM - Harmsco Side Stream Filter			4/4/2014		False	
FO-279326	001-SSF-002	PM - Harmsco Side Stream Filter			4/4/2014		False	
FO-279928	082-CWP-001	PM - Centrifugal Pump, over 1 H.P.			4/15/2014		False	
FO-279931	082-CHWP-006	PM - Centrifugal Pump, over 1 H.P.			4/15/2014		False	
FO-279932	082-CHWP-007	PM - Centrifugal Pump, over 1 H.P.			4/15/2014		False	
FO-279281	609-GEN-001	Generator Maintenance, Monthly	checked battery fluids heaters and belts		4/15/2014		False	4/29/2014

Request			%		Requested	Open	WND	Finished
FO-279331	637-GEN-001	Generator Maintenance, Monthly		checked fluids and belts	4/15/2014		False	4/29/2014
FO-279333	637-GEN-002	Generator Maintenance, Monthly		checked fluids and belts	4/15/2014		False	4/29/2014
FO-278684	001-CHWP-004	PM - Centrifugal Pump, over 1 H.P.			4/1/2014		False	
FO-278685	001-CHWP-005	PM - Centrifugal Pump, over 1 H.P.			4/1/2014		False	
FO-278686	001-CHWP-006	PM - Centrifugal Pump, over 1 H.P.			4/1/2014		False	
FO-278687	001-CHWP-007	PM - Centrifugal Pump, over 1 H.P.		PM UNIT ON 2/24/14	4/1/2014		False	4/2/2014
FO-278688	001-CHWP-008	PM - Centrifugal Pump, over 1 H.P.		PM UNIT ON 2/24/14 ON ANOTHER WORK ORDER.	4/1/2014	4/29/2014	False	2/24/2014
FO-278689	001-CHWP-009	PM - Centrifugal Pump, over 1 H.P.		PM UNIT ON 2/24/14 ON ANOTHER WORK ORDER.	4/1/2014	4/29/2014	False	2/24/2014
FO-278690	001-CWP-010	PM - Centrifugal Pump, over 1 H.P.		PM UNIT ON 2/6/14.	4/1/2014	4/29/2014	False	2/6/2014
FO-278691	001-CWP-011	PM - Centrifugal Pump, over 1 H.P.		PM UNIT ON ANOTHER W.O ON 2/6/14	4/1/2014	4/29/2014	False	2/6/2014
FO-278692	001-CWP-012	PM - Centrifugal Pump, over 1 H.P.		FINISHED PM ON 2/6/14 WITH A DIFFERENT W.O #.	4/1/2014	4/29/2014	False	2/6/2014
FO-279322	017-DHW-001	PM - Domestic Water Heater, Electric		Checked operation of the unit, checked heating elements and thermostat, checked relief valve, checked water temp, all OK. cleaned the unit.	4/3/2014		False	4/18/2014
FO-279323	074-DHW-001	PM - Domestic Water Heater, Gas			4/3/2014		False	
FO-279301	001-CFP-002	PM - Chemical Feed/Metering Pump/Controller		CHECK OPERATION & CLEAN AREA.	4/4/2014		False	4/16/2014
FO-279302	001-CFP-003	PM - Chemical Feed/Metering Pump/Controller		CHECK OPERATION & CLEAN AREA.	4/4/2014		False	4/16/2014
FO-279303	001-CFP-004	PM - Chemical Feed/Metering Pump/Controller		CHECK OPERATION & CLEAN AREA.	4/4/2014		False	4/16/2014
FO-279304	001-CFP-005	PM - Chemical Feed/Metering Pump/Controller		CHECK OPERATION & CLEAN AREA.	4/4/2014		False	4/16/2014
FO-280927	504-DHW-001	PM - Domestic Water Heater, Gas			4/22/2014		False	
FO-279946	071-HEX-001	PM - Heat Exchanger and Economizer	William Willard-Completed the pm task.		4/10/2014		False	4/10/2014
FO-279947	071-HEX-004	PM - Heat Exchanger and Economizer	William Willard-Completed the pm task.		4/10/2014		False	4/10/2014
FO-280005	001-AHU-001	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COILS.	4/10/2014		False	4/10/2014
FO-280006	001-AHU-001MU	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/14/2014
FO-280007	001-AHU-001O	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/10/2014
FO-280008	001-AHU-002	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/10/2014
FO-280009	001-AHU-002MU	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/14/2014
FO-280010	001-AHU-002O	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/10/2014
FO-280011	001-AHU-003MU	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/14/2014
FO-280012	001-AHU-003O	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/10/2014
FO-280013	001-AHU-004O	PM - Chilled Water Coils - Refill (Old Main)		REFILL CHW COIL.	4/10/2014		False	4/10/2014
FO-279306	071-HWP-139	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/3/2014		False	4/3/2014
FO-279307	071-HWP-140	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet		4/3/2014		False	4/3/2014

Request				%	Requested	Open	WND	Finished
FO-279308	071-HWP-141	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.		4/3/2014		False	4/3/2014
FO-279309	071-HWP-142	PM - Heat Pumps (5057 Woodward)	William Willard-The pm task has been completed per the tasking sheet pm.		4/3/2014		False	4/3/2014
FO-279310	071-HWP-143	PM - Heat Pumps (5057 Woodward)	William Willard-Task has been completed.		4/3/2014		False	4/3/2014
FO-279311	071-HWP-144	PM - Heat Pumps (5057 Woodward)	William Willard-The pm has been completed per the tasking sheet pm.		4/3/2014		False	4/4/2014
FO-279312	071-HWP-145	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.		4/3/2014		False	4/4/2014
FO-279313	071-HWP-146	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		4/3/2014		False	4/4/2014
FO-279314	071-HWP-147	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.		4/3/2014		False	4/4/2014
FO-279315	071-HWP-148	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/3/2014		False	4/4/2014
FO-279316	071-HWP-149	PM - Heat Pumps (5057 Woodward)			4/3/2014		False	4/4/2014
FO-281619	071-HUM-001	PM - Humidifier	William Willard-Completed the pm on the equipment per the tasking pm sheet.		4/23/2014		False	4/22/2014
FO-279949	071-HWP-001	PM - Heat Pumps (5057 Woodward)	William Willard-Put in a work order for the control engineer to check the reversing valve on the unit. The unit does not switch from heating to the cooling mode.		4/10/2014		False	4/10/2014
FO-279950	071-HWP-150	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists.		4/10/2014		True	4/11/2014
FO-279951	071-HWP-151	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279952	071-HWP-152	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279953	071-HWP-153	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279954	071-HWP-154	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279955	071-HWP-155	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279956	071-HWP-156	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279957	071-HWP-157	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279958	071-HWP-158	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279959	071-HWP-159	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279960	071-HWP-160	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279961	071-HWP-161	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279962	071-HWP-162	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279963	071-HWP-163	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279964	071-HWP-164	PM - Heat Pumps (5057 Woodward)			4/10/2014		True	4/11/2014
FO-279965	071-HWP-165	PM - Heat Pumps (5057 Woodward)	William Willard-I did not order material with this FO-279965		4/10/2014		True	4/11/2014
FO-279966	071-HWP-166	PM - Heat Pumps (5057 Woodward)	William Willard-unit does not exist		4/10/2014		True	4/11/2014
FO-279967	071-HWP-167	PM - Heat Pumps (5057 Woodward)	William Willard-unit no longer exist		4/10/2014		True	4/11/2014
FO-279968	071-HWP-168	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279969	071-HWP-169	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279970	071-HWP-170	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279971	071-HWP-171	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279972	071-HWP-172	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279973	071-HWP-173	PM - Heat Pumps (5057 Woodward)	William Willard-No longer exists		4/10/2014		True	4/11/2014

Request				%	Requested	Open	WND	Finished
FO-279974	071-HWP-174	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279975	071-HWP-175	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		True	4/11/2014
FO-279976	071-HWP-176	PM - Heat Pumps (5057 Woodward)	William Willard-The unit no longer exists		4/10/2014		False	4/11/2014
FO-279977	071-HWP-177	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279978	071-HWP-178	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279979	071-HWP-179	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists.		4/10/2014		True	4/11/2014
FO-279980	071-HWP-180	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279981	071-HWP-181	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279982	071-HWP-182	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279983	071-HWP-183	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279984	071-HWP-184	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279985	071-HWP-185	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279986	071-HWP-186	PM - Heat Pumps (5057 Woodward)	William Willard-The equipment no longer exists		4/10/2014		True	4/11/2014
FO-279933	022-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279935	001-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279948	071-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279989	016-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279990	499-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279992	504-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-280018	006-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-280042	637-COT-001	PM - Cooling Tower, 500 - 1000 Tons	cleaned tower lub bearings		4/15/2014		False	4/29/2014
FO-280043	068-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-281591	071-AHU-001	PM - Air Handling Unit	William Willard-Completed the pm per the tasking sheet pm.		4/24/2014		False	4/24/2014
FO-281592	071-AHU-002	PM - Air Handling Unit	William Willard-Finished the pm per the pm tasking sheet		4/24/2014		False	4/24/2014
FO-278734	082-ACU-003	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-280916	071-HWP-128	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/17/2014		False	4/18/2014
FO-280917	071-HWP-129	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet		4/17/2014		False	4/17/2014
FO-280918	071-HWP-130	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/17/2014		False	4/17/2014
FO-280919	071-HWP-131	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		4/17/2014		False	4/17/2014
FO-280920	071-HWP-132	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.		4/17/2014		False	4/17/2014

Request				%	Requested	Open	WND	Finished
FO-280921	071-HWP-133	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.		4/17/2014		False	4/17/2014
FO-280922	071-HWP-134	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		4/17/2014		False	4/18/2014
FO-280923	071-HWP-135	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.		4/17/2014		False	4/18/2014
FO-280924	071-HWP-136	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.		4/17/2014		False	4/18/2014
FO-280925	071-HWP-137	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/17/2014		False	4/18/2014
FO-280926	071-HWP-138	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.		4/17/2014		False	4/18/2014
FO-280913	016-CRS-001	PM - Condensate Return Pump			4/18/2014		False	
FO-280914	016-CRS-002	PM - Condensate Return Pump			4/18/2014		False	
FO-281618	504-GFF-001	Gas Fired Furnace			4/23/2014		False	
FO-281622	504-GFF-003	Gas Fired Furnace			4/23/2014		False	
FO-281623	504-GFF-002	Gas Fired Furnace			4/23/2014		False	
FO-281624	504-GFF-004	Gas Fired Furnace			4/23/2014		False	
FO-281593	071-HWP-117	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm		4/24/2014		False	4/25/2014
FO-281594	071-HWP-118	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		4/24/2014		False	4/25/2014
FO-281595	071-HWP-119	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.		4/24/2014		False	4/25/2014
FO-281596	071-HWP-120	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.		4/24/2014		False	4/25/2014
FO-281597	071-HWP-121	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.		4/24/2014		False	4/25/2014
FO-281598	071-HWP-122	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		4/24/2014		False	4/25/2014
FO-281599	071-HWP-123	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.		4/24/2014		False	4/25/2014
FO-281600	071-HWP-124	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/24/2014		False	4/25/2014
FO-281601	071-HWP-125	PM - Heat Pumps (5057 Woodward)	William Willard-completed the pm per the tasking pm sheet.		4/24/2014		False	4/25/2014
FO-281602	071-HWP-126	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.		4/24/2014		False	4/28/2014
FO-281603	071-HWP-127	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.		4/24/2014		False	4/28/2014
FO-281604	001-ROOF-Z2A3	PM - Roof Sumps - Zone 2, Area 3	William Willard-Finished the pm per the tasking pm sheet.		4/24/2014		False	4/28/2014
FO-281605	016-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3	William Willard-Finished cleaning the roof sumps pm per the pm tasking sheet.		4/24/2014		False	4/21/2014
FO-281606	022-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281607	023-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3			4/24/2014		False	
FO-281608	070-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3	William Willard-Finished the pm per the tasking sheet pm.		4/24/2014		False	4/28/2014

Request		%		Requested	Open	WND	Finished
FO-281609	071-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3	William Willard-Completed the pm per thepm tasking sheet.	4/24/2014		False	4/30/2014
FO-281611	189-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3		4/24/2014		False	
FO-281612	499-ROOF-Z2A3*	PM - Roof Sumps - Zone 2, Area 3		4/24/2014		False	
FO-281613	504-ROOF-Z2A3	PM - Roof Sumps - Zone 2, Area 3		4/24/2014		False	
FO-281614	001-AHU-001O	PM - Steam Valves to PreHeat Coils - Close (Old Main)	ISOLATE STEAM COILS FOR SUMMER.	4/24/2014		False	4/29/2014
FO-281615	001-AHU-002O	PM - Steam Valves to PreHeat Coils - Close (Old Main)	ISOLATE STEAM COILS FOR SUMMER.	4/24/2014		False	4/29/2014
FO-281616	001-AHU-003O	PM - Steam Valves to PreHeat Coils - Close (Old Main)	ISOLATE STEAM COILS FOR SUMMER.	4/24/2014		False	4/29/2014
FO-281617	001-AHU-004O	PM - Steam Valves to PreHeat Coils - Close (Old Main)	ISOLATE STEAM COILS FOR SUMMER.	4/24/2014		False	4/29/2014
FO-278693	001-HWP-017A	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION , LUBE & CLEAN AREA.	4/1/2014		False	4/25/2014
FO-278694	001-HWP-017B	PM - Centrifugal Pump, over 1 H.P.	CHECK OPERATION , LUBE & CLEAN AREA.	4/1/2014		False	4/25/2014
<b>E - West</b>		<b>64%</b>		<b>61</b>	<b>22</b>	<b>0</b>	<b>39</b>
FO-278733	195-GEN-001 SPARE from TechTwn	Generator Maintenance, Monthly		4/8/2014		False	
FO-278698	003-CHWP-003	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/3/2014
FO-278699	003-CHWP-004	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/3/2014
FO-278700	003-CHWP-005	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/4/2014
FO-278701	003-CHWP-006	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/7/2014
FO-278702	003-CHWP-007	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/7/2014
FO-278703	003-CHWP-008	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/8/2014
FO-278704	003-CHWP-009	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/8/2014
FO-278705	003-CHWP-010	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/9/2014
FO-278706	003-CHWP-011	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/9/2014
FO-278707	003-CHWP-L01	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/10/2014
FO-278708	003-CWP-003	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/11/2014
FO-278709	003-CWP-004	PM - Centrifugal Pump, over 1 H.P.		4/1/2014		False	4/15/2014
FO-279324	156-DHW-001	PM - Domestic Water Heater, Electric		4/3/2014		False	
FO-279305	003-HEX-001	PM - Heat Exchanger and Economizer		4/5/2014		False	4/18/2014
FO-280915	003-WSS-001	PM - Water Softener		4/20/2014		False	4/23/2014
FO-280016	156-DHW-002	PM - Domestic Water Heater, Electric		4/10/2014		False	
FO-275588	080-SAF-02A	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/7/2014
FO-275589	080-SAF-01A	PM - Air Handling Unit (ANNUAL)		4/1/2014		False	
FO-275590	080-SAF-018	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/21/2014
FO-275591	080-SAF-017	PM - Air Handling Unit (ANNUAL)	performed p.m. task list.	4/1/2014		False	4/21/2014
FO-275592	080-SAF-016	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/21/2014
FO-275593	080-SAF-015	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/9/2014
FO-275594	080-SAF-014	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/9/2014
FO-275595	080-SAF-013	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/9/2014
FO-275596	080-SAF-012	PM - Air Handling Unit (ANNUAL)		4/1/2014		False	4/11/2014
FO-275597	080-SAF-011	PM - Air Handling Unit (ANNUAL)	performed p.m. task list	4/1/2014		False	4/18/2014

Request			%		Requested	Open	WND	Finished
FO-275598	080-SAF-010	PM - Air Handling Unit (ANNUAL)		performed task p.m. list	4/1/2014		False	4/18/2014
FO-275599	080-SAF-009	PM - Air Handling Unit (ANNUAL)		performed p.m. task list	4/1/2014		False	4/18/2014
FO-275600	080-SAF-008	PM - Air Handling Unit (ANNUAL)		performed p.m. task list	4/1/2014		False	4/21/2014
FO-275601	080-SAF-007	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/22/2014
FO-275602	080-SAF-006	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/22/2014
FO-275603	080-SAF-005	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/22/2014
FO-275604	080-SAF-004	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/22/2014
FO-275605	080-SAF-003	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/23/2014
FO-275606	080-SAF-002	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/23/2014
FO-275607	080-SAF-001	PM - Air Handling Unit (ANNUAL)		worked off the p.m. task list.	4/1/2014		False	4/23/2014
FO-279987	166-ACU-001	PM - Clean MEB AC unit Condenser			4/15/2014		False	
FO-279988	166-ACU-002	PM - Clean MEB AC unit Condenser			4/15/2014		False	
FO-279993	169-AHU-001	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279994	169-AHU-002	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279995	169-AHU-003	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279996	169-AHU-004	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279997	169-AHU-005	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279998	169-AHU-006	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-279999	169-AHU-007	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-280000	169-AHU-008	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-280003	166-ACU-001	PM - Clean MEB AC unit Condenser			4/15/2014		False	
FO-280004	166-ACU-002	PM - Clean MEB AC unit Condenser			4/15/2014		False	
FO-279938	155-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-279944	003-COT-001	PM - Cooling Tower, 500 - 1000 Tons			4/15/2014		False	
FO-280001	167-AHU-001	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-280002	167-AHU-002	PM - Water/Air Cooled Condenser			4/15/2014		False	
FO-280015	080-COT-001	PM - Cooling Tower, 500 - 1000 Tons		compelted p.m. task list	4/15/2014		False	4/15/2014
FO-278710	167-AHU-001	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-278711	167-AHU-002	PM - Water/Air Cooled Condenser			4/1/2014		False	
FO-279939	003-CRP-002	PM - Centrifugal Pump, over 1 H.P.			4/13/2014		False	4/21/2014
FO-279940	003-BFP-001	PM - Centrifugal Pump, over 1 H.P.			4/13/2014		False	4/21/2014
FO-279941	003-BFP-002	PM - Centrifugal Pump, over 1 H.P.			4/13/2014		False	4/21/2014
FO-279942	003-BFP-003	PM - Centrifugal Pump, over 1 H.P.			4/13/2014		False	4/22/2014
FO-279943	003-TRP-002	PM - Centrifugal Pump, over 1 H.P.			4/13/2014		False	4/22/2014
<b>Trades</b>			<b>100%</b>		<b>33</b>	<b>0</b>	<b>0</b>	<b>33</b>

## Trades

**100%**

**33**

**0**

**0**

**33**

## T - Electrician

**100%**

**32**

**0**

**0**

**32**

FO-279553	608-GEN-001	Generator Test Friday 4/4/2014 @ 7:15 AM.. Finished 4/7/2014LT			4/4/2014		False	4/4/2014
FO-279543	193-GEN-001	Generator Test Friday 4/4/2014 @ 2:15.. Finished 4/7/2014LT			4/4/2014		False	4/4/2014
FO-279559	193-GEN-002	Generator Test Friday 4/4/2014 @ 2:15 PM.. Finished 4/7/2014LT			4/4/2014		False	4/4/2014
FO-279560	193-GEN-003	Generator Test Friday 4/4/2014 @ 2:15 PM.. Finished 4/7/2014LT			4/4/2014		False	4/4/2014

Request			%	Requested	Open	WND	Finished
FO-279561	193-GEN-004	Generator Test Friday 4/4/2014 @ 7:15 PM.. Finished 4/7/2014LT		4/4/2014		False	4/4/2014
FO-278712	501-GEN-001	Generator Test Tuesday 4/8/2014 @ 1PM. Finished 4/11/2014LT		4/8/2014		False	4/7/2014
FO-279557	195-GEN-001 SPARE from TechTwn	Generator Test Tuesday 4/8/2014 @ 7:15 AM. Finished 4/11/2014LT		4/8/2014		False	4/7/2014
FO-279334	507-GEN-001	Generator Test Wednesday 4/9/2014 @ 1PM. Finished 4/11/2014LT		4/9/2014		False	4/9/2014
FO-279537	007-GEN-001	Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/11/2014LT		4/10/2014		False	4/10/2014
FO-279538	007-GEN-002	Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/11/2014LT		4/10/2014		False	4/10/2014
FO-279554	090-GEN-002	Generator Test Thursday 4/10/2014 @ 9:30 AM. Finished 4/11/2014LT		4/10/2014		False	4/10/2014
FO-279556	048-GEN-001	Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT		4/11/2014		False	4/11/2014
FO-279550	612-GEN-001	Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT		4/11/2014		False	4/11/2014
FO-279551	612-GEN-002	Generator Test Friday 4/11/2014 @ 7:15 AM. Finished 4/14/2014LT		4/11/2014		False	4/11/2014
FO-279329	090-GEN-001	Generator Test Thursday 4/10/2014 @ 7:15 AM. Finished 4/18/2014LT		4/15/2014		False	4/16/2014
FO-279336	203-GEN-001	Generator Test Tuesday 4/15/2014 @ 9:15 AM. Finished 4/18/2014LT		4/15/2014		False	4/16/2014
FO-279327	609-GEN-001	Generator Test Tuesday 4/15/2014 @ 7:15 AM. Finished 4/18/2014LT		4/15/2014		False	4/16/2014
FO-279330	637-GEN-001	Generator Test Tuesday 4/15/2014 @ 8:15 AM. Finished 4/18/2014LT		4/15/2014		False	4/16/2014
FO-279332	637-GEN-002	Generator TestTuesday 4/15/2014 @ 8:15 AM. Finished 4/18/2014LT		4/15/2014		False	4/16/2014
FO-279552	536-GEN-001	Generator Test Wednesday 4/16/2014 @ 7:15 AM. Finished 4/18/2014LT		4/16/2014		False	4/17/2014
FO-279539	089-GEN-001	Generator Test Wednesday 4/16/2014 @ 10AM. Finished 4/18/2014LT		4/16/2014		False	4/16/2014
FO-279555	527-GEN-001	Generator Test Thursday 4/17/2014 @ 7:15 AM. Finished 4/18/2014LT		4/17/2014		False	4/17/2014
FO-279558	006-GEN-001	Generator Test Thursday 4/17/2014 @ 7:15 AM. Finished 4/18/2014LT		4/17/2014		False	4/17/2014
FO-279544	104-GEN-001	Generator Test Tuesday 4/22/2014 @ 10AM.Finished 4/23/2014LT		4/22/2014		False	4/22/2014
FO-279545	127-GEN-001	Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT		4/22/2014		False	4/22/2014
FO-279546	127-GEN-002	Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT		4/22/2014		False	4/22/2014
FO-279547	127-GEN-003	Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT		4/22/2014		False	4/22/2014
FO-279548	127-GEN-004	Generator Test Tuesday 4/22/2014 @ 8AM.Finished 4/23/2014LT		4/22/2014		False	4/22/2014

Request			%	Requested		Open	WND	Finished
FO-279540	066-GEN-001	Generator Test Wednesday 4/23/2014 @ 7:15 AM. Finished 4/23/2014LT		4/23/2014			False	4/23/2014
FO-279549	130-GEN-001	Generator Test Wednesday 4/23/2014 @ 7:15 AM. Finished 4/23/2014LT		4/23/2014			False	4/23/2014
FO-279541	611-GEN-001	Generator Test Friday 4/25/2014 @ 7:15 AM. Finished 4/29/2014LT		4/25/2014			False	4/25/2014
FO-279542	629-GEN-001	Generator Test Friday 4/25/2014 @ 10AM. Finished 4/29/2014LT		4/25/2014			False	4/25/2014
<b>T - Plumber</b>			<b>100%</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>
FO-281483	089-VPS-001	PM Vacuum pump system. Finished 4/4/13LT Changed to low, Laborer didn't recieve work order till 7/22/2013. Open to Plumbers: Replace Flow Switch, see Elecricians Pat, and Ken. ,,,,,,,,,, MM/ 4-14-14 ,,,,,,,,,, DUE 4-28-14	see results for fo#16406	4/14/2014			False	4/14/2014
<b>Report Total:</b>				<b>895</b>	<b>273</b>	<b>73</b>	<b>568</b>	<b>63%</b>