

DRAFT Facilities Operations PM Analysis from 4/1/2015 through 4/30/2015

Requested Finished Open WND								% Finished
Engineering		719	700	7	12			97%
E - Auxiliary		30	29	1	0			97%
FO-311609	Finished	104-GEN-001	4/28/2015	4/29/2015	False	Generator Maintenance, Monthly		
FO-311611	Finished	127-GEN-001	4/28/2015	4/29/2015	False	Generator Maintenance, Monthly		
FO-311613	Finished	127-GEN-002	4/28/2015	4/29/2015	False	Generator Maintenance, Monthly		
FO-311615	Finished	127-GEN-003	4/28/2015	4/29/2015	False	Generator Maintenance, Monthly		
FO-311617	Finished	127-GEN-004	4/28/2015	4/29/2015	False	Generator Maintenance, Monthly		
FO-311629	Finished	501-GEN-001	4/14/2015	4/15/2015	False	Generator Maintenance, Monthly		
FO-311631	Finished	507-GEN-001	4/8/2015	4/9/2015	False	Generator Maintenance, Monthly		
FO-311639	Finished	536-GEN-001	4/15/2015	4/15/2015	False	Generator Maintenance, Monthly		
FO-312292	Finished	034-AHU-001	4/1/2015	4/29/2015	False	0.50	PM - Air Handling Unit	
AHU #1 is out of service. New motor and motor controls are being installed during renovation project.								
FO-312293	Finished	034-AHU-002	4/1/2015	4/29/2015	False	0.50	PM - Air Handling Unit	
AHU #2 is under construction warranty. Changed filters and checked units operation.								
FO-312294	Finished	034-AHU-003	4/1/2015	4/29/2015	False	1.00	PM - Air Handling Unit	
Lubed motor, bearings and dampers. checked belts and changed filters.								
FO-312295	Finished	034-AHU-004	4/1/2015	4/29/2015	False	1.00	PM - Air Handling Unit	
Checked damper operation, lubed motor and bearings, changed filters.								
FO-312296	Finished	034-AHU-005	4/1/2015	4/29/2015	False	1.00	PM - Air Handling Unit	
Lubed motor, bearings and dampers. Changed filters and checked unit's operation.								
FO-312303	Finished	104-MUA-001	4/1/2015	5/1/2015	False	PM - Air Handling Unit		
FO-312304	Finished	104-MUA-002	4/1/2015	5/1/2015	False	PM - Air Handling Unit		
FO-312305	Finished	115-MUA-001	4/1/2015	5/1/2015	False	PM - Air Handling Unit		
FO-312306	Finished	115-MUA-002	4/1/2015	5/1/2015	False	PM - Air Handling Unit		
FO-312307	Finished	115-MUA-003	4/1/2015	5/1/2015	False	PM - Air Handling Unit		
FO-312308	Finished	992-ES-001*	4/6/2015	4/10/2015	False	PM - Emergency Shower/Eyewash Station		
FO-312309	Finished	127-GCP-001	4/1/2015	5/1/2015	False	PM - Centrifugal Pump, over 1 H.P.		
FO-312310	Finished	127-GCP-002	4/1/2015	5/1/2015	False	PM - Centrifugal Pump, over 1 H.P.		
FO-312316	Finished	134-FP-001	4/1/2015	4/1/2015	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test	
Silenced alarm system and drained sprinkler system until both jockey and main pumps started. Closed valve to allow system to refill and placed fire panel back into normal operation.								
FO-312317	Finished	127-FP-001	4/1/2015	5/1/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test		
FO-312318	Finished	115-FP-001	4/1/2015	5/1/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test		
FO-312319	Finished	104-FP-001	4/1/2015	5/1/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test		
FO-312320	Finished	507-FP-001	4/1/2015	5/1/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test		
FO-312852	Finished	992-ES-001*	4/13/2015	4/17/2015	False	PM - Emergency Shower/Eyewash Station		
FO-313697	Finished	992-ES-001*	4/20/2015	4/24/2015	False	0.25	PM - Emergency Shower/Eyewash Station	
Tested unit's operation.								
FO-314216	Finished	992-ES-001*	4/27/2015	4/29/2015	False	0.25	PM - Emergency Shower/Eyewash Station	
Tested unit's operation and cleaned area.								
H-51683	Completed	134	4/22/2015		False	test		

E - Command Center**4****0****1****3****0%**

FO-315264	Completed	203-ACU-001	4/1/2015		True	Clean condenser coils
FO-315265	Completed	203-ACU-002	4/1/2015		True	Clean condenser coils
FO-315266	Completed	203-ACU-003	4/1/2015		True	Clean condenser coils
FO-315526	Completed	033-HVU-003	4/24/2015		False	PM - Forced Air Furnace (Jacob House) - Summer a/c coil drain line trap plugged

This work order was created for Command Center IN ERROR. Work order closed.

E - MedPharm**54****52****2****0****96%**

FO-311604	Finished	611-GEN-001	4/24/2015	4/30/2015	False		Generator Maintenance, Monthly
FO-311606	Finished	629-GEN-001	4/24/2015	5/5/2015	False	1.50	Generator Maintenance, Monthly
FO-311625	Finished	612-GEN-001	4/10/2015	4/30/2015	False		Generator Maintenance, Monthly
FO-311627	Finished	612-GEN-002	4/10/2015	4/30/2015	False		Generator Maintenance, Monthly
FO-311642	Finished	609-GEN-001	4/21/2015	4/27/2015	False		Generator Maintenance, Monthly
checked fluids and battery							
FO-312079	Finished	609-DHW-001	4/1/2015	4/16/2015	False		PM - Domestic Water Heater, Steam
inspected							
FO-312080	Finished	609-DHW-002	4/1/2015	4/16/2015	False		PM - Domestic Water Heater, Steam
inspected							
FO-312081	Finished	609-SP-001	4/1/2015	4/16/2015	False		PM - Sump Pump
inspected and greased							
FO-312082	Finished	609-SP-002	4/1/2015	4/16/2015	False		PM - Sump Pump
inspected and greased							
FO-312083	Finished	603-DHW-001	4/1/2015	4/6/2015	False	1.00	PM - Domestic Water Heater, Steam
checked pump motors/cleaned							
checked relief/ blewdown unit							
FO-312084	Finished	603-DHW-002	4/1/2015	4/14/2015	False	1.00	PM - Domestic Water Heater, Steam
cleaned/ checked pumps / relief							
blewdown							
FO-312085	Created By PM Schedule	629-DWBP-001	4/1/2015		False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-312086	Created By PM Schedule	629-DWBP-002	4/1/2015		False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-312087	Finished	612-EXF-062	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312088	Finished	612-EXF-063	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312089	Finished	612-EXF-064	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312090	Finished	612-EXF-065	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312091	Finished	612-EXF-066	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312092	Finished	612-EXF-067	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312093	Finished	612-EXF-068	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312094	Finished	612-EXF-069	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312095	Finished	612-EXF-070	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312096	Finished	612-EXF-071	4/1/2015	4/21/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312097	Finished	612-EXF-072	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312098	Finished	612-EXF-073	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312099	Finished	612-EXF-074	4/1/2015	5/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312100	Finished	612-EXF-075	4/1/2015	5/29/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312101	Finished	612-EXF-076	4/1/2015	5/22/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-312102	Finished	612-EXF-077	4/1/2015	4/21/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312103	Finished	612-EXF-078	4/1/2015	4/21/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312104	Finished	612-EXF-079	4/1/2015	4/17/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312105	Finished	612-EXF-080	4/1/2015	4/17/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312106	Finished	612-EXF-081	4/1/2015	4/17/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312107	Finished	612-EXF-082	4/1/2015	4/23/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312108	Finished	612-EXF-083	4/1/2015	4/23/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312109	Finished	612-EXF-084	4/1/2015	4/24/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312110	Finished	612-EXF-085	4/1/2015	4/24/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312111	Finished	612-EXF-086	4/1/2015	4/24/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312112	Finished	612-EXF-087	4/1/2015	4/27/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312113	Finished	612-EXF-088	4/1/2015	4/28/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312114	Finished	612-EXF-090	4/1/2015	4/27/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312115	Finished	612-EXF-091	4/1/2015	4/27/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312116	Finished	612-EXF-093	4/1/2015	4/27/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312117	Finished	612-EXF-094	4/1/2015	4/28/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312118	Finished	612-EXF-095	4/1/2015	4/28/2015	False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312119	Finished	612-EXF-096	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312120	Finished	612-EXF-098	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312121	Finished	612-EXF-6345	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312122	Finished	612-EXF-8319	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-312123	Finished	612-WSS-001	4/1/2015	4/30/2015	False	2.00	PM - Water Softener
FO-312124	Finished	603-DHW-003	4/1/2015	4/17/2015	False	2.00	PM - Domestic Water Heater, Steam

couldn't repair steam regulator
sent to FITTERS FO-265399

FO-314206	Finished	612-CRP-001	4/25/2015	5/7/2015	False	1.00	PM - Condensate Return Pump
FO-314207	Finished	612-CRP-002	4/25/2015	5/7/2015	False	1.00	PM - Condensate Return Pump
FO-314208	Finished	612-CRP-003A	4/25/2015	5/7/2015	False	1.00	PM - Condensate Return Pump

E - North **57** **56** **1** **0** **98%**

FO-311009	Finished	130-AHU-001	4/1/2015	4/1/2015	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-311533	Finished	130-AHU-004	4/1/2015	4/3/2015	False	2.00	Replace PRE-filters
FO-311534	Finished	130-AHU-003	4/1/2015	4/1/2015	False	1.00	Replace PRE-filters
FO-311535	Finished	130-AHU-002	4/1/2015	4/1/2015	False	1.00	Replace PRE-filters
FO-311536	Finished	130-AHU-001	4/1/2015	4/1/2015	False	1.50	Replace PRE-filters
FO-311623	Finished	130-GEN-001	4/22/2015	4/22/2015	False	3.00	Generator Maintenance, Monthly
FO-311644	Finished	048-GEN-001	4/10/2015	4/17/2015	False	0.65	Generator Maintenance, Monthly
FO-312125	Finished	026-CFP-001	4/1/2015	4/17/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-312126	Finished	026-SP-001	4/1/2015	3/31/2015	False	0.50	PM - Sump Pump
FO-312127	Finished	026-SP-002	4/1/2015	3/31/2015	False	0.50	PM - Sump Pump
FO-312128	Finished	050-SP-001	4/1/2015	3/25/2015	False	1.00	PM - Sump Pump
FO-312129	Finished	050-SP-002	4/1/2015	3/25/2015	False	1.00	PM - Sump Pump
FO-312130	Finished	038-SP-001	4/1/2015	4/9/2015	False	1.00	PM - Sump Pump

Greased bearings checked pump functions.

Requested Finished Open WND

% Finished

FO-312131	Finished	038-SP-002	4/1/2015	4/9/2015	False	2.00	PM - Sump Pump
Greased bearings checked pump function.							
FO-312132	Finished	039-SP-001	4/1/2015	4/21/2015	False	1.00	PM - Sump Pump
Greased any necessary components, checked pump operation.							
FO-312133	Finished	039-SP-002	4/1/2015	4/21/2015	False	1.00	PM - Sump Pump
Greased any necessary components, checked pump operation.							
FO-312134	Finished	039-SP-003	4/1/2015	4/21/2015	False	1.00	PM - Sump Pump
Greased any necessary components checked pump operation.							
FO-312135	Finished	039-SP-004	4/1/2015	4/23/2015	False	1.00	PM - Sump Pump
Greased any necessary components checked pump operation.							
FO-312136	Finished	039-SP-005	4/1/2015	4/23/2015	False	1.00	PM - Sump Pump
Greased any necessary components, checked pump operation.							
FO-312137	Finished	039-SP-006	4/1/2015	4/21/2015	False	1.00	PM - Sump Pump
Greased any bearings, checked pump operation.							
FO-312138	Finished	042-SP-001	4/1/2015	4/24/2015	False	1.00	PM - Sump Pump
Checked equipment operation, added oil to lubricator, put grease in grease cup.							
FO-312139	Finished	042-SP-002	4/1/2015	4/24/2015	False	1.00	PM - Sump Pump
Checked pump operation, lubricated pump parts.							
FO-312140	Finished	043-SP-001	4/1/2015	4/28/2015	False	0.50	PM - Sump Pump
Greased bearings, checked pump operation.							
FO-312141	Finished	043-SP-002	4/1/2015	4/28/2015	False	0.50	PM - Sump Pump
Greased bearings checked pump operation.							
FO-312142	Finished	026-CFP-002	4/1/2015	4/13/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-312143	Finished	026-CFP-003	4/1/2015	4/13/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-312144	Finished	026-CFP-004	4/1/2015	4/13/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-312145	Finished	033-HVU-001	4/3/2015	4/24/2015	False	0.75	PM - Forced Air Furnace (Jacob House) - Summer
FO-312146	Finished	033-HVU-002	4/3/2015	4/24/2015	False	0.75	PM - Forced Air Furnace (Jacob House) - Summer
FO-312147	Finished	033-HVU-003	4/3/2015	4/24/2015	False	1.00	PM - Forced Air Furnace (Jacob House) - Summer
FO-312148	Finished	130-DHW-001	4/1/2015	3/25/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-312149	Finished	046-COT-001	4/1/2015	4/1/2015	False	1.50	PM - Cooling Tower Start-up
FO-312150	Finished	026-ACU-014	4/1/2015	4/9/2015	False	1.50	Replace PRE-filters
FO-312151	Finished	026-ACU-013	4/1/2015	4/6/2015	False	0.50	Replace PRE-filters
FO-312152	Finished	026-ACU-012	4/1/2015	4/9/2015	False	0.75	Replace PRE-filters
FO-312153	Finished	026-ACU-011	4/1/2015	4/6/2015	False	0.50	Replace PRE-filters
FO-312154	Finished	026-ACU-010	4/1/2015	4/6/2015	False	0.50	Replace PRE-filters
FO-312155	Finished	026-ACU-009	4/1/2015	4/9/2015	False	0.75	Replace PRE-filters
FO-312156	Finished	026-ACU-008	4/1/2015	4/9/2015	False	0.75	Replace PRE-filters
FO-312157	Finished	026-ACU-007	4/1/2015	4/6/2015	False	0.75	Replace PRE-filters
FO-312158	Finished	026-ACU-006	4/1/2015	4/6/2015	False	0.75	Replace PRE-filters
cleaned filters							
FO-312819	Finished	25-ROOF-Z2A3*	4/1/2015	4/10/2015	False	0.75	PM - Roof Sumps - Zone 2, Area 3
FO-312820	Finished	26-ROOF-Z2A3'	4/1/2015	4/7/2015	False	0.75	PM - Roof Sumps - Zone 2, Area 3
FO-312821	Finished	27-ROOF-Z2A3'	4/1/2015	4/17/2015	False	0.50	PM - Roof Sumps - Zone 2, Area 3
FO-312822	Finished	036-ROOF-Z2A3	4/1/2015	4/7/2015	False	0.50	PM - Roof Sumps - Zone 2, Area 3

Requested Finished Open WND

% Finished

FO-312823	Finished	138-ROOF-Z2A3'	4/1/2015	4/23/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleared any debris from roof sumps.							
FO-312824	Finished	139-ROOF-Z2A3'	4/1/2015	4/28/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Checked and cleaned roof sumps of debris.							
FO-312825	Finished	140-ROOF-Z2A3'	4/1/2015	4/28/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
Checked and cleaned roof sumps of debris.							
FO-312826	Finished	142-ROOF-Z2A3'	4/1/2015	4/24/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleared roof sumps of any debris.							
FO-312827	Finished	143-ROOF-Z2A3'	4/1/2015	4/28/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Checked and cleaned roof sumps of debris.							
FO-313676	Finished	049-CFP-002	4/15/2015	4/20/2015	False	0.65	PM - Chemical Feed/Metering Pump/Controller
FO-313677	Finished	049-CFP-003	4/15/2015	4/20/2015	False	0.65	PM - Chemical Feed/Metering Pump/Controller
FO-313678	Finished	049-CFP-004	4/15/2015	4/17/2015	False	0.65	PM - Chemical Feed/Metering Pump/Controller
FO-313679	Finished	043-AHU-INT	4/15/2015	4/28/2015	False	0.50	PM - Outside/Fresh Air Intake Screens
Cleaned dead leaves from screen.							
FO-313680	Finished	043-CRS-001	4/15/2015	4/28/2015	False	0.50	PM - Condensate Return Pump
Checked condensate pump for operation.							
FO-313681	Finished	043-CRS-002	4/15/2015	4/28/2015	False	0.50	PM - Condensate Return Pump
Checked condensate pump for operation.							
FO-315525	Completed	033-HVU-003	4/24/2015		False		PM - Forced Air Furnace (Jacob House) - Summer electronic air filter not working, door was damaged previously
This work order was created and assigned to Command IN ERROR. Work order closed.							

E - Northeast

61

61

0

0

100%

FO-308653	Finished	511-BFAH-001	4/1/2015	4/22/2015	False	1.00	Replace PRE-filters
check operation of fan dampers coils valves							
FO-308654	Finished	511-AHU-206	4/1/2015	4/22/2015	False	1.00	Replace PRE-filters
changed filter checked operation of fan							
FO-308655	Finished	511-AHU-205	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308656	Finished	511-AHU-204	4/1/2015	4/8/2015	False		Replace PRE-filters
changed filters checked operation							
FO-308657	Finished	511-AHU-203	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308658	Finished	511-AHU-202	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308659	Finished	511-AHU-201	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308660	Finished	511-AHU-007	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308661	Finished	511-AHU-006	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308662	Finished	511-AHU-005	4/1/2015	4/8/2015	False		Replace PRE-filters
changed filters checked operation							
FO-308663	Finished	511-AHU-004	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							

Requested Finished Open WND

% Finished

FO-308664	Finished	511-AHU-003	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308665	Finished	511-AHU-002	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-308666	Finished	511-AHU-001	4/1/2015	4/8/2015	False	1.00	Replace PRE-filters
changed filters checked operation							
FO-311601	Finished	066-GEN-001	4/22/2015	4/23/2015	False	1.50	Generator Maintenance, Monthly
FO-311633	Finished	203-GEN-001	4/21/2015	4/7/2015	False	1.00	Generator Maintenance, Monthly
FO-311641	Finished	527-GEN-001	4/16/2015	4/16/2015	False	1.50	Generator Maintenance, Monthly
checked fluid levels louvers battery							
FO-311645	Finished	193-GEN-001	4/3/2015	4/7/2015	False	1.00	Generator Maintenance, Monthly
FO-311651	Finished	193-GEN-002	4/3/2015	4/6/2015	False	1.00	Generator Maintenance, Monthly
FO-311653	Finished	193-GEN-003	4/3/2015	4/6/2015	False	1.00	Generator Maintenance, Monthly
FO-311655	Finished	193-GEN-004	4/3/2015	4/6/2015	False	1.00	Generator Maintenance, Monthly
FO-311659	Finished	060-GEN-001A	4/23/2015	4/28/2015	False	0.50	Generator Maintenance, Monthly
FO-311661	Finished	060-GEN-001B	4/23/2015	4/28/2015	False	0.50	Generator Maintenance, Monthly
FO-312159	Finished	062-ACU-001	4/1/2015	5/11/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312160	Finished	062-ACU-002	4/1/2015	5/11/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312161	Finished	060-ACU-007	4/1/2015	4/14/2015	False	2.00	PM - Fan Coil/HV/AC Unit
FO-312162	Finished	060-ACU-008	4/1/2015	4/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312163	Finished	060-ACU-009	4/1/2015	5/22/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312164	Finished	060-ACU-010	4/1/2015	4/21/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312165	Finished	060-ACU-011	4/1/2015	4/22/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312166	Finished	060-ACU-012	4/1/2015	4/22/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312167	Finished	060-ACU-013	4/1/2015	4/23/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312168	Finished	060-ACU-014	4/1/2015	4/23/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-312169	Finished	060-ACU-015	4/1/2015	4/27/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-312170	Finished	060-ACU-016	4/1/2015	4/27/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-312171	Finished	060-ACU-017	4/1/2015	4/27/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-312172	Finished	060-ACU-018	4/1/2015	4/20/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312173	Finished	060-ACU-019	4/1/2015	4/27/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312174	Finished	065-ACU-001	4/1/2015	4/21/2015	False	2.00	PM - Water/Air Cooled Condenser
FO-312175	Finished	065-ACU-002	4/1/2015	4/21/2015	False	2.00	PM - Water/Air Cooled Condenser
FO-312176	Finished	065-ACU-003	4/1/2015	4/20/2015	False	2.00	PM - Water/Air Cooled Condenser
FO-312177	Finished	065-ACU-005	4/1/2015	4/20/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312178	Finished	065-ACU-007	4/1/2015	4/20/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312179	Finished	065-ACU-008	4/1/2015	4/20/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312180	Finished	065-ACU-009	4/1/2015	4/20/2015	False	0.50	PM - Water/Air Cooled Condenser
FO-312181	Finished	065-ACU-010	4/1/2015	4/20/2015	False	0.25	PM - Water/Air Cooled Condenser
FO-312182	Finished	066-ACU-001	4/1/2015	4/21/2015	False	1.00	PM - Water/Air Cooled Condenser
FO-312183	Finished	066-ACU-002	4/1/2015	4/21/2015	False	1.50	PM - Water/Air Cooled Condenser
FO-312184	Finished	066-ACU-003	4/1/2015	4/21/2015	False	1.50	PM - Water/Air Cooled Condenser
FO-312185	Finished	067-ACU-001	4/1/2015	4/21/2015	False	0.25	PM - Water/Air Cooled Condenser
FO-312186	Finished	067-ACU-002	4/1/2015	4/22/2015	False	2.00	PM - Water/Air Cooled Condenser

Requested Finished Open WND

% Finished

FO-312187	Finished	510-ACU-001	4/1/2015	5/8/2015	False	2.00	PM - Water/Air Cooled Condenser
cleaned condenser							
FO-312188	Finished	065-AIR-001	4/1/2015	4/17/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-312189	Finished	067-AIR-001	4/1/2015	4/17/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-312190	Finished	509-ACU-001	4/1/2015	3/25/2015	False	1.00	PM - Water/Air Cooled Condenser

This unit was replaced late last fall and was replaced with to 40 ton unit with water cooled plate type condensers. the mfg. suggests no type of cleaning available, replacement only. Recommend removal of this P.M. from the system.

FO-312191	Finished	509-ACU-002	4/1/2015	3/25/2015	False	1.00	PM - Water/Air Cooled Condenser
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

This unit was replaced late last year and has not been commissioned. The condenser for this unit is a water cooled plate type, the mfg. does not recommend cleaning only replacement when fouled. Recommend this item be removed from the P.M. schedule.

FO-312192	Finished	062-FCU-003	4/1/2015	4/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312193	Finished	062-FCU-002	4/1/2015	4/9/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312194	Finished	062-FCU-001	4/1/2015	4/9/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-312195	Finished	062-FCU-004	4/1/2015	4/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-314209	Finished	064-DHW-001	4/24/2015	4/17/2015	False	1.00	PM - Domestic Water Heater, Gas

E - Preventative Maintenance	324	314	1	9			97%
-------------------------------------	------------	------------	----------	----------	--	--	------------

FO-307357	Finished	603-AHU-009	4/1/2015	4/25/2015	False	3.00	Replace PRE-filters
FO-307358	Finished	603-AHU-008	4/1/2015	4/16/2015	False	3.00	Replace PRE-filters
FO-307359	Finished	603-AHU-007	4/1/2015	4/16/2015	False	3.00	Replace PRE-filters
FO-307360	Finished	603-AHU-006	4/4/2015	4/25/2015	False	3.00	Replace PRE-filters
FO-307361	Finished	612-AHU-014	4/1/2015	4/22/2015	False	3.00	Replace PRE-filters
FO-307362	Finished	612-AHU-013	4/1/2015	4/15/2015	False	4.00	Replace PRE-filters
FO-307363	Finished	612-AHU-012	4/1/2015	4/17/2015	False	3.00	Replace PRE-filters
FO-307364	Finished	612-AHU-011	4/1/2015	4/17/2015	False	3.00	Replace PRE-filters
FO-307365	Finished	612-AHU-010	4/1/2015	4/21/2015	False	3.00	Replace PRE-filters
FO-307366	Finished	612-AHU-009	4/1/2015	4/21/2015	False	3.00	Replace PRE-filters
FO-307367	Finished	612-AHU-008	4/1/2015	4/10/2015	False	5.00	Replace PRE-filters
FO-307368	Finished	612-AHU-007	4/1/2015	4/15/2015	False	4.00	Replace PRE-filters
FO-307374	Finished	612-AHU-003	4/1/2015	4/23/2015	False	3.00	Replace PRE-filters
FO-307375	Finished	612-AHU-002	4/1/2015	4/23/2015	False	3.00	Replace PRE-filters
FO-307376	Finished	612-AHU-001	4/1/2015	4/24/2015	False	4.00	Replace PRE-filters
FO-307404	Finished	167-AHU-002	4/1/2015	4/7/2015	False	2.50	Replace PRE-filters
FO-307405	Finished	167-AHU-001	4/1/2015	4/7/2015	False	2.50	Replace PRE-filters
FO-307406	Finished	166-AHU-002	4/1/2015	4/2/2015	False	2.50	Replace PRE-filters
FO-307407	Finished	166-AHU-001	4/1/2015	4/2/2015	False	2.50	Replace PRE-filters
FO-307408	Finished	169-AHU-008	4/1/2015	4/16/2015	False	1.50	Replace PRE-filters
FO-307409	Finished	169-AHU-007	4/1/2015	4/17/2015	False	1.50	Replace PRE-filters
FO-307410	Finished	169-AHU-006	4/1/2015	4/17/2015	False	1.50	Replace PRE-filters
FO-307411	Finished	169-AHU-005	4/1/2015	4/21/2015	False	1.50	Replace PRE-filters
FO-307412	Finished	169-AHU-004	4/1/2015	4/21/2015	False	1.50	Replace PRE-filters
FO-307413	Finished	169-AHU-003	4/1/2015	4/21/2015	False	1.50	Replace PRE-filters
FO-307414	Finished	169-AHU-002	4/1/2015	4/21/2015	False	1.50	Replace PRE-filters
FO-307415	Finished	169-AHU-001	4/1/2015	4/21/2015	False	1.50	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-307486	Finished	155-AHU-004	4/1/2015	4/25/2015	False	3.00	Replace PRE-filters
FO-307487	Finished	155-AHU-003	4/1/2015	4/25/2015	False	3.00	Replace PRE-filters
FO-307488	Finished	155-AHU-002	4/1/2015	4/24/2015	False	3.00	Replace PRE-filters
FO-307489	Finished	155-AHU-001	4/1/2015	4/23/2015	False	3.00	Replace PRE-filters
FO-307490	Finished	612-HVU-001	4/1/2015	4/22/2015	False	3.00	Replace PRE-filters
FO-308355	Completed	130-EXF-001	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308356	Completed	130-EXF-002	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308357	Completed	130-EXF-003	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308358	Completed	130-EXF-004	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308359	Finished	090-EXF-001A	4/1/2015	4/20/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308360	Finished	090-EXF-002A	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308361	Finished	090-EXF-003A	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308362	Finished	090-EXF-004A	4/1/2015	4/23/2015	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308363	Finished	090-EXF-005A	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308364	Finished	090-EXF-006A	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308365	Finished	090-EXF-007A	4/1/2015	4/1/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308366	Finished	090-EXF-008A	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308367	Finished	090-EXF-009A	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308368	Finished	090-EXF-010A	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308369	Finished	090-EXF-011A	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308376	Finished	193-FCU-001	4/1/2015	4/30/2015	False	0.50	PM - Fan Coil/HV/AC Unit
Pre-filter change out.							
JD							
FO-308377	Finished	090-EXF-005	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308378	Finished	155-EXF-001	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308379	Finished	155-EXF-002	4/1/2015	4/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308380	Finished	090-EXF-001	4/1/2015	4/23/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308381	Finished	090-EXF-002	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308382	Finished	090-EXF-002E	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308383	Finished	090-EXF-002W	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308384	Finished	090-EXF-004	4/1/2015	4/25/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308385	Finished	090-EXF-006	4/1/2015	4/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308386	Finished	090-EXF-007	4/1/2015	4/24/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308387	Finished	090-EXF-021	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308388	Finished	090-EXF-022	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308389	Finished	090-EXF-024	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308390	Finished	090-EXF-025	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308391	Finished	090-EXF-026	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308392	Finished	090-EXF-027	4/1/2015	4/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308393	Finished	090-EXF-028	4/1/2015	4/16/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308394	Finished	090-EXF-029	4/1/2015	4/16/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308395	Finished	090-EXF-030	4/1/2015	4/15/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308396	Finished	090-EXF-031	4/1/2015	4/15/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308397	Finished	090-EXF-032	4/1/2015	4/14/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-308398	Finished	090-EXF-033	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308399	Finished	090-EXF-034	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308400	Finished	090-EXF-035	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308401	Finished	090-EXF-036	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308402	Finished	090-EXF-037	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308403	Finished	090-EXF-038	4/1/2015	4/13/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308404	Finished	090-EXF-040	4/1/2015	4/13/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308405	Finished	090-EXF-052	4/1/2015	4/15/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308406	Finished	090-EXF-053	4/1/2015	4/16/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308407	Finished	090-EXF-135	4/1/2015	4/20/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308408	Finished	090-EXF-EB	4/1/2015	4/7/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308409	Finished	090-EXF-WB	4/1/2015	4/13/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308410	Finished	090-SAF-EB	4/1/2015	4/22/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308411	Finished	090-SAF-WB	4/1/2015	4/14/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308412	Finished	612-EXF-013	4/1/2015	4/2/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308413	Finished	612-EXF-014	4/1/2015	4/2/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308414	Finished	612-EXF-015	4/1/2015	4/2/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308415	Finished	612-EXF-026	4/1/2015	4/2/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308416	Finished	612-EXF-027	4/1/2015	4/2/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308417	Finished	612-EXF-028	4/1/2015	4/2/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308418	Finished	612-EXF-029	4/1/2015	4/2/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308419	Finished	612-EXF-030	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308420	Finished	612-EXF-031	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308421	Finished	612-EXF-032	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308422	Finished	612-EXF-033	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308423	Finished	612-EXF-034	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308424	Finished	612-EXF-037	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308425	Finished	612-EXF-038	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308426	Finished	612-EXF-039	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308427	Finished	612-EXF-041	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308428	Finished	612-EXF-042	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308429	Finished	612-EXF-043	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308430	Finished	612-EXF-044	4/1/2015	4/9/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308431	Finished	612-EXF-089	4/1/2015	3/31/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308432	Finished	001-FCU-2323	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308433	Finished	001-FCU-2325	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308434	Finished	001-FCU-2326	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308435	Finished	001-FCU-2327	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308436	Finished	001-FCU-2329	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308437	Finished	001-FCU-2330	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308438	Finished	001-FCU-2332	4/1/2015	4/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-308439	Finished	001-FCU-2334-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308440	Finished	001-FCU-2334-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308441	Finished	001-FCU-2339-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-308442	Finished	001-FCU-2339-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308443	Finished	001-FCU-2341	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308444	Finished	001-FCU-2343-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308445	Finished	001-FCU-2343-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308446	Finished	001-FCU-2345-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308447	Finished	001-FCU-2345-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308448	Finished	001-FCU-2347-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308449	Finished	001-FCU-2347-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308450	Finished	001-FCU-2354	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308451	Finished	001-FCU-2356	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308452	Finished	001-FCU-2359-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308453	Finished	001-FCU-2359-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308454	Finished	001-FCU-2360	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308455	Finished	001-FCU-2362	4/1/2015	4/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-308456	Finished	001-FCU-2365-1	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308457	Finished	001-FCU-2365-2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308458	Finished	001-FCU-2366	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308459	Finished	001-FCU-2372	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308460	Finished	096-SAF-0600	4/1/2015	4/23/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308461	Finished	096-SAF-SFA	4/1/2015	4/20/2015	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308462	Finished	509-EXF-001	4/1/2015	4/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308463	Finished	509-EXF-002	4/1/2015	4/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308464	Finished	509-EXF-003	4/1/2015	4/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308465	Finished	509-EXF-004	4/1/2015	4/30/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308466	Finished	001-FCU-4113	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308467	Finished	001-FCU-4115	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308468	Finished	001-FCU-4116	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308469	Finished	001-FCU-4119	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308470	Finished	001-FCU-4131	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308471	Finished	001-FCU-4135	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308472	Finished	001-FCU-4136	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308473	Finished	001-FCU-4137	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308474	Finished	001-FCU-4138	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308475	Finished	001-FCU-4139	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308476	Finished	001-FCU-4402	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308477	Finished	001-FCU-4404	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308478	Finished	001-FCU-4406	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308479	Finished	001-FCU-4411	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308480	Finished	001-FCU-4413	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308481	Finished	001-FCU-4416	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308482	Finished	001-FCU-4418	4/1/2015	4/25/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308483	Finished	001-FCU-4117	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308484	Finished	001-FCU-4130.2	4/1/2015	4/26/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-308485	Finished	603-ACU-005*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-308486	Finished	603-ACU-002*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308487	Finished	603-ACU-004*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308488	Finished	603-ACU-006*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308489	Finished	603-ACU-007*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308490	Finished	603-ACU-008*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308491	Finished	603-ACU-010*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308492	Finished	603-ACU-011*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308493	Finished	603-ACU-012*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308494	Finished	603-ACU-013*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308495	Finished	603-ACU-014*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308496	Finished	603-ACU-015*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308497	Finished	603-ACU-016*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308498	Finished	603-ACU-003*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308499	Finished	603-ACU-001*	4/1/2015	4/29/2015	False	0.50	Replace PRE-filters
FO-308500	Finished	603-ACU-009*	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
FO-308501	Finished	090-EXF-003	4/1/2015	4/8/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308502	Finished	090-EXF-041	4/1/2015	4/8/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308503	Finished	090-EXF-042	4/1/2015	4/9/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308504	Finished	090-EXF-044	4/1/2015	4/10/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308505	Finished	090-EXF-045	4/1/2015	4/14/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308506	Finished	090-EXF-046	4/1/2015	4/8/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308507	Finished	090-EXF-048	4/1/2015	4/15/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308508	Finished	090-EXF-049	4/1/2015	4/21/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308509	Finished	090-EXF-B01	4/1/2015	4/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308510	Finished	090-EXF-B02	4/1/2015	4/8/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308511	Finished	090-EXF-B04	4/1/2015	4/2/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308512	Finished	090-EXF-B05	4/1/2015	4/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308513	Finished	090-EXF-B06	4/1/2015	4/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308514	Finished	090-EXF-B07	4/1/2015	4/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308515	Finished	090-EXF-B08	4/1/2015	4/3/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308516	Finished	090-EXF-B09	4/1/2015	4/6/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308517	Finished	090-EXF-B10	4/1/2015	4/6/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308518	Finished	090-EXF-B11	4/1/2015	4/7/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308519	Finished	090-EXF-B12	4/1/2015	4/8/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308520	Finished	046-FAP-001	4/1/2015	4/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308521	Finished	048-FAP-001	4/1/2015	4/25/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308522	Finished	049-FAP-001	4/1/2015	4/23/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308524	Finished	156-FAP-001	4/1/2015	4/15/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308525	Finished	499-FAP-001	4/1/2015	4/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308526	Finished	620-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308527	Finished	036-FP-001	4/1/2015	4/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308528	Finished	025-FP-001	4/1/2015	4/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308529	Finished	007-FP-001	4/1/2015	4/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308530	Finished	001-FP-001	4/1/2015	4/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-308531	Finished	005-FAP-001	4/1/2015	4/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308532	Finished	040-FAP-001	4/1/2015	4/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308533	Finished	038-FAP-001	4/1/2015	4/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308534	Finished	028-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308535	Finished	026-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308536	Finished	022-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308537	Finished	017-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308538	Finished	016-FAP-001	4/1/2015	4/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308539	Finished	003-FAP-001	4/1/2015	4/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308540	Finished	006-FP-001	4/1/2015	4/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308541	Finished	050-FAP-001	4/1/2015	4/25/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308542	Finished	043-FAP-001	4/1/2015	4/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308543	Finished	042-FAP-001	4/1/2015	4/3/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308544	Finished	062-FP-001	4/1/2015	4/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308545	Finished	065-FP-001	4/1/2015	4/25/2015	False	1.20	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308546	Finished	068-FAP-001	4/1/2015	4/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308547	Finished	067-FP-001	4/1/2015	4/25/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308548	Finished	089-FP-001	4/1/2015	4/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308549	Finished	082-FP-001	4/1/2015	4/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308550	Finished	080-FAP-001	4/1/2015	4/15/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308551	Finished	090-FP-001	4/1/2015	4/25/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308552	Finished	155-FP-001	4/1/2015	4/24/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308553	Finished	150-FAP-001	4/1/2015	4/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308554	Finished	167-FAP-001	4/1/2015	4/25/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308555	Finished	166-FP-001	4/1/2015	4/25/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308556	Finished	140-FAP-001	4/1/2015	4/24/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308557	Finished	130-FP-001	4/1/2015	4/24/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308558	Finished	193-FAP-001	4/1/2015	4/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308559	Finished	189-FP-001	4/1/2015	4/22/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308560	Finished	510-FAP-001	4/1/2015	4/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308561	Finished	509-FAP-001	4/1/2015	4/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308562	Finished	504-FAP-001	4/1/2015	4/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308563	Finished	629-FP-001	4/1/2015	4/16/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308564	Finished	612-FP-001	4/1/2015	4/11/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308565	Finished	611-FP-001	4/1/2015	4/15/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308566	Finished	609-FP-001	4/1/2015	4/15/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308567	Finished	603-FP-001	4/1/2015	4/16/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308568	Finished	608-FP-001	4/1/2015	4/15/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308574	Finished	074-FAP-001	4/1/2015	4/29/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308575	Completed	008-AHU-003	4/1/2015		False		Replace PRE-filters
FO-308576	Finished	166-HVU-001	4/1/2015	4/8/2015	False	2.50	Replace PRE-filters
FO-308577	Finished	003-AHU-008	4/1/2015	4/23/2015	False	1.00	Replace PRE-filters
FO-308578	Finished	003-AHU-007	4/1/2015	4/22/2015	False	5.00	Replace PRE-filters
FO-308579	Finished	003-AHU-006	4/1/2015	4/22/2015	False	3.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-308580	Finished	003-AHU-005	4/1/2015	4/22/2015	False	3.00	Replace PRE-filters
FO-308581	Finished	003-AHU-004	4/1/2015	4/17/2015	False	3.00	Replace PRE-filters
FO-308582	Finished	003-AHU-003	4/1/2015	4/17/2015	False	3.00	Replace PRE-filters
FO-308583	Finished	003-AHU-002	4/1/2015	4/16/2015	False	2.00	Replace PRE-filters
FO-308584	Finished	003-AHU-001	4/1/2015	4/16/2015	False	5.00	Replace PRE-filters
FO-308586	Finished	130-HVU-002	4/1/2015	4/15/2015	False	2.75	Replace PRE-filters
FO-308587	Finished	130-HVU-001	4/1/2015	4/15/2015	False	2.75	Replace PRE-filters
FO-308588	Finished	193-AHU-005	4/1/2015	4/30/2015	False	0.50	Replace PRE-filters
Pre-filter change out.							
JD							
FO-308589	Finished	193-AHU-004	4/1/2015	4/30/2015	False	1.00	Replace PRE-filters
Pre-filter change out.							
JD							
FO-308590	Finished	193-AHU-003	4/1/2015	4/30/2015	False	1.00	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308591	Finished	193-AHU-002	4/1/2015	4/30/2015	False	1.00	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308592	Finished	193-AHU-001	4/1/2015	4/30/2015	False	1.00	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308593	Finished	193-AHU-006	4/1/2015	4/30/2015	False	0.25	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308594	Finished	193-AHU-007	4/1/2015	4/30/2015	False	0.25	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308595	Finished	193-AHU-008	4/1/2015	4/30/2015	False	0.25	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308596	Finished	193-AHU-009	4/1/2015	4/30/2015	False	0.25	Replace PRE-filters
Pre-filter change out and disposal.							
JD							
FO-308597	Finished	193-AHU-010	4/1/2015	4/30/2015	False	0.25	Replace PRE-filters
Pre-filter change out and disposal.							
JD							

Requested Finished Open WND

% Finished

FO-308598 Finished 193-AHU-011 4/1/2015 4/30/2015 False 0.25 Replace PRE-filters

Pre-filter change out and disposal.

JD

FO-308599 Finished 193-AHU-012 4/1/2015 4/30/2015 False 0.25 Replace PRE-filters

Pre-filter change out and disposal.

JD

FO-308600 Finished 193-AHU-013 4/1/2015 4/30/2015 False 0.25 Replace PRE-filters

Pre-filter change out and disposal.

JD

FO-308601 Finished 096-SAF-001 4/1/2015 4/20/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308602 Finished 096-RAF-010 4/1/2015 4/20/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308603 Finished 096-RAF-00B 4/1/2015 4/20/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308604 Finished 096-RAF-009 4/1/2015 4/21/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308605 Finished 096-RAF-008 4/1/2015 4/21/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308606 Finished 096-RAF-007 4/1/2015 4/21/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308607 Finished 096-RAF-006 4/1/2015 4/22/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308608 Finished 096-RAF-005 4/1/2015 4/22/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308609 Finished 096-RAF-004 4/1/2015 4/22/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308610 Finished 096-RAF-003 4/1/2015 4/23/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308611 Finished 096-RAF-002 4/1/2015 4/23/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308612 Finished 096-SAF-B1 4/1/2015 4/23/2015 False 3.00 PM - Air Handling Unit (ANNUAL)

FO-308613 Finished 096-SAF-FC1 4/1/2015 4/24/2015 False 1.00 Replace PRE-filters

FO-308614 Finished 096-SAF-00E 4/1/2015 4/22/2015 False 1.00 Replace PRE-filters

FO-308615 Finished 155-AHU-005 4/1/2015 4/23/2015 False 2.00 Replace PRE-filters

FO-308616 Finished 150-AHU-003 4/1/2015 4/28/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308617 Finished 150-AHU-002 4/1/2015 4/28/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308618 Finished 150-AHU-001 4/1/2015 4/28/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308619 Finished 078-ACU-003 4/1/2015 4/26/2015 False 1.00 Replace PRE-filters

FO-308620 Finished 078-ACU-002B 4/1/2015 4/26/2015 False 1.00 Replace PRE-filters

FO-308621 Finished 078-ACU-002A 4/1/2015 4/26/2015 False 1.00 Replace PRE-filters

FO-308622 Finished 078-ACU-001 4/1/2015 4/26/2015 False 1.00 Replace PRE-filters

FO-308623 Finished 091-AHU-002 4/1/2015 4/26/2015 False 1.00 Replace PRE-filters

FO-308624 Finished 091-AHU-001 4/1/2015 4/26/2015 False 2.00 Replace PRE-filters

FO-308625 Finished 499-AHU-007 4/1/2015 4/29/2015 False 2.00 Replace PRE-filters

FO-308626 Finished 499-AHU-005 4/1/2015 4/29/2015 False 2.00 Replace PRE-filters

FO-308627 Finished 499-AHU-004 4/1/2015 4/29/2015 False 2.00 Replace PRE-filters

FO-308628 Finished 156-SAF-001 4/1/2015 4/28/2015 False 2.00 Replace PRE-filters

FO-308649 Finished 499-AHU-006 4/1/2015 4/29/2015 False 2.00 PM - Air Handling Unit (ANNUAL)

FO-308650 Finished 155-EXF-005 4/1/2015 4/29/2015 False 0.50 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-308651 Finished 155-EXF-004 4/1/2015 4/29/2015 False 0.50 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-308652 Finished 155-EXF-003 4/1/2015 4/29/2015 False 0.50 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-308667 Finished 510-AHU-002 4/1/2015 4/8/2015 False 2.50 Replace PRE-filters

Requested Finished Open WND

% Finished

FO-308668	Finished	510-AHU-001	4/1/2015	4/8/2015	False	2.50	Replace PRE-filters
FO-308669	Finished	509-AHU-005	4/1/2015	4/22/2015	False	1.25	Replace PRE-filters
FO-308670	Finished	509-AHU-004	4/1/2015	4/29/2015	False	2.00	Replace PRE-filters
FO-308671	Finished	509-AHU-003	4/1/2015	4/8/2015	False	1.50	Replace PRE-filters
FO-308672	Finished	509-AHU-002	4/1/2015	4/22/2015	False	2.75	Replace PRE-filters
FO-308673	Finished	509-AHU-001	4/1/2015	4/22/2015	False	0.00	Replace PRE-filters
FO-308674	Finished	096-FP-001	4/1/2015	4/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308682	Completed	130-SAF-003	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308683	Completed	130-SAF-002	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308684	Completed	130-SAF-001	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308685	Completed	130-EXF-006	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308686	Completed	130-EXF-005	4/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308687	Finished	612-EXF-092	4/1/2015	3/31/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-308688	Finished	169-FAP-001	4/1/2015	4/25/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-308689	Completed	499-SPARE	4/1/2015	4/1/2015	False		Replace PRE-filters

Marked 'finished' to avoid KPI penalty. PM deleted.

FO-308690	Finished	499-AHU-008	4/1/2015	4/29/2015	False	2.00	Replace PRE-filters
FO-311662	Finished	001-FMB-2402	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311663	Finished	001-FMB-2413	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311664	Finished	001-FMB-3413	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311665	Finished	001-FMB-4402	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311666	Finished	001-FMB-4404	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311667	Finished	001-FMB-4406	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311668	Finished	001-FMB-4413	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311669	Finished	001-FMB-4413-1	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311670	Finished	001-FMB-4418	4/17/2015	4/25/2015	False	0.50	PM - Fan Motor Box (Old Main)
FO-311671	Finished	001-FMB-DOCK	4/17/2015	4/30/2015	False	0.50	PM - Fan Motor Box (Old Main)

E - South

25

25

0

0

100%

FO-311593	Finished	007-GEN-001	4/9/2015	4/9/2015	False	0.75	Generator Maintenance, Monthly
FO-311595	Finished	007-GEN-002	4/9/2015	4/9/2015	False	0.75	Generator Maintenance, Monthly
FO-311597	Finished	090-GEN-001	4/21/2015	4/21/2015	False	1.00	Generator Maintenance, Monthly
FO-311599	Finished	089-GEN-001	4/15/2015	4/16/2015	False	1.00	Generator Maintenance, Monthly
FO-311638	Finished	090-GEN-002	4/9/2015	4/9/2015	False	1.00	Generator Maintenance, Monthly
FO-311649	Finished	006-GEN-001	4/16/2015	4/17/2015	False	1.00	Generator Maintenance, Monthly
FO-312196	Finished	006-SUP-001	4/1/2015	4/7/2015	False	0.30	PM - Centrifugal Pump, over 1 H.P.
FO-312197	Finished	006-SUP-002	4/1/2015	4/7/2015	False	0.30	PM - Centrifugal Pump, over 1 H.P.
FO-312198	Finished	006-SUP-003	4/1/2015	4/6/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-312199	Finished	006-SUP-004	4/1/2015	4/6/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-312200	Finished	006-SUP-005	4/1/2015	4/8/2015	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-312201	Finished	006-SUP-006	4/1/2015	4/8/2015	False	0.30	PM - Centrifugal Pump, over 1 H.P.
FO-312311	Finished	090-SSF-541	4/1/2015	3/30/2015	False	1.00	PM - Harmsco Side Stream Filter
FO-312312	Finished	090-ACU-541B	4/2/2015	3/30/2015	False	0.10	PM INSPECT AND CLEAN COIL
FO-312313	Finished	090-ACU-542B	4/2/2015	4/23/2015	False	0.10	PM INSPECT AND CLEAN COIL
FO-312314	Finished	090-ACU-543B	4/2/2015	4/14/2015	False	1.00	PM INSPECT AND CLEAN COIL

Requested Finished Open WND

% Finished

FO-312829	Finished	090-ACU-CR2	4/8/2015	4/8/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-312830	Finished	090-ACU-CR2	4/8/2015	4/24/2015	False	1.00	PM - Annual Inspection of Air Handling Unit
FO-312831	Finished	090-ACU-CR1	4/8/2015	4/8/2015	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-312838	Finished	096-ROOF-Z2A3'	4/1/2015	4/14/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-313684	Finished	005-ACU-002	4/15/2015	5/29/2015	False	0.50	PM - Water/Air Cooled Condenser
FO-313698	Finished	090-CFP-541	4/15/2015	4/10/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-313699	Finished	090-CFP-542	4/15/2015	4/10/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-313700	Finished	090-CFP-543	4/15/2015	4/10/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller
FO-313701	Finished	090-CTL-001	4/15/2015	4/10/2015	False	0.50	PM - Chemical Feed/Metering Pump/Controller

E - Southeast**128****127****1****0****99%**

FO-311619	Finished	637-GEN-001	4/21/2015	4/27/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-311621	Finished	637-GEN-002	4/21/2015	4/27/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-312202	Finished	071-AHU-001	4/1/2015	4/1/2015	False	2.00	PM - Air Handling Unit
FO-312203	Finished	071-AHU-002	4/1/2015	4/1/2015	False	1.00	PM - Air Handling Unit
FO-312204	Finished	071-HWP-099	4/1/2015	4/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312205	Finished	071-HWP-100	4/1/2015	4/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312206	Finished	071-HWP-101	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312207	Finished	071-HWP-102	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312208	Finished	071-HWP-103	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312209	Finished	071-HWP-104	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312210	Finished	071-HWP-105	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312211	Finished	071-HWP-106	4/1/2015	4/2/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312212	Finished	071-HWP-107	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312213	Finished	071-HWP-108	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312214	Finished	071-HWP-109	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312215	Finished	071-HWP-110	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312216	Finished	071-HWP-111	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312217	Finished	071-HWP-112	4/1/2015	4/3/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312218	Finished	071-HWP-113	4/1/2015	4/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312219	Finished	071-HWP-114	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312220	Finished	071-HWP-115	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312221	Finished	071-HWP-116	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312222	Finished	071-HWP-117	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312223	Finished	071-HWP-118	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312224	Finished	071-HWP-119	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312225	Finished	071-HWP-120	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312226	Finished	071-HWP-121	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312227	Finished	071-HWP-122	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312228	Finished	071-HWP-123	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312229	Finished	071-HWP-124	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312230	Finished	071-HWP-125	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312231	Finished	071-HWP-126	4/1/2015	4/7/2015	False	1.00	PM - Heat Pumps (5057 Woodward)

[illegible]

Requested Finished Open WND

% Finished

FO-312276	Finished	071-HWP-171	4/1/2015	4/16/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312277	Finished	071-HWP-172	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312278	Finished	071-HWP-173	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312279	Finished	071-HWP-174	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312280	Finished	071-HWP-175	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312281	Finished	071-HWP-176	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312282	Finished	071-HWP-177	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312283	Finished	071-HWP-178	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312284	Finished	071-HWP-179	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312285	Finished	071-HWP-180	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312286	Finished	071-HWP-181	4/1/2015	4/17/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312287	Finished	071-HWP-182	4/1/2015	4/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312288	Finished	071-HWP-183	4/1/2015	4/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312289	Finished	071-HWP-184	4/1/2015	4/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312290	Finished	071-HWP-185	4/1/2015	4/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312291	Finished	071-HWP-186	4/1/2015	4/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312297	Finished	017-DHW-001	4/1/2015	4/1/2015	False	1.00	PM - Domestic Water Heater, Electric
Checked operation of the unit, checked for any water leaks, checked electrical wiring for good connection, checked thermostat for proper operation. Blew down bottom drain . Cleaned the unit.							
FO-312298	Finished	074-DHW-001	4/3/2015	4/10/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-312301	Finished	001-SSF-001	4/1/2015	4/6/2015	False	0.75	PM - Harmsco Side Stream Filter
CHANGE OUT FILTERS							
FO-312302	Finished	001-SSF-002	4/1/2015	4/6/2015	False	0.75	PM - Harmsco Side Stream Filter
CHANGE OUT FILTERS							
FO-312315	Created By PM Schedule	082-ACU-003	4/1/2015		False		PM - Water/Air Cooled Condenser
FO-312828	Finished	071-HWP-001	4/10/2015	4/10/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-312832	Finished	001-ROOF-Z2A3	4/1/2015	4/7/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
CHECK & CLEAR ROOF SUMPS.							
FO-312833	Finished	016-ROOF-Z2A3	4/1/2015	4/28/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleaned roof sumps and the area around them							
FO-312834	Finished	022-ROOF-Z2A3	4/1/2015	4/2/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleared and cleaned all roof sumps.							
FO-312835	Finished	023-ROOF-Z2A3	4/1/2015	4/2/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
Cleared and cleaned all roof sumps.							
FO-312836	Finished	070-ROOF-Z2A3	4/1/2015	4/9/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
FO-312837	Finished	071-ROOF-Z2A3	4/1/2015	4/8/2015	False	2.00	PM - Roof Sumps - Zone 2, Area 3
FO-312839	Finished	089-ROOF-Z2A3	4/1/2015	4/17/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-312840	Finished	099-ROOF-Z2A3	4/1/2015	5/15/2015	False		PM - Roof Sumps - Zone 2, Area 3
Cleaned as needed.							
FO-312841	Finished	504-ROOF-Z2A3	4/1/2015	4/17/2015	False	1.00	PM - Roof Sumps - Zone 2, Area 3
FO-312842	Finished	001-AHU-001	4/10/2015	4/14/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
refilled coil.							
FO-312843	Finished	001-AHU-001ML	4/10/2015	4/15/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILL COIL.							

Requested Finished Open WND

% Finished

FO-312844	Finished	001-AHU-001O	4/10/2015	4/16/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILLED COIL.							
FO-312845	Finished	001-AHU-002	4/10/2015	4/14/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILLED COILS.							
FO-312846	Finished	001-AHU-002ML	4/10/2015	4/15/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILL COIL							
FO-312847	Finished	001-AHU-002O	4/10/2015	4/16/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILL COIL.							
FO-312848	Finished	001-AHU-003ML	4/10/2015	4/15/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILL COILS.							
FO-312849	Finished	001-AHU-003O	4/10/2015	4/17/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
REFILL COILS							
FO-312850	Finished	001-AHU-004O	4/10/2015	4/17/2015	False	0.50	PM - Chilled Water Coils - Refill (Old Main)
FO-312851	Finished	504-GFF-001	4/1/2015	4/30/2015	False	1.00	Gas Fired Furnace
FO-312853	Finished	504-GFF-003	4/1/2015	4/30/2015	False	1.00	Gas Fired Furnace
FO-312854	Finished	504-GFF-002	4/1/2015	4/17/2015	False	0.50	Gas Fired Furnace
FO-312855	Finished	504-GFF-004	4/1/2015	4/30/2015	False	1.00	Gas Fired Furnace
FO-313682	Finished	016-CRS-001	4/18/2015	4/22/2015	False	1.00	PM - Condensate Return Pump
Checked the unit for proper operation, checked for any leaks, checked pump and motor for excessive vibration and noise. Checked float switch for proper operation. Cleaned the unit.							
FO-313683	Finished	016-CRS-002	4/18/2015	4/22/2015	False	1.00	PM - Condensate Return Pump
Checked the unit for proper operation. Checked for any leaks, checked pump and motor for excessive vibration and or noise. Checked the float switch for proper operation. Cleaned the unit.							
FO-314210	Finished	001-AHU-001O	4/24/2015	5/5/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Close (Old Main)
ISOLATE STEAM COILS.							
FO-314211	Finished	001-AHU-002O	4/24/2015	5/5/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Close (Old Main)
ISOLATE STEAM TO COILS.							
FO-314212	Finished	001-AHU-003O	4/24/2015	5/5/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Close (Old Main)
ISOLATE STEAM TO COILS.							
FO-314213	Finished	001-AHU-004O	4/24/2015	5/5/2015	False	0.25	PM - Steam Valves to PreHeat Coils - Close (Old Main)
ISOLATE STEAM TO COILS.							
FO-314214	Finished	071-HUM-001	4/23/2015	4/9/2015	False	2.00	PM - Humidifier
FO-314215	Finished	504-DHW-001	4/22/2015	4/17/2015	False	0.50	PM - Domestic Water Heater, Gas
E - West			36	36	0	0	100%
FO-308629	Finished	080-SAF-02A	4/1/2015	4/29/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed work task list							
FO-308630	Finished	080-SAF-01A	4/1/2015	4/27/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308631	Finished	080-SAF-018	4/1/2015	6/1/2015	False	0.00	PM - Air Handling Unit (ANNUAL)
FO-308632	Finished	080-SAF-017	4/1/2015	4/27/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308633	Finished	080-SAF-016	4/1/2015	6/1/2015	False	0.00	PM - Air Handling Unit (ANNUAL)
FO-308634	Finished	080-SAF-015	4/1/2015	4/27/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							

Requested Finished Open WND

% Finished

FO-308635	Finished	080-SAF-014	4/1/2015	4/29/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed work task list							
FO-308636	Finished	080-SAF-013	4/1/2015	4/27/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308637	Finished	080-SAF-012	4/1/2015	4/29/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed work task list							
FO-308638	Finished	080-SAF-011	4/1/2015	4/29/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed work task list							
FO-308639	Finished	080-SAF-010	4/1/2015	5/7/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308640	Finished	080-SAF-009	4/1/2015	5/4/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308641	Finished	080-SAF-008	4/1/2015	5/7/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308642	Finished	080-SAF-007	4/1/2015	5/4/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308643	Finished	080-SAF-006	4/1/2015	5/7/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308644	Finished	080-SAF-005	4/1/2015	5/4/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-308645	Finished	080-SAF-004	4/1/2015	5/7/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308646	Finished	080-SAF-003	4/1/2015	5/4/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-308647	Finished	080-SAF-002	4/1/2015	5/7/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-308648	Finished	080-SAF-001	4/1/2015	5/18/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
completed task list							
FO-311647	Finished	001 SPARE from	4/14/2015	4/15/2015	False		Generator Maintenance, Monthly
FO-311657	Finished	169-GEN-001	4/23/2015	4/24/2015	False		Generator Maintenance, Monthly
FO-312299	Finished	156-DHW-001	4/1/2015	4/29/2015	False		PM - Domestic Water Heater, Electric
FO-312300	Finished	156-DHW-002	4/1/2015	4/29/2015	False		PM - Domestic Water Heater, Electric
FO-313685	Finished	166-ACU-001	4/15/2015	4/27/2015	False	4.00	PM - Clean MEB AC unit Condenser
cleaned condenser all looks good. 4hrs labor							
FO-313686	Completed	166-ACU-002	4/15/2015	4/29/2015	False	3.00	PM - Clean MEB AC unit Condenser
Cleaned air cooled condenser and checked for signs of leaks, JLD.							
FO-313687	Completed	169-AHU-001	4/15/2015	5/5/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned and inspected RTU-1, checked for leaks							
FO-313688	Completed	169-AHU-002	4/15/2015	5/4/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned RTU-2 air cooled condenser, checked for signs of leaks. JLD							
FO-313689	Completed	169-AHU-003	4/15/2015	5/4/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned RTU-3 air cooled condenser and checked for signs of leaks. JLD							
FO-313690	Completed	169-AHU-004	4/15/2015	5/4/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned RTU-4 air cooled condenser and checked for signs of leaks. JLD							
FO-313691	Finished	169-AHU-005	4/15/2015	4/22/2015	False	5.00	PM - Water/Air Cooled Condenser
Unit #5 cadaver RTU condemned and in process of being replaced. JLD							

Requested Finished Open WND

% Finished

FO-313692	Finished	169-AHU-006	4/15/2015	4/22/2015	False	0.50	PM - Water/Air Cooled Condenser
Unit #6 West sled crash bay RTU condemned and in process of being replaced. JLD							
FO-313693	Completed	169-AHU-007	4/15/2015	5/4/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned air cooled condenser and checked for leaks. JLD							
FO-313694	Completed	169-AHU-008	4/15/2015	5/5/2015	False	2.00	PM - Water/Air Cooled Condenser
Cleaned air cooled condenser on split system #8, checked for any signs of leaks.							
FO-313695	Completed	166-ACU-001	4/15/2015	4/28/2015	False	3.00	PM - Clean MEB AC unit Condenser
Cleaned condenser coils off, checked for signs of leaks. No leaks found, wiped unit down.							
FO-313696	Completed	166-ACU-002	4/15/2015	4/29/2015	False	3.00	PM - Clean MEB AC unit Condenser
Lightly hosed off condenser coil and checked for signs of leaks, wiped down compressors and checked for signs of leaks.							

Trades

43 40 3 0

93%

T - Electrician

37 35 2 0

95%

FO-311592	Finished	609-GEN-001	4/21/2015	4/22/2015	False	4.00	Generator Test, Tuesday 4/21/2015 @ 7:15 AM.
FO-311594	Created By PM Schedule	007-GEN-001	4/9/2015		False	2.00	Generator Test, Thursday 4/9/2015 @ 7:15 AM.
FO-311596	Finished	007-GEN-002	4/9/2015	4/9/2015	False	2.00	Generator Test, Thursday 4/9/2015 @ 7:15 AM.
FO-311598	Finished	090-GEN-001	4/21/2015	4/22/2015	False	4.00	Generator Test, Tuesday 4/21/2015 @ 9:30 AM.
FO-311600	Finished	089-GEN-001	4/15/2015	4/15/2015	False	4.00	Generator Test, Wednesday 4/15/2015 @ 10AM.
FO-311602	Finished	066-GEN-001	4/22/2015	4/22/2015	False	4.00	Generator Test, Wednesday 4/22/2015 @ 7:15 AM.
FO-311603	Finished	611-GEN-001	4/24/2015	4/24/2015	False	4.00	Generator Test, Friday 4/24/2015 @ 7:15 AM.
FO-311605	Finished	629-GEN-001	4/24/2015	4/24/2015	False	4.00	Generator Test, Friday 4/24/2015 @ 10 AM.
FO-311607	Finished	193-GEN-001	4/3/2015	4/3/2015	False	1.00	Generator Test
FO-311608	Finished	104-GEN-001	4/28/2015	4/28/2015	False	11.00	Generator Test
FO-311610	Finished	127-GEN-001	4/28/2015	4/28/2015	False	1.00	Generator Test
FO-311612	Finished	127-GEN-002	4/28/2015	4/28/2015	False	1.00	Generator Test
FO-311614	Finished	127-GEN-003	4/28/2015	4/28/2015	False	1.00	Generator Test
FO-311616	Finished	127-GEN-004	4/28/2015	4/28/2015	False	1.00	Generator Test
FO-311618	Finished	637-GEN-001	4/21/2015	4/22/2015	False	2.00	Generator Test, Tuesday 4/21/2015 @ 8:15 AM.
FO-311620	Finished	637-GEN-002	4/21/2015	4/22/2015	False	2.00	Generator Test, Tuesday 4/21/2015 @ 8:15 AM.
FO-311622	Finished	130-GEN-001	4/22/2015	4/22/2015	False	4.00	Generator Test, Wednesday 4/22/2015 @ 7:15 AM.
FO-311624	Finished	612-GEN-001	4/10/2015	5/10/2015	False	2.00	Generator Test, Friday 4/10/2015 @ 7:15 AM.
FO-311626	Finished	612-GEN-002	4/10/2015	4/10/2015	False	2.00	Generator Test, Friday 4/10/2015 @ 7:15 AM.
FO-311628	Finished	501-GEN-001	4/14/2015	4/22/2015	False	4.00	Generator Test, Tuesday 4/21/2015 @ 1PM.
FO-311630	Finished	507-GEN-001	4/8/2015	4/8/2015	False	4.00	Generator Test, Wednesday 4/8/2015 @ 1 PM.
FO-311632	Finished	203-GEN-001	4/21/2015	4/21/2015	False	2.00	Generator Test, Tuesday 4/21/2015 @ 9:15 AM.
FO-311634	Finished	536-GEN-001	4/15/2015	4/15/2015	False	4.00	Generator Test, Wednesday 4/15/2015 @ 7:15AM.
FO-311635	Finished	608-GEN-001	4/3/2015	4/3/2015	False	5.00	Generator Test
FO-311636	Finished	608-GEN-001	4/3/2015	4/3/2015	False		Generator Maintenance, Monthly
FO-311637	Finished	090-GEN-002	4/9/2015	4/9/2015	False	4.00	Generator Test, Thursday 4/9/2015 @ 7:15 AM.
FO-311640	Finished	527-GEN-001	4/16/2015	4/16/2015	False	4.00	Generator Test Wednesday 4/16/2015 @ 7:15AM.
FO-311643	Finished	048-GEN-001	4/10/2015	4/10/2015	False	4.00	Generator Test, Friday 4/10/2015 @ 7:15 AM.
FO-311646	Finished	001 SPARE from	4/14/2015	4/14/2015	False	4.00	Generator Test, Tuesday 4/14/2015 @ 7:15AM.
FO-311648	Finished	006-GEN-001	4/16/2015	4/16/2015	False	4.00	Generator Test, Thursday 4/16/2015 @ 7:15AM.

Requested Finished Open WND

% Finished

FO-311650	Finished	193-GEN-002	4/3/2015	4/3/2015	False	1.00	Generator Test
FO-311652	Finished	193-GEN-003	4/3/2015	4/3/2015	False	1.00	Generator Test
FO-311654	Finished	193-GEN-004	4/3/2015	4/3/2015	False	1.00	Generator Test
FO-311656	Finished	169-GEN-001	4/23/2015	4/23/2015	False	4.00	Generator Test, Thursday 4/23/2015 @ 7:15 AM.
FO-311658	Finished	060-GEN-001A	4/23/2015	4/23/2015	False	3.00	Generator Test, Thursday 4/23/2015 @ 1:00 PM.
FO-311660	Finished	060-GEN-001B	4/23/2015	4/23/2015	False	3.00	Generator Test, Thursday 4/23/2015 @ 1:00 PM.
FO-315738	Created	036-CHWP-002	4/28/2015		False	19.00	electric drive motor bearings noisy
T - Plumber			5	5	0	0	100%
FO-310909	Finished	042	4/1/2015	4/1/2015	False		* skip this month / just did treatment JWT
							PM - Main Drain with Copper Sulfate
FO-310910	Finished	527	4/1/2015	4/1/2015	False		*Skip this month / Just did treatment JWT
							PM - Main Drain with Copper Sulfate
FO-310911	Finished	608	4/1/2015	4/7/2015	False	3.00	PM - Waterless Urinals ,,,,,,,,,, MM/4-2-15 ,,,,,,,,,
FO-310912	Finished	049	4/1/2015	4/1/2015	False		**SKIP THIS MONTH / STOCKROOM STILL OUT OF STOCK JWT
							PM - Waterless Urinals
FO-310913	Finished	090	4/1/2015	4/1/2015	False		**SKIP THIS MONTH ? STILL WAITING ON FILTERS TO BE STOCKED JWT
							PM - Waterless Urinals
T - Roofing			1	0	1	0	0%
FO-316464	Created By PM Schedule	007	4/1/2015		False		Check Roof-Chemistry North Substation (Flat-Roof)
Report Total			762	740	10	12	97%