

DRAFT Facilities Operations PM Analysis from 7/1/16 through 7/31/16

Requested Finished Open WND										% Finished
Engineering		561		385		118		58		69%
E - Auxiliary		42		29		13		0		69%
FO-350467	Finished	034-AHU-001	7/1/2016	7/20/2016		False	3.00	PM - Air Handling Unit		
Changed pre-filters, checked belts and adjustment, lubed motor and bearings, checked damper operation.										
FO-350468	Finished	034-AHU-002	7/1/2016	7/19/2016		False	3.00	PM - Air Handling Unit		
Changed pre-filters, checked belts and adjustment, lubed motor and bearings, checked damper operation.										
FO-350469	Finished	034-AHU-003	7/1/2016	7/27/2016		False	0.25	PM - Air Handling Unit		
AHU#3 has been removed and is being replaced by a new unit during renovations.										
FO-350470	Finished	034-AHU-004	7/1/2016	7/25/2016		False	1.00	PM - Air Handling Unit		
Changed filters, checked belts and alignment, lubed motor and bearings, checked damper operation.										
FO-350471	Finished	034-AHU-005	7/1/2016	7/27/2016		False	0.25	PM - Air Handling Unit		
AHU#5 has been removed and is being replaced by a new unit during renovations.										
FO-350472	Finished	034-SP-001	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lube motor, checked float operation and rate of discharge.										
FO-350473	Finished	034-SP-002	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lubed motor, checked float and pump operation. Cleaned area.										
FO-350474	Finished	034-SP-003	7/1/2016	7/26/2016		False	0.50	PM - Sump Pump		
Lubed motor and float rods, checked units operation. Cleaned area.										
FO-350475	Completed	034-SP-004	7/1/2016			False	0.50	PM - Sump Pump		
Lubed motor and float rod, checked float and pump operation. Cleaned area.										
FO-350490	Created By PM Schedule	104-MUA-001	7/1/2016			False		PM - Air Handling Unit		
FO-350491	Created By PM Schedule	104-MUA-002	7/1/2016			False		PM - Air Handling Unit		
FO-350492	Created By PM Schedule	115-MUA-001	7/1/2016			False		PM - Air Handling Unit		
FO-350493	Created By PM Schedule	115-MUA-002	7/1/2016			False		PM - Air Handling Unit		
FO-350494	Created By PM Schedule	115-MUA-003	7/1/2016			False		PM - Air Handling Unit		
FO-350497	Finished	136-HWP-003	7/1/2016	7/15/2016		False	0.50	PM - Water Booster Pump		
Lubed motor and bearing, checked coupler and pump operation.										
FO-350498	Created By PM Schedule	134-HWP-003	7/1/2016			False		PM - Water Booster Pump		
FO-350499	Created By PM Schedule	507-AIR-001	7/1/2016			False		PM - Air Compressor, Reciprocating 5-40 H.P.		
FO-350500	Finished	992-ES-001*	7/4/2016	7/8/2016		False		PM - Emergency Shower/Eyewash Station		
FO-350501	Created By PM Schedule	134-DWBP-001	7/1/2016			False		PM - Water Booster Pump		
FO-350502	Created By PM Schedule	134-DWBP-002	7/1/2016			False		PM - Water Booster Pump		
FO-350503	Created By PM Schedule	134-DWBP-003	7/1/2016			False		PM - Water Booster Pump		
FO-350504	Created By PM Schedule	134-CRS-001	7/1/2016			False		PM - Condensate Return Pump		
FO-350505	Created By PM Schedule	134-CRS-002	7/1/2016			False		PM - Condensate Return Pump		
FO-350517	Finished	134-ACU-001	7/1/2016	7/15/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-350527	Finished	507-ACU-001	7/1/2016	7/15/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-350529	Finished	134-FP-001	7/1/2016	7/29/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350530	Finished	127-FP-001	7/1/2016	7/29/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350531	Finished	115-FP-001	7/1/2016	7/29/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-350532	Finished	104-FP-001	7/1/2016	7/29/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test		

Requested Finished Open WND

% Finished

FO-350533	Finished	507-FP-001	7/1/2016	7/29/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-350889	Finished	501-GEN-001	7/12/2016	7/13/2016	False		Generator Maintenance, Monthly
FO-350891	Finished	507-GEN-001	7/13/2016	7/14/2016	False		Generator Maintenance, Monthly
FO-350897	Finished	536-GEN-001	7/20/2016	7/20/2016	False		Generator Maintenance, Monthly
FO-350917	Finished	034-GEN-001	7/7/2016	7/7/2016	False		Generator Maintenance, Monthly
FO-351081	Finished	992-ES-001*	7/11/2016	7/15/2016	False		PM - Emergency Shower/Eyewash Station
FO-351403	Finished	992-ES-001*	7/18/2016	7/22/2016	False		PM - Emergency Shower/Eyewash Station
FO-351998	Finished	104-GEN-001	7/26/2016	7/27/2016	False		Generator Maintenance, Monthly
FO-352000	Finished	127-GEN-001	7/26/2016	7/27/2016	False		Generator Maintenance, Monthly
FO-352002	Finished	127-GEN-002	7/26/2016	7/27/2016	False		Generator Maintenance, Monthly
FO-352004	Finished	127-GEN-003	7/26/2016	7/27/2016	False		Generator Maintenance, Monthly
FO-352006	Finished	127-GEN-004	7/26/2016	7/27/2016	False		Generator Maintenance, Monthly
FO-352007	Finished	992-ES-001*	7/25/2016	7/29/2016	False		PM - Emergency Shower/Eyewash Station
E - MedPharm			35	13	22	0	37%
FO-350287	Created By PM Schedule	629-DHW-001	7/1/2016		False		PM - Domestic Water Heater, Steam
FO-350288	Created By PM Schedule	629-DHW-002	7/1/2016		False		PM - Domestic Water Heater, Steam
FO-350289	Created By PM Schedule	629-DHW-003	7/1/2016		False		PM - Domestic Water Heater, Steam
FO-350290	Finished	629-SP-001	7/1/2016	7/20/2016	False	1.00	PM - Sump Pump
FO-350291	Finished	612-WSS-001	7/1/2016	7/26/2016	False	1.00	PM - Water Softener
FO-350292	Created By PM Schedule	603-ES-001*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350293	Created By PM Schedule	603-ES-003*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350294	Created By PM Schedule	603-ES-004*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350295	Created By PM Schedule	603-ES-005*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350296	Created By PM Schedule	603-ES-006*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350297	Created By PM Schedule	603-ES-007*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350298	Created By PM Schedule	603-ES-008*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350299	Created By PM Schedule	603-ES-009*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350300	Created By PM Schedule	603-ES-010*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350301	Created By PM Schedule	603-ES-011*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350302	Created By PM Schedule	603-ES-012*	7/1/2016		False		PM - Emergency Shower/Eyewash Station
FO-350303	Finished	608-GEN-001	7/5/2016	7/4/2016	False	1.00	Generator Maintenance, Monthly
FO-350304	Created By PM Schedule	629-ACU-002	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350305	Created By PM Schedule	629-ACU-001	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350306	Finished	612-ACU-003	7/1/2016	7/27/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350307	Finished	612-ACU-002	7/1/2016	7/14/2016	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350308	Finished	612-ACU-001	7/1/2016	7/14/2016	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350309	Finished	611-ACU-002**	7/1/2016	8/1/2016	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Trane did maintenance on chillers							
FO-350310	Finished	611-ACU-001**	7/1/2016	8/1/2016	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Trane did maintenance on chillers. Fixed bad float switch.							
FO-350311	Finished	608-ACU-001	7/1/2016	7/13/2016	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350312	Created By PM Schedule	603-ACU-002	7/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers

Requested Finished Open WND

% Finished

FO-350313	Created By PM Schedule	603-ACU-001	7/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350314	Finished	608-ACU-002	7/1/2016	7/14/2016	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350315	Created By PM Schedule	603-GEN-001	7/5/2016		False		Generator Maintenance, Monthly
FO-350885	Finished	612-GEN-001	7/12/2016	7/12/2016	False	1.00	Generator Maintenance, Monthly
FO-350887	Finished	612-GEN-002	7/12/2016	7/12/2016	False	1.00	Generator Maintenance, Monthly
FO-350900	Created By PM Schedule	609-GEN-001	7/19/2016		False		Generator Maintenance, Monthly
FO-351077	Created By PM Schedule	603-ES-002*	7/10/2016		False		PM - Emergency Shower/Eyewash Station
FO-351980	Finished	611-GEN-001	7/26/2016	7/26/2016	False	0.50	Generator Maintenance, Monthly
Electricians did monthly generator load test							
FO-351981	Created By PM Schedule	629-GEN-001	7/26/2016		False		Generator Maintenance, Monthly
E - North			34	31	3	0	91%
FO-350316	Finished	130-DWBP-001	7/1/2016	7/26/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-350317	Finished	130-DWBP-002	7/1/2016	7/26/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-350318	Finished	025-AIR-001	7/1/2016	8/10/2016	False	0.75	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350319	Finished	025-HEX-001	7/1/2016	8/10/2016	False	0.50	PM - Heat Exchanger and Economizer
FO-350320	Finished	025-HEX-002	7/1/2016	8/10/2016	False	0.75	PM - Heat Exchanger and Economizer
FO-350321	Finished	046-AIR-001	7/1/2016	7/27/2016	False	0.78	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350322	Finished	049-AIR-001	7/1/2016	7/26/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350323	Finished	049-DHW-001	7/1/2016	7/27/2016	False	0.65	PM - Domestic Water Heater, Electric
FO-350324	Finished	049-DHW-002	7/1/2016	7/27/2016	False	0.68	PM - Domestic Water Heater, Electric
FO-350325	Finished	038-AIR-001	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM on air compressor, checked operation.							
FO-350326	Finished	039-AIR-001	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM, replaced air filter on this compressor, checked operation.							
FO-350327	Finished	039-AIR-002	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM, checked operation of air compressor.							
FO-350328	Finished	026-AIR-001	7/1/2016	8/5/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350329	Created By PM Schedule	027-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350330	Finished	036-AIR-001	7/1/2016	8/17/2016	False	0.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350331	Finished	026-SSF-001	7/1/2016	8/16/2016	False	1.00	PM - Harmsco Side Stream Filter
FO-350332	Finished	036-SSF-001	7/1/2016	8/22/2016	False	1.00	PM - Harmsco Side Stream Filter
FO-350333	Finished	048-AIR-001	7/1/2016	7/12/2016	False	0.68	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350334	Finished	048-AIR-002	7/1/2016	7/14/2016	False	0.70	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350335	Created By PM Schedule	048-ACU-207	7/1/2016		False		Vendor or Contractor Work
FO-350336	Finished	140-ACU-002	7/1/2016	7/11/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350337	Finished	140-ACU-001	7/1/2016	7/13/2016	False	2.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350338	Finished	050-ACU-001	7/1/2016	7/11/2016	False	2.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350339	Finished	049-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350340	Finished	048-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

Requested Finished Open WND

% Finished

FO-350341	Finished	046-ACU-001	7/1/2016	7/20/2016	False	0.75	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350342	Finished	039-ACU-002	7/1/2016	7/18/2016	False	8.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350343	Finished	039-ACU-001	7/1/2016	7/18/2016	False	8.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350344	Finished	026-ACU-003	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350345	Finished	026-ACU-002	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350346	Finished	026-ACU-001	7/1/2016	6/28/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350347	Created By PM Schedule	043-ACU-001	7/1/2016		False	6.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Ran #3 chiller for several hours, Trane performed routine PM, no major problems found.							
FO-350902	Finished	048-GEN-001	7/12/2016	7/12/2016	False	0.65	Generator Maintenance, Monthly
FO-352461	Finished	130-GEN-001	7/27/2016	7/27/2016	False	0.00	Generator Maintenance, Monthly
E - Northeast			59	58	1	0	98%
FO-350348	Finished	062-DWBP-001	7/1/2016	7/11/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350349	Finished	062-DWBP-002	7/1/2016	7/8/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350350	Completed	067-ACU-109	7/1/2016	8/25/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350351	Finished	509-AIR-001	7/1/2016	7/11/2016	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
changed oil checked belt. cleaned air inlet filter, checked operation of control switch, checked operation of auto drain							
FO-350352	Completed	065-HWP-006	7/1/2016	7/14/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350353	Completed	065-DWBP-001	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350354	Completed	065-DWBP-002	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350355	Completed	067-DWBP-002	7/1/2016	7/15/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350356	Finished	510-AIR-001	7/1/2016	7/19/2016	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
inspected belts drained oil topped off each checked operation							
FO-350357	Created By PM Schedule	065-ACU-001	7/1/2016		False	0.00	PM - Water/Air Cooled Condenser
FO-350358	Completed	065-ACU-002	7/1/2016	8/4/2016	False	2.00	PM - Water/Air Cooled Condenser
FO-350359	Completed	065-ACU-003	7/1/2016	8/23/2016	False	2.00	PM - Water/Air Cooled Condenser
FO-350360	Completed	065-ACU-005	7/1/2016	8/24/2016	False	2.00	PM - Water/Air Cooled Condenser
FO-350361	Completed	065-ACU-007	7/1/2016	8/2/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350362	Completed	065-ACU-009	7/1/2016	8/2/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350363	Completed	065-ACU-010	7/1/2016	8/2/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350364	Completed	066-ACU-001	7/1/2016	8/1/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350365	Completed	066-ACU-002	7/1/2016	8/1/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350366	Completed	066-ACU-003	7/1/2016	8/1/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350367	Completed	067-ACU-001	7/1/2016	8/3/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350368	Completed	067-ACU-002	7/1/2016	8/17/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350369	Completed	067-ACU-003	7/1/2016	8/1/2016	False	1.00	PM - Water/Air Cooled Condenser
FO-350370	Completed	067-ACU-109	7/1/2016	8/4/2016	False	2.00	PM - Water/Air Cooled Condenser
FO-350371	Finished	509-ACU-001	7/1/2016	8/3/2016	False	2.00	PM - Water/Air Cooled Condenser
cleaned pump strainer, condenser strainer, lubricated pump checked operation							

Requested Finished Open WND

% Finished

FO-350372	Finished	509-ACU-002	7/1/2016	8/5/2016	False	2.00	PM - Water/Air Cooled Condenser
Cleaned pump strainer, cleaned condenser strainer, lubricated pump checked operation							
FO-350373	Finished	510-ACU-001	7/1/2016	8/18/2016	False	3.00	PM - Water/Air Cooled Condenser
cleaned air cooled condenser							
FO-350374	Finished	060-DWBP-001	7/1/2016	7/1/2016	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-350375	Finished	193-ACU-001	7/1/2016	7/11/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350376	Finished	062-ACU-002	7/1/2016	7/27/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350377	Finished	062-ACU-001	7/1/2016	7/26/2016	False	4.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350378	Finished	067-ACU-109	7/1/2016	7/6/2016	False	3.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350379	Finished	193-ACU-002	7/1/2016	7/6/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350380	Finished	203-ACU-001	7/1/2016	7/6/2016	False	2.00	Clean condenser coils
FO-350381	Finished	203-ACU-002	7/1/2016	7/7/2016	False	1.50	Clean condenser coils
FO-350382	Finished	203-ACU-003	7/1/2016	7/7/2016	False		Clean condenser coils
FO-350383	Finished	209-AHU-005	7/1/2016	7/28/2016	False	3.00	Replace PRE-filters
FO-350384	Finished	209-AHU-004B	7/1/2016	7/26/2016	False	2.50	Replace PRE-filters
FO-350385	Finished	209-AHU-004A	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350386	Finished	209-AHU-003	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350387	Finished	209-AHU-002	7/1/2016	7/27/2016	False	2.50	Replace PRE-filters
FO-350388	Finished	209-AHU-001	7/1/2016	7/30/2016	False	2.50	Replace PRE-filters
FO-350893	Finished	203-GEN-001	7/19/2016	7/19/2016	False	1.50	Generator Maintenance, Monthly
FO-350899	Finished	527-GEN-001	7/21/2016	7/21/2016	False	2.00	Generator Maintenance, Monthly
preformed test, checked fluid levels and lover operation							
FO-350903	Finished	193-GEN-001	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350907	Finished	GEN-001 (Towa	7/13/2016	7/8/2016	False	1.00	Generator Maintenance, Monthly
FO-350911	Finished	193-GEN-002	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350913	Finished	193-GEN-003	7/1/2016	7/1/2016	False	1.00	Generator Maintenance, Monthly
FO-350915	Finished	193-GEN-004	7/1/2016	7/11/2016	False	1.00	Generator Maintenance, Monthly
FO-350926	Finished	209-GEN-001	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350928	Finished	209-GEN-003	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350930	Finished	209-GEN-004	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350933	Finished	209-GEN-002	7/7/2016	7/7/2016	False	1.00	Generator Maintenance, Monthly
FO-350934	Finished	211-GEN-001	7/1/2016	7/6/2016	False	1.50	Generator Maintenance, Monthly
FO-350935	Finished	211-GEN-002	7/1/2016	7/6/2016	False	1.00	Generator Maintenance, Monthly
FO-351078	Finished	062-ACU-003	7/7/2016	7/7/2016	False	1.00	PM - Semi Anunal Air Handling Unit Inspection
FO-351398	Finished	510-HEX-001	7/15/2016	8/3/2016	False	1.50	PM - Heat Exchanger and Economizer
checked for leaks, lubricated pumps, checked operation							
FO-352477	Completed	066-GEN-001	7/27/2016	7/28/2016	False	1.00	Generator Maintenance, Monthly
FO-352480	Finished	060-GEN-001A	7/28/2016	7/28/2016	False	1.00	Generator Maintenance, Monthly
FO-352481	Finished	060-GEN-001B	7/28/2016	7/29/2016	False	1.00	Generator Maintenance, Monthly

E - Preventative Maintenance

223 184 34 5

83%

FO-338420	Created By PM Schedule	608-EXF-001	7/1/2016	False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
-----------	------------------------	-------------	----------	-------	--	--

Requested Finished Open WND

% Finished

FO-338421	Created By PM Schedule	608-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338422	Created By PM Schedule	608-EXF-004	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338426	Created By PM Schedule	608-EXF-010	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344078	Finished	612-AHU-005C	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-344079	Finished	612-AHU-005B	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-344080	Finished	612-AHU-005A	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-346533	Created By PM Schedule	067-EXF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346534	Created By PM Schedule	067-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346535	Created By PM Schedule	067-EXF-003	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346536	Created By PM Schedule	067-EXF-004	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346662	Cancelled	499-AHU-006	7/1/2016		True		Replace PRE-filters
Unit not currently being run. Unit deactivated on 6-31-16.							
FO-346667	Created By PM Schedule	067-AHU-003	7/1/2016		False		Replace PRE-filters
FO-346668	Created By PM Schedule	067-AHU-001	7/1/2016		False		Replace PRE-filters
FO-346675	Finished	067-EXF-005	7/1/2016	5/23/2016	False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346676	Created By PM Schedule	067-EXF-006	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348743	Finished	096-EXF-001	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348744	Finished	096-EXF-002	7/1/2016	7/19/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348745	Finished	096-EXF-003	7/1/2016	7/19/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348746	Finished	096-EXF-021	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348747	Finished	096-EXF-022	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348748	Finished	096-EXF-023	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348749	Finished	096-EXF-020	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348750	Finished	193-EXF-001	7/1/2016	7/13/2016	False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348751	Finished	612-RAF-001	7/1/2016	8/17/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348752	Finished	612-RAF-002	7/1/2016	8/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348753	Finished	612-RAF-003	7/1/2016	8/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348754	Finished	612-RAF-004	7/1/2016	8/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348755	Finished	612-RAF-005	7/1/2016	8/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348756	Finished	612-RAF-006	7/1/2016	8/17/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348757	Finished	612-RAF-008	7/1/2016	8/17/2016	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348758	Finished	003-EXF-001	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348759	Finished	003-EXF-002	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348760	Finished	003-EXF-003	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348761	Finished	003-EXF-004	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348762	Finished	003-EXF-005	7/1/2016	7/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348763	Finished	003-EXF-006	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348764	Finished	003-EXF-007	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348765	Finished	003-EXF-008	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348766	Finished	003-EXF-009	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348767	Finished	003-EXF-010	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348768	Finished	003-EXF-011	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348769	Finished	003-EXF-013	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348770	Finished	167-EXF-001	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-348771	Finished	167-EXF-002	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348772	Finished	167-EXF-003	7/1/2016	7/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348773	Finished	096-EXF-018	7/1/2016	7/19/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348774	Finished	096-EXF-019	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348775	Finished	096-EXF-025	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348776	Finished	096-EXF-026	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348777	Finished	096-EXF-027	7/1/2016	7/19/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348778	Finished	499-EXF-001	7/1/2016	7/16/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348779	Finished	169-EXF-005	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348780	Finished	169-EXF-001	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348781	Finished	169-EXF-002	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348782	Finished	169-EXF-003	7/1/2016	7/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348783	Finished	169-EXF-004	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348784	Finished	169-EXF-005	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348785	Finished	169-EXF-006	7/1/2016	7/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348786	Finished	080-EXF-003	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348787	Finished	080-EXF-004	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348788	Finished	080-EXF-007	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348789	Finished	080-EXF-201	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348790	Finished	080-EXF-253	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348791	Finished	080-EXF-269	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348792	Finished	080-EXF-274	7/1/2016	7/7/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348793	Finished	166-EXF-001	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348794	Finished	166-EXF-002	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348795	Finished	166-EXF-003	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348796	Finished	166-EXF-004	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348797	Finished	166-EXF-005	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348798	Finished	166-EXF-006	7/1/2016	7/25/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348799	Finished	166-EXF-007	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348800	Finished	166-EXF-008	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348801	Finished	166-EXF-009	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348802	Finished	166-EXF-010	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348803	Finished	166-EXF-011	7/1/2016	7/26/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348804	Finished	166-EXF-012	7/1/2016	7/27/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348805	Finished	166-EXF-013	7/1/2016	7/27/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348806	Finished	046-FAP-001	7/1/2016	7/20/2016	False	0.20	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348807	Finished	048-FAP-001	7/1/2016	7/13/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348808	Finished	049-FAP-001	7/1/2016	7/20/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348809	Finished	003-EXF-014	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348810	Finished	003-EXF-015	7/1/2016	7/20/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348811	Finished	156-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348812	Finished	499-FAP-001	7/1/2016	7/21/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348813	Finished	620-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348814	Finished	036-FP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-348815	Finished	025-FP-001	7/1/2016	7/14/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348816	Finished	007-FP-001	7/1/2016	7/29/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348817	Finished	001-FP-001	7/1/2016	7/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348818	Finished	005-FAP-001	7/1/2016	7/29/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348819	Finished	040-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348820	Finished	038-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348821	Finished	028-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348822	Finished	026-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348823	Finished	022-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348824	Finished	017-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348825	Finished	016-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348826	Finished	003-FAP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348827	Finished	006-FP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348828	Finished	050-FAP-001	7/1/2016	7/14/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348829	Finished	043-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348830	Finished	042-FAP-001	7/1/2016	7/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348831	Finished	062-FP-001	7/1/2016	7/14/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348832	Finished	065-FP-001	7/1/2016	7/13/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348833	Finished	068-FAP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348834	Finished	067-FP-001	7/1/2016	7/13/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348835	Finished	089-FP-001	7/1/2016	7/28/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348836	Finished	082-FP-001	7/1/2016	7/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348837	Finished	080-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348838	Created By PM Schedule	090-FP-001	7/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348839	Finished	155-FP-001	7/1/2016	7/20/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348840	Finished	150-FAP-001	7/1/2016	7/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348841	Finished	167-FAP-001	7/1/2016	7/29/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348842	Finished	166-FP-001	7/1/2016	7/29/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348843	Finished	140-FAP-001	7/1/2016	7/14/2016	False	35.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348844	Finished	130-FP-001	7/1/2016	7/14/2016	False	39.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348845	Finished	193-FAP-001	7/1/2016	8/1/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348846	Finished	189-FP-001	7/1/2016	7/14/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348847	Finished	510-FAP-001	7/1/2016	7/12/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348848	Finished	509-FAP-001	7/1/2016	7/12/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348849	Finished	504-FAP-001	7/1/2016	7/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348850	Finished	629-FP-001	7/1/2016	7/25/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348851	Finished	612-FP-001	7/1/2016	7/29/2016	False	3.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348852	Finished	611-FP-001	7/1/2016	7/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348853	Finished	609-FP-001	7/1/2016	7/26/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348854	Finished	603-FP-001	7/1/2016	7/25/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348855	Finished	608-FP-001	7/1/2016	5/23/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348856	Finished	612-AHU-014	7/1/2016	8/16/2016	False	3.00	Replace PRE-filters
FO-348857	Finished	612-AHU-013	7/1/2016	7/28/2016	False	10.00	Replace PRE-filters
FO-348858	Created By PM Schedule	612-AHU-012	7/1/2016		False		Replace PRE-filters

Requested Finished Open WND

% Finished

FO-348859	Finished	612-AHU-011	7/1/2016	8/30/2016	False	6.00	Replace PRE-filters
FO-348860	Finished	612-AHU-010	7/1/2016	8/30/2016	False	4.00	Replace PRE-filters
FO-348861	Created By PM Schedule	612-AHU-009	7/1/2016		False		Replace PRE-filters
FO-348862	Created By PM Schedule	612-AHU-008	7/1/2016		False		Replace PRE-filters
FO-348863	Finished	612-AHU-007	7/1/2016	8/24/2016	False	6.00	Replace PRE-filters
FO-348864	Finished	612-AHU-003	7/1/2016	8/16/2016	False	3.00	Replace PRE-filters
FO-348865	Finished	612-AHU-002	7/1/2016	8/16/2016	False	2.00	Replace PRE-filters
FO-348866	Finished	612-AHU-001	7/1/2016	8/11/2016	False	4.00	Replace PRE-filters
FO-348867	Finished	074-FAP-001	7/1/2016	7/14/2016	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348868	Finished	167-AHU-002	7/1/2016	7/7/2016	False	2.00	Replace PRE-filters
FO-348869	Finished	167-AHU-001	7/1/2016	7/7/2016	False	2.00	Replace PRE-filters
FO-348870	Finished	003-AHU-008	7/1/2016	7/20/2016	False	0.75	Replace PRE-filters
FO-348871	Completed	003-AHU-007	7/1/2016		True		Replace PRE-filters
FO-348872	Finished	003-AHU-006	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348873	Finished	003-AHU-005	7/1/2016	7/27/2016	False	1.50	Replace PRE-filters
FO-348874	Finished	003-AHU-004	7/1/2016	7/14/2016	False	1.50	Replace PRE-filters
FO-348875	Finished	003-AHU-003	7/1/2016	7/11/2016	False	1.50	Replace PRE-filters
FO-348876	Finished	003-AHU-002	7/1/2016	7/13/2016	False	1.00	Replace PRE-filters
FO-348877	Completed	003-AHU-001	7/1/2016		True		Replace PRE-filters
FO-348878	Created By PM Schedule	141-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348879	Created By PM Schedule	074-AHU-004	7/1/2016		False		Replace PRE-filters
FO-348880	Created By PM Schedule	074-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348881	Created By PM Schedule	074-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348882	Created By PM Schedule	074-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348883	Created By PM Schedule	193-AHU-004	7/1/2016		False		Replace PRE-filters
FO-348884	Created By PM Schedule	193-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348885	Created By PM Schedule	193-AHU-002	7/1/2016		False		Replace PRE-filters
FO-348886	Created By PM Schedule	193-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348887	Finished	096-SAF-FC1	7/1/2016	7/28/2016	False	0.50	Replace PRE-filters
FO-348888	Finished	096-SAF-00E	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348889	Finished	096-SAF-001	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348890	Finished	096-RAF-010	7/1/2016	7/28/2016	False	1.00	Replace PRE-filters
FO-348891	Finished	096-RAF-00B	7/1/2016	7/28/2016	False	1.50	Replace PRE-filters
FO-348892	Finished	096-RAF-009	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348893	Finished	096-RAF-008	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348894	Finished	096-RAF-007	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348895	Finished	096-RAF-006	7/1/2016	7/27/2016	False	2.00	Replace PRE-filters
FO-348896	Finished	096-RAF-005	7/1/2016	7/26/2016	False	1.50	Replace PRE-filters
FO-348897	Finished	096-RAF-004	7/1/2016	7/26/2016	False	2.75	Replace PRE-filters
FO-348898	Finished	096-RAF-003	7/1/2016	7/26/2016	False	2.25	Replace PRE-filters
FO-348899	Finished	096-RAF-002	7/1/2016	7/26/2016	False	2.00	Replace PRE-filters
FO-348900	Finished	155-AHU-005	7/1/2016	7/14/2016	False	1.50	Replace PRE-filters
FO-348901	Finished	155-AHU-004	7/1/2016	7/14/2016	False	3.50	Replace PRE-filters
FO-348902	Finished	155-AHU-003	7/1/2016	7/13/2016	False	3.50	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-348903	Finished	155-AHU-002	7/1/2016	7/12/2016	False	3.50	Replace PRE-filters
FO-348904	Finished	155-AHU-001	7/1/2016	7/12/2016	False	3.50	Replace PRE-filters
FO-348907	Finished	499-AHU-007	7/1/2016	7/15/2016	False	3.00	Replace PRE-filters
FO-348908	Finished	499-AHU-005	7/1/2016	7/19/2016	False	2.00	Replace PRE-filters
FO-348909	Finished	499-AHU-004	7/1/2016	7/19/2016	False	3.00	Replace PRE-filters
FO-348911	Finished	080-EXF-006	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348912	Finished	080-EXF-005	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348913	Finished	080-EXF-001	7/1/2016	7/7/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348914	Finished	150-EXF-002	7/1/2016	7/8/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348915	Created By PM Schedule	612-HVU-001	7/1/2016		False		Replace PRE-filters
FO-348916	Finished	096-FP-001	7/1/2016	7/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348917	Completed	150-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348918	Completed	150-AHU-002	7/1/2016		True		Replace PRE-filters
FO-348919	Completed	150-AHU-001	7/1/2016		True		Replace PRE-filters
FO-348920	Finished	169-FAP-001	7/1/2016	7/28/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348921	Finished	608-AHU-004	7/1/2016	8/31/2016	False	2.00	Replace PRE-filters
FO-348922	Created By PM Schedule	608-AHU-003	7/1/2016		False		Replace PRE-filters
FO-348923	Created By PM Schedule	608-AHU-002	7/1/2016		False	0.00	Replace PRE-filters
FO-348924	Created By PM Schedule	608-AHU-001	7/1/2016		False		Replace PRE-filters
FO-348925	Finished	499-AHU-008	7/1/2016	7/16/2016	False	2.50	Replace PRE-filters
FO-348926	Created By PM Schedule	074-AHU-005	7/1/2016		False		Replace PRE-filters
FO-348928	Finished	637-FP-001	7/1/2016	7/20/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-348956	Finished	499-AHU-003	7/1/2016	7/15/2016	False	0.75	Replace PRE-filters
FO-348957	Finished	499-AHU-002	7/1/2016	7/14/2016	False	0.75	Replace PRE-filters
FO-348959	Finished	499-AHU-001	7/1/2016	7/14/2016	False	0.75	Replace PRE-filters
FO-348960	Finished	096-EXF-028	7/1/2016	7/22/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348961	Created By PM Schedule	096-EXF-024	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348962	Finished	096-EXF-017	7/1/2016	7/22/2016	False	1.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348963	Created By PM Schedule	096-EXF-016	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348964	Created By PM Schedule	096-EXF-015	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348965	Finished	096-EXF-014	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348966	Finished	096-EXF-013	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348967	Finished	096-EXF-012	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348968	Finished	096-EXF-011	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348969	Finished	096-EXF-010	7/1/2016	7/22/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348970	Finished	096-EXF-009	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348971	Finished	096-EXF-008	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348972	Finished	096-EXF-007	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348973	Finished	096-EXF-006	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348974	Finished	096-EXF-005	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348975	Finished	096-EXF-004	7/1/2016	7/21/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348980	Finished	080-ACU-004	7/1/2016	7/21/2016	False	0.75	Replace PRE-filters
FO-348981	Finished	080-ACU-003	7/1/2016	7/6/2016	False	1.50	Replace PRE-filters
FO-348982	Finished	080-ACU-002	7/1/2016	7/6/2016	False	1.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-348983	Finished	080-ACU-001	7/1/2016	7/6/2016	False	1.00	Replace PRE-filters
FO-350153	Finished	096-00600.00	7/1/2016	7/28/2016	False	1.00	UBW-001-600 (Need to add to TMA Equipment Inventory) Replace PRE-filters
FO-351573	Created By PM Schedule	499-EXF-006	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - South			39	35	3	1	90%
FO-350389	Finished	090-AIR-001	7/1/2016	7/25/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350390	Finished	090-AIR-002	7/1/2016	7/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350393	Finished	090-AIR-004	7/1/2016	7/29/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350397	Finished	089-DWBP-001	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350398	Finished	089-DWBP-002	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350399	Finished	089-DWBP-003	7/1/2016	7/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-350452	Finished	090-SP-002	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350453	Finished	090-SP-003	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350454	Finished	090-SP-006	7/1/2016	7/21/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-350455	Finished	006-VPS-001	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350456	Finished	006-VPS-002	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350457	Finished	006-DWBP-001	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350458	Finished	006-DWBP-002	7/1/2016	7/7/2016	False		PM - Centrifugal Pump, over 1 H.P.
Unit not in use.							
FO-350466	Finished	090-ACU-CR1	7/1/2016	7/8/2016	True	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
Cancelled. Changed from monthly to quarterly PM.							
Last PM: June 2016							
Next PM: September 2016							
FO-350495	Created By PM Schedule	127-EXF-002	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350496	Created By PM Schedule	127-EXF-001	7/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350506	Finished	090-AIR-541	7/1/2016	7/14/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350507	Finished	090-SSF-541	7/1/2016	7/12/2016	False	1.00	PM - Harmsco Side Stream Filter
FO-350513	Finished	089-ACU-001	7/1/2016	7/19/2016	False	1.00	PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350514	Created By PM Schedule	016-ACU-004	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350515	Finished	006-ACU-001	7/1/2016	7/13/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
UNIT IS NO LONGER IN SERVICE.							
FO-350518	Finished	090-ACU-403	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350519	Finished	090-ACU-402	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350520	Finished	090-ACU-401	7/1/2016	7/28/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350521	Finished	022-ACU-001	7/1/2016	7/5/2016	False	2.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Checked operation of the unit and the boilers for supplying steam to the absorber. Checked solution level, checked all instruments and gauges for proper operation and reading. checked the purge pump for proper operation. Changed purge pump oil. Checked for any unusual noise and vibration. Cleaned tower pumps strainers on pump # 1&2.							

Requested Finished Open WND

% Finished

FO-350522	Finished	007-ACU-002	7/1/2016	7/27/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Contractors checked machine. Oil samples taken.						
FO-350523	Finished	007-ACU-001	7/1/2016	7/27/2016	False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Contractor performed PM. Oil samples taken.						
FO-350871	Finished	007-GEN-001	7/14/2016	7/14/2016	False	0.50 Generator Maintenance, Monthly
FO-350873	Finished	007-GEN-002	7/7/2016	7/14/2016	False	0.50 Generator Maintenance, Monthly
FO-350875	Finished	090-GEN-001	7/14/2016	7/20/2016	False	1.00 Generator Maintenance, Monthly
FO-350877	Finished	089-GEN-001	7/20/2016	7/26/2016	False	1.00 Generator Maintenance, Monthly
FO-350896	Finished	090-GEN-002	7/14/2016	7/14/2016	False	1.00 Generator Maintenance, Monthly
FO-350909	Finished	006-GEN-001	7/21/2016	7/21/2016	False	0.40 Generator Maintenance, Monthly
FO-350919	Created By PM Schedule	003-GEN-001	7/6/2016		False	Generator Maintenance, Monthly
FO-350921	Finished	005-GEN-001	7/6/2016	7/7/2016	False	0.50 Generator Maintenance, Monthly
FO-350923	Finished	090-GEN-003	7/14/2016	7/14/2016	False	1.00 Generator Maintenance, Monthly
FO-351079	Finished	090-ACU-CR2	7/8/2016	7/7/2016	False	0.50 Monthly AHU Inspection Clean Room Unit 2
FO-351080	Finished	090-ACU-CR2	7/8/2016	7/7/2016	False	0.50 PM - Semi Anunal Air Handling Unit Inspection
FO-351083	Finished	090-EW-001	7/9/2016	7/6/2016	False	1.00 PM - Emergency Shower/Eyewash Station - Annual Flow Test

E - Southeast

92

3

37

52

3%

FO-350391	Created By PM Schedule	022-HEX-001	7/1/2016		False	PM - Heat Exchanger and Economizer
FO-350392	Completed	001-AIR-001	7/1/2016		True	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350400	Completed	001-FCU-0159-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350401	Completed	001-FCU-0159-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350402	Completed	001-FCU-0162-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350403	Completed	001-FCU-0162-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350404	Completed	001-FCU-0162-3	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350405	Completed	001-FCU-0165-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350406	Completed	001-FCU-0165-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350407	Completed	001-FCU-0165-3	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350408	Completed	001-FCU-0168-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350409	Completed	001-FCU-0168-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350410	Completed	001-FCU-0168-3	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350411	Completed	001-FCU-0171-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350412	Completed	001-FCU-0171-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350413	Completed	001-FCU-0174-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350414	Completed	001-FCU-0174-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350415	Completed	001-FCU-0174-3	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350416	Completed	001-FCU-3210-1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350417	Completed	001-FCU-3210-2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350418	Completed	001-FCU-3214	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350419	Completed	001-FCU-3216	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350420	Completed	001-FCU-3225.1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350421	Completed	001-FCU-3225.1	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350422	Completed	001-FCU-3225.2	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350423	Completed	001-FCU-3225.3	7/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-350424	Completed	001-FCU-3225.4	7/1/2016		True	PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-350425	Completed	001-FCU-3225.5	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350426	Completed	001-FCU-3225.6	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350427	Completed	001-FCU-3225.7	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350428	Completed	001-FCU-3225.8	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350429	Completed	001-FCU-3225.1	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350430	Completed	001-FCU-3226.1	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350431	Completed	001-FCU-3226.2	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350432	Completed	001-FCU-3226.3	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350433	Completed	001-FCU-3226.4	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350434	Completed	001-FCU-3226.5	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350435	Completed	001-FCU-3226.6	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350436	Completed	001-FCU-3226.7	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350437	Completed	001-FCU-3303-1	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350438	Completed	001-FCU-3303-2	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350439	Completed	001-FCU-3303-3	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350440	Completed	001-FCU-3337	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350441	Completed	001-FCU-3347	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350442	Completed	001-FCU-3349	7/1/2016	False	1.50	PM - Fan Coil/HV/AC Unit
FO-350443	Completed	001-FCU-3357	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350444	Completed	001-FCU-3361	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350445	Completed	001-FCU-3365	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350446	Completed	001-FCU-3384-1	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350447	Completed	001-FCU-3384-2	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350459	Created By PM Schedule	071-HWP-024	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350460	Created By PM Schedule	071-HWP-025	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350461	Created By PM Schedule	071-HWP-026	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350462	Created By PM Schedule	189-AIR-001	7/1/2016	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350463	Created By PM Schedule	499-AIR-001	7/1/2016	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350465	Completed	001-FCU-3225	7/1/2016	True		PM - Fan Coil/HV/AC Unit
FO-350480	Created By PM Schedule	071-ACU-012	7/1/2016	False		PM - Fan Coil/HV/AC Unit
FO-350481	Created By PM Schedule	071-ACU-013	7/1/2016	False		PM - Fan Coil/HV/AC Unit
FO-350482	Created By PM Schedule	071-HWP-217	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350483	Created By PM Schedule	071-HWP-218	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350484	Created By PM Schedule	071-HWP-219	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350485	Created By PM Schedule	071-HWP-221	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350486	Created By PM Schedule	071-HWP-220	7/1/2016	False		PM - Heat Pumps (5057 Woodward)
FO-350487	Created By PM Schedule	071-ACU-014	7/1/2016	False		PM - Fan Coil/HV/AC Unit
FO-350488	Created By PM Schedule	071-ACU-015	7/1/2016	False		PM - Fan Coil/HV/AC Unit
FO-350508	Created By PM Schedule	637-ACU-003	7/1/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350509	Created By PM Schedule	637-ACU-002	7/1/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350510	Created By PM Schedule	499-ACU-001	7/1/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

Requested Finished Open WND

% Finished

FO-350516	Created By PM Schedule	082-ACU-003	7/1/2016		False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350524	Completed	001-ACU-003	7/1/2016		True		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350525	Completed	001-ACU-002	7/1/2016		True		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350526	Completed	001-ACU-001	7/1/2016		True		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350528	Created By PM Schedule	189-ACU-003	7/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350881	Finished	637-GEN-001	7/19/2016	7/20/2016	False		Generator Maintenance, Monthly
FO-350883	Finished	637-GEN-002	7/19/2016	7/20/2016	False		Generator Maintenance, Monthly
FO-351082	Finished	001-EW-004	7/9/2016	8/24/2016	False	0.50	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-351399	Created By PM Schedule	499-CFP-001	7/15/2016		False		PM - Chemical Feed/Metering Pump/Controller
FO-351400	Created By PM Schedule	499-CFP-002	7/15/2016		False		PM - Chemical Feed/Metering Pump/Controller
FO-351401	Created By PM Schedule	499-CFP-003	7/15/2016		False		PM - Chemical Feed/Metering Pump/Controller
FO-351402	Created By PM Schedule	499-CFP-004	7/15/2016		False		PM - Chemical Feed/Metering Pump/Controller
FO-351983	Created By PM Schedule	082-HWH-001	7/23/2016		False		PM - Domestic Water Heater, Gas
FO-351985	Created By PM Schedule	071-EXF-006	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351986	Created By PM Schedule	071-EXF-007	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351987	Created By PM Schedule	071-EXF-008	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351988	Created By PM Schedule	071-EXF-009	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351989	Created By PM Schedule	071-EXF-010	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351990	Created By PM Schedule	071-EXF-011	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351991	Created By PM Schedule	071-EXF-012	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351992	Created By PM Schedule	071-EXF-013	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351993	Created By PM Schedule	071-EXF-014	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351994	Created By PM Schedule	071-EXF-015	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351995	Created By PM Schedule	071-EXF-016	7/24/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - West			37	32	5	0	86%
FO-350394	Finished	155-AIR-001	7/1/2016	7/31/2016	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350395	Finished	155-SRS-001	7/1/2016	7/31/2016	False		PM - Unspecified
FO-350396	Finished	155-SRS-002	7/1/2016	7/31/2016	False		PM - Unspecified
FO-350448	Created By PM Schedule	003-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350449	Created By PM Schedule	003-AIR-003	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350450	Created By PM Schedule	003-AIR-004	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350451	Created By PM Schedule	167-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350464	Created By PM Schedule	150-AIR-001	7/1/2016		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350476	Finished	080-SP-001	7/1/2016	7/11/2016	False	1.00	PM - Sump Pump
FO-350477	Finished	080-SP-002	7/1/2016	7/11/2016	False	1.00	PM - Sump Pump
FO-350478	Finished	166-AIR-001	7/1/2016	8/28/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350479	Finished	156-AIR-001	7/1/2016	7/29/2016	False	0.75	PM - Air Compressor, Reciprocating 5-40 H.P.

Requested Finished Open WND

% Finished

FO-350511	Finished	155-ACU-002	7/1/2016	7/31/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350512	Finished	155-ACU-001	7/1/2016	7/31/2016	False		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350534	Finished	080-SAF-02A	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350535	Finished	080-SAF-01A	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350536	Finished	080-SAF-018	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350537	Finished	080-SAF-017	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350538	Finished	080-SAF-016	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350539	Finished	080-SAF-015	7/1/2016	7/7/2016	False	1.00	Replace PRE-filters
FO-350540	Finished	080-SAF-014	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350541	Finished	080-SAF-013	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350542	Finished	080-SAF-012	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350543	Finished	080-SAF-011	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350544	Finished	080-SAF-010	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350545	Finished	080-SAF-009	7/1/2016	7/8/2016	False	1.00	Replace PRE-filters
FO-350546	Finished	080-SAF-008	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
FO-350547	Finished	080-SAF-007	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
FO-350548	Finished	080-SAF-006	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
FO-350549	Finished	080-SAF-005	7/1/2016	7/11/2016	False	1.00	Replace PRE-filters
FO-350550	Finished	080-SAF-004	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
FO-350551	Finished	080-SAF-003	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
FO-350552	Finished	080-SAF-002	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
FO-350553	Finished	080-SAF-001	7/1/2016	7/18/2016	False	1.00	Replace PRE-filters
FO-350905	Finished	001 SPARE from	7/12/2016	8/12/2016	False		Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-351984	Finished	155-SP-001	7/24/2016	8/23/2016	False	PM - Sump Pump
FO-352611	Finished	169-GEN-001	7/28/2016	8/1/2016	False	Generator Maintenance, Monthly
Trades		112	97	15	0	87%
T - Electrician		71	58	13	0	82%
FO-350489	Finished	608-GEN-001	7/5/2016	7/5/2016	False	4.00 Generator Test
FO-350554	Finished	603-GEN-001	7/5/2016	7/5/2016	False	4.00 Generator Test
FO-350555	Finished	051-SP-001	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350556	Finished	051-SP-002	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350557	Finished	051-SP-003	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350558	Finished	051-SP-004	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350559	Finished	051-SP-005	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350560	Finished	051-SP-006	7/4/2016	7/18/2016	False	0.25 PM - Sump Pump
FO-350870	Finished	609-GEN-001	7/19/2016	7/19/2016	False	4.00 Generator Test
FO-350872	Created By PM Schedule	007-GEN-001	7/14/2016		False	2.00 Generator Test
FO-350874	Finished	007-GEN-002	7/14/2016	8/4/2016	False	2.00 Generator Test
Won't Transfer						
FO-350876	Finished	090-GEN-001	7/14/2016	7/19/2016	False	4.00 Generator Test
FO-350878	Finished	089-GEN-001	7/20/2016	7/20/2016	False	4.00 Generator Test
FO-350879	Finished	193-GEN-001	7/1/2016	7/8/2016	False	1.00 Generator Test
FO-350880	Finished	637-GEN-001	7/19/2016	7/19/2016	False	2.00 Generator Test
FO-350882	Finished	637-GEN-002	7/19/2016	7/19/2016	False	2.00 Generator Test
OUT OF SERVICE						
FO-350884	Finished	612-GEN-001	7/12/2016	7/12/2016	False	2.00 Generator Test
Fault alarm light blinking						
FO-350886	Finished	612-GEN-002	7/12/2016	7/12/2016	False	2.00 Generator Test
FO-350888	Finished	501-GEN-001	7/12/2016	7/12/2016	False	4.00 Generator Test
FO-350890	Finished	507-GEN-001	7/13/2016	7/13/2016	False	4.00 Generator Test
FO-350892	Finished	203-GEN-001	7/19/2016	7/19/2016	False	4.00 Generator Test
FO-350894	Finished	536-GEN-001	7/20/2016	7/20/2016	False	8.00 Generator Test
FO-350895	Finished	090-GEN-002	7/14/2016	7/14/2016	False	2.00 Generator Test
FO-350898	Finished	527-GEN-001	7/21/2016	7/21/2016	False	4.00 Generator Test
FO-350901	Finished	048-GEN-001	7/12/2016	7/12/2016	False	5.00 Generator Test
FO-350904	Finished	001 SPARE from	7/12/2016	7/12/2016	False	4.00 Generator Test
FO-350906	Finished	-GEN-001 (Towa	7/13/2016	7/13/2016	False	4.00 Generator Test
FO-350908	Finished	006-GEN-001	7/21/2016	7/21/2016	False	4.00 Generator Test
FO-350910	Finished	193-GEN-002	7/1/2016	7/8/2016	False	1.00 Generator Test
FO-350912	Finished	193-GEN-003	7/1/2016	7/8/2016	False	1.00 Generator Test
FO-350914	Finished	193-GEN-004	7/1/2016	7/8/2016	False	1.00 Generator Test
FO-350916	Finished	034-GEN-001	7/7/2016	7/7/2016	False	4.00 Generator Test
FO-350918	Finished	003-GEN-001	7/6/2016	7/6/2016	False	4.00 Generator Test
FO-350920	Finished	005-GEN-001	7/6/2016	7/6/2016	False	4.00 Generator Test
FO-350922	Finished	090-GEN-003	7/14/2016	7/14/2016	False	2.00 Generator Test
FO-350924	Finished	209-GEN-002	7/7/2016	7/7/2016	False	2.00 Generator Test

Requested Finished Open WND

% Finished

FO-350925	Finished	209-GEN-001	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350927	Finished	209-GEN-003	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350929	Finished	209-GEN-004	7/7/2016	7/7/2016	False	2.00	Generator Test
FO-350931	Finished	211-GEN-001	7/1/2016	7/8/2016	False	2.00	Generator Test
FO-350932	Finished	211-GEN-002	7/1/2016	7/8/2016	False	2.00	Generator Test
FO-351084	Finished	051-SP-001	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351085	Finished	051-SP-002	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351086	Finished	051-SP-003	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351087	Finished	051-SP-004	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351088	Finished	051-SP-005	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351089	Finished	051-SP-006	7/11/2016	8/2/2016	False	0.25	PM - Sump Pump
FO-351404	Created By PM Schedule	051-SP-001	7/18/2016		False		PM - Sump Pump
FO-351405	Created By PM Schedule	051-SP-002	7/18/2016		False		PM - Sump Pump
FO-351406	Created By PM Schedule	051-SP-003	7/18/2016		False		PM - Sump Pump
FO-351407	Created By PM Schedule	051-SP-004	7/18/2016		False		PM - Sump Pump
FO-351408	Created By PM Schedule	051-SP-005	7/18/2016		False		PM - Sump Pump
FO-351409	Created By PM Schedule	051-SP-006	7/18/2016		False		PM - Sump Pump
FO-351996	Finished	611-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-351997	Finished	104-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-351999	Finished	127-GEN-001	7/26/2016	7/26/2016	False	1.00	Generator Test
FO-352001	Finished	127-GEN-002	7/26/2016	7/26/2016	False		Generator Test
FO-352003	Finished	127-GEN-003	7/26/2016	7/26/2016	False		Generator Test
FO-352005	Finished	127-GEN-004	7/26/2016	7/26/2016	False		Generator Test
FO-352008	Created By PM Schedule	051-SP-001	7/25/2016		False		PM - Sump Pump
FO-352009	Created By PM Schedule	051-SP-002	7/25/2016		False		PM - Sump Pump
FO-352010	Created By PM Schedule	051-SP-003	7/25/2016		False		PM - Sump Pump
FO-352011	Created By PM Schedule	051-SP-004	7/25/2016		False		PM - Sump Pump
FO-352012	Created By PM Schedule	051-SP-005	7/25/2016		False		PM - Sump Pump
FO-352013	Created By PM Schedule	051-SP-006	7/25/2016		False		PM - Sump Pump
FO-352014	Finished	629-GEN-001	7/26/2016	7/26/2016	False	4.00	Generator Test
FO-352566	Finished	066-GEN-001	7/27/2016	7/29/2016	False	16.00	Generator Test
Low oil pressure alarm-call for svc							
FO-352567	Finished	130-GEN-001	7/27/2016	7/27/2016	False	4.00	Generator Test
FO-352610	Finished	169-GEN-001	7/28/2016	7/28/2016	False	4.00	Generator Test
FO-352613	Finished	060-GEN-001A	7/28/2016	7/28/2016	False	2.00	Generator Test
FO-352614	Finished	060-GEN-001B	7/28/2016	7/28/2016	False	2.00	Generator Test
T - Plumber			41	39	2	0	95%
FO-349097	Finished	042	7/1/2016	8/5/2016	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/7/1 ,,,,,,,,,,
FO-349098	Finished	527	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Main Drain with Copper Sulfate
FO-349099	Finished	608	7/1/2016	7/1/2016	False		*CANCELLED JWT
							PM - Waterless Urinals

Requested Finished Open WND

% Finished

FO-349100	Finished	049	7/1/2016	7/1/2016	False	*CANCELLED JWT
						PM - Waterless Urinals
FO-349101	Finished	090	7/1/2016	7/1/2016	False	*CANCELLED JWT
						PM - Waterless Urinals
FO-351329	Finished	629-PVB-002	7/1/2016	8/1/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351330	Finished	629-RPZ-002	7/1/2016	7/21/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351331	Finished	629-RPZ-003	7/1/2016	7/21/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351332	Finished	629-RPZ-004	7/1/2016	7/26/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351333	Finished	629-RPZ-005	7/1/2016	7/21/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16.
FO-351334	Finished	629-RPZ-006	7/1/2016	7/21/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351335	Finished	629-RPZ-007	7/1/2016	7/22/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351336	Finished	629-RPZ-008	7/1/2016	7/27/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351337	Created By PM Schedule	629-RPZ-009	7/1/2016		False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351338	Finished	629-RPZ-010	7/1/2016	7/28/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351339	Created By PM Schedule	629-RPZ-011	7/1/2016		False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351340	Finished	629-RPZ-012	7/1/2016	7/27/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351341	Finished	629-RPZ-013	7/1/2016	7/28/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351342	Finished	629-PVB-003	7/1/2016	8/1/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351343	Finished	629-PVB-001	7/1/2016	7/22/2016	False	2.00 PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351344	Finished	611-PVB-001	7/1/2016	7/14/2016	False	3.00 PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351345	Finished	611-RPZ-001	7/1/2016	7/15/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351346	Finished	611-RPZ-003	7/1/2016	7/15/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351347	Finished	611-RPZ-002	7/1/2016	7/12/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351348	Finished	611-RPZ-004	7/1/2016	7/15/2016	False	2.50 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351349	Finished	611-RPZ-005	7/1/2016	7/12/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351350	Finished	611-RPZ-006	7/1/2016	7/11/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351351	Finished	611-RPZ-007	7/1/2016	7/12/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351352	Finished	611-RPZ-008	7/1/2016	7/11/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351353	Finished	193-RPZ-001	7/1/2016	7/7/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351354	Finished	193-RPZ-002	7/1/2016	7/8/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351355	Finished	193-RPZ-003	7/1/2016	7/11/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351356	Finished	193-RPZ-004	7/1/2016	7/7/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351357	Finished	620-RPZ-001	7/1/2016	7/7/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351358	Finished	203-RPZ-001	7/1/2016	7/7/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351851	Finished	193-RPZ-005	7/1/2016	7/8/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/7/16
FO-352984	Finished	629-RPZ-015	7/1/2016	7/26/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB7/25/16
FO-352985	Finished	629-RPZ-018	7/1/2016	7/27/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352986	Finished	629-RPZ-017	7/1/2016	7/27/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352987	Finished	629-RPZ-016	7/1/2016	7/26/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352988	Finished	629-RPZ-019	7/1/2016	7/28/2016	False	2.00 PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16

Report Total

673

482

133

58

72%