

*DRAFT Facilities Operations PM DUE DATE Analysis from 1/1/2012 through 1/31/2013

Finish Date Due Date							Total per Trade		
Custodial							0 of 4	0%	
C-Director							0 of 4	0%	
FO-222044	Routine	Scheduled Maint. (PM)	7/16/2012	1/11/2006	-2378	Lighting Crew - Change Lights in Building			
FO-221369	Routine	Scheduled Maint. (PM)	7/16/2012	12/28/2005	-2392	Lighting Crew - Change Lights in Building			
FO-227314	Routine	Scheduled Maint. (PM)	9/18/2012	2/8/2006	-2414	Lighting Crew - Change Lights in Building			
FO-224771	Routine	Scheduled Maint. (PM)	9/18/2012	1/25/2006	-2428	Lighting Crew - Change Lights in Building			
Engineering							3930 of 5815	68%	
E - Afternoon Engineer							1943 of 2536	77%	
FO-208150	Routine	Scheduled Maint. (PM)	2/17/2012	4/28/2012	71	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-208148	Routine	Scheduled Maint. (PM)	2/16/2012	4/21/2012	65	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-208149	Routine	Scheduled Maint. (PM)	2/17/2012	4/21/2012	64	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-215448	Routine	Scheduled Maint. (PM)	4/1/2012	5/27/2012	56	PM - Fire Pump, Main/Jockey			
FO-215449	Routine	Scheduled Maint. (PM)	4/1/2012	5/27/2012	56	PM - Fire Pump, Main/Jockey			
FO-228804	Low	Scheduled Maint. (PM)	9/12/2012	10/31/2012	49	PM - Fire Alarm System Test			
FO-227404	Low	Scheduled Maint. (PM)	9/13/2012	10/28/2012	45	PM INSPECT AND CLEAN COIL			
FO-236974	Routine	Scheduled Maint. (PM)	12/14/2012	1/28/2013	45	PM - Fan Coil/HV/AC Unit			
FO-236975	Routine	Scheduled Maint. (PM)	12/14/2012	1/28/2013	45	PM - Fan Coil/HV/AC Unit			
FO-236976	Routine	Scheduled Maint. (PM)	12/14/2012	1/28/2013	45	PM - Fan Coil/HV/AC Unit			
FO-236977	Routine	Scheduled Maint. (PM)	12/14/2012	1/28/2013	45	PM - Fan Coil/HV/AC Unit			
FO-236978	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-236979	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-236980	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-236981	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-236982	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-236983	Routine	Scheduled Maint. (PM)	12/15/2012	1/28/2013	44	PM - Fan Coil/HV/AC Unit			
FO-227405	Low	Scheduled Maint. (PM)	9/15/2012	10/28/2012	43	PM INSPECT AND CLEAN COIL			
FO-228803	Low	Scheduled Maint. (PM)	9/19/2012	10/31/2012	42	PM - Fire Alarm System Test			
FO-238152	Routine	Scheduled Maint. (PM)	1/15/2013	2/26/2013	42	PM - Fire Pump, Main/Jockey			
FO-238153	Routine	Scheduled Maint. (PM)	1/16/2013	2/26/2013	41	PM - Fire Pump, Main/Jockey			
FO-236027	Routine	Scheduled Maint. (PM)	12/7/2012	1/16/2013	40	PM - Fire Pump, Main/Jockey			
FO-236033	Routine	Scheduled Maint. (PM)	12/7/2012	1/16/2013	40	PM - Fire Pump, Main/Jockey			
FO-211237	Routine	Scheduled Maint. (PM)	3/8/2012	4/16/2012	39	PM - Fire Pump, Main/Jockey			
FO-214866	Routine	Scheduled Maint. (PM)	4/12/2012	5/21/2012	39	PM - Fire Pump, Main/Jockey			
FO-230547	Routine	Scheduled Maint. (PM)	10/19/2012	11/27/2012	39	PM - Fire Pump, Main/Jockey			
FO-211238	Routine	Scheduled Maint. (PM)	3/9/2012	4/16/2012	38	PM - Fire Pump, Main/Jockey			
FO-230575	Routine	Scheduled Maint. (PM)	10/13/2012	11/20/2012	38	PM - Fire Pump, Main/Jockey			
FO-230702	Routine	Scheduled Maint. (PM)	10/19/2012	11/26/2012	38	PM - Fire Pump, Main/Jockey			
FO-211282	Low	Scheduled Maint. (PM)	3/9/2012	4/15/2012	37	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-237002	Routine	Scheduled Maint. (PM)	12/19/2012	1/25/2013	37	PM - Air Handling Unit			

			Finish Date	Due Date	Total per Trade	
FO-208168	Routine	Scheduled Maint. (PM)	2/13/2012	3/20/2012	36	PM - Air Handling Unit, over 50 Ton
FO-214834	Low	Scheduled Maint. (PM)	4/12/2012	5/17/2012	35	PM - Fan Motor Box (Old Main)
FO-214835	Low	Scheduled Maint. (PM)	4/12/2012	5/17/2012	35	PM - Fan Motor Box (Old Main)
FO-214836	Low	Scheduled Maint. (PM)	4/12/2012	5/17/2012	35	PM - Fan Motor Box (Old Main)
FO-214837	Low	Scheduled Maint. (PM)	4/12/2012	5/17/2012	35	PM - Fan Motor Box (Old Main)
FO-227335	Routine	Scheduled Maint. (PM)	9/12/2012	10/17/2012	35	PM - Fire Pump, Main/Jockey
FO-227570	Routine	Scheduled Maint. (PM)	9/12/2012	10/17/2012	35	PM - Fire Pump, Main/Jockey
FO-214830	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-214831	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-214832	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-214833	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-214838	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-214839	Low	Scheduled Maint. (PM)	4/13/2012	5/17/2012	34	PM - Fan Motor Box (Old Main)
FO-222471	Routine	Scheduled Maint. (PM)	7/18/2012	8/20/2012	33	PM - Fire Pump, Main/Jockey
FO-234275	Routine	Scheduled Maint. (PM)	11/14/2012	12/17/2012	33	PM - Air Handling Unit, over 50 Ton
FO-233618	Low	Scheduled Maint. (PM)	11/15/2012	12/17/2012	32	PM - Fire Pump, Main/Jockey
FO-237017	Routine	Scheduled Maint. (PM)	12/19/2012	1/20/2013	32	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215470	Routine	Scheduled Maint. (PM)	4/17/2012	5/18/2012	31	PM - Air Handling Unit, over 50 Ton
FO-225537	Routine	Scheduled Maint. (PM)	8/16/2012	9/16/2012	31	PM - Air Handling Unit, over 50 Ton
FO-230328	Routine	Scheduled Maint. (PM)	10/6/2012	11/6/2012	31	PM - Air Handling Unit, over 50 Ton
FO-232245	Routine	Scheduled Maint. (PM)	11/3/2012	12/4/2012	31	PM - Air Handling Unit, over 50 Ton
FO-235345	Routine	Scheduled Maint. (PM)	11/28/2012	12/29/2012	31	PM - Air Handling Unit, over 50 Ton
FO-235368	Routine	Scheduled Maint. (PM)	11/30/2012	12/31/2012	31	PM - Fan Coil/HV/AC Unit
FO-235369	Routine	Scheduled Maint. (PM)	11/30/2012	12/31/2012	31	PM - Fan Coil/HV/AC Unit
FO-235373	Routine	Scheduled Maint. (PM)	11/30/2012	12/31/2012	31	PM - Fan Coil/HV/AC Unit
FO-235374	Routine	Scheduled Maint. (PM)	11/30/2012	12/31/2012	31	PM - Fan Coil/HV/AC Unit
FO-221980	Routine	Scheduled Maint. (PM)	7/11/2012	8/10/2012	30	PM - Fire Pump, Main/Jockey
FO-221981	Routine	Scheduled Maint. (PM)	7/11/2012	8/10/2012	30	PM - Fire Pump, Main/Jockey
FO-222539	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222540	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222541	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222542	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222543	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222544	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-222545	Low	Scheduled Maint. (PM)	7/31/2012	8/30/2012	30	PM - Air Handling Unit, over 50 Ton
FO-230285	Routine	Scheduled Maint. (PM)	10/9/2012	11/8/2012	30	PM - Air Handling Unit, over 50 Ton
FO-230327	Routine	Scheduled Maint. (PM)	10/6/2012	11/5/2012	30	PM - Air Handling Unit, over 50 Ton
FO-230468	Low	Scheduled Maint. (PM)	10/9/2012	11/8/2012	30	Replace filters
FO-230469	Low	Scheduled Maint. (PM)	10/9/2012	11/8/2012	30	Replace filters
FO-230470	Low	Scheduled Maint. (PM)	10/9/2012	11/8/2012	30	Replace filters
FO-232800	Routine	Scheduled Maint. (PM)	11/2/2012	12/2/2012	30	PM - Air Handling Unit, over 50 Ton
FO-205250	Routine	Scheduled Maint. (PM)	1/27/2012	2/25/2012	29	PM - Fire Pump, Main/Jockey
FO-205249	Routine	Scheduled Maint. (PM)	1/27/2012	2/25/2012	29	PM - Fire Pump, Main/Jockey
FO-215425	Routine	Scheduled Maint. (PM)	4/16/2012	5/15/2012	29	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date			Total per Trade
FO-215427	Routine	Scheduled Maint. (PM)	4/16/2012	5/15/2012	29	PM - Air Handling Unit, over 50 Ton	
FO-221057	Routine	Scheduled Maint. (PM)	6/29/2012	7/28/2012	29	Monthly Fire System Test	
FO-222242	Routine	Scheduled Maint. (PM)	7/25/2012	8/23/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-222243	Routine	Scheduled Maint. (PM)	7/25/2012	8/23/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-222244	Routine	Scheduled Maint. (PM)	7/25/2012	8/23/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-222245	Routine	Scheduled Maint. (PM)	7/25/2012	8/23/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225045	Routine	Scheduled Maint. (PM)	8/9/2012	9/7/2012	29	PM - Fire Pump, Main/Jockey	
FO-225046	Routine	Scheduled Maint. (PM)	8/9/2012	9/7/2012	29	PM - Fire Pump, Main/Jockey	
FO-225580	Routine	Scheduled Maint. (PM)	9/21/2012	10/20/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225581	Routine	Scheduled Maint. (PM)	9/21/2012	10/20/2012	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-229582	Routine	Scheduled Maint. (PM)	10/2/2012	10/31/2012	29	Please perform PM on EF-3B1	
FO-229583	Routine	Scheduled Maint. (PM)	10/2/2012	10/31/2012	29	Please perform PM on EF-3B2	
FO-230284	Routine	Scheduled Maint. (PM)	10/10/2012	11/8/2012	29	PM - Air Handling Unit, over 50 Ton	
FO-230288	Routine	Scheduled Maint. (PM)	10/10/2012	11/8/2012	29	PM - Air Handling Unit, over 50 Ton	
FO-230289	Routine	Scheduled Maint. (PM)	10/10/2012	11/8/2012	29	PM - Air Handling Unit, over 50 Ton	
FO-230326	Routine	Scheduled Maint. (PM)	10/6/2012	11/4/2012	29	PM - Air Handling Unit, over 50 Ton	
FO-230372	Low	Scheduled Maint. (PM)	10/18/2012	11/16/2012	29	PM - Fan Motor Box (Old Main)	
FO-230373	Low	Scheduled Maint. (PM)	10/18/2012	11/16/2012	29	PM - Fan Motor Box (Old Main)	
FO-233560	Routine	Scheduled Maint. (PM)	11/15/2012	12/14/2012	29	PM - Fire Pump, Main/Jockey	
FO-213501	Routine	Scheduled Maint. (PM)	3/30/2012	4/27/2012	28	PM - Air Handling Unit, over 50 Ton	
FO-218788	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	Monthly Fire System Test	
FO-222240	Routine	Scheduled Maint. (PM)	7/18/2012	8/15/2012	28	PM - Air Handling Unit, over 50 Ton	
FO-229575	Routine	Scheduled Maint. (PM)	10/3/2012	10/31/2012	28	Perform PM on EF-1	
FO-229576	Routine	Scheduled Maint. (PM)	10/3/2012	10/31/2012	28	Please perform PM on EF-10A.	
FO-229577	Routine	Scheduled Maint. (PM)	10/3/2012	10/31/2012	28	Please perform PM on EF-10-B.	
FO-230287	Routine	Scheduled Maint. (PM)	10/11/2012	11/8/2012	28	PM - Air Handling Unit, over 50 Ton	
FO-230325	Routine	Scheduled Maint. (PM)	10/6/2012	11/3/2012	28	PM - Air Handling Unit, over 50 Ton	
FO-230375	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-230376	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-230377	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-230378	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-230379	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-230380	Low	Scheduled Maint. (PM)	10/19/2012	11/16/2012	28	PM - Fan Motor Box (Old Main)	
FO-234971	Routine	Scheduled Maint. (PM)	11/21/2012	12/19/2012	28	PM - Air Handling Unit, over 50 Ton	
FO-203817	Routine	Scheduled Maint. (PM)	1/5/2012	2/1/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-203818	Routine	Scheduled Maint. (PM)	1/5/2012	2/1/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-203819	Routine	Scheduled Maint. (PM)	1/5/2012	2/1/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-203837	Routine	Scheduled Maint. (PM)	1/6/2012	2/2/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-203838	Routine	Scheduled Maint. (PM)	1/6/2012	2/2/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-213502	Routine	Scheduled Maint. (PM)	4/6/2012	5/3/2012	27	PM - Fire Pump, Main/Jockey	
FO-213503	Routine	Scheduled Maint. (PM)	4/6/2012	5/3/2012	27	PM - Fire Pump, Main/Jockey	
FO-215429	Routine	Scheduled Maint. (PM)	4/18/2012	5/15/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-222241	Routine	Scheduled Maint. (PM)	7/19/2012	8/15/2012	27	PM - Air Handling Unit, over 50 Ton	
FO-227179	Routine	Scheduled Maint. (PM)	9/15/2012	10/12/2012	27	PM - Unit/Space Heater	

			Finish Date	Due Date			Total per Trade
FO-227181	Routine	Scheduled Maint. (PM)	9/15/2012	10/12/2012	27	PM - Unit/Space Heater	
FO-229578	Routine	Scheduled Maint. (PM)	10/4/2012	10/31/2012	27	Please perform PM on EF-1A.	
FO-229579	Routine	Scheduled Maint. (PM)	10/4/2012	10/31/2012	27	Please perform PM on EF-1B	
FO-229580	Routine	Scheduled Maint. (PM)	10/4/2012	10/31/2012	27	Please perform PM on EF-2A	
FO-229581	Routine	Scheduled Maint. (PM)	10/4/2012	10/31/2012	27	Please perform PM on EF-2B	
FO-230381	Low	Scheduled Maint. (PM)	10/20/2012	11/16/2012	27	PM - Fan Motor Box (Old Main)	
FO-230703	Routine	Scheduled Maint. (PM)	10/30/2012	11/26/2012	27	PM - Fire Pump, Main/Jockey	
FO-233561	Routine	Scheduled Maint. (PM)	11/17/2012	12/14/2012	27	PM - Fire Pump, Main/Jockey	
FO-208171	Routine	Scheduled Maint. (PM)	2/16/2012	3/13/2012	26	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208173	Routine	Scheduled Maint. (PM)	2/16/2012	3/13/2012	26	PM - Fan Coil/HV/AC Unit	
FO-222239	Routine	Scheduled Maint. (PM)	7/20/2012	8/15/2012	26	PM - Air Handling Unit, over 50 Ton	
FO-229584	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	Please perform PM on EF-5A	
FO-229585	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	Please perform PM on EF-5B	
FO-229586	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	Please perform PM on EF-6A	
FO-236064	Routine	Scheduled Maint. (PM)	12/8/2012	1/3/2013	26	PM - Air Handling Unit, over 50 Ton	
FO-237897	Routine	Scheduled Maint. (PM)	1/19/2013	2/14/2013	26	PM - Air Handling Unit	
FO-205278	Routine	Scheduled Maint. (PM)	1/26/2012	2/20/2012	25	PM - Fire Pump, Main/Jockey	
FO-210838	Routine	Scheduled Maint. (PM)	3/1/2012	3/26/2012	25	PM - Unit/Space Heater	
FO-210839	Routine	Scheduled Maint. (PM)	3/1/2012	3/26/2012	25	PM - Unit/Space Heater	
FO-214176	Routine	Scheduled Maint. (PM)	4/3/2012	4/28/2012	25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215426	Routine	Scheduled Maint. (PM)	4/20/2012	5/15/2012	25	PM - Air Handling Unit, over 50 Ton	
FO-215428	Routine	Scheduled Maint. (PM)	4/20/2012	5/15/2012	25	PM - Air Handling Unit, over 50 Ton	
FO-215468	Routine	Scheduled Maint. (PM)	5/3/2012	5/28/2012	25	PM - Fire Pump, Main/Jockey	
FO-218777	Routine	Scheduled Maint. (PM)	5/24/2012	6/18/2012	25	PM - Fan Coil/HV/AC Unit	
FO-229587	Routine	Scheduled Maint. (PM)	10/6/2012	10/31/2012	25	Please perform PM on EF-6B	
FO-232826	Routine	Scheduled Maint. (PM)	11/1/2012	11/26/2012	25	PM - Fan Coil/HV/AC Unit	
FO-232827	Routine	Scheduled Maint. (PM)	11/1/2012	11/26/2012	25	PM - Fan Coil/HV/AC Unit	
FO-232828	Routine	Scheduled Maint. (PM)	11/1/2012	11/26/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235013	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235014	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235015	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235016	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235017	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235018	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235019	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235020	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235021	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235022	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235045	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-235046	Routine	Scheduled Maint. (PM)	11/29/2012	12/24/2012	25	PM - Fan Coil/HV/AC Unit	
FO-236068	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236069	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236070	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236071	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	

			Finish Date	Due Date			Total per Trade
FO-236072	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236073	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236074	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236075	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236085	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-236086	Routine	Scheduled Maint. (PM)	12/13/2012	1/7/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237946	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237953	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237954	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237955	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237956	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-237957	Routine	Scheduled Maint. (PM)	1/10/2013	2/4/2013	25	PM - Fan Coil/HV/AC Unit	
FO-238155	Routine	Scheduled Maint. (PM)	1/28/2013	2/22/2013	25	PM - Air Handling Unit, HV Type	
FO-203854	Routine	Scheduled Maint. (PM)	1/12/2012	2/5/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-207147	Routine	Scheduled Maint. (PM)	2/14/2012	3/9/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-214869	Routine	Scheduled Maint. (PM)	4/16/2012	5/10/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-214870	Routine	Scheduled Maint. (PM)	4/17/2012	5/11/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-217810	Routine	Scheduled Maint. (PM)	5/22/2012	6/15/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-217811	Routine	Scheduled Maint. (PM)	5/22/2012	6/15/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-218779	Routine	Scheduled Maint. (PM)	5/25/2012	6/18/2012	24	PM - Fan Coil/HV/AC Unit	
FO-218780	Routine	Scheduled Maint. (PM)	5/25/2012	6/18/2012	24	PM - Fan Coil/HV/AC Unit	
FO-218781	Routine	Scheduled Maint. (PM)	5/25/2012	6/18/2012	24	PM - Fan Coil/HV/AC Unit	
FO-218782	Routine	Scheduled Maint. (PM)	5/25/2012	6/18/2012	24	PM - Fan Coil/HV/AC Unit	
FO-218783	Routine	Scheduled Maint. (PM)	5/25/2012	6/18/2012	24	PM - Fan Coil/HV/AC Unit	
FO-221016	Routine	Scheduled Maint. (PM)	6/8/2012	7/2/2012	24	PM - Fan Coil/HV/AC Unit	
FO-221018	Routine	Scheduled Maint. (PM)	6/8/2012	7/2/2012	24	PM - Fan Coil/HV/AC Unit	
FO-221019	Routine	Scheduled Maint. (PM)	6/8/2012	7/2/2012	24	PM - Fan Coil/HV/AC Unit	
FO-226083	Routine	Scheduled Maint. (PM)	8/29/2012	9/22/2012	24	PM - Air Handling Unit, over 50 Ton	
FO-234975	Routine	Scheduled Maint. (PM)	11/22/2012	12/16/2012	24	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236065	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Fan Coil/HV/AC Unit	
FO-236066	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Fan Coil/HV/AC Unit	
FO-236067	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Fan Coil/HV/AC Unit	
FO-236960	Routine	Scheduled Maint. (PM)	1/16/2013	2/9/2013	24	PM - Fire Pump, Main/Jockey	
FO-236961	Routine	Scheduled Maint. (PM)	1/16/2013	2/9/2013	24	PM - Fire Pump, Main/Jockey	
FO-238156	Routine	Scheduled Maint. (PM)	1/18/2013	2/11/2013	24	PM - Fan Coil/HV/AC Unit	
FO-238157	Routine	Scheduled Maint. (PM)	1/18/2013	2/11/2013	24	PM - Fan Coil/HV/AC Unit	
FO-238158	Routine	Scheduled Maint. (PM)	1/18/2013	2/11/2013	24	PM - Fan Coil/HV/AC Unit	
FO-238159	Routine	Scheduled Maint. (PM)	1/18/2013	2/11/2013	24	PM - Fan Coil/HV/AC Unit	
FO-203853	Routine	Scheduled Maint. (PM)	1/12/2012	2/4/2012	23	PM - Air Handling Unit, over 50 Ton	
FO-208182	Routine	Scheduled Maint. (PM)	2/23/2012	3/17/2012	23	PM - Air Handling Unit, over 50 Ton	
FO-210537	Routine	Scheduled Maint. (PM)	2/27/2012	3/21/2012	23	PM - Fan Coil/HV/AC Unit	
FO-210538	Routine	Scheduled Maint. (PM)	2/27/2012	3/21/2012	23	PM - Fan Coil/HV/AC Unit	
FO-213486	Routine	Scheduled Maint. (PM)	4/2/2012	4/25/2012	23	PM - Fan Coil/HV/AC Unit	
FO-216715	Routine	Scheduled Maint. (PM)	5/11/2012	6/3/2012	23	PM - Air Handling Unit, over 50 Ton	

			Finish Date	Due Date	Total per Trade	
FO-221029	Routine	Scheduled Maint. (PM)	6/9/2012	7/2/2012	23	PM - Fan Coil/HV/AC Unit
FO-221030	Routine	Scheduled Maint. (PM)	6/9/2012	7/2/2012	23	PM - Fan Coil/HV/AC Unit
FO-221031	Routine	Scheduled Maint. (PM)	6/9/2012	7/2/2012	23	PM - Fan Coil/HV/AC Unit
FO-221032	Routine	Scheduled Maint. (PM)	6/9/2012	7/2/2012	23	PM - Fan Coil/HV/AC Unit
FO-215198	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly
FO-215199	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly
FO-215200	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly
FO-215201	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly
FO-226074	Routine	Scheduled Maint. (PM)	8/30/2012	9/22/2012	23	PM - Air Handling Unit, over 50 Ton
FO-229389	Routine	Scheduled Maint. (PM)	10/10/2012	11/2/2012	23	PM - Fire Pump, Main/Jockey
FO-229390	Routine	Scheduled Maint. (PM)	10/10/2012	11/2/2012	23	PM - Fire Pump, Main/Jockey
FO-230332	Routine	Scheduled Maint. (PM)	10/9/2012	11/1/2012	23	PM - Fan Coil/HV/AC Unit
FO-230720	Routine	Scheduled Maint. (PM)	10/20/2012	11/12/2012	23	PM - Fan Coil/HV/AC Unit
FO-230721	Routine	Scheduled Maint. (PM)	10/20/2012	11/12/2012	23	PM - Fan Coil/HV/AC Unit
FO-230722	Routine	Scheduled Maint. (PM)	10/20/2012	11/12/2012	23	PM - Fan Coil/HV/AC Unit
FO-235397	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235398	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235399	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235400	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235401	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235402	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-235403	Routine	Scheduled Maint. (PM)	12/8/2012	12/31/2012	23	PM - Fan Coil/HV/AC Unit
FO-237933	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237935	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237936	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237938	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237939	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237940	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-237941	Routine	Scheduled Maint. (PM)	1/5/2013	1/28/2013	23	PM - Fan Coil/HV/AC Unit
FO-238129	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-238130	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-238131	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-238132	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-238133	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-238134	Routine	Scheduled Maint. (PM)	1/19/2013	2/11/2013	23	PM - Fan Coil/HV/AC Unit
FO-203793	Routine	Scheduled Maint. (PM)	1/12/2012	2/3/2012	22	PM - Air Handling Unit, over 50 Ton
FO-203794	Routine	Scheduled Maint. (PM)	1/12/2012	2/3/2012	22	PM - Air Handling Unit, over 50 Ton
FO-203852	Routine	Scheduled Maint. (PM)	1/12/2012	2/3/2012	22	PM - Air Handling Unit, over 50 Ton
FO-205227	Routine	Scheduled Maint. (PM)	1/23/2012	2/14/2012	22	PM - Air Handling Unit, over 50 Ton
FO-205231	Routine	Scheduled Maint. (PM)	1/23/2012	2/14/2012	22	PM - Air Handling Unit, over 50 Ton
FO-205229	Routine	Scheduled Maint. (PM)	1/23/2012	2/14/2012	22	PM - Air Handling Unit, over 50 Ton
FO-206192	Routine	Scheduled Maint. (PM)	1/30/2012	2/21/2012	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208175	Routine	Scheduled Maint. (PM)	2/27/2012	3/20/2012	22	PM - Air Handling Unit, over 50 Ton
FO-213487	Routine	Scheduled Maint. (PM)	4/3/2012	4/25/2012	22	PM - Fan Coil/HV/AC Unit

Finish Date Due Date

Total per Trade

FO-213493	Routine	Scheduled Maint. (PM)	4/3/2012	4/25/2012	22	PM - Air Handling Unit, over 50 Ton
FO-213497	Routine	Scheduled Maint. (PM)	4/5/2012	4/27/2012	22	PM - Fire Pump, Main/Jockey
FO-214167	Routine	Scheduled Maint. (PM)	4/3/2012	4/25/2012	22	PM - Fan Coil/HV/AC Unit
FO-219549	Routine	Scheduled Maint. (PM)	6/5/2012	6/27/2012	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227204	Routine	Scheduled Maint. (PM)	9/29/2012	10/21/2012	22	PM - Air Handling Unit, over 50 Ton
FO-227571	Routine	Scheduled Maint. (PM)	9/12/2012	10/4/2012	22	PM - Air Handling Unit, over 50 Ton
FO-227572	Routine	Scheduled Maint. (PM)	9/12/2012	10/4/2012	22	PM - Air Handling Unit, over 50 Ton
FO-229446	Routine	Scheduled Maint. (PM)	10/3/2012	10/25/2012	22	PM - Fan Coil/HV/AC Unit
FO-229447	Routine	Scheduled Maint. (PM)	10/3/2012	10/25/2012	22	PM - Fan Coil/HV/AC Unit
FO-229448	Routine	Scheduled Maint. (PM)	10/3/2012	10/25/2012	22	PM - Fan Coil/HV/AC Unit
FO-229588	Routine	Scheduled Maint. (PM)	10/9/2012	10/31/2012	22	Please perform PM on EF-3A1
FO-230333	Routine	Scheduled Maint. (PM)	10/10/2012	11/1/2012	22	PM - Fan Coil/HV/AC Unit
FO-230339	Routine	Scheduled Maint. (PM)	10/11/2012	11/2/2012	22	PM - Air Handling Unit, over 50 Ton
FO-237056	Routine	Scheduled Maint. (PM)	1/9/2013	1/31/2013	22	PM - Fire Alarm System Test
FO-237058	Routine	Scheduled Maint. (PM)	1/9/2013	1/31/2013	22	PM - Fire Alarm System Test
FO-238123	Routine	Scheduled Maint. (PM)	1/24/2013	2/15/2013	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238124	Routine	Scheduled Maint. (PM)	1/24/2013	2/15/2013	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238125	Routine	Scheduled Maint. (PM)	1/24/2013	2/15/2013	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203791	Routine	Scheduled Maint. (PM)	1/19/2012	2/9/2012	21	PM - Fire Pump, Main/Jockey
FO-203792	Routine	Scheduled Maint. (PM)	1/19/2012	2/9/2012	21	PM - Fire Pump, Main/Jockey
FO-205230	Routine	Scheduled Maint. (PM)	1/24/2012	2/14/2012	21	PM - Air Handling Unit, over 50 Ton
FO-206187	Routine	Scheduled Maint. (PM)	1/31/2012	2/21/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206188	Routine	Scheduled Maint. (PM)	1/31/2012	2/21/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206193	Routine	Scheduled Maint. (PM)	1/31/2012	2/21/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206194	Routine	Scheduled Maint. (PM)	1/31/2012	2/21/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206195	Routine	Scheduled Maint. (PM)	1/31/2012	2/21/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208170	Routine	Scheduled Maint. (PM)	2/14/2012	3/6/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211277	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211278	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211279	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211280	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211281	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211283	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211284	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211285	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211287	Routine	Scheduled Maint. (PM)	3/9/2012	3/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213428	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213429	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213430	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213431	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213432	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213433	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213434	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213435	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date			Total per Trade
FO-213436	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213444	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213445	Routine	Scheduled Maint. (PM)	3/28/2012	4/18/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-214166	Routine	Scheduled Maint. (PM)	4/4/2012	4/25/2012	21	PM - Fan Coil/HV/AC Unit	
FO-214863	Routine	Scheduled Maint. (PM)	4/13/2012	5/4/2012	21	PM - Unit/Space Heater	
FO-215461	Routine	Scheduled Maint. (PM)	4/25/2012	5/16/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-215462	Routine	Scheduled Maint. (PM)	4/25/2012	5/16/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-215463	Routine	Scheduled Maint. (PM)	4/25/2012	5/16/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-215464	Routine	Scheduled Maint. (PM)	4/25/2012	5/16/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-215471	Routine	Scheduled Maint. (PM)	4/18/2012	5/9/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-217787	Routine	Scheduled Maint. (PM)	5/14/2012	6/4/2012	21	PM - Fan Coil/HV/AC Unit	
FO-217790	Routine	Scheduled Maint. (PM)	5/14/2012	6/4/2012	21	PM - Fan Coil/HV/AC Unit	
FO-217888	Routine	Scheduled Maint. (PM)	5/17/2012	6/7/2012	21	PM - Unit/Space Heater	
FO-222548	Low	Scheduled Maint. (PM)	8/9/2012	8/30/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-229393	Routine	Scheduled Maint. (PM)	10/6/2012	10/27/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-230281	Routine	Scheduled Maint. (PM)	10/9/2012	10/30/2012	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230286	Routine	Scheduled Maint. (PM)	10/18/2012	11/8/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-230320	Routine	Scheduled Maint. (PM)	10/8/2012	10/29/2012	21	PM - Unit/Space Heater	
FO-230321	Routine	Scheduled Maint. (PM)	10/8/2012	10/29/2012	21	PM - Unit/Space Heater	
FO-230322	Routine	Scheduled Maint. (PM)	10/8/2012	10/29/2012	21	PM - Unit/Space Heater	
FO-230433	Routine	Scheduled Maint. (PM)	10/8/2012	10/29/2012	21	PM - Unit/Space Heater	
FO-230434	Routine	Scheduled Maint. (PM)	10/8/2012	10/29/2012	21	PM - Unit/Space Heater	
FO-232873	Low	Scheduled Maint. (PM)	11/16/2012	12/7/2012	21	PM - Fan Motor Box (Old Main)	
FO-232874	Low	Scheduled Maint. (PM)	11/16/2012	12/7/2012	21	PM - Fan Motor Box (Old Main)	
FO-232875	Low	Scheduled Maint. (PM)	11/16/2012	12/7/2012	21	PM - Fan Motor Box (Old Main)	
FO-234968	Routine	Scheduled Maint. (PM)	12/7/2012	12/28/2012	21	PM - Fire Pump, Main/Jockey	
FO-237057	Routine	Scheduled Maint. (PM)	1/10/2013	1/31/2013	21	PM - Fire Alarm System Test	
FO-203825	Routine	Scheduled Maint. (PM)	1/5/2012	1/25/2012	20	PM - Fan Coil/HV/AC Unit	
FO-203826	Routine	Scheduled Maint. (PM)	1/5/2012	1/25/2012	20	PM - Fan Coil/HV/AC Unit	
FO-203827	Routine	Scheduled Maint. (PM)	1/5/2012	1/25/2012	20	PM - Fan Coil/HV/AC Unit	
FO-203795	Routine	Scheduled Maint. (PM)	1/14/2012	2/3/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-208178	Routine	Scheduled Maint. (PM)	3/9/2012	3/29/2012	20	PM - Fire Pump, Main/Jockey	
FO-210539	Routine	Scheduled Maint. (PM)	3/10/2012	3/30/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-211232	Routine	Scheduled Maint. (PM)	3/14/2012	4/3/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-213427	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213437	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213438	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213439	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213440	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213441	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213442	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213443	Routine	Scheduled Maint. (PM)	3/29/2012	4/18/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213488	Routine	Scheduled Maint. (PM)	4/5/2012	4/25/2012	20	PM - Fan Coil/HV/AC Unit	
FO-214179	Routine	Scheduled Maint. (PM)	4/14/2012	5/4/2012	20	PM - Air Handling Unit, over 50 Ton	

Finish Date Due Date

Total per Trade

FO-214868	Routine	Scheduled Maint. (PM)	4/17/2012	5/7/2012	20	PM - Air Handling Unit, over 50 Ton
FO-217889	Routine	Scheduled Maint. (PM)	5/18/2012	6/7/2012	20	PM - Unit/Space Heater
FO-219531	Routine	Scheduled Maint. (PM)	6/9/2012	6/29/2012	20	PM - Air Handling Unit, over 50 Ton
FO-222476	Routine	Scheduled Maint. (PM)	7/18/2012	8/7/2012	20	PM - Air Handling Unit, over 50 Ton
FO-228734	Routine	Scheduled Maint. (PM)	10/2/2012	10/22/2012	20	PM - Air Handling Unit, over 50 Ton
FO-232876	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232877	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232878	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232879	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232880	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232881	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232882	Low	Scheduled Maint. (PM)	11/17/2012	12/7/2012	20	PM - Fan Motor Box (Old Main)
FO-232885	Low	Scheduled Maint. (PM)	11/2/2012	11/22/2012	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203841	Routine	Scheduled Maint. (PM)	1/6/2012	1/25/2012	19	PM - Air Handling Unit, over 50 Ton
FO-203842	Routine	Scheduled Maint. (PM)	1/6/2012	1/25/2012	19	PM - Air Handling Unit, over 50 Ton
FO-203844	Routine	Scheduled Maint. (PM)	1/6/2012	1/25/2012	19	PM - Air Handling Unit, over 50 Ton
FO-208163	Routine	Scheduled Maint. (PM)	2/23/2012	3/13/2012	19	PM - Fan Coil/HV/AC Unit
FO-208164	Routine	Scheduled Maint. (PM)	2/23/2012	3/13/2012	19	PM - Fan Coil/HV/AC Unit
FO-208174	Routine	Scheduled Maint. (PM)	2/28/2012	3/18/2012	19	PM - Air Handling Unit, over 50 Ton
FO-208176	Routine	Scheduled Maint. (PM)	3/1/2012	3/20/2012	19	PM - Air Handling Unit, over 50 Ton
FO-211966	Routine	Scheduled Maint. (PM)	3/16/2012	4/4/2012	19	PM - Fan Coil/HV/AC Unit
FO-211967	Routine	Scheduled Maint. (PM)	3/16/2012	4/4/2012	19	PM - Fan Coil/HV/AC Unit
FO-214169	Routine	Scheduled Maint. (PM)	4/14/2012	5/3/2012	19	PM - Air Handling Unit, over 50 Ton
FO-214170	Routine	Scheduled Maint. (PM)	4/14/2012	5/3/2012	19	PM - Air Handling Unit, over 50 Ton
FO-214867	Routine	Scheduled Maint. (PM)	4/17/2012	5/6/2012	19	PM - Air Handling Unit, over 50 Ton
FO-216610	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-216611	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-216612	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-216613	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-216614	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-216615	Routine	Scheduled Maint. (PM)	5/2/2012	5/21/2012	19	PM - Fan Coil/HV/AC Unit
FO-218730	Routine	Scheduled Maint. (PM)	6/8/2012	6/27/2012	19	PM - Fire Pump, Main/Jockey
FO-219548	Routine	Scheduled Maint. (PM)	6/8/2012	6/27/2012	19	PM - Fan Coil/HV/AC Unit
FO-221230	Routine	Scheduled Maint. (PM)	7/6/2012	7/25/2012	19	PM - Air Handling Unit, over 50 Ton
FO-224581	Routine	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fire Pump, Main/Jockey
FO-207136	Low	Scheduled Maint. (PM)	2/15/2012	3/5/2012	19	PM - Air Handling Unit, HV Type
FO-218737	Low	Scheduled Maint. (PM)	6/12/2012	7/1/2012	19	PM - Fire Alarm System Test
FO-218748	Low	Scheduled Maint. (PM)	6/12/2012	7/1/2012	19	PM - Fire Alarm System Test
FO-225077	Low	Scheduled Maint. (PM)	8/28/2012	9/16/2012	19	PM - Fire Pump, Main/Jockey
FO-226150	Routine	Scheduled Maint. (PM)	10/8/2012	10/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226230	Low	Scheduled Maint. (PM)	9/12/2012	10/1/2012	19	PM - Fire Alarm System Test
FO-227331	Low	Scheduled Maint. (PM)	9/22/2012	10/11/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230280	Routine	Scheduled Maint. (PM)	10/9/2012	10/28/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233502	Routine	Scheduled Maint. (PM)	11/20/2012	12/9/2012	19	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-235061	Routine	Scheduled Maint. (PM)	12/12/2012	12/31/2012	19	PM - Fire Alarm System Test
FO-235062	Routine	Scheduled Maint. (PM)	12/12/2012	12/31/2012	19	PM - Fire Alarm System Test
FO-235063	Routine	Scheduled Maint. (PM)	12/12/2012	12/31/2012	19	PM - Fire Alarm System Test
FO-237893	Routine	Scheduled Maint. (PM)	1/26/2013	2/14/2013	19	PM - Air Handling Unit
FO-237895	Routine	Scheduled Maint. (PM)	1/26/2013	2/14/2013	19	PM - Air Handling Unit
FO-237896	Routine	Scheduled Maint. (PM)	1/26/2013	2/14/2013	19	PM - Air Handling Unit
FO-208165	Routine	Scheduled Maint. (PM)	2/24/2012	3/13/2012	18	PM - Fan Coil/HV/AC Unit
FO-214180	Routine	Scheduled Maint. (PM)	4/17/2012	5/5/2012	18	PM - Air Handling Unit, over 50 Ton
FO-216605	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216606	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216607	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216608	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216609	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216616	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-216617	Routine	Scheduled Maint. (PM)	5/3/2012	5/21/2012	18	PM - Fan Coil/HV/AC Unit
FO-217779	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-217780	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-217783	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-217785	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-217786	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-217789	Routine	Scheduled Maint. (PM)	5/17/2012	6/4/2012	18	PM - Fan Coil/HV/AC Unit
FO-222463	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222464	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222465	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222466	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222467	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222468	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222469	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222474	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-222475	Routine	Scheduled Maint. (PM)	7/14/2012	8/1/2012	18	PM - Unit/Space Heater
FO-213835	Low	Scheduled Maint. (PM)	4/6/2012	4/24/2012	18	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218738	Low	Scheduled Maint. (PM)	6/13/2012	7/1/2012	18	PM - Fire Alarm System Test
FO-226178	Routine	Scheduled Maint. (PM)	8/31/2012	9/18/2012	18	PM - Air Handling Unit, over 50 Ton
FO-226229	Low	Scheduled Maint. (PM)	9/13/2012	10/1/2012	18	PM - Fire Alarm System Test
FO-226748	Routine	Scheduled Maint. (PM)	9/12/2012	9/30/2012	18	PM - Air Handling Unit, over 50 Ton
FO-228600	Routine	Scheduled Maint. (PM)	10/10/2012	10/28/2012	18	PM - Fire Pump, Main/Jockey
FO-232896	Routine	Scheduled Maint. (PM)	11/5/2012	11/23/2012	18	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-233578	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-233579	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-233580	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-233581	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-233582	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-233583	Routine	Scheduled Maint. (PM)	11/15/2012	12/3/2012	18	PM - Fan Coil/HV/AC Unit
FO-234293	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit

			Finish Date	Due Date	Total per Trade	
FO-234294	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234295	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234296	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234297	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234298	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234299	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234300	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234301	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234302	Routine	Scheduled Maint. (PM)	11/22/2012	12/10/2012	18	PM - Fan Coil/HV/AC Unit
FO-234976	Routine	Scheduled Maint. (PM)	11/29/2012	12/17/2012	18	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234986	Routine	Scheduled Maint. (PM)	12/4/2012	12/22/2012	18	PM - Air Handling Unit, over 50 Ton
FO-234996	Routine	Scheduled Maint. (PM)	11/29/2012	12/17/2012	18	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235056	Routine	Scheduled Maint. (PM)	12/4/2012	12/22/2012	18	PM - Air Handling Unit, over 50 Ton
FO-235057	Routine	Scheduled Maint. (PM)	12/4/2012	12/22/2012	18	PM - Air Handling Unit, over 50 Ton
FO-235340	Routine	Scheduled Maint. (PM)	12/5/2012	12/23/2012	18	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235370	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Fan Coil/HV/AC Unit
FO-235371	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Fan Coil/HV/AC Unit
FO-235372	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Fan Coil/HV/AC Unit
FO-236964	Routine	Scheduled Maint. (PM)	1/9/2013	1/27/2013	18	PM - Air Handling Unit
FO-237934	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Fan Coil/HV/AC Unit
FO-237942	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Fan Coil/HV/AC Unit
FO-237943	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Fan Coil/HV/AC Unit
FO-237944	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Fan Coil/HV/AC Unit
FO-237945	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Fan Coil/HV/AC Unit
FO-207131	Routine	Scheduled Maint. (PM)	2/22/2012	3/10/2012	17	PM - Air Handling Unit, over 50 Ton
FO-217781	Routine	Scheduled Maint. (PM)	5/18/2012	6/4/2012	17	PM - Fan Coil/HV/AC Unit
FO-217782	Routine	Scheduled Maint. (PM)	5/18/2012	6/4/2012	17	PM - Fan Coil/HV/AC Unit
FO-217784	Routine	Scheduled Maint. (PM)	5/18/2012	6/4/2012	17	PM - Fan Coil/HV/AC Unit
FO-217788	Routine	Scheduled Maint. (PM)	5/18/2012	6/4/2012	17	PM - Fan Coil/HV/AC Unit
FO-218772	Routine	Scheduled Maint. (PM)	5/25/2012	6/11/2012	17	PM - Fan Coil/HV/AC Unit
FO-218773	Routine	Scheduled Maint. (PM)	5/25/2012	6/11/2012	17	PM - Fan Coil/HV/AC Unit
FO-218774	Routine	Scheduled Maint. (PM)	5/25/2012	6/11/2012	17	PM - Fan Coil/HV/AC Unit
FO-218775	Routine	Scheduled Maint. (PM)	5/25/2012	6/11/2012	17	PM - Fan Coil/HV/AC Unit
FO-218776	Routine	Scheduled Maint. (PM)	5/25/2012	6/11/2012	17	PM - Fan Coil/HV/AC Unit
FO-219538	Routine	Scheduled Maint. (PM)	6/8/2012	6/25/2012	17	PM - Fan Coil/HV/AC Unit
FO-219539	Routine	Scheduled Maint. (PM)	6/8/2012	6/25/2012	17	PM - Fan Coil/HV/AC Unit
FO-219540	Routine	Scheduled Maint. (PM)	6/8/2012	6/25/2012	17	PM - Fan Coil/HV/AC Unit
FO-219541	Routine	Scheduled Maint. (PM)	6/8/2012	6/25/2012	17	PM - Fan Coil/HV/AC Unit
FO-219542	Routine	Scheduled Maint. (PM)	6/8/2012	6/25/2012	17	PM - Fan Coil/HV/AC Unit
FO-221014	Routine	Scheduled Maint. (PM)	6/15/2012	7/2/2012	17	PM - Fan Coil/HV/AC Unit
FO-221015	Routine	Scheduled Maint. (PM)	6/15/2012	7/2/2012	17	PM - Fan Coil/HV/AC Unit
FO-221042	Routine	Scheduled Maint. (PM)	6/29/2012	7/16/2012	17	PM - Fan Coil/HV/AC Unit
FO-221043	Routine	Scheduled Maint. (PM)	6/29/2012	7/16/2012	17	PM - Fan Coil/HV/AC Unit
FO-224749	Routine	Scheduled Maint. (PM)	8/10/2012	8/27/2012	17	Monthly Fire System Test

			Finish Date	Due Date			Total per Trade
FO-225545	Routine	Scheduled Maint. (PM)	8/29/2012	9/15/2012	17	PM - Air Handling Unit, over 50 Ton	
FO-226075	Routine	Scheduled Maint. (PM)	9/5/2012	9/22/2012	17	PM - Air Handling Unit, over 50 Ton	
FO-227214	Routine	Scheduled Maint. (PM)	10/2/2012	10/19/2012	17	PM - Fan Coil/HV/AC Unit	
FO-230456	Low	Scheduled Maint. (PM)	11/13/2012	11/30/2012	17	PM - Air Handling Unit, over 50 Ton	
FO-230457	Low	Scheduled Maint. (PM)	11/13/2012	11/30/2012	17	PM - Air Handling Unit, over 50 Ton	
FO-230603	Routine	Scheduled Maint. (PM)	10/31/2012	11/17/2012	17	PM - Air Handling Unit, over 50 Ton	
FO-230718	Routine	Scheduled Maint. (PM)	10/26/2012	11/12/2012	17	PM - Fan Coil/HV/AC Unit	
FO-232283	Low	Scheduled Maint. (PM)	11/14/2012	12/1/2012	17	PM - Fire Alarm System Test	
FO-232870	Routine	Scheduled Maint. (PM)	11/21/2012	12/8/2012	17	PM - Fire Pump, Main/Jockey	
FO-232871	Routine	Scheduled Maint. (PM)	11/21/2012	12/8/2012	17	PM - Fire Pump, Main/Jockey	
FO-233576	Routine	Scheduled Maint. (PM)	11/16/2012	12/3/2012	17	PM - Fan Coil/HV/AC Unit	
FO-233577	Routine	Scheduled Maint. (PM)	11/16/2012	12/3/2012	17	PM - Fan Coil/HV/AC Unit	
FO-233584	Routine	Scheduled Maint. (PM)	11/16/2012	12/3/2012	17	PM - Fan Coil/HV/AC Unit	
FO-233585	Routine	Scheduled Maint. (PM)	11/16/2012	12/3/2012	17	PM - Fan Coil/HV/AC Unit	
FO-235365	Routine	Scheduled Maint. (PM)	12/4/2012	12/21/2012	17	PM - Fan Coil/HV/AC Unit	
FO-235366	Routine	Scheduled Maint. (PM)	12/4/2012	12/21/2012	17	PM - Fan Coil/HV/AC Unit	
FO-235367	Routine	Scheduled Maint. (PM)	12/4/2012	12/21/2012	17	PM - Fan Coil/HV/AC Unit	
FO-236057	Routine	Scheduled Maint. (PM)	12/10/2012	12/27/2012	17	PM - Fan Coil/HV/AC Unit	
FO-236942	Routine	Scheduled Maint. (PM)	1/16/2013	2/2/2013	17	PM - Fire Pump, Main/Jockey	
FO-236943	Routine	Scheduled Maint. (PM)	1/16/2013	2/2/2013	17	PM - Fire Pump, Main/Jockey	
FO-237947	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237948	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237949	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237950	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237951	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237952	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237958	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-237959	Routine	Scheduled Maint. (PM)	1/18/2013	2/4/2013	17	PM - Fan Coil/HV/AC Unit	
FO-206630	Routine	Scheduled Maint. (PM)	2/14/2012	3/1/2012	16	PM - Air Handling Unit, over 50 Ton	
FO-207153	Routine	Scheduled Maint. (PM)	2/23/2012	3/10/2012	16	PM - Air Handling Unit, over 50 Ton	
FO-207132	Routine	Scheduled Maint. (PM)	2/23/2012	3/10/2012	16	PM - Air Handling Unit, over 50 Ton	
FO-210536	Routine	Scheduled Maint. (PM)	3/5/2012	3/21/2012	16	PM - Fan Coil/HV/AC Unit	
FO-211275	Routine	Scheduled Maint. (PM)	3/14/2012	3/30/2012	16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211276	Routine	Scheduled Maint. (PM)	3/14/2012	3/30/2012	16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211286	Routine	Scheduled Maint. (PM)	3/14/2012	3/30/2012	16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211288	Routine	Scheduled Maint. (PM)	3/14/2012	3/30/2012	16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213484	Routine	Scheduled Maint. (PM)	4/2/2012	4/18/2012	16	PM - Fan Coil/HV/AC Unit	
FO-213485	Routine	Scheduled Maint. (PM)	4/2/2012	4/18/2012	16	PM - Fan Coil/HV/AC Unit	
FO-218731	Routine	Scheduled Maint. (PM)	6/6/2012	6/22/2012	16	PM - Air Handling Unit, over 50 Ton	
FO-219517	Routine	Scheduled Maint. (PM)	6/8/2012	6/24/2012	16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-221004	Routine	Scheduled Maint. (PM)	7/12/2012	7/28/2012	16	PM - Fire Pump, Main/Jockey	
FO-221021	Routine	Scheduled Maint. (PM)	6/23/2012	7/9/2012	16	PM - Fan Coil/HV/AC Unit	
FO-221022	Routine	Scheduled Maint. (PM)	6/23/2012	7/9/2012	16	PM - Fan Coil/HV/AC Unit	
FO-221024	Routine	Scheduled Maint. (PM)	6/23/2012	7/9/2012	16	PM - Fan Coil/HV/AC Unit	

			Finish Date	Due Date	Total per Trade	
FO-226151	Low	Scheduled Maint. (PM)	9/15/2012	10/1/2012	16	PM - Fire Alarm System Test
FO-227180	Routine	Scheduled Maint. (PM)	9/26/2012	10/12/2012	16	PM - Unit/Space Heater
FO-227213	Routine	Scheduled Maint. (PM)	10/3/2012	10/19/2012	16	PM - Fan Coil/HV/AC Unit
FO-229388	Routine	Scheduled Maint. (PM)	10/9/2012	10/25/2012	16	PM - Air Handling Unit, over 50 Ton
FO-230719	Routine	Scheduled Maint. (PM)	10/27/2012	11/12/2012	16	PM - Fan Coil/HV/AC Unit
FO-230723	Routine	Scheduled Maint. (PM)	10/27/2012	11/12/2012	16	PM - Fan Coil/HV/AC Unit
FO-230724	Routine	Scheduled Maint. (PM)	10/27/2012	11/12/2012	16	PM - Fan Coil/HV/AC Unit
FO-230726	Routine	Scheduled Maint. (PM)	10/27/2012	11/12/2012	16	PM - Fan Coil/HV/AC Unit
FO-232281	Low	Scheduled Maint. (PM)	11/15/2012	12/1/2012	16	PM - Fire Alarm System Test
FO-232282	Low	Scheduled Maint. (PM)	11/15/2012	12/1/2012	16	PM - Fire Alarm System Test
FO-235065	Routine	Scheduled Maint. (PM)	12/15/2012	12/31/2012	16	PM - Fire Alarm System Test
FO-236029	Routine	Scheduled Maint. (PM)	12/18/2012	1/3/2013	16	PM - Air Handling Unit, over 50 Ton
FO-236933	Routine	Scheduled Maint. (PM)	1/9/2013	1/25/2013	16	PM - Air Handling Unit
FO-237063	Routine	Scheduled Maint. (PM)	1/15/2013	1/31/2013	16	PM - Fire Alarm System Test
FO-206633	Routine	Scheduled Maint. (PM)	2/15/2012	3/1/2012	15	PM - Air Handling Unit, over 50 Ton
FO-209962	Routine	Scheduled Maint. (PM)	3/7/2012	3/22/2012	15	PM - Air Handling Unit, over 50 Ton
FO-218721	Routine	Scheduled Maint. (PM)	6/1/2012	6/16/2012	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219516	Routine	Scheduled Maint. (PM)	6/8/2012	6/23/2012	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221242	Routine	Scheduled Maint. (PM)	7/18/2012	8/2/2012	15	PM - Fire Pump, Main/Jockey
FO-221933	Routine	Scheduled Maint. (PM)	7/18/2012	8/2/2012	15	PM - Fire Pump, Main/Jockey
FO-221934	Routine	Scheduled Maint. (PM)	7/17/2012	8/1/2012	15	PM - Air Handling Unit, over 50 Ton
FO-221935	Routine	Scheduled Maint. (PM)	7/17/2012	8/1/2012	15	PM - Air Handling Unit, over 50 Ton
FO-221936	Routine	Scheduled Maint. (PM)	7/17/2012	8/1/2012	15	PM - Air Handling Unit, over 50 Ton
FO-224689	Routine	Scheduled Maint. (PM)	8/9/2012	8/24/2012	15	PM - Fire Pump, Main/Jockey
FO-208113	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-208114	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-208115	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-208116	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-208117	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-208118	Low	Scheduled Maint. (PM)	3/6/2012	3/21/2012	15	PM - Fan Coil/HV/AC Unit
FO-217828	Low	Scheduled Maint. (PM)	5/21/2012	6/5/2012	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217830	Low	Scheduled Maint. (PM)	5/21/2012	6/5/2012	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226070	Routine	Scheduled Maint. (PM)	9/12/2012	9/27/2012	15	PM - Fire Pump, Main/Jockey
FO-227178	Routine	Scheduled Maint. (PM)	9/27/2012	10/12/2012	15	PM - Unit/Space Heater
FO-227182	Routine	Scheduled Maint. (PM)	9/20/2012	10/5/2012	15	PM - Unit/Space Heater
FO-227183	Routine	Scheduled Maint. (PM)	9/20/2012	10/5/2012	15	PM - Unit/Space Heater
FO-227184	Routine	Scheduled Maint. (PM)	9/20/2012	10/5/2012	15	PM - Unit/Space Heater
FO-227185	Routine	Scheduled Maint. (PM)	9/20/2012	10/5/2012	15	PM - Unit/Space Heater
FO-227282	Routine	Scheduled Maint. (PM)	9/11/2012	9/26/2012	15	PM - Unit/Space Heater
FO-227283	Routine	Scheduled Maint. (PM)	9/11/2012	9/26/2012	15	PM - Unit/Space Heater
FO-228791	Routine	Scheduled Maint. (PM)	10/16/2012	10/31/2012	15	Maintain Fan Powered Boxes
FO-229383	Routine	Scheduled Maint. (PM)	10/10/2012	10/25/2012	15	PM - Air Handling Unit, over 50 Ton
FO-230308	Routine	Scheduled Maint. (PM)	10/23/2012	11/7/2012	15	PM - Air Handling Unit, over 50 Ton
FO-230329	Routine	Scheduled Maint. (PM)	10/10/2012	10/25/2012	15	PM - Fan Coil/HV/AC Unit

			Finish Date	Due Date	Total per Trade	
FO-230358	Routine	Scheduled Maint. (PM)	10/10/2012	10/25/2012	15	PM - Air Handling Unit, over 50 Ton
FO-230374	Low	Scheduled Maint. (PM)	11/1/2012	11/16/2012	15	PM - Fan Motor Box (Old Main)
FO-234276	Routine	Scheduled Maint. (PM)	12/1/2012	12/16/2012	15	PM - Air Handling Unit, over 50 Ton
FO-234343	Routine	Scheduled Maint. (PM)	11/26/2012	12/11/2012	15	PM - Air Handling Unit, HV Type
FO-236026	Routine	Scheduled Maint. (PM)	12/15/2012	12/30/2012	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237064	Routine	Scheduled Maint. (PM)	1/16/2013	1/31/2013	15	PM - Fire Alarm System Test
FO-205257	Routine	Scheduled Maint. (PM)	1/25/2012	2/8/2012	14	PM - Fan Coil/HV/AC Unit
FO-205258	Routine	Scheduled Maint. (PM)	1/25/2012	2/8/2012	14	PM - Fan Coil/HV/AC Unit
FO-205225	Routine	Scheduled Maint. (PM)	1/31/2012	2/14/2012	14	PM - Air Handling Unit, over 50 Ton
FO-208169	Routine	Scheduled Maint. (PM)	2/22/2012	3/7/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209963	Routine	Scheduled Maint. (PM)	3/8/2012	3/22/2012	14	PM - Air Handling Unit, over 50 Ton
FO-213483	Routine	Scheduled Maint. (PM)	4/4/2012	4/18/2012	14	PM - Fan Coil/HV/AC Unit
FO-213500	Routine	Scheduled Maint. (PM)	4/6/2012	4/20/2012	14	PM - Air Handling Unit, over 50 Ton
FO-215433	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215434	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215435	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215436	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215437	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215438	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215439	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215440	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215441	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215442	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215443	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216639	Routine	Scheduled Maint. (PM)	5/7/2012	5/21/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216641	Routine	Scheduled Maint. (PM)	5/7/2012	5/21/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217887	Routine	Scheduled Maint. (PM)	6/2/2012	6/16/2012	14	PM - Air Handling Unit, over 50 Ton
FO-221271	Routine	Scheduled Maint. (PM)	7/6/2012	7/20/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221928	Routine	Scheduled Maint. (PM)	7/18/2012	8/1/2012	14	PM - Air Handling Unit, over 50 Ton
FO-221953	Routine	Scheduled Maint. (PM)	7/26/2012	8/9/2012	14	PM - Fire Pump, Main/Jockey
FO-221954	Routine	Scheduled Maint. (PM)	7/26/2012	8/9/2012	14	PM - Fire Pump, Main/Jockey
FO-224908	Routine	Scheduled Maint. (PM)	8/9/2012	8/23/2012	14	PM - Air Handling Unit, HV Type
FO-224667	Low	Scheduled Maint. (PM)	8/17/2012	8/31/2012	14	PM - Fire Alarm System Test
FO-224763	Low	Scheduled Maint. (PM)	8/17/2012	8/31/2012	14	PM - Fire Alarm System Test
FO-224764	Low	Scheduled Maint. (PM)	8/17/2012	8/31/2012	14	PM - Fire Alarm System Test
FO-226756	Routine	Scheduled Maint. (PM)	9/13/2012	9/27/2012	14	PM - Air Handling Unit, over 50 Ton
FO-226757	Routine	Scheduled Maint. (PM)	9/13/2012	9/27/2012	14	PM - Air Handling Unit, over 50 Ton
FO-227329	Low	Scheduled Maint. (PM)	9/20/2012	10/4/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-228802	Low	Scheduled Maint. (PM)	10/17/2012	10/31/2012	14	PM - Fire Alarm System Test
FO-228806	Low	Scheduled Maint. (PM)	10/17/2012	10/31/2012	14	PM - Fire Alarm System Test
FO-230309	Routine	Scheduled Maint. (PM)	10/24/2012	11/7/2012	14	PM - Air Handling Unit, over 50 Ton
FO-230687	Routine	Scheduled Maint. (PM)	11/1/2012	11/15/2012	14	PM - Air Handling Unit, over 50 Ton
FO-230689	Routine	Scheduled Maint. (PM)	11/1/2012	11/15/2012	14	PM - Air Handling Unit, over 50 Ton
FO-232284	Low	Scheduled Maint. (PM)	11/17/2012	12/1/2012	14	PM - Fire Alarm System Test

			Finish Date	Due Date	Total per Trade	
FO-232883	Low	Scheduled Maint. (PM)	11/8/2012	11/22/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234974	Routine	Scheduled Maint. (PM)	12/1/2012	12/15/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235001	Routine	Scheduled Maint. (PM)	12/1/2012	12/15/2012	14	Replace filters
FO-235003	Routine	Scheduled Maint. (PM)	12/1/2012	12/15/2012	14	Replace filters
FO-235334	Routine	Scheduled Maint. (PM)	12/8/2012	12/22/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236025	Routine	Scheduled Maint. (PM)	12/15/2012	12/29/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203823	Routine	Scheduled Maint. (PM)	1/5/2012	1/18/2012	13	PM - Fan Coil/HV/AC Unit
FO-203824	Routine	Scheduled Maint. (PM)	1/5/2012	1/18/2012	13	PM - Fan Coil/HV/AC Unit
FO-203822	Routine	Scheduled Maint. (PM)	1/5/2012	1/18/2012	13	PM - Fan Coil/HV/AC Unit
FO-203820	Routine	Scheduled Maint. (PM)	1/11/2012	1/24/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203804	Routine	Scheduled Maint. (PM)	1/12/2012	1/25/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203806	Routine	Scheduled Maint. (PM)	1/12/2012	1/25/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203851	Routine	Scheduled Maint. (PM)	1/14/2012	1/27/2012	13	PM - Air Handling Unit, over 50 Ton
FO-208161	Routine	Scheduled Maint. (PM)	2/22/2012	3/6/2012	13	PM - Fan Coil/HV/AC Unit
FO-208160	Routine	Scheduled Maint. (PM)	2/22/2012	3/6/2012	13	PM - Fan Coil/HV/AC Unit
FO-208177	Routine	Scheduled Maint. (PM)	2/24/2012	3/8/2012	13	PM - Unit/Space Heater
FO-214168	Routine	Scheduled Maint. (PM)	4/12/2012	4/25/2012	13	PM - Fan Coil/HV/AC Unit
FO-214871	Routine	Scheduled Maint. (PM)	4/19/2012	5/2/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216652	Routine	Scheduled Maint. (PM)	5/19/2012	6/1/2012	13	PM - Air Handling Unit, over 50 Ton
FO-216653	Routine	Scheduled Maint. (PM)	5/19/2012	6/1/2012	13	PM - Air Handling Unit, over 50 Ton
FO-217791	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-217792	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-217793	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-217794	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-217795	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-217796	Routine	Scheduled Maint. (PM)	5/15/2012	5/28/2012	13	PM - Fan Coil/HV/AC Unit
FO-218712	Routine	Scheduled Maint. (PM)	6/2/2012	6/15/2012	13	Replace filters
FO-218713	Routine	Scheduled Maint. (PM)	6/2/2012	6/15/2012	13	Replace filters
FO-218714	Routine	Scheduled Maint. (PM)	6/2/2012	6/15/2012	13	Replace filters
FO-218715	Routine	Scheduled Maint. (PM)	6/2/2012	6/15/2012	13	Replace filters
FO-219515	Routine	Scheduled Maint. (PM)	6/9/2012	6/22/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221924	Routine	Scheduled Maint. (PM)	7/27/2012	8/9/2012	13	PM - Fire Pump, Main/Jockey
FO-222492	Routine	Scheduled Maint. (PM)	7/27/2012	8/9/2012	13	PM - Air Handling Unit, over 50 Ton
FO-215927	Low	Scheduled Maint. (PM)	5/2/2012	5/15/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217884	Low	Scheduled Maint. (PM)	5/18/2012	5/31/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222003	Low	Scheduled Maint. (PM)	7/10/2012	7/23/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222004	Low	Scheduled Maint. (PM)	7/10/2012	7/23/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224887	Routine	Scheduled Maint. (PM)	8/21/2012	9/3/2012	13	PM - Air Handling Unit, over 50 Ton
FO-226076	Routine	Scheduled Maint. (PM)	9/5/2012	9/18/2012	13	PM - Air Handling Unit, over 50 Ton
FO-226758	Routine	Scheduled Maint. (PM)	9/14/2012	9/27/2012	13	PM - Air Handling Unit, over 50 Ton
FO-227173	Routine	Scheduled Maint. (PM)	9/21/2012	10/4/2012	13	PM - Air Handling Unit, over 50 Ton
FO-227186	Routine	Scheduled Maint. (PM)	9/15/2012	9/28/2012	13	PM - Unit/Space Heater
FO-227573	Routine	Scheduled Maint. (PM)	9/14/2012	9/27/2012	13	PM - Unit/Space Heater
FO-227574	Routine	Scheduled Maint. (PM)	9/14/2012	9/27/2012	13	PM - Unit/Space Heater

			Finish Date	Due Date	Total per Trade	
FO-227575	Routine	Scheduled Maint. (PM)	9/14/2012	9/27/2012	13	PM - Unit/Space Heater
FO-227576	Routine	Scheduled Maint. (PM)	9/14/2012	9/27/2012	13	PM - Unit/Space Heater
FO-230360	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230363	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230364	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230365	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230366	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230367	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230368	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230369	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230370	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230371	Routine	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Fan Coil/HV/AC Unit
FO-230617	Routine	Scheduled Maint. (PM)	10/26/2012	11/8/2012	13	PM - Fan Coil/HV/AC Unit
FO-230618	Routine	Scheduled Maint. (PM)	10/26/2012	11/8/2012	13	PM - Fan Coil/HV/AC Unit
FO-230808	Routine	Scheduled Maint. (PM)	10/31/2012	11/13/2012	13	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-230809	Routine	Scheduled Maint. (PM)	10/31/2012	11/13/2012	13	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-230818	Routine	Scheduled Maint. (PM)	11/6/2012	11/19/2012	13	PM AHU - Belts & Lubrication
FO-232888	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Air Handling Unit, HV Type
FO-232889	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Air Handling Unit, HV Type
FO-234303	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Fan Coil/HV/AC Unit
FO-234304	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Fan Coil/HV/AC Unit
FO-234305	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Fan Coil/HV/AC Unit
FO-234306	Routine	Scheduled Maint. (PM)	11/27/2012	12/10/2012	13	PM - Fan Coil/HV/AC Unit
FO-235058	Routine	Scheduled Maint. (PM)	12/15/2012	12/28/2012	13	Monthly Fire System Test
FO-235333	Routine	Scheduled Maint. (PM)	12/8/2012	12/21/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236024	Routine	Scheduled Maint. (PM)	12/15/2012	12/28/2012	13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205266	Routine	Scheduled Maint. (PM)	2/3/2012	2/15/2012	12	PM - Air Handling Unit, over 50 Ton
FO-205263	Routine	Scheduled Maint. (PM)	2/3/2012	2/15/2012	12	PM - Air Handling Unit, over 50 Ton
FO-205264	Routine	Scheduled Maint. (PM)	2/3/2012	2/15/2012	12	PM - Air Handling Unit, over 50 Ton
FO-206638	Routine	Scheduled Maint. (PM)	2/7/2012	2/19/2012	12	PM - Air Handling Unit, HV Type
FO-206639	Routine	Scheduled Maint. (PM)	2/11/2012	2/23/2012	12	PM - Air Handling Unit, HV Type
FO-208162	Routine	Scheduled Maint. (PM)	2/23/2012	3/6/2012	12	PM - Fan Coil/HV/AC Unit
FO-208184	Routine	Scheduled Maint. (PM)	3/1/2012	3/13/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208185	Routine	Scheduled Maint. (PM)	3/1/2012	3/13/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211265	Routine	Scheduled Maint. (PM)	3/16/2012	3/28/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211267	Routine	Scheduled Maint. (PM)	3/16/2012	3/28/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-210840	Routine	Scheduled Maint. (PM)	3/21/2012	4/2/2012	12	PM - Air Handling Unit, over 50 Ton
FO-211968	Routine	Scheduled Maint. (PM)	3/23/2012	4/4/2012	12	PM - Fan Coil/HV/AC Unit
FO-213452	Routine	Scheduled Maint. (PM)	4/6/2012	4/18/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215459	Routine	Scheduled Maint. (PM)	5/4/2012	5/16/2012	12	PM - Air Handling Unit, over 50 Ton
FO-215460	Routine	Scheduled Maint. (PM)	5/4/2012	5/16/2012	12	PM - Air Handling Unit, over 50 Ton
FO-219533	Routine	Scheduled Maint. (PM)	6/15/2012	6/27/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220942	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221070	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-221071	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221072	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221073	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221074	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221075	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221076	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221077	Routine	Scheduled Maint. (PM)	7/3/2012	7/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215928	Low	Scheduled Maint. (PM)	5/3/2012	5/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215929	Low	Scheduled Maint. (PM)	5/3/2012	5/15/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217883	Low	Scheduled Maint. (PM)	5/19/2012	5/31/2012	12	-> Consolidated PM items:Annual task: W847301 - PM - Fan, Centrifugal: Supply/Return/Exhaust FanSemi-annual t
FO-222005	Low	Scheduled Maint. (PM)	7/11/2012	7/23/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222006	Low	Scheduled Maint. (PM)	7/11/2012	7/23/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226078	Routine	Scheduled Maint. (PM)	9/11/2012	9/23/2012	12	PM - Air Handling Unit, over 50 Ton
FO-226153	Routine	Scheduled Maint. (PM)	8/30/2012	9/11/2012	12	PM - Fan Coil/HV/AC Unit
FO-226154	Routine	Scheduled Maint. (PM)	8/30/2012	9/11/2012	12	PM - Fan Coil/HV/AC Unit
FO-227194	Routine	Scheduled Maint. (PM)	9/28/2012	10/10/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227195	Routine	Scheduled Maint. (PM)	9/28/2012	10/10/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227205	Routine	Scheduled Maint. (PM)	10/2/2012	10/14/2012	12	PM - Air Handling Unit, over 50 Ton
FO-227330	Low	Scheduled Maint. (PM)	9/22/2012	10/4/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229385	Routine	Scheduled Maint. (PM)	10/6/2012	10/18/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229386	Routine	Scheduled Maint. (PM)	10/6/2012	10/18/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229387	Routine	Scheduled Maint. (PM)	10/6/2012	10/18/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229589	Routine	Scheduled Maint. (PM)	10/19/2012	10/31/2012	12	Please perform PM on EF-3A2
FO-230582	Routine	Scheduled Maint. (PM)	11/2/2012	11/14/2012	12	PM - Air Handling Unit, over 50 Ton
FO-230585	Routine	Scheduled Maint. (PM)	11/2/2012	11/14/2012	12	PM - Air Handling Unit, over 50 Ton
FO-230688	Routine	Scheduled Maint. (PM)	11/3/2012	11/15/2012	12	PM - Air Handling Unit, over 50 Ton
FO-230706	Routine	Scheduled Maint. (PM)	10/24/2012	11/5/2012	12	PM - Fan Coil/HV/AC Unit
FO-230708	Routine	Scheduled Maint. (PM)	10/24/2012	11/5/2012	12	PM - Fan Coil/HV/AC Unit
FO-230709	Routine	Scheduled Maint. (PM)	10/24/2012	11/5/2012	12	PM - Fan Coil/HV/AC Unit
FO-232832	Routine	Scheduled Maint. (PM)	11/14/2012	11/26/2012	12	PM - Fan Coil/HV/AC Unit
FO-232833	Routine	Scheduled Maint. (PM)	11/14/2012	11/26/2012	12	PM - Fan Coil/HV/AC Unit
FO-232872	Routine	Scheduled Maint. (PM)	11/17/2012	11/29/2012	12	PM - Air Handling Unit, over 50 Ton
FO-232884	Low	Scheduled Maint. (PM)	11/10/2012	11/22/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232886	Low	Scheduled Maint. (PM)	11/28/2012	12/10/2012	12	PM - Air Handling Unit, over 50 Ton
FO-232887	Low	Scheduled Maint. (PM)	11/28/2012	12/10/2012	12	PM - Air Handling Unit, over 50 Ton
FO-235010	Routine	Scheduled Maint. (PM)	11/30/2012	12/12/2012	12	PM - Fan Coil/HV/AC Unit
FO-235011	Routine	Scheduled Maint. (PM)	11/30/2012	12/12/2012	12	PM - Fan Coil/HV/AC Unit
FO-235012	Routine	Scheduled Maint. (PM)	11/30/2012	12/12/2012	12	PM - Fan Coil/HV/AC Unit
FO-235330	Routine	Scheduled Maint. (PM)	12/18/2012	12/30/2012	12	PM - Air Handling Unit, over 50 Ton
FO-236022	Routine	Scheduled Maint. (PM)	12/15/2012	12/27/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236023	Routine	Scheduled Maint. (PM)	12/15/2012	12/27/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236028	Routine	Scheduled Maint. (PM)	12/22/2012	1/3/2013	12	PM - Air Handling Unit, over 50 Ton
FO-236088	Routine	Scheduled Maint. (PM)	12/21/2012	1/2/2013	12	PM - Air Handling Unit, over 50 Ton
FO-236963	Routine	Scheduled Maint. (PM)	1/8/2013	1/20/2013	12	PM - Air Handling Unit

			Finish Date	Due Date	Total per Trade	
FO-237914	Routine	Scheduled Maint. (PM)	1/25/2013	2/6/2013	12	PM - Air Handling Unit
FO-205254	Routine	Scheduled Maint. (PM)	1/27/2012	2/7/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205267	Routine	Scheduled Maint. (PM)	2/4/2012	2/15/2012	11	PM - Air Handling Unit, over 50 Ton
FO-206647	Routine	Scheduled Maint. (PM)	2/21/2012	3/3/2012	11	PM - Air Handling Unit, over 50 Ton
FO-208183	Routine	Scheduled Maint. (PM)	3/2/2012	3/13/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213461	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213462	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213463	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213466	Routine	Scheduled Maint. (PM)	4/14/2012	4/25/2012	11	PM - Air Handling Unit, over 50 Ton
FO-213494	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213495	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213496	Routine	Scheduled Maint. (PM)	4/7/2012	4/18/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216642	Routine	Scheduled Maint. (PM)	5/10/2012	5/21/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218784	Routine	Scheduled Maint. (PM)	6/7/2012	6/18/2012	11	PM - Fan Coil/HV/AC Unit
FO-218785	Routine	Scheduled Maint. (PM)	6/7/2012	6/18/2012	11	PM - Fan Coil/HV/AC Unit
FO-218786	Routine	Scheduled Maint. (PM)	6/7/2012	6/18/2012	11	PM - Fan Coil/HV/AC Unit
FO-218787	Routine	Scheduled Maint. (PM)	6/7/2012	6/18/2012	11	PM - Fan Coil/HV/AC Unit
FO-219534	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219535	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219536	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219537	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219543	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219544	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-219545	Routine	Scheduled Maint. (PM)	6/14/2012	6/25/2012	11	PM - Fan Coil/HV/AC Unit
FO-220971	Routine	Scheduled Maint. (PM)	7/11/2012	7/22/2012	11	PM - Air Handling Unit, over 50 Ton
FO-221012	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221013	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221017	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221020	Routine	Scheduled Maint. (PM)	6/28/2012	7/9/2012	11	PM - Fan Coil/HV/AC Unit
FO-221023	Routine	Scheduled Maint. (PM)	6/28/2012	7/9/2012	11	PM - Fan Coil/HV/AC Unit
FO-221033	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221034	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221035	Routine	Scheduled Maint. (PM)	6/21/2012	7/2/2012	11	PM - Fan Coil/HV/AC Unit
FO-221922	Routine	Scheduled Maint. (PM)	7/25/2012	8/5/2012	11	PM - Air Handling Unit, over 50 Ton
FO-221929	Routine	Scheduled Maint. (PM)	7/21/2012	8/1/2012	11	PM - Air Handling Unit, over 50 Ton
FO-222458	Routine	Scheduled Maint. (PM)	7/26/2012	8/6/2012	11	PM - Air Handling Unit, over 50 Ton
FO-222482	Routine	Scheduled Maint. (PM)	7/19/2012	7/30/2012	11	PM - Fan Coil/HV/AC Unit
FO-222483	Routine	Scheduled Maint. (PM)	7/19/2012	7/30/2012	11	PM - Fan Coil/HV/AC Unit
FO-222484	Routine	Scheduled Maint. (PM)	7/19/2012	7/30/2012	11	PM - Fan Coil/HV/AC Unit
FO-222485	Routine	Scheduled Maint. (PM)	7/19/2012	7/30/2012	11	PM - Fan Coil/HV/AC Unit
FO-203830	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-203831	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-203832	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-203833	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater

Finish Date Due Date

Total per Trade

FO-203834	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-203835	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-203836	Low	Scheduled Maint. (PM)	1/12/2012	1/23/2012	11	PM - Unit/Space Heater
FO-210201	Low	Scheduled Maint. (PM)	3/9/2012	3/20/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217829	Low	Scheduled Maint. (PM)	5/25/2012	6/5/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220966	Low	Scheduled Maint. (PM)	7/20/2012	7/31/2012	11	PM - Fire Alarm System Test
FO-220967	Low	Scheduled Maint. (PM)	7/20/2012	7/31/2012	11	PM - Fire Alarm System Test
FO-220968	Low	Scheduled Maint. (PM)	7/20/2012	7/31/2012	11	PM - Fire Alarm System Test
FO-222007	Low	Scheduled Maint. (PM)	7/12/2012	7/23/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222008	Low	Scheduled Maint. (PM)	7/12/2012	7/23/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224911	Routine	Scheduled Maint. (PM)	8/28/2012	9/8/2012	11	PM - Air Handling Unit, over 50 Ton
FO-225563	Routine	Scheduled Maint. (PM)	9/1/2012	9/12/2012	11	PM - Air Handling Unit, over 50 Ton
FO-226134	Routine	Scheduled Maint. (PM)	8/31/2012	9/11/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226135	Routine	Scheduled Maint. (PM)	8/31/2012	9/11/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226195	Low	Scheduled Maint. (PM)	9/20/2012	10/1/2012	11	PM - Fire Alarm System Test
FO-226196	Low	Scheduled Maint. (PM)	9/20/2012	10/1/2012	11	PM - Fire Alarm System Test
FO-227198	Routine	Scheduled Maint. (PM)	9/29/2012	10/10/2012	11	PM - Unit/Space Heater
FO-227199	Routine	Scheduled Maint. (PM)	9/29/2012	10/10/2012	11	PM - Unit/Space Heater
FO-227422	Routine	Scheduled Maint. (PM)	9/29/2012	10/10/2012	11	PM - Unit/Space Heater
FO-227423	Routine	Scheduled Maint. (PM)	9/29/2012	10/10/2012	11	PM - Unit/Space Heater
FO-229477	Routine	Scheduled Maint. (PM)	10/11/2012	10/22/2012	11	PM - Fan Coil/HV/AC Unit
FO-229478	Routine	Scheduled Maint. (PM)	10/11/2012	10/22/2012	11	PM - Fan Coil/HV/AC Unit
FO-229479	Routine	Scheduled Maint. (PM)	10/11/2012	10/22/2012	11	PM - Fan Coil/HV/AC Unit
FO-229480	Routine	Scheduled Maint. (PM)	10/11/2012	10/22/2012	11	PM - Fan Coil/HV/AC Unit
FO-229481	Routine	Scheduled Maint. (PM)	10/11/2012	10/22/2012	11	PM - Fan Coil/HV/AC Unit
FO-230361	Routine	Scheduled Maint. (PM)	10/18/2012	10/29/2012	11	PM - Fan Coil/HV/AC Unit
FO-230362	Routine	Scheduled Maint. (PM)	10/18/2012	10/29/2012	11	PM - Fan Coil/HV/AC Unit
FO-230437	Routine	Scheduled Maint. (PM)	10/18/2012	10/29/2012	11	PM - Unit/Space Heater
FO-230439	Routine	Scheduled Maint. (PM)	10/18/2012	10/29/2012	11	PM - Unit/Space Heater
FO-230440	Routine	Scheduled Maint. (PM)	10/18/2012	10/29/2012	11	PM - Unit/Space Heater
FO-230583	Routine	Scheduled Maint. (PM)	11/3/2012	11/14/2012	11	PM - Air Handling Unit, over 50 Ton
FO-230586	Routine	Scheduled Maint. (PM)	11/3/2012	11/14/2012	11	PM - Air Handling Unit, over 50 Ton
FO-230601	Routine	Scheduled Maint. (PM)	10/29/2012	11/9/2012	11	PM - Air Handling Unit, over 50 Ton
FO-230602	Routine	Scheduled Maint. (PM)	10/30/2012	11/10/2012	11	PM - Air Handling Unit, over 50 Ton
FO-230725	Routine	Scheduled Maint. (PM)	11/1/2012	11/12/2012	11	PM - Fan Coil/HV/AC Unit
FO-230729	Routine	Scheduled Maint. (PM)	11/1/2012	11/12/2012	11	PM - Fan Coil/HV/AC Unit
FO-232285	Low	Scheduled Maint. (PM)	11/20/2012	12/1/2012	11	PM - Fire Alarm System Test
FO-232834	Routine	Scheduled Maint. (PM)	11/15/2012	11/26/2012	11	PM - Fan Coil/HV/AC Unit
FO-232835	Routine	Scheduled Maint. (PM)	11/15/2012	11/26/2012	11	PM - Fan Coil/HV/AC Unit
FO-232836	Routine	Scheduled Maint. (PM)	11/15/2012	11/26/2012	11	PM - Fan Coil/HV/AC Unit
FO-232837	Routine	Scheduled Maint. (PM)	11/15/2012	11/26/2012	11	PM - Fan Coil/HV/AC Unit
FO-234980	Routine	Scheduled Maint. (PM)	12/4/2012	12/15/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234981	Routine	Scheduled Maint. (PM)	12/4/2012	12/15/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235006	Routine	Scheduled Maint. (PM)	12/20/2012	12/31/2012	11	PM - Fire Alarm System Test

			Finish Date	Due Date			Total per Trade
FO-235335	Routine	Scheduled Maint. (PM)	12/12/2012	12/23/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236031	Routine	Scheduled Maint. (PM)	12/14/2012	12/25/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236032	Routine	Scheduled Maint. (PM)	12/14/2012	12/25/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236932	Routine	Scheduled Maint. (PM)	1/16/2013	1/27/2013	11	PM - Fire Pump, Main/Jockey	
FO-237913	Routine	Scheduled Maint. (PM)	1/25/2013	2/5/2013	11	PM - Air Handling Unit	
FO-203036	Routine	Scheduled Maint. (PM)	1/10/2012	1/20/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-205253	Routine	Scheduled Maint. (PM)	1/28/2012	2/7/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-207155	Routine	Scheduled Maint. (PM)	2/18/2012	2/28/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-207157	Routine	Scheduled Maint. (PM)	2/18/2012	2/28/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-207156	Routine	Scheduled Maint. (PM)	2/18/2012	2/28/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211976	Routine	Scheduled Maint. (PM)	4/3/2012	4/13/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-216716	Routine	Scheduled Maint. (PM)	5/22/2012	6/1/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-216717	Routine	Scheduled Maint. (PM)	5/17/2012	5/27/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-217808	Routine	Scheduled Maint. (PM)	6/5/2012	6/15/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-218762	Routine	Scheduled Maint. (PM)	6/8/2012	6/18/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221036	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221037	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221038	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221039	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221040	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-221041	Routine	Scheduled Maint. (PM)	6/29/2012	7/9/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222457	Routine	Scheduled Maint. (PM)	7/31/2012	8/10/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-222486	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222487	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222488	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222489	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222490	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-222491	Routine	Scheduled Maint. (PM)	7/20/2012	7/30/2012	10	PM - Fan Coil/HV/AC Unit	
FO-213471	Low	Scheduled Maint. (PM)	4/7/2012	4/17/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213472	Low	Scheduled Maint. (PM)	4/7/2012	4/17/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213473	Low	Scheduled Maint. (PM)	4/7/2012	4/17/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-214850	Low	Scheduled Maint. (PM)	4/21/2012	5/1/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215935	Low	Scheduled Maint. (PM)	5/4/2012	5/14/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215946	Low	Scheduled Maint. (PM)	5/4/2012	5/14/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-222009	Low	Scheduled Maint. (PM)	7/13/2012	7/23/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-222010	Low	Scheduled Maint. (PM)	7/13/2012	7/23/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-226073	Routine	Scheduled Maint. (PM)	9/7/2012	9/17/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-226746	Routine	Scheduled Maint. (PM)	9/12/2012	9/22/2012	10	PM - Unit/Space Heater	
FO-228712	Routine	Scheduled Maint. (PM)	10/5/2012	10/15/2012	10	PM - Fan Coil/HV/AC Unit	
FO-228764	Routine	Scheduled Maint. (PM)	10/5/2012	10/15/2012	10	PM - Fan Coil/HV/AC Unit	
FO-228768	Routine	Scheduled Maint. (PM)	10/5/2012	10/15/2012	10	PM - Fan Coil/HV/AC Unit	
FO-229482	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Fan Coil/HV/AC Unit	
FO-229483	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Fan Coil/HV/AC Unit	
FO-229485	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Fan Coil/HV/AC Unit	

			Finish Date	Due Date			Total per Trade
FO-229486	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Fan Coil/HV/AC Unit	
FO-229487	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Fan Coil/HV/AC Unit	
FO-230353	Routine	Scheduled Maint. (PM)	10/31/2012	11/10/2012	10	PM - Fire Pump, Main/Jockey	
FO-230354	Routine	Scheduled Maint. (PM)	10/31/2012	11/10/2012	10	PM - Fire Pump, Main/Jockey	
FO-230710	Routine	Scheduled Maint. (PM)	10/26/2012	11/5/2012	10	PM - Fan Coil/HV/AC Unit	
FO-230712	Routine	Scheduled Maint. (PM)	10/26/2012	11/5/2012	10	PM - Fan Coil/HV/AC Unit	
FO-230713	Routine	Scheduled Maint. (PM)	10/26/2012	11/5/2012	10	PM - Fan Coil/HV/AC Unit	
FO-230715	Routine	Scheduled Maint. (PM)	10/26/2012	11/5/2012	10	PM - Fan Coil/HV/AC Unit	
FO-230717	Routine	Scheduled Maint. (PM)	10/26/2012	11/5/2012	10	PM - Fan Coil/HV/AC Unit	
FO-232829	Routine	Scheduled Maint. (PM)	11/16/2012	11/26/2012	10	PM - Fan Coil/HV/AC Unit	
FO-232830	Routine	Scheduled Maint. (PM)	11/16/2012	11/26/2012	10	PM - Fan Coil/HV/AC Unit	
FO-232831	Routine	Scheduled Maint. (PM)	11/16/2012	11/26/2012	10	PM - Fan Coil/HV/AC Unit	
FO-233609	Routine	Scheduled Maint. (PM)	11/27/2012	12/7/2012	10	PM - Air Handling Unit, over 50 Ton	
FO-234995	Routine	Scheduled Maint. (PM)	11/22/2012	12/2/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-235336	Routine	Scheduled Maint. (PM)	12/14/2012	12/24/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236048	Routine	Scheduled Maint. (PM)	12/19/2012	12/29/2012	10	Replace filters	
FO-236999	Routine	Scheduled Maint. (PM)	1/15/2013	1/25/2013	10	PM - Air Handling Unit	
FO-237000	Routine	Scheduled Maint. (PM)	1/15/2013	1/25/2013	10	PM - Air Handling Unit	
FO-237001	Routine	Scheduled Maint. (PM)	1/15/2013	1/25/2013	10	PM - Air Handling Unit	
FO-237043	Routine	Scheduled Maint. (PM)	1/5/2013	1/15/2013	10	Replace filters	
FO-237044	Routine	Scheduled Maint. (PM)	1/5/2013	1/15/2013	10	Replace filters	
FO-237045	Routine	Scheduled Maint. (PM)	1/5/2013	1/15/2013	10	Replace filters	
FO-237046	Routine	Scheduled Maint. (PM)	1/5/2013	1/15/2013	10	Replace filters	
FO-237047	Routine	Scheduled Maint. (PM)	1/5/2013	1/15/2013	10	Replace filters	
FO-237912	Routine	Scheduled Maint. (PM)	1/25/2013	2/4/2013	10	PM - Air Handling Unit	
FO-238120	Routine	Scheduled Maint. (PM)	1/16/2013	1/26/2013	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-203035	Routine	Scheduled Maint. (PM)	1/11/2012	1/20/2012	9	PM - Air Handling Unit, over 50 Ton	
FO-206636	Routine	Scheduled Maint. (PM)	2/10/2012	2/19/2012	9	PM - Air Handling Unit, HV Type	
FO-209964	Routine	Scheduled Maint. (PM)	3/14/2012	3/23/2012	9	PM - Air Handling Unit, over 50 Ton	
FO-213470	Routine	Scheduled Maint. (PM)	4/13/2012	4/22/2012	9	PM - Air Handling Unit, over 50 Ton	
FO-214155	Routine	Scheduled Maint. (PM)	4/25/2012	5/4/2012	9	PM - Air Handling Unit, over 50 Ton	
FO-216640	Routine	Scheduled Maint. (PM)	5/12/2012	5/21/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-216709	Routine	Scheduled Maint. (PM)	5/29/2012	6/7/2012	9	PM - Fire Pump, Main/Jockey	
FO-216710	Routine	Scheduled Maint. (PM)	5/29/2012	6/7/2012	9	PM - Fire Pump, Main/Jockey	
FO-216719	Routine	Scheduled Maint. (PM)	5/18/2012	5/27/2012	9	PM - Air Handling Unit, over 50 Ton	
FO-217797	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217798	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217799	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217800	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217801	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217802	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217803	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217804	Routine	Scheduled Maint. (PM)	5/19/2012	5/28/2012	9	PM - Fan Coil/HV/AC Unit	
FO-217890	Routine	Scheduled Maint. (PM)	5/30/2012	6/8/2012	9	PM - Air Handling Unit, over 50 Ton	

			Finish Date	Due Date	Total per Trade	
FO-220970	Routine	Scheduled Maint. (PM)	7/2/2012	7/11/2012	9	PM - Unit/Space Heater
FO-221025	Routine	Scheduled Maint. (PM)	6/30/2012	7/9/2012	9	PM - Fan Coil/HV/AC Unit
FO-221026	Routine	Scheduled Maint. (PM)	6/30/2012	7/9/2012	9	PM - Fan Coil/HV/AC Unit
FO-221027	Routine	Scheduled Maint. (PM)	6/30/2012	7/9/2012	9	PM - Fan Coil/HV/AC Unit
FO-221028	Routine	Scheduled Maint. (PM)	6/30/2012	7/9/2012	9	PM - Fan Coil/HV/AC Unit
FO-221921	Routine	Scheduled Maint. (PM)	7/26/2012	8/4/2012	9	PM - Air Handling Unit, over 50 Ton
FO-224675	Routine	Scheduled Maint. (PM)	8/17/2012	8/26/2012	9	PM - Fire Pump, Main/Jockey
FO-224717	Routine	Scheduled Maint. (PM)	8/17/2012	8/26/2012	9	PM - Fire Pump, Main/Jockey
FO-224883	Routine	Scheduled Maint. (PM)	8/14/2012	8/23/2012	9	PM - Air Handling Unit, HV Type
FO-222011	Low	Scheduled Maint. (PM)	7/14/2012	7/23/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222012	Low	Scheduled Maint. (PM)	7/14/2012	7/23/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222013	Low	Scheduled Maint. (PM)	7/14/2012	7/23/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225076	Low	Scheduled Maint. (PM)	8/31/2012	9/9/2012	9	PM - Air Handling Unit, over 50 Ton
FO-225561	Routine	Scheduled Maint. (PM)	9/13/2012	9/22/2012	9	PM - Fire Pump, Main/Jockey
FO-226080	Routine	Scheduled Maint. (PM)	9/7/2012	9/16/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226137	Routine	Scheduled Maint. (PM)	9/8/2012	9/17/2012	9	PM - Fan Coil/HV/AC Unit
FO-226138	Routine	Scheduled Maint. (PM)	9/8/2012	9/17/2012	9	PM - Fan Coil/HV/AC Unit
FO-226139	Routine	Scheduled Maint. (PM)	9/8/2012	9/17/2012	9	PM - Fan Coil/HV/AC Unit
FO-226140	Routine	Scheduled Maint. (PM)	9/8/2012	9/17/2012	9	PM - Fan Coil/HV/AC Unit
FO-226796	Routine	Scheduled Maint. (PM)	9/15/2012	9/24/2012	9	PM - Fan Coil/HV/AC Unit
FO-226797	Routine	Scheduled Maint. (PM)	9/15/2012	9/24/2012	9	PM - Fan Coil/HV/AC Unit
FO-226798	Routine	Scheduled Maint. (PM)	9/15/2012	9/24/2012	9	PM - Fan Coil/HV/AC Unit
FO-227192	Routine	Scheduled Maint. (PM)	9/17/2012	9/26/2012	9	PM - Unit/Space Heater
FO-227193	Routine	Scheduled Maint. (PM)	9/17/2012	9/26/2012	9	PM - Unit/Space Heater
FO-227212	Routine	Scheduled Maint. (PM)	10/10/2012	10/19/2012	9	PM - Fan Coil/HV/AC Unit
FO-228765	Routine	Scheduled Maint. (PM)	10/6/2012	10/15/2012	9	PM - Fan Coil/HV/AC Unit
FO-228766	Routine	Scheduled Maint. (PM)	10/6/2012	10/15/2012	9	PM - Fan Coil/HV/AC Unit
FO-228767	Routine	Scheduled Maint. (PM)	10/6/2012	10/15/2012	9	PM - Fan Coil/HV/AC Unit
FO-230294	Routine	Scheduled Maint. (PM)	10/31/2012	11/9/2012	9	PM - Fire Pump, Main/Jockey
FO-230295	Routine	Scheduled Maint. (PM)	10/31/2012	11/9/2012	9	PM - Fire Pump, Main/Jockey
FO-230314	Routine	Scheduled Maint. (PM)	10/31/2012	11/9/2012	9	PM - Fire Pump, Main/Jockey
FO-230315	Routine	Scheduled Maint. (PM)	10/31/2012	11/9/2012	9	PM - Fire Pump, Main/Jockey
FO-230356	Routine	Scheduled Maint. (PM)	10/16/2012	10/25/2012	9	PM - Air Handling Unit, over 50 Ton
FO-230359	Routine	Scheduled Maint. (PM)	10/16/2012	10/25/2012	9	PM - Air Handling Unit, over 50 Ton
FO-230595	Routine	Scheduled Maint. (PM)	11/6/2012	11/15/2012	9	PM - Air Handling Unit, over 50 Ton
FO-230711	Routine	Scheduled Maint. (PM)	10/27/2012	11/5/2012	9	PM - Fan Coil/HV/AC Unit
FO-230714	Routine	Scheduled Maint. (PM)	10/27/2012	11/5/2012	9	PM - Fan Coil/HV/AC Unit
FO-230716	Routine	Scheduled Maint. (PM)	10/27/2012	11/5/2012	9	PM - Fan Coil/HV/AC Unit
FO-232250	Routine	Scheduled Maint. (PM)	10/24/2012	11/2/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232251	Routine	Scheduled Maint. (PM)	10/25/2012	11/3/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232278	Low	Scheduled Maint. (PM)	11/6/2012	11/15/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233607	Routine	Scheduled Maint. (PM)	11/29/2012	12/8/2012	9	PM - Air Handling Unit, over 50 Ton
FO-233608	Routine	Scheduled Maint. (PM)	11/29/2012	12/8/2012	9	PM - Air Handling Unit, over 50 Ton
FO-236631	Routine	Scheduled Maint. (PM)	1/4/2013	1/13/2013	9	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-236938	Routine	Scheduled Maint. (PM)	1/16/2013	1/25/2013	9	PM - Air Handling Unit
FO-236962	Routine	Scheduled Maint. (PM)	1/11/2013	1/20/2013	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236987	Routine	Scheduled Maint. (PM)	1/11/2013	1/20/2013	9	PM - Air Handling Unit
FO-238116	Routine	Scheduled Maint. (PM)	1/17/2013	1/26/2013	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238119	Routine	Scheduled Maint. (PM)	1/17/2013	1/26/2013	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238121	Routine	Scheduled Maint. (PM)	1/17/2013	1/26/2013	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238122	Routine	Scheduled Maint. (PM)	1/17/2013	1/26/2013	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203038	Routine	Scheduled Maint. (PM)	1/12/2012	1/20/2012	8	PM - Air Handling Unit, over 50 Ton
FO-205269	Routine	Scheduled Maint. (PM)	2/7/2012	2/15/2012	8	PM - Air Handling Unit, over 50 Ton
FO-205268	Routine	Scheduled Maint. (PM)	2/7/2012	2/15/2012	8	PM - Air Handling Unit, over 50 Ton
FO-205265	Routine	Scheduled Maint. (PM)	2/7/2012	2/15/2012	8	PM - Air Handling Unit, over 50 Ton
FO-206637	Routine	Scheduled Maint. (PM)	2/11/2012	2/19/2012	8	PM - Air Handling Unit, HV Type
FO-206632	Routine	Scheduled Maint. (PM)	2/22/2012	3/1/2012	8	PM - Air Handling Unit, over 50 Ton
FO-208167	Routine	Scheduled Maint. (PM)	3/12/2012	3/20/2012	8	PM - Air Handling Unit, over 50 Ton
FO-213460	Routine	Scheduled Maint. (PM)	4/10/2012	4/18/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213465	Routine	Scheduled Maint. (PM)	4/17/2012	4/25/2012	8	PM - Air Handling Unit, over 50 Ton
FO-214154	Routine	Scheduled Maint. (PM)	4/26/2012	5/4/2012	8	PM - Air Handling Unit, over 50 Ton
FO-214165	Routine	Scheduled Maint. (PM)	4/12/2012	4/20/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215465	Routine	Scheduled Maint. (PM)	5/8/2012	5/16/2012	8	PM - Air Handling Unit, over 50 Ton
FO-215466	Routine	Scheduled Maint. (PM)	5/8/2012	5/16/2012	8	PM - Air Handling Unit, over 50 Ton
FO-216643	Routine	Scheduled Maint. (PM)	5/15/2012	5/23/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216644	Routine	Scheduled Maint. (PM)	5/15/2012	5/23/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216718	Routine	Scheduled Maint. (PM)	5/19/2012	5/27/2012	8	PM - Air Handling Unit, over 50 Ton
FO-217858	Routine	Scheduled Maint. (PM)	6/6/2012	6/14/2012	8	PM - Air Handling Unit, HV Type
FO-217859	Routine	Scheduled Maint. (PM)	6/6/2012	6/14/2012	8	PM - Air Handling Unit, HV Type
FO-217860	Routine	Scheduled Maint. (PM)	6/6/2012	6/14/2012	8	PM - Air Handling Unit, HV Type
FO-217861	Routine	Scheduled Maint. (PM)	6/6/2012	6/14/2012	8	PM - Air Handling Unit, HV Type
FO-217867	Routine	Scheduled Maint. (PM)	6/6/2012	6/14/2012	8	PM - Air Handling Unit, HV Type
FO-219513	Routine	Scheduled Maint. (PM)	6/12/2012	6/20/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220988	Routine	Scheduled Maint. (PM)	7/11/2012	7/19/2012	8	PM - Fan Coil/HV/AC Unit
FO-224620	Routine	Scheduled Maint. (PM)	8/9/2012	8/17/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224621	Routine	Scheduled Maint. (PM)	8/9/2012	8/17/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224622	Routine	Scheduled Maint. (PM)	8/9/2012	8/17/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224623	Routine	Scheduled Maint. (PM)	8/9/2012	8/17/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225539	Routine	Scheduled Maint. (PM)	8/15/2012	8/23/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225540	Routine	Scheduled Maint. (PM)	8/15/2012	8/23/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225541	Routine	Scheduled Maint. (PM)	8/15/2012	8/23/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217879	Low	Scheduled Maint. (PM)	5/23/2012	5/31/2012	8	-> Consolidated PM items:Annual task: W847301 - PM - Fan, Centrifugal: Supply/Return/Exhaust FanSemi-annual t
FO-225061	Routine	Scheduled Maint. (PM)	8/29/2012	9/6/2012	8	PM - Air Handling Unit, over 50 Ton
FO-226811	Routine	Scheduled Maint. (PM)	9/11/2012	9/19/2012	8	PM - Unit/Space Heater
FO-229411	Routine	Scheduled Maint. (PM)	10/10/2012	10/18/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229490	Low	Scheduled Maint. (PM)	10/9/2012	10/17/2012	8	PM - Unit/Space Heater
FO-230355	Routine	Scheduled Maint. (PM)	10/17/2012	10/25/2012	8	PM - Air Handling Unit, over 50 Ton
FO-230584	Routine	Scheduled Maint. (PM)	11/6/2012	11/14/2012	8	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date			Total per Trade
FO-230587	Routine	Scheduled Maint. (PM)	11/6/2012	11/14/2012	8	PM - Air Handling Unit, over 50 Ton	
FO-230596	Routine	Scheduled Maint. (PM)	11/7/2012	11/15/2012	8	PM - Air Handling Unit, over 50 Ton	
FO-230810	Low	Scheduled Maint. (PM)	11/21/2012	11/29/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230811	Low	Scheduled Maint. (PM)	11/21/2012	11/29/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-232792	Routine	Scheduled Maint. (PM)	11/22/2012	11/30/2012	8	PM - Air Handling Unit, over 50 Ton	
FO-232793	Routine	Scheduled Maint. (PM)	11/22/2012	11/30/2012	8	PM - Air Handling Unit, over 50 Ton	
FO-233614	Low	Scheduled Maint. (PM)	11/21/2012	11/29/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-233615	Low	Scheduled Maint. (PM)	11/21/2012	11/29/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-233616	Low	Scheduled Maint. (PM)	11/21/2012	11/29/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-233630	Low	Scheduled Maint. (PM)	11/26/2012	12/4/2012	8	PM - Air Handling Unit, HV Type	
FO-236047	Routine	Scheduled Maint. (PM)	12/21/2012	12/29/2012	8	Replace filters	
FO-236934	Routine	Scheduled Maint. (PM)	1/9/2013	1/17/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236939	Routine	Scheduled Maint. (PM)	1/19/2013	1/27/2013	8	PM - Air Handling Unit	
FO-236940	Routine	Scheduled Maint. (PM)	1/19/2013	1/27/2013	8	PM - Air Handling Unit	
FO-236997	Routine	Scheduled Maint. (PM)	1/12/2013	1/20/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-237022	Routine	Scheduled Maint. (PM)	1/12/2013	1/20/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-238117	Routine	Scheduled Maint. (PM)	1/18/2013	1/26/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-238118	Routine	Scheduled Maint. (PM)	1/18/2013	1/26/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-205255	Routine	Scheduled Maint. (PM)	1/25/2012	2/1/2012	7	PM - Fan Coil/HV/AC Unit	
FO-205256	Routine	Scheduled Maint. (PM)	1/25/2012	2/1/2012	7	PM - Fan Coil/HV/AC Unit	
FO-206189	Routine	Scheduled Maint. (PM)	2/14/2012	2/21/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-206651	Routine	Scheduled Maint. (PM)	2/17/2012	2/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-206650	Routine	Scheduled Maint. (PM)	2/17/2012	2/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-206649	Routine	Scheduled Maint. (PM)	2/17/2012	2/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-206648	Routine	Scheduled Maint. (PM)	2/17/2012	2/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-207143	Routine	Scheduled Maint. (PM)	2/21/2012	2/28/2012	7	PM - Fan Coil/HV/AC Unit	
FO-207144	Routine	Scheduled Maint. (PM)	2/21/2012	2/28/2012	7	PM - Fan Coil/HV/AC Unit	
FO-207133	Routine	Scheduled Maint. (PM)	3/3/2012	3/10/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-208143	Routine	Scheduled Maint. (PM)	3/10/2012	3/17/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-209959	Routine	Scheduled Maint. (PM)	3/15/2012	3/22/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-209958	Routine	Scheduled Maint. (PM)	3/15/2012	3/22/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-211953	Routine	Scheduled Maint. (PM)	4/4/2012	4/11/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-211954	Routine	Scheduled Maint. (PM)	4/4/2012	4/11/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-211974	Routine	Scheduled Maint. (PM)	4/4/2012	4/11/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-213464	Routine	Scheduled Maint. (PM)	4/18/2012	4/25/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-214164	Routine	Scheduled Maint. (PM)	4/13/2012	4/20/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215467	Routine	Scheduled Maint. (PM)	5/9/2012	5/16/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-215908	Routine	Scheduled Maint. (PM)	5/9/2012	5/16/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-216645	Routine	Scheduled Maint. (PM)	5/16/2012	5/23/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-221920	Routine	Scheduled Maint. (PM)	7/27/2012	8/3/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-221923	Routine	Scheduled Maint. (PM)	8/2/2012	8/9/2012	7	PM - Fire Pump, Main/Jockey	
FO-222477	Routine	Scheduled Maint. (PM)	7/31/2012	8/7/2012	7	PM - Air Handling Unit, over 50 Ton	
FO-224690	Routine	Scheduled Maint. (PM)	8/17/2012	8/24/2012	7	PM - Fire Pump, Main/Jockey	
FO-224902	Routine	Scheduled Maint. (PM)	8/17/2012	8/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	

			Finish Date	Due Date	Total per Trade	
FO-224903	Routine	Scheduled Maint. (PM)	8/17/2012	8/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217871	Low	Scheduled Maint. (PM)	6/2/2012	6/9/2012	7	PM - Air Handling Unit, over 50 Ton
FO-217872	Low	Scheduled Maint. (PM)	6/2/2012	6/9/2012	7	PM - Air Handling Unit, over 50 Ton
FO-217880	Low	Scheduled Maint. (PM)	5/24/2012	5/31/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224904	Routine	Scheduled Maint. (PM)	8/21/2012	8/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224905	Routine	Scheduled Maint. (PM)	8/21/2012	8/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224906	Routine	Scheduled Maint. (PM)	8/21/2012	8/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225074	Low	Scheduled Maint. (PM)	8/27/2012	9/3/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226077	Routine	Scheduled Maint. (PM)	9/11/2012	9/18/2012	7	PM - Air Handling Unit, over 50 Ton
FO-226185	Routine	Scheduled Maint. (PM)	9/11/2012	9/18/2012	7	PM - Air Handling Unit, over 50 Ton
FO-226186	Routine	Scheduled Maint. (PM)	9/11/2012	9/18/2012	7	PM - Air Handling Unit, over 50 Ton
FO-226191	Routine	Scheduled Maint. (PM)	9/20/2012	9/27/2012	7	Monthly Fire System Test
FO-226755	Routine	Scheduled Maint. (PM)	9/14/2012	9/21/2012	7	PM - Unit/Space Heater
FO-226801	Routine	Scheduled Maint. (PM)	9/18/2012	9/25/2012	7	PM - Air Handling Unit, over 50 Ton
FO-226807	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-226808	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-226809	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-226810	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-226812	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-226813	Routine	Scheduled Maint. (PM)	9/12/2012	9/19/2012	7	PM - Unit/Space Heater
FO-227189	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Unit/Space Heater
FO-227191	Routine	Scheduled Maint. (PM)	9/19/2012	9/26/2012	7	PM - Unit/Space Heater
FO-227206	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan Coil/HV/AC Unit
FO-227215	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227216	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227217	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227218	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227219	Routine	Scheduled Maint. (PM)	9/21/2012	9/28/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227327	Low	Scheduled Maint. (PM)	9/20/2012	9/27/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227328	Low	Scheduled Maint. (PM)	9/20/2012	9/27/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229437	Routine	Scheduled Maint. (PM)	10/26/2012	11/2/2012	7	PM - Fire Pump, Main/Jockey
FO-230812	Low	Scheduled Maint. (PM)	11/22/2012	11/29/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230813	Low	Scheduled Maint. (PM)	11/22/2012	11/29/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232279	Low	Scheduled Maint. (PM)	11/8/2012	11/15/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235342	Routine	Scheduled Maint. (PM)	12/14/2012	12/21/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236046	Routine	Scheduled Maint. (PM)	12/22/2012	12/29/2012	7	Replace filters
FO-236653	Routine	Scheduled Maint. (PM)	1/10/2013	1/17/2013	7	PM - Air Handling Unit, over 50 Ton
FO-236965	Routine	Scheduled Maint. (PM)	1/11/2013	1/18/2013	7	PM - Fan Coil/HV/AC Unit
FO-237023	Routine	Scheduled Maint. (PM)	1/15/2013	1/22/2013	7	PM - Air Handling Unit
FO-203406	Routine	Scheduled Maint. (PM)	1/5/2012	1/11/2012	6	PM - Fan Coil/HV/AC Unit
FO-203407	Routine	Scheduled Maint. (PM)	1/5/2012	1/11/2012	6	PM - Fan Coil/HV/AC Unit
FO-203408	Routine	Scheduled Maint. (PM)	1/5/2012	1/11/2012	6	PM - Fan Coil/HV/AC Unit
FO-203037	Routine	Scheduled Maint. (PM)	1/14/2012	1/20/2012	6	PM - Air Handling Unit, over 50 Ton
FO-203366	Routine	Scheduled Maint. (PM)	1/14/2012	1/20/2012	6	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-203839	Routine	Scheduled Maint. (PM)	1/18/2012	1/24/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203840	Routine	Scheduled Maint. (PM)	1/18/2012	1/24/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203369	Routine	Scheduled Maint. (PM)	1/27/2012	2/2/2012	6	PM - Fire Pump, Main/Jockey
FO-203368	Routine	Scheduled Maint. (PM)	1/27/2012	2/2/2012	6	PM - Fire Pump, Main/Jockey
FO-205235	Routine	Scheduled Maint. (PM)	2/9/2012	2/15/2012	6	PM - Air Handling Unit, over 50 Ton
FO-205236	Routine	Scheduled Maint. (PM)	2/9/2012	2/15/2012	6	PM - Air Handling Unit, over 50 Ton
FO-205262	Routine	Scheduled Maint. (PM)	2/9/2012	2/15/2012	6	PM - Air Handling Unit, over 50 Ton
FO-206045	Routine	Scheduled Maint. (PM)	2/11/2012	2/17/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206046	Routine	Scheduled Maint. (PM)	2/11/2012	2/17/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206047	Routine	Scheduled Maint. (PM)	2/11/2012	2/17/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206048	Routine	Scheduled Maint. (PM)	2/11/2012	2/17/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-207154	Routine	Scheduled Maint. (PM)	2/22/2012	2/28/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211964	Routine	Scheduled Maint. (PM)	3/22/2012	3/28/2012	6	PM - Fan Coil/HV/AC Unit
FO-211965	Routine	Scheduled Maint. (PM)	3/22/2012	3/28/2012	6	PM - Fan Coil/HV/AC Unit
FO-211261	Routine	Scheduled Maint. (PM)	3/22/2012	3/28/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211262	Routine	Scheduled Maint. (PM)	3/22/2012	3/28/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211955	Routine	Scheduled Maint. (PM)	4/5/2012	4/11/2012	6	PM - Air Handling Unit, over 50 Ton
FO-211958	Routine	Scheduled Maint. (PM)	3/28/2012	4/3/2012	6	PM - Air Handling Unit, over 50 Ton
FO-211973	Routine	Scheduled Maint. (PM)	4/5/2012	4/11/2012	6	PM - Air Handling Unit, over 50 Ton
FO-211975	Routine	Scheduled Maint. (PM)	4/5/2012	4/11/2012	6	PM - Air Handling Unit, over 50 Ton
FO-214174	Routine	Scheduled Maint. (PM)	4/19/2012	4/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-214175	Routine	Scheduled Maint. (PM)	4/19/2012	4/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-216674	Routine	Scheduled Maint. (PM)	5/25/2012	5/31/2012	6	PM - Air Handling Unit, HV Type
FO-221231	Routine	Scheduled Maint. (PM)	7/27/2012	8/2/2012	6	PM - Fire Pump, Main/Jockey
FO-224617	Routine	Scheduled Maint. (PM)	8/9/2012	8/15/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224664	Routine	Scheduled Maint. (PM)	8/11/2012	8/17/2012	6	PM - Air Handling Unit, over 50 Ton
FO-224683	Routine	Scheduled Maint. (PM)	8/16/2012	8/22/2012	6	PM - Air Handling Unit, over 50 Ton
FO-224886	Routine	Scheduled Maint. (PM)	8/17/2012	8/23/2012	6	PM - Air Handling Unit, HV Type
FO-209946	Low	Scheduled Maint. (PM)	3/6/2012	3/12/2012	6	Final Filter Replacement (18 MONTH FIXED INTERVAL)This work order is formal authorization to remove prefilters
FO-215450	Low	Scheduled Maint. (PM)	5/2/2012	5/8/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215451	Low	Scheduled Maint. (PM)	5/2/2012	5/8/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215452	Low	Scheduled Maint. (PM)	5/2/2012	5/8/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217881	Low	Scheduled Maint. (PM)	5/25/2012	5/31/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225062	Routine	Scheduled Maint. (PM)	9/1/2012	9/7/2012	6	PM - Air Handling Unit, over 50 Ton
FO-225063	Routine	Scheduled Maint. (PM)	9/1/2012	9/7/2012	6	PM - Air Handling Unit, over 50 Ton
FO-225064	Low	Scheduled Maint. (PM)	8/28/2012	9/3/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225065	Low	Scheduled Maint. (PM)	8/21/2012	8/27/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225582	Routine	Scheduled Maint. (PM)	9/11/2012	9/17/2012	6	PM - Air Handling Unit, over 50 Ton
FO-226782	Routine	Scheduled Maint. (PM)	9/15/2012	9/21/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226783	Routine	Scheduled Maint. (PM)	9/15/2012	9/21/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226784	Routine	Scheduled Maint. (PM)	9/19/2012	9/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-226802	Routine	Scheduled Maint. (PM)	9/19/2012	9/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-226831	Low	Scheduled Maint. (PM)	9/14/2012	9/20/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226832	Low	Scheduled Maint. (PM)	9/14/2012	9/20/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-227246	Routine	Scheduled Maint. (PM)	9/29/2012	10/5/2012	6	PM - Fan Coil/HV/AC Unit
FO-227271	Routine	Scheduled Maint. (PM)	9/20/2012	9/26/2012	6	PM - Unit/Space Heater
FO-227272	Routine	Scheduled Maint. (PM)	9/20/2012	9/26/2012	6	PM - Unit/Space Heater
FO-227279	Routine	Scheduled Maint. (PM)	9/29/2012	10/5/2012	6	PM - Fan Coil/HV/AC Unit
FO-228769	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228770	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228771	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228772	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228775	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228776	Routine	Scheduled Maint. (PM)	10/9/2012	10/15/2012	6	PM - Fan Coil/HV/AC Unit
FO-228790	Routine	Scheduled Maint. (PM)	10/25/2012	10/31/2012	6	Maintain Fan Powered Boxes
FO-228792	Routine	Scheduled Maint. (PM)	10/25/2012	10/31/2012	6	Maintain Fan Powered Boxes
FO-228793	Routine	Scheduled Maint. (PM)	10/25/2012	10/31/2012	6	Maintain Fan Powered Boxes
FO-229430	Routine	Scheduled Maint. (PM)	10/12/2012	10/18/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229431	Routine	Scheduled Maint. (PM)	10/12/2012	10/18/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229432	Routine	Scheduled Maint. (PM)	10/12/2012	10/18/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229453	Routine	Scheduled Maint. (PM)	10/19/2012	10/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-229454	Routine	Scheduled Maint. (PM)	10/19/2012	10/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-230435	Routine	Scheduled Maint. (PM)	10/23/2012	10/29/2012	6	PM - Unit/Space Heater
FO-230455	Low	Scheduled Maint. (PM)	11/24/2012	11/30/2012	6	PM - Air Handling Unit, over 50 Ton
FO-230458	Low	Scheduled Maint. (PM)	11/24/2012	11/30/2012	6	PM - Air Handling Unit, over 50 Ton
FO-230589	Routine	Scheduled Maint. (PM)	11/8/2012	11/14/2012	6	PM - Air Handling Unit, over 50 Ton
FO-230590	Routine	Scheduled Maint. (PM)	11/8/2012	11/14/2012	6	PM - Air Handling Unit, over 50 Ton
FO-230776	Routine	Scheduled Maint. (PM)	11/21/2012	11/27/2012	6	Monthly Fire System Test
FO-232819	Routine	Scheduled Maint. (PM)	11/1/2012	11/7/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232838	Routine	Scheduled Maint. (PM)	11/17/2012	11/23/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232901	Low	Scheduled Maint. (PM)	11/21/2012	11/27/2012	6	PM - Air Handling Unit, HV Type
FO-234334	Routine	Scheduled Maint. (PM)	11/30/2012	12/6/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234972	Routine	Scheduled Maint. (PM)	12/13/2012	12/19/2012	6	PM - Air Handling Unit, over 50 Ton
FO-235331	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235341	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235364	Routine	Scheduled Maint. (PM)	12/19/2012	12/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-235395	Routine	Scheduled Maint. (PM)	12/19/2012	12/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-235396	Routine	Scheduled Maint. (PM)	12/19/2012	12/25/2012	6	PM - Air Handling Unit, over 50 Ton
FO-236651	Routine	Scheduled Maint. (PM)	1/11/2013	1/17/2013	6	PM - Air Handling Unit, over 50 Ton
FO-236652	Routine	Scheduled Maint. (PM)	1/11/2013	1/17/2013	6	PM - Air Handling Unit, over 50 Ton
FO-237042	Routine	Scheduled Maint. (PM)	1/9/2013	1/15/2013	6	Replace filters
FO-205283	Routine	Scheduled Maint. (PM)	2/4/2012	2/9/2012	5	PM - Air Handling Unit, over 50 Ton
FO-207142	Routine	Scheduled Maint. (PM)	2/23/2012	2/28/2012	5	PM - Fan Coil/HV/AC Unit
FO-214171	Routine	Scheduled Maint. (PM)	4/20/2012	4/25/2012	5	PM - Air Handling Unit, over 50 Ton
FO-214172	Routine	Scheduled Maint. (PM)	4/20/2012	4/25/2012	5	PM - Air Handling Unit, over 50 Ton
FO-215431	Routine	Scheduled Maint. (PM)	5/11/2012	5/16/2012	5	PM - Air Handling Unit, over 50 Ton
FO-215432	Routine	Scheduled Maint. (PM)	5/11/2012	5/16/2012	5	PM - Air Handling Unit, over 50 Ton
FO-216707	Routine	Scheduled Maint. (PM)	5/18/2012	5/23/2012	5	PM - Unit/Space Heater

			Finish Date	Due Date	Total per Trade	
FO-216708	Routine	Scheduled Maint. (PM)	5/18/2012	5/23/2012	5	PM - Unit/Space Heater
FO-216711	Routine	Scheduled Maint. (PM)	5/24/2012	5/29/2012	5	PM - Air Handling Unit, over 50 Ton
FO-217815	Routine	Scheduled Maint. (PM)	6/1/2012	6/6/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217818	Routine	Scheduled Maint. (PM)	6/1/2012	6/6/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218778	Routine	Scheduled Maint. (PM)	6/13/2012	6/18/2012	5	PM - Fan Coil/HV/AC Unit
FO-219572	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219575	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219579	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219580	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219581	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219582	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219583	Routine	Scheduled Maint. (PM)	6/15/2012	6/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220943	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220944	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220946	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220997	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	Replace filters
FO-220999	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	Replace filters
FO-221000	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	Replace filters
FO-221001	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	Replace filters
FO-221002	Routine	Scheduled Maint. (PM)	7/12/2012	7/17/2012	5	PM - Fire Pump, Main/Jockey
FO-221003	Routine	Scheduled Maint. (PM)	7/12/2012	7/17/2012	5	PM - Fire Pump, Main/Jockey
FO-222470	Routine	Scheduled Maint. (PM)	7/27/2012	8/1/2012	5	PM - Unit/Space Heater
FO-222493	Routine	Scheduled Maint. (PM)	7/27/2012	8/1/2012	5	PM - Fan Coil/HV/AC Unit
FO-222494	Routine	Scheduled Maint. (PM)	7/27/2012	8/1/2012	5	PM - Fan Coil/HV/AC Unit
FO-209945	Low	Scheduled Maint. (PM)	3/7/2012	3/12/2012	5	Final Filter Replacement (18 MONTH FIXED INTERVAL)This work order is formal authorization to remove prefilters
FO-209947	Low	Scheduled Maint. (PM)	3/7/2012	3/12/2012	5	Final Filter Replacement (18 MONTH FIXED INTERVAL)This work order is formal authorization to remove prefilters
FO-213468	Low	Scheduled Maint. (PM)	4/24/2012	4/29/2012	5	Replace filters
FO-213469	Low	Scheduled Maint. (PM)	4/24/2012	4/29/2012	5	Replace filters
FO-217882	Low	Scheduled Maint. (PM)	5/26/2012	5/31/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218741	Low	Scheduled Maint. (PM)	6/22/2012	6/27/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224762	Low	Scheduled Maint. (PM)	8/10/2012	8/15/2012	5	PM - Air Handling Unit, over 50 Ton
FO-225004	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225005	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225006	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225007	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225008	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225009	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225023	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225024	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-225025	Routine	Scheduled Maint. (PM)	8/29/2012	9/3/2012	5	PM - Fan Coil/HV/AC Unit
FO-227285	Routine	Scheduled Maint. (PM)	9/28/2012	10/3/2012	5	PM - Air Handling Unit, over 50 Ton
FO-228668	Low	Scheduled Maint. (PM)	10/26/2012	10/31/2012	5	PM - Fire Alarm System Test
FO-228807	Low	Scheduled Maint. (PM)	10/26/2012	10/31/2012	5	PM - Fire Alarm System Test
FO-229433	Routine	Scheduled Maint. (PM)	10/13/2012	10/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-229434	Routine	Scheduled Maint. (PM)	10/13/2012	10/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229435	Routine	Scheduled Maint. (PM)	10/13/2012	10/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229436	Routine	Scheduled Maint. (PM)	10/13/2012	10/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229456	Routine	Scheduled Maint. (PM)	10/20/2012	10/25/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232260	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232266	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232267	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232268	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232269	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232270	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232271	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-232280	Low	Scheduled Maint. (PM)	11/10/2012	11/15/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232286	Routine	Scheduled Maint. (PM)	11/17/2012	11/22/2012	5	PM - Air Handling Unit, HV Type
FO-234290	Routine	Scheduled Maint. (PM)	11/30/2012	12/5/2012	5	PM - Fan Coil/HV/AC Unit
FO-234291	Routine	Scheduled Maint. (PM)	11/30/2012	12/5/2012	5	PM - Fan Coil/HV/AC Unit
FO-234292	Routine	Scheduled Maint. (PM)	11/30/2012	12/5/2012	5	PM - Fan Coil/HV/AC Unit
FO-234333	Routine	Scheduled Maint. (PM)	12/1/2012	12/6/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235332	Routine	Scheduled Maint. (PM)	12/13/2012	12/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235350	Routine	Scheduled Maint. (PM)	12/13/2012	12/18/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235393	Routine	Scheduled Maint. (PM)	12/22/2012	12/27/2012	5	PM - Air Handling Unit, over 50 Ton
FO-235394	Routine	Scheduled Maint. (PM)	12/22/2012	12/27/2012	5	PM - Air Handling Unit, over 50 Ton
FO-236083	Routine	Scheduled Maint. (PM)	12/22/2012	12/27/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236084	Routine	Scheduled Maint. (PM)	12/22/2012	12/27/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236988	Routine	Scheduled Maint. (PM)	1/15/2013	1/20/2013	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237004	Routine	Scheduled Maint. (PM)	1/5/2013	1/10/2013	5	PM - Air Handling Unit
FO-237005	Routine	Scheduled Maint. (PM)	1/5/2013	1/10/2013	5	PM - Air Handling Unit
FO-237006	Routine	Scheduled Maint. (PM)	1/5/2013	1/10/2013	5	PM - Air Handling Unit
FO-237034	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237035	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237036	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237037	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237038	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237039	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-237040	Routine	Scheduled Maint. (PM)	1/18/2013	1/23/2013	5	PM - Unit/Space Heater
FO-205251	Routine	Scheduled Maint. (PM)	1/27/2012	1/31/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205259	Routine	Scheduled Maint. (PM)	2/3/2012	2/7/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205260	Routine	Scheduled Maint. (PM)	2/3/2012	2/7/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206042	Routine	Scheduled Maint. (PM)	2/11/2012	2/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206043	Routine	Scheduled Maint. (PM)	2/11/2012	2/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206044	Routine	Scheduled Maint. (PM)	2/11/2012	2/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205261	Routine	Scheduled Maint. (PM)	2/11/2012	2/15/2012	4	PM - Air Handling Unit, over 50 Ton
FO-206190	Routine	Scheduled Maint. (PM)	2/17/2012	2/21/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209966	Routine	Scheduled Maint. (PM)	3/13/2012	3/17/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208144	Routine	Scheduled Maint. (PM)	3/13/2012	3/17/2012	4	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-211963	Routine	Scheduled Maint. (PM)	3/24/2012	3/28/2012	4	PM - Fan Coil/HV/AC Unit
FO-213476	Routine	Scheduled Maint. (PM)	4/14/2012	4/18/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213477	Routine	Scheduled Maint. (PM)	4/14/2012	4/18/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213478	Routine	Scheduled Maint. (PM)	4/14/2012	4/18/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213479	Routine	Scheduled Maint. (PM)	4/14/2012	4/18/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214158	Routine	Scheduled Maint. (PM)	4/28/2012	5/2/2012	4	PM - Air Handling Unit, over 50 Ton
FO-215921	Routine	Scheduled Maint. (PM)	5/18/2012	5/22/2012	4	PM - Air Handling Unit, over 50 Ton
FO-216657	Routine	Scheduled Maint. (PM)	5/26/2012	5/30/2012	4	PM - Air Handling Unit, over 50 Ton
FO-216692	Routine	Scheduled Maint. (PM)	5/18/2012	5/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216693	Routine	Scheduled Maint. (PM)	5/18/2012	5/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216694	Routine	Scheduled Maint. (PM)	5/18/2012	5/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216695	Routine	Scheduled Maint. (PM)	5/18/2012	5/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217814	Routine	Scheduled Maint. (PM)	6/2/2012	6/6/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217816	Routine	Scheduled Maint. (PM)	6/2/2012	6/6/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218763	Routine	Scheduled Maint. (PM)	6/14/2012	6/18/2012	4	PM - Fan Coil/HV/AC Unit
FO-219571	Routine	Scheduled Maint. (PM)	6/16/2012	6/20/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219573	Routine	Scheduled Maint. (PM)	6/16/2012	6/20/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219574	Routine	Scheduled Maint. (PM)	6/16/2012	6/20/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220947	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220955	Routine	Scheduled Maint. (PM)	7/7/2012	7/11/2012	4	PM - Air Handling Unit, over 50 Ton
FO-220972	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221005	Routine	Scheduled Maint. (PM)	7/17/2012	7/21/2012	4	PM - Air Handling Unit, over 50 Ton
FO-221006	Routine	Scheduled Maint. (PM)	7/10/2012	7/14/2012	4	PM - Air Handling Unit, over 50 Ton
FO-221009	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	-> Consolidated PM items:
FO-221010	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	-> Consolidated PM items:
FO-221047	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-221048	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-221049	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-221050	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-221051	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-221052	Routine	Scheduled Maint. (PM)	7/12/2012	7/16/2012	4	PM - Fan Coil/HV/AC Unit
FO-224591	Routine	Scheduled Maint. (PM)	8/10/2012	8/14/2012	4	PM - Air Handling Unit, over 50 Ton
FO-224618	Routine	Scheduled Maint. (PM)	8/11/2012	8/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224619	Routine	Scheduled Maint. (PM)	8/11/2012	8/15/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224637	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224638	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224639	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224646	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224647	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224648	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224649	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224650	Routine	Scheduled Maint. (PM)	8/9/2012	8/13/2012	4	PM - Fan Coil/HV/AC Unit
FO-224679	Routine	Scheduled Maint. (PM)	8/18/2012	8/22/2012	4	PM - Air Handling Unit, over 50 Ton
FO-224898	Routine	Scheduled Maint. (PM)	8/17/2012	8/21/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-224899	Routine	Scheduled Maint. (PM)	8/17/2012	8/21/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-207137	Low	Scheduled Maint. (PM)	2/23/2012	2/27/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208151	Low	Scheduled Maint. (PM)	3/8/2012	3/12/2012	4	PM - Air Handling Unit, HV Type
FO-217824	Low	Scheduled Maint. (PM)	6/6/2012	6/10/2012	4	PM - Air Handling Unit, HV Type
FO-217825	Low	Scheduled Maint. (PM)	5/25/2012	5/29/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217826	Low	Scheduled Maint. (PM)	5/25/2012	5/29/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220975	Low	Scheduled Maint. (PM)	7/6/2012	7/10/2012	4	PM - Unit/Space Heater
FO-220976	Low	Scheduled Maint. (PM)	7/6/2012	7/10/2012	4	PM - Unit/Space Heater
FO-224910	Routine	Scheduled Maint. (PM)	8/28/2012	9/1/2012	4	PM - Air Handling Unit, over 50 Ton
FO-225551	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Air Handling Unit, HV Type
FO-225567	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225568	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225569	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225570	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225571	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225577	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-225578	Routine	Scheduled Maint. (PM)	9/6/2012	9/10/2012	4	PM - Fan Coil/HV/AC Unit
FO-226102	Low	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fire Alarm System Test
FO-226792	Routine	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226793	Routine	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226794	Routine	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226795	Routine	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226826	Low	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226827	Low	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226828	Low	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-226829	Low	Scheduled Maint. (PM)	9/20/2012	9/24/2012	4	PM - Fan Coil/HV/AC Unit
FO-227196	Routine	Scheduled Maint. (PM)	9/29/2012	10/3/2012	4	PM - Unit/Space Heater
FO-227197	Routine	Scheduled Maint. (PM)	9/29/2012	10/3/2012	4	PM - Unit/Space Heater
FO-227203	Routine	Scheduled Maint. (PM)	9/29/2012	10/3/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227223	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227224	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227225	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227226	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227227	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227228	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227229	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227230	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227231	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227232	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227233	Routine	Scheduled Maint. (PM)	9/27/2012	10/1/2012	4	PM - Fan Coil/HV/AC Unit
FO-227234	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227235	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227236	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227237	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit

			Finish Date	Due Date	Total per Trade	
FO-227238	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227239	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227240	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227243	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227244	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-227245	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Fan Coil/HV/AC Unit
FO-229488	Routine	Scheduled Maint. (PM)	10/18/2012	10/22/2012	4	PM - Fan Coil/HV/AC Unit
FO-229491	Routine	Scheduled Maint. (PM)	10/18/2012	10/22/2012	4	PM - Fan Coil/HV/AC Unit
FO-230430	Routine	Scheduled Maint. (PM)	10/25/2012	10/29/2012	4	PM - Unit/Space Heater
FO-230432	Routine	Scheduled Maint. (PM)	10/25/2012	10/29/2012	4	PM - Unit/Space Heater
FO-230707	Routine	Scheduled Maint. (PM)	11/1/2012	11/5/2012	4	PM - Fan Coil/HV/AC Unit
FO-230767	Low	Scheduled Maint. (PM)	11/2/2012	11/6/2012	4	PM - Unit/Space Heater
FO-230768	Low	Scheduled Maint. (PM)	11/2/2012	11/6/2012	4	PM - Unit/Space Heater
FO-234969	Routine	Scheduled Maint. (PM)	12/18/2012	12/22/2012	4	PM - Air Handling Unit, over 50 Ton
FO-236994	Routine	Scheduled Maint. (PM)	1/16/2013	1/20/2013	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236996	Routine	Scheduled Maint. (PM)	1/16/2013	1/20/2013	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237048	Routine	Scheduled Maint. (PM)	1/11/2013	1/15/2013	4	Karmanos - North Tower Filter Replacement Safety Procedures
FO-237049	Routine	Scheduled Maint. (PM)	1/11/2013	1/15/2013	4	Karmanos - North Tower Filter Replacement Safety Procedures
FO-203131	Routine	Scheduled Maint. (PM)	1/14/2012	1/17/2012	3	PM - Air Handling Unit, over 50 Ton
FO-203132	Routine	Scheduled Maint. (PM)	1/14/2012	1/17/2012	3	PM - Air Handling Unit, over 50 Ton
FO-205252	Routine	Scheduled Maint. (PM)	1/28/2012	1/31/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205234	Routine	Scheduled Maint. (PM)	2/24/2012	2/27/2012	3	Monthly Fire System Test
FO-206628	Routine	Scheduled Maint. (PM)	2/29/2012	3/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-209965	Routine	Scheduled Maint. (PM)	3/13/2012	3/16/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208141	Routine	Scheduled Maint. (PM)	3/14/2012	3/17/2012	3	PM - Air Handling Unit, over 50 Ton
FO-214846	Routine	Scheduled Maint. (PM)	5/5/2012	5/8/2012	3	PM - Air Handling Unit, over 50 Ton
FO-214847	Routine	Scheduled Maint. (PM)	5/5/2012	5/8/2012	3	PM - Air Handling Unit, over 50 Ton
FO-215430	Routine	Scheduled Maint. (PM)	5/25/2012	5/28/2012	3	Monthly Fire System Test
FO-215913	Routine	Scheduled Maint. (PM)	5/11/2012	5/14/2012	3	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-215914	Routine	Scheduled Maint. (PM)	5/11/2012	5/14/2012	3	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-217807	Routine	Scheduled Maint. (PM)	6/5/2012	6/8/2012	3	PM - Air Handling Unit, over 50 Ton
FO-217813	Routine	Scheduled Maint. (PM)	6/9/2012	6/12/2012	3	PM - Air Handling Unit, over 50 Ton
FO-217869	Routine	Scheduled Maint. (PM)	6/6/2012	6/9/2012	3	PM - Air Handling Unit, HV Type
FO-217873	Routine	Scheduled Maint. (PM)	5/25/2012	5/28/2012	3	PM - Fan Coil/HV/AC Unit
FO-217874	Routine	Scheduled Maint. (PM)	5/25/2012	5/28/2012	3	PM - Fan Coil/HV/AC Unit
FO-217875	Routine	Scheduled Maint. (PM)	5/25/2012	5/28/2012	3	PM - Fan Coil/HV/AC Unit
FO-217891	Routine	Scheduled Maint. (PM)	6/12/2012	6/15/2012	3	PM - Air Handling Unit, over 50 Ton
FO-218709	Routine	Scheduled Maint. (PM)	6/15/2012	6/18/2012	3	PM - Air Handling Unit, over 50 Ton
FO-218710	Routine	Scheduled Maint. (PM)	6/15/2012	6/18/2012	3	PM - Air Handling Unit, over 50 Ton
FO-218724	Routine	Scheduled Maint. (PM)	6/14/2012	6/17/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218725	Routine	Scheduled Maint. (PM)	6/14/2012	6/17/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218761	Routine	Scheduled Maint. (PM)	6/15/2012	6/18/2012	3	PM - Air Handling Unit, over 50 Ton
FO-218792	Routine	Scheduled Maint. (PM)	6/9/2012	6/12/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219521	Routine	Scheduled Maint. (PM)	6/26/2012	6/29/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date

Total per Trade

FO-219522	Routine	Scheduled Maint. (PM)	6/27/2012	6/30/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219523	Routine	Scheduled Maint. (PM)	6/22/2012	6/25/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221044	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221045	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221046	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221053	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221054	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221055	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221056	Routine	Scheduled Maint. (PM)	7/13/2012	7/16/2012	3	PM - Fan Coil/HV/AC Unit
FO-221062	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221063	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221064	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221065	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221066	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221067	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221068	Routine	Scheduled Maint. (PM)	7/12/2012	7/15/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221916	Routine	Scheduled Maint. (PM)	7/31/2012	8/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221937	Routine	Scheduled Maint. (PM)	7/31/2012	8/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221967	Routine	Scheduled Maint. (PM)	7/31/2012	8/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-224590	Routine	Scheduled Maint. (PM)	8/11/2012	8/14/2012	3	PM - Air Handling Unit, over 50 Ton
FO-224640	Routine	Scheduled Maint. (PM)	8/10/2012	8/13/2012	3	PM - Fan Coil/HV/AC Unit
FO-224641	Routine	Scheduled Maint. (PM)	8/10/2012	8/13/2012	3	PM - Fan Coil/HV/AC Unit
FO-224642	Routine	Scheduled Maint. (PM)	8/10/2012	8/13/2012	3	PM - Fan Coil/HV/AC Unit
FO-207138	Low	Scheduled Maint. (PM)	2/24/2012	2/27/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208155	Low	Scheduled Maint. (PM)	3/9/2012	3/12/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-210200	Low	Scheduled Maint. (PM)	3/17/2012	3/20/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213474	Low	Scheduled Maint. (PM)	4/7/2012	4/10/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213475	Low	Scheduled Maint. (PM)	4/7/2012	4/10/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213833	Low	Scheduled Maint. (PM)	4/21/2012	4/24/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213834	Low	Scheduled Maint. (PM)	4/21/2012	4/24/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215926	Low	Scheduled Maint. (PM)	5/18/2012	5/21/2012	3	PM - Air Handling Unit, HV Type
FO-217868	Low	Scheduled Maint. (PM)	6/13/2012	6/16/2012	3	PM - Fire Pump, Main/Jockey
FO-224596	Routine	Scheduled Maint. (PM)	8/25/2012	8/28/2012	3	PM - Air Handling Unit, over 50 Ton
FO-224901	Routine	Scheduled Maint. (PM)	8/21/2012	8/24/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225590	Low	Scheduled Maint. (PM)	9/7/2012	9/10/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225591	Low	Scheduled Maint. (PM)	9/7/2012	9/10/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226096	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226097	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226098	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226106	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226107	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226108	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226109	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226110	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater

			Finish Date	Due Date	Total per Trade	
FO-226111	Low	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Unit/Space Heater
FO-226152	Routine	Scheduled Maint. (PM)	9/8/2012	9/11/2012	3	PM - Fan Coil/HV/AC Unit
FO-226179	Routine	Scheduled Maint. (PM)	9/11/2012	9/14/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226180	Routine	Scheduled Maint. (PM)	9/11/2012	9/14/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226181	Routine	Scheduled Maint. (PM)	9/11/2012	9/14/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226182	Routine	Scheduled Maint. (PM)	9/11/2012	9/14/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226188	Routine	Scheduled Maint. (PM)	9/19/2012	9/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-226190	Routine	Scheduled Maint. (PM)	9/12/2012	9/15/2012	3	PM - Air Handling Unit, HV Type
FO-227241	Routine	Scheduled Maint. (PM)	10/5/2012	10/8/2012	3	PM - Fan Coil/HV/AC Unit
FO-227242	Routine	Scheduled Maint. (PM)	10/5/2012	10/8/2012	3	PM - Fan Coil/HV/AC Unit
FO-227333	Routine	Scheduled Maint. (PM)	10/9/2012	10/12/2012	3	PM - Air Handling Unit, over 50 Ton
FO-227346	Routine	Scheduled Maint. (PM)	10/25/2012	10/28/2012	3	Monthly Fire System Test
FO-229391	Routine	Scheduled Maint. (PM)	10/17/2012	10/20/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230334	Routine	Scheduled Maint. (PM)	10/31/2012	11/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-230453	Low	Scheduled Maint. (PM)	11/27/2012	11/30/2012	3	PM - Air Handling Unit, over 50 Ton
FO-230454	Low	Scheduled Maint. (PM)	11/27/2012	11/30/2012	3	PM - Air Handling Unit, over 50 Ton
FO-230471	Routine	Scheduled Maint. (PM)	10/31/2012	11/3/2012	3	PM - Air Handling Unit, over 50 Ton
FO-232252	Routine	Scheduled Maint. (PM)	11/1/2012	11/4/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232797	Routine	Scheduled Maint. (PM)	11/20/2012	11/23/2012	3	PM - Air Handling Unit, HV Type
FO-232798	Routine	Scheduled Maint. (PM)	11/20/2012	11/23/2012	3	PM - Air Handling Unit, HV Type
FO-232820	Routine	Scheduled Maint. (PM)	11/27/2012	11/30/2012	3	PM - Air Handling Unit, over 50 Ton
FO-232839	Routine	Scheduled Maint. (PM)	11/20/2012	11/23/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232840	Routine	Scheduled Maint. (PM)	11/20/2012	11/23/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233520	Routine	Scheduled Maint. (PM)	12/6/2012	12/9/2012	3	PM - Air Handling Unit, over 50 Ton
FO-233521	Routine	Scheduled Maint. (PM)	12/6/2012	12/9/2012	3	PM - Air Handling Unit, over 50 Ton
FO-234278	Routine	Scheduled Maint. (PM)	12/13/2012	12/16/2012	3	PM - Air Handling Unit, over 50 Ton
FO-234279	Routine	Scheduled Maint. (PM)	12/13/2012	12/16/2012	3	PM - Air Handling Unit, over 50 Ton
FO-234307	Routine	Scheduled Maint. (PM)	12/4/2012	12/7/2012	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234970	Routine	Scheduled Maint. (PM)	12/19/2012	12/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-235002	Routine	Scheduled Maint. (PM)	12/12/2012	12/15/2012	3	Replace filters
FO-235004	Routine	Scheduled Maint. (PM)	12/12/2012	12/15/2012	3	Replace filters
FO-236632	Routine	Scheduled Maint. (PM)	1/8/2013	1/11/2013	3	PM - Air Handling Unit, over 50 Ton
FO-236637	Routine	Scheduled Maint. (PM)	1/8/2013	1/11/2013	3	PM - Air Handling Unit, over 50 Ton
FO-236941	Routine	Scheduled Maint. (PM)	1/24/2013	1/27/2013	3	PM - Air Handling Unit
FO-236984	Routine	Scheduled Maint. (PM)	1/17/2013	1/20/2013	3	PM - Air Handling Unit
FO-236985	Routine	Scheduled Maint. (PM)	1/17/2013	1/20/2013	3	PM - Air Handling Unit
FO-236991	Routine	Scheduled Maint. (PM)	1/17/2013	1/20/2013	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236992	Routine	Scheduled Maint. (PM)	1/17/2013	1/20/2013	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236993	Routine	Scheduled Maint. (PM)	1/17/2013	1/20/2013	3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237050	Routine	Scheduled Maint. (PM)	1/12/2013	1/15/2013	3	Karmanos - North Tower Filter Replacement Safety Procedures
FO-237051	Routine	Scheduled Maint. (PM)	1/12/2013	1/15/2013	3	PM - Air Handling Unit
FO-237052	Routine	Scheduled Maint. (PM)	1/12/2013	1/15/2013	3	PM - Air Handling Unit
FO-237053	Routine	Scheduled Maint. (PM)	1/12/2013	1/15/2013	3	PM - Air Handling Unit
FO-205282	Routine	Scheduled Maint. (PM)	2/4/2012	2/6/2012	2	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-206635	Routine	Scheduled Maint. (PM)	2/28/2012	3/1/2012	2	PM - Air Handling Unit, over 50 Ton
FO-206634	Routine	Scheduled Maint. (PM)	2/28/2012	3/1/2012	2	PM - Air Handling Unit, over 50 Ton
FO-208145	Routine	Scheduled Maint. (PM)	3/15/2012	3/17/2012	2	PM - Air Handling Unit, over 50 Ton
FO-208147	Routine	Scheduled Maint. (PM)	3/17/2012	3/19/2012	2	PM - Air Handling Unit, over 50 Ton
FO-210590	Routine	Scheduled Maint. (PM)	3/21/2012	3/23/2012	2	PM - Fan Coil/HV/AC Unit
FO-213446	Routine	Scheduled Maint. (PM)	4/16/2012	4/18/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213448	Routine	Scheduled Maint. (PM)	4/18/2012	4/20/2012	2	PM - Air Handling Unit, over 50 Ton
FO-213489	Routine	Scheduled Maint. (PM)	4/7/2012	4/9/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213490	Routine	Scheduled Maint. (PM)	4/7/2012	4/9/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214159	Routine	Scheduled Maint. (PM)	4/24/2012	4/26/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217851	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217852	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217853	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217854	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217855	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217856	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217862	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217863	Routine	Scheduled Maint. (PM)	6/12/2012	6/14/2012	2	PM - Air Handling Unit, HV Type
FO-217870	Routine	Scheduled Maint. (PM)	6/7/2012	6/9/2012	2	PM - Air Handling Unit, HV Type
FO-218718	Routine	Scheduled Maint. (PM)	6/16/2012	6/18/2012	2	PM - Air Handling Unit, over 50 Ton
FO-218723	Routine	Scheduled Maint. (PM)	6/13/2012	6/15/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218728	Routine	Scheduled Maint. (PM)	6/13/2012	6/15/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218729	Routine	Scheduled Maint. (PM)	6/13/2012	6/15/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219505	Routine	Scheduled Maint. (PM)	6/27/2012	6/29/2012	2	Replace filters
FO-219506	Routine	Scheduled Maint. (PM)	6/27/2012	6/29/2012	2	Replace filters
FO-219507	Routine	Scheduled Maint. (PM)	6/27/2012	6/29/2012	2	Replace filters
FO-219508	Routine	Scheduled Maint. (PM)	6/27/2012	6/29/2012	2	Replace filters
FO-219509	Routine	Scheduled Maint. (PM)	6/27/2012	6/29/2012	2	Replace filters
FO-219510	Routine	Scheduled Maint. (PM)	6/28/2012	6/30/2012	2	PM - Air Handling Unit, over 50 Ton
FO-219520	Routine	Scheduled Maint. (PM)	6/26/2012	6/28/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220969	Routine	Scheduled Maint. (PM)	7/2/2012	7/4/2012	2	PM - Unit/Space Heater
FO-220989	Routine	Scheduled Maint. (PM)	7/17/2012	7/19/2012	2	PM - Fan Coil/HV/AC Unit
FO-220990	Routine	Scheduled Maint. (PM)	7/17/2012	7/19/2012	2	PM - Fan Coil/HV/AC Unit
FO-220996	Routine	Scheduled Maint. (PM)	7/13/2012	7/15/2012	2	Replace filters
FO-220998	Routine	Scheduled Maint. (PM)	7/13/2012	7/15/2012	2	Replace filters
FO-221011	Routine	Scheduled Maint. (PM)	7/13/2012	7/15/2012	2	-> Consolidated PM items:
FO-224629	Routine	Scheduled Maint. (PM)	8/11/2012	8/13/2012	2	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-224652	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224654	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224655	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224657	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224658	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224659	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224660	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit

			Finish Date	Due Date	Total per Trade	
FO-224661	Routine	Scheduled Maint. (PM)	8/4/2012	8/6/2012	2	PM - Fan Coil/HV/AC Unit
FO-224779	Routine	Scheduled Maint. (PM)	8/18/2012	8/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224780	Routine	Scheduled Maint. (PM)	8/18/2012	8/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224781	Routine	Scheduled Maint. (PM)	8/18/2012	8/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224782	Routine	Scheduled Maint. (PM)	8/18/2012	8/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224783	Routine	Scheduled Maint. (PM)	8/18/2012	8/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224680	Routine	Scheduled Maint. (PM)	8/20/2012	8/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-224682	Routine	Scheduled Maint. (PM)	8/20/2012	8/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-224685	Routine	Scheduled Maint. (PM)	8/20/2012	8/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-224900	Routine	Scheduled Maint. (PM)	8/22/2012	8/24/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224909	Routine	Scheduled Maint. (PM)	8/21/2012	8/23/2012	2	PM - Air Handling Unit, HV Type
FO-224918	Routine	Scheduled Maint. (PM)	9/6/2012	9/8/2012	2	PM - Air Handling Unit, over 50 Ton
FO-225020	Routine	Scheduled Maint. (PM)	9/1/2012	9/3/2012	2	PM - Fan Coil/HV/AC Unit
FO-225021	Routine	Scheduled Maint. (PM)	9/1/2012	9/3/2012	2	PM - Fan Coil/HV/AC Unit
FO-225022	Routine	Scheduled Maint. (PM)	9/1/2012	9/3/2012	2	PM - Fan Coil/HV/AC Unit
FO-225572	Routine	Scheduled Maint. (PM)	9/8/2012	9/10/2012	2	PM - Fan Coil/HV/AC Unit
FO-225573	Routine	Scheduled Maint. (PM)	9/8/2012	9/10/2012	2	PM - Fan Coil/HV/AC Unit
FO-225574	Routine	Scheduled Maint. (PM)	9/8/2012	9/10/2012	2	PM - Fan Coil/HV/AC Unit
FO-225575	Routine	Scheduled Maint. (PM)	9/8/2012	9/10/2012	2	PM - Fan Coil/HV/AC Unit
FO-225576	Routine	Scheduled Maint. (PM)	9/8/2012	9/10/2012	2	PM - Fan Coil/HV/AC Unit
FO-226099	Low	Scheduled Maint. (PM)	9/13/2012	9/15/2012	2	PM - Unit/Space Heater
FO-226101	Low	Scheduled Maint. (PM)	9/13/2012	9/15/2012	2	PM - Unit/Space Heater
FO-226103	Low	Scheduled Maint. (PM)	9/13/2012	9/15/2012	2	PM - Unit/Space Heater
FO-226104	Low	Scheduled Maint. (PM)	9/13/2012	9/15/2012	2	PM - Unit/Space Heater
FO-226105	Low	Scheduled Maint. (PM)	9/13/2012	9/15/2012	2	PM - Unit/Space Heater
FO-226141	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226142	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226143	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226145	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226146	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226147	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226148	Routine	Scheduled Maint. (PM)	9/15/2012	9/17/2012	2	PM - Fan Coil/HV/AC Unit
FO-226183	Routine	Scheduled Maint. (PM)	9/12/2012	9/14/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226184	Routine	Scheduled Maint. (PM)	9/12/2012	9/14/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226189	Routine	Scheduled Maint. (PM)	9/20/2012	9/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-226814	Routine	Scheduled Maint. (PM)	9/25/2012	9/27/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227187	Routine	Scheduled Maint. (PM)	9/26/2012	9/28/2012	2	PM - Unit/Space Heater
FO-227188	Routine	Scheduled Maint. (PM)	9/26/2012	9/28/2012	2	PM - Unit/Space Heater
FO-227207	Routine	Scheduled Maint. (PM)	9/26/2012	9/28/2012	2	PM - Fan Coil/HV/AC Unit
FO-227209	Routine	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Fan Coil/HV/AC Unit
FO-227210	Routine	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Fan Coil/HV/AC Unit
FO-227249	Routine	Scheduled Maint. (PM)	10/19/2012	10/21/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227250	Routine	Scheduled Maint. (PM)	10/19/2012	10/21/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227263	Routine	Scheduled Maint. (PM)	10/9/2012	10/11/2012	2	PM - Air Handling Unit, over 50 Ton

Finish Date Due Date**Total per Trade**

FO-227264	Routine	Scheduled Maint. (PM)	10/9/2012	10/11/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227414	Low	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227415	Low	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Air Handling Unit, over 50 Ton
FO-229392	Routine	Scheduled Maint. (PM)	10/18/2012	10/20/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229450	Routine	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229452	Routine	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229473	Routine	Scheduled Maint. (PM)	10/25/2012	10/27/2012	2	PM - Air Handling Unit, over 50 Ton
FO-229474	Routine	Scheduled Maint. (PM)	10/25/2012	10/27/2012	2	PM - Air Handling Unit, over 50 Ton
FO-230441	Routine	Scheduled Maint. (PM)	10/27/2012	10/29/2012	2	PM - Unit/Space Heater
FO-230442	Routine	Scheduled Maint. (PM)	10/27/2012	10/29/2012	2	PM - Unit/Space Heater
FO-230443	Routine	Scheduled Maint. (PM)	10/27/2012	10/29/2012	2	PM - Unit/Space Heater
FO-230452	Low	Scheduled Maint. (PM)	11/28/2012	11/30/2012	2	PM - Air Handling Unit, over 50 Ton
FO-230478	Routine	Scheduled Maint. (PM)	10/31/2012	11/2/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230727	Routine	Scheduled Maint. (PM)	11/10/2012	11/12/2012	2	PM - Fan Coil/HV/AC Unit
FO-230819	Routine	Scheduled Maint. (PM)	11/17/2012	11/19/2012	2	PM AHU - Belts & Lubrication
FO-232261	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232262	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232263	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232264	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232273	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232274	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232275	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232276	Routine	Scheduled Maint. (PM)	11/20/2012	11/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232795	Routine	Scheduled Maint. (PM)	11/21/2012	11/23/2012	2	PM - Air Handling Unit, HV Type
FO-232799	Routine	Scheduled Maint. (PM)	11/21/2012	11/23/2012	2	PM - Air Handling Unit, HV Type
FO-232806	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232807	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232808	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232809	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232810	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232811	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232812	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232813	Routine	Scheduled Maint. (PM)	12/5/2012	12/7/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232821	Routine	Scheduled Maint. (PM)	11/28/2012	11/30/2012	2	PM - Air Handling Unit, over 50 Ton
FO-234280	Routine	Scheduled Maint. (PM)	12/14/2012	12/16/2012	2	PM - Air Handling Unit, over 50 Ton
FO-234335	Routine	Scheduled Maint. (PM)	12/4/2012	12/6/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234973	Routine	Scheduled Maint. (PM)	12/21/2012	12/23/2012	2	PM - Air Handling Unit, over 50 Ton
FO-235007	Routine	Scheduled Maint. (PM)	12/11/2012	12/13/2012	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236633	Routine	Scheduled Maint. (PM)	1/9/2013	1/11/2013	2	PM - Air Handling Unit, over 50 Ton
FO-236986	Routine	Scheduled Maint. (PM)	1/18/2013	1/20/2013	2	PM - Air Handling Unit
FO-236995	Routine	Scheduled Maint. (PM)	1/18/2013	1/20/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237007	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237008	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237009	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-237010	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237011	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237012	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237019	Routine	Scheduled Maint. (PM)	1/23/2013	1/25/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237021	Routine	Scheduled Maint. (PM)	1/23/2013	1/25/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-205285	Routine	Scheduled Maint. (PM)	2/16/2012	2/17/2012	1	PM - Air Handling Unit, over 50 Ton
FO-211956	Routine	Scheduled Maint. (PM)	4/3/2012	4/4/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211957	Routine	Scheduled Maint. (PM)	4/3/2012	4/4/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213449	Routine	Scheduled Maint. (PM)	4/19/2012	4/20/2012	1	PM - Air Handling Unit, over 50 Ton
FO-213453	Routine	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213454	Routine	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213836	Routine	Scheduled Maint. (PM)	5/9/2012	5/10/2012	1	PM - Fire Pump, Main/Jockey
FO-213837	Routine	Scheduled Maint. (PM)	5/9/2012	5/10/2012	1	PM - Fire Pump, Main/Jockey
FO-214156	Routine	Scheduled Maint. (PM)	5/10/2012	5/11/2012	1	PM - Fire Pump, Main/Jockey
FO-214157	Routine	Scheduled Maint. (PM)	5/10/2012	5/11/2012	1	PM - Fire Pump, Main/Jockey
FO-214848	Routine	Scheduled Maint. (PM)	5/2/2012	5/3/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214849	Routine	Scheduled Maint. (PM)	5/2/2012	5/3/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214861	Routine	Scheduled Maint. (PM)	5/1/2012	5/2/2012	1	PM - Fan Coil/HV/AC Unit
FO-214862	Routine	Scheduled Maint. (PM)	5/1/2012	5/2/2012	1	PM - Fan Coil/HV/AC Unit
FO-215904	Routine	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215905	Routine	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215906	Routine	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216661	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216663	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216664	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216666	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216668	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216669	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216670	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216671	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216672	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216673	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216684	Routine	Scheduled Maint. (PM)	5/30/2012	5/31/2012	1	PM - Air Handling Unit, HV Type
FO-216696	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216697	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216698	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216699	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216700	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216701	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216702	Routine	Scheduled Maint. (PM)	5/21/2012	5/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217831	Routine	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-217832	Routine	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-217833	Routine	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-217834	Routine	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type

			Finish Date	Due Date	Total per Trade	
FO-217835	Routine	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-217885	Routine	Scheduled Maint. (PM)	6/6/2012	6/7/2012	1	PM - Air Handling Unit, over 50 Ton
FO-217886	Routine	Scheduled Maint. (PM)	6/6/2012	6/7/2012	1	PM - Air Handling Unit, over 50 Ton
FO-218732	Routine	Scheduled Maint. (PM)	6/16/2012	6/17/2012	1	PM - Air Handling Unit, over 50 Ton
FO-218733	Routine	Scheduled Maint. (PM)	6/16/2012	6/17/2012	1	PM - Air Handling Unit, over 50 Ton
FO-218789	Routine	Scheduled Maint. (PM)	6/9/2012	6/10/2012	1	PM - Air Handling Unit, HV Type
FO-218790	Routine	Scheduled Maint. (PM)	6/9/2012	6/10/2012	1	PM - Air Handling Unit, HV Type
FO-218791	Routine	Scheduled Maint. (PM)	6/9/2012	6/10/2012	1	PM - Air Handling Unit, HV Type
FO-218793	Routine	Scheduled Maint. (PM)	6/16/2012	6/17/2012	1	PM - Air Handling Unit, over 50 Ton
FO-219519	Routine	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219576	Routine	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219577	Routine	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219578	Routine	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220953	Routine	Scheduled Maint. (PM)	7/10/2012	7/11/2012	1	PM - Air Handling Unit, over 50 Ton
FO-220954	Routine	Scheduled Maint. (PM)	7/10/2012	7/11/2012	1	PM - Air Handling Unit, over 50 Ton
FO-221007	Routine	Scheduled Maint. (PM)	7/14/2012	7/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-221008	Routine	Scheduled Maint. (PM)	7/14/2012	7/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224888	Routine	Scheduled Maint. (PM)	8/15/2012	8/16/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214844	Low	Scheduled Maint. (PM)	5/2/2012	5/3/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214845	Low	Scheduled Maint. (PM)	5/2/2012	5/3/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216648	Low	Scheduled Maint. (PM)	6/2/2012	6/3/2012	1	PM - Air Handling Unit, HV Type
FO-217838	Low	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-217839	Low	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	PM - Air Handling Unit, HV Type
FO-218755	Low	Scheduled Maint. (PM)	6/30/2012	7/1/2012	1	PM - Fire Alarm System Test
FO-219482	Low	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219483	Low	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219487	Low	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219488	Low	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224668	Routine	Scheduled Maint. (PM)	8/21/2012	8/22/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224669	Routine	Scheduled Maint. (PM)	8/21/2012	8/22/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224686	Routine	Scheduled Maint. (PM)	8/21/2012	8/22/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224878	Routine	Scheduled Maint. (PM)	8/29/2012	8/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224879	Routine	Scheduled Maint. (PM)	8/29/2012	8/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224880	Routine	Scheduled Maint. (PM)	8/29/2012	8/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-224912	Routine	Scheduled Maint. (PM)	8/22/2012	8/23/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224931	Routine	Scheduled Maint. (PM)	8/22/2012	8/23/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225538	Routine	Scheduled Maint. (PM)	9/14/2012	9/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-225546	Routine	Scheduled Maint. (PM)	9/14/2012	9/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-225547	Routine	Scheduled Maint. (PM)	9/14/2012	9/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-226112	Routine	Scheduled Maint. (PM)	9/14/2012	9/15/2012	1	PM - Unit/Space Heater
FO-226759	Routine	Scheduled Maint. (PM)	9/28/2012	9/29/2012	1	PM - Air Handling Unit, over 50 Ton
FO-226815	Routine	Scheduled Maint. (PM)	9/26/2012	9/27/2012	1	PM - Air Handling Unit, over 50 Ton
FO-227208	Routine	Scheduled Maint. (PM)	9/27/2012	9/28/2012	1	PM - Fan Coil/HV/AC Unit
FO-227220	Routine	Scheduled Maint. (PM)	9/27/2012	9/28/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-227221	Routine	Scheduled Maint. (PM)	9/27/2012	9/28/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227222	Routine	Scheduled Maint. (PM)	9/27/2012	9/28/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227251	Routine	Scheduled Maint. (PM)	10/20/2012	10/21/2012	1	PM - Air Handling Unit, over 50 Ton
FO-227252	Routine	Scheduled Maint. (PM)	10/20/2012	10/21/2012	1	PM - Air Handling Unit, over 50 Ton
FO-227260	Routine	Scheduled Maint. (PM)	10/11/2012	10/12/2012	1	PM - Air Handling Unit, over 50 Ton
FO-227265	Routine	Scheduled Maint. (PM)	10/10/2012	10/11/2012	1	PM - Air Handling Unit, over 50 Ton
FO-227275	Routine	Scheduled Maint. (PM)	10/4/2012	10/5/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227276	Routine	Scheduled Maint. (PM)	10/4/2012	10/5/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227332	Low	Scheduled Maint. (PM)	10/10/2012	10/11/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227403	Routine	Scheduled Maint. (PM)	9/12/2012	9/13/2012	1	HEPA Filter Replacement at Applebaum Pharmacy Building
FO-227416	Low	Scheduled Maint. (PM)	10/17/2012	10/18/2012	1	PM - Air Handling Unit, over 50 Ton
FO-229451	Routine	Scheduled Maint. (PM)	10/17/2012	10/18/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229455	Routine	Scheduled Maint. (PM)	10/24/2012	10/25/2012	1	PM - Air Handling Unit, over 50 Ton
FO-229475	Routine	Scheduled Maint. (PM)	10/26/2012	10/27/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230297	Routine	Scheduled Maint. (PM)	10/31/2012	11/1/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230298	Routine	Scheduled Maint. (PM)	10/31/2012	11/1/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230299	Routine	Scheduled Maint. (PM)	10/31/2012	11/1/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230302	Routine	Scheduled Maint. (PM)	10/30/2012	10/31/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230338	Routine	Scheduled Maint. (PM)	11/1/2012	11/2/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230451	Low	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230683	Routine	Scheduled Maint. (PM)	11/14/2012	11/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230684	Routine	Scheduled Maint. (PM)	11/14/2012	11/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-230755	Low	Scheduled Maint. (PM)	11/6/2012	11/7/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230814	Low	Scheduled Maint. (PM)	11/14/2012	11/15/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232253	Low	Scheduled Maint. (PM)	11/30/2012	12/1/2012	1	PM - Fire Alarm System Test
FO-232265	Routine	Scheduled Maint. (PM)	11/21/2012	11/22/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232272	Routine	Scheduled Maint. (PM)	11/21/2012	11/22/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232277	Routine	Scheduled Maint. (PM)	11/21/2012	11/22/2012	1	PM - Air Handling Unit, HV Type
FO-232789	Routine	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232790	Routine	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232822	Routine	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Air Handling Unit, over 50 Ton
FO-233557	Routine	Scheduled Maint. (PM)	11/14/2012	11/15/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234281	Routine	Scheduled Maint. (PM)	12/15/2012	12/16/2012	1	PM - Air Handling Unit, over 50 Ton
FO-234282	Routine	Scheduled Maint. (PM)	12/15/2012	12/16/2012	1	PM - Air Handling Unit, over 50 Ton
FO-235005	Routine	Scheduled Maint. (PM)	11/30/2012	12/1/2012	1	Replace belts
FO-236989	Routine	Scheduled Maint. (PM)	1/19/2013	1/20/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236990	Routine	Scheduled Maint. (PM)	1/19/2013	1/20/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237015	Routine	Scheduled Maint. (PM)	1/24/2013	1/25/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203306	Routine	Scheduled Maint. (PM)	1/18/2012	1/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203802	Routine	Scheduled Maint. (PM)	2/10/2012	2/10/2012	0	PM - Fire Pump, Main/Jockey
FO-203803	Routine	Scheduled Maint. (PM)	2/10/2012	2/10/2012	0	PM - Fire Pump, Main/Jockey
FO-206019	Routine	Scheduled Maint. (PM)	2/22/2012	2/22/2012	0	PM - Air Handling Unit, HV Type
FO-207139	Routine	Scheduled Maint. (PM)	2/28/2012	2/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-207140	Routine	Scheduled Maint. (PM)	2/28/2012	2/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date**Total per Trade**

FO-206629	Routine	Scheduled Maint. (PM)	3/3/2012	3/3/2012	0	PM - Air Handling Unit, over 50 Ton
FO-208142	Routine	Scheduled Maint. (PM)	3/17/2012	3/17/2012	0	PM - Air Handling Unit, over 50 Ton
FO-210540	Routine	Scheduled Maint. (PM)	3/29/2012	3/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-211257	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211258	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211259	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211260	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211263	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211264	Routine	Scheduled Maint. (PM)	3/28/2012	3/28/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211977	Routine	Scheduled Maint. (PM)	4/4/2012	4/4/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211978	Routine	Scheduled Maint. (PM)	4/4/2012	4/4/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211979	Routine	Scheduled Maint. (PM)	4/4/2012	4/4/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211980	Routine	Scheduled Maint. (PM)	4/4/2012	4/4/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213450	Routine	Scheduled Maint. (PM)	4/20/2012	4/20/2012	0	PM - Air Handling Unit, over 50 Ton
FO-213480	Routine	Scheduled Maint. (PM)	4/20/2012	4/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213481	Routine	Scheduled Maint. (PM)	4/20/2012	4/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-213482	Routine	Scheduled Maint. (PM)	5/3/2012	5/3/2012	0	PM - Fire Pump, Main/Jockey
FO-213830	Routine	Scheduled Maint. (PM)	5/10/2012	5/10/2012	0	PM - Fire Pump, Main/Jockey
FO-213831	Routine	Scheduled Maint. (PM)	5/10/2012	5/10/2012	0	PM - Fire Pump, Main/Jockey
FO-213832	Routine	Scheduled Maint. (PM)	5/1/2012	5/1/2012	0	PM - Air Handling Unit, over 50 Ton
FO-214161	Routine	Scheduled Maint. (PM)	5/2/2012	5/2/2012	0	PM - Air Handling Unit, over 50 Ton
FO-214162	Routine	Scheduled Maint. (PM)	5/2/2012	5/2/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215444	Routine	Scheduled Maint. (PM)	5/9/2012	5/9/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215445	Routine	Scheduled Maint. (PM)	5/16/2012	5/16/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215446	Routine	Scheduled Maint. (PM)	5/16/2012	5/16/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215457	Routine	Scheduled Maint. (PM)	5/9/2012	5/9/2012	0	PM - Fan Coil/HV/AC Unit
FO-215458	Routine	Scheduled Maint. (PM)	5/9/2012	5/9/2012	0	PM - Fan Coil/HV/AC Unit
FO-215948	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, HV Type
FO-215949	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215950	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215951	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215952	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215953	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215954	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215955	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215956	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215957	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215958	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215959	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215960	Routine	Scheduled Maint. (PM)	5/22/2012	5/22/2012	0	PM - Air Handling Unit, over 50 Ton
FO-216632	Routine	Scheduled Maint. (PM)	6/6/2012	6/6/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216633	Routine	Scheduled Maint. (PM)	6/6/2012	6/6/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216634	Routine	Scheduled Maint. (PM)	6/6/2012	6/6/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216675	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type

Finish Date Due Date**Total per Trade**

FO-216676	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216679	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216680	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216681	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216682	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216683	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216685	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216686	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216688	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216689	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-216703	Routine	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	PM - Air Handling Unit, HV Type
FO-216704	Routine	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	PM - Air Handling Unit, HV Type
FO-217805	Routine	Scheduled Maint. (PM)	6/8/2012	6/8/2012	0	PM - Air Handling Unit, over 50 Ton
FO-217806	Routine	Scheduled Maint. (PM)	6/8/2012	6/8/2012	0	PM - Air Handling Unit, over 50 Ton
FO-217809	Routine	Scheduled Maint. (PM)	6/15/2012	6/15/2012	0	PM - Air Handling Unit, over 50 Ton
FO-217812	Routine	Scheduled Maint. (PM)	6/15/2012	6/15/2012	0	PM - Air Handling Unit, over 50 Ton
FO-217817	Routine	Scheduled Maint. (PM)	6/6/2012	6/6/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217822	Routine	Scheduled Maint. (PM)	6/13/2012	6/13/2012	0	PM - Fire Pump, Main/Jockey
FO-217823	Routine	Scheduled Maint. (PM)	6/13/2012	6/13/2012	0	PM - Fire Pump, Main/Jockey
FO-217840	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217841	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217842	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217843	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217844	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217845	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217846	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217847	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217848	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217849	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217850	Routine	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217892	Routine	Scheduled Maint. (PM)	6/6/2012	6/6/2012	0	PM - Air Handling Unit, over 50 Ton
FO-218720	Routine	Scheduled Maint. (PM)	6/23/2012	6/23/2012	0	PM - Air Handling Unit, over 50 Ton
FO-218764	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218765	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218766	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218767	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218768	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218769	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218770	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-218771	Routine	Scheduled Maint. (PM)	6/11/2012	6/11/2012	0	PM - Fan Coil/HV/AC Unit
FO-219472	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219473	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219474	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219475	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date

Total per Trade

FO-219476	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219485	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219486	Routine	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219502	Routine	Scheduled Maint. (PM)	6/29/2012	6/29/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219503	Routine	Scheduled Maint. (PM)	6/29/2012	6/29/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219504	Routine	Scheduled Maint. (PM)	6/29/2012	6/29/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219512	Routine	Scheduled Maint. (PM)	7/4/2012	7/4/2012	0	PM - Air Handling Unit, over 50 Ton
FO-219518	Routine	Scheduled Maint. (PM)	6/27/2012	6/27/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219524	Routine	Scheduled Maint. (PM)	6/25/2012	6/25/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219555	Routine	Scheduled Maint. (PM)	7/4/2012	7/4/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220948	Routine	Scheduled Maint. (PM)	7/12/2012	7/12/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220950	Routine	Scheduled Maint. (PM)	7/12/2012	7/12/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220956	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220957	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220958	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220959	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220960	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220961	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220962	Routine	Scheduled Maint. (PM)	7/11/2012	7/11/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221234	Routine	Scheduled Maint. (PM)	7/17/2012	7/17/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221239	Routine	Scheduled Maint. (PM)	7/24/2012	7/24/2012	0	PM - Air Handling Unit, over 50 Ton
FO-221244	Routine	Scheduled Maint. (PM)	7/20/2012	7/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221264	Routine	Scheduled Maint. (PM)	7/20/2012	7/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221265	Routine	Scheduled Maint. (PM)	7/20/2012	7/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221267	Routine	Scheduled Maint. (PM)	7/20/2012	7/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221911	Routine	Scheduled Maint. (PM)	8/2/2012	8/2/2012	0	PM - Air Handling Unit, over 50 Ton
FO-221948	Routine	Scheduled Maint. (PM)	7/31/2012	7/31/2012	0	PM - Air Handling Unit, over 50 Ton
FO-222478	Routine	Scheduled Maint. (PM)	7/31/2012	7/31/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222479	Routine	Scheduled Maint. (PM)	7/31/2012	7/31/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224653	Routine	Scheduled Maint. (PM)	8/8/2012	8/8/2012	0	PM - Unit/Space Heater
FO-224656	Routine	Scheduled Maint. (PM)	8/8/2012	8/8/2012	0	PM - Unit/Space Heater
FO-224890	Routine	Scheduled Maint. (PM)	8/16/2012	8/16/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224891	Routine	Scheduled Maint. (PM)	8/16/2012	8/16/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214842	Low	Scheduled Maint. (PM)	5/3/2012	5/3/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214843	Low	Scheduled Maint. (PM)	5/3/2012	5/3/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214851	Low	Scheduled Maint. (PM)	5/1/2012	5/1/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214852	Low	Scheduled Maint. (PM)	5/1/2012	5/1/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215447	Low	Scheduled Maint. (PM)	5/16/2012	5/16/2012	0	PM - Air Handling Unit, over 50 Ton
FO-216690	Low	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Air Handling Unit, HV Type
FO-217864	Low	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-217865	Low	Scheduled Maint. (PM)	6/14/2012	6/14/2012	0	PM - Air Handling Unit, HV Type
FO-218742	Low	Scheduled Maint. (PM)	6/27/2012	6/27/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219477	Low	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219478	Low	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date			Total per Trade
FO-219566	Low	Scheduled Maint. (PM)	6/20/2012	6/20/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-220981	Low	Scheduled Maint. (PM)	7/31/2012	7/31/2012	0	PM - Fire Alarm System Test	
FO-224684	Routine	Scheduled Maint. (PM)	8/22/2012	8/22/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224687	Routine	Scheduled Maint. (PM)	8/22/2012	8/22/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224719	Routine	Scheduled Maint. (PM)	8/22/2012	8/22/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224720	Routine	Scheduled Maint. (PM)	8/22/2012	8/22/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224875	Routine	Scheduled Maint. (PM)	8/30/2012	8/30/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224876	Routine	Scheduled Maint. (PM)	8/30/2012	8/30/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224877	Routine	Scheduled Maint. (PM)	8/30/2012	8/30/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-224932	Routine	Scheduled Maint. (PM)	8/23/2012	8/23/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224985	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224986	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224997	Routine	Scheduled Maint. (PM)	9/13/2012	9/13/2012	0	PM - Fire Pump, Main/Jockey	
FO-224998	Routine	Scheduled Maint. (PM)	9/13/2012	9/13/2012	0	PM - Fire Pump, Main/Jockey	
FO-224999	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225000	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225001	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225038	Routine	Scheduled Maint. (PM)	8/28/2012	8/28/2012	0	PM - Fan Coil/HV/AC Unit	
FO-225058	Routine	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-225073	Low	Scheduled Maint. (PM)	8/27/2012	8/27/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-225544	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-225548	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-226084	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Unit/Space Heater	
FO-226085	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Unit/Space Heater	
FO-226086	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Unit/Space Heater	
FO-226087	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Unit/Space Heater	
FO-226803	Routine	Scheduled Maint. (PM)	9/21/2012	9/21/2012	0	PM - Fan Coil/HV/AC Unit	
FO-226804	Routine	Scheduled Maint. (PM)	9/21/2012	9/21/2012	0	PM - Fan Coil/HV/AC Unit	
FO-226805	Routine	Scheduled Maint. (PM)	9/21/2012	9/21/2012	0	PM - Fan Coil/HV/AC Unit	
FO-227261	Routine	Scheduled Maint. (PM)	10/12/2012	10/12/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-227298	Low	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-227301	Low	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-229449	Routine	Scheduled Maint. (PM)	10/18/2012	10/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-229484	Routine	Scheduled Maint. (PM)	10/22/2012	10/22/2012	0	PM - Fan Coil/HV/AC Unit	
FO-230335	Routine	Scheduled Maint. (PM)	11/3/2012	11/3/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-230336	Routine	Scheduled Maint. (PM)	11/3/2012	11/3/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-230357	Routine	Scheduled Maint. (PM)	10/11/2012	10/11/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-230383	Low	Scheduled Maint. (PM)	10/31/2012	10/31/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230384	Low	Scheduled Maint. (PM)	10/31/2012	10/31/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230466	Routine	Scheduled Maint. (PM)	10/29/2012	10/29/2012	0	PM - Unit/Space Heater	
FO-230467	Routine	Scheduled Maint. (PM)	10/29/2012	10/29/2012	0	PM - Unit/Space Heater	
FO-230588	Routine	Scheduled Maint. (PM)	11/14/2012	11/14/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-230685	Routine	Scheduled Maint. (PM)	11/15/2012	11/15/2012	0	PM - Air Handling Unit, over 50 Ton	
FO-230686	Routine	Scheduled Maint. (PM)	11/15/2012	11/15/2012	0	PM - Air Handling Unit, over 50 Ton	

Finish Date Due Date**Total per Trade**

FO-230752	Low	Scheduled Maint. (PM)	11/7/2012	11/7/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230756	Low	Scheduled Maint. (PM)	11/7/2012	11/7/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233526	Routine	Scheduled Maint. (PM)	11/16/2012	11/16/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234277	Routine	Scheduled Maint. (PM)	12/5/2012	12/5/2012	0	PM - Unit/Space Heater
FO-234308	Routine	Scheduled Maint. (PM)	12/7/2012	12/7/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-234310	Routine	Scheduled Maint. (PM)	12/7/2012	12/7/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235008	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	PM - Air Handling Unit, over 50 Ton
FO-235009	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	PM - Air Handling Unit, over 50 Ton
FO-236635	Routine	Scheduled Maint. (PM)	1/11/2013	1/11/2013	0	PM - Air Handling Unit, over 50 Ton
FO-236636	Routine	Scheduled Maint. (PM)	1/11/2013	1/11/2013	0	PM - Air Handling Unit, over 50 Ton
FO-236928	Routine	Scheduled Maint. (PM)	1/17/2013	1/17/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236929	Routine	Scheduled Maint. (PM)	1/17/2013	1/17/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236930	Routine	Scheduled Maint. (PM)	1/17/2013	1/17/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236931	Routine	Scheduled Maint. (PM)	1/17/2013	1/17/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236946	Routine	Scheduled Maint. (PM)	1/24/2013	1/24/2013	0	PM - Air Handling Unit
FO-236947	Routine	Scheduled Maint. (PM)	1/24/2013	1/24/2013	0	PM - Air Handling Unit
FO-237016	Routine	Scheduled Maint. (PM)	1/25/2013	1/25/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237033	Routine	Scheduled Maint. (PM)	1/15/2013	1/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237054	Routine	Scheduled Maint. (PM)	1/15/2013	1/15/2013	0	PM - Air Handling Unit
FO-237055	Routine	Scheduled Maint. (PM)	1/15/2013	1/15/2013	0	PM - Air Handling Unit
FO-203075	Routine	Scheduled Maint. (PM)	1/11/2012	1/10/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-201870	Routine	Scheduled Maint. (PM)	1/14/2012	1/13/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-203305	Routine	Scheduled Maint. (PM)	1/18/2012	1/17/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-203304	Routine	Scheduled Maint. (PM)	1/18/2012	1/17/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-203384	Routine	Scheduled Maint. (PM)	2/3/2012	2/2/2012	-1	PM - Fire Pump, Main/Jockey
FO-203829	Routine	Scheduled Maint. (PM)	2/10/2012	2/9/2012	-1	PM - Fire Pump, Main/Jockey
FO-203828	Routine	Scheduled Maint. (PM)	2/10/2012	2/9/2012	-1	PM - Fire Pump, Main/Jockey
FO-207145	Routine	Scheduled Maint. (PM)	3/1/2012	2/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-207146	Routine	Scheduled Maint. (PM)	3/1/2012	2/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206631	Routine	Scheduled Maint. (PM)	3/2/2012	3/1/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-206623	Routine	Scheduled Maint. (PM)	3/2/2012	3/1/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-206624	Routine	Scheduled Maint. (PM)	3/2/2012	3/1/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-206625	Routine	Scheduled Maint. (PM)	3/2/2012	3/1/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-208159	Routine	Scheduled Maint. (PM)	3/7/2012	3/6/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-207148	Routine	Scheduled Maint. (PM)	3/10/2012	3/9/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-206641	Routine	Scheduled Maint. (PM)	3/10/2012	3/9/2012	-1	PM - Fire Pump, Main/Jockey
FO-206640	Routine	Scheduled Maint. (PM)	3/10/2012	3/9/2012	-1	PM - Fire Pump, Main/Jockey
FO-208138	Routine	Scheduled Maint. (PM)	3/13/2012	3/12/2012	-1	PM - Air Handling Unit, HV Type
FO-208139	Routine	Scheduled Maint. (PM)	3/13/2012	3/12/2012	-1	PM - Air Handling Unit, HV Type
FO-208140	Routine	Scheduled Maint. (PM)	3/13/2012	3/12/2012	-1	PM - Air Handling Unit, HV Type
FO-208172	Routine	Scheduled Maint. (PM)	3/14/2012	3/13/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208166	Routine	Scheduled Maint. (PM)	3/21/2012	3/20/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-210534	Routine	Scheduled Maint. (PM)	3/22/2012	3/21/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-210535	Routine	Scheduled Maint. (PM)	3/22/2012	3/21/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date

Total per Trade

FO-209970	Routine	Scheduled Maint. (PM)	3/23/2012	3/22/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-208137	Routine	Scheduled Maint. (PM)	3/30/2012	3/29/2012	-1	Monthly Fire System Test
FO-209984	Routine	Scheduled Maint. (PM)	4/3/2012	4/2/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-210196	Routine	Scheduled Maint. (PM)	3/28/2012	3/27/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-211254	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	-> Consolidated PM items:Annual task: W847301 - PM - Fan, Centrifugal: Supply/Return/Exhaust FanAnnual task:
FO-211255	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211256	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211266	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211969	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	PM - Unit/Space Heater
FO-211970	Routine	Scheduled Maint. (PM)	3/29/2012	3/28/2012	-1	PM - Unit/Space Heater
FO-211971	Routine	Scheduled Maint. (PM)	4/5/2012	4/4/2012	-1	PM - Unit/Space Heater
FO-211972	Routine	Scheduled Maint. (PM)	4/5/2012	4/4/2012	-1	PM - Unit/Space Heater
FO-213447	Routine	Scheduled Maint. (PM)	4/28/2012	4/27/2012	-1	Monthly Fire System Test
FO-213451	Routine	Scheduled Maint. (PM)	4/21/2012	4/20/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-213457	Routine	Scheduled Maint. (PM)	4/11/2012	4/10/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-213458	Routine	Scheduled Maint. (PM)	4/11/2012	4/10/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-213459	Routine	Scheduled Maint. (PM)	4/11/2012	4/10/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-213491	Routine	Scheduled Maint. (PM)	4/12/2012	4/11/2012	-1	PM - Unit/Space Heater
FO-213492	Routine	Scheduled Maint. (PM)	4/12/2012	4/11/2012	-1	PM - Unit/Space Heater
FO-214153	Routine	Scheduled Maint. (PM)	5/5/2012	5/4/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-214163	Routine	Scheduled Maint. (PM)	5/3/2012	5/2/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-214840	Routine	Scheduled Maint. (PM)	5/4/2012	5/3/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215895	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215896	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215897	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215898	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215899	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215900	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215901	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215902	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215903	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215922	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-215923	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-215924	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-215925	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-215931	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, HV Type
FO-215932	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Unit/Space Heater
FO-215933	Routine	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	PM - Unit/Space Heater
FO-215947	Routine	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Air Handling Unit, HV Type
FO-216628	Routine	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216629	Routine	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216630	Routine	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216631	Routine	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216636	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton

Finish Date Due Date**Total per Trade**

FO-216637	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216638	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216646	Routine	Scheduled Maint. (PM)	5/24/2012	5/23/2012	-1	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-216654	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216655	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216656	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216658	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216659	Routine	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-216678	Routine	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Air Handling Unit, HV Type
FO-216687	Routine	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Air Handling Unit, HV Type
FO-217876	Routine	Scheduled Maint. (PM)	6/5/2012	6/4/2012	-1	PM - Fan Coil/HV/AC Unit
FO-217877	Routine	Scheduled Maint. (PM)	6/5/2012	6/4/2012	-1	PM - Fan Coil/HV/AC Unit
FO-217878	Routine	Scheduled Maint. (PM)	6/5/2012	6/4/2012	-1	PM - Fan Coil/HV/AC Unit
FO-218734	Routine	Scheduled Maint. (PM)	6/26/2012	6/25/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-218735	Routine	Scheduled Maint. (PM)	6/26/2012	6/25/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-218736	Routine	Scheduled Maint. (PM)	6/26/2012	6/25/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-218758	Routine	Scheduled Maint. (PM)	6/12/2012	6/11/2012	-1	PM - Fan Coil/HV/AC Unit
FO-218759	Routine	Scheduled Maint. (PM)	6/12/2012	6/11/2012	-1	PM - Fan Coil/HV/AC Unit
FO-218760	Routine	Scheduled Maint. (PM)	6/12/2012	6/11/2012	-1	PM - Fan Coil/HV/AC Unit
FO-219501	Routine	Scheduled Maint. (PM)	7/4/2012	7/3/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-219528	Routine	Scheduled Maint. (PM)	6/22/2012	6/21/2012	-1	PM - Unit/Space Heater
FO-219529	Routine	Scheduled Maint. (PM)	6/22/2012	6/21/2012	-1	PM - Unit/Space Heater
FO-219530	Routine	Scheduled Maint. (PM)	6/22/2012	6/21/2012	-1	PM - Unit/Space Heater
FO-219550	Routine	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219551	Routine	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219552	Routine	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219553	Routine	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219554	Routine	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219562	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219563	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219564	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219565	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219567	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219568	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219569	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219570	Routine	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220949	Routine	Scheduled Maint. (PM)	7/13/2012	7/12/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-220963	Routine	Scheduled Maint. (PM)	7/12/2012	7/11/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220964	Routine	Scheduled Maint. (PM)	7/12/2012	7/11/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220965	Routine	Scheduled Maint. (PM)	7/12/2012	7/11/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221226	Routine	Scheduled Maint. (PM)	7/18/2012	7/17/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221253	Routine	Scheduled Maint. (PM)	7/28/2012	7/27/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-221266	Routine	Scheduled Maint. (PM)	7/21/2012	7/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221268	Routine	Scheduled Maint. (PM)	7/21/2012	7/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date**Total per Trade**

FO-221269	Routine	Scheduled Maint. (PM)	7/21/2012	7/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221302	Routine	Scheduled Maint. (PM)	7/21/2012	7/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221303	Routine	Scheduled Maint. (PM)	7/21/2012	7/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224671	Routine	Scheduled Maint. (PM)	8/9/2012	8/8/2012	-1	PM - Fan Coil/HV/AC Unit
FO-224672	Routine	Scheduled Maint. (PM)	8/9/2012	8/8/2012	-1	PM - Fan Coil/HV/AC Unit
FO-224889	Routine	Scheduled Maint. (PM)	8/15/2012	8/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208152	Low	Scheduled Maint. (PM)	3/6/2012	3/5/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208153	Low	Scheduled Maint. (PM)	3/6/2012	3/5/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208154	Low	Scheduled Maint. (PM)	3/13/2012	3/12/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211961	Low	Scheduled Maint. (PM)	4/4/2012	4/3/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211962	Low	Scheduled Maint. (PM)	4/4/2012	4/3/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214841	Low	Scheduled Maint. (PM)	5/4/2012	5/3/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214853	Low	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-215912	Low	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Fire Alarm System Test
FO-215915	Low	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Fire Alarm System Test
FO-215916	Low	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215917	Low	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215918	Low	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215919	Low	Scheduled Maint. (PM)	5/31/2012	5/30/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215920	Low	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Fire Alarm System Test
FO-215930	Low	Scheduled Maint. (PM)	6/1/2012	5/31/2012	-1	PM - Fire Alarm System Test
FO-215934	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215936	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215937	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215938	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215939	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215940	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215941	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215942	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215943	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215944	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215945	Low	Scheduled Maint. (PM)	5/15/2012	5/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216618	Low	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan Motor Box (Old Main)
FO-216619	Low	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan Motor Box (Old Main)
FO-216620	Low	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan Motor Box (Old Main)
FO-216624	Low	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan Motor Box (Old Main)
FO-216627	Low	Scheduled Maint. (PM)	6/7/2012	6/6/2012	-1	PM - Fan Motor Box (Old Main)
FO-216649	Low	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216650	Low	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216651	Low	Scheduled Maint. (PM)	5/23/2012	5/22/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217827	Low	Scheduled Maint. (PM)	5/30/2012	5/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217836	Low	Scheduled Maint. (PM)	6/8/2012	6/7/2012	-1	PM - Air Handling Unit, HV Type
FO-217837	Low	Scheduled Maint. (PM)	6/8/2012	6/7/2012	-1	PM - Air Handling Unit, HV Type
FO-218743	Low	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date

Total per Trade

FO-218744	Low	Scheduled Maint. (PM)	6/28/2012	6/27/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218749	Low	Scheduled Maint. (PM)	6/20/2012	6/19/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218750	Low	Scheduled Maint. (PM)	6/20/2012	6/19/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218751	Low	Scheduled Maint. (PM)	6/20/2012	6/19/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219480	Low	Scheduled Maint. (PM)	6/21/2012	6/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219556	Low	Scheduled Maint. (PM)	6/27/2012	6/26/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219557	Low	Scheduled Maint. (PM)	6/27/2012	6/26/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219558	Low	Scheduled Maint. (PM)	6/27/2012	6/26/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220973	Low	Scheduled Maint. (PM)	7/4/2012	7/3/2012	-1	PM - Unit/Space Heater
FO-220974	Low	Scheduled Maint. (PM)	7/4/2012	7/3/2012	-1	PM - Unit/Space Heater
FO-224756	Low	Scheduled Maint. (PM)	9/1/2012	8/31/2012	-1	PM - Fire Alarm System Test
FO-224884	High	Scheduled Maint. (PM)	8/17/2012	8/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224885	High	Scheduled Maint. (PM)	8/17/2012	8/16/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224896	Routine	Scheduled Maint. (PM)	8/22/2012	8/21/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224897	Routine	Scheduled Maint. (PM)	8/22/2012	8/21/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224933	Routine	Scheduled Maint. (PM)	8/24/2012	8/23/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224967	Routine	Scheduled Maint. (PM)	8/29/2012	8/28/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224984	Routine	Scheduled Maint. (PM)	8/30/2012	8/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224987	Routine	Scheduled Maint. (PM)	8/30/2012	8/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225031	Routine	Scheduled Maint. (PM)	8/28/2012	8/27/2012	-1	PM - Fan Coil/HV/AC Unit
FO-225032	Routine	Scheduled Maint. (PM)	8/28/2012	8/27/2012	-1	PM - Fan Coil/HV/AC Unit
FO-225033	Routine	Scheduled Maint. (PM)	8/28/2012	8/27/2012	-1	PM - Fan Coil/HV/AC Unit
FO-225034	Routine	Scheduled Maint. (PM)	8/28/2012	8/27/2012	-1	PM - Fan Coil/HV/AC Unit
FO-225035	Routine	Scheduled Maint. (PM)	8/28/2012	8/27/2012	-1	PM - Fan Coil/HV/AC Unit
FO-225053	Routine	Scheduled Maint. (PM)	8/30/2012	8/29/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225066	Low	Scheduled Maint. (PM)	8/21/2012	8/20/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226095	Routine	Scheduled Maint. (PM)	10/4/2012	10/3/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226131	Routine	Scheduled Maint. (PM)	9/15/2012	9/14/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226825	Low	Scheduled Maint. (PM)	9/25/2012	9/24/2012	-1	PM - Fan Coil/HV/AC Unit
FO-226830	Low	Scheduled Maint. (PM)	9/25/2012	9/24/2012	-1	PM - Fan Coil/HV/AC Unit
FO-227262	Routine	Scheduled Maint. (PM)	10/13/2012	10/12/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-227273	Routine	Scheduled Maint. (PM)	10/13/2012	10/12/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-227274	Routine	Scheduled Maint. (PM)	10/13/2012	10/12/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-227299	Low	Scheduled Maint. (PM)	9/27/2012	9/26/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-227300	Low	Scheduled Maint. (PM)	9/27/2012	9/26/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-229489	Low	Scheduled Maint. (PM)	10/18/2012	10/17/2012	-1	PM - Unit/Space Heater
FO-230313	Routine	Scheduled Maint. (PM)	10/30/2012	10/29/2012	-1	PM - Unit/Space Heater
FO-230330	Routine	Scheduled Maint. (PM)	10/26/2012	10/25/2012	-1	PM - Fan Coil/HV/AC Unit
FO-230331	Routine	Scheduled Maint. (PM)	10/26/2012	10/25/2012	-1	PM - Fan Coil/HV/AC Unit
FO-230337	Routine	Scheduled Maint. (PM)	11/2/2012	11/1/2012	-1	PM - Air Handling Unit, over 50 Ton
FO-230431	Routine	Scheduled Maint. (PM)	10/30/2012	10/29/2012	-1	PM - Unit/Space Heater
FO-230436	Routine	Scheduled Maint. (PM)	10/30/2012	10/29/2012	-1	PM - Unit/Space Heater
FO-230438	Routine	Scheduled Maint. (PM)	10/30/2012	10/29/2012	-1	PM - Unit/Space Heater
FO-230445	Low	Scheduled Maint. (PM)	10/30/2012	10/29/2012	-1	PM - Unit/Space Heater

			Finish Date	Due Date			Total per Trade
FO-232791	Routine	Scheduled Maint. (PM)	12/1/2012	11/30/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-232794	Routine	Scheduled Maint. (PM)	12/1/2012	11/30/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-233527	Routine	Scheduled Maint. (PM)	11/16/2012	11/15/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-233623	Low	Scheduled Maint. (PM)	11/28/2012	11/27/2012	-1	PM - Unit/Space Heater	
FO-234289	Routine	Scheduled Maint. (PM)	12/14/2012	12/13/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-234309	Routine	Scheduled Maint. (PM)	12/8/2012	12/7/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-234311	Routine	Scheduled Maint. (PM)	12/8/2012	12/7/2012	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-234992	Routine	Scheduled Maint. (PM)	12/12/2012	12/11/2012	-1	PM - Air Handling Unit, HV Type	
FO-234993	Routine	Scheduled Maint. (PM)	12/12/2012	12/11/2012	-1	PM - Air Handling Unit, HV Type	
FO-234994	Routine	Scheduled Maint. (PM)	12/12/2012	12/11/2012	-1	PM - Air Handling Unit, HV Type	
FO-235041	Routine	Scheduled Maint. (PM)	12/19/2012	12/18/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-235043	Routine	Scheduled Maint. (PM)	12/20/2012	12/19/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-235044	Routine	Scheduled Maint. (PM)	12/20/2012	12/19/2012	-1	PM - Air Handling Unit, over 50 Ton	
FO-235358	Routine	Scheduled Maint. (PM)	12/8/2012	12/7/2012	-1	HEPA Filter Replacement at Applebaum Pharmacy Building	
FO-235359	Routine	Scheduled Maint. (PM)	12/8/2012	12/7/2012	-1	Animal Lab Filter Changes for Applebaum	
FO-236634	Routine	Scheduled Maint. (PM)	1/12/2013	1/11/2013	-1	PM - Air Handling Unit, over 50 Ton	
FO-237018	Routine	Scheduled Maint. (PM)	1/26/2013	1/25/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-237020	Routine	Scheduled Maint. (PM)	1/26/2013	1/25/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-210197	Routine	Scheduled Maint. (PM)	3/27/2012	3/25/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-210198	Routine	Scheduled Maint. (PM)	3/27/2012	3/25/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-210199	Routine	Scheduled Maint. (PM)	3/27/2012	3/25/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-210195	Routine	Scheduled Maint. (PM)	3/29/2012	3/27/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-215907	Routine	Scheduled Maint. (PM)	5/18/2012	5/16/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215909	Routine	Scheduled Maint. (PM)	5/18/2012	5/16/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-216635	Routine	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-216660	Routine	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, HV Type	
FO-216662	Routine	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, HV Type	
FO-216665	Routine	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, HV Type	
FO-216667	Routine	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, HV Type	
FO-216677	Routine	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, HV Type	
FO-216705	Routine	Scheduled Maint. (PM)	5/25/2012	5/23/2012	-2	PM - Air Handling Unit, HV Type	
FO-216706	Routine	Scheduled Maint. (PM)	5/25/2012	5/23/2012	-2	PM - Air Handling Unit, HV Type	
FO-218719	Routine	Scheduled Maint. (PM)	6/20/2012	6/18/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-218726	Routine	Scheduled Maint. (PM)	6/20/2012	6/18/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-218727	Routine	Scheduled Maint. (PM)	6/20/2012	6/18/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219484	Routine	Scheduled Maint. (PM)	6/22/2012	6/20/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219498	Routine	Scheduled Maint. (PM)	6/30/2012	6/28/2012	-2	PM - Fan Coil/HV/AC Unit	
FO-219499	Routine	Scheduled Maint. (PM)	6/30/2012	6/28/2012	-2	PM - Fan Coil/HV/AC Unit	
FO-219500	Routine	Scheduled Maint. (PM)	6/30/2012	6/28/2012	-2	PM - Fan Coil/HV/AC Unit	
FO-219511	Routine	Scheduled Maint. (PM)	7/6/2012	7/4/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-219525	Routine	Scheduled Maint. (PM)	6/25/2012	6/23/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-220991	Routine	Scheduled Maint. (PM)	7/14/2012	7/12/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-220992	Routine	Scheduled Maint. (PM)	7/14/2012	7/12/2012	-2	PM - Air Handling Unit, over 50 Ton	
FO-220993	Routine	Scheduled Maint. (PM)	7/14/2012	7/12/2012	-2	PM - Air Handling Unit, over 50 Ton	

			Finish Date	Due Date	Total per Trade	
FO-221251	Routine	Scheduled Maint. (PM)	7/21/2012	7/19/2012	-2	PM - Unit/Space Heater
FO-221917	Routine	Scheduled Maint. (PM)	7/26/2012	7/24/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221964	Routine	Scheduled Maint. (PM)	7/27/2012	7/25/2012	-2	PM - Fan Coil/HV/AC Unit
FO-222235	Routine	Scheduled Maint. (PM)	8/16/2012	8/14/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224651	Routine	Scheduled Maint. (PM)	8/17/2012	8/15/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214854	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214855	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214856	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214857	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214858	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214859	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-214860	Low	Scheduled Maint. (PM)	6/2/2012	5/31/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-216621	Low	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan Motor Box (Old Main)
FO-216622	Low	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan Motor Box (Old Main)
FO-216623	Low	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan Motor Box (Old Main)
FO-216625	Low	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan Motor Box (Old Main)
FO-216626	Low	Scheduled Maint. (PM)	6/8/2012	6/6/2012	-2	PM - Fan Motor Box (Old Main)
FO-217820	Low	Scheduled Maint. (PM)	5/30/2012	5/28/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217821	Low	Scheduled Maint. (PM)	5/30/2012	5/28/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218740	Low	Scheduled Maint. (PM)	6/29/2012	6/27/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218745	Low	Scheduled Maint. (PM)	6/29/2012	6/27/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218746	Low	Scheduled Maint. (PM)	6/29/2012	6/27/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218747	Low	Scheduled Maint. (PM)	6/29/2012	6/27/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219481	Low	Scheduled Maint. (PM)	6/22/2012	6/20/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224676	Routine	Scheduled Maint. (PM)	8/24/2012	8/22/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224677	Routine	Scheduled Maint. (PM)	8/24/2012	8/22/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224678	Routine	Scheduled Maint. (PM)	8/24/2012	8/22/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224681	Routine	Scheduled Maint. (PM)	8/24/2012	8/22/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224714	Routine	Scheduled Maint. (PM)	8/24/2012	8/22/2012	-2	PM - Air Handling Unit, HV Type
FO-224958	Routine	Scheduled Maint. (PM)	9/1/2012	8/30/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224960	Routine	Scheduled Maint. (PM)	9/1/2012	8/30/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-224969	Routine	Scheduled Maint. (PM)	8/30/2012	8/28/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225003	Routine	Scheduled Maint. (PM)	8/25/2012	8/23/2012	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225026	Routine	Scheduled Maint. (PM)	8/29/2012	8/27/2012	-2	PM - Fan Coil/HV/AC Unit
FO-225027	Routine	Scheduled Maint. (PM)	8/29/2012	8/27/2012	-2	PM - Fan Coil/HV/AC Unit
FO-225028	Routine	Scheduled Maint. (PM)	8/29/2012	8/27/2012	-2	PM - Fan Coil/HV/AC Unit
FO-225029	Routine	Scheduled Maint. (PM)	8/29/2012	8/27/2012	-2	PM - Fan Coil/HV/AC Unit
FO-225030	Routine	Scheduled Maint. (PM)	8/29/2012	8/27/2012	-2	PM - Fan Coil/HV/AC Unit
FO-225549	Routine	Scheduled Maint. (PM)	9/12/2012	9/10/2012	-2	PM - Air Handling Unit, HV Type
FO-225550	Routine	Scheduled Maint. (PM)	9/12/2012	9/10/2012	-2	PM - Air Handling Unit, HV Type
FO-230728	Routine	Scheduled Maint. (PM)	11/14/2012	11/12/2012	-2	PM - Fan Coil/HV/AC Unit
FO-230757	Low	Scheduled Maint. (PM)	11/22/2012	11/20/2012	-2	PM - Air Handling Unit, HV Type
FO-232823	Routine	Scheduled Maint. (PM)	12/4/2012	12/2/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-232824	Routine	Scheduled Maint. (PM)	12/4/2012	12/2/2012	-2	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-233522	Routine	Scheduled Maint. (PM)	12/11/2012	12/9/2012	-2	PM - Air Handling Unit, over 50 Ton
FO-233573	Routine	Scheduled Maint. (PM)	11/30/2012	11/28/2012	-2	PM - Fan Coil/HV/AC Unit
FO-233574	Routine	Scheduled Maint. (PM)	11/30/2012	11/28/2012	-2	PM - Fan Coil/HV/AC Unit
FO-233575	Routine	Scheduled Maint. (PM)	11/30/2012	11/28/2012	-2	PM - Fan Coil/HV/AC Unit
FO-237024	Routine	Scheduled Maint. (PM)	1/29/2013	1/27/2013	-2	PM - Air Handling Unit
FO-237025	Routine	Scheduled Maint. (PM)	1/29/2013	1/27/2013	-2	PM - Air Handling Unit
FO-237026	Routine	Scheduled Maint. (PM)	1/29/2013	1/27/2013	-2	PM - Air Handling Unit
FO-237027	Routine	Scheduled Maint. (PM)	1/29/2013	1/27/2013	-2	PM - Air Handling Unit
FO-203344	Routine	Scheduled Maint. (PM)	1/18/2012	1/15/2012	-3	Replace filters
FO-203346	Routine	Scheduled Maint. (PM)	1/18/2012	1/15/2012	-3	Replace filters
FO-203807	Routine	Scheduled Maint. (PM)	1/28/2012	1/25/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219492	Routine	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219493	Routine	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219494	Routine	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219546	Routine	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-219547	Routine	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-221246	Routine	Scheduled Maint. (PM)	7/21/2012	7/18/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221915	Routine	Scheduled Maint. (PM)	7/28/2012	7/25/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-221918	Routine	Scheduled Maint. (PM)	7/27/2012	7/24/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221972	Routine	Scheduled Maint. (PM)	7/28/2012	7/25/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-222236	Routine	Scheduled Maint. (PM)	8/17/2012	8/14/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224624	Routine	Scheduled Maint. (PM)	8/18/2012	8/15/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-224625	Routine	Scheduled Maint. (PM)	8/18/2012	8/15/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-224628	Routine	Scheduled Maint. (PM)	8/11/2012	8/8/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224635	Routine	Scheduled Maint. (PM)	8/9/2012	8/6/2012	-3	PM - Fan Coil/HV/AC Unit
FO-224636	Routine	Scheduled Maint. (PM)	8/9/2012	8/6/2012	-3	PM - Fan Coil/HV/AC Unit
FO-224643	Routine	Scheduled Maint. (PM)	8/9/2012	8/6/2012	-3	PM - Fan Coil/HV/AC Unit
FO-224644	Routine	Scheduled Maint. (PM)	8/9/2012	8/6/2012	-3	PM - Fan Coil/HV/AC Unit
FO-224645	Routine	Scheduled Maint. (PM)	8/9/2012	8/6/2012	-3	PM - Fan Coil/HV/AC Unit
FO-224692	Routine	Scheduled Maint. (PM)	8/18/2012	8/15/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-224693	Routine	Scheduled Maint. (PM)	8/18/2012	8/15/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-206015	Low	Scheduled Maint. (PM)	2/23/2012	2/20/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-217819	Low	Scheduled Maint. (PM)	5/31/2012	5/28/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218739	Low	Scheduled Maint. (PM)	6/30/2012	6/27/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219479	Low	Scheduled Maint. (PM)	6/23/2012	6/20/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222037	Low	Scheduled Maint. (PM)	8/11/2012	8/8/2012	-3	Replace filters
FO-222038	Low	Scheduled Maint. (PM)	8/11/2012	8/8/2012	-3	Replace filters
FO-222039	Low	Scheduled Maint. (PM)	8/11/2012	8/8/2012	-3	Replace filters
FO-224924	Routine	Scheduled Maint. (PM)	9/11/2012	9/8/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-224968	Routine	Scheduled Maint. (PM)	8/24/2012	8/21/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224976	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224977	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224978	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224988	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater

Finish Date Due Date**Total per Trade**

FO-224989	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224990	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224991	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-224992	Routine	Scheduled Maint. (PM)	9/1/2012	8/29/2012	-3	PM - Unit/Space Heater
FO-225096	Low	Scheduled Maint. (PM)	9/13/2012	9/10/2012	-3	PM - Air Handling Unit, HV Type
FO-229476	Routine	Scheduled Maint. (PM)	10/30/2012	10/27/2012	-3	PM - Air Handling Unit, over 50 Ton
FO-235406	Routine	Scheduled Maint. (PM)	12/22/2012	12/19/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235407	Routine	Scheduled Maint. (PM)	12/22/2012	12/19/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235408	Routine	Scheduled Maint. (PM)	12/22/2012	12/19/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203857	Routine	Scheduled Maint. (PM)	1/31/2012	1/27/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-205284	Routine	Scheduled Maint. (PM)	2/14/2012	2/10/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-206018	Routine	Scheduled Maint. (PM)	2/18/2012	2/14/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-214160	Routine	Scheduled Maint. (PM)	4/30/2012	4/26/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219527	Routine	Scheduled Maint. (PM)	6/25/2012	6/21/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221223	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221224	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221247	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-221248	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-221249	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-221250	Routine	Scheduled Maint. (PM)	7/21/2012	7/17/2012	-4	PM - Air Handling Unit, over 50 Ton
FO-221270	Routine	Scheduled Maint. (PM)	7/24/2012	7/20/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221273	Routine	Scheduled Maint. (PM)	7/24/2012	7/20/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221278	Routine	Scheduled Maint. (PM)	7/24/2012	7/20/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224892	Routine	Scheduled Maint. (PM)	8/13/2012	8/9/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206016	Low	Scheduled Maint. (PM)	2/24/2012	2/20/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224966	Routine	Scheduled Maint. (PM)	8/25/2012	8/21/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224975	Routine	Scheduled Maint. (PM)	8/25/2012	8/21/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225002	Routine	Scheduled Maint. (PM)	8/25/2012	8/21/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225562	Routine	Scheduled Maint. (PM)	9/8/2012	9/4/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225583	Routine	Scheduled Maint. (PM)	9/8/2012	9/4/2012	-4	PM - Fan Coil/HV/AC Unit
FO-225584	Routine	Scheduled Maint. (PM)	9/8/2012	9/4/2012	-4	PM - Fan Coil/HV/AC Unit
FO-225585	Routine	Scheduled Maint. (PM)	9/8/2012	9/4/2012	-4	PM - Fan Coil/HV/AC Unit
FO-230291	Routine	Scheduled Maint. (PM)	10/30/2012	10/26/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230761	Routine	Scheduled Maint. (PM)	11/10/2012	11/6/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230762	Routine	Scheduled Maint. (PM)	11/10/2012	11/6/2012	-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-237030	Routine	Scheduled Maint. (PM)	1/15/2013	1/11/2013	-4	PM - Air Handling Unit
FO-203856	Routine	Scheduled Maint. (PM)	2/1/2012	1/27/2012	-5	PM - Air Handling Unit, over 50 Ton
FO-218756	Routine	Scheduled Maint. (PM)	6/27/2012	6/22/2012	-5	PM - Air Handling Unit, over 50 Ton
FO-218757	Routine	Scheduled Maint. (PM)	6/27/2012	6/22/2012	-5	PM - Air Handling Unit, over 50 Ton
FO-219526	Routine	Scheduled Maint. (PM)	6/25/2012	6/20/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220985	Routine	Scheduled Maint. (PM)	7/10/2012	7/5/2012	-5	PM - Fan Coil/HV/AC Unit
FO-220986	Routine	Scheduled Maint. (PM)	7/10/2012	7/5/2012	-5	PM - Fan Coil/HV/AC Unit
FO-221272	Routine	Scheduled Maint. (PM)	7/25/2012	7/20/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224630	Routine	Scheduled Maint. (PM)	8/18/2012	8/13/2012	-5	PM - Air Handling Unit, over 50 Ton (Filters Excluded)

Finish Date Due Date

Total per Trade

FO-224893	Routine	Scheduled Maint. (PM)	8/14/2012	8/9/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224894	Routine	Scheduled Maint. (PM)	8/14/2012	8/9/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224895	Routine	Scheduled Maint. (PM)	8/14/2012	8/9/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-216647	Low	Scheduled Maint. (PM)	6/1/2012	5/27/2012	-5	PM - Air Handling Unit, HV Type
FO-216691	Low	Scheduled Maint. (PM)	6/5/2012	5/31/2012	-5	PM - Air Handling Unit, HV Type
FO-224925	Routine	Scheduled Maint. (PM)	9/13/2012	9/8/2012	-5	PM - Air Handling Unit, over 50 Ton
FO-225019	Routine	Scheduled Maint. (PM)	9/1/2012	8/27/2012	-5	PM - Fan Coil/HV/AC Unit
FO-226752	Routine	Scheduled Maint. (PM)	9/26/2012	9/21/2012	-5	PM - Unit/Space Heater
FO-226753	Routine	Scheduled Maint. (PM)	9/26/2012	9/21/2012	-5	PM - Unit/Space Heater
FO-226754	Routine	Scheduled Maint. (PM)	9/26/2012	9/21/2012	-5	PM - Unit/Space Heater
FO-227211	Routine	Scheduled Maint. (PM)	10/10/2012	10/5/2012	-5	PM - Fan Coil/HV/AC Unit
FO-230290	Routine	Scheduled Maint. (PM)	10/31/2012	10/26/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230292	Routine	Scheduled Maint. (PM)	10/31/2012	10/26/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230594	Routine	Scheduled Maint. (PM)	11/13/2012	11/8/2012	-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230599	Routine	Scheduled Maint. (PM)	11/30/2012	11/25/2012	-5	PM - Fire Pump, Main/Jockey
FO-230600	Routine	Scheduled Maint. (PM)	11/30/2012	11/25/2012	-5	PM - Fire Pump, Main/Jockey
FO-230641	Routine	Scheduled Maint. (PM)	11/14/2012	11/9/2012	-5	PM - Unit/Space Heater
FO-230642	Routine	Scheduled Maint. (PM)	11/14/2012	11/9/2012	-5	PM - Unit/Space Heater
FO-230815	Routine	Scheduled Maint. (PM)	11/30/2012	11/25/2012	-5	PM - Fire Pump, Main/Jockey
FO-230816	Routine	Scheduled Maint. (PM)	11/30/2012	11/25/2012	-5	PM - Fire Pump, Main/Jockey
FO-213467	Routine	Scheduled Maint. (PM)	5/1/2012	4/25/2012	-6	PM - Air Handling Unit, over 50 Ton
FO-215453	Routine	Scheduled Maint. (PM)	6/1/2012	5/26/2012	-6	PM - Fire Pump, Main/Jockey
FO-215454	Routine	Scheduled Maint. (PM)	6/1/2012	5/26/2012	-6	PM - Fire Pump, Main/Jockey
FO-215455	Routine	Scheduled Maint. (PM)	6/1/2012	5/26/2012	-6	PM - Fire Pump, Main/Jockey
FO-215456	Routine	Scheduled Maint. (PM)	6/1/2012	5/26/2012	-6	PM - Fire Pump, Main/Jockey
FO-220987	Routine	Scheduled Maint. (PM)	7/11/2012	7/5/2012	-6	PM - Fan Coil/HV/AC Unit
FO-221258	Routine	Scheduled Maint. (PM)	7/31/2012	7/25/2012	-6	PM - Fan Coil/HV/AC Unit
FO-221259	Routine	Scheduled Maint. (PM)	7/31/2012	7/25/2012	-6	PM - Fan Coil/HV/AC Unit
FO-221962	Routine	Scheduled Maint. (PM)	7/31/2012	7/25/2012	-6	PM - Fan Coil/HV/AC Unit
FO-221963	Routine	Scheduled Maint. (PM)	7/31/2012	7/25/2012	-6	PM - Fan Coil/HV/AC Unit
FO-224708	Routine	Scheduled Maint. (PM)	8/21/2012	8/15/2012	-6	PM - Air Handling Unit, over 50 Ton
FO-224709	Routine	Scheduled Maint. (PM)	8/21/2012	8/15/2012	-6	PM - Air Handling Unit, over 50 Ton
FO-224722	Routine	Scheduled Maint. (PM)	8/28/2012	8/22/2012	-6	PM - Air Handling Unit, HV Type
FO-224959	Routine	Scheduled Maint. (PM)	9/5/2012	8/30/2012	-6	PM - Air Handling Unit, over 50 Ton
FO-224981	Routine	Scheduled Maint. (PM)	8/29/2012	8/23/2012	-6	PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-230293	Routine	Scheduled Maint. (PM)	11/1/2012	10/26/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236944	Routine	Scheduled Maint. (PM)	1/23/2013	1/17/2013	-6	PM - Air Handling Unit
FO-236951	Routine	Scheduled Maint. (PM)	1/30/2013	1/24/2013	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236952	Routine	Scheduled Maint. (PM)	1/30/2013	1/24/2013	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221058	Routine	Scheduled Maint. (PM)	7/28/2012	7/21/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-221059	Routine	Scheduled Maint. (PM)	7/28/2012	7/21/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-221060	Routine	Scheduled Maint. (PM)	7/28/2012	7/21/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-221061	Routine	Scheduled Maint. (PM)	7/28/2012	7/21/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-221257	Routine	Scheduled Maint. (PM)	8/1/2012	7/25/2012	-7	PM - Fan Coil/HV/AC Unit

Finish Date Due Date**Total per Trade**

FO-221956	Routine	Scheduled Maint. (PM)	7/31/2012	7/24/2012	-7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221957	Routine	Scheduled Maint. (PM)	7/31/2012	7/24/2012	-7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224665	Routine	Scheduled Maint. (PM)	9/1/2012	8/25/2012	-7	PM - Fire Pump, Main/Jockey
FO-224666	Routine	Scheduled Maint. (PM)	9/1/2012	8/25/2012	-7	PM - Fire Pump, Main/Jockey
FO-224711	Routine	Scheduled Maint. (PM)	8/22/2012	8/15/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-224712	Routine	Scheduled Maint. (PM)	8/22/2012	8/15/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-224765	Routine	Scheduled Maint. (PM)	9/1/2012	8/25/2012	-7	PM - Fire Pump, Main/Jockey
FO-224766	Routine	Scheduled Maint. (PM)	9/1/2012	8/25/2012	-7	PM - Fire Pump, Main/Jockey
FO-224964	Routine	Scheduled Maint. (PM)	9/8/2012	9/1/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-224965	Routine	Scheduled Maint. (PM)	9/8/2012	9/1/2012	-7	PM - Air Handling Unit, over 50 Ton
FO-225071	Low	Scheduled Maint. (PM)	8/27/2012	8/20/2012	-7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236656	Routine	Scheduled Maint. (PM)	1/11/2013	1/4/2013	-7	PM - Fan Coil/HV/AC Unit
FO-236657	Routine	Scheduled Maint. (PM)	1/11/2013	1/4/2013	-7	PM - Fan Coil/HV/AC Unit
FO-236658	Routine	Scheduled Maint. (PM)	1/11/2013	1/4/2013	-7	PM - Fan Coil/HV/AC Unit
FO-236945	Routine	Scheduled Maint. (PM)	1/24/2013	1/17/2013	-7	PM - Air Handling Unit
FO-203821	Routine	Scheduled Maint. (PM)	2/1/2012	1/24/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-206017	Routine	Scheduled Maint. (PM)	2/22/2012	2/14/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218716	Routine	Scheduled Maint. (PM)	6/30/2012	6/22/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-221914	Routine	Scheduled Maint. (PM)	8/2/2012	7/25/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-221958	Routine	Scheduled Maint. (PM)	8/1/2012	7/24/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-221959	Routine	Scheduled Maint. (PM)	8/1/2012	7/24/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-221974	Routine	Scheduled Maint. (PM)	8/2/2012	7/25/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221975	Routine	Scheduled Maint. (PM)	8/2/2012	7/25/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221976	Routine	Scheduled Maint. (PM)	8/2/2012	7/25/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222233	Routine	Scheduled Maint. (PM)	8/15/2012	8/7/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224940	Routine	Scheduled Maint. (PM)	8/15/2012	8/7/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225010	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225011	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225012	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225013	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225014	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225015	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225016	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-225017	Routine	Scheduled Maint. (PM)	8/28/2012	8/20/2012	-8	PM - Fan Coil/HV/AC Unit
FO-226144	Routine	Scheduled Maint. (PM)	9/25/2012	9/17/2012	-8	PM - Fan Coil/HV/AC Unit
FO-236090	Routine	Scheduled Maint. (PM)	1/3/2013	12/26/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236091	Routine	Scheduled Maint. (PM)	1/3/2013	12/26/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236092	Routine	Scheduled Maint. (PM)	1/3/2013	12/26/2012	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203425	Routine	Scheduled Maint. (PM)	2/2/2012	1/24/2012	-9	PM - Air Handling Unit, over 50 Ton
FO-221225	Routine	Scheduled Maint. (PM)	7/26/2012	7/17/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221977	Routine	Scheduled Maint. (PM)	8/3/2012	7/25/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221978	Routine	Scheduled Maint. (PM)	8/3/2012	7/25/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221979	Routine	Scheduled Maint. (PM)	8/3/2012	7/25/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222234	Routine	Scheduled Maint. (PM)	8/16/2012	8/7/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Finish Date Due Date

Total per Trade

FO-224694	Routine	Scheduled Maint. (PM)	8/17/2012	8/8/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224695	Routine	Scheduled Maint. (PM)	8/17/2012	8/8/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224696	Routine	Scheduled Maint. (PM)	8/17/2012	8/8/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224700	Routine	Scheduled Maint. (PM)	8/17/2012	8/8/2012	-9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224592	Routine	Scheduled Maint. (PM)	8/23/2012	8/14/2012	-9	PM - Air Handling Unit, over 50 Ton
FO-224593	Routine	Scheduled Maint. (PM)	8/23/2012	8/14/2012	-9	PM - Air Handling Unit, over 50 Ton
FO-224713	Routine	Scheduled Maint. (PM)	8/24/2012	8/15/2012	-9	PM - Air Handling Unit, over 50 Ton
FO-226136	Routine	Scheduled Maint. (PM)	9/20/2012	9/11/2012	-9	PM - Fan Coil/HV/AC Unit
FO-221274	Routine	Scheduled Maint. (PM)	8/4/2012	7/25/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-221276	Routine	Scheduled Maint. (PM)	8/4/2012	7/25/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-222524	Routine	Scheduled Maint. (PM)	8/9/2012	7/30/2012	-10	PM - Fan Coil/HV/AC Unit
FO-224701	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224702	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224703	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224594	Routine	Scheduled Maint. (PM)	8/24/2012	8/14/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-224595	Routine	Scheduled Maint. (PM)	8/24/2012	8/14/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-224704	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224705	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224706	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224707	Routine	Scheduled Maint. (PM)	8/18/2012	8/8/2012	-10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225075	Low	Scheduled Maint. (PM)	9/19/2012	9/9/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-225095	Low	Scheduled Maint. (PM)	9/13/2012	9/3/2012	-10	PM - Air Handling Unit, HV Type
FO-236044	Routine	Scheduled Maint. (PM)	1/8/2013	12/29/2012	-10	Replace filters
FO-236045	Routine	Scheduled Maint. (PM)	1/8/2013	12/29/2012	-10	Replace filters
FO-218717	Routine	Scheduled Maint. (PM)	7/3/2012	6/22/2012	-11	PM - Air Handling Unit, over 50 Ton
FO-220945	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220977	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220978	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220979	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220980	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221069	Routine	Scheduled Maint. (PM)	7/26/2012	7/15/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224759	Routine	Scheduled Maint. (PM)	8/14/2012	8/3/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224939	Routine	Scheduled Maint. (PM)	8/15/2012	8/4/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224597	Routine	Scheduled Maint. (PM)	8/25/2012	8/14/2012	-11	PM - Air Handling Unit, over 50 Ton
FO-224598	Routine	Scheduled Maint. (PM)	8/25/2012	8/14/2012	-11	PM - Air Handling Unit, over 50 Ton
FO-225039	Routine	Scheduled Maint. (PM)	9/8/2012	8/28/2012	-11	PM - Fan Coil/HV/AC Unit
FO-225040	Routine	Scheduled Maint. (PM)	9/8/2012	8/28/2012	-11	PM - Fan Coil/HV/AC Unit
FO-226158	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226159	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226174	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226175	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226176	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226177	Routine	Scheduled Maint. (PM)	9/25/2012	9/14/2012	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-203855	Routine	Scheduled Maint. (PM)	2/8/2012	1/27/2012	-12	PM - Air Handling Unit, over 50 Ton

Finish Date Due Date

Total per Trade

FO-221913	Routine	Scheduled Maint. (PM)	8/6/2012	7/25/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-224758	Routine	Scheduled Maint. (PM)	8/14/2012	8/2/2012	-12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224962	Routine	Scheduled Maint. (PM)	9/21/2012	9/9/2012	-12	PM - Air Handling Unit, HV Type
FO-224963	Routine	Scheduled Maint. (PM)	9/21/2012	9/9/2012	-12	PM - Air Handling Unit, HV Type
FO-224996	Routine	Scheduled Maint. (PM)	9/1/2012	8/20/2012	-12	PM - Fan Coil/HV/AC Unit
FO-225018	Routine	Scheduled Maint. (PM)	9/1/2012	8/20/2012	-12	PM - Fan Coil/HV/AC Unit
FO-226155	Routine	Scheduled Maint. (PM)	9/26/2012	9/14/2012	-12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226156	Routine	Scheduled Maint. (PM)	9/26/2012	9/14/2012	-12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226157	Routine	Scheduled Maint. (PM)	9/26/2012	9/14/2012	-12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208156	Routine	Scheduled Maint. (PM)	4/6/2012	3/24/2012	-13	PM - Fire Pump, Main/Jockey
FO-221275	Routine	Scheduled Maint. (PM)	8/7/2012	7/25/2012	-13	PM - Air Handling Unit, over 50 Ton
FO-221910	Routine	Scheduled Maint. (PM)	8/15/2012	8/2/2012	-13	PM - Air Handling Unit, over 50 Ton
FO-222495	Routine	Scheduled Maint. (PM)	8/14/2012	8/1/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222496	Routine	Scheduled Maint. (PM)	8/14/2012	8/1/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222497	Routine	Scheduled Maint. (PM)	8/14/2012	8/1/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222498	Routine	Scheduled Maint. (PM)	8/14/2012	8/1/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224588	Routine	Scheduled Maint. (PM)	8/8/2012	7/26/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224589	Routine	Scheduled Maint. (PM)	8/8/2012	7/26/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224609	Routine	Scheduled Maint. (PM)	8/8/2012	7/26/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224612	Routine	Scheduled Maint. (PM)	8/8/2012	7/26/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-220982	Low	Scheduled Maint. (PM)	7/31/2012	7/18/2012	-13	PM - Air Handling Unit, over 50 Ton
FO-220983	Low	Scheduled Maint. (PM)	7/31/2012	7/18/2012	-13	PM - Air Handling Unit, over 50 Ton
FO-220984	Low	Scheduled Maint. (PM)	7/31/2012	7/18/2012	-13	PM - Air Handling Unit, over 50 Ton
FO-224599	Routine	Scheduled Maint. (PM)	8/28/2012	8/15/2012	-13	PM - Unit/Space Heater
FO-224604	Routine	Scheduled Maint. (PM)	8/28/2012	8/15/2012	-13	PM - Unit/Space Heater
FO-224605	Routine	Scheduled Maint. (PM)	8/28/2012	8/15/2012	-13	PM - Unit/Space Heater
FO-224606	Routine	Scheduled Maint. (PM)	8/28/2012	8/15/2012	-13	PM - Unit/Space Heater
FO-224607	Routine	Scheduled Maint. (PM)	8/28/2012	8/15/2012	-13	PM - Unit/Space Heater
FO-224710	Routine	Scheduled Maint. (PM)	8/21/2012	8/8/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225054	Routine	Scheduled Maint. (PM)	9/11/2012	8/29/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225055	Routine	Scheduled Maint. (PM)	9/11/2012	8/29/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225056	Routine	Scheduled Maint. (PM)	9/11/2012	8/29/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225057	Routine	Scheduled Maint. (PM)	9/11/2012	8/29/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236082	Routine	Scheduled Maint. (PM)	1/9/2013	12/27/2012	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236948	Routine	Scheduled Maint. (PM)	1/30/2013	1/17/2013	-13	PM - Air Handling Unit
FO-236949	Routine	Scheduled Maint. (PM)	1/30/2013	1/17/2013	-13	PM - Air Handling Unit
FO-221305	Routine	Scheduled Maint. (PM)	8/10/2012	7/27/2012	-14	PM - Air Handling Unit, over 50 Ton
FO-221306	Routine	Scheduled Maint. (PM)	8/10/2012	7/27/2012	-14	PM - Air Handling Unit, over 50 Ton
FO-221307	Routine	Scheduled Maint. (PM)	8/10/2012	7/27/2012	-14	PM - Air Handling Unit, over 50 Ton
FO-221308	Routine	Scheduled Maint. (PM)	8/10/2012	7/27/2012	-14	PM - Air Handling Unit, over 50 Ton
FO-224613	Routine	Scheduled Maint. (PM)	8/9/2012	7/26/2012	-14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211959	Low	Scheduled Maint. (PM)	4/10/2012	3/27/2012	-14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211960	Low	Scheduled Maint. (PM)	4/10/2012	3/27/2012	-14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221966	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-222231	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222232	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222499	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222500	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222501	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222502	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222503	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222504	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222521	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222522	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222523	Routine	Scheduled Maint. (PM)	8/16/2012	8/1/2012	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221240	Routine	Scheduled Maint. (PM)	7/20/2012	7/4/2012	-16	PM - Air Handling Unit, over 50 Ton
FO-221277	Routine	Scheduled Maint. (PM)	8/10/2012	7/25/2012	-16	PM - Air Handling Unit, over 50 Ton
FO-224610	Routine	Scheduled Maint. (PM)	8/11/2012	7/26/2012	-16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224611	Routine	Scheduled Maint. (PM)	8/11/2012	7/26/2012	-16	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235042	Routine	Scheduled Maint. (PM)	1/4/2013	12/19/2012	-16	PM - Air Handling Unit, over 50 Ton
FO-221971	Routine	Scheduled Maint. (PM)	7/28/2012	7/11/2012	-17	PM - Air Handling Unit, over 50 Ton
FO-224600	Routine	Scheduled Maint. (PM)	9/1/2012	8/15/2012	-17	PM - Unit/Space Heater
FO-224601	Routine	Scheduled Maint. (PM)	9/1/2012	8/15/2012	-17	PM - Unit/Space Heater
FO-224602	Routine	Scheduled Maint. (PM)	9/1/2012	8/15/2012	-17	PM - Unit/Space Heater
FO-224603	Routine	Scheduled Maint. (PM)	9/1/2012	8/15/2012	-17	PM - Unit/Space Heater
FO-224608	Routine	Scheduled Maint. (PM)	9/1/2012	8/15/2012	-17	PM - Unit/Space Heater
FO-220995	Routine	Scheduled Maint. (PM)	8/1/2012	7/11/2012	-21	PM - Unit/Space Heater
FO-232868	Routine	Scheduled Maint. (PM)	12/12/2012	11/21/2012	-21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-232869	Routine	Scheduled Maint. (PM)	12/12/2012	11/21/2012	-21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219495	Routine	Scheduled Maint. (PM)	7/13/2012	6/21/2012	-22	PM - Fan Coil/HV/AC Unit
FO-219496	Routine	Scheduled Maint. (PM)	7/13/2012	6/21/2012	-22	PM - Fan Coil/HV/AC Unit
FO-219497	Routine	Scheduled Maint. (PM)	7/13/2012	6/21/2012	-22	PM - Fan Coil/HV/AC Unit
FO-225094	Low	Scheduled Maint. (PM)	9/18/2012	8/27/2012	-22	PM - Air Handling Unit, HV Type
FO-224732	Low	Scheduled Maint. (PM)	9/13/2012	8/20/2012	-24	PM - Air Handling Unit, HV Type
FO-203372	Routine	Scheduled Maint. (PM)	2/10/2012	1/15/2012	-26	-> Consolidated PM items:Semi-annual task: 637FILT - Karmanos - North Tower Filter Replacement Safety Procedu
FO-203373	Routine	Scheduled Maint. (PM)	2/10/2012	1/15/2012	-26	-> Consolidated PM items:Semi-annual task: 637FILT - Karmanos - North Tower Filter Replacement Safety Procedu
FO-220994	Routine	Scheduled Maint. (PM)	8/1/2012	7/4/2012	-28	PM - Unit/Space Heater
FO-218794	Low	Scheduled Maint. (PM)	7/12/2012	6/14/2012	-28	PM - Air Handling Unit, HV Type
FO-202546	Routine	Scheduled Maint. (PM)	2/15/2012	1/15/2012	-31	-> Consolidated PM items:Semi-annual task: 637FILT - Karmanos - North Tower Filter Replacement Safety Procedu
FO-209948	Routine	Scheduled Maint. (PM)	4/16/2012	3/15/2012	-32	PM - Air Handling Unit, HV Type
FO-219532	Routine	Scheduled Maint. (PM)	8/4/2012	6/27/2012	-38	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219489	Low	Scheduled Maint. (PM)	7/31/2012	6/20/2012	-41	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208146	Routine	Scheduled Maint. (PM)	4/28/2012	3/14/2012	-45	PM - Air Handling Unit, over 50 Ton
FO-222040	Routine	Scheduled Maint. (PM)	10/3/2012	8/3/2012	-61	PM - Air Handling Unit, over 50 Ton
FO-203805	Routine	Scheduled Maint. (PM)	4/11/2012	1/25/2012	-77	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - Afternoon Swing Shift

10 of 10 100%

FO-227392	Low	Scheduled Maint. (PM)	9/15/2012	10/6/2012	21	Replace Chemistry Final Filters (AHU-1A/2A) North End
FO-227394	Routine	Scheduled Maint. (PM)	9/15/2012	10/6/2012	21	Replace Chemistry Final Filters (AHU-1A/2A) North End

			Finish Date	Due Date			Total per Trade
FO-226765	Routine	Scheduled Maint. (PM)	9/15/2012	9/29/2012	14	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	
FO-226765	Routine	Scheduled Maint. (PM)	9/15/2012	9/29/2012	14	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	
FO-235356	Routine	Scheduled Maint. (PM)	12/15/2012	12/29/2012	14	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	
FO-235357	Routine	Scheduled Maint. (PM)	12/15/2012	12/29/2012	14	Replace Chemistry PreFilters (AHU-1A/2A) North End	
FO-210841	Routine	Scheduled Maint. (PM)	3/17/2012	3/28/2012	11	-> Consolidated PM items:	
FO-209985	Routine	Scheduled Maint. (PM)	3/17/2012	3/24/2012	7	-> Consolidated PM items:	
FO-221331	Routine	Scheduled Maint. (PM)	6/16/2012	6/23/2012	7	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	
FO-221331	Routine	Scheduled Maint. (PM)	6/16/2012	6/23/2012	7	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	
E - Area 1 Engineer							394 of 910 43%
FO-211235	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.	
FO-211236	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.	
FO-228615	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.	
FO-228622	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.	
FO-229395	Routine	Scheduled Maint. (PM)	10/5/2012	12/2/2012	58	PM - Centrifugal Pump, over 1 H.P.	
FO-228637	Routine	Scheduled Maint. (PM)	10/4/2012	11/30/2012	57	PM - Centrifugal Pump, over 1 H.P.	
FO-228667	Routine	Scheduled Maint. (PM)	10/4/2012	11/30/2012	57	PM - Centrifugal Pump, over 1 H.P.	
FO-235329	Routine	Scheduled Maint. (PM)	12/13/2012	2/8/2013	57	PM - Centrifugal Pump, over 1 H.P.	
FO-211477	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.	
FO-211478	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.	
FO-211480	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.	
FO-211481	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.	
FO-227163	Routine	Scheduled Maint. (PM)	9/26/2012	11/18/2012	53	PM - Centrifugal Pump, over 1 H.P.	
FO-229396	Routine	Scheduled Maint. (PM)	10/10/2012	12/2/2012	53	PM - Centrifugal Pump, over 1 H.P.	
FO-228594	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228595	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228596	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-210586	Routine	Scheduled Maint. (PM)	3/13/2012	5/3/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-210587	Routine	Scheduled Maint. (PM)	3/13/2012	5/3/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-229397	Routine	Scheduled Maint. (PM)	10/12/2012	12/2/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228589	Routine	Scheduled Maint. (PM)	10/12/2012	11/30/2012	49	PM - Centrifugal Pump, over 1 H.P.	
FO-228590	Routine	Scheduled Maint. (PM)	10/12/2012	11/30/2012	49	PM - Centrifugal Pump, over 1 H.P.	
FO-215350	Routine	Scheduled Maint. (PM)	4/27/2012	6/14/2012	48	PM - Heat Exchanger and Economizer	
FO-230604	Routine	Scheduled Maint. (PM)	11/2/2012	12/20/2012	48	PM - Centrifugal Pump, over 1 H.P.	
FO-233510	Routine	Scheduled Maint. (PM)	11/28/2012	1/14/2013	47	PM - Punch Tubes - Chiller/Absorber	
FO-217493	Routine	Scheduled Maint. (PM)	6/1/2012	7/17/2012	46	PM - Centrifugal Pump, over 1 H.P.	
FO-227408	Routine	Scheduled Maint. (PM)	10/4/2012	11/19/2012	46	PM - Centrifugal Pump, over 1 H.P.	
FO-228634	Routine	Scheduled Maint. (PM)	10/15/2012	11/30/2012	46	PM - Centrifugal Pump, over 1 H.P.	
FO-228635	Routine	Scheduled Maint. (PM)	10/15/2012	11/30/2012	46	PM - Centrifugal Pump, over 1 H.P.	
FO-228636	Routine	Scheduled Maint. (PM)	10/15/2012	11/30/2012	46	PM - Centrifugal Pump, over 1 H.P.	
FO-211229	Routine	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Punch Tubes - Chiller/Absorber	
FO-211230	Routine	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Punch Tubes - Chiller/Absorber	
FO-211233	Routine	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Cooling Tower, 500 - 1000 Tons	
FO-211234	Routine	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Cooling Tower, 500 - 1000 Tons	
FO-228607	Routine	Scheduled Maint. (PM)	10/17/2012	11/30/2012	44	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date			Total per Trade
FO-228608	Routine	Scheduled Maint. (PM)	10/17/2012	11/30/2012	44	PM - Centrifugal Pump, over 1 H.P.	
FO-228610	Routine	Scheduled Maint. (PM)	10/17/2012	11/30/2012	44	PM - Centrifugal Pump, over 1 H.P.	
FO-229398	Routine	Scheduled Maint. (PM)	10/19/2012	12/2/2012	44	PM - Centrifugal Pump, over 1 H.P.	
FO-229399	Routine	Scheduled Maint. (PM)	10/19/2012	12/2/2012	44	PM - Centrifugal Pump, over 1 H.P.	
FO-228591	Routine	Scheduled Maint. (PM)	10/4/2012	11/15/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228616	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228617	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228618	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228619	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228655	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-228656	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.	
FO-211252	Routine	Scheduled Maint. (PM)	4/3/2012	5/14/2012	41	PM - Centrifugal Pump, over 1 H.P.	
FO-211253	Routine	Scheduled Maint. (PM)	4/3/2012	5/14/2012	41	PM - Centrifugal Pump, over 1 H.P.	
FO-229400	Routine	Scheduled Maint. (PM)	10/22/2012	12/2/2012	41	PM - Centrifugal Pump, over 1 H.P.	
FO-211479	Routine	Scheduled Maint. (PM)	3/20/2012	4/29/2012	40	PM - Cooling Tower, 500 - 1000 Tons	
FO-211249	Routine	Scheduled Maint. (PM)	4/4/2012	5/14/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-211251	Routine	Scheduled Maint. (PM)	4/4/2012	5/14/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217468	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217469	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217470	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217471	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217472	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217473	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217474	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-217475	Routine	Scheduled Maint. (PM)	6/7/2012	7/17/2012	40	PM - Centrifugal Pump, over 1 H.P.	
FO-211250	Routine	Scheduled Maint. (PM)	4/5/2012	5/14/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-228611	Routine	Scheduled Maint. (PM)	10/22/2012	11/30/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-228612	Routine	Scheduled Maint. (PM)	10/22/2012	11/30/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-228613	Routine	Scheduled Maint. (PM)	10/22/2012	11/30/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-228614	Routine	Scheduled Maint. (PM)	10/22/2012	11/30/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-229401	Routine	Scheduled Maint. (PM)	10/24/2012	12/2/2012	39	PM - Centrifugal Pump, over 1 H.P.	
FO-211248	Routine	Scheduled Maint. (PM)	4/6/2012	5/14/2012	38	PM - Centrifugal Pump, over 1 H.P.	
FO-228620	Routine	Scheduled Maint. (PM)	10/23/2012	11/30/2012	38	PM - Centrifugal Pump, over 1 H.P.	
FO-228621	Routine	Scheduled Maint. (PM)	10/23/2012	11/30/2012	38	PM - Centrifugal Pump, over 1 H.P.	
FO-229402	Routine	Scheduled Maint. (PM)	10/25/2012	12/2/2012	38	PM - Centrifugal Pump, over 1 H.P.	
FO-233512	Routine	Scheduled Maint. (PM)	12/7/2012	1/14/2013	38	PM - Centrifugal Pump, over 1 H.P.	
FO-233513	Routine	Scheduled Maint. (PM)	12/7/2012	1/14/2013	38	PM - Centrifugal Pump, over 1 H.P.	
FO-228592	Routine	Scheduled Maint. (PM)	10/9/2012	11/15/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-228593	Routine	Scheduled Maint. (PM)	10/9/2012	11/15/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-230269	Routine	Scheduled Maint. (PM)	10/23/2012	11/29/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-230270	Routine	Scheduled Maint. (PM)	10/23/2012	11/29/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-230271	Routine	Scheduled Maint. (PM)	10/23/2012	11/29/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-230272	Routine	Scheduled Maint. (PM)	10/23/2012	11/29/2012	37	PM - Centrifugal Pump, over 1 H.P.	
FO-214022	Routine	Scheduled Maint. (PM)	5/7/2012	6/12/2012	36	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date	Total per Trade	
FO-214023	Routine	Scheduled Maint. (PM)	5/7/2012	6/12/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-214024	Routine	Scheduled Maint. (PM)	5/7/2012	6/12/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-214026	Routine	Scheduled Maint. (PM)	5/7/2012	6/12/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-215356	Low	Scheduled Maint. (PM)	4/24/2012	5/30/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-230449	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Chemical Feed/Metering Pump/Controller
FO-230459	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-230460	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-230461	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-230462	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-230463	Low	Scheduled Maint. (PM)	10/24/2012	11/29/2012	36	PM - Centrifugal Pump, over 1 H.P.
FO-215154	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-215155	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-215156	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-215159	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Centrifugal Pump, over 1 H.P.
FO-215160	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Centrifugal Pump, over 1 H.P.
FO-215161	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-215164	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Centrifugal Pump, over 1 H.P.
FO-215165	Low	Scheduled Maint. (PM)	4/25/2012	5/30/2012	35	PM - Centrifugal Pump, over 1 H.P.
FO-230446	Low	Scheduled Maint. (PM)	10/25/2012	11/29/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-230447	Low	Scheduled Maint. (PM)	10/25/2012	11/29/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-230448	Low	Scheduled Maint. (PM)	10/25/2012	11/29/2012	35	PM - Chemical Feed/Metering Pump/Controller
FO-214025	Routine	Scheduled Maint. (PM)	5/9/2012	6/12/2012	34	PM - Centrifugal Pump, over 1 H.P.
FO-229403	Routine	Scheduled Maint. (PM)	10/29/2012	12/2/2012	34	PM - Centrifugal Pump, over 1 H.P.
FO-229404	Routine	Scheduled Maint. (PM)	10/30/2012	12/2/2012	33	PM - Centrifugal Pump, over 1 H.P.
FO-229405	Routine	Scheduled Maint. (PM)	10/30/2012	12/2/2012	33	PM - Centrifugal Pump, over 1 H.P.
FO-210591	Routine	Scheduled Maint. (PM)	4/5/2012	5/7/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-210592	Routine	Scheduled Maint. (PM)	4/5/2012	5/7/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-228624	Routine	Scheduled Maint. (PM)	10/29/2012	11/30/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-228625	Routine	Scheduled Maint. (PM)	10/29/2012	11/30/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-228626	Routine	Scheduled Maint. (PM)	10/29/2012	11/30/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-229406	Routine	Scheduled Maint. (PM)	10/31/2012	12/2/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-229407	Routine	Scheduled Maint. (PM)	10/31/2012	12/2/2012	32	PM - Centrifugal Pump, over 1 H.P.
FO-224927	Routine	Scheduled Maint. (PM)	8/7/2012	9/7/2012	31	PM - Monthly AHU Inspection Clean Room Unit 1
FO-228646	Routine	Scheduled Maint. (PM)	10/15/2012	11/15/2012	31	PM - Water/Air Cooled Condenser
FO-228647	Routine	Scheduled Maint. (PM)	10/15/2012	11/15/2012	31	PM - Water/Air Cooled Condenser
FO-234990	Routine	Scheduled Maint. (PM)	12/1/2012	12/31/2012	30	PM - Fire Pump, Main/Jockey
FO-234991	Routine	Scheduled Maint. (PM)	12/1/2012	12/31/2012	30	PM - Fire Pump, Main/Jockey
FO-221905	Routine	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-221906	Routine	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-221907	Routine	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-221908	Routine	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-222025	Low	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-222026	Low	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.
FO-222035	Low	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date			Total per Trade
FO-222036	Low	Scheduled Maint. (PM)	7/31/2012	8/29/2012	29	PM - Centrifugal Pump, over 1 H.P.	
FO-230300	Routine	Scheduled Maint. (PM)	10/16/2012	11/14/2012	29	PM - Heat Exchanger and Economizer	
FO-230301	Routine	Scheduled Maint. (PM)	10/16/2012	11/14/2012	29	PM - Heat Exchanger and Economizer	
FO-221310	Routine	Scheduled Maint. (PM)	7/10/2012	8/7/2012	28	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-226100	Low	Scheduled Maint. (PM)	9/5/2012	10/3/2012	28	PM - Vacuum Pump	
FO-238022	Routine	Scheduled Maint. (PM)	1/10/2013	2/7/2013	28	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-222024	Low	Scheduled Maint. (PM)	8/2/2012	8/29/2012	27	PM - Centrifugal Pump, over 1 H.P.	
FO-238021	Routine	Scheduled Maint. (PM)	1/11/2013	2/7/2013	27	PM - Semi Annual Air Handling Unit Inspection	
FO-209222	Routine	Scheduled Maint. (PM)	3/12/2012	4/7/2012	26	PM - Chiller: Centrifugal/Screw	
FO-213605	Routine	Scheduled Maint. (PM)	4/9/2012	5/5/2012	26	PM - Boiler, Steam Boiler, 500-1000 MBH	
FO-229412	Routine	Scheduled Maint. (PM)	10/12/2012	11/7/2012	26	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-213567	Routine	Scheduled Maint. (PM)	4/10/2012	5/4/2012	24	PM - Sump Pump	
FO-218966	Routine	Scheduled Maint. (PM)	6/14/2012	7/8/2012	24	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-230268	Routine	Scheduled Maint. (PM)	11/5/2012	11/29/2012	24	PM - Cooling Tower, 500 - 1000 Tons	
FO-230450	Low	Scheduled Maint. (PM)	11/5/2012	11/29/2012	24	PM - Cooling Tower, 500 - 1000 Tons	
FO-233500	Routine	Scheduled Maint. (PM)	12/6/2012	12/30/2012	24	PM - Punch Tubes - Chiller/Absorber	
FO-233504	Routine	Scheduled Maint. (PM)	12/7/2012	12/31/2012	24	PM - Cooling Tower, 500 - 1000 Tons	
FO-228598	Routine	Scheduled Maint. (PM)	11/7/2012	11/30/2012	23	PM - Centrifugal Pump, over 1 H.P.	
FO-216164	Routine	Scheduled Maint. (PM)	6/13/2012	7/5/2012	22	PM - Centrifugal Pump, over 1 H.P.	
FO-218367	Routine	Scheduled Maint. (PM)	6/9/2012	7/1/2012	22	PM - Fire Pump, Main/Jockey	
FO-218368	Routine	Scheduled Maint. (PM)	6/9/2012	7/1/2012	22	PM - Fire Pump, Main/Jockey	
FO-228597	Routine	Scheduled Maint. (PM)	11/9/2012	11/30/2012	21	PM - Centrifugal Pump, over 1 H.P.	
FO-228599	Routine	Scheduled Maint. (PM)	11/9/2012	11/30/2012	21	PM - Centrifugal Pump, over 1 H.P.	
FO-215168	Routine	Scheduled Maint. (PM)	5/5/2012	5/25/2012	20	PM - Condensate Return Pump	
FO-215169	Routine	Scheduled Maint. (PM)	5/5/2012	5/25/2012	20	PM - Condensate Return Pump	
FO-230615	Routine	Scheduled Maint. (PM)	11/30/2012	12/20/2012	20	PM - Centrifugal Pump, over 1 H.P.	
FO-230616	Routine	Scheduled Maint. (PM)	11/30/2012	12/20/2012	20	PM - Centrifugal Pump, over 1 H.P.	
FO-235348	Routine	Scheduled Maint. (PM)	12/18/2012	1/7/2013	20	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-217504	Routine	Scheduled Maint. (PM)	5/21/2012	6/9/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-217505	Routine	Scheduled Maint. (PM)	5/21/2012	6/9/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-217506	Routine	Scheduled Maint. (PM)	5/21/2012	6/9/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-217507	Routine	Scheduled Maint. (PM)	5/21/2012	6/9/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-220209	High	Scheduled Maint. (PM)	6/15/2012	7/4/2012	19	Generator Maintenance	
FO-224936	Low	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224937	Low	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224938	Low	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224941	Low	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224942	Low	Scheduled Maint. (PM)	8/8/2012	8/27/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-226766	Routine	Scheduled Maint. (PM)	10/1/2012	10/19/2012	18	PM - Deaerator Tank	
FO-230567	Routine	Scheduled Maint. (PM)	10/17/2012	11/4/2012	18	PM - Domestic Water Heater, Steam	
FO-230568	Routine	Scheduled Maint. (PM)	10/17/2012	11/4/2012	18	PM - Domestic Water Heater, Steam	
FO-233503	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Cooling Tower, 500 - 1000 Tons	
FO-233505	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Cooling Tower, 500 - 1000 Tons	
FO-233506	Routine	Scheduled Maint. (PM)	12/13/2012	12/31/2012	18	PM - Cooling Tower, 500 - 1000 Tons	

Finish Date Due Date

Total per Trade

FO-237368	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237369	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237370	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237371	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237372	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237373	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237374	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-237375	Routine	Scheduled Maint. (PM)	1/10/2013	1/28/2013	18	PM - Air Handling Unit
FO-219684	Low	Scheduled Maint. (PM)	6/19/2012	7/6/2012	17	PM - Centrifugal Pump, over 1 H.P.
FO-219685	Low	Scheduled Maint. (PM)	6/19/2012	7/6/2012	17	PM - Centrifugal Pump, over 1 H.P.
FO-230613	Routine	Scheduled Maint. (PM)	12/3/2012	12/20/2012	17	PM - Centrifugal Pump, over 1 H.P.
FO-230758	Routine	Scheduled Maint. (PM)	10/18/2012	11/4/2012	17	PM - Domestic Water Heater, Steam
FO-233545	Routine	Scheduled Maint. (PM)	12/13/2012	12/30/2012	17	PM - Punch Tubes - Chiller/Absorber
FO-237822	Routine	Scheduled Maint. (PM)	1/9/2013	1/26/2013	17	PM - Centrifugal Pump, over 1 H.P.
FO-237823	Routine	Scheduled Maint. (PM)	1/9/2013	1/26/2013	17	PM - Centrifugal Pump, over 1 H.P.
FO-237824	Routine	Scheduled Maint. (PM)	1/9/2013	1/26/2013	17	PM - Centrifugal Pump, over 1 H.P.
FO-215170	Routine	Scheduled Maint. (PM)	5/9/2012	5/25/2012	16	PM - Condensate Return Pump
FO-229394	Routine	Scheduled Maint. (PM)	11/16/2012	12/2/2012	16	PM - Centrifugal Pump, over 1 H.P.
FO-214756	Routine	Scheduled Maint. (PM)	4/30/2012	5/15/2012	15	PM - Water/Air Cooled Condenser
FO-224926	Routine	Scheduled Maint. (PM)	8/7/2012	8/22/2012	15	Monthly AHU Inspection Clean Room Unit 2
FO-209312	Routine	Scheduled Maint. (PM)	2/8/2012	2/22/2012	14	PM - Emergency Shower/Eyewash Station
FO-209313	Routine	Scheduled Maint. (PM)	2/8/2012	2/22/2012	14	PM - Emergency Shower/Eyewash Station
FO-209311	Routine	Scheduled Maint. (PM)	2/8/2012	2/22/2012	14	PM - Emergency Shower/Eyewash Station
FO-209969	Routine	Scheduled Maint. (PM)	3/1/2012	3/15/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-210588	Routine	Scheduled Maint. (PM)	3/8/2012	3/22/2012	14	PM - Unspecified
FO-213611	Routine	Scheduled Maint. (PM)	4/24/2012	5/8/2012	14	PM - Monthly AHU Inspection Clean Room Unit 1
FO-213612	Routine	Scheduled Maint. (PM)	4/24/2012	5/8/2012	14	-> Consolidated PM items:Annual task: W-A-090 - PM - Annual Inspection of Air Handling UnitMonthly task: W CR
FO-217491	Routine	Scheduled Maint. (PM)	5/24/2012	6/7/2012	14	PM - Monthly AHU Inspection Clean Room Unit 1
FO-218968	Low	Scheduled Maint. (PM)	6/4/2012	6/18/2012	14	PM - Water Softener
FO-238519	Routine	Scheduled Maint. (PM)	1/15/2013	1/29/2013	14	PM - Harmsco Side Stream Filter
FO-213569	Routine	Scheduled Maint. (PM)	4/5/2012	4/18/2012	13	PM - Water Softener
FO-215351	Routine	Scheduled Maint. (PM)	5/2/2012	5/15/2012	13	PM - Heat Exchanger and Economizer
FO-215352	Routine	Scheduled Maint. (PM)	5/2/2012	5/15/2012	13	PM - Heat Exchanger and Economizer
FO-224947	Routine	Scheduled Maint. (PM)	8/16/2012	8/29/2012	13	PM - Domestic Water Heater, Electric
FO-224943	Low	Scheduled Maint. (PM)	8/7/2012	8/20/2012	13	PM - Sump Pump
FO-224944	Low	Scheduled Maint. (PM)	8/7/2012	8/20/2012	13	PM - Sump Pump
FO-224945	Low	Scheduled Maint. (PM)	8/7/2012	8/20/2012	13	PM - Sump Pump
FO-224946	Low	Scheduled Maint. (PM)	8/7/2012	8/20/2012	13	PM - Sump Pump
FO-230464	Low	Scheduled Maint. (PM)	10/16/2012	10/29/2012	13	PM - Harmsco Side Stream Filter
FO-235360	Routine	Scheduled Maint. (PM)	12/5/2012	12/18/2012	13	PM - Water Softener
FO-237825	Routine	Scheduled Maint. (PM)	1/5/2013	1/18/2013	13	PM - Water Softener
FO-209227	Routine	Scheduled Maint. (PM)	2/16/2012	2/28/2012	12	PM - Chemical Feed/Metering Pump/Controller
FO-209226	Routine	Scheduled Maint. (PM)	2/16/2012	2/28/2012	12	PM - Chemical Feed/Metering Pump/Controller
FO-209228	Routine	Scheduled Maint. (PM)	2/16/2012	2/28/2012	12	PM - Chemical Feed/Metering Pump/Controller

			Finish Date	Due Date			Total per Trade
FO-209229	Routine	Scheduled Maint. (PM)	2/16/2012	2/28/2012	12	PM - Chemical Feed/Metering Pump/Controller	
FO-209230	Routine	Scheduled Maint. (PM)	2/16/2012	2/28/2012	12	PM - Chemical Feed/Metering Pump/Controller	
FO-211271	Routine	Scheduled Maint. (PM)	5/2/2012	5/14/2012	12	PM - Centrifugal Pump, over 1 H.P.	
FO-222031	Routine	Scheduled Maint. (PM)	7/11/2012	7/23/2012	12	PM - Emergency Shower/Eyewash Station - Annual Flow Test	
FO-218060	High	Scheduled Maint. (PM)	5/25/2012	6/6/2012	12	Generator Maintenance	
FO-232805	Routine	Scheduled Maint. (PM)	11/26/2012	12/8/2012	12	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-233501	Routine	Scheduled Maint. (PM)	12/18/2012	12/30/2012	12	PM - Punch Tubes - Chiller/Absorber	
FO-238020	Routine	Scheduled Maint. (PM)	1/10/2013	1/22/2013	12	Monthly AHU Inspection Clean Room Unit 2	
FO-224917	Low	Scheduled Maint. (PM)	8/9/2012	8/20/2012	11	PM - Sump Pump	
FO-224919	Low	Scheduled Maint. (PM)	8/9/2012	8/20/2012	11	PM - Sump Pump	
FO-224920	Low	Scheduled Maint. (PM)	8/9/2012	8/20/2012	11	PM - Sump Pump	
FO-233508	Routine	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Vacuum Pump	
FO-233509	Routine	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Vacuum Pump	
FO-208920	Routine	Scheduled Maint. (PM)	4/5/2012	4/15/2012	10	PM - Centrifugal Pump, over 1 H.P.	
FO-218981	Low	Scheduled Maint. (PM)	6/8/2012	6/18/2012	10	PM - Water Softener	
FO-224921	Low	Scheduled Maint. (PM)	8/10/2012	8/20/2012	10	PM - Sump Pump	
FO-224922	Low	Scheduled Maint. (PM)	8/10/2012	8/20/2012	10	PM - Sump Pump	
FO-224923	Low	Scheduled Maint. (PM)	8/10/2012	8/20/2012	10	PM - Sump Pump	
FO-226764	Routine	Scheduled Maint. (PM)	9/28/2012	10/8/2012	10	PM - Monthly AHU Inspection Clean Room Unit 1	
FO-229410	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	Monthly AHU Inspection Clean Room Unit 2	
FO-229415	Low	Scheduled Maint. (PM)	10/19/2012	10/29/2012	10	PM - Domestic Water Heater, Gas	
FO-210574	Routine	Scheduled Maint. (PM)	3/13/2012	3/22/2012	9	Monthly AHU Inspection Clean Room Unit 2	
FO-215157	Routine	Scheduled Maint. (PM)	5/21/2012	5/30/2012	9	PM - Centrifugal Pump, over 1 H.P.	
FO-215158	Routine	Scheduled Maint. (PM)	5/21/2012	5/30/2012	9	PM - Centrifugal Pump, over 1 H.P.	
FO-215162	Routine	Scheduled Maint. (PM)	5/21/2012	5/30/2012	9	PM - Centrifugal Pump, over 1 H.P.	
FO-215163	Routine	Scheduled Maint. (PM)	5/21/2012	5/30/2012	9	PM - Centrifugal Pump, over 1 H.P.	
FO-216160	Routine	Scheduled Maint. (PM)	5/7/2012	5/16/2012	9	PM - Water Softener	
FO-218969	Routine	Scheduled Maint. (PM)	6/13/2012	6/22/2012	9	PM - Domestic Water Heater, Gas	
FO-230592	Routine	Scheduled Maint. (PM)	11/5/2012	11/14/2012	9	PM - Chemical Feed/Metering Pump/Controller	
FO-230593	Routine	Scheduled Maint. (PM)	11/5/2012	11/14/2012	9	PM - Chemical Feed/Metering Pump/Controller	
FO-209971	Routine	Scheduled Maint. (PM)	3/8/2012	3/16/2012	8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-217629	Routine	Scheduled Maint. (PM)	5/21/2012	5/29/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-218967	Routine	Scheduled Maint. (PM)	6/14/2012	6/22/2012	8	Monthly AHU Inspection Clean Room Unit 2	
FO-228623	Routine	Scheduled Maint. (PM)	11/22/2012	11/30/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-229416	Low	Scheduled Maint. (PM)	10/15/2012	10/23/2012	8	PM INSPECT AND CLEAN COIL	
FO-229417	Low	Scheduled Maint. (PM)	10/15/2012	10/23/2012	8	PM INSPECT AND CLEAN COIL	
FO-229418	Low	Scheduled Maint. (PM)	10/15/2012	10/23/2012	8	PM INSPECT AND CLEAN COIL	
FO-209972	Routine	Scheduled Maint. (PM)	3/9/2012	3/16/2012	7	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209973	Routine	Scheduled Maint. (PM)	3/9/2012	3/16/2012	7	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-211482	Routine	Scheduled Maint. (PM)	4/5/2012	4/12/2012	7	PM - Unspecified	
FO-216166	Routine	Scheduled Maint. (PM)	5/25/2012	6/1/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-216167	Routine	Scheduled Maint. (PM)	5/25/2012	6/1/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-216168	Routine	Scheduled Maint. (PM)	5/25/2012	6/1/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-217501	Routine	Scheduled Maint. (PM)	5/17/2012	5/24/2012	7	PM - Condensate Return Pump	

			Finish Date	Due Date	Total per Trade	
FO-218369	Routine	Scheduled Maint. (PM)	6/8/2012	6/15/2012	7	PM - Reverse Osmosis Water Softener System
FO-226767	Low	Scheduled Maint. (PM)	9/11/2012	9/18/2012	7	PM - Water Softener
FO-212852	Routine	Scheduled Maint. (PM)	5/10/2012	5/16/2012	6	PM - Water/Air Cooled Condenser
FO-212853	Routine	Scheduled Maint. (PM)	5/10/2012	5/16/2012	6	PM - Water/Air Cooled Condenser
FO-215355	Routine	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-217489	Routine	Scheduled Maint. (PM)	5/24/2012	5/30/2012	6	PM - Vacuum Pump
FO-217490	Routine	Scheduled Maint. (PM)	5/24/2012	5/30/2012	6	PM - Vacuum Pump
FO-215348	Low	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Water Booster Pump
FO-215349	Low	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Water Booster Pump
FO-215353	Low	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-215354	Low	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-215357	Low	Scheduled Maint. (PM)	4/23/2012	4/29/2012	6	PM - Harmsco Side Stream Filter
FO-219687	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219688	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219689	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219690	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219691	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219692	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-219693	Low	Scheduled Maint. (PM)	6/30/2012	7/6/2012	6	PM - Water/Air Cooled Condenser
FO-227164	Routine	Scheduled Maint. (PM)	9/28/2012	10/4/2012	6	PM - Domestic Water Heater, Steam
FO-236700	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-236703	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-211272	Routine	Scheduled Maint. (PM)	5/9/2012	5/14/2012	5	PM - Centrifugal Pump, over 1 H.P.
FO-217492	Routine	Scheduled Maint. (PM)	5/17/2012	5/22/2012	5	Monthly AHU Inspection Clean Room Unit 2
FO-230614	Routine	Scheduled Maint. (PM)	12/15/2012	12/20/2012	5	PM - Centrifugal Pump, over 1 H.P.
FO-230976	Low	Scheduled Maint. (PM)	10/17/2012	10/22/2012	5	PM - Sump Pump
FO-230977	Low	Scheduled Maint. (PM)	10/17/2012	10/22/2012	5	PM - Sump Pump
FO-230978	Low	Scheduled Maint. (PM)	10/17/2012	10/22/2012	5	PM - Sump Pump
FO-230979	Low	Scheduled Maint. (PM)	10/17/2012	10/22/2012	5	PM - Sump Pump
FO-235347	Routine	Scheduled Maint. (PM)	12/17/2012	12/22/2012	5	Monthly AHU Inspection Clean Room Unit 2
FO-211239	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-211240	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-211241	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-211242	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Cooling Tower, 500 - 1000 Tons
FO-211243	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Cooling Tower, 500 - 1000 Tons
FO-234983	Routine	Scheduled Maint. (PM)	12/13/2012	12/17/2012	4	PM - Heat Exchanger and Economizer
FO-227412	Low	Scheduled Maint. (PM)	9/26/2012	9/29/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-227413	Low	Scheduled Maint. (PM)	9/26/2012	9/29/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-209249	Routine	Scheduled Maint. (PM)	4/6/2012	4/8/2012	2	PM - Centrifugal Pump, over 1 H.P.
FO-211289	Routine	Scheduled Maint. (PM)	4/12/2012	4/14/2012	2	PM - Marley Cooling Tower @ Physics
FO-224881	Routine	Scheduled Maint. (PM)	8/28/2012	8/30/2012	2	PM - Deaerator Tank
FO-224882	Routine	Scheduled Maint. (PM)	8/28/2012	8/30/2012	2	PM - Domestic Water Heater, Gas
FO-226091	Routine	Scheduled Maint. (PM)	9/29/2012	10/1/2012	2	PM - Fire Pump, Main/Jockey
FO-226092	Routine	Scheduled Maint. (PM)	9/29/2012	10/1/2012	2	PM - Fire Pump, Main/Jockey

			Finish Date	Due Date			Total per Trade
FO-227420	Routine	Scheduled Maint. (PM)	11/3/2012	11/5/2012	2	PM - Cooling Tower, 500 - 1000 Tons	
FO-227421	Routine	Scheduled Maint. (PM)	11/3/2012	11/5/2012	2	PM - Cooling Tower, 500 - 1000 Tons	
FO-238100	Routine	Scheduled Maint. (PM)	1/14/2013	1/16/2013	2	Generator Maintenance, Monthly	
FO-238102	Routine	Scheduled Maint. (PM)	1/14/2013	1/16/2013	2	Generator Maintenance, Monthly	
FO-208924	Routine	Scheduled Maint. (PM)	2/21/2012	2/22/2012	1	Generator Maintenance	
FO-209437	Routine	Scheduled Maint. (PM)	2/29/2012	3/1/2012	1	PM - Domestic Water Heater, Gas	
FO-209543	Routine	Scheduled Maint. (PM)	3/12/2012	3/13/2012	1	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-215166	Routine	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Maintenance	
FO-217503	Routine	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	Generator Maintenance	
FO-220206	Routine	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	Generator Maintenance	
FO-224582	Routine	Scheduled Maint. (PM)	8/15/2012	8/16/2012	1	PM - Water Softener	
FO-208365	High	Scheduled Maint. (PM)	2/9/2012	2/10/2012	1	Generator Maintenance	
FO-208366	High	Scheduled Maint. (PM)	2/9/2012	2/10/2012	1	Generator Maintenance	
FO-208925	High	Scheduled Maint. (PM)	2/9/2012	2/10/2012	1	Generator Maintenance	
FO-209214	High	Scheduled Maint. (PM)	2/24/2012	2/25/2012	1	Generator Maintenance	
FO-210575	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Maintenance	
FO-210601	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Maintenance	
FO-210602	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Maintenance	
FO-214027	High	Scheduled Maint. (PM)	4/12/2012	4/13/2012	1	Generator Maintenance	
FO-214028	High	Scheduled Maint. (PM)	4/12/2012	4/13/2012	1	Generator Maintenance	
FO-214784	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Maintenance	
FO-214785	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Maintenance	
FO-214788	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	PM Generator	
FO-215329	High	Scheduled Maint. (PM)	4/27/2012	4/28/2012	1	Generator Maintenance	
FO-217512	High	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	Generator Maintenance	
FO-217513	High	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	Generator Maintenance	
FO-218964	High	Scheduled Maint. (PM)	6/7/2012	6/8/2012	1	Generator Maintenance	
FO-219686	High	Scheduled Maint. (PM)	6/14/2012	6/15/2012	1	Generator Maintenance	
FO-219696	High	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	Generator Maintenance	
FO-219697	High	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	Generator Maintenance	
FO-222252	High	Scheduled Maint. (PM)	7/20/2012	7/21/2012	1	Generator Test	
FO-224907	Routine	Scheduled Maint. (PM)	8/28/2012	8/29/2012	1	PM - Domestic Water Heater, Electric	
FO-227389	High	Scheduled Maint. (PM)	9/13/2012	9/14/2012	1	Generator Maintenance	
FO-229408	Routine	Scheduled Maint. (PM)	10/17/2012	10/18/2012	1	PM - Water Softener	
FO-230398	Routine	Scheduled Maint. (PM)	10/16/2012	10/17/2012	1	Generator Maintenance	
FO-230418	High	Scheduled Maint. (PM)	10/11/2012	10/12/2012	1	Generator Maintenance	
FO-230795	High	Scheduled Maint. (PM)	10/12/2012	10/13/2012	1	Generator Maintenance	
FO-232818	High	Scheduled Maint. (PM)	11/8/2012	11/9/2012	1	Generator Maintenance	
FO-234283	Routine	Scheduled Maint. (PM)	11/20/2012	11/21/2012	1	Generator Maintenance	
FO-236638	Routine	Scheduled Maint. (PM)	12/18/2012	12/19/2012	1	Generator Maintenance	
FO-238032	Routine	Scheduled Maint. (PM)	1/10/2013	1/11/2013	1	Generator Maintenance, Monthly	
FO-238079	Routine	Scheduled Maint. (PM)	1/15/2013	1/16/2013	1	Generator Maintenance, Monthly	
FO-238086	Routine	Scheduled Maint. (PM)	1/25/2013	1/26/2013	1	Generator Maintenance, Monthly	
FO-209621	Routine	Scheduled Maint. (PM)	2/22/2012	2/22/2012	0	Monthly AHU Inspection Clean Room Unit 2	

			Finish Date	Due Date	Total per Trade	
FO-209450	Routine	Scheduled Maint. (PM)	2/29/2012	2/29/2012	0	PM - Domestic Water Heater, Electric
FO-209436	Routine	Scheduled Maint. (PM)	3/1/2012	3/1/2012	0	PM - Deaerator Tank
FO-209593	Routine	Scheduled Maint. (PM)	3/13/2012	3/13/2012	0	PM - Reverse Osmosis Water Softener System
FO-212070	Routine	Scheduled Maint. (PM)	3/21/2012	3/21/2012	0	Generator Maintenance
FO-211914	Routine	Scheduled Maint. (PM)	4/3/2012	4/3/2012	0	PM - Domestic Water Heater, Steam
FO-214757	Routine	Scheduled Maint. (PM)	5/15/2012	5/15/2012	0	PM - Water/Air Cooled Condenser
FO-214783	Routine	Scheduled Maint. (PM)	5/2/2012	5/2/2012	0	PM - Domestic Water Heater, Steam
FO-214787	Routine	Scheduled Maint. (PM)	5/2/2012	5/2/2012	0	PM - Domestic Water Heater, Steam
FO-222505	Routine	Scheduled Maint. (PM)	7/20/2012	7/20/2012	0	PM - Water Softener
FO-210598	High	Scheduled Maint. (PM)	3/10/2012	3/10/2012	0	Generator Maintenance
FO-210599	High	Scheduled Maint. (PM)	3/10/2012	3/10/2012	0	Generator Maintenance
FO-217510	High	Scheduled Maint. (PM)	5/12/2012	5/12/2012	0	Generator Maintenance
FO-217511	High	Scheduled Maint. (PM)	5/12/2012	5/12/2012	0	Generator Maintenance
FO-218965	High	Scheduled Maint. (PM)	6/8/2012	6/8/2012	0	Generator Maintenance
FO-218978	Routine	Scheduled Maint. (PM)	10/23/2012	10/23/2012	0	PM - Heat Exchanger and Economizer
FO-219694	Low	Scheduled Maint. (PM)	7/6/2012	7/6/2012	0	PM - Water/Air Cooled Condenser
FO-220632	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220633	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220634	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220635	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220636	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220637	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220638	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-220639	Low	Scheduled Maint. (PM)	7/29/2012	7/29/2012	0	PM - Air Handling Unit, over 50 Ton
FO-224750	Low	Scheduled Maint. (PM)	8/1/2012	8/1/2012	0	PM - Sump Pump
FO-224752	Low	Scheduled Maint. (PM)	8/1/2012	8/1/2012	0	PM - Sump Pump
FO-224915	Low	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	PM - Domestic Water Heater, Electric
FO-224916	Low	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	PM - Domestic Water Heater, Electric
FO-224930	Low	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	PM - Domestic Water Heater, Electric
FO-226088	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Domestic Water Heater, Steam
FO-226089	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Domestic Water Heater, Steam
FO-226090	Routine	Scheduled Maint. (PM)	9/15/2012	9/15/2012	0	PM - Domestic Water Heater, Steam
FO-227353	Routine	Scheduled Maint. (PM)	9/18/2012	9/18/2012	0	Generator Maintenance
FO-227355	Routine	Scheduled Maint. (PM)	9/19/2012	9/19/2012	0	Generator Maintenance
FO-227374	High	Scheduled Maint. (PM)	9/18/2012	9/18/2012	0	Generator Maintenance
FO-227376	High	Scheduled Maint. (PM)	9/18/2012	9/18/2012	0	Generator Maintenance
FO-230416	High	Scheduled Maint. (PM)	10/12/2012	10/12/2012	0	Generator Maintenance
FO-230609	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-230610	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-230611	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-230612	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-230797	High	Scheduled Maint. (PM)	10/13/2012	10/13/2012	0	Generator Maintenance
FO-232101	Routine	Scheduled Maint. (PM)	11/16/2012	11/16/2012	0	PM INSPECT AND CLEAN COIL
FO-232102	Routine	Scheduled Maint. (PM)	11/16/2012	11/16/2012	0	PM INSPECT AND CLEAN COIL

			Finish Date	Due Date	Total per Trade	
FO-234284	Routine	Scheduled Maint. (PM)	11/21/2012	11/21/2012	0	Generator Maintenance
FO-235354	Routine	Scheduled Maint. (PM)	12/7/2012	12/7/2012	0	Generator Maintenance
FO-235355	Routine	Scheduled Maint. (PM)	12/13/2012	12/13/2012	0	Generator Maintenance
FO-236639	Routine	Scheduled Maint. (PM)	12/19/2012	12/19/2012	0	Generator Maintenance
FO-238028	Routine	Scheduled Maint. (PM)	1/12/2013	1/12/2013	0	Generator Maintenance, Monthly
FO-238030	Routine	Scheduled Maint. (PM)	1/12/2013	1/12/2013	0	Generator Maintenance, Monthly
FO-238081	Routine	Scheduled Maint. (PM)	1/16/2013	1/16/2013	0	Generator Maintenance, Monthly
FO-209561	Routine	Scheduled Maint. (PM)	3/1/2012	2/29/2012	-1	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-211245	Routine	Scheduled Maint. (PM)	3/31/2012	3/30/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-216163	Routine	Scheduled Maint. (PM)	5/16/2012	5/15/2012	-1	PM - Heat Exchanger and Economizer
FO-230591	Routine	Scheduled Maint. (PM)	11/5/2012	11/4/2012	-1	PM - Chemical Feed/Metering Pump/Controller
FO-230605	Routine	Scheduled Maint. (PM)	12/21/2012	12/20/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-230606	Routine	Scheduled Maint. (PM)	12/21/2012	12/20/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-230607	Routine	Scheduled Maint. (PM)	12/21/2012	12/20/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-230608	Routine	Scheduled Maint. (PM)	12/21/2012	12/20/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-232249	High	Scheduled Maint. (PM)	11/3/2012	11/2/2012	-1	Generator Maintenance
FO-234982	Routine	Scheduled Maint. (PM)	12/13/2012	12/12/2012	-1	PM - Reverse Osmosis Water Softener System
FO-235352	Routine	Scheduled Maint. (PM)	12/14/2012	12/13/2012	-1	Generator Maintenance
FO-235353	Routine	Scheduled Maint. (PM)	12/14/2012	12/13/2012	-1	Generator Maintenance
FO-236054	Routine	Scheduled Maint. (PM)	12/19/2012	12/18/2012	-1	Generator Maintenance
FO-236642	Routine	Scheduled Maint. (PM)	12/15/2012	12/14/2012	-1	Generator Maintenance
FO-236643	Routine	Scheduled Maint. (PM)	12/15/2012	12/14/2012	-1	Generator Maintenance
FO-237833	Routine	Scheduled Maint. (PM)	1/5/2013	1/4/2013	-1	Generator Maintenance, Monthly
FO-222034	Low	Scheduled Maint. (PM)	7/31/2012	7/29/2012	-2	PM - Harmsco Side Stream Filter
FO-224929	Low	Scheduled Maint. (PM)	8/31/2012	8/29/2012	-2	PM - Domestic Water Heater, Electric
FO-232814	High	Scheduled Maint. (PM)	11/9/2012	11/7/2012	-2	PM Generator
FO-209570	Routine	Scheduled Maint. (PM)	3/2/2012	2/28/2012	-3	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-227307	Routine	Scheduled Maint. (PM)	9/24/2012	9/21/2012	-3	Inspection of Air Handling Unit
FO-232242	Routine	Scheduled Maint. (PM)	11/19/2012	11/16/2012	-3	PM - Water Softener
FO-209564	Routine	Scheduled Maint. (PM)	3/5/2012	3/1/2012	-4	PM - Vacuum Pump
FO-209563	Routine	Scheduled Maint. (PM)	3/5/2012	3/1/2012	-4	PM - Vacuum Pump
FO-226763	Routine	Scheduled Maint. (PM)	9/26/2012	9/22/2012	-4	Monthly AHU Inspection Clean Room Unit 2
FO-232801	Routine	Scheduled Maint. (PM)	11/26/2012	11/22/2012	-4	Monthly AHU Inspection Clean Room Unit 2
FO-209974	Routine	Scheduled Maint. (PM)	4/5/2012	3/31/2012	-5	PM - Fire Pump, Main/Jockey
FO-209975	Routine	Scheduled Maint. (PM)	4/5/2012	3/31/2012	-5	PM - Fire Pump, Main/Jockey
FO-214773	Routine	Scheduled Maint. (PM)	5/11/2012	5/6/2012	-5	-> Consolidated PM items:Annual task: W990166 - PM - Clean MEB AC unit CondenserAnnual task: W990166 - PM
FO-214774	Routine	Scheduled Maint. (PM)	5/11/2012	5/6/2012	-5	-> Consolidated PM items:Annual task: W990166 - PM - Clean MEB AC unit CondenserAnnual task: W990166 - PM
FO-226768	High	Scheduled Maint. (PM)	9/10/2012	9/5/2012	-5	PM Generator
FO-209562	Routine	Scheduled Maint. (PM)	3/7/2012	3/1/2012	-6	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209250	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209252	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209253	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209251	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209254	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date			Total per Trade
FO-209256	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-209257	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-209258	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-209259	Routine	Scheduled Maint. (PM)	3/12/2012	3/6/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211246	Routine	Scheduled Maint. (PM)	4/5/2012	3/30/2012	-6	PM - Centrifugal Pump, over 1 H.P.	
FO-213568	Routine	Scheduled Maint. (PM)	5/10/2012	5/4/2012	-6	PM - Sump Pump	
FO-213592	High	Scheduled Maint. (PM)	4/12/2012	4/6/2012	-6	Generator Maintenance	
FO-216161	High	Scheduled Maint. (PM)	5/10/2012	5/4/2012	-6	Generator Maintenance	
FO-226760	Routine	Scheduled Maint. (PM)	9/27/2012	9/21/2012	-6	PM - Chemical Feed/Metering Pump/Controller	
FO-226761	Routine	Scheduled Maint. (PM)	9/27/2012	9/21/2012	-6	PM - Chemical Feed/Metering Pump/Controller	
FO-226762	Routine	Scheduled Maint. (PM)	9/27/2012	9/21/2012	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-211268	Routine	Scheduled Maint. (PM)	4/6/2012	3/30/2012	-7	PM - Centrifugal Pump, over 1 H.P.	
FO-226771	Low	Scheduled Maint. (PM)	9/25/2012	9/18/2012	-7	PM - Water Softener	
FO-227419	Low	Scheduled Maint. (PM)	9/25/2012	9/18/2012	-7	Generator Maintenance	
FO-230278	Routine	Scheduled Maint. (PM)	11/8/2012	11/1/2012	-7	PM - Domestic Water Heater, Steam	
FO-230279	Routine	Scheduled Maint. (PM)	11/8/2012	11/1/2012	-7	PM - Domestic Water Heater, Steam	
FO-230394	High	Scheduled Maint. (PM)	10/19/2012	10/12/2012	-7	Generator Maintenance	
FO-230396	High	Scheduled Maint. (PM)	10/19/2012	10/12/2012	-7	Generator Maintenance	
FO-230400	Routine	Scheduled Maint. (PM)	10/17/2012	10/10/2012	-7	Generator Maintenance	
FO-233547	Low	Scheduled Maint. (PM)	11/27/2012	11/20/2012	-7	Generator Maintenance	
FO-234285	Routine	Scheduled Maint. (PM)	11/28/2012	11/21/2012	-7	Generator Maintenance	
FO-234286	Routine	Scheduled Maint. (PM)	11/28/2012	11/21/2012	-7	Generator Maintenance	
FO-211269	Routine	Scheduled Maint. (PM)	4/7/2012	3/30/2012	-8	PM - Centrifugal Pump, over 1 H.P.	
FO-224935	High	Scheduled Maint. (PM)	8/16/2012	8/8/2012	-8	PM Generator	
FO-235351	Routine	Scheduled Maint. (PM)	12/13/2012	12/5/2012	-8	PM Generator	
FO-211244	Routine	Scheduled Maint. (PM)	4/6/2012	3/28/2012	-9	PM - Centrifugal Pump, over 1 H.P.	
FO-218366	Routine	Scheduled Maint. (PM)	6/20/2012	6/11/2012	-9	PM - Reverse Osmosis Water Softener System	
FO-215331	High	Scheduled Maint. (PM)	5/18/2012	5/9/2012	-9	Generator Maintenance	
FO-238111	Routine	Scheduled Maint. (PM)	1/25/2013	1/16/2013	-9	Generator Maintenance, Monthly	
FO-208353	Routine	Scheduled Maint. (PM)	3/12/2012	3/2/2012	-10	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-215330	Routine	Scheduled Maint. (PM)	6/7/2012	5/28/2012	-10	PM - Punch Tubes - Chiller/Absorber	
FO-224614	Routine	Scheduled Maint. (PM)	8/17/2012	8/7/2012	-10	PM - Domestic Water Heater, Steam	
FO-224615	Routine	Scheduled Maint. (PM)	8/17/2012	8/7/2012	-10	PM - Domestic Water Heater, Steam	
FO-224616	Routine	Scheduled Maint. (PM)	8/17/2012	8/7/2012	-10	PM - Domestic Water Heater, Steam	
FO-208354	Low	Scheduled Maint. (PM)	3/12/2012	3/2/2012	-10	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-226081	Routine	Scheduled Maint. (PM)	9/25/2012	9/15/2012	-10	PM - Reverse Osmosis Water Softener System	
FO-227349	High	Scheduled Maint. (PM)	9/24/2012	9/14/2012	-10	Generator Maintenance	
FO-227351	High	Scheduled Maint. (PM)	9/24/2012	9/14/2012	-10	Generator Maintenance	
FO-228609	Routine	Scheduled Maint. (PM)	10/17/2012	10/7/2012	-10	PM - Centrifugal Pump, over 1 H.P.	
FO-209545	Routine	Scheduled Maint. (PM)	3/12/2012	3/1/2012	-11	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237102	Routine	Scheduled Maint. (PM)	1/9/2013	12/29/2012	-11	Generator Maintenance, Monthly	
FO-212508	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton	
FO-212509	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton	
FO-212510	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton	

			Finish Date	Due Date	Total per Trade	
FO-212511	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-212512	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-212513	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-212514	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-212515	Low	Scheduled Maint. (PM)	5/10/2012	4/28/2012	-12	PM - Air Handling Unit, over 50 Ton
FO-221243	Routine	Scheduled Maint. (PM)	8/17/2012	8/4/2012	-13	PM - Sump Pump
FO-209361	Low	Scheduled Maint. (PM)	3/13/2012	2/29/2012	-13	PM - Domestic Water Heater, Electric
FO-209362	Low	Scheduled Maint. (PM)	3/13/2012	2/29/2012	-13	PM - Domestic Water Heater, Electric
FO-209473	Low	Scheduled Maint. (PM)	3/13/2012	2/29/2012	-13	PM - Domestic Water Heater, Electric
FO-209474	Low	Scheduled Maint. (PM)	3/13/2012	2/29/2012	-13	PM - Domestic Water Heater, Electric
FO-218354	High	Scheduled Maint. (PM)	6/14/2012	6/1/2012	-13	Generator Maintenance
FO-212516	Routine	Scheduled Maint. (PM)	5/10/2012	4/26/2012	-14	PM - Sewage Lift Pump
FO-212517	Routine	Scheduled Maint. (PM)	5/10/2012	4/26/2012	-14	PM - Sewage Lift Pump
FO-230820	Low	Scheduled Maint. (PM)	10/31/2012	10/17/2012	-14	Generator Maintenance
FO-209442	Routine	Scheduled Maint. (PM)	2/22/2012	2/7/2012	-15	-> Consolidated PM items:Semi-annual task: W-S-AHU - PM - Semi Anunal Air Handling Unit InspectionMonthly tas
FO-214758	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214759	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214760	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214775	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214776	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214777	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214779	Low	Scheduled Maint. (PM)	5/22/2012	5/6/2012	-16	PM - Water/Air Cooled Condenser
FO-214030	High	Scheduled Maint. (PM)	5/2/2012	4/14/2012	-18	Generator Maintenance
FO-209565	Routine	Scheduled Maint. (PM)	3/6/2012	2/16/2012	-19	PM - Water Softener
FO-214029	High	Scheduled Maint. (PM)	5/3/2012	4/14/2012	-19	Generator Maintenance
FO-235346	Routine	Scheduled Maint. (PM)	1/10/2013	12/22/2012	-19	PM - Domestic Water Heater, Gas
FO-209330	High	Scheduled Maint. (PM)	3/13/2012	2/22/2012	-20	Generator Maintenance
FO-209978	Routine	Scheduled Maint. (PM)	4/5/2012	3/15/2012	-21	PM - Domestic Water Heater, Steam
FO-213561	Routine	Scheduled Maint. (PM)	5/10/2012	4/19/2012	-21	PM - Heat Exchanger and Economizer
FO-221985	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221986	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221987	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221988	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221989	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221990	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221991	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221992	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221993	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221994	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221995	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-221996	Routine	Scheduled Maint. (PM)	8/14/2012	7/24/2012	-21	PM - Emergency Shower/Eyewash Station
FO-226082	Routine	Scheduled Maint. (PM)	10/24/2012	10/3/2012	-21	PM - Vacuum Pump
FO-209977	Routine	Scheduled Maint. (PM)	4/6/2012	3/15/2012	-22	PM - Domestic Water Heater, Steam
FO-226079	Routine	Scheduled Maint. (PM)	10/3/2012	9/11/2012	-22	PM - Reverse Osmosis Water Softener System

			Finish Date	Due Date	Total per Trade	
FO-233524	Routine	Scheduled Maint. (PM)	12/7/2012	11/15/2012	-22	PM - Centrifugal Pump, over 1 H.P.
FO-209976	Routine	Scheduled Maint. (PM)	4/7/2012	3/15/2012	-23	PM - Domestic Water Heater, Steam
FO-213564	Routine	Scheduled Maint. (PM)	5/10/2012	4/17/2012	-23	PM - Air Dryer
FO-212078	High	Scheduled Maint. (PM)	4/27/2012	4/4/2012	-23	Generator Maintenance
FO-209196	High	Scheduled Maint. (PM)	3/13/2012	2/18/2012	-24	PM Generator
FO-209331	High	Scheduled Maint. (PM)	3/13/2012	2/18/2012	-24	Generator Maintenance
FO-226071	Routine	Scheduled Maint. (PM)	9/25/2012	9/1/2012	-24	PM - Bi Annual Inspection of Glycol
FO-226072	Routine	Scheduled Maint. (PM)	9/25/2012	9/1/2012	-24	PM - Bi Annual Inspection of Glycol
FO-217485	High	Scheduled Maint. (PM)	6/5/2012	5/11/2012	-25	Generator Maintenance
FO-217486	High	Scheduled Maint. (PM)	6/5/2012	5/11/2012	-25	Generator Maintenance
FO-211247	Routine	Scheduled Maint. (PM)	5/10/2012	4/14/2012	-26	PM - Boiler, Steam Boiler, 500-1000 MBH
FO-209580	Routine	Scheduled Maint. (PM)	3/13/2012	2/15/2012	-27	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209268	High	Scheduled Maint. (PM)	3/9/2012	2/11/2012	-27	Generator Maintenance
FO-209269	High	Scheduled Maint. (PM)	3/9/2012	2/11/2012	-27	Generator Maintenance
FO-227360	High	Scheduled Maint. (PM)	10/26/2012	9/29/2012	-27	Generator Maintenance
FO-224913	Routine	Scheduled Maint. (PM)	9/27/2012	8/30/2012	-28	PM - Vacuum Pump
FO-224914	Routine	Scheduled Maint. (PM)	9/27/2012	8/30/2012	-28	PM - Vacuum Pump
FO-209594	Routine	Scheduled Maint. (PM)	2/16/2012	1/18/2012	-29	PM - Water Softener
FO-214778	Low	Scheduled Maint. (PM)	6/4/2012	5/6/2012	-29	PM - Water/Air Cooled Condenser
FO-217508	High	Scheduled Maint. (PM)	6/14/2012	5/16/2012	-29	PM Generator
FO-226094	Routine	Scheduled Maint. (PM)	10/1/2012	9/1/2012	-30	PM - Water/Air Cooled Condenser
FO-230627	Routine	Scheduled Maint. (PM)	12/14/2012	11/14/2012	-30	PM - Chemical Feed/Metering Pump/Controller
FO-230629	Routine	Scheduled Maint. (PM)	12/14/2012	11/14/2012	-30	PM - Chemical Feed/Metering Pump/Controller
FO-209618	Routine	Scheduled Maint. (PM)	2/22/2012	1/22/2012	-31	Monthly AHU Inspection Clean Room Unit 2
FO-209221	Routine	Scheduled Maint. (PM)	3/9/2012	2/6/2012	-32	PM - Absorption Unit
FO-209220	Routine	Scheduled Maint. (PM)	3/9/2012	2/6/2012	-32	PM - Absorption Unit
FO-209255	Routine	Scheduled Maint. (PM)	4/7/2012	3/6/2012	-32	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-212818	Routine	Scheduled Maint. (PM)	5/10/2012	4/7/2012	-33	PM - Emergency Shower/Eyewash Station
FO-230405	High	Scheduled Maint. (PM)	11/19/2012	10/17/2012	-33	Generator Maintenance
FO-230628	Routine	Scheduled Maint. (PM)	12/17/2012	11/14/2012	-33	PM - Chemical Feed/Metering Pump/Controller
FO-209182	Routine	Scheduled Maint. (PM)	3/13/2012	2/8/2012	-34	PM - Centrifugal Pump, over 1 H.P.
FO-209193	Routine	Scheduled Maint. (PM)	3/13/2012	2/8/2012	-34	PM - Centrifugal Pump, over 1 H.P.
FO-213562	High	Scheduled Maint. (PM)	5/10/2012	4/6/2012	-34	Generator Maintenance
FO-213563	High	Scheduled Maint. (PM)	5/10/2012	4/6/2012	-34	Generator Maintenance
FO-234979	Routine	Scheduled Maint. (PM)	1/17/2013	12/14/2012	-34	PM - Heat Exchanger and Economizer
FO-234997	Routine	Scheduled Maint. (PM)	1/17/2013	12/14/2012	-34	PM - Heat Exchanger and Economizer
FO-209568	Routine	Scheduled Maint. (PM)	3/6/2012	1/31/2012	-35	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209569	Routine	Scheduled Maint. (PM)	3/6/2012	1/31/2012	-35	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209571	Routine	Scheduled Maint. (PM)	3/6/2012	1/31/2012	-35	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209181	Routine	Scheduled Maint. (PM)	3/13/2012	2/7/2012	-35	PM - Centrifugal Pump, over 1 H.P.
FO-229414	High	Scheduled Maint. (PM)	11/7/2012	10/3/2012	-35	PM Generator
FO-232815	Routine	Scheduled Maint. (PM)	12/14/2012	11/9/2012	-35	Generator Maintenance
FO-232816	Routine	Scheduled Maint. (PM)	12/14/2012	11/9/2012	-35	Generator Maintenance
FO-209443	Routine	Scheduled Maint. (PM)	2/23/2012	1/18/2012	-36	PM - Air Dryer

			Finish Date	Due Date			Total per Trade
FO-209444	Routine	Scheduled Maint. (PM)	2/23/2012	1/18/2012	-36	PM - Air Dryer	
FO-209180	Routine	Scheduled Maint. (PM)	3/13/2012	2/6/2012	-36	PM - Centrifugal Pump, over 1 H.P.	
FO-222015	High	Scheduled Maint. (PM)	8/16/2012	7/11/2012	-36	PM Generator	
FO-212074	Routine	Scheduled Maint. (PM)	5/10/2012	4/3/2012	-37	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-212075	Routine	Scheduled Maint. (PM)	5/10/2012	4/3/2012	-37	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214780	Routine	Scheduled Maint. (PM)	6/11/2012	5/5/2012	-37	PM - Domestic Water Heater, Steam	
FO-226747	Routine	Scheduled Maint. (PM)	10/29/2012	9/22/2012	-37	PM - Unspecified	
FO-209980	Routine	Scheduled Maint. (PM)	5/10/2012	4/2/2012	-38	PM - Vacuum Pump	
FO-208875	Routine	Scheduled Maint. (PM)	3/5/2012	1/26/2012	-39	PM - Centrifugal Pump, over 1 H.P.	
FO-208874	Routine	Scheduled Maint. (PM)	3/5/2012	1/26/2012	-39	PM - Centrifugal Pump, over 1 H.P.	
FO-208873	Routine	Scheduled Maint. (PM)	3/5/2012	1/26/2012	-39	PM - Centrifugal Pump, over 1 H.P.	
FO-214781	Routine	Scheduled Maint. (PM)	6/13/2012	5/5/2012	-39	PM - Domestic Water Heater, Steam	
FO-214782	Routine	Scheduled Maint. (PM)	6/13/2012	5/5/2012	-39	PM - Domestic Water Heater, Steam	
FO-234977	Routine	Scheduled Maint. (PM)	1/22/2013	12/14/2012	-39	PM - Heat Exchanger and Economizer	
FO-234978	Routine	Scheduled Maint. (PM)	1/22/2013	12/14/2012	-39	PM - Heat Exchanger and Economizer	
FO-230407	High	Scheduled Maint. (PM)	11/19/2012	10/10/2012	-40	Generator Maintenance	
FO-236640	Routine	Scheduled Maint. (PM)	1/28/2013	12/19/2012	-40	Generator Maintenance	
FO-236641	Routine	Scheduled Maint. (PM)	1/28/2013	12/19/2012	-40	Generator Maintenance	
FO-209445	Routine	Scheduled Maint. (PM)	2/29/2012	1/18/2012	-42	PM - Air Dryer	
FO-209355	Routine	Scheduled Maint. (PM)	3/13/2012	1/29/2012	-44	PM - Air Dryer	
FO-209356	Routine	Scheduled Maint. (PM)	3/13/2012	1/29/2012	-44	PM - Air Dryer	
FO-209357	Routine	Scheduled Maint. (PM)	3/13/2012	1/29/2012	-44	PM - Air Dryer	
FO-209471	Routine	Scheduled Maint. (PM)	3/13/2012	1/29/2012	-44	PM - Air Dryer	
FO-209579	Routine	Scheduled Maint. (PM)	3/13/2012	1/29/2012	-44	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209309	Routine	Scheduled Maint. (PM)	4/26/2012	3/12/2012	-45	PM - Centrifugal Pump, over 1 H.P.	
FO-209310	Routine	Scheduled Maint. (PM)	4/26/2012	3/12/2012	-45	PM - Centrifugal Pump, over 1 H.P.	
FO-209476	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209477	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209478	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209479	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209480	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209481	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209482	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209483	Low	Scheduled Maint. (PM)	3/13/2012	1/28/2012	-45	PM - Air Handling Unit, over 50 Ton	
FO-209200	Routine	Scheduled Maint. (PM)	2/14/2012	12/30/2011	-46	PM - Punch Tubes - Chiller/Absorber	
FO-211290	Routine	Scheduled Maint. (PM)	5/10/2012	3/25/2012	-46	Inspection of Air Handling Unit	
FO-227315	Low	Scheduled Maint. (PM)	12/14/2012	10/29/2012	-46	PM - Air Handling Unit, over 50 Ton	
FO-227316	Low	Scheduled Maint. (PM)	12/14/2012	10/29/2012	-46	PM - Air Handling Unit, over 50 Ton	
FO-227317	Low	Scheduled Maint. (PM)	12/14/2012	10/29/2012	-46	PM - Air Handling Unit, over 50 Ton	
FO-227318	Low	Scheduled Maint. (PM)	12/14/2012	10/29/2012	-46	PM - Air Handling Unit, over 50 Ton	
FO-212077	High	Scheduled Maint. (PM)	5/10/2012	3/24/2012	-47	Generator Maintenance	
FO-208861	Routine	Scheduled Maint. (PM)	3/14/2012	1/26/2012	-48	PM - Punch Tubes - Chiller/Absorber	
FO-210589	Routine	Scheduled Maint. (PM)	5/10/2012	3/23/2012	-48	PM - Fan Coil/HV/AC Unit	
FO-224580	Routine	Scheduled Maint. (PM)	9/24/2012	8/7/2012	-48	Inspection of Air Handling Unit	

			Finish Date	Due Date			Total per Trade
FO-227319	Low	Scheduled Maint. (PM)	12/17/2012	10/29/2012	-49	PM - Air Handling Unit, over 50 Ton	
FO-227320	Low	Scheduled Maint. (PM)	12/17/2012	10/29/2012	-49	PM - Air Handling Unit, over 50 Ton	
FO-227321	Low	Scheduled Maint. (PM)	12/17/2012	10/29/2012	-49	PM - Air Handling Unit, over 50 Ton	
FO-227322	Low	Scheduled Maint. (PM)	12/17/2012	10/29/2012	-49	PM - Air Handling Unit, over 50 Ton	
FO-209453	Routine	Scheduled Maint. (PM)	3/2/2012	1/12/2012	-50	PM - Unspecified	
FO-209979	Routine	Scheduled Maint. (PM)	5/4/2012	3/15/2012	-50	PM - Reverse Osmosis Water Softener System	
FO-212076	High	Scheduled Maint. (PM)	5/10/2012	3/21/2012	-50	PM Generator	
FO-212079	High	Scheduled Maint. (PM)	5/10/2012	3/21/2012	-50	Generator Maintenance	
FO-212080	High	Scheduled Maint. (PM)	5/10/2012	3/21/2012	-50	Generator Maintenance	
FO-209314	High	Scheduled Maint. (PM)	4/27/2012	3/7/2012	-51	Generator Maintenance	
FO-225542	Routine	Scheduled Maint. (PM)	10/26/2012	9/5/2012	-51	PM - Heat Exchanger and Economizer	
FO-225543	Routine	Scheduled Maint. (PM)	10/26/2012	9/5/2012	-51	PM - Heat Exchanger and Economizer	
FO-208330	Routine	Scheduled Maint. (PM)	3/12/2012	1/20/2012	-52	PM - Centrifugal Pump, over 1 H.P.	
FO-208345	Routine	Scheduled Maint. (PM)	3/12/2012	1/18/2012	-54	PM - Centrifugal Pump, over 1 H.P.	
FO-228665	Routine	Scheduled Maint. (PM)	1/25/2013	11/30/2012	-56	PM - Centrifugal Pump, over 1 H.P.	
FO-208284	Routine	Scheduled Maint. (PM)	3/13/2012	1/14/2012	-59	PM - Punch Tubes - Chiller/Absorber	
FO-208311	Routine	Scheduled Maint. (PM)	3/13/2012	1/14/2012	-59	PM - Centrifugal Pump, over 1 H.P.	
FO-208322	Routine	Scheduled Maint. (PM)	3/13/2012	1/14/2012	-59	PM - Centrifugal Pump, over 1 H.P.	
FO-228603	Routine	Scheduled Maint. (PM)	1/28/2013	11/30/2012	-59	PM - Centrifugal Pump, over 1 H.P.	
FO-228604	Routine	Scheduled Maint. (PM)	1/28/2013	11/30/2012	-59	PM - Centrifugal Pump, over 1 H.P.	
FO-228605	Routine	Scheduled Maint. (PM)	1/28/2013	11/30/2012	-59	PM - Centrifugal Pump, over 1 H.P.	
FO-209539	Routine	Scheduled Maint. (PM)	3/13/2012	1/13/2012	-60	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209540	Routine	Scheduled Maint. (PM)	3/13/2012	1/13/2012	-60	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209541	Routine	Scheduled Maint. (PM)	3/13/2012	1/13/2012	-60	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209202	Routine	Scheduled Maint. (PM)	3/20/2012	1/20/2012	-60	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-228601	Routine	Scheduled Maint. (PM)	1/29/2013	11/30/2012	-60	PM - Centrifugal Pump, over 1 H.P.	
FO-234998	Routine	Scheduled Maint. (PM)	1/30/2013	12/1/2012	-60	Generator Maintenance	
FO-228602	Routine	Scheduled Maint. (PM)	1/30/2013	11/30/2012	-61	PM - Centrifugal Pump, over 1 H.P.	
FO-209532	Routine	Scheduled Maint. (PM)	5/8/2012	3/7/2012	-62	PM - Heat Exchanger and Economizer	
FO-209533	Routine	Scheduled Maint. (PM)	5/8/2012	3/7/2012	-62	PM - Heat Exchanger and Economizer	
FO-218970	Routine	Scheduled Maint. (PM)	9/6/2012	7/6/2012	-62	PM - Condensate Return Pump	
FO-218971	Routine	Scheduled Maint. (PM)	9/6/2012	7/6/2012	-62	PM - Condensate Return Pump	
FO-208903	Routine	Scheduled Maint. (PM)	3/2/2012	12/30/2011	-63	PM - Punch Tubes - Chiller/Absorber	
FO-208904	Routine	Scheduled Maint. (PM)	3/2/2012	12/30/2011	-63	PM - Punch Tubes - Chiller/Absorber	
FO-224211	Low	Scheduled Maint. (PM)	10/24/2012	8/22/2012	-63	Generator Maintenance	
FO-209201	Routine	Scheduled Maint. (PM)	3/5/2012	12/30/2011	-66	PM - Punch Tubes - Chiller/Absorber	
FO-209235	Routine	Scheduled Maint. (PM)	3/9/2012	12/31/2011	-69	PM - Cooling Tower, 500 - 1000 Tons	
FO-209236	Routine	Scheduled Maint. (PM)	3/9/2012	12/31/2011	-69	PM - Cooling Tower, 500 - 1000 Tons	
FO-209237	Routine	Scheduled Maint. (PM)	3/9/2012	12/31/2011	-69	PM - Cooling Tower, 500 - 1000 Tons	
FO-209238	Routine	Scheduled Maint. (PM)	3/9/2012	12/31/2011	-69	PM - Cooling Tower, 500 - 1000 Tons	
FO-217467	Routine	Scheduled Maint. (PM)	9/24/2012	7/17/2012	-69	PM - Centrifugal Pump, over 1 H.P.	
FO-209520	Routine	Scheduled Maint. (PM)	3/10/2012	12/31/2011	-70	PM - Fire Pump, Main/Jockey	
FO-209521	Routine	Scheduled Maint. (PM)	3/10/2012	12/31/2011	-70	PM - Fire Pump, Main/Jockey	
FO-217477	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date			Total per Trade
FO-217478	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217479	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217480	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217481	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217482	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217483	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217484	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217495	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-217496	Routine	Scheduled Maint. (PM)	9/25/2012	7/17/2012	-70	PM - Centrifugal Pump, over 1 H.P.	
FO-209613	Routine	Scheduled Maint. (PM)	3/2/2012	12/22/2011	-71	Monthly AHU Inspection Clean Room Unit 2	
FO-217502	Routine	Scheduled Maint. (PM)	5/11/2012	2/29/2012	-72	PM - Centrifugal Pump, over 1 H.P.	
FO-208334	Routine	Scheduled Maint. (PM)	3/12/2012	12/30/2011	-73	PM - Punch Tubes - Chiller/Absorber	
FO-208352	Routine	Scheduled Maint. (PM)	3/12/2012	12/30/2011	-73	PM - Punch Tubes - Chiller/Absorber	
FO-209208	Routine	Scheduled Maint. (PM)	3/12/2012	12/30/2011	-73	PM - Cooling Tower, 500 - 1000 Tons	
FO-218974	Routine	Scheduled Maint. (PM)	10/24/2012	8/9/2012	-76	PM - Centrifugal Pump, over 1 H.P.	
FO-218973	Routine	Scheduled Maint. (PM)	10/24/2012	8/8/2012	-77	PM - Centrifugal Pump, over 1 H.P.	
FO-218972	Routine	Scheduled Maint. (PM)	10/24/2012	8/7/2012	-78	PM - Centrifugal Pump, over 1 H.P.	
FO-209231	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209232	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209234	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209233	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209239	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209240	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209241	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209242	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209243	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209244	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209245	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209246	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-209247	Routine	Scheduled Maint. (PM)	3/9/2012	12/20/2011	-80	PM - Centrifugal Pump, over 1 H.P.	
FO-221333	High	Scheduled Maint. (PM)	9/24/2012	7/6/2012	-80	Generator Maintenance	
FO-221334	High	Scheduled Maint. (PM)	9/24/2012	7/6/2012	-80	Generator Maintenance	
FO-209039	Routine	Scheduled Maint. (PM)	3/13/2012	12/22/2011	-82	PM - Domestic Water Heater, Gas	
FO-218362	Routine	Scheduled Maint. (PM)	9/4/2012	6/13/2012	-83	PM - Heat Exchanger and Economizer	
FO-218363	Routine	Scheduled Maint. (PM)	9/4/2012	6/13/2012	-83	PM - Heat Exchanger and Economizer	
FO-218364	Routine	Scheduled Maint. (PM)	9/4/2012	6/13/2012	-83	PM - Heat Exchanger and Economizer	
FO-218365	Routine	Scheduled Maint. (PM)	9/4/2012	6/13/2012	-83	PM - Heat Exchanger and Economizer	
FO-209517	Routine	Scheduled Maint. (PM)	3/9/2012	12/16/2011	-84	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209518	Routine	Scheduled Maint. (PM)	3/9/2012	12/16/2011	-84	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209148	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-209149	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-209150	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-209151	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-209152	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date	Total per Trade	
FO-209207	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-209206	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-209205	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-209519	Routine	Scheduled Maint. (PM)	3/10/2012	12/16/2011	-85	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209195	Routine	Scheduled Maint. (PM)	3/13/2012	12/17/2011	-87	PM - Heat Exchanger and Economizer
FO-208360	Routine	Scheduled Maint. (PM)	3/12/2012	12/15/2011	-88	PM - Cooling Tower, 500 - 1000 Tons
FO-209187	Routine	Scheduled Maint. (PM)	3/13/2012	12/16/2011	-88	PM - Punch Tubes - Chiller/Absorber
FO-209188	Routine	Scheduled Maint. (PM)	3/13/2012	12/16/2011	-88	PM - Punch Tubes - Chiller/Absorber
FO-209168	Routine	Scheduled Maint. (PM)	3/13/2012	12/14/2011	-90	PM - Heat Exchanger and Economizer
FO-209169	Routine	Scheduled Maint. (PM)	3/13/2012	12/14/2011	-90	PM - Heat Exchanger and Economizer
FO-209170	Routine	Scheduled Maint. (PM)	3/13/2012	12/14/2011	-90	PM - Heat Exchanger and Economizer
FO-209171	Routine	Scheduled Maint. (PM)	3/13/2012	12/14/2011	-90	PM - Heat Exchanger and Economizer
FO-209529	Routine	Scheduled Maint. (PM)	5/7/2012	2/7/2012	-90	PM - Domestic Water Heater, Steam
FO-209530	Routine	Scheduled Maint. (PM)	5/7/2012	2/7/2012	-90	PM - Domestic Water Heater, Steam
FO-209531	Routine	Scheduled Maint. (PM)	5/7/2012	2/7/2012	-90	PM - Domestic Water Heater, Steam
FO-209364	Routine	Scheduled Maint. (PM)	3/12/2012	12/12/2011	-91	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209512	Routine	Scheduled Maint. (PM)	3/13/2012	12/12/2011	-92	PM - Reverse Osmosis Water Softener System
FO-219698	Routine	Scheduled Maint. (PM)	9/24/2012	6/23/2012	-93	Inspection of Air Handling Unit
FO-209448	Routine	Scheduled Maint. (PM)	3/2/2012	11/28/2011	-95	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209435	Routine	Scheduled Maint. (PM)	3/6/2012	11/30/2011	-97	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209438	Routine	Scheduled Maint. (PM)	3/6/2012	11/30/2011	-97	PM - Vacuum Pump
FO-209439	Routine	Scheduled Maint. (PM)	3/6/2012	11/30/2011	-97	PM - Vacuum Pump
FO-209434	Routine	Scheduled Maint. (PM)	3/6/2012	11/29/2011	-98	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209273	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209274	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209275	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209276	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209278	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209277	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209279	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209280	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209281	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209282	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209283	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209284	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209285	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209286	Routine	Scheduled Maint. (PM)	3/9/2012	12/2/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209325	Routine	Scheduled Maint. (PM)	5/1/2012	1/24/2012	-98	PM - Unit/Space Heater
FO-209326	Routine	Scheduled Maint. (PM)	5/1/2012	1/24/2012	-98	PM - Unit/Space Heater
FO-209327	Routine	Scheduled Maint. (PM)	5/1/2012	1/24/2012	-98	PM - Unit/Space Heater
FO-217476	Routine	Scheduled Maint. (PM)	10/23/2012	7/17/2012	-98	PM - Centrifugal Pump, over 1 H.P.
FO-209324	Routine	Scheduled Maint. (PM)	5/3/2012	1/24/2012	-100	PM - Unit/Space Heater
FO-209608	Routine	Scheduled Maint. (PM)	3/2/2012	11/22/2011	-101	Monthly AHU Inspection Clean Room Unit 2
FO-209515	Routine	Scheduled Maint. (PM)	4/2/2012	12/23/2011	-101	PM - Fan Coil/HV/AC Unit

			Finish Date	Due Date			Total per Trade
FO-209516	Routine	Scheduled Maint. (PM)	4/2/2012	12/23/2011	-101	PM - Fan Coil/HV/AC Unit	
FO-217509	Routine	Scheduled Maint. (PM)	10/26/2012	7/17/2012	-101	PM - Centrifugal Pump, over 1 H.P.	
FO-209511	Routine	Scheduled Maint. (PM)	3/13/2012	12/2/2011	-102	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-208325	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Air Dryer	
FO-208335	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Air Dryer	
FO-208336	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Air Dryer	
FO-209366	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-208928	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208929	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208930	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208931	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208932	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208933	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208934	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208935	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-208936	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.	
FO-209197	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.	
FO-209198	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.	
FO-209199	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.	
FO-218976	Routine	Scheduled Maint. (PM)	10/22/2012	7/8/2012	-106	PM - Sump Pump	
FO-218975	Routine	Scheduled Maint. (PM)	10/23/2012	7/8/2012	-107	PM - Sump Pump	
FO-208915	Routine	Scheduled Maint. (PM)	3/2/2012	11/14/2011	-109	PM - Chemical Feed/Metering Pump/Controller	
FO-208916	Routine	Scheduled Maint. (PM)	3/2/2012	11/14/2011	-109	PM - Chemical Feed/Metering Pump/Controller	
FO-209525	Routine	Scheduled Maint. (PM)	5/7/2012	1/19/2012	-109	PM - Air Dryer	
FO-209527	Routine	Scheduled Maint. (PM)	5/7/2012	1/19/2012	-109	PM - Air Dryer	
FO-209526	Routine	Scheduled Maint. (PM)	5/8/2012	1/19/2012	-110	PM - Air Dryer	
FO-209440	Routine	Scheduled Maint. (PM)	3/6/2012	11/16/2011	-111	PM - Water Softener	
FO-209194	Routine	Scheduled Maint. (PM)	3/13/2012	11/18/2011	-116	PM - Centrifugal Pump, over 1 H.P.	
FO-209036	Routine	Scheduled Maint. (PM)	3/13/2012	11/15/2011	-119	PM - Water/Air Cooled Condenser	
FO-209035	Routine	Scheduled Maint. (PM)	3/13/2012	11/15/2011	-119	PM - Air Dryer	
FO-209037	Routine	Scheduled Maint. (PM)	3/13/2012	11/15/2011	-119	PM - Water/Air Cooled Condenser	
FO-209040	Routine	Scheduled Maint. (PM)	3/13/2012	11/15/2011	-119	PM - Heat Exchanger and Economizer	
FO-209475	Routine	Scheduled Maint. (PM)	3/13/2012	11/15/2011	-119	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-208293	Routine	Scheduled Maint. (PM)	3/13/2012	11/14/2011	-120	PM - Chemical Feed/Metering Pump/Controller	
FO-208294	Routine	Scheduled Maint. (PM)	3/13/2012	11/14/2011	-120	PM - Chemical Feed/Metering Pump/Controller	
FO-208295	Routine	Scheduled Maint. (PM)	3/13/2012	11/14/2011	-120	PM - Chemical Feed/Metering Pump/Controller	
FO-209211	Routine	Scheduled Maint. (PM)	4/18/2012	12/20/2011	-120	PM - Centrifugal Pump, over 1 H.P.	
FO-209522	Routine	Scheduled Maint. (PM)	2/16/2012	10/18/2011	-121	PM - Water Softener	
FO-209212	Routine	Scheduled Maint. (PM)	4/19/2012	12/20/2011	-121	PM - Centrifugal Pump, over 1 H.P.	
FO-209213	Routine	Scheduled Maint. (PM)	4/19/2012	12/20/2011	-121	PM - Centrifugal Pump, over 1 H.P.	
FO-209446	Routine	Scheduled Maint. (PM)	3/2/2012	10/31/2011	-123	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209447	Routine	Scheduled Maint. (PM)	3/2/2012	10/31/2011	-123	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209449	Routine	Scheduled Maint. (PM)	3/2/2012	10/31/2011	-123	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-215585	Routine	Scheduled Maint. (PM)	10/1/2012	5/30/2012	-124	PM - Boiler, Steam Boiler, 500-1000 MBH	

Finish Date Due Date

Total per Trade

FO-220207	Low	Scheduled Maint. (PM)	10/23/2012	6/20/2012	-125	Generator Maintenance
FO-220208	High	Scheduled Maint. (PM)	10/26/2012	6/23/2012	-125	Generator Maintenance
FO-220210	High	Scheduled Maint. (PM)	10/23/2012	6/20/2012	-125	Generator Maintenance
FO-220211	High	Scheduled Maint. (PM)	10/23/2012	6/20/2012	-125	Generator Maintenance
FO-209544	Routine	Scheduled Maint. (PM)	3/12/2012	11/5/2011	-128	Inspection of Air Handling Unit
FO-209186	Routine	Scheduled Maint. (PM)	4/7/2012	11/30/2011	-129	PM - Centrifugal Pump, over 1 H.P.
FO-209153	Routine	Scheduled Maint. (PM)	3/13/2012	11/4/2011	-130	PM - Domestic Water Heater, Steam
FO-209154	Routine	Scheduled Maint. (PM)	3/13/2012	11/4/2011	-130	PM - Domestic Water Heater, Steam
FO-209155	Routine	Scheduled Maint. (PM)	3/13/2012	11/4/2011	-130	PM - Domestic Water Heater, Steam
FO-209209	Routine	Scheduled Maint. (PM)	4/18/2012	12/9/2011	-131	PM - Condensate Return Pump
FO-209599	Routine	Scheduled Maint. (PM)	3/2/2012	10/22/2011	-132	Monthly AHU Inspection Clean Room Unit 2
FO-209210	Routine	Scheduled Maint. (PM)	4/19/2012	12/9/2011	-132	PM - Condensate Return Pump
FO-209300	Routine	Scheduled Maint. (PM)	5/10/2012	12/30/2011	-132	PM - Cooling Tower, 500 - 1000 Tons
FO-209301	Routine	Scheduled Maint. (PM)	5/10/2012	12/30/2011	-132	PM - Cooling Tower, 500 - 1000 Tons
FO-219695	High	Scheduled Maint. (PM)	10/23/2012	6/13/2012	-132	PM Generator
FO-209191	Routine	Scheduled Maint. (PM)	3/13/2012	11/1/2011	-133	PM - Domestic Water Heater, Steam
FO-209192	Routine	Scheduled Maint. (PM)	3/13/2012	11/1/2011	-133	PM - Domestic Water Heater, Steam
FO-209296	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209297	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209298	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209299	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209304	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209305	Routine	Scheduled Maint. (PM)	5/2/2012	12/20/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209472	Routine	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209043	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209044	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209045	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209046	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209047	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209048	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209049	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-209050	Low	Scheduled Maint. (PM)	3/13/2012	10/29/2011	-136	PM - Air Handling Unit, over 50 Ton
FO-215584	Routine	Scheduled Maint. (PM)	9/24/2012	5/9/2012	-138	Inspection of Air Handling Unit
FO-209302	Routine	Scheduled Maint. (PM)	4/26/2012	12/9/2011	-139	PM - Condensate Return Pump
FO-209534	Routine	Scheduled Maint. (PM)	5/4/2012	12/15/2011	-141	PM - Reverse Osmosis Water Softener System
FO-209248	Routine	Scheduled Maint. (PM)	3/9/2012	10/19/2011	-142	PM - Deaerator Tank
FO-208314	Routine	Scheduled Maint. (PM)	3/13/2012	10/19/2011	-146	PM - Heat Exchanger and Economizer
FO-215152	Routine	Scheduled Maint. (PM)	10/23/2012	5/30/2012	-146	PM - Water/Air Cooled Condenser
FO-209144	Routine	Scheduled Maint. (PM)	3/13/2012	10/17/2011	-148	PM - Air Dryer
FO-209317	Routine	Scheduled Maint. (PM)	4/26/2012	11/30/2011	-148	PM - Centrifugal Pump, over 1 H.P.
FO-209318	Routine	Scheduled Maint. (PM)	4/26/2012	11/30/2011	-148	PM - Centrifugal Pump, over 1 H.P.
FO-209319	Routine	Scheduled Maint. (PM)	4/27/2012	11/30/2011	-149	PM - Centrifugal Pump, over 1 H.P.
FO-209320	Routine	Scheduled Maint. (PM)	4/27/2012	11/30/2011	-149	PM - Centrifugal Pump, over 1 H.P.
FO-209321	Routine	Scheduled Maint. (PM)	4/27/2012	11/30/2011	-149	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date	Total per Trade	
FO-209028	Low	Scheduled Maint. (PM)	3/13/2012	10/15/2011	-150	PM - Heat Exchanger and Economizer
FO-218059	High	Scheduled Maint. (PM)	10/23/2012	5/26/2012	-150	Generator Maintenance
FO-208923	Routine	Scheduled Maint. (PM)	3/12/2012	10/13/2011	-151	PM - Unspecified
FO-209358	Routine	Scheduled Maint. (PM)	3/13/2012	10/14/2011	-151	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209359	Routine	Scheduled Maint. (PM)	3/13/2012	10/14/2011	-151	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209360	Routine	Scheduled Maint. (PM)	3/13/2012	10/14/2011	-151	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209223	Routine	Scheduled Maint. (PM)	2/16/2012	9/16/2011	-153	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209224	Routine	Scheduled Maint. (PM)	2/16/2012	9/16/2011	-153	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209225	Routine	Scheduled Maint. (PM)	2/16/2012	9/16/2011	-153	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208877	Routine	Scheduled Maint. (PM)	3/12/2012	10/7/2011	-157	PM - Centrifugal Pump, over 1 H.P.
FO-208918	Routine	Scheduled Maint. (PM)	3/12/2012	10/4/2011	-160	PM - Domestic Water Heater, Steam
FO-209303	Routine	Scheduled Maint. (PM)	5/8/2012	11/30/2011	-160	PM - Centrifugal Pump, over 1 H.P.
FO-209266	Routine	Scheduled Maint. (PM)	3/10/2012	10/1/2011	-161	PM - Fire Pump, Main/Jockey
FO-209267	Routine	Scheduled Maint. (PM)	3/10/2012	10/1/2011	-161	PM - Fire Pump, Main/Jockey
FO-209189	Routine	Scheduled Maint. (PM)	3/13/2012	10/4/2011	-161	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209190	Routine	Scheduled Maint. (PM)	3/13/2012	10/4/2011	-161	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209172	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209173	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209174	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209175	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209176	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209177	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209178	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209179	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209217	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209218	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-209219	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-186845	Routine	Scheduled Maint. (PM)	1/18/2012	8/8/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-186844	Routine	Scheduled Maint. (PM)	1/18/2012	8/7/2011	-164	PM - Centrifugal Pump, over 1 H.P.
FO-209567	Routine	Scheduled Maint. (PM)	3/12/2012	9/22/2011	-172	Monthly AHU Inspection Clean Room Unit 2
FO-209365	Routine	Scheduled Maint. (PM)	3/13/2012	9/21/2011	-174	Inspection of Air Handling Unit
FO-208623	Routine	Scheduled Maint. (PM)	3/13/2012	9/21/2011	-174	PM - Chemical Feed/Metering Pump/Controller
FO-208624	Routine	Scheduled Maint. (PM)	3/13/2012	9/21/2011	-174	PM - Chemical Feed/Metering Pump/Controller
FO-208625	Routine	Scheduled Maint. (PM)	3/13/2012	9/21/2011	-174	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209271	Routine	Scheduled Maint. (PM)	3/9/2012	9/15/2011	-176	PM - Domestic Water Heater, Steam
FO-209272	Routine	Scheduled Maint. (PM)	3/9/2012	9/15/2011	-176	PM - Domestic Water Heater, Steam
FO-209270	Routine	Scheduled Maint. (PM)	3/9/2012	9/15/2011	-176	PM - Domestic Water Heater, Steam
FO-209024	Routine	Scheduled Maint. (PM)	3/13/2012	9/13/2011	-182	Boiler - Open Clean and Close 48 inch Boilers
FO-208326	Routine	Scheduled Maint. (PM)	3/13/2012	9/11/2011	-184	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208865	Routine	Scheduled Maint. (PM)	3/12/2012	8/30/2011	-195	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208871	Routine	Scheduled Maint. (PM)	3/12/2012	8/30/2011	-195	PM - Deaerator Tank
FO-208872	Routine	Scheduled Maint. (PM)	3/12/2012	8/30/2011	-195	PM - Domestic Water Heater, Gas
FO-208900	Routine	Scheduled Maint. (PM)	3/12/2012	8/30/2011	-195	PM - Vacuum Pump
FO-208901	Routine	Scheduled Maint. (PM)	3/12/2012	8/30/2011	-195	PM - Vacuum Pump

			Finish Date	Due Date	Total per Trade	
FO-208919	Routine	Scheduled Maint. (PM)	3/12/2012	8/29/2011	-196	PM - Domestic Water Heater, Electric
FO-208864	Routine	Scheduled Maint. (PM)	3/12/2012	8/29/2011	-196	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208338	Routine	Scheduled Maint. (PM)	3/13/2012	8/30/2011	-196	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208912	Routine	Scheduled Maint. (PM)	3/12/2012	8/28/2011	-197	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208313	Low	Scheduled Maint. (PM)	3/13/2012	8/29/2011	-197	PM - Domestic Water Heater, Electric
FO-209025	Low	Scheduled Maint. (PM)	3/13/2012	8/29/2011	-197	PM - Domestic Water Heater, Electric
FO-209026	Low	Scheduled Maint. (PM)	3/13/2012	8/29/2011	-197	PM - Domestic Water Heater, Electric
FO-209023	Routine	Scheduled Maint. (PM)	3/13/2012	8/23/2011	-203	Boiler - Open Clean and Close 48 inch Boilers
FO-208902	Routine	Scheduled Maint. (PM)	3/12/2012	8/16/2011	-209	PM - Water Softener
FO-209038	Routine	Scheduled Maint. (PM)	3/13/2012	8/15/2011	-211	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208906	Routine	Scheduled Maint. (PM)	3/12/2012	8/7/2011	-218	-> Consolidated PM items:Semi-annual task: W-S-AHU - PM - Semi Anunal Air Handling Unit InspectionMonthly tas
FO-208337	Routine	Scheduled Maint. (PM)	3/13/2012	8/7/2011	-219	Inspection of Air Handling Unit
FO-208910	Routine	Scheduled Maint. (PM)	3/12/2012	7/31/2011	-225	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208911	Routine	Scheduled Maint. (PM)	3/12/2012	7/31/2011	-225	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208913	Routine	Scheduled Maint. (PM)	3/12/2012	7/31/2011	-225	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-184580	Routine	Scheduled Maint. (PM)	1/19/2012	5/30/2011	-234	PM - Vacuum Pump
FO-184581	Routine	Scheduled Maint. (PM)	1/19/2012	5/30/2011	-234	PM - Vacuum Pump
FO-184578	Routine	Scheduled Maint. (PM)	1/19/2012	5/29/2011	-235	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209287	Routine	Scheduled Maint. (PM)	3/9/2012	7/18/2011	-235	PM - Water Softener
FO-208907	Routine	Scheduled Maint. (PM)	3/12/2012	7/18/2011	-238	PM - Air Dryer
FO-208908	Routine	Scheduled Maint. (PM)	3/12/2012	7/18/2011	-238	PM - Air Dryer
FO-208909	Routine	Scheduled Maint. (PM)	3/12/2012	7/18/2011	-238	PM - Air Dryer
FO-179299	Routine	Scheduled Maint. (PM)	1/19/2012	5/14/2011	-250	PM - Centrifugal Pump, over 1 H.P.
FO-179300	Routine	Scheduled Maint. (PM)	1/19/2012	5/14/2011	-250	PM - Centrifugal Pump, over 1 H.P.
FO-179302	Routine	Scheduled Maint. (PM)	1/19/2012	5/14/2011	-250	PM - Centrifugal Pump, over 1 H.P.
FO-179303	Routine	Scheduled Maint. (PM)	1/19/2012	5/14/2011	-250	PM - Centrifugal Pump, over 1 H.P.
FO-181010	Routine	Scheduled Maint. (PM)	1/19/2012	5/5/2011	-259	PM - Boiler, Steam Boiler, 500-1000 MBH
FO-179301	Routine	Scheduled Maint. (PM)	1/19/2012	4/29/2011	-265	PM - Cooling Tower, 500 - 1000 Tons
FO-176730	Routine	Scheduled Maint. (PM)	1/19/2012	3/2/2011	-323	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-176733	Routine	Scheduled Maint. (PM)	1/19/2012	3/2/2011	-323	PM - Vacuum Pump
FO-176734	Routine	Scheduled Maint. (PM)	1/19/2012	3/2/2011	-323	PM - Vacuum Pump
FO-176729	Routine	Scheduled Maint. (PM)	1/19/2012	3/1/2011	-324	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-176186	Routine	Scheduled Maint. (PM)	1/19/2012	2/16/2011	-337	PM - Water Softener
FO-183576	Routine	Scheduled Maint. (PM)	4/19/2012	5/15/2011	-340	Boiler - Open Clean and Close 60 inch Boilers
FO-173823	Routine	Scheduled Maint. (PM)	1/19/2012	1/26/2011	-358	PM - Centrifugal Pump, over 1 H.P.
FO-173824	Routine	Scheduled Maint. (PM)	1/19/2012	1/26/2011	-358	PM - Centrifugal Pump, over 1 H.P.
FO-173865	Routine	Scheduled Maint. (PM)	1/19/2012	1/26/2011	-358	PM - Centrifugal Pump, over 1 H.P.
FO-167746	Routine	Scheduled Maint. (PM)	1/19/2012	12/14/2010	-401	PM - Cooling Tower, 500 - 1000 Tons
FO-170573	Routine	Scheduled Maint. (PM)	1/19/2012	11/30/2010	-415	PM - Vacuum Pump
E - Area 2 Engineer					1156 of 1608	72%
FO-224734	Routine	Scheduled Maint. (PM)	3/15/2012	8/25/2012	163	PM - Fan Coil/HV/AC Unit
FO-224733	Routine	Scheduled Maint. (PM)	3/16/2012	8/25/2012	162	PM - Fan Coil/HV/AC Unit
FO-224736	Routine	Scheduled Maint. (PM)	3/16/2012	8/23/2012	160	PM - Fan Coil/HV/AC Unit
FO-224735	Routine	Scheduled Maint. (PM)	3/16/2012	8/23/2012	160	PM - Fan Coil/HV/AC Unit

Finish Date Due Date**Total per Trade**

FO-224728	Routine	Scheduled Maint. (PM)	3/15/2012	8/7/2012	145	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224729	Routine	Scheduled Maint. (PM)	3/19/2012	8/7/2012	141	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224738	Routine	Scheduled Maint. (PM)	3/20/2012	8/7/2012	140	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224739	Routine	Scheduled Maint. (PM)	3/20/2012	8/7/2012	140	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-224740	Routine	Scheduled Maint. (PM)	3/21/2012	8/7/2012	139	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221942	Routine	Scheduled Maint. (PM)	6/7/2012	8/29/2012	83	PM - Centrifugal Pump, over 1 H.P.
FO-221943	Routine	Scheduled Maint. (PM)	6/7/2012	8/29/2012	83	PM - Centrifugal Pump, over 1 H.P.
FO-221944	Routine	Scheduled Maint. (PM)	6/7/2012	8/29/2012	83	PM - Centrifugal Pump, over 1 H.P.
FO-221945	Routine	Scheduled Maint. (PM)	6/7/2012	8/29/2012	83	PM - Centrifugal Pump, over 1 H.P.
FO-228773	Low	Scheduled Maint. (PM)	8/13/2012	10/31/2012	79	PM - Centrifugal Pump, over 1 H.P.
FO-228774	Low	Scheduled Maint. (PM)	8/13/2012	10/31/2012	79	PM - Centrifugal Pump, over 1 H.P.
FO-234339	Routine	Scheduled Maint. (PM)	9/20/2012	12/5/2012	76	PM - Harmsco Side Stream Filter
FO-221949	Routine	Scheduled Maint. (PM)	6/15/2012	8/29/2012	75	PM - Centrifugal Pump, over 1 H.P.
FO-221950	Routine	Scheduled Maint. (PM)	6/15/2012	8/29/2012	75	PM - Centrifugal Pump, over 1 H.P.
FO-221951	Routine	Scheduled Maint. (PM)	6/15/2012	8/29/2012	75	PM - Centrifugal Pump, over 1 H.P.
FO-221952	Routine	Scheduled Maint. (PM)	6/15/2012	8/29/2012	75	PM - Centrifugal Pump, over 1 H.P.
FO-215363	Routine	Scheduled Maint. (PM)	3/22/2012	5/30/2012	69	PM - Chemical Feed/Metering Pump/Controller
FO-215364	Routine	Scheduled Maint. (PM)	3/22/2012	5/30/2012	69	PM - Chemical Feed/Metering Pump/Controller
FO-215365	Routine	Scheduled Maint. (PM)	3/22/2012	5/30/2012	69	PM - Chemical Feed/Metering Pump/Controller
FO-218359	Routine	Scheduled Maint. (PM)	5/23/2012	7/28/2012	66	PM - Centrifugal Pump, over 1 H.P.
FO-239162	Routine	Scheduled Maint. (PM)	1/16/2013	3/23/2013	66	PM - Centrifugal Pump, over 1 H.P.
FO-239163	Routine	Scheduled Maint. (PM)	1/16/2013	3/23/2013	66	PM - Centrifugal Pump, over 1 H.P.
FO-218358	Routine	Scheduled Maint. (PM)	5/24/2012	7/28/2012	65	PM - Centrifugal Pump, over 1 H.P.
FO-208262	Routine	Scheduled Maint. (PM)	1/24/2012	3/24/2012	60	PM - Water Booster Pump
FO-208263	Routine	Scheduled Maint. (PM)	1/24/2012	3/24/2012	60	PM - Water Booster Pump
FO-211523	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-211474	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-211291	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-211292	Routine	Scheduled Maint. (PM)	3/15/2012	5/14/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-212825	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212826	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212827	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212828	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212829	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212830	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212831	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212832	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212835	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212837	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212838	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212839	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-212872	Routine	Scheduled Maint. (PM)	4/1/2012	5/31/2012	60	PM - Water/Air Cooled Condenser
FO-217533	Routine	Scheduled Maint. (PM)	5/16/2012	7/15/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-217534	Routine	Scheduled Maint. (PM)	5/16/2012	7/15/2012	60	PM - Centrifugal Pump, over 1 H.P.

Finish Date Due Date**Total per Trade**

FO-217535	Routine	Scheduled Maint. (PM)	5/16/2012	7/15/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-228713	Routine	Scheduled Maint. (PM)	10/1/2012	11/30/2012	60	PM - Centrifugal Pump, over 1 H.P.
FO-219039	Routine	Scheduled Maint. (PM)	6/7/2012	8/5/2012	59	PM - Centrifugal Pump, over 1 H.P.
FO-219040	Routine	Scheduled Maint. (PM)	6/7/2012	8/5/2012	59	PM - Centrifugal Pump, over 1 H.P.
FO-219041	Routine	Scheduled Maint. (PM)	6/7/2012	8/5/2012	59	PM - Centrifugal Pump, over 1 H.P.
FO-228715	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.
FO-228716	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.
FO-228736	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.
FO-228737	Routine	Scheduled Maint. (PM)	10/3/2012	11/30/2012	58	PM - Centrifugal Pump, over 1 H.P.
FO-211447	Routine	Scheduled Maint. (PM)	3/19/2012	5/14/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-211533	Routine	Scheduled Maint. (PM)	3/19/2012	5/14/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-211297	Routine	Scheduled Maint. (PM)	3/19/2012	5/14/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-211293	Routine	Scheduled Maint. (PM)	3/19/2012	5/14/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-211294	Routine	Scheduled Maint. (PM)	3/19/2012	5/14/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-228689	Routine	Scheduled Maint. (PM)	10/5/2012	11/30/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-228690	Routine	Scheduled Maint. (PM)	10/5/2012	11/30/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-228714	Routine	Scheduled Maint. (PM)	10/5/2012	11/30/2012	56	PM - Centrifugal Pump, over 1 H.P.
FO-211295	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-211296	Routine	Scheduled Maint. (PM)	3/20/2012	5/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-219707	Routine	Scheduled Maint. (PM)	6/20/2012	8/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-219708	Routine	Scheduled Maint. (PM)	6/20/2012	8/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-219709	Routine	Scheduled Maint. (PM)	6/20/2012	8/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-219710	Routine	Scheduled Maint. (PM)	6/20/2012	8/14/2012	55	PM - Centrifugal Pump, over 1 H.P.
FO-213589	Routine	Scheduled Maint. (PM)	3/10/2012	5/3/2012	54	PM - Heat Pumps (5057 Woodward)
FO-213590	Routine	Scheduled Maint. (PM)	3/10/2012	5/3/2012	54	PM - Heat Pumps (5057 Woodward)
FO-211451	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211452	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211455	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211453	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211459	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211457	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211456	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211535	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211534	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211509	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-211510	Routine	Scheduled Maint. (PM)	3/21/2012	5/14/2012	54	PM - Centrifugal Pump, over 1 H.P.
FO-219490	Routine	Scheduled Maint. (PM)	6/12/2012	8/5/2012	54	PM - Water Booster Pump
FO-219491	Routine	Scheduled Maint. (PM)	6/12/2012	8/5/2012	54	PM - Water Booster Pump
FO-215362	Low	Scheduled Maint. (PM)	3/23/2012	5/16/2012	54	PM - Cooling Tower Start-up
FO-234338	Routine	Scheduled Maint. (PM)	10/12/2012	12/5/2012	54	PM - Harmsco Side Stream Filter
FO-211496	Routine	Scheduled Maint. (PM)	3/22/2012	5/14/2012	53	PM - Centrifugal Pump, over 1 H.P.
FO-211501	Routine	Scheduled Maint. (PM)	3/22/2012	5/14/2012	53	PM - Centrifugal Pump, over 1 H.P.
FO-211505	Routine	Scheduled Maint. (PM)	3/22/2012	5/14/2012	53	PM - Centrifugal Pump, over 1 H.P.
FO-228717	Routine	Scheduled Maint. (PM)	10/8/2012	11/30/2012	53	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date			Total per Trade
FO-228718	Routine	Scheduled Maint. (PM)	10/8/2012	11/30/2012	53	PM - Centrifugal Pump, over 1 H.P.	
FO-211454	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-211460	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-211497	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-211499	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-211500	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-211504	Routine	Scheduled Maint. (PM)	3/23/2012	5/14/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-219059	Routine	Scheduled Maint. (PM)	6/14/2012	8/5/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-219060	Routine	Scheduled Maint. (PM)	6/14/2012	8/5/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228697	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228719	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228720	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228722	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228723	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228724	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228725	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228726	Routine	Scheduled Maint. (PM)	10/9/2012	11/30/2012	52	PM - Centrifugal Pump, over 1 H.P.	
FO-228700	Routine	Scheduled Maint. (PM)	10/10/2012	11/30/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228701	Routine	Scheduled Maint. (PM)	10/10/2012	11/30/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228702	Routine	Scheduled Maint. (PM)	10/10/2012	11/30/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228721	Routine	Scheduled Maint. (PM)	10/10/2012	11/30/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228735	Routine	Scheduled Maint. (PM)	10/10/2012	11/30/2012	51	PM - Centrifugal Pump, over 1 H.P.	
FO-228691	Routine	Scheduled Maint. (PM)	10/11/2012	11/30/2012	50	PM - Centrifugal Pump, over 1 H.P.	
FO-228698	Routine	Scheduled Maint. (PM)	10/11/2012	11/30/2012	50	PM - Centrifugal Pump, over 1 H.P.	
FO-228763	Routine	Scheduled Maint. (PM)	10/11/2012	11/30/2012	50	PM - Centrifugal Pump, over 1 H.P.	
FO-227256	Routine	Scheduled Maint. (PM)	9/27/2012	11/14/2012	48	PM - Water/Air Cooled Condenser	
FO-227257	Routine	Scheduled Maint. (PM)	9/27/2012	11/14/2012	48	PM - Water/Air Cooled Condenser	
FO-227258	Routine	Scheduled Maint. (PM)	9/27/2012	11/14/2012	48	PM - Water/Air Cooled Condenser	
FO-228679	Routine	Scheduled Maint. (PM)	10/13/2012	11/30/2012	48	PM - Centrifugal Pump, over 1 H.P.	
FO-211527	Routine	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Cooling Tower, 500 - 1000 Tons	
FO-211526	Routine	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Cooling Tower, 500 - 1000 Tons	
FO-211436	Low	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Water/Air Cooled Condenser	
FO-211437	Low	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Water/Air Cooled Condenser	
FO-211438	Low	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Water/Air Cooled Condenser	
FO-211462	Low	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Punch Tubes - Chiller/Absorber	
FO-211465	Low	Scheduled Maint. (PM)	3/15/2012	4/29/2012	45	PM - Cooling Tower, 500 - 1000 Tons	
FO-233562	Routine	Scheduled Maint. (PM)	11/15/2012	12/30/2012	45	PM - Punch Tubes - Chiller/Absorber	
FO-211476	Routine	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Cooling Tower, 500 - 1000 Tons	
FO-220198	Routine	Scheduled Maint. (PM)	6/4/2012	7/18/2012	44	PM - Emergency Shower/Eyewash Station - Annual Flow Test	
FO-217514	Low	Scheduled Maint. (PM)	5/1/2012	6/14/2012	44	PM - Steam to Air Handling Unit - Close for Spring (Old Main)	
FO-217515	Low	Scheduled Maint. (PM)	5/1/2012	6/14/2012	44	PM - Steam to Air Handling Unit - Close for Spring (Old Main)	
FO-228681	Routine	Scheduled Maint. (PM)	10/17/2012	11/30/2012	44	PM - Centrifugal Pump, over 1 H.P.	
FO-215360	Routine	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller	
FO-215361	Routine	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller	

Finish Date Due Date**Total per Trade**

FO-215366	Routine	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller
FO-215367	Routine	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller
FO-215596	Routine	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller
FO-215359	Low	Scheduled Maint. (PM)	4/17/2012	5/30/2012	43	PM - Chemical Feed/Metering Pump/Controller
FO-228682	Routine	Scheduled Maint. (PM)	10/18/2012	11/30/2012	43	PM - Centrifugal Pump, over 1 H.P.
FO-228683	Routine	Scheduled Maint. (PM)	10/18/2012	11/30/2012	43	PM - Centrifugal Pump, over 1 H.P.
FO-228680	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.
FO-228727	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.
FO-228728	Routine	Scheduled Maint. (PM)	10/19/2012	11/30/2012	42	PM - Centrifugal Pump, over 1 H.P.
FO-211458	Routine	Scheduled Maint. (PM)	3/19/2012	4/29/2012	41	PM - Cooling Tower, 500 - 1000 Tons
FO-225592	Low	Scheduled Maint. (PM)	7/25/2012	9/4/2012	41	PM - Harmsco Side Stream Filter
FO-232897	Low	Scheduled Maint. (PM)	10/23/2012	12/3/2012	41	PM - Condensate Return Pump
FO-232898	Low	Scheduled Maint. (PM)	10/23/2012	12/3/2012	41	PM - Condensate Return Pump
FO-211537	Routine	Scheduled Maint. (PM)	3/15/2012	4/24/2012	40	PM - Water/Air Cooled Condenser
FO-211298	Routine	Scheduled Maint. (PM)	4/4/2012	5/14/2012	40	PM - Centrifugal Pump, over 1 H.P.
FO-211448	Routine	Scheduled Maint. (PM)	3/21/2012	4/29/2012	39	PM - Cooling Tower, 500 - 1000 Tons
FO-211506	Routine	Scheduled Maint. (PM)	3/21/2012	4/29/2012	39	PM - Centrifugal Pump, over 1 H.P.
FO-211507	Routine	Scheduled Maint. (PM)	3/21/2012	4/29/2012	39	PM - Centrifugal Pump, over 1 H.P.
FO-211508	Routine	Scheduled Maint. (PM)	3/21/2012	4/29/2012	39	PM - Cooling Tower, 500 - 1000 Tons
FO-211299	Routine	Scheduled Maint. (PM)	4/5/2012	5/14/2012	39	PM - Centrifugal Pump, over 1 H.P.
FO-212836	Routine	Scheduled Maint. (PM)	4/22/2012	5/31/2012	39	PM - Water/Air Cooled Condenser
FO-217519	Routine	Scheduled Maint. (PM)	6/5/2012	7/14/2012	39	PM - Water/Air Cooled Condenser
FO-217520	Routine	Scheduled Maint. (PM)	6/5/2012	7/14/2012	39	PM - Water/Air Cooled Condenser
FO-217521	Routine	Scheduled Maint. (PM)	6/5/2012	7/14/2012	39	PM - Water/Air Cooled Condenser
FO-221939	Routine	Scheduled Maint. (PM)	6/20/2012	7/29/2012	39	PM - Centrifugal Pump, over 1 H.P.
FO-224979	Routine	Scheduled Maint. (PM)	7/30/2012	9/7/2012	39	PM - Sump Pump
FO-224980	Routine	Scheduled Maint. (PM)	7/30/2012	9/7/2012	39	PM - Sump Pump
FO-211502	Routine	Scheduled Maint. (PM)	3/22/2012	4/29/2012	38	PM - Cooling Tower, 500 - 1000 Tons
FO-212821	Routine	Scheduled Maint. (PM)	4/9/2012	5/17/2012	38	PM - Cooling Tower, 500 - 1000 Tons
FO-217522	Routine	Scheduled Maint. (PM)	6/6/2012	7/14/2012	38	PM - Water/Air Cooled Condenser
FO-217523	Routine	Scheduled Maint. (PM)	6/6/2012	7/14/2012	38	PM - Water/Air Cooled Condenser
FO-217524	Routine	Scheduled Maint. (PM)	6/6/2012	7/14/2012	38	PM - Water/Air Cooled Condenser
FO-211498	Routine	Scheduled Maint. (PM)	3/23/2012	4/29/2012	37	PM - Cooling Tower, 500 - 1000 Tons
FO-212822	Routine	Scheduled Maint. (PM)	4/10/2012	5/17/2012	37	PM - Cooling Tower, 500 - 1000 Tons
FO-233550	Routine	Scheduled Maint. (PM)	11/23/2012	12/30/2012	37	PM - Punch Tubes - Chiller/Absorber
FO-212823	Routine	Scheduled Maint. (PM)	4/11/2012	5/17/2012	36	PM - Cooling Tower, 500 - 1000 Tons
FO-212824	Routine	Scheduled Maint. (PM)	4/11/2012	5/17/2012	36	PM - Cooling Tower, 500 - 1000 Tons
FO-230342	Routine	Scheduled Maint. (PM)	10/11/2012	11/16/2012	36	PM - Heat Pumps (5057 Woodward)
FO-230388	Routine	Scheduled Maint. (PM)	11/8/2012	12/14/2012	36	PM - Cooling Tower, 500 - 1000 Tons
FO-234342	Routine	Scheduled Maint. (PM)	10/30/2012	12/5/2012	36	PM - Harmsco Side Stream Filter
FO-209416	Low	Scheduled Maint. (PM)	1/18/2012	2/22/2012	35	PM - Fire Pump, Main/Jockey
FO-209417	Low	Scheduled Maint. (PM)	1/18/2012	2/22/2012	35	PM - Fire Pump, Main/Jockey
FO-230343	Routine	Scheduled Maint. (PM)	10/12/2012	11/16/2012	35	PM - Heat Pumps (5057 Woodward)
FO-230344	Routine	Scheduled Maint. (PM)	10/12/2012	11/16/2012	35	PM - Heat Pumps (5057 Woodward)

			Finish Date	Due Date			Total per Trade
FO-235052	Routine	Scheduled Maint. (PM)	11/7/2012	12/12/2012	35	PM - Chilled Water Coils - Drain (Old Main)	
FO-217525	Low	Scheduled Maint. (PM)	5/1/2012	6/4/2012	34	PM - Harmsco Side Stream Filter	
FO-217526	Low	Scheduled Maint. (PM)	5/1/2012	6/4/2012	34	PM - Harmsco Side Stream Filter	
FO-220196	Low	Scheduled Maint. (PM)	6/7/2012	7/11/2012	34	PM - Water Booster Pump	
FO-220197	Low	Scheduled Maint. (PM)	6/7/2012	7/11/2012	34	PM - Water Booster Pump	
FO-228801	Low	Scheduled Maint. (PM)	9/18/2012	10/22/2012	34	PM - Humidifier	
FO-235049	Routine	Scheduled Maint. (PM)	11/8/2012	12/12/2012	34	PM - Chilled Water Coils - Drain (Old Main)	
FO-230345	Routine	Scheduled Maint. (PM)	10/15/2012	11/16/2012	32	PM - Heat Pumps (5057 Woodward)	
FO-230346	Routine	Scheduled Maint. (PM)	10/15/2012	11/16/2012	32	PM - Heat Pumps (5057 Woodward)	
FO-211521	Routine	Scheduled Maint. (PM)	4/13/2012	5/14/2012	31	PM - Centrifugal Pump, over 1 H.P.	
FO-211522	Routine	Scheduled Maint. (PM)	4/13/2012	5/14/2012	31	PM - Centrifugal Pump, over 1 H.P.	
FO-228699	Routine	Scheduled Maint. (PM)	10/30/2012	11/30/2012	31	PM - Centrifugal Pump, over 1 H.P.	
FO-230347	Routine	Scheduled Maint. (PM)	10/16/2012	11/16/2012	31	PM - Heat Pumps (5057 Woodward)	
FO-208943	Routine	Scheduled Maint. (PM)	1/2/2012	2/1/2012	30	-> Consolidated PM items:Annual task: W990008 - PM - HumidifierAnnual task: W990008 - PM - Humidifier<-	
FO-208944	Routine	Scheduled Maint. (PM)	1/2/2012	2/1/2012	30	PM - Humidifier	
FO-208945	Routine	Scheduled Maint. (PM)	1/2/2012	2/1/2012	30	PM - Humidifier	
FO-208941	Routine	Scheduled Maint. (PM)	1/2/2012	2/1/2012	30	-> Consolidated PM items:Annual task: W990008 - PM - HumidifierAnnual task: W990008 - PM - Humidifier<-	
FO-208942	Routine	Scheduled Maint. (PM)	1/2/2012	2/1/2012	30	-> Consolidated PM items:Annual task: W990008 - PM - HumidifierAnnual task: W990008 - PM - Humidifier<-	
FO-209506	Routine	Scheduled Maint. (PM)	1/5/2012	2/4/2012	30	-> Consolidated PM items:Semi-annual task: AD0001 - Air Dryer - Operational InspectionSemi-annual task: AD0015	
FO-209508	Routine	Scheduled Maint. (PM)	1/15/2012	2/14/2012	30	PM - Heat Exchanger and Economizer	
FO-209338	Routine	Scheduled Maint. (PM)	2/1/2012	3/2/2012	30	PM - Air Intake Dampers (Old Main)	
FO-209339	Routine	Scheduled Maint. (PM)	2/1/2012	3/2/2012	30	PM - Air Intake Dampers (Old Main)	
FO-209340	Routine	Scheduled Maint. (PM)	2/1/2012	3/2/2012	30	PM - Air Intake Dampers (Old Main)	
FO-209347	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209348	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209349	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209350	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209351	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209352	Routine	Scheduled Maint. (PM)	2/14/2012	3/15/2012	30	PM - Sump Pump	
FO-209412	Routine	Scheduled Maint. (PM)	2/28/2012	3/29/2012	30	PM - Vacuum Pump	
FO-210584	Routine	Scheduled Maint. (PM)	3/7/2012	4/6/2012	30	PM - Sump Pump	
FO-210585	Routine	Scheduled Maint. (PM)	3/7/2012	4/6/2012	30	PM - Sump Pump	
FO-211270	Routine	Scheduled Maint. (PM)	3/12/2012	4/11/2012	30	PM - Fire Pump, Main/Jockey	
FO-211511	Routine	Scheduled Maint. (PM)	3/14/2012	4/13/2012	30	PM - Sump Pump	
FO-212073	Routine	Scheduled Maint. (PM)	3/19/2012	4/18/2012	30	PM - Condensate Return System **Needs Task Sheet**	
FO-212072	Routine	Scheduled Maint. (PM)	3/19/2012	4/18/2012	30	PM - Condensate Return System **Needs Task Sheet**	
FO-213456	Routine	Scheduled Maint. (PM)	3/27/2012	4/26/2012	30	PM - Sump Pump	
FO-213455	Routine	Scheduled Maint. (PM)	3/27/2012	4/26/2012	30	PM - Sump Pump	
FO-213582	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-213583	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-213584	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-213585	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-213599	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Forced Air Furnace (Jacob House) - Summer	
FO-213600	Routine	Scheduled Maint. (PM)	4/3/2012	5/3/2012	30	PM - Forced Air Furnace (Jacob House) - Summer	

			Finish Date	Due Date			Total per Trade
FO-214054	Routine	Scheduled Maint. (PM)	4/11/2012	5/11/2012	30	PM - Sump Pump	
FO-214061	Routine	Scheduled Maint. (PM)	4/10/2012	5/10/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214734	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214735	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214736	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214737	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214738	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214739	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214740	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214741	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-214744	Routine	Scheduled Maint. (PM)	4/17/2012	5/17/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-215139	Routine	Scheduled Maint. (PM)	4/24/2012	5/24/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-215140	Routine	Scheduled Maint. (PM)	4/24/2012	5/24/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-215141	Routine	Scheduled Maint. (PM)	4/24/2012	5/24/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-216145	Routine	Scheduled Maint. (PM)	5/2/2012	6/1/2012	30	PM - Sump Pump	
FO-217556	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217557	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217558	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217559	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217560	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217561	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217571	Routine	Scheduled Maint. (PM)	5/7/2012	6/6/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217572	Routine	Scheduled Maint. (PM)	5/7/2012	6/6/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-217595	Routine	Scheduled Maint. (PM)	5/14/2012	6/13/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219048	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219049	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219050	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219051	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219052	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219053	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219054	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219055	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219056	Routine	Scheduled Maint. (PM)	6/5/2012	7/5/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219701	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219702	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219703	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219704	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219705	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-219706	Routine	Scheduled Maint. (PM)	6/12/2012	7/12/2012	30	PM - Heat Pumps (5057 Woodward)	
FO-215138	Low	Scheduled Maint. (PM)	4/24/2012	5/24/2012	30	PM - Roof Sumps - Zone 2, Area 3	
FO-215182	Low	Scheduled Maint. (PM)	4/24/2012	5/24/2012	30	PM - Roof Sumps - Zone 2, Area 3	
FO-217536	Low	Scheduled Maint. (PM)	5/23/2012	6/22/2012	30	PM - Fire Pump, Main/Jockey	
FO-217537	Low	Scheduled Maint. (PM)	5/23/2012	6/22/2012	30	PM - Fire Pump, Main/Jockey	
FO-219149	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date	Total per Trade	
FO-219150	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)
FO-219151	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)
FO-219152	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)
FO-219153	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)
FO-219154	Low	Scheduled Maint. (PM)	6/11/2012	7/11/2012	30	PM - Heat Pumps (5057 Woodward)
FO-219699	Low	Scheduled Maint. (PM)	6/15/2012	7/15/2012	30	PM - Outside/Fresh Air Intake Screens
FO-228742	Routine	Scheduled Maint. (PM)	10/1/2012	10/31/2012	30	PM - Centrifugal Pump, over 1 H.P.
FO-228743	Routine	Scheduled Maint. (PM)	10/1/2012	10/31/2012	30	PM - Centrifugal Pump, over 1 H.P.
FO-228777	Low	Scheduled Maint. (PM)	10/31/2012	11/30/2012	30	PM - Centrifugal Pump, over 1 H.P.
FO-229458	Routine	Scheduled Maint. (PM)	10/3/2012	11/2/2012	30	PM - Heat Pumps (5057 Woodward)
FO-229459	Routine	Scheduled Maint. (PM)	10/3/2012	11/2/2012	30	PM - Heat Pumps (5057 Woodward)
FO-230274	Routine	Scheduled Maint. (PM)	10/18/2012	11/17/2012	30	PM - Condensate Return Pump
FO-230275	Routine	Scheduled Maint. (PM)	10/18/2012	11/17/2012	30	PM - Condensate Return Pump
FO-230348	Routine	Scheduled Maint. (PM)	10/17/2012	11/16/2012	30	PM - Heat Pumps (5057 Woodward)
FO-230349	Routine	Scheduled Maint. (PM)	10/17/2012	11/16/2012	30	PM - Heat Pumps (5057 Woodward)
FO-230667	Routine	Scheduled Maint. (PM)	10/24/2012	11/23/2012	30	PM - Heat Pumps (5057 Woodward)
FO-230743	Low	Scheduled Maint. (PM)	10/24/2012	11/23/2012	30	PM - Roof Sumps - Zone 2, Area 3
FO-230765	Low	Scheduled Maint. (PM)	10/23/2012	11/22/2012	30	PM - Centrifugal Pump, over 1 H.P.
FO-235054	Routine	Scheduled Maint. (PM)	11/12/2012	12/12/2012	30	PM - Chilled Water Coils - Drain (Old Main)
FO-235055	Routine	Scheduled Maint. (PM)	11/12/2012	12/12/2012	30	PM - Chilled Water Coils - Drain (Old Main)
FO-236659	Routine	Scheduled Maint. (PM)	12/19/2012	1/18/2013	30	PM - Heat Pumps (5057 Woodward)
FO-236660	Routine	Scheduled Maint. (PM)	12/19/2012	1/18/2013	30	PM - Heat Pumps (5057 Woodward)
FO-236661	Routine	Scheduled Maint. (PM)	12/19/2012	1/18/2013	30	PM - Heat Pumps (5057 Woodward)
FO-236662	Routine	Scheduled Maint. (PM)	12/19/2012	1/18/2013	30	PM - Heat Pumps (5057 Woodward)
FO-210579	Routine	Scheduled Maint. (PM)	3/7/2012	4/5/2012	29	PM - Condensate Return System **Needs Task Sheet**
FO-210578	Routine	Scheduled Maint. (PM)	3/7/2012	4/5/2012	29	PM - Condensate Return System **Needs Task Sheet**
FO-213576	Routine	Scheduled Maint. (PM)	4/4/2012	5/3/2012	29	PM - Heat Pumps (5057 Woodward)
FO-213581	Routine	Scheduled Maint. (PM)	4/4/2012	5/3/2012	29	PM - Heat Pumps (5057 Woodward)
FO-213586	Routine	Scheduled Maint. (PM)	4/4/2012	5/3/2012	29	PM - Heat Pumps (5057 Woodward)
FO-213587	Routine	Scheduled Maint. (PM)	4/4/2012	5/3/2012	29	PM - Heat Pumps (5057 Woodward)
FO-213588	Routine	Scheduled Maint. (PM)	4/4/2012	5/3/2012	29	PM - Heat Pumps (5057 Woodward)
FO-214742	Routine	Scheduled Maint. (PM)	4/18/2012	5/17/2012	29	PM - Heat Pumps (5057 Woodward)
FO-214743	Routine	Scheduled Maint. (PM)	4/18/2012	5/17/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215142	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215143	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215206	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215207	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215208	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215209	Routine	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215597	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215598	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215599	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215600	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)
FO-215601	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)

			Finish Date	Due Date			Total per Trade
FO-215602	Routine	Scheduled Maint. (PM)	5/1/2012	5/30/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-216150	Routine	Scheduled Maint. (PM)	5/7/2012	6/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-216151	Routine	Scheduled Maint. (PM)	5/7/2012	6/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-216152	Routine	Scheduled Maint. (PM)	5/7/2012	6/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-216153	Routine	Scheduled Maint. (PM)	5/7/2012	6/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-216154	Routine	Scheduled Maint. (PM)	5/3/2012	6/1/2012	29	PM - Condensate Return Pump	
FO-217538	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217539	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217540	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217541	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217542	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217543	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217544	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217545	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217546	Routine	Scheduled Maint. (PM)	5/22/2012	6/20/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217562	Routine	Scheduled Maint. (PM)	5/15/2012	6/13/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217563	Routine	Scheduled Maint. (PM)	5/15/2012	6/13/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217564	Routine	Scheduled Maint. (PM)	5/15/2012	6/13/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217566	Routine	Scheduled Maint. (PM)	5/15/2012	6/13/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217567	Routine	Scheduled Maint. (PM)	5/15/2012	6/13/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217573	Routine	Scheduled Maint. (PM)	5/8/2012	6/6/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217574	Routine	Scheduled Maint. (PM)	5/8/2012	6/6/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217575	Routine	Scheduled Maint. (PM)	5/8/2012	6/6/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-217576	Routine	Scheduled Maint. (PM)	5/8/2012	6/6/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219038	Routine	Scheduled Maint. (PM)	6/7/2012	7/6/2012	29	PM - Centrifugal Pump, over 1 H.P.	
FO-219042	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219043	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219044	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219045	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219046	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-219047	Routine	Scheduled Maint. (PM)	6/6/2012	7/5/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-220194	Routine	Scheduled Maint. (PM)	6/21/2012	7/20/2012	29	PM - Condensate Return Pump	
FO-220200	Routine	Scheduled Maint. (PM)	6/20/2012	7/19/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-220201	Routine	Scheduled Maint. (PM)	6/20/2012	7/19/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-220202	Routine	Scheduled Maint. (PM)	6/20/2012	7/19/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-220215	Routine	Scheduled Maint. (PM)	6/21/2012	7/20/2012	29	PM - Condensate Return Pump	
FO-215616	Low	Scheduled Maint. (PM)	4/25/2012	5/24/2012	29	PM - Roof Sumps - Zone 2, Area 3	
FO-229460	Routine	Scheduled Maint. (PM)	10/4/2012	11/2/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-229461	Routine	Scheduled Maint. (PM)	10/4/2012	11/2/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230341	Routine	Scheduled Maint. (PM)	10/11/2012	11/9/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230350	Routine	Scheduled Maint. (PM)	10/18/2012	11/16/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230351	Routine	Scheduled Maint. (PM)	10/18/2012	11/16/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230352	Routine	Scheduled Maint. (PM)	10/18/2012	11/16/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230649	Routine	Scheduled Maint. (PM)	10/31/2012	11/29/2012	29	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-230650	Routine	Scheduled Maint. (PM)	10/31/2012	11/29/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230651	Routine	Scheduled Maint. (PM)	10/31/2012	11/29/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230652	Routine	Scheduled Maint. (PM)	10/31/2012	11/29/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230668	Routine	Scheduled Maint. (PM)	10/25/2012	11/23/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230669	Routine	Scheduled Maint. (PM)	10/25/2012	11/23/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230670	Routine	Scheduled Maint. (PM)	10/25/2012	11/23/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-230693	Routine	Scheduled Maint. (PM)	10/22/2012	11/20/2012	29	PM - Centrifugal Pump, over 1 H.P.	
FO-230700	Routine	Scheduled Maint. (PM)	10/22/2012	11/20/2012	29	PM - Centrifugal Pump, over 1 H.P.	
FO-230701	Routine	Scheduled Maint. (PM)	10/22/2012	11/20/2012	29	PM - Centrifugal Pump, over 1 H.P.	
FO-230748	Low	Scheduled Maint. (PM)	10/25/2012	11/23/2012	29	PM - Roof Sumps - Zone 2, Area 3	
FO-232842	Routine	Scheduled Maint. (PM)	11/8/2012	12/7/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-232843	Routine	Scheduled Maint. (PM)	11/8/2012	12/7/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-232844	Routine	Scheduled Maint. (PM)	11/8/2012	12/7/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-232845	Routine	Scheduled Maint. (PM)	11/8/2012	12/7/2012	29	PM - Heat Pumps (5057 Woodward)	
FO-235047	Routine	Scheduled Maint. (PM)	11/13/2012	12/12/2012	29	PM - Chilled Water Coils - Drain (Old Main)	
FO-235050	Routine	Scheduled Maint. (PM)	11/13/2012	12/12/2012	29	PM - Chilled Water Coils - Drain (Old Main)	
FO-236663	Routine	Scheduled Maint. (PM)	12/20/2012	1/18/2013	29	PM - Heat Pumps (5057 Woodward)	
FO-236664	Routine	Scheduled Maint. (PM)	12/20/2012	1/18/2013	29	PM - Heat Pumps (5057 Woodward)	
FO-236665	Routine	Scheduled Maint. (PM)	12/20/2012	1/18/2013	29	PM - Heat Pumps (5057 Woodward)	
FO-236666	Routine	Scheduled Maint. (PM)	12/20/2012	1/18/2013	29	PM - Heat Pumps (5057 Woodward)	
FO-214055	Routine	Scheduled Maint. (PM)	4/13/2012	5/11/2012	28	PM - Sump Pump	
FO-214056	Routine	Scheduled Maint. (PM)	4/13/2012	5/11/2012	28	PM - Sump Pump	
FO-214745	Routine	Scheduled Maint. (PM)	4/20/2012	5/18/2012	28	PM - Condensate Return Pump	
FO-214746	Routine	Scheduled Maint. (PM)	4/20/2012	5/18/2012	28	PM - Condensate Return Pump	
FO-215210	Routine	Scheduled Maint. (PM)	4/26/2012	5/24/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215211	Routine	Scheduled Maint. (PM)	4/26/2012	5/24/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215603	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215605	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215606	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215607	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215608	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215609	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-215610	Routine	Scheduled Maint. (PM)	5/2/2012	5/30/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217547	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217548	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217549	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217550	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217551	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217552	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217553	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217554	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217555	Routine	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217565	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217568	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-217569	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217570	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217577	Routine	Scheduled Maint. (PM)	5/9/2012	6/6/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217578	Routine	Scheduled Maint. (PM)	5/9/2012	6/6/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217579	Routine	Scheduled Maint. (PM)	5/9/2012	6/6/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217580	Routine	Scheduled Maint. (PM)	5/9/2012	6/6/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217594	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-217596	Routine	Scheduled Maint. (PM)	5/16/2012	6/13/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218041	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218042	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218043	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218044	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218045	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-218046	Routine	Scheduled Maint. (PM)	5/30/2012	6/27/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-220199	Routine	Scheduled Maint. (PM)	6/6/2012	7/4/2012	28	PM - Heat Exchanger and Economizer	
FO-220203	Routine	Scheduled Maint. (PM)	6/21/2012	7/19/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-220204	Routine	Scheduled Maint. (PM)	6/21/2012	7/19/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-220218	Routine	Scheduled Maint. (PM)	6/21/2012	7/19/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-221947	Routine	Scheduled Maint. (PM)	8/1/2012	8/29/2012	28	PM - Centrifugal Pump, over 1 H.P.	
FO-224632	Routine	Scheduled Maint. (PM)	7/26/2012	8/23/2012	28	PM - Sump Pump	
FO-215181	Low	Scheduled Maint. (PM)	4/26/2012	5/24/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-215185	Low	Scheduled Maint. (PM)	4/26/2012	5/24/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-215190	Low	Scheduled Maint. (PM)	4/26/2012	5/24/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-229462	Routine	Scheduled Maint. (PM)	10/5/2012	11/2/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230653	Routine	Scheduled Maint. (PM)	11/1/2012	11/29/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230654	Routine	Scheduled Maint. (PM)	11/1/2012	11/29/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230655	Routine	Scheduled Maint. (PM)	11/1/2012	11/29/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230656	Routine	Scheduled Maint. (PM)	11/1/2012	11/29/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230671	Routine	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230672	Routine	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230673	Routine	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-230692	Routine	Scheduled Maint. (PM)	10/23/2012	11/20/2012	28	PM - Centrifugal Pump, over 1 H.P.	
FO-230740	Low	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-230741	Low	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-230742	Low	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-230749	Low	Scheduled Maint. (PM)	10/26/2012	11/23/2012	28	PM - Roof Sumps - Zone 2, Area 3	
FO-230751	Routine	Scheduled Maint. (PM)	10/23/2012	11/20/2012	28	PM - Centrifugal Pump, over 1 H.P.	
FO-232846	Routine	Scheduled Maint. (PM)	11/9/2012	12/7/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-232847	Routine	Scheduled Maint. (PM)	11/9/2012	12/7/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-232848	Routine	Scheduled Maint. (PM)	11/9/2012	12/7/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-233588	Routine	Scheduled Maint. (PM)	11/16/2012	12/14/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-233589	Routine	Scheduled Maint. (PM)	11/16/2012	12/14/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-234314	Routine	Scheduled Maint. (PM)	11/23/2012	12/21/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-234315	Routine	Scheduled Maint. (PM)	11/23/2012	12/21/2012	28	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-234316	Routine	Scheduled Maint. (PM)	11/23/2012	12/21/2012	28	PM - Heat Pumps (5057 Woodward)	
FO-235376	Routine	Scheduled Maint. (PM)	12/7/2012	1/4/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-235377	Routine	Scheduled Maint. (PM)	12/7/2012	1/4/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236076	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236077	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236078	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236079	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236080	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236081	Routine	Scheduled Maint. (PM)	12/14/2012	1/11/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236667	Routine	Scheduled Maint. (PM)	12/21/2012	1/18/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236668	Routine	Scheduled Maint. (PM)	12/21/2012	1/18/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236669	Routine	Scheduled Maint. (PM)	12/21/2012	1/18/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-236670	Routine	Scheduled Maint. (PM)	12/21/2012	1/18/2013	28	PM - Heat Pumps (5057 Woodward)	
FO-215604	Routine	Scheduled Maint. (PM)	5/3/2012	5/30/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-215611	Routine	Scheduled Maint. (PM)	5/3/2012	5/30/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-215612	Routine	Scheduled Maint. (PM)	5/3/2012	5/30/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-215613	Routine	Scheduled Maint. (PM)	5/3/2012	5/30/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-215614	Routine	Scheduled Maint. (PM)	5/3/2012	5/30/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-217597	Routine	Scheduled Maint. (PM)	5/10/2012	6/6/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-217598	Routine	Scheduled Maint. (PM)	5/10/2012	6/6/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-217599	Routine	Scheduled Maint. (PM)	5/10/2012	6/6/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-217600	Routine	Scheduled Maint. (PM)	5/10/2012	6/6/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218047	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218048	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218049	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218050	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218051	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218052	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-218053	Routine	Scheduled Maint. (PM)	5/31/2012	6/27/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-220219	Routine	Scheduled Maint. (PM)	6/22/2012	7/19/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-220220	Routine	Scheduled Maint. (PM)	6/22/2012	7/19/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-208540	Low	Scheduled Maint. (PM)	2/8/2012	3/6/2012	27	PM - Harmsco Side Stream Filter	
FO-208541	Medium	Scheduled Maint. (PM)	2/8/2012	3/6/2012	27	PM - Harmsco Side Stream Filter	
FO-215188	Low	Scheduled Maint. (PM)	4/27/2012	5/24/2012	27	PM - Roof Sumps - Zone 2, Area 3	
FO-215189	Low	Scheduled Maint. (PM)	4/27/2012	5/24/2012	27	PM - Roof Sumps - Zone 2, Area 3	
FO-220195	Low	Scheduled Maint. (PM)	6/7/2012	7/4/2012	27	PM - Domestic Water Heater, Steam	
FO-230316	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Centrifugal Pump, over 1 H.P.	
FO-230317	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Centrifugal Pump, over 1 H.P.	
FO-230657	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-230658	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-230659	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-230660	Routine	Scheduled Maint. (PM)	11/2/2012	11/29/2012	27	PM - Heat Pumps (5057 Woodward)	
FO-217601	Routine	Scheduled Maint. (PM)	5/11/2012	6/6/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-217602	Routine	Scheduled Maint. (PM)	5/11/2012	6/6/2012	26	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-217603	Routine	Scheduled Maint. (PM)	5/11/2012	6/6/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-217604	Routine	Scheduled Maint. (PM)	5/11/2012	6/6/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-218054	Routine	Scheduled Maint. (PM)	6/1/2012	6/27/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-218055	Routine	Scheduled Maint. (PM)	6/1/2012	6/27/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-218056	Routine	Scheduled Maint. (PM)	6/1/2012	6/27/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-218057	Routine	Scheduled Maint. (PM)	6/1/2012	6/27/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-218058	Routine	Scheduled Maint. (PM)	6/1/2012	6/27/2012	26	PM - Heat Pumps (5057 Woodward)	
FO-225593	Medium	Scheduled Maint. (PM)	8/9/2012	9/4/2012	26	PM - Harmsco Side Stream Filter	
FO-228739	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	PM - Centrifugal Pump, over 1 H.P.	
FO-228740	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	PM - Centrifugal Pump, over 1 H.P.	
FO-228746	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	PM - Centrifugal Pump, over 1 H.P.	
FO-228758	Routine	Scheduled Maint. (PM)	10/5/2012	10/31/2012	26	PM - Centrifugal Pump, over 1 H.P.	
FO-233606	Routine	Scheduled Maint. (PM)	12/4/2012	12/30/2012	26	PM - Punch Tubes - Chiller/Absorber	
FO-215202	Routine	Scheduled Maint. (PM)	4/30/2012	5/25/2012	25	PM - Sump Pump	
FO-215203	Routine	Scheduled Maint. (PM)	4/30/2012	5/25/2012	25	PM - Sump Pump	
FO-222480	Routine	Scheduled Maint. (PM)	7/23/2012	8/17/2012	25	PM - Unspecified	
FO-222481	Routine	Scheduled Maint. (PM)	7/23/2012	8/17/2012	25	PM - Unspecified	
FO-217530	Low	Scheduled Maint. (PM)	5/4/2012	5/29/2012	25	PM - Water Booster Pump	
FO-217531	Low	Scheduled Maint. (PM)	5/4/2012	5/29/2012	25	PM - Water Booster Pump	
FO-227170	Routine	Scheduled Maint. (PM)	10/2/2012	10/27/2012	25	PM - Sump Pump	
FO-229463	Routine	Scheduled Maint. (PM)	10/8/2012	11/2/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-229464	Routine	Scheduled Maint. (PM)	10/8/2012	11/2/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-230674	Routine	Scheduled Maint. (PM)	10/29/2012	11/23/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-230675	Routine	Scheduled Maint. (PM)	10/29/2012	11/23/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-230694	Routine	Scheduled Maint. (PM)	10/26/2012	11/20/2012	25	PM - Centrifugal Pump, over 1 H.P.	
FO-230695	Routine	Scheduled Maint. (PM)	10/26/2012	11/20/2012	25	PM - Centrifugal Pump, over 1 H.P.	
FO-230698	Routine	Scheduled Maint. (PM)	10/26/2012	11/20/2012	25	PM - Centrifugal Pump, over 1 H.P.	
FO-230699	Routine	Scheduled Maint. (PM)	10/26/2012	11/20/2012	25	PM - Centrifugal Pump, over 1 H.P.	
FO-230734	Low	Scheduled Maint. (PM)	10/29/2012	11/23/2012	25	PM - Roof Sumps - Zone 2, Area 3	
FO-230735	Low	Scheduled Maint. (PM)	10/29/2012	11/23/2012	25	PM - Roof Sumps - Zone 2, Area 3	
FO-232849	Routine	Scheduled Maint. (PM)	11/12/2012	12/7/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-232850	Routine	Scheduled Maint. (PM)	11/12/2012	12/7/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-232851	Routine	Scheduled Maint. (PM)	11/12/2012	12/7/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-232852	Routine	Scheduled Maint. (PM)	11/12/2012	12/7/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-233549	Routine	Scheduled Maint. (PM)	12/5/2012	12/30/2012	25	PM - Punch Tubes - Chiller/Absorber	
FO-233590	Routine	Scheduled Maint. (PM)	11/19/2012	12/14/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-233591	Routine	Scheduled Maint. (PM)	11/19/2012	12/14/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-233592	Routine	Scheduled Maint. (PM)	11/19/2012	12/14/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-235023	Routine	Scheduled Maint. (PM)	12/3/2012	12/28/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-235024	Routine	Scheduled Maint. (PM)	12/3/2012	12/28/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-235025	Routine	Scheduled Maint. (PM)	12/3/2012	12/28/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-235026	Routine	Scheduled Maint. (PM)	12/3/2012	12/28/2012	25	PM - Heat Pumps (5057 Woodward)	
FO-235378	Routine	Scheduled Maint. (PM)	12/10/2012	1/4/2013	25	PM - Heat Pumps (5057 Woodward)	
FO-235379	Routine	Scheduled Maint. (PM)	12/10/2012	1/4/2013	25	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-235380	Routine	Scheduled Maint. (PM)	12/10/2012	1/4/2013	25	PM - Heat Pumps (5057 Woodward)	
FO-235381	Routine	Scheduled Maint. (PM)	12/10/2012	1/4/2013	25	PM - Heat Pumps (5057 Woodward)	
FO-238526	Routine	Scheduled Maint. (PM)	1/22/2013	2/16/2013	25	PM - Heat Pumps (5057 Woodward)	
FO-238539	Routine	Scheduled Maint. (PM)	1/22/2013	2/16/2013	25	PM - Heat Pumps (5057 Woodward)	
FO-209374	Routine	Scheduled Maint. (PM)	1/31/2012	2/24/2012	24	PM - Drinking Fountain and Water Cooler	
FO-220221	Routine	Scheduled Maint. (PM)	6/25/2012	7/19/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-220222	Routine	Scheduled Maint. (PM)	6/25/2012	7/19/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-220223	Routine	Scheduled Maint. (PM)	6/25/2012	7/19/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-220290	Routine	Scheduled Maint. (PM)	6/26/2012	7/20/2012	24	-> Consolidated PM items:	
FO-215186	Low	Scheduled Maint. (PM)	4/30/2012	5/24/2012	24	PM - Roof Sumps - Zone 2, Area 3	
FO-215187	Low	Scheduled Maint. (PM)	4/30/2012	5/24/2012	24	PM - Roof Sumps - Zone 2, Area 3	
FO-215371	Low	Scheduled Maint. (PM)	4/30/2012	5/24/2012	24	PM - Roof Sumps - Zone 2, Area 3	
FO-227277	Routine	Scheduled Maint. (PM)	9/25/2012	10/19/2012	24	PM - Condensate Return System **Needs Task Sheet**	
FO-227278	Routine	Scheduled Maint. (PM)	9/25/2012	10/19/2012	24	PM - Condensate Return System **Needs Task Sheet**	
FO-229465	Routine	Scheduled Maint. (PM)	10/9/2012	11/2/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-229466	Routine	Scheduled Maint. (PM)	10/9/2012	11/2/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-229467	Routine	Scheduled Maint. (PM)	10/9/2012	11/2/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-230318	Routine	Scheduled Maint. (PM)	11/5/2012	11/29/2012	24	PM - Centrifugal Pump, over 1 H.P.	
FO-230319	Routine	Scheduled Maint. (PM)	11/5/2012	11/29/2012	24	PM - Centrifugal Pump, over 1 H.P.	
FO-230661	Routine	Scheduled Maint. (PM)	11/5/2012	11/29/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-230676	Routine	Scheduled Maint. (PM)	10/30/2012	11/23/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-230677	Routine	Scheduled Maint. (PM)	10/30/2012	11/23/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-230744	Low	Scheduled Maint. (PM)	10/30/2012	11/23/2012	24	PM - Roof Sumps - Zone 2, Area 3	
FO-232853	Routine	Scheduled Maint. (PM)	11/13/2012	12/7/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-232854	Routine	Scheduled Maint. (PM)	11/13/2012	12/7/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-232855	Routine	Scheduled Maint. (PM)	11/13/2012	12/7/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-232856	Routine	Scheduled Maint. (PM)	11/13/2012	12/7/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-233593	Routine	Scheduled Maint. (PM)	11/20/2012	12/14/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-233594	Routine	Scheduled Maint. (PM)	11/20/2012	12/14/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-233595	Routine	Scheduled Maint. (PM)	11/20/2012	12/14/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-233596	Routine	Scheduled Maint. (PM)	11/20/2012	12/14/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-234317	Routine	Scheduled Maint. (PM)	11/27/2012	12/21/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-234318	Routine	Scheduled Maint. (PM)	11/27/2012	12/21/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-235027	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-235028	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-235029	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-235030	Routine	Scheduled Maint. (PM)	12/4/2012	12/28/2012	24	PM - Heat Pumps (5057 Woodward)	
FO-235382	Routine	Scheduled Maint. (PM)	12/11/2012	1/4/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-235383	Routine	Scheduled Maint. (PM)	12/11/2012	1/4/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-235384	Routine	Scheduled Maint. (PM)	12/11/2012	1/4/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-236093	Routine	Scheduled Maint. (PM)	12/17/2012	1/10/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-236094	Routine	Scheduled Maint. (PM)	12/17/2012	1/10/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-238527	Routine	Scheduled Maint. (PM)	1/23/2013	2/16/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-238528	Routine	Scheduled Maint. (PM)	1/23/2013	2/16/2013	24	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-238536	Routine	Scheduled Maint. (PM)	1/23/2013	2/16/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-238540	Routine	Scheduled Maint. (PM)	1/23/2013	2/16/2013	24	PM - Heat Pumps (5057 Woodward)	
FO-209557	Routine	Scheduled Maint. (PM)	2/13/2012	3/7/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-209558	Routine	Scheduled Maint. (PM)	2/13/2012	3/7/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-220224	Routine	Scheduled Maint. (PM)	6/26/2012	7/19/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-220225	Routine	Scheduled Maint. (PM)	6/26/2012	7/19/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-221282	Routine	Scheduled Maint. (PM)	6/18/2012	7/11/2012	23	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-221283	Routine	Scheduled Maint. (PM)	6/18/2012	7/11/2012	23	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-215198	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly	
FO-215199	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly	
FO-215200	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly	
FO-215201	Low	Scheduled Maint. (PM)	5/1/2012	5/24/2012	23	-> Consolidated PM items:Annual task: W990024 - PM - Steam Valves to PreHeat Coils - Close (Old Main)Quarterly	
FO-227284	Routine	Scheduled Maint. (PM)	9/19/2012	10/12/2012	23	PM - Fire Pump, Main/Jockey	
FO-228753	Routine	Scheduled Maint. (PM)	10/8/2012	10/31/2012	23	PM - Centrifugal Pump, over 1 H.P.	
FO-228754	Routine	Scheduled Maint. (PM)	10/8/2012	10/31/2012	23	PM - Centrifugal Pump, over 1 H.P.	
FO-228756	Routine	Scheduled Maint. (PM)	10/8/2012	10/31/2012	23	PM - Centrifugal Pump, over 1 H.P.	
FO-228759	Routine	Scheduled Maint. (PM)	10/8/2012	10/31/2012	23	PM - Centrifugal Pump, over 1 H.P.	
FO-230662	Routine	Scheduled Maint. (PM)	11/6/2012	11/29/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-230663	Routine	Scheduled Maint. (PM)	11/6/2012	11/29/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-230664	Routine	Scheduled Maint. (PM)	11/6/2012	11/29/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-230665	Routine	Scheduled Maint. (PM)	11/6/2012	11/29/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-230666	Routine	Scheduled Maint. (PM)	11/6/2012	11/29/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-230745	Low	Scheduled Maint. (PM)	10/31/2012	11/23/2012	23	PM - Roof Sumps - Zone 2, Area 3	
FO-230747	Low	Scheduled Maint. (PM)	10/31/2012	11/23/2012	23	PM - Roof Sumps - Zone 2, Area 3	
FO-232857	Routine	Scheduled Maint. (PM)	11/14/2012	12/7/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-232858	Routine	Scheduled Maint. (PM)	11/14/2012	12/7/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-233597	Routine	Scheduled Maint. (PM)	11/21/2012	12/14/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-233598	Routine	Scheduled Maint. (PM)	11/21/2012	12/14/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-233599	Routine	Scheduled Maint. (PM)	11/21/2012	12/14/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-233600	Routine	Scheduled Maint. (PM)	11/21/2012	12/14/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-234319	Routine	Scheduled Maint. (PM)	11/28/2012	12/21/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-234320	Routine	Scheduled Maint. (PM)	11/28/2012	12/21/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-234321	Routine	Scheduled Maint. (PM)	11/28/2012	12/21/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-234322	Routine	Scheduled Maint. (PM)	11/28/2012	12/21/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-235031	Routine	Scheduled Maint. (PM)	12/5/2012	12/28/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-235032	Routine	Scheduled Maint. (PM)	12/5/2012	12/28/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-235033	Routine	Scheduled Maint. (PM)	12/5/2012	12/28/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-235034	Routine	Scheduled Maint. (PM)	12/5/2012	12/28/2012	23	PM - Heat Pumps (5057 Woodward)	
FO-235385	Routine	Scheduled Maint. (PM)	12/12/2012	1/4/2013	23	PM - Heat Pumps (5057 Woodward)	
FO-235386	Routine	Scheduled Maint. (PM)	12/12/2012	1/4/2013	23	PM - Heat Pumps (5057 Woodward)	
FO-235387	Routine	Scheduled Maint. (PM)	12/12/2012	1/4/2013	23	PM - Heat Pumps (5057 Woodward)	
FO-209559	Routine	Scheduled Maint. (PM)	2/14/2012	3/7/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-209560	Routine	Scheduled Maint. (PM)	2/14/2012	3/7/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-220226	Routine	Scheduled Maint. (PM)	6/27/2012	7/19/2012	22	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-220227	Routine	Scheduled Maint. (PM)	6/27/2012	7/19/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-220228	Routine	Scheduled Maint. (PM)	6/27/2012	7/19/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-220229	Routine	Scheduled Maint. (PM)	6/27/2012	7/19/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-215183	Low	Scheduled Maint. (PM)	5/2/2012	5/24/2012	22	PM - Roof Sumps - Zone 2, Area 3	
FO-217518	Low	Scheduled Maint. (PM)	5/21/2012	6/12/2012	22	PM - Heat Exchanger and Economizer	
FO-227171	Routine	Scheduled Maint. (PM)	10/5/2012	10/27/2012	22	PM - Sump Pump	
FO-230733	Low	Scheduled Maint. (PM)	11/1/2012	11/23/2012	22	PM - Roof Sumps - Zone 2, Area 3	
FO-232859	Routine	Scheduled Maint. (PM)	11/15/2012	12/7/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-233601	Routine	Scheduled Maint. (PM)	11/22/2012	12/14/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-233602	Routine	Scheduled Maint. (PM)	11/22/2012	12/14/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-233603	Routine	Scheduled Maint. (PM)	11/22/2012	12/14/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-233604	Routine	Scheduled Maint. (PM)	11/22/2012	12/14/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-234323	Routine	Scheduled Maint. (PM)	11/29/2012	12/21/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-234324	Routine	Scheduled Maint. (PM)	11/29/2012	12/21/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-234325	Routine	Scheduled Maint. (PM)	11/29/2012	12/21/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-234326	Routine	Scheduled Maint. (PM)	11/29/2012	12/21/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-234327	Routine	Scheduled Maint. (PM)	11/29/2012	12/21/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-235035	Routine	Scheduled Maint. (PM)	12/6/2012	12/28/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-235036	Routine	Scheduled Maint. (PM)	12/6/2012	12/28/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-235037	Routine	Scheduled Maint. (PM)	12/6/2012	12/28/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-235038	Routine	Scheduled Maint. (PM)	12/6/2012	12/28/2012	22	PM - Heat Pumps (5057 Woodward)	
FO-235388	Routine	Scheduled Maint. (PM)	12/13/2012	1/4/2013	22	PM - Heat Pumps (5057 Woodward)	
FO-235389	Routine	Scheduled Maint. (PM)	12/13/2012	1/4/2013	22	PM - Heat Pumps (5057 Woodward)	
FO-235390	Routine	Scheduled Maint. (PM)	12/13/2012	1/4/2013	22	PM - Heat Pumps (5057 Woodward)	
FO-238537	Routine	Scheduled Maint. (PM)	1/25/2013	2/16/2013	22	PM - Heat Pumps (5057 Woodward)	
FO-238538	Routine	Scheduled Maint. (PM)	1/25/2013	2/16/2013	22	PM - Heat Pumps (5057 Woodward)	
FO-209505	Routine	Scheduled Maint. (PM)	1/16/2012	2/6/2012	21	PB - B&G Series 100 Pump	
FO-209523	Routine	Scheduled Maint. (PM)	2/16/2012	3/8/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-213980	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213981	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213982	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213983	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213984	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213985	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213986	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213987	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213988	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213989	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213990	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213991	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213992	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213993	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213994	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213995	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-213996	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213997	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213998	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-213999	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214000	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214001	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214002	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214003	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214004	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214005	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214006	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214007	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214008	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214009	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214010	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214011	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214012	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214013	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214014	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214015	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214016	Routine	Scheduled Maint. (PM)	4/19/2012	5/10/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-214092	Routine	Scheduled Maint. (PM)	4/11/2012	5/2/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-214093	Routine	Scheduled Maint. (PM)	4/11/2012	5/2/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-217620	Routine	Scheduled Maint. (PM)	5/16/2012	6/6/2012	21	PB - B&G Series 100 Pump	
FO-219058	Routine	Scheduled Maint. (PM)	6/15/2012	7/6/2012	21	-> Consolidated PM items:	
FO-232860	Routine	Scheduled Maint. (PM)	11/15/2012	12/6/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-232861	Routine	Scheduled Maint. (PM)	11/15/2012	12/6/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-232862	Routine	Scheduled Maint. (PM)	11/15/2012	12/6/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-233605	Routine	Scheduled Maint. (PM)	11/23/2012	12/14/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-234328	Routine	Scheduled Maint. (PM)	11/30/2012	12/21/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-234329	Routine	Scheduled Maint. (PM)	11/30/2012	12/21/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-234330	Routine	Scheduled Maint. (PM)	11/30/2012	12/21/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-234331	Routine	Scheduled Maint. (PM)	11/30/2012	12/21/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-235039	Routine	Scheduled Maint. (PM)	12/7/2012	12/28/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-235040	Routine	Scheduled Maint. (PM)	12/7/2012	12/28/2012	21	PM - Heat Pumps (5057 Woodward)	
FO-236095	Routine	Scheduled Maint. (PM)	12/20/2012	1/10/2013	21	PM - Heat Pumps (5057 Woodward)	
FO-236096	Routine	Scheduled Maint. (PM)	12/20/2012	1/10/2013	21	PM - Heat Pumps (5057 Woodward)	
FO-236097	Routine	Scheduled Maint. (PM)	12/20/2012	1/10/2013	21	PM - Heat Pumps (5057 Woodward)	
FO-236098	Routine	Scheduled Maint. (PM)	12/20/2012	1/10/2013	21	PM - Heat Pumps (5057 Woodward)	
FO-211515	Routine	Scheduled Maint. (PM)	4/24/2012	5/14/2012	20	PM - Centrifugal Pump, over 1 H.P.	
FO-211516	Routine	Scheduled Maint. (PM)	4/24/2012	5/14/2012	20	PM - Centrifugal Pump, over 1 H.P.	
FO-211528	Routine	Scheduled Maint. (PM)	4/9/2012	4/29/2012	20	PM - Cooling Tower, 500 - 1000 Tons	
FO-225041	Routine	Scheduled Maint. (PM)	8/16/2012	9/5/2012	20	PM - Heat Pumps (5057 Woodward)	
FO-225042	Routine	Scheduled Maint. (PM)	8/16/2012	9/5/2012	20	PM - Heat Pumps (5057 Woodward)	

			Finish Date	Due Date			Total per Trade
FO-225043	Routine	Scheduled Maint. (PM)	8/16/2012	9/5/2012	20	PM - Heat Pumps (5057 Woodward)	
FO-225044	Routine	Scheduled Maint. (PM)	8/16/2012	9/5/2012	20	PM - Heat Pumps (5057 Woodward)	
FO-225594	Low	Scheduled Maint. (PM)	8/15/2012	9/4/2012	20	PM - Harmsco Side Stream Filter	
FO-225595	Low	Scheduled Maint. (PM)	8/15/2012	9/4/2012	20	PM - Harmsco Side Stream Filter	
FO-225596	Low	Scheduled Maint. (PM)	8/15/2012	9/4/2012	20	PM - Harmsco Side Stream Filter	
FO-232863	Routine	Scheduled Maint. (PM)	11/16/2012	12/6/2012	20	PM - Heat Pumps (5057 Woodward)	
FO-234312	Routine	Scheduled Maint. (PM)	11/14/2012	12/4/2012	20	PM - Heat Exchanger and Economizer	
FO-234313	Routine	Scheduled Maint. (PM)	11/14/2012	12/4/2012	20	PM - Heat Exchanger and Economizer	
FO-211518	Routine	Scheduled Maint. (PM)	4/25/2012	5/14/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-211519	Routine	Scheduled Maint. (PM)	4/25/2012	5/14/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-211520	Routine	Scheduled Maint. (PM)	4/25/2012	5/14/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-227302	Low	Scheduled Maint. (PM)	11/6/2012	11/25/2012	19	PM - Water/Air Cooled Condenser	
FO-227303	Low	Scheduled Maint. (PM)	11/6/2012	11/25/2012	19	PM - Water/Air Cooled Condenser	
FO-228760	Routine	Scheduled Maint. (PM)	10/12/2012	10/31/2012	19	PM - Centrifugal Pump, over 1 H.P.	
FO-211529	Routine	Scheduled Maint. (PM)	4/11/2012	4/29/2012	18	PM - Cooling Tower, 500 - 1000 Tons	
FO-215368	Routine	Scheduled Maint. (PM)	4/27/2012	5/15/2012	18	PM - Air Handling Unit, over 50 Ton	
FO-215369	Routine	Scheduled Maint. (PM)	4/27/2012	5/15/2012	18	PM - Air Handling Unit, over 50 Ton	
FO-221961	Routine	Scheduled Maint. (PM)	7/27/2012	8/14/2012	18	PM - Heat Exchanger and Economizer	
FO-227268	Routine	Scheduled Maint. (PM)	10/24/2012	11/11/2012	18	PM - Water/Air Cooled Condenser	
FO-228692	Routine	Scheduled Maint. (PM)	11/12/2012	11/30/2012	18	PM - Centrifugal Pump, over 1 H.P.	
FO-230746	Low	Scheduled Maint. (PM)	11/5/2012	11/23/2012	18	PM - Roof Sumps - Zone 2, Area 3	
FO-230817	Routine	Scheduled Maint. (PM)	11/27/2012	12/15/2012	18	PM - Cooling Tower, 500 - 1000 Tons	
FO-220230	Routine	Scheduled Maint. (PM)	7/2/2012	7/19/2012	17	PM - Heat Pumps (5057 Woodward)	
FO-220231	Routine	Scheduled Maint. (PM)	7/2/2012	7/19/2012	17	PM - Heat Pumps (5057 Woodward)	
FO-224626	Routine	Scheduled Maint. (PM)	7/12/2012	7/29/2012	17	PM - Domestic Water Heater, Electric	
FO-224627	Routine	Scheduled Maint. (PM)	7/12/2012	7/29/2012	17	PM - Domestic Water Heater, Electric	
FO-228693	Routine	Scheduled Maint. (PM)	11/13/2012	11/30/2012	17	PM - Centrifugal Pump, over 1 H.P.	
FO-230737	Low	Scheduled Maint. (PM)	11/6/2012	11/23/2012	17	PM - Roof Sumps - Zone 2, Area 3	
FO-230738	Low	Scheduled Maint. (PM)	11/6/2012	11/23/2012	17	PM - Roof Sumps - Zone 2, Area 3	
FO-216162	Routine	Scheduled Maint. (PM)	4/30/2012	5/16/2012	16	PM - Chemical Feed/Metering Pump/Controller	
FO-215184	Low	Scheduled Maint. (PM)	5/8/2012	5/24/2012	16	PM - Roof Sumps - Zone 2, Area 3	
FO-227267	Routine	Scheduled Maint. (PM)	10/26/2012	11/11/2012	16	PM - Water/Air Cooled Condenser	
FO-228694	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Centrifugal Pump, over 1 H.P.	
FO-228705	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Centrifugal Pump, over 1 H.P.	
FO-228706	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Centrifugal Pump, over 1 H.P.	
FO-228707	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Centrifugal Pump, over 1 H.P.	
FO-228708	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Centrifugal Pump, over 1 H.P.	
FO-228798	Low	Scheduled Maint. (PM)	10/30/2012	11/15/2012	16	PM - Cooling Tower Lay-up - GE Betz	
FO-236671	Routine	Scheduled Maint. (PM)	1/2/2013	1/18/2013	16	PM - Heat Pumps (5057 Woodward)	
FO-236672	Routine	Scheduled Maint. (PM)	1/2/2013	1/18/2013	16	PM - Heat Pumps (5057 Woodward)	
FO-236673	Routine	Scheduled Maint. (PM)	1/2/2013	1/18/2013	16	PM - Heat Pumps (5057 Woodward)	
FO-209012	Low	Scheduled Maint. (PM)	3/7/2012	3/22/2012	15	PM - Centrifugal Pump, over 1 H.P.	
FO-209381	Low	Scheduled Maint. (PM)	2/16/2012	3/2/2012	15	PM - Sump Pump	
FO-228695	Routine	Scheduled Maint. (PM)	11/15/2012	11/30/2012	15	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date			Total per Trade
FO-232825	Routine	Scheduled Maint. (PM)	12/6/2012	12/21/2012	15	PM - Cooling Tower, 500 - 1000 Tons	
FO-236674	Routine	Scheduled Maint. (PM)	1/3/2013	1/18/2013	15	PM - Heat Pumps (5057 Woodward)	
FO-236675	Routine	Scheduled Maint. (PM)	1/3/2013	1/18/2013	15	PM - Heat Pumps (5057 Woodward)	
FO-236676	Routine	Scheduled Maint. (PM)	1/3/2013	1/18/2013	15	PM - Heat Pumps (5057 Woodward)	
FO-236677	Routine	Scheduled Maint. (PM)	1/3/2013	1/18/2013	15	PM - Heat Pumps (5057 Woodward)	
FO-209546	Routine	Scheduled Maint. (PM)	1/3/2012	1/17/2012	14	PM - Air Dryer	
FO-209061	Routine	Scheduled Maint. (PM)	1/6/2012	1/20/2012	14	PM - Chemical Feed/Metering Pump/Controller	
FO-209062	Routine	Scheduled Maint. (PM)	1/6/2012	1/20/2012	14	PM - Chemical Feed/Metering Pump/Controller	
FO-209554	Routine	Scheduled Maint. (PM)	1/10/2012	1/24/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209550	Routine	Scheduled Maint. (PM)	1/10/2012	1/24/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209343	Routine	Scheduled Maint. (PM)	1/17/2012	1/31/2012	14	PM - Heat Exchanger and Economizer	
FO-209344	Routine	Scheduled Maint. (PM)	1/17/2012	1/31/2012	14	PM - Heat Exchanger and Economizer	
FO-209345	Routine	Scheduled Maint. (PM)	1/17/2012	1/31/2012	14	PM - Heat Exchanger and Economizer	
FO-209346	Routine	Scheduled Maint. (PM)	1/17/2012	1/31/2012	14	PM - Heat Exchanger and Economizer	
FO-209590	Routine	Scheduled Maint. (PM)	1/27/2012	2/10/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209410	Routine	Scheduled Maint. (PM)	1/27/2012	2/10/2012	14	PM - Air Dryer	
FO-209555	Routine	Scheduled Maint. (PM)	1/27/2012	2/10/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209502	Routine	Scheduled Maint. (PM)	1/27/2012	2/10/2012	14	PM - Air Dryer	
FO-209067	Routine	Scheduled Maint. (PM)	2/3/2012	2/17/2012	14	PM - Emergency Generator, Monthly	
FO-209488	Routine	Scheduled Maint. (PM)	2/7/2012	2/21/2012	14	PM - Deaerator Tank	
FO-209415	Routine	Scheduled Maint. (PM)	2/15/2012	2/29/2012	14	PM - Domestic Water Heater, Steam	
FO-209465	Routine	Scheduled Maint. (PM)	2/15/2012	2/29/2012	14	PM - Domestic Water Heater, Electric	
FO-209382	Routine	Scheduled Maint. (PM)	2/17/2012	3/2/2012	14	PM - Sump Pump	
FO-208979	Routine	Scheduled Maint. (PM)	2/23/2012	3/8/2012	14	PM - Centrifugal Pump, over 1 H.P.	
FO-208978	Routine	Scheduled Maint. (PM)	2/23/2012	3/8/2012	14	PM - Centrifugal Pump, over 1 H.P.	
FO-209591	Routine	Scheduled Maint. (PM)	2/24/2012	3/9/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209406	Routine	Scheduled Maint. (PM)	2/28/2012	3/13/2012	14	PM - Unspecified	
FO-209407	Routine	Scheduled Maint. (PM)	2/28/2012	3/13/2012	14	PM - Unspecified	
FO-209960	Routine	Scheduled Maint. (PM)	3/2/2012	3/16/2012	14	PM - Emergency Generator, Monthly	
FO-210582	Routine	Scheduled Maint. (PM)	3/7/2012	3/21/2012	14	PM - Domestic Water Heater, Gas	
FO-210583	Routine	Scheduled Maint. (PM)	3/7/2012	3/21/2012	14	PM - Domestic Water Heater, Gas	
FO-211503	Routine	Scheduled Maint. (PM)	3/23/2012	4/6/2012	14	PM - Condensate Return Pump	
FO-212857	Routine	Scheduled Maint. (PM)	4/2/2012	4/16/2012	14	PM - Heat Exchanger and Economizer	
FO-212858	Routine	Scheduled Maint. (PM)	4/2/2012	4/16/2012	14	PM - Heat Exchanger and Economizer	
FO-213602	Routine	Scheduled Maint. (PM)	4/4/2012	4/18/2012	14	PM - Unspecified	
FO-213603	Routine	Scheduled Maint. (PM)	4/4/2012	4/18/2012	14	PM - Unspecified	
FO-213613	Routine	Scheduled Maint. (PM)	4/6/2012	4/20/2012	14	PM - Emergency Generator, Monthly	
FO-214017	Routine	Scheduled Maint. (PM)	4/10/2012	4/24/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214058	Routine	Scheduled Maint. (PM)	4/11/2012	4/25/2012	14	PM - Fan Coil/HV/AC Unit	
FO-214063	Routine	Scheduled Maint. (PM)	4/11/2012	4/25/2012	14	PM - Fan Coil/HV/AC Unit	
FO-214064	Routine	Scheduled Maint. (PM)	4/11/2012	4/25/2012	14	PM - Fan Coil/HV/AC Unit	
FO-214065	Routine	Scheduled Maint. (PM)	4/11/2012	4/25/2012	14	PM - Fan Coil/HV/AC Unit	
FO-214750	Routine	Scheduled Maint. (PM)	4/18/2012	5/2/2012	14	PM - Unspecified	
FO-215135	Routine	Scheduled Maint. (PM)	4/25/2012	5/9/2012	14	PM - Fan Coil/HV/AC Unit	

			Finish Date	Due Date			Total per Trade
FO-215204	Routine	Scheduled Maint. (PM)	4/18/2012	5/2/2012	14	PM - Fan Coil/HV/AC Unit	
FO-215205	Routine	Scheduled Maint. (PM)	4/18/2012	5/2/2012	14	PM - Fan Coil/HV/AC Unit	
FO-217581	Routine	Scheduled Maint. (PM)	5/9/2012	5/23/2012	14	PM - Unit/Space Heater	
FO-219062	Routine	Scheduled Maint. (PM)	6/8/2012	6/22/2012	14	PM - Emergency Generator, Monthly	
FO-209289	Low	Scheduled Maint. (PM)	2/16/2012	3/1/2012	14	PM - Domestic Water Heater, Electric	
FO-209290	Low	Scheduled Maint. (PM)	2/23/2012	3/8/2012	14	PM - Domestic Water Heater, Electric	
FO-209500	Low	Scheduled Maint. (PM)	2/28/2012	3/13/2012	14	PM - Domestic Water Heater, Electric	
FO-209551	Low	Scheduled Maint. (PM)	2/21/2012	3/6/2012	14	PM - Harmsco Side Stream Filter	
FO-209552	Low	Scheduled Maint. (PM)	2/21/2012	3/6/2012	14	PM - Harmsco Side Stream Filter	
FO-211538	Low	Scheduled Maint. (PM)	3/12/2012	3/26/2012	14	PM - Domestic Water Heater, Electric	
FO-212071	Low	Scheduled Maint. (PM)	3/19/2012	4/2/2012	14	PM - Domestic Water Heater, Electric	
FO-212506	Low	Scheduled Maint. (PM)	3/27/2012	4/10/2012	14	PM - Air Dryer	
FO-213604	Low	Scheduled Maint. (PM)	4/3/2012	4/17/2012	14	PM - Domestic Water Heater, Gas	
FO-215370	Low	Scheduled Maint. (PM)	4/23/2012	5/7/2012	14	PM - Humidifier	
FO-228696	Routine	Scheduled Maint. (PM)	11/16/2012	11/30/2012	14	PM - Centrifugal Pump, over 1 H.P.	
FO-230296	Routine	Scheduled Maint. (PM)	10/12/2012	10/26/2012	14	PM - Emergency Generator, Monthly	
FO-230340	Routine	Scheduled Maint. (PM)	10/10/2012	10/24/2012	14	PM - Heat Exchanger and Economizer	
FO-230420	Routine	Scheduled Maint. (PM)	10/15/2012	10/29/2012	14	PM - Condensate Return Pump	
FO-230421	Routine	Scheduled Maint. (PM)	10/15/2012	10/29/2012	14	PM - Condensate Return Pump	
FO-230766	Low	Scheduled Maint. (PM)	10/23/2012	11/6/2012	14	PM - Centrifugal Pump, over 1 H.P.	
FO-233567	Routine	Scheduled Maint. (PM)	11/16/2012	11/30/2012	14	PM - Emergency Generator, Monthly	
FO-209433	Routine	Scheduled Maint. (PM)	1/24/2012	2/6/2012	13	PM - Domestic Water Heater, Gas	
FO-209432	Routine	Scheduled Maint. (PM)	2/24/2012	3/8/2012	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-210567	Routine	Scheduled Maint. (PM)	3/8/2012	3/21/2012	13	PM - Unspecified	
FO-210568	Routine	Scheduled Maint. (PM)	3/8/2012	3/21/2012	13	PM - Unspecified	
FO-211536	Routine	Scheduled Maint. (PM)	3/15/2012	3/28/2012	13	PM - Centrifugal Pump, over 1 H.P.	
FO-211449	Routine	Scheduled Maint. (PM)	3/15/2012	3/28/2012	13	PM - Centrifugal Pump, over 1 H.P.	
FO-211546	Routine	Scheduled Maint. (PM)	3/15/2012	3/28/2012	13	PM - Unspecified	
FO-211532	Routine	Scheduled Maint. (PM)	3/15/2012	3/28/2012	13	PM - Unspecified	
FO-214059	Routine	Scheduled Maint. (PM)	4/11/2012	4/24/2012	13	PM - Heat Exchanger and Economizer	
FO-214751	Routine	Scheduled Maint. (PM)	4/19/2012	5/2/2012	13	PM - Unspecified	
FO-217582	Routine	Scheduled Maint. (PM)	5/10/2012	5/23/2012	13	PM - Unit/Space Heater	
FO-217586	Routine	Scheduled Maint. (PM)	5/10/2012	5/23/2012	13	PM - Chemical Feed/Metering Pump/Controller	
FO-217587	Routine	Scheduled Maint. (PM)	5/17/2012	5/30/2012	13	PM - Chemical Feed/Metering Pump/Controller	
FO-219037	Routine	Scheduled Maint. (PM)	6/7/2012	6/20/2012	13	PM - Fan Coil/HV/AC Unit	
FO-228794	Low	Scheduled Maint. (PM)	9/18/2012	10/1/2012	13	PM - Humidifier	
FO-228795	Low	Scheduled Maint. (PM)	9/18/2012	10/1/2012	13	PM - Humidifier	
FO-230385	Low	Scheduled Maint. (PM)	10/11/2012	10/24/2012	13	PM - Domestic Water Heater, Electric	
FO-230630	Routine	Scheduled Maint. (PM)	12/7/2012	12/20/2012	13	PM - Centrifugal Pump, over 1 H.P.	
FO-230631	Routine	Scheduled Maint. (PM)	12/7/2012	12/20/2012	13	PM - Centrifugal Pump, over 1 H.P.	
FO-230769	Routine	Scheduled Maint. (PM)	10/31/2012	11/13/2012	13	PM - Chemical Feed/Metering Pump/Controller	
FO-209401	Routine	Scheduled Maint. (PM)	1/5/2012	1/17/2012	12	PM - Air Dryer	
FO-209404	Routine	Scheduled Maint. (PM)	2/23/2012	3/6/2012	12	PM - Unspecified	
FO-211306	Routine	Scheduled Maint. (PM)	5/2/2012	5/14/2012	12	PM - Centrifugal Pump, over 1 H.P.	

			Finish Date	Due Date	Total per Trade	
FO-213572	Routine	Scheduled Maint. (PM)	4/5/2012	4/17/2012	12	PM - Air Dryer
FO-214060	Routine	Scheduled Maint. (PM)	4/12/2012	4/24/2012	12	PM - Heat Exchanger and Economizer
FO-215593	Routine	Scheduled Maint. (PM)	5/2/2012	5/14/2012	12	PM - Chemical Feed/Metering Pump/Controller
FO-215594	Routine	Scheduled Maint. (PM)	4/25/2012	5/7/2012	12	PM - Heat Exchanger and Economizer
FO-215595	Routine	Scheduled Maint. (PM)	4/25/2012	5/7/2012	12	PM - Heat Exchanger and Economizer
FO-217583	Routine	Scheduled Maint. (PM)	5/11/2012	5/23/2012	12	PM - Unit/Space Heater
FO-219036	Routine	Scheduled Maint. (PM)	6/8/2012	6/20/2012	12	PM - Fan Coil/HV/AC Unit
FO-214747	Low	Scheduled Maint. (PM)	5/3/2012	5/15/2012	12	PM - Outside/Fresh Air Intake Screens
FO-225587	Routine	Scheduled Maint. (PM)	8/24/2012	9/5/2012	12	PM - Heat Exchanger and Economizer
FO-233563	Routine	Scheduled Maint. (PM)	12/18/2012	12/30/2012	12	PM - Punch Tubes - Chiller/Absorber
FO-209575	Routine	Scheduled Maint. (PM)	1/6/2012	1/17/2012	11	PM - Air Dryer
FO-210577	Routine	Scheduled Maint. (PM)	3/9/2012	3/20/2012	11	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-211307	Routine	Scheduled Maint. (PM)	5/3/2012	5/14/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-221252	Routine	Scheduled Maint. (PM)	7/9/2012	7/20/2012	11	PM - Emergency Generator, Monthly
FO-221940	Routine	Scheduled Maint. (PM)	7/18/2012	7/29/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-221941	Routine	Scheduled Maint. (PM)	7/18/2012	7/29/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-224583	Routine	Scheduled Maint. (PM)	7/26/2012	8/6/2012	11	PM - Domestic Water Heater, Gas
FO-209576	Low	Scheduled Maint. (PM)	2/29/2012	3/11/2012	11	PM - Air Handling Unit, over 50 Ton
FO-209577	Low	Scheduled Maint. (PM)	2/29/2012	3/11/2012	11	PM - Air Handling Unit, over 50 Ton
FO-216143	Low	Scheduled Maint. (PM)	5/9/2012	5/20/2012	11	PM - Outside/Fresh Air Intake Screens
FO-216144	Low	Scheduled Maint. (PM)	5/9/2012	5/20/2012	11	PM - Outside/Fresh Air Intake Screens
FO-217528	Low	Scheduled Maint. (PM)	5/24/2012	6/4/2012	11	PM - Harmsco Side Stream Filter
FO-226789	Routine	Scheduled Maint. (PM)	9/25/2012	10/6/2012	11	PM - Condensate Return System **Needs Task Sheet**
FO-226790	Routine	Scheduled Maint. (PM)	9/25/2012	10/6/2012	11	PM - Condensate Return System **Needs Task Sheet**
FO-228703	Routine	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-228704	Routine	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-229468	Routine	Scheduled Maint. (PM)	11/5/2012	11/16/2012	11	PM - Cooling Tower, 500 - 1000 Tons
FO-233564	Routine	Scheduled Maint. (PM)	12/19/2012	12/30/2012	11	PM - Punch Tubes - Chiller/Absorber
FO-209464	Routine	Scheduled Maint. (PM)	2/2/2012	2/12/2012	10	PM - Heat Exchanger and Economizer
FO-209418	Routine	Scheduled Maint. (PM)	2/6/2012	2/16/2012	10	PM - Heat Pumps (5057 Woodward)
FO-209419	Routine	Scheduled Maint. (PM)	2/6/2012	2/16/2012	10	PM - Heat Pumps (5057 Woodward)
FO-209383	Routine	Scheduled Maint. (PM)	2/21/2012	3/2/2012	10	PM - Sump Pump
FO-214057	Routine	Scheduled Maint. (PM)	5/1/2012	5/11/2012	10	PM - Sump Pump
FO-214062	Routine	Scheduled Maint. (PM)	5/1/2012	5/11/2012	10	PM - Sump Pump
FO-215328	Low	Scheduled Maint. (PM)	5/1/2012	5/11/2012	10	PM - Centrifugal Pump, over 1 H.P.
FO-228678	Routine	Scheduled Maint. (PM)	10/1/2012	10/11/2012	10	PM - Heat Exchanger and Economizer
FO-229469	Routine	Scheduled Maint. (PM)	11/6/2012	11/16/2012	10	PM - Cooling Tower, 500 - 1000 Tons
FO-209420	Routine	Scheduled Maint. (PM)	2/7/2012	2/16/2012	9	PM - Heat Pumps (5057 Woodward)
FO-209425	Routine	Scheduled Maint. (PM)	2/7/2012	2/16/2012	9	PM - Heat Pumps (5057 Woodward)
FO-209573	Routine	Scheduled Maint. (PM)	3/2/2012	3/11/2012	9	PM - Air Handling Unit, HV Type
FO-211514	Routine	Scheduled Maint. (PM)	4/20/2012	4/29/2012	9	PM - Cooling Tower, 500 - 1000 Tons
FO-212500	Routine	Scheduled Maint. (PM)	4/3/2012	4/12/2012	9	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-212504	Routine	Scheduled Maint. (PM)	4/2/2012	4/11/2012	9	PM - Fan Coil/HV/AC Unit
FO-220294	Routine	Scheduled Maint. (PM)	6/18/2012	6/27/2012	9	PM - Unit/Space Heater

			Finish Date	Due Date	Total per Trade	
FO-209384	Low	Scheduled Maint. (PM)	2/22/2012	3/2/2012	9	PM - Sump Pump
FO-211461	Low	Scheduled Maint. (PM)	3/27/2012	4/5/2012	9	PM - Centrifugal Pump, over 1 H.P.
FO-225047	Routine	Scheduled Maint. (PM)	8/20/2012	8/29/2012	9	PM - Heat Exchanger and Economizer
FO-225048	Routine	Scheduled Maint. (PM)	8/20/2012	8/29/2012	9	PM - Heat Exchanger and Economizer
FO-225049	Routine	Scheduled Maint. (PM)	8/20/2012	8/29/2012	9	PM - Heat Exchanger and Economizer
FO-225050	Routine	Scheduled Maint. (PM)	8/20/2012	8/29/2012	9	PM - Heat Exchanger and Economizer
FO-225072	Low	Scheduled Maint. (PM)	9/5/2012	9/14/2012	9	PM - Outside/Fresh Air Intake Screens
FO-227172	Routine	Scheduled Maint. (PM)	10/2/2012	10/11/2012	9	PM - Heat Exchanger and Economizer
FO-227286	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227295	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227296	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227297	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227304	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227312	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-227313	Low	Scheduled Maint. (PM)	10/3/2012	10/12/2012	9	PM - Drinking Fountain and Water Cooler
FO-229470	Routine	Scheduled Maint. (PM)	11/7/2012	11/16/2012	9	PM - Cooling Tower, 500 - 1000 Tons
FO-229493	Low	Scheduled Maint. (PM)	10/8/2012	10/17/2012	9	PM - Domestic Water Heater, Electric
FO-230553	Routine	Scheduled Maint. (PM)	12/11/2012	12/20/2012	9	PM - Centrifugal Pump, over 1 H.P.
FO-230554	Routine	Scheduled Maint. (PM)	12/11/2012	12/20/2012	9	PM - Centrifugal Pump, over 1 H.P.
FO-230750	Low	Scheduled Maint. (PM)	11/14/2012	11/23/2012	9	PM - Roof Sumps - Zone 2, Area 3
FO-209548	Routine	Scheduled Maint. (PM)	1/4/2012	1/12/2012	8	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209426	Routine	Scheduled Maint. (PM)	2/8/2012	2/16/2012	8	PM - Heat Pumps (5057 Woodward)
FO-209389	Routine	Scheduled Maint. (PM)	2/23/2012	3/2/2012	8	PM - Sump Pump
FO-209489	Routine	Scheduled Maint. (PM)	2/27/2012	3/6/2012	8	PM - Domestic Water Heater, Gas
FO-212496	Routine	Scheduled Maint. (PM)	4/2/2012	4/10/2012	8	PM - Heat Exchanger and Economizer
FO-212497	Routine	Scheduled Maint. (PM)	4/3/2012	4/11/2012	8	PM - Chemical Feed/Metering Pump/Controller
FO-212498	Routine	Scheduled Maint. (PM)	4/3/2012	4/11/2012	8	PM - Chemical Feed/Metering Pump/Controller
FO-212499	Routine	Scheduled Maint. (PM)	4/3/2012	4/11/2012	8	PM - Chemical Feed/Metering Pump/Controller
FO-212501	Routine	Scheduled Maint. (PM)	4/4/2012	4/12/2012	8	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-212505	Routine	Scheduled Maint. (PM)	4/3/2012	4/11/2012	8	PM - Fan Coil/HV/AC Unit
FO-212534	Routine	Scheduled Maint. (PM)	4/2/2012	4/10/2012	8	PM - Heat Exchanger and Economizer
FO-215133	Routine	Scheduled Maint. (PM)	5/1/2012	5/9/2012	8	PM - Fan Coil/HV/AC Unit
FO-225051	Routine	Scheduled Maint. (PM)	8/21/2012	8/29/2012	8	PM - Heat Exchanger and Economizer
FO-225052	Routine	Scheduled Maint. (PM)	8/21/2012	8/29/2012	8	PM - Heat Exchanger and Economizer
FO-227287	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227288	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227289	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227290	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227292	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227293	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227294	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-227308	Low	Scheduled Maint. (PM)	10/4/2012	10/12/2012	8	PM - Drinking Fountain and Water Cooler
FO-229471	Routine	Scheduled Maint. (PM)	11/8/2012	11/16/2012	8	PM - Cooling Tower, 500 - 1000 Tons
FO-230386	Low	Scheduled Maint. (PM)	10/16/2012	10/24/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date			Total per Trade
FO-230387	Low	Scheduled Maint. (PM)	10/16/2012	10/24/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230555	Routine	Scheduled Maint. (PM)	12/12/2012	12/20/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-230556	Routine	Scheduled Maint. (PM)	12/12/2012	12/20/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-230564	Routine	Scheduled Maint. (PM)	11/5/2012	11/13/2012	8	PM - Chemical Feed/Metering Pump/Controller	
FO-230678	Routine	Scheduled Maint. (PM)	11/5/2012	11/13/2012	8	PM - Chemical Feed/Metering Pump/Controller	
FO-230696	Routine	Scheduled Maint. (PM)	11/12/2012	11/20/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-230697	Routine	Scheduled Maint. (PM)	11/12/2012	11/20/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-230705	Routine	Scheduled Maint. (PM)	11/12/2012	11/20/2012	8	PM - Centrifugal Pump, over 1 H.P.	
FO-209402	Routine	Scheduled Maint. (PM)	1/17/2012	1/24/2012	7	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209403	Routine	Scheduled Maint. (PM)	1/24/2012	1/31/2012	7	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209427	Routine	Scheduled Maint. (PM)	2/9/2012	2/16/2012	7	PM - Heat Pumps (5057 Woodward)	
FO-209428	Routine	Scheduled Maint. (PM)	2/9/2012	2/16/2012	7	PM - Heat Pumps (5057 Woodward)	
FO-209390	Routine	Scheduled Maint. (PM)	2/24/2012	3/2/2012	7	PM - Sump Pump	
FO-209405	Routine	Scheduled Maint. (PM)	2/28/2012	3/6/2012	7	PM - Unspecified	
FO-208569	Routine	Scheduled Maint. (PM)	3/6/2012	3/13/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-213575	Routine	Scheduled Maint. (PM)	4/11/2012	4/18/2012	7	PM - Fan Coil/HV/AC Unit	
FO-214018	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Domestic Water Heater, Electric	
FO-214019	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-214020	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-214039	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Chilled Water Coils - Refill (Old Main)	
FO-214042	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Chilled Water Coils - Refill (Old Main)	
FO-214044	Low	Scheduled Maint. (PM)	4/17/2012	4/24/2012	7	PM - Chilled Water Coils - Refill (Old Main)	
FO-215136	Low	Scheduled Maint. (PM)	5/1/2012	5/8/2012	7	PM - Domestic Water Heater, Gas	
FO-215192	Low	Scheduled Maint. (PM)	4/30/2012	5/7/2012	7	PM - Domestic Water Heater, Electric	
FO-224982	Routine	Scheduled Maint. (PM)	8/21/2012	8/28/2012	7	PM - Domestic Water Heater, Steam	
FO-227406	Low	Scheduled Maint. (PM)	10/17/2012	10/24/2012	7	PM - Water Booster Pump	
FO-227407	Low	Scheduled Maint. (PM)	10/17/2012	10/24/2012	7	PM - Water Booster Pump	
FO-230557	Routine	Scheduled Maint. (PM)	12/13/2012	12/20/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-230558	Routine	Scheduled Maint. (PM)	12/13/2012	12/20/2012	7	PM - Centrifugal Pump, over 1 H.P.	
FO-230679	Routine	Scheduled Maint. (PM)	11/6/2012	11/13/2012	7	PM - Chemical Feed/Metering Pump/Controller	
FO-230680	Routine	Scheduled Maint. (PM)	11/6/2012	11/13/2012	7	PM - Chemical Feed/Metering Pump/Controller	
FO-230732	Low	Scheduled Maint. (PM)	11/16/2012	11/23/2012	7	PM - Roof Sumps - Zone 2, Area 3	
FO-230739	Low	Scheduled Maint. (PM)	11/16/2012	11/23/2012	7	PM - Roof Sumps - Zone 2, Area 3	
FO-209549	Routine	Scheduled Maint. (PM)	1/6/2012	1/12/2012	6	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209458	Routine	Scheduled Maint. (PM)	2/7/2012	2/13/2012	6	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209429	Routine	Scheduled Maint. (PM)	2/10/2012	2/16/2012	6	PM - Heat Pumps (5057 Woodward)	
FO-209468	Routine	Scheduled Maint. (PM)	2/22/2012	2/28/2012	6	PM - Domestic Water Heater, Steam	
FO-209387	Routine	Scheduled Maint. (PM)	2/23/2012	2/29/2012	6	PM - Heat Exchanger and Economizer	
FO-209388	Routine	Scheduled Maint. (PM)	2/23/2012	2/29/2012	6	PM - Heat Exchanger and Economizer	
FO-209574	Routine	Scheduled Maint. (PM)	3/5/2012	3/11/2012	6	PM - Air Handling Unit, HV Type	
FO-212503	Routine	Scheduled Maint. (PM)	4/5/2012	4/11/2012	6	PM - Fan Coil/HV/AC Unit	
FO-215589	Routine	Scheduled Maint. (PM)	5/8/2012	5/14/2012	6	PM - Chemical Feed/Metering Pump/Controller	
FO-215590	Routine	Scheduled Maint. (PM)	5/8/2012	5/14/2012	6	PM - Chemical Feed/Metering Pump/Controller	
FO-217584	Routine	Scheduled Maint. (PM)	5/31/2012	6/6/2012	6	PM - Air Handling Unit, over 50 Ton	

			Finish Date	Due Date	Total per Trade	
FO-220457	Routine	Scheduled Maint. (PM)	7/5/2012	7/11/2012	6	PM - Domestic Water Heater, Electric
FO-220458	Routine	Scheduled Maint. (PM)	7/5/2012	7/11/2012	6	PM - Domestic Water Heater, Electric
FO-220459	Routine	Scheduled Maint. (PM)	7/5/2012	7/11/2012	6	PM - Domestic Water Heater, Electric
FO-210603	Low	Scheduled Maint. (PM)	3/14/2012	3/20/2012	6	PM - Harmsco Side Stream Filter
FO-219712	Low	Scheduled Maint. (PM)	6/15/2012	6/21/2012	6	PM - Chemical Feed/Metering Pump/Controller
FO-224596	Routine	Scheduled Maint. (PM)	8/25/2012	8/31/2012	6	PM - Air Handling Unit, over 50 Ton
FO-224597	Routine	Scheduled Maint. (PM)	8/25/2012	8/31/2012	6	PM - Air Handling Unit, over 50 Ton
FO-224598	Routine	Scheduled Maint. (PM)	8/25/2012	8/31/2012	6	PM - Air Handling Unit, over 50 Ton
FO-227280	Low	Scheduled Maint. (PM)	9/27/2012	10/3/2012	6	PM - Domestic Water Heater, Electric
FO-229494	Low	Scheduled Maint. (PM)	10/11/2012	10/17/2012	6	PM - Domestic Water Heater, Electric
FO-230559	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-230681	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-230682	Routine	Scheduled Maint. (PM)	12/14/2012	12/20/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-233570	Routine	Scheduled Maint. (PM)	11/23/2012	11/29/2012	6	PM - Fan Coil/HV/AC Unit
FO-210570	Routine	Scheduled Maint. (PM)	3/16/2012	3/21/2012	5	PM - Fan Coil/HV/AC Unit
FO-210581	Routine	Scheduled Maint. (PM)	3/16/2012	3/21/2012	5	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-210580	Routine	Scheduled Maint. (PM)	3/16/2012	3/21/2012	5	PM - Air Dryer
FO-215591	Routine	Scheduled Maint. (PM)	5/9/2012	5/14/2012	5	PM - Chemical Feed/Metering Pump/Controller
FO-215592	Routine	Scheduled Maint. (PM)	5/9/2012	5/14/2012	5	PM - Chemical Feed/Metering Pump/Controller
FO-217529	Medium	Scheduled Maint. (PM)	5/30/2012	6/4/2012	5	PM - Harmsco Side Stream Filter
FO-222000	Low	Scheduled Maint. (PM)	7/16/2012	7/21/2012	5	PM - Chemical Feed/Metering Pump/Controller
FO-222001	Low	Scheduled Maint. (PM)	7/16/2012	7/21/2012	5	PM - Chemical Feed/Metering Pump/Controller
FO-222002	Low	Scheduled Maint. (PM)	7/16/2012	7/21/2012	5	PM - Chemical Feed/Metering Pump/Controller
FO-232893	Low	Scheduled Maint. (PM)	11/15/2012	11/20/2012	5	PM - Outside/Fresh Air Intake Screens
FO-232894	Low	Scheduled Maint. (PM)	11/15/2012	11/20/2012	5	PM - Outside/Fresh Air Intake Screens
FO-209369	Routine	Scheduled Maint. (PM)	1/20/2012	1/24/2012	4	PM - Heat Exchanger and Economizer
FO-212859	Routine	Scheduled Maint. (PM)	4/12/2012	4/16/2012	4	PM - Heat Exchanger and Economizer
FO-222515	Routine	Scheduled Maint. (PM)	8/13/2012	8/17/2012	4	PM - Condensate Return Pump
FO-210604	Low	Scheduled Maint. (PM)	3/16/2012	3/20/2012	4	PM - Harmsco Side Stream Filter
FO-224745	Low	Scheduled Maint. (PM)	8/27/2012	8/31/2012	4	PM - Sump Pump
FO-226164	Routine	Scheduled Maint. (PM)	9/11/2012	9/15/2012	4	PM - Unit/Space Heater
FO-227291	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227305	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227306	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227309	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227310	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227311	Low	Scheduled Maint. (PM)	10/8/2012	10/12/2012	4	PM - Drinking Fountain and Water Cooler
FO-227341	Low	Scheduled Maint. (PM)	9/17/2012	9/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-227342	Low	Scheduled Maint. (PM)	9/17/2012	9/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-227343	Low	Scheduled Maint. (PM)	9/17/2012	9/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-227344	Low	Scheduled Maint. (PM)	9/17/2012	9/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-228729	Routine	Scheduled Maint. (PM)	11/26/2012	11/30/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-230389	Low	Scheduled Maint. (PM)	10/17/2012	10/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-230390	Low	Scheduled Maint. (PM)	10/17/2012	10/21/2012	4	PM - Chemical Feed/Metering Pump/Controller

			Finish Date	Due Date	Total per Trade	
FO-230391	Low	Scheduled Maint. (PM)	10/17/2012	10/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-230392	Low	Scheduled Maint. (PM)	10/17/2012	10/21/2012	4	PM - Chemical Feed/Metering Pump/Controller
FO-237862	Routine	Scheduled Maint. (PM)	1/3/2013	1/7/2013	4	PM - Semi Annual Air Handling Unit Inspection
FO-217516	Routine	Scheduled Maint. (PM)	6/5/2012	6/8/2012	3	PM - Condensate Return Pump
FO-217517	Routine	Scheduled Maint. (PM)	6/5/2012	6/8/2012	3	PM - Condensate Return Pump
FO-222514	Routine	Scheduled Maint. (PM)	8/14/2012	8/17/2012	3	PM - Condensate Return Pump
FO-224699	Routine	Scheduled Maint. (PM)	8/28/2012	8/31/2012	3	PM - Sump Pump
FO-224716	Routine	Scheduled Maint. (PM)	8/28/2012	8/31/2012	3	PM - Sump Pump
FO-228730	Routine	Scheduled Maint. (PM)	11/27/2012	11/30/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-229495	Low	Scheduled Maint. (PM)	10/29/2012	11/1/2012	3	PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-229496	Low	Scheduled Maint. (PM)	10/29/2012	11/1/2012	3	PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-229497	Low	Scheduled Maint. (PM)	10/29/2012	11/1/2012	3	PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-229498	Low	Scheduled Maint. (PM)	10/29/2012	11/1/2012	3	PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-230566	Routine	Scheduled Maint. (PM)	11/26/2012	11/29/2012	3	PM - Sump Pump
FO-232864	Routine	Scheduled Maint. (PM)	12/18/2012	12/21/2012	3	PM - Cooling Tower, 500 - 1000 Tons
FO-234340	Routine	Scheduled Maint. (PM)	1/16/2013	1/19/2013	3	PM - Water/Air Cooled Condenser
FO-209399	Routine	Scheduled Maint. (PM)	1/27/2012	1/29/2012	2	PM - Domestic Water Heater, Electric
FO-209400	Routine	Scheduled Maint. (PM)	1/27/2012	1/29/2012	2	PM - Domestic Water Heater, Electric
FO-208264	Routine	Scheduled Maint. (PM)	2/6/2012	2/8/2012	2	PM - Emergency Shower/Eyewash Station
FO-209342	Routine	Scheduled Maint. (PM)	2/13/2012	2/15/2012	2	PM - Emergency Shower/Eyewash Station
FO-209538	Routine	Scheduled Maint. (PM)	2/20/2012	2/22/2012	2	PM - Emergency Shower/Eyewash Station
FO-209597	Routine	Scheduled Maint. (PM)	2/27/2012	2/29/2012	2	PM - Emergency Shower/Eyewash Station
FO-209380	Routine	Scheduled Maint. (PM)	2/27/2012	2/29/2012	2	PM - Heat Exchanger and Economizer
FO-209504	Routine	Scheduled Maint. (PM)	2/28/2012	3/1/2012	2	PM - Domestic Water Heater, Electric
FO-209983	Routine	Scheduled Maint. (PM)	3/5/2012	3/7/2012	2	PM - Emergency Shower/Eyewash Station
FO-212086	Routine	Scheduled Maint. (PM)	4/2/2012	4/4/2012	2	PM - Fan Coil/HV/AC Unit
FO-213573	Routine	Scheduled Maint. (PM)	4/16/2012	4/18/2012	2	PM - Fan Coil/HV/AC Unit
FO-216149	Routine	Scheduled Maint. (PM)	5/14/2012	5/16/2012	2	PM - Fan Coil/HV/AC Unit
FO-222237	Routine	Scheduled Maint. (PM)	8/10/2012	8/12/2012	2	PM - Heat Exchanger and Economizer
FO-222513	Routine	Scheduled Maint. (PM)	8/15/2012	8/17/2012	2	PM - Condensate Return Pump
FO-224634	Routine	Scheduled Maint. (PM)	8/13/2012	8/15/2012	2	PM - Water Softener
FO-215180	Low	Scheduled Maint. (PM)	5/22/2012	5/24/2012	2	PM - Roof Sumps - Zone 2, Area 3
FO-219713	Low	Scheduled Maint. (PM)	6/19/2012	6/21/2012	2	PM - Chemical Feed/Metering Pump/Controller
FO-221335	Low	Scheduled Maint. (PM)	7/18/2012	7/20/2012	2	PM - Harmsco Side Stream Filter
FO-224698	Routine	Scheduled Maint. (PM)	8/29/2012	8/31/2012	2	PM - Sump Pump
FO-224715	Routine	Scheduled Maint. (PM)	8/29/2012	8/31/2012	2	PM - Sump Pump
FO-224972	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-224973	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-224974	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-225067	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-225068	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-225069	Routine	Scheduled Maint. (PM)	9/11/2012	9/13/2012	2	PM - Sump Pump
FO-226822	Routine	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Forced Air Furnace (Jacob House) - Winter
FO-226823	Routine	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Forced Air Furnace (Jacob House) - Winter

			Finish Date	Due Date	Total per Trade	
FO-226824	Routine	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Forced Air Furnace (Jacob House) - Winter
FO-227338	Low	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Drinking Fountain and Water Cooler
FO-227339	Low	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Drinking Fountain and Water Cooler
FO-227340	Low	Scheduled Maint. (PM)	10/16/2012	10/18/2012	2	PM - Drinking Fountain and Water Cooler
FO-228731	Routine	Scheduled Maint. (PM)	11/28/2012	11/30/2012	2	PM - Centrifugal Pump, over 1 H.P.
FO-229457	Routine	Scheduled Maint. (PM)	10/31/2012	11/2/2012	2	PM - Heat Pumps (5057 Woodward)
FO-230565	Routine	Scheduled Maint. (PM)	11/27/2012	11/29/2012	2	PM - Sump Pump
FO-237378	Routine	Scheduled Maint. (PM)	1/8/2013	1/10/2013	2	PM - Domestic Water Heater, Electric
FO-208604	Routine	Scheduled Maint. (PM)	2/22/2012	2/23/2012	1	Generator Maintenance
FO-209377	Routine	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	PM - Heat Exchanger and Economizer
FO-209378	Routine	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	PM - Heat Exchanger and Economizer
FO-209379	Routine	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	PM - Heat Exchanger and Economizer
FO-209961	Routine	Scheduled Maint. (PM)	3/14/2012	3/15/2012	1	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-210576	Routine	Scheduled Maint. (PM)	3/19/2012	3/20/2012	1	PM - Air Dryer
FO-211513	Routine	Scheduled Maint. (PM)	4/28/2012	4/29/2012	1	PM - Cooling Tower, 500 - 1000 Tons
FO-212069	Routine	Scheduled Maint. (PM)	4/3/2012	4/4/2012	1	PM - Fan Coil/HV/AC Unit
FO-212537	Routine	Scheduled Maint. (PM)	3/28/2012	3/29/2012	1	Generator Maintenance
FO-213574	Routine	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	PM - Fan Coil/HV/AC Unit
FO-215137	Routine	Scheduled Maint. (PM)	4/25/2012	4/26/2012	1	Generator Maintenance Same as FO-28604 & FO-212537 need oil chang & filter change.
FO-216146	Routine	Scheduled Maint. (PM)	5/15/2012	5/16/2012	1	PM - Fan Coil/HV/AC Unit
FO-217532	Routine	Scheduled Maint. (PM)	5/23/2012	5/24/2012	1	Generator Maintenance
FO-219030	Routine	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-219031	Routine	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-219032	Routine	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-222512	Routine	Scheduled Maint. (PM)	8/16/2012	8/17/2012	1	PM - Condensate Return Pump
FO-208975	High	Scheduled Maint. (PM)	2/22/2012	2/23/2012	1	Generator Maintenance
FO-209078	High	Scheduled Maint. (PM)	2/21/2012	2/22/2012	1	Generator Maintenance
FO-212088	High	Scheduled Maint. (PM)	3/20/2012	3/21/2012	1	Generator Maintenance
FO-212538	High	Scheduled Maint. (PM)	3/28/2012	3/29/2012	1	Generator Maintenance
FO-214761	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Maintenance
FO-217585	High	Scheduled Maint. (PM)	5/23/2012	5/24/2012	1	Generator Maintenance
FO-219714	Low	Scheduled Maint. (PM)	6/20/2012	6/21/2012	1	PM - Chemical Feed/Metering Pump/Controller
FO-220460	High	Scheduled Maint. (PM)	6/27/2012	6/28/2012	1	Generator Maintenance
FO-221336	Low	Scheduled Maint. (PM)	7/19/2012	7/20/2012	1	PM - Harmsco Side Stream Filter
FO-224670	Routine	Scheduled Maint. (PM)	8/23/2012	8/24/2012	1	PM - Drinking Fountain and Water Cooler
FO-224697	Low	Scheduled Maint. (PM)	8/30/2012	8/31/2012	1	PM - Sump Pump
FO-225078	Low	Scheduled Maint. (PM)	8/20/2012	8/21/2012	1	PM - Chemical Feed/Metering Pump/Controller
FO-225079	Low	Scheduled Maint. (PM)	8/20/2012	8/21/2012	1	PM - Chemical Feed/Metering Pump/Controller
FO-225080	Low	Scheduled Maint. (PM)	8/20/2012	8/21/2012	1	PM - Chemical Feed/Metering Pump/Controller
FO-225081	Low	Scheduled Maint. (PM)	8/20/2012	8/21/2012	1	PM - Chemical Feed/Metering Pump/Controller
FO-227266	Routine	Scheduled Maint. (PM)	9/25/2012	9/26/2012	1	PM - Fan Coil/HV/AC Unit
FO-228732	Routine	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Centrifugal Pump, over 1 H.P.
FO-228733	Routine	Scheduled Maint. (PM)	11/29/2012	11/30/2012	1	PM - Centrifugal Pump, over 1 H.P.
FO-230774	Low	Scheduled Maint. (PM)	11/5/2012	11/6/2012	1	PM - Humidifier

			Finish Date	Due Date	Total per Trade	
FO-233624	Low	Scheduled Maint. (PM)	12/12/2012	12/13/2012	1	PM - Heat Exchanger and Economizer
FO-234341	Routine	Scheduled Maint. (PM)	11/20/2012	11/21/2012	1	Generator Maintenance
FO-235048	Routine	Scheduled Maint. (PM)	12/11/2012	12/12/2012	1	PM - Chilled Water Coils - Drain (Old Main)
FO-235053	Routine	Scheduled Maint. (PM)	12/11/2012	12/12/2012	1	PM - Chilled Water Coils - Drain (Old Main)
FO-235060	Routine	Scheduled Maint. (PM)	11/28/2012	11/29/2012	1	Generator Maintenance
FO-209385	Routine	Scheduled Maint. (PM)	1/12/2012	1/12/2012	0	PM - Air Dryer
FO-208568	Routine	Scheduled Maint. (PM)	3/6/2012	3/6/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-210571	Routine	Scheduled Maint. (PM)	3/21/2012	3/21/2012	0	PM - Fan Coil/HV/AC Unit
FO-210569	Routine	Scheduled Maint. (PM)	3/21/2012	3/21/2012	0	PM - Fan Coil/HV/AC Unit
FO-212087	Routine	Scheduled Maint. (PM)	4/4/2012	4/4/2012	0	PM - Fan Coil/HV/AC Unit
FO-213601	Routine	Scheduled Maint. (PM)	5/3/2012	5/3/2012	0	PM - Forced Air Furnace (Jacob House) - Summer
FO-214047	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214048	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214049	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214050	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214051	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214052	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214053	Routine	Scheduled Maint. (PM)	5/11/2012	5/11/2012	0	PM - Sump Pump
FO-214755	Routine	Scheduled Maint. (PM)	5/9/2012	5/9/2012	0	PM - Air Handling Unit, over 50 Ton
FO-215134	Routine	Scheduled Maint. (PM)	5/9/2012	5/9/2012	0	PM - Fan Coil/HV/AC Unit
FO-216158	Routine	Scheduled Maint. (PM)	5/18/2012	5/18/2012	0	PM - Emergency Generator, Monthly
FO-221359	Routine	Scheduled Maint. (PM)	7/7/2012	7/7/2012	0	PM - Semi Annual Air Handling Unit Inspection
FO-211463	Low	Scheduled Maint. (PM)	5/14/2012	5/14/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-215191	Low	Scheduled Maint. (PM)	5/24/2012	5/24/2012	0	PM - Roof Sumps - Zone 2, Area 3
FO-217527	Low	Scheduled Maint. (PM)	6/4/2012	6/4/2012	0	PM - Harmsco Side Stream Filter
FO-217588	High	Scheduled Maint. (PM)	5/16/2012	5/16/2012	0	Generator Maintenance
FO-219715	Low	Scheduled Maint. (PM)	6/21/2012	6/21/2012	0	PM - Chemical Feed/Metering Pump/Controller
FO-224662	Routine	Scheduled Maint. (PM)	9/23/2012	9/23/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-224751	Low	Scheduled Maint. (PM)	8/1/2012	8/1/2012	0	PM - Sump Pump
FO-224753	Low	Scheduled Maint. (PM)	8/1/2012	8/1/2012	0	PM - Sump Pump
FO-224993	Routine	Scheduled Maint. (PM)	8/21/2012	8/21/2012	0	PM - Deaerator Tank
FO-225087	Routine	Scheduled Maint. (PM)	9/7/2012	9/7/2012	0	PM - Condensate Return Pump
FO-225088	Routine	Scheduled Maint. (PM)	9/7/2012	9/7/2012	0	PM - Condensate Return Pump
FO-227577	Routine	Scheduled Maint. (PM)	11/12/2012	11/12/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228038	Routine	Scheduled Maint. (PM)	10/8/2012	10/8/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228039	Routine	Scheduled Maint. (PM)	10/8/2012	10/8/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228040	Routine	Scheduled Maint. (PM)	10/8/2012	10/8/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228041	Routine	Scheduled Maint. (PM)	10/8/2012	10/8/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228687	Routine	Scheduled Maint. (PM)	11/30/2012	11/30/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228688	Routine	Scheduled Maint. (PM)	11/30/2012	11/30/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228786	Low	Scheduled Maint. (PM)	10/22/2012	10/22/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228787	Low	Scheduled Maint. (PM)	10/22/2012	10/22/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228788	Low	Scheduled Maint. (PM)	10/22/2012	10/22/2012	0	PM - Centrifugal Pump, over 1 H.P.
FO-228789	Low	Scheduled Maint. (PM)	10/22/2012	10/22/2012	0	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date	Total per Trade	
FO-229492	Low	Scheduled Maint. (PM)	11/3/2012	11/3/2012	0	PM - Cooling Tower Fan (Old Main)
FO-229508	Low	Scheduled Maint. (PM)	10/17/2012	10/17/2012	0	PM - Domestic Water Heater, Gas
FO-230647	Routine	Scheduled Maint. (PM)	11/14/2012	11/14/2012	0	PM - Air Handling Unit, over 50 Ton
FO-230648	Routine	Scheduled Maint. (PM)	11/14/2012	11/14/2012	0	PM - Air Handling Unit, over 50 Ton
FO-233611	Low	Scheduled Maint. (PM)	11/29/2012	11/29/2012	0	PM - Chemical Feed/Metering Pump/Controller
FO-233626	High	Scheduled Maint. (PM)	11/15/2012	11/15/2012	0	Generator Maintenance
FO-233629	Low	Scheduled Maint. (PM)	12/13/2012	12/13/2012	0	PM - Heat Exchanger and Economizer
FO-235051	Routine	Scheduled Maint. (PM)	12/12/2012	12/12/2012	0	PM - Chilled Water Coils - Drain (Old Main)
FO-209469	Routine	Scheduled Maint. (PM)	2/22/2012	2/21/2012	-1	PM - Heat Exchanger and Economizer
FO-211450	Routine	Scheduled Maint. (PM)	4/30/2012	4/29/2012	-1	PM - Water/Air Cooled Condenser
FO-214040	Low	Scheduled Maint. (PM)	4/25/2012	4/24/2012	-1	PM - Chilled Water Coils - Refill (Old Main)
FO-214043	Low	Scheduled Maint. (PM)	4/25/2012	4/24/2012	-1	PM - Chilled Water Coils - Refill (Old Main)
FO-214045	Low	Scheduled Maint. (PM)	4/25/2012	4/24/2012	-1	PM - Chilled Water Coils - Refill (Old Main)
FO-214046	Low	Scheduled Maint. (PM)	4/25/2012	4/24/2012	-1	PM - Chilled Water Coils - Refill (Old Main)
FO-219148	Low	Scheduled Maint. (PM)	7/12/2012	7/11/2012	-1	PM - Water Booster Pump
FO-221999	Low	Scheduled Maint. (PM)	7/22/2012	7/21/2012	-1	PM - Chemical Feed/Metering Pump/Controller
FO-227254	Low	Scheduled Maint. (PM)	10/24/2012	10/23/2012	-1	PM - Fire Pump, Main/Jockey
FO-228747	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228748	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228749	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228750	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228751	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228752	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228761	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-228762	Routine	Scheduled Maint. (PM)	11/1/2012	10/31/2012	-1	PM - Centrifugal Pump, over 1 H.P.
FO-230423	High	Scheduled Maint. (PM)	10/19/2012	10/18/2012	-1	Generator Maintenance
FO-233571	Routine	Scheduled Maint. (PM)	11/30/2012	11/29/2012	-1	PM - Fan Coil/HV/AC Unit
FO-211475	Routine	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-211489	Routine	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-211493	Routine	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-211494	Routine	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-211495	Routine	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-213615	Routine	Scheduled Maint. (PM)	4/19/2012	4/17/2012	-2	PM - Air Dryer
FO-211464	Low	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-211466	Low	Scheduled Maint. (PM)	5/16/2012	5/14/2012	-2	PM - Centrifugal Pump, over 1 H.P.verify pump operation
FO-214038	Low	Scheduled Maint. (PM)	4/26/2012	4/24/2012	-2	PM - Chilled Water Coils - Refill (Old Main)
FO-214041	Low	Scheduled Maint. (PM)	4/26/2012	4/24/2012	-2	PM - Chilled Water Coils - Refill (Old Main)
FO-224663	Routine	Scheduled Maint. (PM)	9/25/2012	9/23/2012	-2	PM - Centrifugal Pump, over 1 H.P.
FO-230474	Medium	Scheduled Maint. (PM)	10/31/2012	10/29/2012	-2	PM - Fan Coil/HV/AC Unit
FO-230475	Medium	Scheduled Maint. (PM)	10/31/2012	10/29/2012	-2	PM - Fan Coil/HV/AC Unit
FO-230476	Medium	Scheduled Maint. (PM)	10/31/2012	10/29/2012	-2	PM - Fan Coil/HV/AC Unit
FO-230477	Medium	Scheduled Maint. (PM)	10/31/2012	10/29/2012	-2	PM - Fan Coil/HV/AC Unit
FO-211541	Routine	Scheduled Maint. (PM)	5/17/2012	5/14/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-211542	Routine	Scheduled Maint. (PM)	5/17/2012	5/14/2012	-3	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date	Total per Trade	
FO-216155	Routine	Scheduled Maint. (PM)	6/4/2012	6/1/2012	-3	PM - Condensate Return Pump
FO-216159	Routine	Scheduled Maint. (PM)	5/18/2012	5/15/2012	-3	PM - Water Softener
FO-220287	Routine	Scheduled Maint. (PM)	7/23/2012	7/20/2012	-3	-> Consolidated PM items:
FO-220288	Routine	Scheduled Maint. (PM)	7/23/2012	7/20/2012	-3	-> Consolidated PM items:
FO-220289	Routine	Scheduled Maint. (PM)	7/23/2012	7/20/2012	-3	-> Consolidated PM items:
FO-213598	Low	Scheduled Maint. (PM)	4/20/2012	4/17/2012	-3	PM - Domestic Water Heater, Electric
FO-225082	Low	Scheduled Maint. (PM)	8/7/2012	8/4/2012	-3	PM - Harmsco Side Stream Filter
FO-225083	Low	Scheduled Maint. (PM)	8/7/2012	8/4/2012	-3	PM - Harmsco Side Stream Filter
FO-225579	Routine	Scheduled Maint. (PM)	10/24/2012	10/21/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-226149	Routine	Scheduled Maint. (PM)	10/31/2012	10/28/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-228685	Routine	Scheduled Maint. (PM)	12/3/2012	11/30/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-228686	Routine	Scheduled Maint. (PM)	12/3/2012	11/30/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-229500	Routine	Scheduled Maint. (PM)	10/19/2012	10/16/2012	-3	PM - Heat Exchanger and Economizer
FO-230759	Low	Scheduled Maint. (PM)	11/9/2012	11/6/2012	-3	PM - Domestic Water Heater, Electric
FO-230763	Low	Scheduled Maint. (PM)	11/16/2012	11/13/2012	-3	PM - Unit/Space Heater
FO-212860	Routine	Scheduled Maint. (PM)	4/20/2012	4/16/2012	-4	PM - Heat Exchanger and Economizer
FO-212861	Routine	Scheduled Maint. (PM)	4/20/2012	4/16/2012	-4	PM - Heat Exchanger and Economizer
FO-216157	Routine	Scheduled Maint. (PM)	6/5/2012	6/1/2012	-4	PM - Condensate Return Pump
FO-224994	Routine	Scheduled Maint. (PM)	8/25/2012	8/21/2012	-4	PM - Heat Exchanger and Economizer
FO-224995	Routine	Scheduled Maint. (PM)	8/25/2012	8/21/2012	-4	PM - Heat Exchanger and Economizer
FO-227190	Routine	Scheduled Maint. (PM)	11/3/2012	10/30/2012	-4	PM - Cooling Tower, 500 - 1000 Tons
FO-227255	Routine	Scheduled Maint. (PM)	11/3/2012	10/30/2012	-4	PM - Cooling Tower, 500 - 1000 Tons
FO-233572	Routine	Scheduled Maint. (PM)	12/3/2012	11/29/2012	-4	PM - Fan Coil/HV/AC Unit
FO-233610	Low	Scheduled Maint. (PM)	12/3/2012	11/29/2012	-4	PM - Chemical Feed/Metering Pump/Controller
FO-238038	Routine	Scheduled Maint. (PM)	1/28/2013	1/24/2013	-4	PM - Heat Exchanger and Economizer
FO-213594	Routine	Scheduled Maint. (PM)	4/23/2012	4/18/2012	-5	PM - Chemical Feed/Metering Pump/Controller
FO-213595	Routine	Scheduled Maint. (PM)	4/23/2012	4/18/2012	-5	PM - Chemical Feed/Metering Pump/Controller
FO-213596	Routine	Scheduled Maint. (PM)	4/23/2012	4/18/2012	-5	PM - Chemical Feed/Metering Pump/Controller
FO-213597	Routine	Scheduled Maint. (PM)	4/23/2012	4/18/2012	-5	PM - Chemical Feed/Metering Pump/Controller
FO-215193	High	Scheduled Maint. (PM)	5/1/2012	4/26/2012	-5	Generator Maintenance
FO-237376	Routine	Scheduled Maint. (PM)	1/15/2013	1/10/2013	-5	PM - Domestic Water Heater, Electric
FO-237377	Routine	Scheduled Maint. (PM)	1/15/2013	1/10/2013	-5	PM - Domestic Water Heater, Electric
FO-219026	Routine	Scheduled Maint. (PM)	7/12/2012	7/6/2012	-6	PM - Condensate Return Pump
FO-220291	Routine	Scheduled Maint. (PM)	7/26/2012	7/20/2012	-6	-> Consolidated PM items:
FO-220292	Routine	Scheduled Maint. (PM)	7/26/2012	7/20/2012	-6	-> Consolidated PM items:
FO-209547	Routine	Scheduled Maint. (PM)	2/27/2012	2/20/2012	-7	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-211490	Routine	Scheduled Maint. (PM)	5/21/2012	5/14/2012	-7	PM - Centrifugal Pump, over 1 H.P.
FO-211491	Routine	Scheduled Maint. (PM)	5/21/2012	5/14/2012	-7	PM - Centrifugal Pump, over 1 H.P.
FO-211492	Routine	Scheduled Maint. (PM)	5/21/2012	5/14/2012	-7	PM - Centrifugal Pump, over 1 H.P.
FO-212855	Routine	Scheduled Maint. (PM)	6/7/2012	5/31/2012	-7	PM - Centrifugal Pump, over 1 H.P.
FO-212856	Routine	Scheduled Maint. (PM)	6/7/2012	5/31/2012	-7	PM - Centrifugal Pump, over 1 H.P.
FO-227259	Routine	Scheduled Maint. (PM)	11/6/2012	10/30/2012	-7	PM - Cooling Tower, 500 - 1000 Tons
FO-230764	Low	Scheduled Maint. (PM)	11/29/2012	11/22/2012	-7	Gas Fired Furnace
FO-227345	Low	Scheduled Maint. (PM)	10/31/2012	10/23/2012	-8	PM - Fire Pump, Main/Jockey

			Finish Date	Due Date	Total per Trade	
FO-230267	Routine	Scheduled Maint. (PM)	11/9/2012	11/1/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-230597	Routine	Scheduled Maint. (PM)	11/14/2012	11/6/2012	-8	PM - Heat Exchanger and Economizer
FO-230598	Routine	Scheduled Maint. (PM)	11/14/2012	11/6/2012	-8	PM - Heat Exchanger and Economizer
FO-233619	Low	Scheduled Maint. (PM)	11/29/2012	11/21/2012	-8	PM - Chemical Feed/Metering Pump/Controller
FO-233620	Low	Scheduled Maint. (PM)	11/29/2012	11/21/2012	-8	PM - Chemical Feed/Metering Pump/Controller
FO-233621	Low	Scheduled Maint. (PM)	11/29/2012	11/21/2012	-8	PM - Chemical Feed/Metering Pump/Controller
FO-233622	Low	Scheduled Maint. (PM)	11/29/2012	11/21/2012	-8	PM - Chemical Feed/Metering Pump/Controller
FO-212535	Routine	Scheduled Maint. (PM)	4/20/2012	4/11/2012	-9	PM - Unspecified
FO-212536	Routine	Scheduled Maint. (PM)	4/20/2012	4/11/2012	-9	PM - Unspecified
FO-224983	Routine	Scheduled Maint. (PM)	8/30/2012	8/21/2012	-9	PM - Heat Exchanger and Economizer
FO-225037	Routine	Scheduled Maint. (PM)	10/23/2012	10/14/2012	-9	PM - Centrifugal Pump, over 1 H.P.
FO-225070	Routine	Scheduled Maint. (PM)	10/23/2012	10/14/2012	-9	PM - Centrifugal Pump, over 1 H.P.
FO-225086	Routine	Scheduled Maint. (PM)	9/7/2012	8/29/2012	-9	PM - Domestic Water Heater, Electric
FO-228741	Routine	Scheduled Maint. (PM)	11/9/2012	10/31/2012	-9	PM - Centrifugal Pump, over 1 H.P.
FO-214748	Routine	Scheduled Maint. (PM)	5/9/2012	4/29/2012	-10	PM - Condensate Return Pump
FO-214749	Routine	Scheduled Maint. (PM)	5/9/2012	4/29/2012	-10	PM - Condensate Return Pump
FO-219027	Routine	Scheduled Maint. (PM)	7/16/2012	7/6/2012	-10	PM - Condensate Return Pump
FO-219029	Routine	Scheduled Maint. (PM)	7/16/2012	7/6/2012	-10	PM - Condensate Return Pump
FO-225566	Routine	Scheduled Maint. (PM)	9/14/2012	9/4/2012	-10	PM - Domestic Water Heater, Gas
FO-237101	Routine	Scheduled Maint. (PM)	1/6/2013	12/27/2012	-10	Generator Maintenance, Monthly
FO-210572	Routine	Scheduled Maint. (PM)	4/1/2012	3/21/2012	-11	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-216156	Routine	Scheduled Maint. (PM)	6/12/2012	6/1/2012	-11	PM - Condensate Return Pump
FO-225060	Low	Scheduled Maint. (PM)	9/10/2012	8/30/2012	-11	PM - Domestic Water Heater, Electric
FO-227336	Low	Scheduled Maint. (PM)	10/29/2012	10/18/2012	-11	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
FO-227337	Low	Scheduled Maint. (PM)	10/29/2012	10/18/2012	-11	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
FO-233569	Routine	Scheduled Maint. (PM)	1/10/2013	12/30/2012	-11	PM - Punch Tubes - Chiller/Absorber
FO-212834	Routine	Scheduled Maint. (PM)	6/12/2012	5/31/2012	-12	PM - Water/Air Cooled Condenser
FO-216147	Routine	Scheduled Maint. (PM)	5/28/2012	5/16/2012	-12	PM - Fan Coil/HV/AC Unit
FO-216148	Routine	Scheduled Maint. (PM)	5/28/2012	5/16/2012	-12	PM - Fan Coil/HV/AC Unit
FO-219028	Routine	Scheduled Maint. (PM)	7/18/2012	7/6/2012	-12	PM - Condensate Return Pump
FO-233568	Routine	Scheduled Maint. (PM)	1/11/2013	12/30/2012	-12	PM - Punch Tubes - Chiller/Absorber
FO-220293	Routine	Scheduled Maint. (PM)	8/2/2012	7/20/2012	-13	-> Consolidated PM items:
FO-219711	Routine	Scheduled Maint. (PM)	7/11/2012	6/27/2012	-14	PM - Chemical Feed/Metering Pump/Controller
FO-212507	Low	Scheduled Maint. (PM)	5/1/2012	4/17/2012	-14	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-213577	Low	Scheduled Maint. (PM)	5/1/2012	4/17/2012	-14	PM - Domestic Water Heater, Electric
FO-230560	Routine	Scheduled Maint. (PM)	1/3/2013	12/20/2012	-14	PM - Centrifugal Pump, over 1 H.P.
FO-209583	Routine	Scheduled Maint. (PM)	3/1/2012	2/15/2012	-15	PM - Water Softener
FO-222459	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Heat Exchanger and Economizer
FO-222460	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Heat Exchanger and Economizer
FO-222461	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Heat Exchanger and Economizer
FO-222462	Routine	Scheduled Maint. (PM)	8/15/2012	7/31/2012	-15	PM - Heat Exchanger and Economizer
FO-219700	Low	Scheduled Maint. (PM)	7/12/2012	6/27/2012	-15	PM - Water Booster Pump
FO-230382	Low	Scheduled Maint. (PM)	11/29/2012	11/14/2012	-15	PM - Outside/Fresh Air Intake Screens
FO-230561	Routine	Scheduled Maint. (PM)	1/4/2013	12/20/2012	-15	PM - Centrifugal Pump, over 1 H.P.

Finish Date Due Date

Total per Trade

FO-225036	Routine	Scheduled Maint. (PM)	10/23/2012	10/7/2012	-16	PM - Centrifugal Pump, over 1 H.P.
FO-227269	Routine	Scheduled Maint. (PM)	11/1/2012	10/14/2012	-18	PM - Sump Pump
FO-227270	Routine	Scheduled Maint. (PM)	11/1/2012	10/14/2012	-18	PM - Sump Pump
FO-229442	Routine	Scheduled Maint. (PM)	11/5/2012	10/18/2012	-18	PM - Chemical Feed/Metering Pump/Controller
FO-229443	Routine	Scheduled Maint. (PM)	11/5/2012	10/18/2012	-18	PM - Chemical Feed/Metering Pump/Controller
FO-229444	Routine	Scheduled Maint. (PM)	11/5/2012	10/18/2012	-18	PM - Chemical Feed/Metering Pump/Controller
FO-229445	Routine	Scheduled Maint. (PM)	11/5/2012	10/18/2012	-18	PM - Chemical Feed/Metering Pump/Controller
FO-230562	Routine	Scheduled Maint. (PM)	1/7/2013	12/20/2012	-18	PM - Centrifugal Pump, over 1 H.P.
FO-232256	Routine	Scheduled Maint. (PM)	12/3/2012	11/15/2012	-18	PM - Water Softener
FO-209009	Routine	Scheduled Maint. (PM)	3/7/2012	2/17/2012	-19	PM - Centrifugal Pump, over 1 H.P.
FO-222030	Routine	Scheduled Maint. (PM)	8/2/2012	7/14/2012	-19	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-230563	Routine	Scheduled Maint. (PM)	1/8/2013	12/20/2012	-19	PM - Centrifugal Pump, over 1 H.P.
FO-229499	Routine	Scheduled Maint. (PM)	11/5/2012	10/16/2012	-20	PM - Heat Exchanger and Economizer
FO-232890	Low	Scheduled Maint. (PM)	12/10/2012	11/20/2012	-20	PM - Harmsco Side Stream Filter
FO-227281	Low	Scheduled Maint. (PM)	10/18/2012	9/26/2012	-22	PM - Domestic Water Heater, Electric
FO-230408	High	Scheduled Maint. (PM)	11/9/2012	10/18/2012	-22	Generator Maintenance
FO-230632	Routine	Scheduled Maint. (PM)	1/11/2013	12/20/2012	-22	PM - Centrifugal Pump, over 1 H.P.
FO-230634	Routine	Scheduled Maint. (PM)	1/11/2013	12/20/2012	-22	PM - Centrifugal Pump, over 1 H.P.
FO-230799	Routine	Scheduled Maint. (PM)	11/14/2012	10/22/2012	-23	PM - Domestic Water Heater, Gas
FO-211439	Routine	Scheduled Maint. (PM)	6/7/2012	5/14/2012	-24	PM - Centrifugal Pump, over 1 H.P.
FO-211440	Routine	Scheduled Maint. (PM)	6/7/2012	5/14/2012	-24	PM - Centrifugal Pump, over 1 H.P.
FO-211441	Routine	Scheduled Maint. (PM)	6/7/2012	5/14/2012	-24	PM - Centrifugal Pump, over 1 H.P.
FO-211442	Routine	Scheduled Maint. (PM)	6/7/2012	5/14/2012	-24	PM - Centrifugal Pump, over 1 H.P.
FO-211443	Routine	Scheduled Maint. (PM)	6/7/2012	5/14/2012	-24	PM - Centrifugal Pump, over 1 H.P.
FO-227200	Routine	Scheduled Maint. (PM)	11/5/2012	10/12/2012	-24	PM - Chemical Feed/Metering Pump/Controller
FO-227201	Routine	Scheduled Maint. (PM)	11/5/2012	10/12/2012	-24	PM - Chemical Feed/Metering Pump/Controller
FO-227202	Routine	Scheduled Maint. (PM)	11/5/2012	10/12/2012	-24	PM - Chemical Feed/Metering Pump/Controller
FO-232891	Routine	Scheduled Maint. (PM)	12/14/2012	11/20/2012	-24	PM - Harmsco Side Stream Filter
FO-235059	Routine	Scheduled Maint. (PM)	12/23/2012	11/29/2012	-24	Generator Maintenance
FO-226820	Routine	Scheduled Maint. (PM)	11/1/2012	10/7/2012	-25	PM - Sump Pump
FO-226821	Routine	Scheduled Maint. (PM)	11/1/2012	10/7/2012	-25	PM - Sump Pump
FO-227347	Routine	Scheduled Maint. (PM)	11/1/2012	10/7/2012	-25	PB - B&G Series 100 Pump
FO-233551	Routine	Scheduled Maint. (PM)	1/24/2013	12/30/2012	-25	PM - Punch Tubes - Chiller/Absorber
FO-209490	Routine	Scheduled Maint. (PM)	3/19/2012	2/21/2012	-27	PM - Heat Exchanger and Economizer
FO-229501	Routine	Scheduled Maint. (PM)	11/12/2012	10/16/2012	-27	PM - Heat Exchanger and Economizer
FO-229503	Routine	Scheduled Maint. (PM)	11/12/2012	10/16/2012	-27	PM - Heat Exchanger and Economizer
FO-208387	Routine	Scheduled Maint. (PM)	1/27/2012	12/30/2011	-28	PM - Punch Tubes - Chiller/Absorber
FO-209491	Routine	Scheduled Maint. (PM)	3/20/2012	2/21/2012	-28	PM - Heat Exchanger and Economizer
FO-212502	Routine	Scheduled Maint. (PM)	5/9/2012	4/11/2012	-28	PM - Air Dryer
FO-228709	Routine	Scheduled Maint. (PM)	11/12/2012	10/15/2012	-28	PM - Centrifugal Pump, over 1 H.P.
FO-228710	Routine	Scheduled Maint. (PM)	11/12/2012	10/15/2012	-28	PM - Centrifugal Pump, over 1 H.P.
FO-228711	Routine	Scheduled Maint. (PM)	11/12/2012	10/15/2012	-28	PM - Centrifugal Pump, over 1 H.P.
FO-230282	Routine	Scheduled Maint. (PM)	12/3/2012	11/1/2012	-32	PM - Unspecified
FO-230283	Routine	Scheduled Maint. (PM)	12/3/2012	11/1/2012	-32	PM - Unspecified

			Finish Date	Due Date	Total per Trade	
FO-208546	Routine	Scheduled Maint. (PM)	2/1/2012	12/30/2011	-33	PM - Punch Tubes - Chiller/Absorber
FO-228755	Routine	Scheduled Maint. (PM)	12/3/2012	10/31/2012	-33	PM - Centrifugal Pump, over 1 H.P.
FO-225586	Routine	Scheduled Maint. (PM)	10/9/2012	9/5/2012	-34	PM - Heat Exchanger and Economizer
FO-209553	Low	Scheduled Maint. (PM)	4/12/2012	3/6/2012	-37	PM - Harmsco Side Stream Filter
FO-208415	Routine	Scheduled Maint. (PM)	2/6/2012	12/30/2011	-38	PM - Punch Tubes - Chiller/Absorber
FO-228757	Routine	Scheduled Maint. (PM)	12/8/2012	10/31/2012	-38	PM - Centrifugal Pump, over 1 H.P.
FO-208416	Routine	Scheduled Maint. (PM)	2/7/2012	12/30/2011	-39	PM - Punch Tubes - Chiller/Absorber
FO-208417	Routine	Scheduled Maint. (PM)	2/8/2012	12/30/2011	-40	PM - Punch Tubes - Chiller/Absorber
FO-208418	Routine	Scheduled Maint. (PM)	2/9/2012	12/30/2011	-41	PM - Punch Tubes - Chiller/Absorber
FO-226818	Routine	Scheduled Maint. (PM)	11/1/2012	9/21/2012	-41	PM - Domestic Water Heater, Gas
FO-226819	Routine	Scheduled Maint. (PM)	11/1/2012	9/21/2012	-41	PM - Domestic Water Heater, Gas
FO-228639	Routine	Scheduled Maint. (PM)	1/11/2013	11/30/2012	-42	PM - Centrifugal Pump, over 1 H.P.
FO-228642	Routine	Scheduled Maint. (PM)	1/11/2013	11/30/2012	-42	PM - Centrifugal Pump, over 1 H.P.
FO-225084	Low	Scheduled Maint. (PM)	9/19/2012	8/5/2012	-45	PM - Unspecified
FO-229440	Routine	Scheduled Maint. (PM)	12/3/2012	10/18/2012	-46	PM - Unspecified
FO-229441	Routine	Scheduled Maint. (PM)	12/3/2012	10/18/2012	-46	PM - Unspecified
FO-226169	Routine	Scheduled Maint. (PM)	11/1/2012	9/15/2012	-47	PM - Unit/Space Heater
FO-226170	Routine	Scheduled Maint. (PM)	11/1/2012	9/15/2012	-47	PM - Unit/Space Heater
FO-226171	Routine	Scheduled Maint. (PM)	11/1/2012	9/15/2012	-47	PM - Unit/Space Heater
FO-226172	Routine	Scheduled Maint. (PM)	11/1/2012	9/15/2012	-47	PM - Unit/Space Heater
FO-226173	Routine	Scheduled Maint. (PM)	11/1/2012	9/15/2012	-47	PM - Unit/Space Heater
FO-209013	Low	Scheduled Maint. (PM)	5/9/2012	3/22/2012	-48	PM - Centrifugal Pump, over 1 H.P.
FO-227176	Routine	Scheduled Maint. (PM)	11/30/2012	10/12/2012	-49	PM - Unspecified
FO-227177	Routine	Scheduled Maint. (PM)	11/30/2012	10/12/2012	-49	PM - Unspecified
FO-235409	Routine	Scheduled Maint. (PM)	1/24/2013	12/4/2012	-51	PM - Harmsco Side Stream Filter
FO-235410	Routine	Scheduled Maint. (PM)	1/24/2013	12/4/2012	-51	PM - Harmsco Side Stream Filter
FO-206336	Medium	Scheduled Maint. (PM)	1/30/2012	12/5/2011	-56	PM - Harmsco Side Stream Filter
FO-206337	Medium	Scheduled Maint. (PM)	1/30/2012	12/5/2011	-56	PM - Harmsco Side Stream Filter
FO-208663	Routine	Scheduled Maint. (PM)	3/10/2012	1/11/2012	-59	PM - Heat Pumps (5057 Woodward)
FO-230402	Routine	Scheduled Maint. (PM)	12/23/2012	10/24/2012	-60	Generator Maintenance
FO-208532	Routine	Scheduled Maint. (PM)	2/29/2012	12/30/2011	-61	PM - Punch Tubes - Chiller/Absorber
FO-221286	Routine	Scheduled Maint. (PM)	11/1/2012	8/30/2012	-63	PM - Water/Air Cooled Condenser
FO-221295	Routine	Scheduled Maint. (PM)	11/1/2012	8/30/2012	-63	PM - Water/Air Cooled Condenser
FO-221296	Routine	Scheduled Maint. (PM)	11/1/2012	8/30/2012	-63	PM - Water/Air Cooled Condenser
FO-226167	Routine	Scheduled Maint. (PM)	11/29/2012	9/27/2012	-63	PM - Vacuum Pump
FO-226168	Routine	Scheduled Maint. (PM)	11/1/2012	8/30/2012	-63	PM - Domestic Water Heater, Electric
FO-227174	Routine	Scheduled Maint. (PM)	11/30/2012	9/28/2012	-63	PM - Unspecified
FO-227175	Routine	Scheduled Maint. (PM)	11/30/2012	9/28/2012	-63	PM - Unspecified
FO-227578	Emergency	Scheduled Maint. (PM)	11/16/2012	9/14/2012	-63	Generator Test
FO-209337	Routine	Scheduled Maint. (PM)	4/2/2012	1/24/2012	-69	PM - Air Dryer
FO-226786	Routine	Scheduled Maint. (PM)	11/30/2012	9/21/2012	-70	PM - Unspecified
FO-226787	Routine	Scheduled Maint. (PM)	11/30/2012	9/21/2012	-70	PM - Unspecified
FO-226160	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater
FO-226161	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater

			Finish Date	Due Date	Total per Trade	
FO-226162	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater
FO-226163	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater
FO-226165	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater
FO-226166	Routine	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	PM - Unit/Space Heater
FO-208523	Routine	Scheduled Maint. (PM)	3/15/2012	12/30/2011	-76	PM - Punch Tubes - Chiller/Absorber
FO-222506	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222507	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222508	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222529	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222530	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222531	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222532	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-222533	Routine	Scheduled Maint. (PM)	10/31/2012	8/16/2012	-76	PM - Heat Pumps (5057 Woodward)
FO-208847	Low	Scheduled Maint. (PM)	5/10/2012	2/23/2012	-77	PM - Centrifugal Pump, over 1 H.P.
FO-208848	Low	Scheduled Maint. (PM)	5/10/2012	2/23/2012	-77	PM - Centrifugal Pump, over 1 H.P.
FO-222527	Low	Scheduled Maint. (PM)	10/31/2012	8/15/2012	-77	PM - Sump Pump
FO-222528	Low	Scheduled Maint. (PM)	10/31/2012	8/15/2012	-77	PM - Sump Pump
FO-219061	Low	Scheduled Maint. (PM)	10/22/2012	8/4/2012	-79	PM - Boiler, Hydronic/Hot Water, greater than 1000 MBH
FO-226132	Routine	Scheduled Maint. (PM)	11/30/2012	9/11/2012	-80	PM - Unspecified
FO-226133	Routine	Scheduled Maint. (PM)	11/30/2012	9/11/2012	-80	PM - Unspecified
FO-208542	Routine	Scheduled Maint. (PM)	3/21/2012	12/30/2011	-82	PM - Punch Tubes - Chiller/Absorber
FO-208868	Routine	Scheduled Maint. (PM)	3/6/2012	12/14/2011	-83	PM - Cooling Tower, 500 - 1000 Tons
FO-208327	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208328	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208329	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208331	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208332	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208340	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208341	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208346	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208347	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208357	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208358	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208359	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208361	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208362	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208363	Routine	Scheduled Maint. (PM)	3/12/2012	12/20/2011	-83	PM - Centrifugal Pump, over 1 H.P.
FO-208298	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208299	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208300	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208301	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208302	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208303	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.
FO-208304	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date			Total per Trade
FO-208305	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-208306	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-208307	Routine	Scheduled Maint. (PM)	3/13/2012	12/20/2011	-84	PM - Centrifugal Pump, over 1 H.P.	
FO-209430	Low	Scheduled Maint. (PM)	5/10/2012	2/15/2012	-85	PM - Sump Pump	
FO-209431	Low	Scheduled Maint. (PM)	5/10/2012	2/15/2012	-85	PM - Sump Pump	
FO-224673	Low	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Chemical Feed/Metering Pump/Controller	
FO-224724	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224725	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224726	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224727	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224737	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224741	Routine	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-224742	Low	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Chemical Feed/Metering Pump/Controller	
FO-224743	Low	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Chemical Feed/Metering Pump/Controller	
FO-224744	Low	Scheduled Maint. (PM)	10/31/2012	8/7/2012	-85	PM - Chemical Feed/Metering Pump/Controller	
FO-225564	Routine	Scheduled Maint. (PM)	11/30/2012	9/4/2012	-87	PM - Unspecified	
FO-225565	Routine	Scheduled Maint. (PM)	11/30/2012	9/4/2012	-87	PM - Unspecified	
FO-209413	Routine	Scheduled Maint. (PM)	5/10/2012	2/10/2012	-90	PM - Air Dryer	
FO-209556	Routine	Scheduled Maint. (PM)	5/10/2012	2/10/2012	-90	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-222518	Routine	Scheduled Maint. (PM)	10/30/2012	8/1/2012	-90	PM - Chemical Feed/Metering Pump/Controller	
FO-222519	Routine	Scheduled Maint. (PM)	10/30/2012	8/1/2012	-90	PM - Chemical Feed/Metering Pump/Controller	
FO-222520	Routine	Scheduled Maint. (PM)	10/30/2012	8/1/2012	-90	PM - Chemical Feed/Metering Pump/Controller	
FO-208662	Routine	Scheduled Maint. (PM)	4/11/2012	1/11/2012	-91	PM - Heat Pumps (5057 Woodward)	
FO-221287	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221288	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221289	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221290	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221291	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221292	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221311	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221312	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221313	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221317	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221318	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221319	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221320	Routine	Scheduled Maint. (PM)	11/29/2012	8/30/2012	-91	PM - Water/Air Cooled Condenser	
FO-221909	Routine	Scheduled Maint. (PM)	11/30/2012	8/30/2012	-92	PM - Water/Air Cooled Condenser	
FO-225059	Routine	Scheduled Maint. (PM)	11/30/2012	8/29/2012	-93	PM - Domestic Water Heater, Steam	
FO-209014	Low	Scheduled Maint. (PM)	4/17/2012	1/14/2012	-94	PM - Water/Air Cooled Condenser	
FO-208217	Routine	Scheduled Maint. (PM)	4/3/2012	12/30/2011	-95	PM - Punch Tubes - Chiller/Absorber	
FO-208218	Routine	Scheduled Maint. (PM)	4/4/2012	12/30/2011	-96	PM - Punch Tubes - Chiller/Absorber	
FO-219033	Routine	Scheduled Maint. (PM)	10/10/2012	7/5/2012	-97	PM - Boiler, Hydronic/Hot Water, greater than 1000 MBH	
FO-219034	Routine	Scheduled Maint. (PM)	10/10/2012	7/5/2012	-97	PM - Condensate Return Pump	
FO-219035	Routine	Scheduled Maint. (PM)	10/10/2012	7/5/2012	-97	PM - Condensate Return Pump	

			Finish Date	Due Date	Total per Trade	
FO-220454	Routine	Scheduled Maint. (PM)	11/6/2012	7/27/2012	-102	PM - Sump Pump
FO-220455	Routine	Scheduled Maint. (PM)	11/6/2012	7/27/2012	-102	PM - Sump Pump
FO-208926	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.
FO-208927	Routine	Scheduled Maint. (PM)	3/12/2012	11/30/2011	-103	PM - Centrifugal Pump, over 1 H.P.
FO-208342	Routine	Scheduled Maint. (PM)	3/12/2012	11/29/2011	-104	PM - Cooling Tower, 500 - 1000 Tons
FO-208368	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208348	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208349	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208350	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208351	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208315	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208316	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208317	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208318	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208319	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208320	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-208321	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209041	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209042	Routine	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209029	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209030	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209031	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209032	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209033	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-209034	Low	Scheduled Maint. (PM)	3/13/2012	11/30/2011	-104	PM - Centrifugal Pump, over 1 H.P.
FO-221919	Routine	Scheduled Maint. (PM)	11/5/2012	7/24/2012	-104	PM - Heat Exchanger and Economizer
FO-208396	Routine	Scheduled Maint. (PM)	5/10/2012	1/26/2012	-105	PM - Sump Pump
FO-208397	Routine	Scheduled Maint. (PM)	5/10/2012	1/26/2012	-105	PM - Sump Pump
FO-209578	Routine	Scheduled Maint. (PM)	5/9/2012	1/24/2012	-106	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209409	Routine	Scheduled Maint. (PM)	5/10/2012	1/24/2012	-107	PM - Air Dryer
FO-209470	Low	Scheduled Maint. (PM)	5/8/2012	1/17/2012	-112	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208343	Routine	Scheduled Maint. (PM)	3/12/2012	11/20/2011	-113	PM - Centrifugal Pump, over 1 H.P.
FO-208344	Routine	Scheduled Maint. (PM)	3/12/2012	11/20/2011	-113	PM - Centrifugal Pump, over 1 H.P.
FO-219057	Routine	Scheduled Maint. (PM)	11/29/2012	8/5/2012	-116	-> Consolidated PM items:
FO-208937	Routine	Scheduled Maint. (PM)	5/11/2012	1/14/2012	-118	PM - Punch Tubes - Chiller/Absorber
FO-208493	Routine	Scheduled Maint. (PM)	5/9/2012	1/11/2012	-119	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208500	Routine	Scheduled Maint. (PM)	5/9/2012	1/11/2012	-119	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208501	Routine	Scheduled Maint. (PM)	5/9/2012	1/11/2012	-119	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208938	Routine	Scheduled Maint. (PM)	5/11/2012	1/10/2012	-122	PM - Domestic Water Heater, Electric
FO-208939	Routine	Scheduled Maint. (PM)	5/11/2012	1/10/2012	-122	PM - Domestic Water Heater, Electric
FO-208940	Routine	Scheduled Maint. (PM)	5/11/2012	1/10/2012	-122	PM - Domestic Water Heater, Electric
FO-208914	Routine	Scheduled Maint. (PM)	3/6/2012	11/4/2011	-123	PM - Chemical Feed/Metering Pump/Controller
FO-208852	Routine	Scheduled Maint. (PM)	5/2/2012	12/30/2011	-124	PM - Punch Tubes - Chiller/Absorber
FO-208851	Routine	Scheduled Maint. (PM)	5/3/2012	12/30/2011	-125	PM - Punch Tubes - Chiller/Absorber

Finish Date Due Date**Total per Trade**

FO-208633	Routine	Scheduled Maint. (PM)	4/27/2012	12/19/2011	-130	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208634	Routine	Scheduled Maint. (PM)	4/27/2012	12/19/2011	-130	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208498	Routine	Scheduled Maint. (PM)	5/9/2012	12/30/2011	-131	PM - Punch Tubes - Chiller/Absorber
FO-208499	Routine	Scheduled Maint. (PM)	5/9/2012	12/30/2011	-131	PM - Punch Tubes - Chiller/Absorber
FO-208216	Routine	Scheduled Maint. (PM)	5/10/2012	12/30/2011	-132	PM - Punch Tubes - Chiller/Absorber
FO-208370	Routine	Scheduled Maint. (PM)	5/10/2012	12/30/2011	-132	PM - Punch Tubes - Chiller/Absorber
FO-209058	Routine	Scheduled Maint. (PM)	5/11/2012	12/30/2011	-133	PM - Punch Tubes - Chiller/Absorber
FO-208369	Routine	Scheduled Maint. (PM)	3/13/2012	10/31/2011	-134	PM - Centrifugal Pump, over 1 H.P.
FO-209503	Routine	Scheduled Maint. (PM)	3/23/2012	11/10/2011	-134	PM - Air Compressor, Reciprocating 5-40 H.P.Start-up oil should be in the system for 100 hours - Monday 3/26 - Q
FO-208845	Low	Scheduled Maint. (PM)	5/10/2012	12/26/2011	-136	PM - Air Dryer
FO-209466	Routine	Scheduled Maint. (PM)	5/9/2012	12/20/2011	-141	PM - Air Dryer
FO-208846	Low	Scheduled Maint. (PM)	5/10/2012	12/19/2011	-143	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-208658	Routine	Scheduled Maint. (PM)	4/27/2012	12/4/2011	-145	PM - Heat Exchanger and Economizer
FO-208659	Routine	Scheduled Maint. (PM)	4/27/2012	12/4/2011	-145	PM - Heat Exchanger and Economizer
FO-209027	Low	Scheduled Maint. (PM)	3/13/2012	10/15/2011	-150	PM - Heat Exchanger and Economizer
FO-208296	Routine	Scheduled Maint. (PM)	3/13/2012	10/14/2011	-151	PM - Chemical Feed/Metering Pump/Controller
FO-208297	Routine	Scheduled Maint. (PM)	3/13/2012	10/14/2011	-151	PM - Chemical Feed/Metering Pump/Controller
FO-208494	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208495	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208496	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208502	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208511	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208512	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208517	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208518	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208519	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208520	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208521	Routine	Scheduled Maint. (PM)	5/9/2012	11/30/2011	-161	PM - Centrifugal Pump, over 1 H.P.
FO-208270	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-208271	Routine	Scheduled Maint. (PM)	5/10/2012	11/30/2011	-162	PM - Centrifugal Pump, over 1 H.P.
FO-208878	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208879	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208880	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208882	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208883	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208884	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208885	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208886	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208887	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208888	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208889	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208890	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208891	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208892	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.

			Finish Date	Due Date	Total per Trade	
FO-208893	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208894	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208895	Routine	Scheduled Maint. (PM)	5/11/2012	11/30/2011	-163	PM - Centrifugal Pump, over 1 H.P.
FO-208367	Routine	Scheduled Maint. (PM)	3/13/2012	9/30/2011	-165	PM - Centrifugal Pump, over 1 H.P.
FO-208219	Low	Scheduled Maint. (PM)	5/10/2012	11/25/2011	-167	PM - Water/Air Cooled Condenser
FO-208220	Low	Scheduled Maint. (PM)	5/10/2012	11/25/2011	-167	PM - Water/Air Cooled Condenser
FO-208497	Low	Scheduled Maint. (PM)	5/9/2012	11/23/2011	-168	PM - Roof Sumps - Zone 2, Area 3
FO-208503	Low	Scheduled Maint. (PM)	5/9/2012	11/23/2011	-168	PM - Roof Sumps - Zone 2, Area 3
FO-208505	Low	Scheduled Maint. (PM)	5/9/2012	11/23/2011	-168	PM - Roof Sumps - Zone 2, Area 3
FO-208513	Low	Scheduled Maint. (PM)	5/9/2012	11/23/2011	-168	PM - Roof Sumps - Zone 2, Area 3
FO-208522	Low	Scheduled Maint. (PM)	5/9/2012	11/23/2011	-168	PM - Roof Sumps - Zone 2, Area 3
FO-208275	Low	Scheduled Maint. (PM)	5/10/2012	11/23/2011	-169	PM - Roof Sumps - Zone 2, Area 3
FO-208951	Low	Scheduled Maint. (PM)	5/11/2012	11/23/2011	-170	PM - Roof Sumps - Zone 2, Area 3
FO-211467	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211468	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211469	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211470	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211471	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211472	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-211473	Low	Scheduled Maint. (PM)	10/31/2012	5/14/2012	-170	PM - Centrifugal Pump, over 1 H.P.
FO-208613	Routine	Scheduled Maint. (PM)	5/9/2012	11/20/2011	-171	PM - Centrifugal Pump, over 1 H.P.
FO-208615	Routine	Scheduled Maint. (PM)	5/9/2012	11/20/2011	-171	PM - Centrifugal Pump, over 1 H.P.
FO-208506	Low	Scheduled Maint. (PM)	5/9/2012	11/20/2011	-171	PM - Outside/Fresh Air Intake Screens
FO-208507	Low	Scheduled Maint. (PM)	5/9/2012	11/20/2011	-171	PM - Outside/Fresh Air Intake Screens
FO-209131	Routine	Scheduled Maint. (PM)	5/11/2012	11/20/2011	-173	PM - Centrifugal Pump, over 1 H.P.
FO-209019	Low	Scheduled Maint. (PM)	4/17/2012	10/24/2011	-176	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209020	Low	Scheduled Maint. (PM)	4/17/2012	10/24/2011	-176	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208508	Routine	Scheduled Maint. (PM)	5/9/2012	11/14/2011	-177	PM - Water/Air Cooled Condenser
FO-208509	Routine	Scheduled Maint. (PM)	5/9/2012	11/14/2011	-177	PM - Water/Air Cooled Condenser
FO-208510	Routine	Scheduled Maint. (PM)	5/9/2012	11/14/2011	-177	PM - Water/Air Cooled Condenser
FO-209393	Low	Scheduled Maint. (PM)	5/9/2012	11/14/2011	-177	PM - Outside/Fresh Air Intake Screens
FO-209414	Routine	Scheduled Maint. (PM)	5/10/2012	11/10/2011	-182	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-212833	Routine	Scheduled Maint. (PM)	11/29/2012	5/31/2012	-182	PM - Water/Air Cooled Condenser
FO-208603	Routine	Scheduled Maint. (PM)	5/1/2012	10/31/2011	-183	PM - Centrifugal Pump, over 1 H.P.
FO-208614	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-208617	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-208618	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-208620	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-208622	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-209136	Routine	Scheduled Maint. (PM)	5/9/2012	10/31/2011	-191	PM - Centrifugal Pump, over 1 H.P.
FO-208224	Low	Scheduled Maint. (PM)	5/10/2012	11/1/2011	-191	-> Consolidated PM items:Annual task: W990025 - PM - Steam Valves to PreHeat Coils - Open (Old Main)Annual ta
FO-208227	Low	Scheduled Maint. (PM)	5/10/2012	11/1/2011	-191	-> Consolidated PM items:Annual task: W990025 - PM - Steam Valves to PreHeat Coils - Open (Old Main)Annual ta
FO-208229	Low	Scheduled Maint. (PM)	5/10/2012	11/1/2011	-191	-> Consolidated PM items:Annual task: W990025 - PM - Steam Valves to PreHeat Coils - Open (Old Main)Annual ta
FO-208230	Low	Scheduled Maint. (PM)	5/10/2012	11/1/2011	-191	-> Consolidated PM items:Annual task: W990025 - PM - Steam Valves to PreHeat Coils - Open (Old Main)Annual ta

			Finish Date	Due Date			Total per Trade
FO-208619	Routine	Scheduled Maint. (PM)	5/10/2012	10/31/2011	-192	PM - Centrifugal Pump, over 1 H.P.	
FO-208621	Routine	Scheduled Maint. (PM)	5/10/2012	10/31/2011	-192	PM - Centrifugal Pump, over 1 H.P.	
FO-208237	Routine	Scheduled Maint. (PM)	5/10/2012	10/30/2011	-193	PM - Cooling Tower, 500 - 1000 Tons	
FO-208515	Routine	Scheduled Maint. (PM)	5/9/2012	10/29/2011	-193	PM - Condensate Return Pump	
FO-208516	Routine	Scheduled Maint. (PM)	5/9/2012	10/29/2011	-193	PM - Condensate Return Pump	
FO-209018	Low	Scheduled Maint. (PM)	5/7/2012	10/24/2011	-196	PM - Domestic Water Heater, Electric	
FO-209467	Routine	Scheduled Maint. (PM)	5/9/2012	10/24/2011	-198	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-209017	Low	Scheduled Maint. (PM)	5/7/2012	10/17/2011	-203	PM - Domestic Water Heater, Electric	
FO-208233	Routine	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	PM - Chemical Feed/Metering Pump/Controller	
FO-208234	Routine	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	PM - Chemical Feed/Metering Pump/Controller	
FO-208235	Routine	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	PM - Chemical Feed/Metering Pump/Controller	
FO-208236	Routine	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	PM - Chemical Feed/Metering Pump/Controller	
FO-208222	Low	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	-> Consolidated PM items:Annual task: W990027 - PM - Steam to Air Handling Unit - Open for Winter (Old Main)A	
FO-208225	Low	Scheduled Maint. (PM)	5/10/2012	10/18/2011	-205	-> Consolidated PM items:Annual task: W990027 - PM - Steam to Air Handling Unit - Open for Winter (Old Main)A	
FO-208324	Routine	Scheduled Maint. (PM)	3/13/2012	8/15/2011	-211	PM - Water/Air Cooled Condenser	
FO-208611	Routine	Scheduled Maint. (PM)	4/19/2012	9/9/2011	-223	Boiler - Open Clean and Close 48 inch Boilers	
FO-208627	Routine	Scheduled Maint. (PM)	4/11/2012	8/25/2011	-230	PM - Fan Coil/HV/AC Unit	
FO-208628	Routine	Scheduled Maint. (PM)	4/11/2012	8/25/2011	-230	PM - Fan Coil/HV/AC Unit	
FO-208333	Routine	Scheduled Maint. (PM)	3/13/2012	7/22/2011	-235	PM - Heat Exchanger and Economizer	
FO-184707	Routine	Scheduled Maint. (PM)	3/29/2012	4/29/2007	-1796	PM - Chiller: Centrifugal/Screw	

E - Area 3 Auxiliary Eng

299 of 437 68%

FO-211301	Low	Scheduled Maint. (PM)	3/16/2012	5/14/2012	59	PM - Centrifugal Pump, over 1 H.P.	
FO-211302	Low	Scheduled Maint. (PM)	3/16/2012	5/14/2012	59	PM - Centrifugal Pump, over 1 H.P.	
FO-211304	Low	Scheduled Maint. (PM)	3/16/2012	5/14/2012	59	PM - Centrifugal Pump, over 1 H.P.	
FO-211305	Low	Scheduled Maint. (PM)	3/16/2012	5/14/2012	59	PM - Centrifugal Pump, over 1 H.P.	
FO-211300	Low	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Punch Tubes - Chiller/Absorber	
FO-211303	Low	Scheduled Maint. (PM)	3/16/2012	4/29/2012	44	PM - Cooling Tower, 500 - 1000 Tons	
FO-208477	Low	Scheduled Maint. (PM)	2/2/2012	3/5/2012	32	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208469	Low	Scheduled Maint. (PM)	1/18/2012	2/13/2012	26	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208470	Low	Scheduled Maint. (PM)	1/18/2012	2/13/2012	26	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208980	Routine	Scheduled Maint. (PM)	2/6/2012	3/2/2012	25	PM - Air Handling Unit, over 50 Ton	
FO-208476	Low	Scheduled Maint. (PM)	2/2/2012	2/27/2012	25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208407	Routine	Scheduled Maint. (PM)	1/20/2012	2/12/2012	23	PM - Fire Pump, Main/Jockey	
FO-215130	Low	Scheduled Maint. (PM)	5/2/2012	5/24/2012	22	PM - Roof Sumps - Zone 2, Area 3	
FO-224730	Low	Scheduled Maint. (PM)	7/31/2012	8/22/2012	22	PM - Fire Pump, Main/Jockey	
FO-224731	Low	Scheduled Maint. (PM)	7/31/2012	8/22/2012	22	PM - Fire Pump, Main/Jockey	
FO-212796	Low	Scheduled Maint. (PM)	4/2/2012	4/23/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-212797	Low	Scheduled Maint. (PM)	4/2/2012	4/23/2012	21	PM - Air Handling Unit, over 50 Ton	
FO-209100	Routine	Scheduled Maint. (PM)	1/11/2012	1/31/2012	20	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-211910	Low	Scheduled Maint. (PM)	3/20/2012	4/9/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-211911	Low	Scheduled Maint. (PM)	3/20/2012	4/9/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-211912	Low	Scheduled Maint. (PM)	3/20/2012	4/9/2012	20	PM - Air Handling Unit, over 50 Ton	
FO-208473	Low	Scheduled Maint. (PM)	2/1/2012	2/20/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-208474	Low	Scheduled Maint. (PM)	2/1/2012	2/20/2012	19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	

			Finish Date	Due Date	Total per Trade	
FO-212801	Routine	Scheduled Maint. (PM)	4/4/2012	4/22/2012	18	PM - Cooling Tower, 500 - 1000 Tons
FO-221912	Routine	Scheduled Maint. (PM)	7/25/2012	8/12/2012	18	PM - Fire Pump, Main/Jockey
FO-209370	Routine	Scheduled Maint. (PM)	2/2/2012	2/19/2012	17	PM - Air Handling Unit, over 50 Ton
FO-209371	Routine	Scheduled Maint. (PM)	2/2/2012	2/19/2012	17	PM - Air Handling Unit, over 50 Ton
FO-212486	Routine	Scheduled Maint. (PM)	4/2/2012	4/19/2012	17	PM - Air Handling Unit, over 50 Ton
FO-212487	Routine	Scheduled Maint. (PM)	4/2/2012	4/19/2012	17	PM - Air Handling Unit, over 50 Ton
FO-212798	Routine	Scheduled Maint. (PM)	4/5/2012	4/22/2012	17	PM - Cooling Tower, 500 - 1000 Tons
FO-228839	Routine	Scheduled Maint. (PM)	11/13/2012	11/30/2012	17	PM - Heat Exchanger and Economizer
FO-235067	Routine	Scheduled Maint. (PM)	12/14/2012	12/31/2012	17	PM - Fire Alarm System Test
FO-218988	Routine	Scheduled Maint. (PM)	6/15/2012	7/1/2012	16	PM - Fire Alarm System Test
FO-228837	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Heat Exchanger and Economizer
FO-228838	Routine	Scheduled Maint. (PM)	11/14/2012	11/30/2012	16	PM - Heat Exchanger and Economizer
FO-208398	Routine	Scheduled Maint. (PM)	1/4/2012	1/19/2012	15	PM - Air Handling Unit, over 50 Ton
FO-208399	Routine	Scheduled Maint. (PM)	1/4/2012	1/19/2012	15	PM - Air Handling Unit, over 50 Ton
FO-211444	Routine	Scheduled Maint. (PM)	3/21/2012	4/5/2012	15	PM - Cooling Tower, 500 - 1000 Tons
FO-227324	Low	Scheduled Maint. (PM)	9/25/2012	10/10/2012	15	PM - Air Handling Unit, over 50 Ton
FO-227325	Low	Scheduled Maint. (PM)	9/25/2012	10/10/2012	15	PM - Air Handling Unit, over 50 Ton
FO-227393	Routine	Scheduled Maint. (PM)	9/15/2012	9/30/2012	15	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End
FO-208956	Routine	Scheduled Maint. (PM)	1/13/2012	1/27/2012	14	PM - Centrifugal Pump, over 1 H.P.
FO-209957	Routine	Scheduled Maint. (PM)	3/1/2012	3/15/2012	14	PM - Fan Coil/HV/AC Unit
FO-227326	Low	Scheduled Maint. (PM)	9/26/2012	10/10/2012	14	PM - Air Handling Unit, over 50 Ton
FO-228815	Low	Scheduled Maint. (PM)	10/1/2012	10/15/2012	14	PM - Air Handling Unit, over 50 Ton
FO-230736	Low	Scheduled Maint. (PM)	11/9/2012	11/23/2012	14	PM - Roof Sumps - Zone 2, Area 3
FO-212799	Routine	Scheduled Maint. (PM)	4/9/2012	4/22/2012	13	PM - Air Handling Unit, over 50 Ton
FO-212800	Routine	Scheduled Maint. (PM)	4/9/2012	4/22/2012	13	PM - Air Handling Unit, over 50 Ton
FO-230545	Routine	Scheduled Maint. (PM)	11/6/2012	11/19/2012	13	PM - Air Handling Unit, over 50 Ton
FO-212808	Routine	Scheduled Maint. (PM)	3/27/2012	4/8/2012	12	PM - Centrifugal Pump, over 1 H.P.
FO-216522	Routine	Scheduled Maint. (PM)	5/29/2012	6/10/2012	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225097	Routine	Scheduled Maint. (PM)	8/29/2012	9/10/2012	12	PM - Condensate Return Pump
FO-228818	Routine	Scheduled Maint. (PM)	10/10/2012	10/22/2012	12	PM - Air Handling Unit, over 50 Ton
FO-228819	Routine	Scheduled Maint. (PM)	10/10/2012	10/22/2012	12	PM - Air Handling Unit, over 50 Ton
FO-228820	Routine	Scheduled Maint. (PM)	10/10/2012	10/22/2012	12	PM - Air Handling Unit, over 50 Ton
FO-208961	Routine	Scheduled Maint. (PM)	1/16/2012	1/27/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-209372	Routine	Scheduled Maint. (PM)	2/2/2012	2/13/2012	11	PM - Air Handling Unit, over 50 Ton
FO-218355	Routine	Scheduled Maint. (PM)	6/4/2012	6/15/2012	11	PM - Fan Coil/HV/AC Unit
FO-218982	Routine	Scheduled Maint. (PM)	6/11/2012	6/22/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218983	Routine	Scheduled Maint. (PM)	6/11/2012	6/22/2012	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-222023	Routine	Scheduled Maint. (PM)	7/16/2012	7/27/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-218357	Low	Scheduled Maint. (PM)	6/4/2012	6/15/2012	11	PM - Air Handling Unit, over 50 Ton
FO-228811	Low	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Centrifugal Pump, over 1 H.P.
FO-228812	Low	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Water Booster Pump
FO-228813	Low	Scheduled Maint. (PM)	11/19/2012	11/30/2012	11	PM - Water Booster Pump
FO-230273	Routine	Scheduled Maint. (PM)	11/1/2012	11/12/2012	11	PM - Fire Pump, Main/Jockey
FO-235066	Routine	Scheduled Maint. (PM)	12/4/2012	12/15/2012	11	PM - Fan Coil/HV/AC Unit

Finish Date Due Date

Total per Trade

FO-208954	Routine	Scheduled Maint. (PM)	1/12/2012	1/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-208955	Routine	Scheduled Maint. (PM)	1/12/2012	1/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-208958	Routine	Scheduled Maint. (PM)	1/12/2012	1/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-208957	Routine	Scheduled Maint. (PM)	1/12/2012	1/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-208959	Routine	Scheduled Maint. (PM)	1/12/2012	1/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-215586	Routine	Scheduled Maint. (PM)	5/10/2012	5/20/2012	10	PM - Air Handling Unit, over 50 Ton
FO-215587	Routine	Scheduled Maint. (PM)	5/10/2012	5/20/2012	10	PM - Air Handling Unit, over 50 Ton
FO-216521	Routine	Scheduled Maint. (PM)	5/17/2012	5/27/2012	10	PM - Domestic Water Heater, Steam
FO-218984	Routine	Scheduled Maint. (PM)	6/12/2012	6/22/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-218985	Routine	Scheduled Maint. (PM)	6/12/2012	6/22/2012	10	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-228809	Low	Scheduled Maint. (PM)	11/20/2012	11/30/2012	10	PM - Centrifugal Pump, over 1 H.P.
FO-228810	Low	Scheduled Maint. (PM)	11/20/2012	11/30/2012	10	PM - Centrifugal Pump, over 1 H.P.
FO-228816	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-228817	Routine	Scheduled Maint. (PM)	10/12/2012	10/22/2012	10	PM - Air Handling Unit, over 50 Ton
FO-208403	Routine	Scheduled Maint. (PM)	1/11/2012	1/20/2012	9	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209951	Routine	Scheduled Maint. (PM)	3/6/2012	3/15/2012	9	PB - B&G Series 100 Pump
FO-209952	Routine	Scheduled Maint. (PM)	3/6/2012	3/15/2012	9	PB - B&G Series 100 Pump
FO-209953	Routine	Scheduled Maint. (PM)	3/6/2012	3/15/2012	9	PB - B&G Series 100 Pump
FO-209954	Routine	Scheduled Maint. (PM)	3/6/2012	3/15/2012	9	PB - B&G Series 100 Pump
FO-212807	Routine	Scheduled Maint. (PM)	4/20/2012	4/29/2012	9	PM - Cooling Tower, 500 - 1000 Tons
FO-224584	Routine	Scheduled Maint. (PM)	8/10/2012	8/19/2012	9	PM - Air Handling Unit, over 50 Ton
FO-224585	Routine	Scheduled Maint. (PM)	8/10/2012	8/19/2012	9	PM - Air Handling Unit, over 50 Ton
FO-208981	Low	Scheduled Maint. (PM)	2/6/2012	2/15/2012	9	PM - Air Handling Unit, over 50 Ton
FO-236104	Routine	Scheduled Maint. (PM)	12/20/2012	12/29/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-236105	Routine	Scheduled Maint. (PM)	12/20/2012	12/29/2012	9	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208408	Routine	Scheduled Maint. (PM)	2/1/2012	2/9/2012	8	PM - Heat Exchanger and Economizer
FO-208409	Routine	Scheduled Maint. (PM)	2/1/2012	2/9/2012	8	PM - Heat Exchanger and Economizer
FO-216524	Routine	Scheduled Maint. (PM)	6/1/2012	6/9/2012	8	PM - Centrifugal Pump, over 1 H.P.
FO-216525	Routine	Scheduled Maint. (PM)	6/1/2012	6/9/2012	8	PM - Centrifugal Pump, over 1 H.P.
FO-218360	Routine	Scheduled Maint. (PM)	6/5/2012	6/13/2012	8	PM - Water/Air Cooled Condenser
FO-222525	Low	Scheduled Maint. (PM)	8/7/2012	8/15/2012	8	PM - Sump Pump
FO-222526	Low	Scheduled Maint. (PM)	8/7/2012	8/15/2012	8	PM - Sump Pump
FO-232287	Routine	Scheduled Maint. (PM)	11/14/2012	11/22/2012	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233635	Routine	Scheduled Maint. (PM)	11/19/2012	11/27/2012	8	PM - Domestic Water Heater, Steam
FO-237867	Routine	Scheduled Maint. (PM)	1/14/2013	1/22/2013	8	PM - Air Handling Unit
FO-209099	Routine	Scheduled Maint. (PM)	1/11/2012	1/18/2012	7	PM - Air Dryer
FO-209609	Routine	Scheduled Maint. (PM)	1/17/2012	1/24/2012	7	PM - Fire Alarm System Test
FO-225089	Low	Scheduled Maint. (PM)	8/27/2012	9/3/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225091	Low	Scheduled Maint. (PM)	8/20/2012	8/27/2012	7	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230753	Low	Scheduled Maint. (PM)	11/15/2012	11/22/2012	7	PM - Fire Pump, Main/Jockey
FO-230754	Low	Scheduled Maint. (PM)	11/15/2012	11/22/2012	7	PM - Fire Pump, Main/Jockey
FO-237868	Routine	Scheduled Maint. (PM)	1/15/2013	1/22/2013	7	PM - Air Handling Unit
FO-237869	Routine	Scheduled Maint. (PM)	1/15/2013	1/22/2013	7	PM - Air Handling Unit
FO-216141	Routine	Scheduled Maint. (PM)	5/9/2012	5/15/2012	6	PM - Air Handling Unit, HV Type

			Finish Date	Due Date	Total per Trade	
FO-216142	Routine	Scheduled Maint. (PM)	5/9/2012	5/15/2012	6	PM - Air Handling Unit, HV Type
FO-221362	Routine	Scheduled Maint. (PM)	7/10/2012	7/16/2012	6	PM - Condensate Return Pump
FO-224586	Routine	Scheduled Maint. (PM)	8/3/2012	8/9/2012	6	PM - Heat Exchanger and Economizer
FO-224587	Routine	Scheduled Maint. (PM)	8/3/2012	8/9/2012	6	PM - Heat Exchanger and Economizer
FO-208465	Low	Scheduled Maint. (PM)	1/17/2012	1/23/2012	6	PM - Air Handling Unit, over 50 Ton
FO-228831	Routine	Scheduled Maint. (PM)	10/2/2012	10/8/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-228832	Routine	Scheduled Maint. (PM)	10/2/2012	10/8/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-228834	Routine	Scheduled Maint. (PM)	10/2/2012	10/8/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-228835	Routine	Scheduled Maint. (PM)	10/2/2012	10/8/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-228836	Routine	Scheduled Maint. (PM)	10/2/2012	10/8/2012	6	PM - Centrifugal Pump, over 1 H.P.
FO-229506	Low	Scheduled Maint. (PM)	10/17/2012	10/23/2012	6	PM - Air Handling Unit, over 50 Ton
FO-229507	Low	Scheduled Maint. (PM)	10/17/2012	10/23/2012	6	PM - Air Handling Unit, over 50 Ton
FO-237865	Routine	Scheduled Maint. (PM)	1/17/2013	1/23/2013	6	PM - Air Handling Unit
FO-237866	Routine	Scheduled Maint. (PM)	1/17/2013	1/23/2013	6	PM - Air Handling Unit
FO-237870	Routine	Scheduled Maint. (PM)	1/16/2013	1/22/2013	6	PM - Air Handling Unit
FO-237871	Routine	Scheduled Maint. (PM)	1/16/2013	1/22/2013	6	PM - Air Handling Unit
FO-209610	Routine	Scheduled Maint. (PM)	1/2/2012	1/7/2012	5	PM - Emergency Shower/Eyewash Station
FO-212805	Routine	Scheduled Maint. (PM)	4/3/2012	4/8/2012	5	PM - Centrifugal Pump, over 1 H.P.
FO-213973	Routine	Scheduled Maint. (PM)	5/8/2012	5/13/2012	5	PM - Fire Pump, Main/Jockey
FO-218356	Routine	Scheduled Maint. (PM)	6/26/2012	7/1/2012	5	PM - Air Handling Unit, over 50 Ton
FO-221340	Routine	Scheduled Maint. (PM)	7/10/2012	7/15/2012	5	PM - Condensate Return Pump
FO-221341	Routine	Scheduled Maint. (PM)	7/17/2012	7/22/2012	5	PM - Water Booster Pump
FO-221352	Routine	Scheduled Maint. (PM)	7/17/2012	7/22/2012	5	PM - Water Booster Pump
FO-222021	Routine	Scheduled Maint. (PM)	7/17/2012	7/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-222022	Routine	Scheduled Maint. (PM)	7/17/2012	7/22/2012	5	PM - Air Handling Unit, over 50 Ton
FO-208466	Low	Scheduled Maint. (PM)	1/18/2012	1/23/2012	5	PM - Air Handling Unit, over 50 Ton
FO-219886	Low	Scheduled Maint. (PM)	7/5/2012	7/10/2012	5	PM - Air Handling Unit, over 50 Ton
FO-219887	Low	Scheduled Maint. (PM)	7/5/2012	7/10/2012	5	PM - Air Handling Unit, over 50 Ton
FO-225092	Low	Scheduled Maint. (PM)	8/15/2012	8/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-225093	Low	Scheduled Maint. (PM)	8/15/2012	8/20/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226231	Routine	Scheduled Maint. (PM)	9/17/2012	9/22/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226233	Routine	Scheduled Maint. (PM)	9/10/2012	9/15/2012	5	PB - B&G Series 100 Pump
FO-226234	Routine	Scheduled Maint. (PM)	9/10/2012	9/15/2012	5	PB - B&G Series 100 Pump
FO-227165	Routine	Scheduled Maint. (PM)	10/15/2012	10/20/2012	5	PM - Air Handling Unit, over 50 Ton
FO-227166	Routine	Scheduled Maint. (PM)	10/15/2012	10/20/2012	5	PM - Air Handling Unit, over 50 Ton
FO-235412	Routine	Scheduled Maint. (PM)	12/17/2012	12/22/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235413	Routine	Scheduled Maint. (PM)	12/17/2012	12/22/2012	5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238064	Routine	Scheduled Maint. (PM)	1/22/2013	1/27/2013	5	PM - Centrifugal Pump, over 1 H.P.
FO-238066	Routine	Scheduled Maint. (PM)	1/22/2013	1/27/2013	5	PM - Centrifugal Pump, over 1 H.P.
FO-209614	Routine	Scheduled Maint. (PM)	2/20/2012	2/24/2012	4	PM - Fire Alarm System Test
FO-212804	Routine	Scheduled Maint. (PM)	4/18/2012	4/22/2012	4	PM - Air Handling Unit, over 50 Ton
FO-213974	Routine	Scheduled Maint. (PM)	4/23/2012	4/27/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-215588	Routine	Scheduled Maint. (PM)	5/10/2012	5/14/2012	4	PM - Air Handling Unit, over 50 Ton
FO-220629	Routine	Scheduled Maint. (PM)	7/16/2012	7/20/2012	4	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-220630	Routine	Scheduled Maint. (PM)	7/16/2012	7/20/2012	4	PM - Air Handling Unit, over 50 Ton
FO-221337	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	PM - Water Booster Pump
FO-221338	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	PM - Water Booster Pump
FO-221339	Routine	Scheduled Maint. (PM)	7/11/2012	7/15/2012	4	PM - Water Booster Pump
FO-221358	Routine	Scheduled Maint. (PM)	7/18/2012	7/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-221361	Routine	Scheduled Maint. (PM)	7/27/2012	7/31/2012	4	PM - Fire Alarm System Test
FO-222020	Routine	Scheduled Maint. (PM)	7/23/2012	7/27/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-225090	Low	Scheduled Maint. (PM)	8/23/2012	8/27/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-226237	Routine	Scheduled Maint. (PM)	9/11/2012	9/15/2012	4	PB - B&G Series 100 Pump
FO-228827	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-228828	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-228829	Routine	Scheduled Maint. (PM)	10/4/2012	10/8/2012	4	PM - Centrifugal Pump, over 1 H.P.
FO-235414	Routine	Scheduled Maint. (PM)	12/18/2012	12/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-235415	Routine	Scheduled Maint. (PM)	12/18/2012	12/22/2012	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-238065	Routine	Scheduled Maint. (PM)	1/23/2013	1/27/2013	4	PM - Centrifugal Pump, over 1 H.P.
FO-212802	Routine	Scheduled Maint. (PM)	4/19/2012	4/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-212803	Routine	Scheduled Maint. (PM)	4/19/2012	4/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221349	Routine	Scheduled Maint. (PM)	7/19/2012	7/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221351	Routine	Scheduled Maint. (PM)	7/19/2012	7/22/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221324	Low	Scheduled Maint. (PM)	7/20/2012	7/23/2012	3	PM - Air Handling Unit, over 50 Ton
FO-221325	Low	Scheduled Maint. (PM)	7/20/2012	7/23/2012	3	PM - Air Handling Unit, over 50 Ton
FO-226239	Routine	Scheduled Maint. (PM)	9/28/2012	10/1/2012	3	PM - Fire Alarm System Test
FO-227167	Routine	Scheduled Maint. (PM)	9/26/2012	9/29/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-227168	Routine	Scheduled Maint. (PM)	9/26/2012	9/29/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-227169	Routine	Scheduled Maint. (PM)	9/26/2012	9/29/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-228841	Routine	Scheduled Maint. (PM)	10/5/2012	10/8/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-230424	Routine	Scheduled Maint. (PM)	10/24/2012	10/27/2012	3	PM - Centrifugal Pump, over 1 H.P.
FO-236704	Routine	Scheduled Maint. (PM)	12/21/2012	12/24/2012	3	PM - Fire Alarm System Test
FO-237385	Routine	Scheduled Maint. (PM)	1/16/2013	1/19/2013	3	PM - Air Handling Unit
FO-237386	Routine	Scheduled Maint. (PM)	1/16/2013	1/19/2013	3	PM - Air Handling Unit
FO-211273	Routine	Scheduled Maint. (PM)	4/3/2012	4/5/2012	2	PM - Cooling Tower, 500 - 1000 Tons
FO-221350	Routine	Scheduled Maint. (PM)	7/20/2012	7/22/2012	2	PM - Air Handling Unit, over 50 Ton
FO-222029	Routine	Scheduled Maint. (PM)	7/25/2012	7/27/2012	2	PM - Centrifugal Pump, over 1 H.P.
FO-224760	Routine	Scheduled Maint. (PM)	8/13/2012	8/15/2012	2	PM - Air Handling Unit, HV Type
FO-227391	High	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227398	High	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Air Handling Unit, over 50 Ton
FO-227399	High	Scheduled Maint. (PM)	10/3/2012	10/5/2012	2	PM - Air Handling Unit, over 50 Ton
FO-232290	Routine	Scheduled Maint. (PM)	11/29/2012	12/1/2012	2	PM - Fire Alarm System Test
FO-236688	Routine	Scheduled Maint. (PM)	1/7/2013	1/9/2013	2	PM - Air Handling Unit, over 50 Ton
FO-236689	Routine	Scheduled Maint. (PM)	1/7/2013	1/9/2013	2	PM - Air Handling Unit, over 50 Ton
FO-236690	Routine	Scheduled Maint. (PM)	1/7/2013	1/9/2013	2	PM - Air Handling Unit, over 50 Ton
FO-237876	Routine	Scheduled Maint. (PM)	1/14/2013	1/16/2013	2	PM - Condensate Return Pump
FO-209509	Routine	Scheduled Maint. (PM)	2/14/2012	2/15/2012	1	PM - Air Handling Unit, HV Type
FO-209510	Routine	Scheduled Maint. (PM)	2/14/2012	2/15/2012	1	PM - Air Handling Unit, HV Type

			Finish Date	Due Date	Total per Trade	
FO-208964	Routine	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Maintenance
FO-209955	Routine	Scheduled Maint. (PM)	3/21/2012	3/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-209956	Routine	Scheduled Maint. (PM)	3/21/2012	3/22/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-211915	Routine	Scheduled Maint. (PM)	3/23/2012	3/24/2012	1	PM - Fire Alarm System Test
FO-212491	Routine	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Maintenance
FO-211274	Routine	Scheduled Maint. (PM)	4/4/2012	4/5/2012	1	PM - Cooling Tower, 500 - 1000 Tons
FO-215147	Routine	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Maintenance
FO-215150	Routine	Scheduled Maint. (PM)	4/23/2012	4/24/2012	1	PM - Fire Alarm System Test
FO-220464	Routine	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Maintenance
FO-224754	Routine	Scheduled Maint. (PM)	7/23/2012	7/24/2012	1	PM - Fire Alarm System Test
FO-208953	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Maintenance
FO-208962	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Maintenance
FO-208963	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Maintenance
FO-208965	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Maintenance
FO-209102	High	Scheduled Maint. (PM)	2/8/2012	2/9/2012	1	Generator Maintenance
FO-211445	High	Scheduled Maint. (PM)	3/13/2012	3/14/2012	1	Generator Maintenance
FO-211446	High	Scheduled Maint. (PM)	3/14/2012	3/15/2012	1	Generator Maintenance
FO-212488	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Maintenance
FO-212489	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Maintenance
FO-212490	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Maintenance
FO-212492	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Maintenance
FO-213977	High	Scheduled Maint. (PM)	4/10/2012	4/11/2012	1	Generator Maintenance
FO-213979	High	Scheduled Maint. (PM)	4/11/2012	4/12/2012	1	Generator Maintenance
FO-215144	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Maintenance
FO-215145	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Maintenance
FO-215146	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Maintenance
FO-215148	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Maintenance
FO-216523	High	Scheduled Maint. (PM)	5/8/2012	5/9/2012	1	Generator Maintenance
FO-216526	High	Scheduled Maint. (PM)	5/9/2012	5/10/2012	1	Generator Maintenance
FO-219888	Low	Scheduled Maint. (PM)	7/9/2012	7/10/2012	1	PM - Air Handling Unit, over 50 Ton
FO-220462	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Maintenance
FO-220463	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Maintenance
FO-220465	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Maintenance
FO-220631	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Maintenance
FO-221982	Low	Scheduled Maint. (PM)	8/7/2012	8/8/2012	1	PM - Sump Pump
FO-221983	Low	Scheduled Maint. (PM)	8/7/2012	8/8/2012	1	PM - Sump Pump
FO-224212	High	Scheduled Maint. (PM)	8/28/2012	8/29/2012	1	Generator Maintenance
FO-224213	High	Scheduled Maint. (PM)	8/8/2012	8/9/2012	1	Generator Test
FO-224761	Routine	Scheduled Maint. (PM)	8/30/2012	8/31/2012	1	PM - Fire Alarm System Test
FO-228814	Routine	Scheduled Maint. (PM)	10/30/2012	10/31/2012	1	PM - Air Handling Unit, over 50 Ton
FO-229510	High	Scheduled Maint. (PM)	10/3/2012	10/4/2012	1	Generator Maintenance
FO-230798	Routine	Scheduled Maint. (PM)	11/12/2012	11/13/2012	1	PM - Air Handling Unit, over 50 Ton
FO-232902	Routine	Scheduled Maint. (PM)	12/10/2012	12/11/2012	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-233633	High	Scheduled Maint. (PM)	11/14/2012	11/15/2012	1	Generator Maintenance

			Finish Date	Due Date	Total per Trade	
FO-236109	Routine	Scheduled Maint. (PM)	12/12/2012	12/13/2012	1	Generator Maintenance
FO-237875	Routine	Scheduled Maint. (PM)	1/14/2013	1/15/2013	1	PM - Condensate Return Pump
FO-238061	Routine	Scheduled Maint. (PM)	1/8/2013	1/9/2013	1	Generator Maintenance, Monthly
FO-238063	Routine	Scheduled Maint. (PM)	1/9/2013	1/10/2013	1	Generator Maintenance, Monthly
FO-238090	Routine	Scheduled Maint. (PM)	1/22/2013	1/23/2013	1	Generator Maintenance, Monthly
FO-238092	Routine	Scheduled Maint. (PM)	1/22/2013	1/23/2013	1	Generator Maintenance, Monthly
FO-238094	Routine	Scheduled Maint. (PM)	1/22/2013	1/23/2013	1	Generator Maintenance, Monthly
FO-238096	Routine	Scheduled Maint. (PM)	1/22/2013	1/23/2013	1	Generator Maintenance, Monthly
FO-238098	Routine	Scheduled Maint. (PM)	1/22/2013	1/23/2013	1	Generator Maintenance, Monthly
FO-209982	Routine	Scheduled Maint. (PM)	3/2/2012	3/2/2012	0	PM - Fire Alarm System Test
FO-212809	Routine	Scheduled Maint. (PM)	4/2/2012	4/2/2012	0	PM - Fire Alarm System Test
FO-215962	Routine	Scheduled Maint. (PM)	5/31/2012	5/31/2012	0	PM - Fire Alarm System Test
FO-217614	Routine	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	Generator Maintenance
FO-224755	Routine	Scheduled Maint. (PM)	8/13/2012	8/13/2012	0	PM - Air Handling Unit, over 50 Ton
FO-208475	Low	Scheduled Maint. (PM)	2/27/2012	2/27/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-215131	Low	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	PM - Fire Pump, Main/Jockey
FO-215132	Low	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	PM - Fire Pump, Main/Jockey
FO-217611	High	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	Generator Maintenance
FO-217612	High	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	Generator Maintenance
FO-217613	High	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	Generator Maintenance
FO-217615	High	Scheduled Maint. (PM)	5/23/2012	5/23/2012	0	Generator Maintenance
FO-222258	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222259	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222260	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222261	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222262	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-224230	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-224231	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-224232	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-224234	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-225598	Routine	Scheduled Maint. (PM)	8/24/2012	8/24/2012	0	PM - Fire Alarm System Test
FO-227364	High	Scheduled Maint. (PM)	9/25/2012	9/25/2012	0	Generator Maintenance
FO-227366	High	Scheduled Maint. (PM)	9/25/2012	9/25/2012	0	Generator Maintenance
FO-227368	High	Scheduled Maint. (PM)	9/25/2012	9/25/2012	0	Generator Maintenance
FO-227370	High	Scheduled Maint. (PM)	9/25/2012	9/25/2012	0	Generator Maintenance
FO-227390	High	Scheduled Maint. (PM)	9/12/2012	9/12/2012	0	Generator Maintenance
FO-227402	Routine	Scheduled Maint. (PM)	9/24/2012	9/24/2012	0	PM - Fire Alarm System Test
FO-228833	Routine	Scheduled Maint. (PM)	10/1/2012	10/1/2012	0	PM - Heat Exchanger and Economizer
FO-228840	Routine	Scheduled Maint. (PM)	10/31/2012	10/31/2012	0	PM - Fire Alarm System Test
FO-230784	High	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	Generator Maintenance
FO-230786	High	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	Generator Maintenance
FO-230788	High	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	Generator Maintenance
FO-230790	High	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	Generator Maintenance
FO-230792	High	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	Generator Maintenance

			Finish Date	Due Date	Total per Trade	
FO-230807	Routine	Scheduled Maint. (PM)	10/24/2012	10/24/2012	0	PM - Fire Alarm System Test
FO-234344	Routine	Scheduled Maint. (PM)	11/27/2012	11/27/2012	0	Generator Maintenance
FO-234345	Routine	Scheduled Maint. (PM)	11/27/2012	11/27/2012	0	Generator Maintenance
FO-234346	Routine	Scheduled Maint. (PM)	11/27/2012	11/27/2012	0	Generator Maintenance
FO-234347	Routine	Scheduled Maint. (PM)	11/27/2012	11/27/2012	0	Generator Maintenance
FO-234348	Routine	Scheduled Maint. (PM)	11/27/2012	11/27/2012	0	Generator Maintenance
FO-236691	Routine	Scheduled Maint. (PM)	12/25/2012	12/25/2012	0	Generator Maintenance
FO-236692	Routine	Scheduled Maint. (PM)	12/25/2012	12/25/2012	0	Generator Maintenance
FO-236693	Routine	Scheduled Maint. (PM)	12/25/2012	12/25/2012	0	Generator Maintenance
FO-236694	Routine	Scheduled Maint. (PM)	12/25/2012	12/25/2012	0	Generator Maintenance
FO-236695	Routine	Scheduled Maint. (PM)	12/25/2012	12/25/2012	0	Generator Maintenance
FO-237873	Routine	Scheduled Maint. (PM)	1/4/2013	1/4/2013	0	Housing - Towers Kitchen Make Up Air PM
FO-209616	Routine	Scheduled Maint. (PM)	2/3/2012	2/2/2012	-1	PM - Fire Alarm System Test
FO-217619	Routine	Scheduled Maint. (PM)	5/25/2012	5/24/2012	-1	PM - Fire Alarm System Test
FO-236697	Routine	Scheduled Maint. (PM)	12/24/2012	12/23/2012	-1	Housing Fog Treatment
FO-209615	Routine	Scheduled Maint. (PM)	2/6/2012	2/4/2012	-2	PM - Emergency Shower/Eyewash Station
FO-209619	Routine	Scheduled Maint. (PM)	3/5/2012	3/3/2012	-2	PM - Emergency Shower/Eyewash Station
FO-208478	Low	Scheduled Maint. (PM)	2/17/2012	2/15/2012	-2	PM - Sump Pump
FO-208479	Low	Scheduled Maint. (PM)	2/17/2012	2/15/2012	-2	PM - Sump Pump
FO-234350	Routine	Scheduled Maint. (PM)	11/26/2012	11/24/2012	-2	PM - Fire Alarm System Test
FO-219884	Routine	Scheduled Maint. (PM)	7/2/2012	6/29/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-219885	Routine	Scheduled Maint. (PM)	7/2/2012	6/29/2012	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-230425	Routine	Scheduled Maint. (PM)	10/16/2012	10/13/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-230426	Routine	Scheduled Maint. (PM)	10/16/2012	10/13/2012	-3	PM - Centrifugal Pump, over 1 H.P.
FO-209611	Routine	Scheduled Maint. (PM)	1/6/2012	1/2/2012	-4	PM - Fire Alarm System Test
FO-212806	Routine	Scheduled Maint. (PM)	4/13/2012	4/8/2012	-5	PM - Centrifugal Pump, over 1 H.P.
FO-208952	Routine	Scheduled Maint. (PM)	2/2/2012	1/27/2012	-6	PM - Centrifugal Pump, over 1 H.P.
FO-220216	Routine	Scheduled Maint. (PM)	7/12/2012	7/6/2012	-6	PM - Unit/Space Heater
FO-220217	Routine	Scheduled Maint. (PM)	7/12/2012	7/6/2012	-6	PM - Unit/Space Heater
FO-218986	High	Scheduled Maint. (PM)	6/12/2012	6/6/2012	-6	Generator Maintenance
FO-218987	High	Scheduled Maint. (PM)	6/13/2012	6/7/2012	-6	Generator Maintenance
FO-226843	High	Scheduled Maint. (PM)	9/12/2012	9/6/2012	-6	Generator Test
FO-208982	Routine	Scheduled Maint. (PM)	1/23/2012	1/15/2012	-8	PM - Condensate Return Pump
FO-208462	Low	Scheduled Maint. (PM)	1/17/2012	1/9/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-208463	Low	Scheduled Maint. (PM)	1/17/2012	1/9/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-208464	Low	Scheduled Maint. (PM)	1/17/2012	1/9/2012	-8	PM - Air Handling Unit, over 50 Ton
FO-208983	Routine	Scheduled Maint. (PM)	1/25/2012	1/16/2012	-9	PM - Condensate Return Pump
FO-220233	Routine	Scheduled Maint. (PM)	7/3/2012	6/24/2012	-9	PM - Fire Alarm System Test
FO-208480	Low	Scheduled Maint. (PM)	2/17/2012	2/8/2012	-9	PM - Sump Pump
FO-208481	Low	Scheduled Maint. (PM)	2/17/2012	2/8/2012	-9	PM - Sump Pump
FO-228823	Routine	Scheduled Maint. (PM)	11/7/2012	10/29/2012	-9	PM - Cooling Tower, 500 - 1000 Tons
FO-230546	Routine	Scheduled Maint. (PM)	11/29/2012	11/19/2012	-10	PM - Air Handling Unit, over 50 Ton
FO-208405	Routine	Scheduled Maint. (PM)	1/9/2012	12/29/2011	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208406	Routine	Scheduled Maint. (PM)	1/9/2012	12/29/2011	-11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date	Total per Trade	
FO-228824	Routine	Scheduled Maint. (PM)	11/2/2012	10/22/2012	-11	PM - Cooling Tower, 500 - 1000 Tons
FO-220214	Routine	Scheduled Maint. (PM)	6/16/2012	6/3/2012	-13	-> Consolidated PM items:
FO-224928	Routine	Scheduled Maint. (PM)	9/15/2012	9/2/2012	-13	Replace Chemistry PreFilters (AHU-1A/2A) North End
FO-226238	Routine	Scheduled Maint. (PM)	10/1/2012	9/15/2012	-16	PM - Fan Coil/HV/AC Unit
FO-208410	Routine	Scheduled Maint. (PM)	1/9/2012	12/22/2011	-18	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208411	Routine	Scheduled Maint. (PM)	1/10/2012	12/22/2011	-19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208412	Routine	Scheduled Maint. (PM)	1/10/2012	12/22/2011	-19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-208413	Routine	Scheduled Maint. (PM)	1/10/2012	12/22/2011	-19	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-228822	Routine	Scheduled Maint. (PM)	11/15/2012	10/22/2012	-24	PM - Cooling Tower, 500 - 1000 Tons
FO-228821	Routine	Scheduled Maint. (PM)	11/20/2012	10/22/2012	-29	PM - Cooling Tower, 500 - 1000 Tons
FO-226232	Routine	Scheduled Maint. (PM)	10/24/2012	9/11/2012	-43	Inspection of DA / Surge Tank
FO-226236	Routine	Scheduled Maint. (PM)	10/24/2012	9/11/2012	-43	Inspection of DA / Surge Tank
FO-196340	Low	Scheduled Maint. (PM)	1/14/2012	11/30/2011	-45	PM - Water Booster Pump
FO-196341	Low	Scheduled Maint. (PM)	1/14/2012	11/30/2011	-45	PM - Water Booster Pump
FO-196344	Low	Scheduled Maint. (PM)	1/14/2012	11/30/2011	-45	PM - Centrifugal Pump, over 1 H.P.
FO-196345	Low	Scheduled Maint. (PM)	1/14/2012	11/30/2011	-45	PM - Centrifugal Pump, over 1 H.P.
FO-196346	Low	Scheduled Maint. (PM)	1/14/2012	11/30/2011	-45	PM - Centrifugal Pump, over 1 H.P.
FO-208400	Routine	Scheduled Maint. (PM)	1/4/2012	11/19/2011	-46	PM - Air Handling Unit, over 50 Ton
FO-208404	Routine	Scheduled Maint. (PM)	1/12/2012	11/27/2011	-46	PM - Domestic Water Heater, Steam
FO-221345	Low	Scheduled Maint. (PM)	9/14/2012	7/30/2012	-46	Boiler Open Clean & Close - Vapor Boilers
FO-221346	Low	Scheduled Maint. (PM)	9/14/2012	7/30/2012	-46	Boiler Open Clean & Close - Vapor Boilers
FO-228826	Routine	Scheduled Maint. (PM)	12/14/2012	10/29/2012	-46	PM - Absorption Unit
FO-208401	Routine	Scheduled Maint. (PM)	1/5/2012	11/19/2011	-47	PM - Air Handling Unit, over 50 Ton
FO-228830	Routine	Scheduled Maint. (PM)	12/19/2012	10/29/2012	-51	PM - Absorption Unit
FO-208402	Routine	Scheduled Maint. (PM)	1/5/2012	11/13/2011	-53	PM - Air Handling Unit, over 50 Ton
FO-196342	Low	Scheduled Maint. (PM)	1/14/2012	11/22/2011	-53	PM - Fire Pump, Main/Jockey
FO-196343	Low	Scheduled Maint. (PM)	1/14/2012	11/22/2011	-53	PM - Fire Pump, Main/Jockey
FO-196332	Routine	Scheduled Maint. (PM)	1/14/2012	11/12/2011	-63	PM - Fire Pump, Main/Jockey
FO-224757	Routine	Scheduled Maint. (PM)	10/23/2012	8/15/2012	-69	PM - Air Handling Unit, HV Type
FO-196366	Routine	Scheduled Maint. (PM)	1/14/2012	10/31/2011	-75	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-196356	Routine	Scheduled Maint. (PM)	1/14/2012	10/29/2011	-77	PM - Cooling Tower, 500 - 1000 Tons
FO-208960	Routine	Scheduled Maint. (PM)	2/7/2012	11/22/2011	-77	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-196348	Routine	Scheduled Maint. (PM)	1/14/2012	10/27/2011	-79	PM - Centrifugal Pump, over 1 H.P.
FO-196338	Low	Scheduled Maint. (PM)	1/14/2012	10/23/2011	-83	PM - Air Handling Unit, over 50 Ton
FO-196339	Low	Scheduled Maint. (PM)	1/14/2012	10/23/2011	-83	PM - Air Handling Unit, over 50 Ton
FO-195352	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Cooling Tower, 500 - 1000 Tons
FO-195354	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Air Handling Unit, over 50 Ton
FO-195355	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Air Handling Unit, over 50 Ton
FO-195364	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Cooling Tower, 500 - 1000 Tons
FO-195369	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Air Handling Unit, over 50 Ton
FO-195370	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Air Handling Unit, over 50 Ton
FO-195371	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Air Handling Unit, over 50 Ton
FO-196372	Routine	Scheduled Maint. (PM)	1/14/2012	10/22/2011	-84	PM - Cooling Tower, 500 - 1000 Tons
FO-196328	Routine	Scheduled Maint. (PM)	1/14/2012	10/20/2011	-86	PM - Air Handling Unit, over 50 Ton

			Finish Date	Due Date	Total per Trade	
FO-196329	Routine	Scheduled Maint. (PM)	1/14/2012	10/20/2011	-86	PM - Air Handling Unit, over 50 Ton
FO-196330	Routine	Scheduled Maint. (PM)	1/14/2012	10/20/2011	-86	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-209140	Routine	Scheduled Maint. (PM)	2/14/2012	11/15/2011	-91	PM - Air Handling Unit, HV Type
FO-209142	Routine	Scheduled Maint. (PM)	2/14/2012	11/15/2011	-91	PM - Air Handling Unit, HV Type
FO-196360	Routine	Scheduled Maint. (PM)	1/14/2012	10/13/2011	-93	PM - Water/Air Cooled Condenser
FO-196335	Low	Scheduled Maint. (PM)	1/14/2012	10/10/2011	-96	PM - Air Handling Unit, over 50 Ton
FO-196336	Low	Scheduled Maint. (PM)	1/14/2012	10/10/2011	-96	PM - Air Handling Unit, over 50 Ton
FO-196337	Low	Scheduled Maint. (PM)	1/14/2012	10/10/2011	-96	PM - Air Handling Unit, over 50 Ton
FO-196355	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196357	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196367	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196368	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196369	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196370	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196371	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196373	Routine	Scheduled Maint. (PM)	1/14/2012	10/8/2011	-98	PM - Centrifugal Pump, over 1 H.P.
FO-196363	High	Scheduled Maint. (PM)	1/14/2012	10/5/2011	-101	PM - Air Handling Unit, over 50 Ton
FO-196364	High	Scheduled Maint. (PM)	1/14/2012	10/5/2011	-101	PM - Air Handling Unit, over 50 Ton
FO-196365	High	Scheduled Maint. (PM)	1/14/2012	10/5/2011	-101	PM - Air Handling Unit, over 50 Ton
FO-208414	Low	Scheduled Maint. (PM)	3/7/2012	11/23/2011	-105	PM - Roof Sumps - Zone 2, Area 3
FO-195356	Routine	Scheduled Maint. (PM)	1/14/2012	9/22/2011	-114	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-196331	Routine	Scheduled Maint. (PM)	1/14/2012	9/22/2011	-114	PM - Condensate Return Pump
FO-195361	Routine	Scheduled Maint. (PM)	1/14/2012	9/15/2011	-121	PM - Fan Coil/HV/AC Unit
FO-195365	Routine	Scheduled Maint. (PM)	1/14/2012	9/15/2011	-121	PB - B&G Series 100 Pump
FO-195366	Routine	Scheduled Maint. (PM)	1/14/2012	9/15/2011	-121	PB - B&G Series 100 Pump
FO-195367	Routine	Scheduled Maint. (PM)	1/14/2012	9/15/2011	-121	PB - B&G Series 100 Pump
FO-195368	Routine	Scheduled Maint. (PM)	1/14/2012	9/15/2011	-121	PB - B&G Series 100 Pump
FO-196361	High	Scheduled Maint. (PM)	1/14/2012	9/14/2011	-122	Generator Maintenance
FO-196359	Routine	Scheduled Maint. (PM)	1/14/2012	9/10/2011	-126	PM - Condensate Return Pump
FO-196347	Low	Scheduled Maint. (PM)	1/14/2012	9/3/2011	-133	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-196374	Routine	Scheduled Maint. (PM)	1/14/2012	8/24/2011	-143	PM - Fire Alarm System Test
FO-196380	Routine	Scheduled Maint. (PM)	1/14/2012	8/20/2011	-147	PM - Emergency Shower/Eyewash Station **Needs Task Sheet**
FO-191406	Routine	Scheduled Maint. (PM)	1/14/2012	8/19/2011	-148	PM - Air Handling Unit, over 50 Ton
FO-191407	Routine	Scheduled Maint. (PM)	1/14/2012	8/19/2011	-148	PM - Air Handling Unit, over 50 Ton
FO-191443	Routine	Scheduled Maint. (PM)	1/14/2012	8/16/2011	-151	State Boiler Inspection - http://www.hsb.com/cmsfiles/769.pdf Boiler Inspection Due: 8-24-11CSD-1 Completed: 3
FO-191441	Routine	Scheduled Maint. (PM)	1/14/2012	8/15/2011	-152	PM - Air Handling Unit, HV Type
FO-191442	Routine	Scheduled Maint. (PM)	1/14/2012	8/15/2011	-152	PM - Air Handling Unit, HV Type
FO-191408	Routine	Scheduled Maint. (PM)	1/14/2012	8/13/2011	-154	PM - Air Handling Unit, over 50 Ton
FO-191423	Low	Scheduled Maint. (PM)	1/14/2012	8/8/2011	-159	PM - Sump Pump
FO-191444	Routine	Scheduled Maint. (PM)	1/14/2012	8/6/2011	-161	State Boiler Inspection - http://www.hsb.com/cmsfiles/769.pdf STATE BOILER INSPECTIONBoiler Inspection Due: 8
FO-191438	Routine	Scheduled Maint. (PM)	1/14/2012	7/31/2011	-167	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-191425	Routine	Scheduled Maint. (PM)	1/14/2012	7/27/2011	-171	PM - Centrifugal Pump, over 1 H.P.
FO-191428	Routine	Scheduled Maint. (PM)	1/14/2012	7/27/2011	-171	PM - Centrifugal Pump, over 1 H.P.
FO-191433	Routine	Scheduled Maint. (PM)	1/14/2012	7/27/2011	-171	PM - Centrifugal Pump, over 1 H.P.

Finish Date Due Date

Total per Trade

FO-191439	Routine	Scheduled Maint. (PM)	1/14/2012	7/24/2011	-174	PM - Fire Alarm System Test
FO-191445	Routine	Scheduled Maint. (PM)	1/14/2012	7/23/2011	-175	PM - Emergency Shower/Eyewash Station **Needs Task Sheet**
FO-191426	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Air Handling Unit, over 50 Ton
FO-191427	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Air Handling Unit, over 50 Ton
FO-191429	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Air Handling Unit, over 50 Ton
FO-191432	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-191434	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Water Booster Pump
FO-191435	Routine	Scheduled Maint. (PM)	1/14/2012	7/22/2011	-176	PM - Water Booster Pump
FO-191404	Routine	Scheduled Maint. (PM)	1/14/2012	7/20/2011	-178	PM - Air Handling Unit, over 50 Ton
FO-191405	Routine	Scheduled Maint. (PM)	1/14/2012	7/20/2011	-178	PM - Air Handling Unit, over 50 Ton
FO-191437	Routine	Scheduled Maint. (PM)	1/14/2012	7/18/2011	-180	PM - Air Dryer
FO-193223	Routine	Scheduled Maint. (PM)	1/14/2012	7/15/2011	-183	PM - Condensate Return Pump
FO-188160	Routine	Scheduled Maint. (PM)	1/14/2012	7/12/2011	-186	State Boiler Inspection - http://www.hsb.com/cmsfiles/769.pdf
FO-188151	Routine	Scheduled Maint. (PM)	1/14/2012	6/15/2011	-213	PM - Fan Coil/HV/AC Unit
FO-184585	Routine	Scheduled Maint. (PM)	1/14/2012	6/7/2011	-221	Boiler - Open Clean and Close 78 inch Boilers
FO-184584	Routine	Scheduled Maint. (PM)	1/25/2012	6/7/2011	-232	Boiler - Open Clean and Close 78 inch Boilers
FO-183303	Routine	Scheduled Maint. (PM)	1/14/2012	5/5/2011	-254	Boiler - Open Clean and Close 60 inch Boilers
FO-181870	Routine	Scheduled Maint. (PM)	1/14/2012	4/23/2011	-266	Boiler - Open Clean and Close 60 inch Boilers

E - Controls Engineer

75 of 234 32%

FO-222534	Routine	Scheduled Maint. (PM)	5/25/2012	8/15/2012	82	Boiler - Open Clean and Close 48 inch Boilers
FO-221925	Routine	Scheduled Maint. (PM)	5/21/2012	7/24/2012	64	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221926	Routine	Scheduled Maint. (PM)	5/21/2012	7/24/2012	64	PM - Air Dryer
FO-221342	Low	Scheduled Maint. (PM)	5/18/2012	7/16/2012	59	Boiler - Open Clean and Close 60 inch Boilers
FO-221229	Routine	Scheduled Maint. (PM)	5/23/2012	7/20/2012	58	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-222455	Routine	Scheduled Maint. (PM)	6/13/2012	7/31/2012	48	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-222456	Routine	Scheduled Maint. (PM)	6/13/2012	7/31/2012	48	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-222472	Routine	Scheduled Maint. (PM)	6/13/2012	7/31/2012	48	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-222473	Routine	Scheduled Maint. (PM)	6/13/2012	7/31/2012	48	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221965	Routine	Scheduled Maint. (PM)	6/13/2012	7/29/2012	46	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221984	Routine	Scheduled Maint. (PM)	6/13/2012	7/29/2012	46	PM - Air Dryer
FO-222549	Routine	Scheduled Maint. (PM)	6/15/2012	7/31/2012	46	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-228669	Low	Scheduled Maint. (PM)	10/1/2012	11/15/2012	45	Boiler Open Clean & Close - Vapor Boilers
FO-219276	Routine	Scheduled Maint. (PM)	6/6/2012	7/12/2012	36	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221227	Routine	Scheduled Maint. (PM)	6/13/2012	7/18/2012	35	PM - Air Dryer
FO-221228	Routine	Scheduled Maint. (PM)	6/13/2012	7/18/2012	35	PM - Air Dryer
FO-221245	Routine	Scheduled Maint. (PM)	6/13/2012	7/18/2012	35	PM - Air Dryer
FO-237838	Routine	Scheduled Maint. (PM)	12/13/2012	1/17/2013	35	PM - Air Dryer
FO-237839	Routine	Scheduled Maint. (PM)	12/14/2012	1/17/2013	34	PM - Air Dryer
FO-237383	Routine	Scheduled Maint. (PM)	12/13/2012	1/12/2013	30	PM - Air Dryer
FO-218393	Routine	Scheduled Maint. (PM)	6/7/2012	7/5/2012	28	Boiler - Open Clean and Close 78 inch Boilers
FO-218402	Low	Scheduled Maint. (PM)	5/23/2012	6/20/2012	28	State Boiler Inspection - http://www.hsb.com/cmsfiles/769.pdf
FO-233627	Low	Scheduled Maint. (PM)	12/10/2012	1/3/2013	24	Boiler Rear Refractory Inspection - 60 " Boiler
FO-213955	Routine	Scheduled Maint. (PM)	4/2/2012	4/24/2012	22	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221343	Routine	Scheduled Maint. (PM)	7/12/2012	8/1/2012	20	Boiler - Open Clean and Close 60 inch Boilers

			Finish Date	Due Date			Total per Trade
FO-227334	Low	Scheduled Maint. (PM)	9/26/2012	10/11/2012	15	PM - Air Dryer	
FO-214087	Routine	Scheduled Maint. (PM)	4/10/2012	4/24/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214091	Routine	Scheduled Maint. (PM)	4/10/2012	4/24/2012	14	PM - Air Dryer	
FO-232246	Routine	Scheduled Maint. (PM)	11/1/2012	11/15/2012	14	PM - Air Dryer	
FO-232247	Routine	Scheduled Maint. (PM)	11/1/2012	11/15/2012	14	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-213144	Routine	Scheduled Maint. (PM)	3/27/2012	4/9/2012	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221360	Routine	Scheduled Maint. (PM)	7/5/2012	7/18/2012	13	PM - Air Dryer	
FO-237853	Routine	Scheduled Maint. (PM)	1/3/2013	1/16/2013	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237854	Routine	Scheduled Maint. (PM)	1/3/2013	1/16/2013	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-238039	Routine	Scheduled Maint. (PM)	1/11/2013	1/24/2013	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-238545	Routine	Scheduled Maint. (PM)	1/18/2013	1/31/2013	13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214084	Routine	Scheduled Maint. (PM)	4/12/2012	4/24/2012	12	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214089	Routine	Scheduled Maint. (PM)	4/12/2012	4/24/2012	12	PM - Air Dryer	
FO-221968	Routine	Scheduled Maint. (PM)	7/17/2012	7/29/2012	12	PM - Air Dryer	
FO-221969	Routine	Scheduled Maint. (PM)	7/17/2012	7/29/2012	12	PM - Air Dryer	
FO-221970	Routine	Scheduled Maint. (PM)	7/17/2012	7/29/2012	12	PM - Air Dryer	
FO-222535	Routine	Scheduled Maint. (PM)	8/3/2012	8/15/2012	12	Boiler - Open Clean and Close 60 inch Boilers	
FO-222546	Low	Scheduled Maint. (PM)	7/20/2012	7/31/2012	11	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-226785	Routine	Scheduled Maint. (PM)	9/13/2012	9/24/2012	11	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218431	Low	Scheduled Maint. (PM)	6/5/2012	6/15/2012	10	Boiler - Open Clean and Close 60 inch Boilers	
FO-219968	Low	Scheduled Maint. (PM)	10/5/2012	10/15/2012	10	Boiler - Open Clean and Close 48 inch Boilers	
FO-226194	Routine	Scheduled Maint. (PM)	10/8/2012	10/18/2012	10	Boiler - Open Clean and Close 60 inch Boilers	
FO-221930	Routine	Scheduled Maint. (PM)	7/11/2012	7/19/2012	8	PM - Air Dryer	
FO-221931	Routine	Scheduled Maint. (PM)	7/11/2012	7/19/2012	8	PM - Air Dryer	
FO-221932	Routine	Scheduled Maint. (PM)	7/11/2012	7/19/2012	8	PM - Air Dryer	
FO-222516	Routine	Scheduled Maint. (PM)	7/24/2012	8/1/2012	8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-222517	Routine	Scheduled Maint. (PM)	7/24/2012	8/1/2012	8	PM - Air Dryer	
FO-236089	Routine	Scheduled Maint. (PM)	12/18/2012	12/26/2012	8	PM - Air Dryer	
FO-221353	Low	Scheduled Maint. (PM)	7/12/2012	7/18/2012	6	PM - Air Dryer	
FO-221354	Low	Scheduled Maint. (PM)	7/12/2012	7/18/2012	6	PM - Air Dryer	
FO-237840	Routine	Scheduled Maint. (PM)	1/11/2013	1/17/2013	6	PM - Air Dryer	
FO-238511	Routine	Scheduled Maint. (PM)	1/23/2013	1/29/2013	6	PM - Air Dryer	
FO-238512	Routine	Scheduled Maint. (PM)	1/23/2013	1/29/2013	6	PM - Air Dryer	
FO-238513	Routine	Scheduled Maint. (PM)	1/23/2013	1/29/2013	6	PM - Air Dryer	
FO-221938	Routine	Scheduled Maint. (PM)	7/20/2012	7/24/2012	4	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221955	Routine	Scheduled Maint. (PM)	7/20/2012	7/24/2012	4	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237872	Routine	Scheduled Maint. (PM)	1/14/2013	1/18/2013	4	PM - Air Dryer	
FO-238530	Routine	Scheduled Maint. (PM)	1/28/2013	2/1/2013	4	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-238532	Routine	Scheduled Maint. (PM)	1/28/2013	2/1/2013	4	PM - Air Dryer	
FO-221262	Routine	Scheduled Maint. (PM)	8/16/2012	8/17/2012	1	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-235405	Routine	Scheduled Maint. (PM)	12/18/2012	12/19/2012	1	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218423	Routine	Scheduled Maint. (PM)	6/1/2012	6/1/2012	0	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221347	Routine	Scheduled Maint. (PM)	7/30/2012	7/30/2012	0	Boiler Open Clean & Close - Vapor Boilers	
FO-221946	Routine	Scheduled Maint. (PM)	7/24/2012	7/24/2012	0	PM - Air Compressor, Reciprocating 5-40 H.P.	

			Finish Date	Due Date			Total per Trade
FO-222538	Routine	Scheduled Maint. (PM)	8/15/2012	8/15/2012	0	Boiler - Open Clean and Close 60 inch Boilers	
FO-225391	Low	Scheduled Maint. (PM)	10/8/2012	10/8/2012	0	Boiler - Open Clean and Close 60 inch Boilers	
FO-233516	Routine	Scheduled Maint. (PM)	11/30/2012	11/30/2012	0	PM - Air Dryer	
FO-233519	Routine	Scheduled Maint. (PM)	12/3/2012	12/3/2012	0	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-235404	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	PM - Air Dryer	
FO-237382	Routine	Scheduled Maint. (PM)	1/10/2013	1/10/2013	0	PM - Air Dryer	
FO-218390	Routine	Scheduled Maint. (PM)	6/12/2012	6/11/2012	-1	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218396	Routine	Scheduled Maint. (PM)	5/21/2012	5/20/2012	-1	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-213928	Routine	Scheduled Maint. (PM)	4/18/2012	4/16/2012	-2	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218426	Routine	Scheduled Maint. (PM)	6/18/2012	6/16/2012	-2	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-226841	Routine	Scheduled Maint. (PM)	9/26/2012	9/24/2012	-2	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-233515	Routine	Scheduled Maint. (PM)	12/5/2012	12/3/2012	-2	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221279	Routine	Scheduled Maint. (PM)	7/17/2012	7/14/2012	-3	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221280	Routine	Scheduled Maint. (PM)	7/17/2012	7/14/2012	-3	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221281	Routine	Scheduled Maint. (PM)	7/17/2012	7/14/2012	-3	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-233517	Routine	Scheduled Maint. (PM)	12/3/2012	11/30/2012	-3	PM - Air Dryer	
FO-233518	Routine	Scheduled Maint. (PM)	12/3/2012	11/30/2012	-3	PM - Air Dryer	
FO-214088	Routine	Scheduled Maint. (PM)	4/13/2012	4/9/2012	-4	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-214109	Routine	Scheduled Maint. (PM)	5/24/2012	5/17/2012	-7	Boiler - Open Clean and Close 48 inch Boilers	
FO-214138	Routine	Scheduled Maint. (PM)	5/24/2012	5/17/2012	-7	Boiler - Open Clean and Close 78 inch Boilers	
FO-225589	Routine	Scheduled Maint. (PM)	9/14/2012	9/7/2012	-7	PM - Air Dryer	
FO-236055	Routine	Scheduled Maint. (PM)	1/7/2013	12/31/2012	-7	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-236106	Routine	Scheduled Maint. (PM)	1/2/2013	12/26/2012	-7	PM - Air Dryer	
FO-218391	Routine	Scheduled Maint. (PM)	6/7/2012	5/30/2012	-8	PM - Air Dryer	
FO-218392	Routine	Scheduled Maint. (PM)	6/7/2012	5/30/2012	-8	PM - Air Dryer	
FO-221222	Routine	Scheduled Maint. (PM)	7/19/2012	7/11/2012	-8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-225560	Routine	Scheduled Maint. (PM)	9/14/2012	9/6/2012	-8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237826	Routine	Scheduled Maint. (PM)	1/23/2013	1/15/2013	-8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237827	Routine	Scheduled Maint. (PM)	1/23/2013	1/15/2013	-8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-237828	Routine	Scheduled Maint. (PM)	1/23/2013	1/15/2013	-8	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218394	Routine	Scheduled Maint. (PM)	7/5/2012	6/26/2012	-9	Boiler - Open Clean and Close 60 inch Boilers	
FO-218403	Routine	Scheduled Maint. (PM)	6/7/2012	5/29/2012	-9	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-230428	Routine	Scheduled Maint. (PM)	11/2/2012	10/24/2012	-9	PM - Air Dryer	
FO-230429	Routine	Scheduled Maint. (PM)	11/2/2012	10/24/2012	-9	PM - Air Dryer	
FO-217464	Routine	Scheduled Maint. (PM)	5/25/2012	5/15/2012	-10	Boiler - Open Clean and Close 60 inch Boilers	
FO-226791	Routine	Scheduled Maint. (PM)	10/4/2012	9/24/2012	-10	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-224674	Routine	Scheduled Maint. (PM)	8/21/2012	8/10/2012	-11	PM - Air Dryer	
FO-224718	Routine	Scheduled Maint. (PM)	8/21/2012	8/10/2012	-11	PM - Air Dryer	
FO-234332	Routine	Scheduled Maint. (PM)	12/18/2012	12/7/2012	-11	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-226563	Low	Scheduled Maint. (PM)	10/4/2012	9/22/2012	-12	Boiler - Open Clean and Close 60 inch Boilers	
FO-213578	Routine	Scheduled Maint. (PM)	5/3/2012	4/20/2012	-13	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218389	Routine	Scheduled Maint. (PM)	6/12/2012	5/30/2012	-13	PM - Air Dryer	
FO-226800	Routine	Scheduled Maint. (PM)	10/4/2012	9/21/2012	-13	PM - Air Dryer	
FO-226193	Low	Scheduled Maint. (PM)	10/17/2012	10/3/2012	-14	Boiler - Open Clean and Close 48 inch Boilers	

Finish Date Due Date

Total per Trade

FO-229472	Routine	Scheduled Maint. (PM)	11/2/2012	10/19/2012	-14	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-235391	Routine	Scheduled Maint. (PM)	1/3/2013	12/20/2012	-14	PM - Air Dryer
FO-235392	Routine	Scheduled Maint. (PM)	1/3/2013	12/20/2012	-14	PM - Air Dryer
FO-235417	Routine	Scheduled Maint. (PM)	1/2/2013	12/19/2012	-14	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221297	Routine	Scheduled Maint. (PM)	7/25/2012	7/10/2012	-15	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-229438	Routine	Scheduled Maint. (PM)	11/1/2012	10/17/2012	-15	PM - Air Dryer
FO-232841	Routine	Scheduled Maint. (PM)	12/5/2012	11/20/2012	-15	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-235416	Routine	Scheduled Maint. (PM)	1/3/2013	12/19/2012	-15	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-212820	Routine	Scheduled Maint. (PM)	5/16/2012	4/29/2012	-17	Boiler - Open Clean and Close 60 inch Boilers
FO-235375	Routine	Scheduled Maint. (PM)	1/7/2013	12/19/2012	-19	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-214119	Routine	Scheduled Maint. (PM)	5/22/2012	5/2/2012	-20	PM - Boiler, Steam Boiler, 500-1000 MBH
FO-221233	Routine	Scheduled Maint. (PM)	7/17/2012	6/27/2012	-20	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221328	Low	Scheduled Maint. (PM)	7/16/2012	6/26/2012	-20	PM - Air Dryer
FO-227253	Routine	Scheduled Maint. (PM)	11/1/2012	10/12/2012	-20	PM - Air Dryer
FO-212494	Routine	Scheduled Maint. (PM)	5/4/2012	4/13/2012	-21	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-216140	Routine	Scheduled Maint. (PM)	6/8/2012	5/17/2012	-22	Boiler - Open Clean and Close 78 inch Boilers
FO-221329	Low	Scheduled Maint. (PM)	7/18/2012	6/26/2012	-22	PM - Air Dryer
FO-226192	Routine	Scheduled Maint. (PM)	10/23/2012	10/1/2012	-22	Boiler - Open Clean and Close 48 inch Boilers
FO-226745	Medium	Scheduled Maint. (PM)	10/19/2012	9/26/2012	-23	State Boiler Inspection
FO-212495	Routine	Scheduled Maint. (PM)	5/7/2012	4/13/2012	-24	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218395	Routine	Scheduled Maint. (PM)	6/14/2012	5/20/2012	-25	PM - Air Dryer
FO-219934	Low	Scheduled Maint. (PM)	8/28/2012	8/3/2012	-25	Boiler - Open Clean and Close 78 inch Boilers
FO-230691	Routine	Scheduled Maint. (PM)	12/4/2012	11/9/2012	-25	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221241	Routine	Scheduled Maint. (PM)	8/17/2012	7/21/2012	-27	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221284	Routine	Scheduled Maint. (PM)	7/16/2012	6/19/2012	-27	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221285	Routine	Scheduled Maint. (PM)	7/16/2012	6/19/2012	-27	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-220532	Routine	Scheduled Maint. (PM)	8/1/2012	7/4/2012	-28	Boiler - Open Clean and Close 60 inch Boilers
FO-221235	Routine	Scheduled Maint. (PM)	7/25/2012	6/27/2012	-28	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221236	Routine	Scheduled Maint. (PM)	7/25/2012	6/27/2012	-28	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221314	Routine	Scheduled Maint. (PM)	7/18/2012	6/20/2012	-28	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221315	Routine	Scheduled Maint. (PM)	7/18/2012	6/20/2012	-28	PM - Air Dryer
FO-221316	Routine	Scheduled Maint. (PM)	7/18/2012	6/20/2012	-28	PM - Air Dryer
FO-218398	Low	Scheduled Maint. (PM)	6/14/2012	5/17/2012	-28	Boiler Rear Refractory Inspection - 60 " Boiler
FO-236058	Routine	Scheduled Maint. (PM)	1/24/2013	12/27/2012	-28	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221330	Low	Scheduled Maint. (PM)	7/18/2012	6/19/2012	-29	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-236056	Routine	Scheduled Maint. (PM)	1/25/2013	12/27/2012	-29	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-235363	Routine	Scheduled Maint. (PM)	1/24/2013	12/24/2012	-31	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-212493	Routine	Scheduled Maint. (PM)	5/15/2012	4/13/2012	-32	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-214107	Routine	Scheduled Maint. (PM)	6/18/2012	5/17/2012	-32	Boiler - Open Clean and Close 60 inch Boilers
FO-214122	Low	Scheduled Maint. (PM)	6/18/2012	5/17/2012	-32	State Boiler Inspection - http://www.hsb.com/cmsfiles/769.pdf
FO-217617	Routine	Scheduled Maint. (PM)	7/10/2012	6/7/2012	-33	Boiler - Open Clean and Close 78 inch Boilers
FO-218418	Routine	Scheduled Maint. (PM)	6/4/2012	5/2/2012	-33	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-226565	Low	Scheduled Maint. (PM)	10/26/2012	9/22/2012	-34	Boiler - Open Clean and Close 60 inch Boilers
FO-221263	Routine	Scheduled Maint. (PM)	8/16/2012	7/12/2012	-35	PM - Air Compressor, Reciprocating 5-40 H.P.

			Finish Date	Due Date	Total per Trade	
FO-221960	Routine	Scheduled Maint. (PM)	8/28/2012	7/24/2012	-35	PM - Air Dryer
FO-224688	Routine	Scheduled Maint. (PM)	9/14/2012	8/10/2012	-35	PM - Air Dryer
FO-214108	Routine	Scheduled Maint. (PM)	6/22/2012	5/17/2012	-36	Boiler - Open Clean and Close 48 inch Boilers
FO-218410	Low	Scheduled Maint. (PM)	7/26/2012	6/20/2012	-36	Boiler - Open Clean and Close 60 inch Boilers
FO-226742	Routine	Scheduled Maint. (PM)	10/31/2012	9/24/2012	-37	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-226749	Routine	Scheduled Maint. (PM)	11/1/2012	9/24/2012	-38	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-226806	Routine	Scheduled Maint. (PM)	11/1/2012	9/24/2012	-38	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218417	Routine	Scheduled Maint. (PM)	6/12/2012	5/2/2012	-41	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218405	Routine	Scheduled Maint. (PM)	6/13/2012	5/1/2012	-43	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218406	Routine	Scheduled Maint. (PM)	6/13/2012	5/1/2012	-43	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218408	Routine	Scheduled Maint. (PM)	6/13/2012	5/1/2012	-43	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218407	Routine	Scheduled Maint. (PM)	6/14/2012	5/1/2012	-44	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218414	Routine	Scheduled Maint. (PM)	6/12/2012	4/29/2012	-44	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218421	Routine	Scheduled Maint. (PM)	6/14/2012	5/1/2012	-44	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-232865	Routine	Scheduled Maint. (PM)	1/3/2013	11/20/2012	-44	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218430	Routine	Scheduled Maint. (PM)	7/9/2012	5/24/2012	-46	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218411	Routine	Scheduled Maint. (PM)	7/25/2012	6/8/2012	-47	Boiler - Open Clean and Close 60 inch Boilers
FO-221348	Low	Scheduled Maint. (PM)	9/10/2012	7/21/2012	-51	Boiler - Open Clean and Close 48 inch Boilers
FO-218401	Routine	Scheduled Maint. (PM)	8/24/2012	7/1/2012	-54	Boiler - Open Clean and Close 48 inch Boilers
FO-221927	Routine	Scheduled Maint. (PM)	9/18/2012	7/24/2012	-56	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221238	Routine	Scheduled Maint. (PM)	9/13/2012	7/17/2012	-58	PM - Air Dryer
FO-229439	Routine	Scheduled Maint. (PM)	12/14/2012	10/17/2012	-58	PM - Air Dryer
FO-222014	Low	Scheduled Maint. (PM)	10/8/2012	8/10/2012	-59	Boiler - Open Clean and Close 60 inch Boilers
FO-224934	Low	Scheduled Maint. (PM)	11/8/2012	9/9/2012	-60	Boiler - Open Clean and Close 60 inch Boilers
FO-220534	Routine	Scheduled Maint. (PM)	9/12/2012	7/11/2012	-63	Boiler - Open Clean and Close 48 inch Boilers
FO-221332	Low	Scheduled Maint. (PM)	9/19/2012	7/18/2012	-63	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-217616	Routine	Scheduled Maint. (PM)	8/10/2012	6/7/2012	-64	Boiler - Open Clean and Close 78 inch Boilers
FO-226833	Low	Scheduled Maint. (PM)	11/30/2012	9/26/2012	-65	Boiler - Open Clean and Close 78 inch Boilers
FO-218397	Low	Scheduled Maint. (PM)	8/31/2012	6/20/2012	-72	Boiler - Open Clean and Close 48 inch Boilers
FO-218409	Low	Scheduled Maint. (PM)	7/12/2012	5/1/2012	-72	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218427	Routine	Scheduled Maint. (PM)	8/30/2012	6/16/2012	-75	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218428	Low	Scheduled Maint. (PM)	8/29/2012	6/15/2012	-75	Boiler Open Clean & Close - Vapor Boilers
FO-221255	Low	Scheduled Maint. (PM)	10/23/2012	8/9/2012	-75	Boiler Open Clean & Close - Vapor Boilers
FO-218400	Routine	Scheduled Maint. (PM)	7/26/2012	5/11/2012	-76	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218420	Low	Scheduled Maint. (PM)	9/12/2012	6/27/2012	-77	Boiler - Open Clean and Close 48 inch Boilers
FO-218415	Routine	Scheduled Maint. (PM)	8/1/2012	5/15/2012	-78	PM - Air Dryer
FO-221261	Routine	Scheduled Maint. (PM)	10/2/2012	7/16/2012	-78	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218416	Routine	Scheduled Maint. (PM)	8/2/2012	5/15/2012	-79	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221326	Low	Scheduled Maint. (PM)	9/6/2012	6/19/2012	-79	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-221327	Low	Scheduled Maint. (PM)	9/6/2012	6/19/2012	-79	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-226788	Routine	Scheduled Maint. (PM)	12/12/2012	9/24/2012	-79	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-218419	Routine	Scheduled Maint. (PM)	7/24/2012	5/2/2012	-83	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-213528	Routine	Scheduled Maint. (PM)	7/3/2012	4/7/2012	-87	Boiler - Open Clean and Close 60 inch Boilers
FO-226817	Routine	Scheduled Maint. (PM)	12/20/2012	9/24/2012	-87	PM - Air Compressor, Reciprocating 5-40 H.P.

			Finish Date	Due Date			Total per Trade
FO-226564	Low	Scheduled Maint. (PM)	12/20/2012	9/22/2012	-89	Boiler - Open Clean and Close 60 inch Boilers	
FO-222510	Routine	Scheduled Maint. (PM)	10/31/2012	8/1/2012	-91	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-222511	Routine	Scheduled Maint. (PM)	10/31/2012	8/1/2012	-91	PM - Air Dryer	
FO-226816	Routine	Scheduled Maint. (PM)	12/20/2012	9/20/2012	-91	PM - Air Dryer	
FO-214096	Routine	Scheduled Maint. (PM)	8/17/2012	5/17/2012	-92	Boiler - Open Clean and Close 48 inch Boilers	
FO-212819	Routine	Scheduled Maint. (PM)	8/2/2012	4/29/2012	-95	Boiler - Open Clean and Close 60 inch Boilers	
FO-218425	Routine	Scheduled Maint. (PM)	9/21/2012	6/16/2012	-97	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-229384	Routine	Scheduled Maint. (PM)	1/23/2013	10/17/2012	-98	PM - Air Dryer	
FO-209528	Routine	Scheduled Maint. (PM)	5/4/2012	1/24/2012	-101	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218429	Low	Scheduled Maint. (PM)	10/11/2012	6/27/2012	-106	Boiler Open Clean & Close - Vapor Boilers	
FO-221344	Routine	Scheduled Maint. (PM)	11/28/2012	8/14/2012	-106	Boiler - Open Clean and Close 78 inch Boilers	
FO-221237	Routine	Scheduled Maint. (PM)	11/2/2012	7/17/2012	-108	PM - Air Dryer	
FO-221254	Low	Scheduled Maint. (PM)	12/3/2012	8/16/2012	-109	Boiler Open Clean & Close - Vapor Boilers	
FO-221300	Routine	Scheduled Maint. (PM)	10/31/2012	7/13/2012	-110	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221301	Routine	Scheduled Maint. (PM)	10/31/2012	7/13/2012	-110	PM - Air Dryer	
FO-221299	Routine	Scheduled Maint. (PM)	11/1/2012	7/13/2012	-111	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-229413	Routine	Scheduled Maint. (PM)	1/23/2013	10/3/2012	-112	PM - Air Dryer	
FO-221304	Routine	Scheduled Maint. (PM)	11/2/2012	7/11/2012	-114	PM - Air Dryer	
FO-219969	Low	Scheduled Maint. (PM)	10/29/2012	7/4/2012	-117	Boiler - Open Clean and Close 48 inch Boilers	
FO-222536	Routine	Scheduled Maint. (PM)	12/12/2012	8/15/2012	-119	Boiler - Open Clean and Close 60 inch Boilers	
FO-218385	Routine	Scheduled Maint. (PM)	10/2/2012	5/30/2012	-125	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-222537	Low	Scheduled Maint. (PM)	12/18/2012	8/15/2012	-125	Boiler Open Clean & Close - Fulton Boilers	
FO-208563	Routine	Scheduled Maint. (PM)	5/4/2012	12/30/2011	-126	PM - Water/Air Cooled Condenser	
FO-208564	Routine	Scheduled Maint. (PM)	5/9/2012	12/30/2011	-131	PM - Water/Air Cooled Condenser	
FO-214097	Routine	Scheduled Maint. (PM)	9/28/2012	5/17/2012	-134	Boiler - Open Clean and Close 78 inch Boilers	
FO-218404	Routine	Scheduled Maint. (PM)	10/12/2012	5/30/2012	-135	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218412	Routine	Scheduled Maint. (PM)	10/2/2012	5/14/2012	-141	PM - Air Dryer	
FO-218399	Routine	Scheduled Maint. (PM)	10/2/2012	5/11/2012	-144	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221232	Routine	Scheduled Maint. (PM)	12/13/2012	7/17/2012	-149	PM - Air Dryer	
FO-221321	Routine	Scheduled Maint. (PM)	12/20/2012	6/20/2012	-183	PM - Air Dryer	
FO-222238	Routine	Scheduled Maint. (PM)	1/30/2013	7/31/2012	-183	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-221260	Routine	Scheduled Maint. (PM)	1/30/2013	6/6/2012	-238	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-218413	Routine	Scheduled Maint. (PM)	1/30/2013	5/14/2012	-261	PM - Air Compressor, Reciprocating 5-40 H.P.	

E - Director

1 of 1 100%

FO-222547 Low Scheduled Maint. (PM) 7/16/2012 8/30/2012 45 Vendor or Contractor Work

E - Midnight Engineer

34 of 47 72%

FO-208364 Routine Scheduled Maint. (PM) 2/17/2012 3/28/2012 40 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-211864 Routine Scheduled Maint. (PM) 3/22/2012 4/4/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-211865 Routine Scheduled Maint. (PM) 3/22/2012 4/4/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-211866 Routine Scheduled Maint. (PM) 3/22/2012 4/4/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-211867 Routine Scheduled Maint. (PM) 3/22/2012 4/4/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-211868 Routine Scheduled Maint. (PM) 3/22/2012 4/4/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

FO-212521 Routine Scheduled Maint. (PM) 3/29/2012 4/11/2012 13 PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

			Finish Date	Due Date			Total per Trade
FO-219731	Routine	Scheduled Maint. (PM)	6/13/2012	6/27/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219732	Routine	Scheduled Maint. (PM)	6/13/2012	6/27/2012	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-230770	Routine	Scheduled Maint. (PM)	12/28/2012	12/30/2012	2	PM - Fan Coil/HV/AC Unit	
FO-224633	Routine	Scheduled Maint. (PM)	8/30/2012	8/31/2012	1	PM - Unspecified	
FO-224723	Routine	Scheduled Maint. (PM)	8/30/2012	8/31/2012	1	PM - Condensate Return System **Needs Task Sheet**	
FO-213552	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213553	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213554	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213555	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213556	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213557	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213558	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213559	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213560	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-213591	Routine	Scheduled Maint. (PM)	4/18/2012	4/18/2012	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-226842	Routine	Scheduled Maint. (PM)	10/8/2012	10/5/2012	-3	PM - Condensate Return System **Needs Task Sheet**	
FO-224970	Routine	Scheduled Maint. (PM)	8/30/2012	8/22/2012	-8	PM - Sewage Lift Pump	
FO-224971	Routine	Scheduled Maint. (PM)	8/30/2012	8/22/2012	-8	PM - Sewage Lift Pump	
FO-236059	Routine	Scheduled Maint. (PM)	1/30/2013	12/27/2012	-34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236060	Routine	Scheduled Maint. (PM)	1/30/2013	12/27/2012	-34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236061	Routine	Scheduled Maint. (PM)	1/30/2013	12/27/2012	-34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236062	Routine	Scheduled Maint. (PM)	1/30/2013	12/27/2012	-34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-236063	Routine	Scheduled Maint. (PM)	1/30/2013	12/27/2012	-34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219723	Routine	Scheduled Maint. (PM)	8/1/2012	6/27/2012	-35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219724	Routine	Scheduled Maint. (PM)	8/1/2012	6/27/2012	-35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219727	Routine	Scheduled Maint. (PM)	8/1/2012	6/27/2012	-35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219728	Routine	Scheduled Maint. (PM)	8/1/2012	6/27/2012	-35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-219729	Routine	Scheduled Maint. (PM)	8/1/2012	6/27/2012	-35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	
FO-207469	Routine	Scheduled Maint. (PM)	2/10/2012	10/17/2011	-116	PM - Fan Coil/HV/AC Unit	

Trades

220 of 265 83%

T - Electrician

220 of 265 83%

FO-206105	High	Scheduled Maint. (PM)	2/3/2012	2/22/2012	19	Generator Test Tuesday, February 21 @ 8:15 am
FO-206106	High	Scheduled Maint. (PM)	2/3/2012	2/22/2012	19	Generator Test Tuesday, February 21 @ 8:15 am2 Work orders was generated, please close, Duplicate.
FO-233540	High	Scheduled Maint. (PM)	11/8/2012	11/20/2012	12	Generator TestFinished 11/9/2012 LT
FO-216427	High	Scheduled Maint. (PM)	5/18/2012	5/26/2012	8	Generator Test Friday, May 25 @ 7:15am
FO-216430	High	Scheduled Maint. (PM)	5/18/2012	5/26/2012	8	Generator Test Friday, May 25 @ 10am
FO-210416	High	Scheduled Maint. (PM)	3/14/2012	3/21/2012	7	Generator Test Tuesday, March 20 @ 9:15am
FO-203446	High	Scheduled Maint. (PM)	1/12/2012	1/17/2012	5	Generator Test Thursday, January 12 @ 7:15am
FO-233529	High	Scheduled Maint. (PM)	11/15/2012	11/20/2012	5	Generator TestDetroit, MI 48227
FO-203465	High	Scheduled Maint. (PM)	1/17/2012	1/20/2012	3	Generator Test Tuesday, January 17 @ 7:15am
FO-203470	High	Scheduled Maint. (PM)	1/17/2012	1/20/2012	3	Generator Test Tuesday, January 17 @ 8:15am
FO-203471	High	Scheduled Maint. (PM)	1/17/2012	1/20/2012	3	Generator Test Tuesday, January 17 @ 8:15am

Finish Date Due Date**Total per Trade**

FO-236593	Routine	Scheduled Maint. (PM)	12/24/2012	12/27/2012	3	Generator Test Finished 12/27/12 LT
FO-213787	High	Scheduled Maint. (PM)	4/24/2012	4/26/2012	2	Generator Test Wednesday, April 25 @ 7:15am
FO-222227	High	Scheduled Maint. (PM)	7/5/2012	7/7/2012	2	Generator Test
FO-203448	High	Scheduled Maint. (PM)	1/25/2012	1/26/2012	1	Generator Test Wednesday, January 25 @ 7:15am
FO-203449	High	Scheduled Maint. (PM)	1/18/2012	1/19/2012	1	Generator Test Wednesday, January 18 @ 10am
FO-203451	High	Scheduled Maint. (PM)	1/12/2012	1/13/2012	1	Generator Test Thursday, January 12 @ 7:15am
FO-203453	High	Scheduled Maint. (PM)	1/24/2012	1/25/2012	1	Generator Test Tuesday, January 24 @ 8am
FO-203454	High	Scheduled Maint. (PM)	1/24/2012	1/25/2012	1	Generator Test Tuesday, January 24 @ 8am
FO-203455	High	Scheduled Maint. (PM)	1/24/2012	1/25/2012	1	Generator Test Tuesday, January 24 @ 8am
FO-203456	High	Scheduled Maint. (PM)	1/24/2012	1/25/2012	1	Generator Test Tuesday, January 24 @ 8am
FO-203457	High	Scheduled Maint. (PM)	1/25/2012	1/26/2012	1	Generator Test Wednesday, January 25 @ 7:15am
FO-203458	High	Scheduled Maint. (PM)	1/6/2012	1/7/2012	1	Monthly Generator Test Friday, January 6 @ 2:15pm
FO-203459	High	Scheduled Maint. (PM)	1/17/2012	1/18/2012	1	Generator Test Tuesday, January 17 @ 9:15am
FO-203460	High	Scheduled Maint. (PM)	1/10/2012	1/11/2012	1	Generator Test Tuesday, January 10 @ 12:15pm
FO-203461	High	Scheduled Maint. (PM)	1/11/2012	1/12/2012	1	Generator Test Wednesday, January 11 @ 12:15 pm
FO-203466	High	Scheduled Maint. (PM)	1/27/2012	1/28/2012	1	Generator Test Friday, January 27 @ 7:15am
FO-203467	High	Scheduled Maint. (PM)	1/13/2012	1/14/2012	1	Generator Test Friday, January 13 @ 7:15 am
FO-203468	High	Scheduled Maint. (PM)	1/13/2012	1/14/2012	1	Generator Test Friday, January 13 @ 7:15 am
FO-203469	High	Scheduled Maint. (PM)	1/27/2012	1/28/2012	1	Generator Test Friday, January 27 @ 10am
FO-204619	High	Scheduled Maint. (PM)	1/12/2012	1/13/2012	1	Generator Test
FO-206088	High	Scheduled Maint. (PM)	2/22/2012	2/23/2012	1	Generator Test Wednesday, February 22 @ 7:15am
FO-206089	High	Scheduled Maint. (PM)	2/15/2012	2/16/2012	1	Generator Test Wednesday, February 15 @ 10am
FO-206091	High	Scheduled Maint. (PM)	2/9/2012	2/10/2012	1	Generator Test Thursday, February 9 @ 7:15am
FO-206092	High	Scheduled Maint. (PM)	2/22/2012	2/23/2012	1	Generator Test Wednesday, February 22 @ 7:15am
FO-206093	High	Scheduled Maint. (PM)	2/3/2012	2/4/2012	1	Generator Test Friday, February 3 @ 2:15pm
FO-206094	High	Scheduled Maint. (PM)	2/21/2012	2/22/2012	1	Generator Test Tuesday, February 21 @ 9:15am
FO-206095	High	Scheduled Maint. (PM)	2/14/2012	2/15/2012	1	Generator Test Tuesday, February 14 @ 12:15pm
FO-206096	High	Scheduled Maint. (PM)	2/8/2012	2/9/2012	1	Generator Test Wednesday, February 8 @ 12:15pm
FO-206100	High	Scheduled Maint. (PM)	2/21/2012	2/22/2012	1	Generator Test Tuesday, February 21 @ 7:15am
FO-206101	High	Scheduled Maint. (PM)	2/24/2012	2/25/2012	1	Generator Test Friday, February 24 @ 7:15am
FO-206102	High	Scheduled Maint. (PM)	2/10/2012	2/11/2012	1	Generator Test Friday, February 10 @ 7:15am
FO-206103	High	Scheduled Maint. (PM)	2/10/2012	2/11/2012	1	Generator Test Friday, February 10 @ 7:15am
FO-206116	High	Scheduled Maint. (PM)	2/17/2012	2/18/2012	1	Generator Test
FO-206839	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Test Tuesday, February 28 @ 8am.
FO-206841	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Test Tuesday, February 28 @ 8am.
FO-206842	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Test Tuesday, February 28 @ 8am.
FO-206843	High	Scheduled Maint. (PM)	2/28/2012	2/29/2012	1	Generator Test Tuesday, February 28 @ 8am.
FO-206844	High	Scheduled Maint. (PM)	2/21/2012	2/22/2012	1	Generator Test
FO-210403	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Test Thursday, March 8 @ 7:15 am
FO-210404	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Test Thursday, March 8 @ 7:15 am
FO-210405	High	Scheduled Maint. (PM)	3/28/2012	3/29/2012	1	Generator Test Wednesday, March 28 @ 7:15am
FO-210406	High	Scheduled Maint. (PM)	3/21/2012	3/22/2012	1	Generator Test Wednesday, March 21 @ 10am
FO-210408	High	Scheduled Maint. (PM)	3/8/2012	3/9/2012	1	Generator Test Thursday, March 8 @ 7:15am
FO-210410	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Test Tuesday, March 27 @ 8am

Finish Date Due Date

Total per Trade

FO-210411	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Test Tuesday, March 27 @ 8am
FO-210412	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Test Tuesday, March 27 @ 8am
FO-210413	High	Scheduled Maint. (PM)	3/27/2012	3/28/2012	1	Generator Test Tuesday, March 27 @ 8am
FO-210414	High	Scheduled Maint. (PM)	3/28/2012	3/29/2012	1	Generator Test Wednesday, March 28 @ 7:15am
FO-210417	High	Scheduled Maint. (PM)	3/13/2012	3/14/2012	1	Generator Test Tuesday, March 13 @ 12:15pm
FO-210418	High	Scheduled Maint. (PM)	3/14/2012	3/15/2012	1	Generator Test Wednesday, March 14 @ 12:15 pm
FO-210423	High	Scheduled Maint. (PM)	3/23/2012	3/24/2012	1	Generator Test Friday, March 23 @ 7:15am
FO-210424	High	Scheduled Maint. (PM)	3/9/2012	3/10/2012	1	Generator Test Friday, March 9 @ 7:15am
FO-210425	High	Scheduled Maint. (PM)	3/9/2012	3/10/2012	1	Generator Test Friday, March 9 @ 7:15am
FO-210426	High	Scheduled Maint. (PM)	3/23/2012	3/24/2012	1	Generator Test Friday, March 23 at 7:15am.
FO-213785	High	Scheduled Maint. (PM)	4/12/2012	4/13/2012	1	Generator Test Thursday, April 12 @ 7:15 am
FO-213786	High	Scheduled Maint. (PM)	4/12/2012	4/13/2012	1	Generator Test Thursday, April 12 @ 7:15 am
FO-213788	High	Scheduled Maint. (PM)	4/18/2012	4/19/2012	1	Generator Test Wednesday, April 18 @ 10am
FO-213792	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Test Tuesday, April 24 @ 8am
FO-213793	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Test Tuesday, April 24 @ 8am
FO-213794	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Test Tuesday, April 24 @ 8am
FO-213795	High	Scheduled Maint. (PM)	4/24/2012	4/25/2012	1	Generator Test Tuesday, April 24 @ 8am
FO-213796	High	Scheduled Maint. (PM)	4/25/2012	4/26/2012	1	Generator Test Wednesday, April 25 @ 7:15am
FO-213797	High	Scheduled Maint. (PM)	4/6/2012	4/7/2012	1	Generator Test Friday, April 6th @ 2:15pm
FO-213798	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Test Tuesday, April 17 @ 9:15am
FO-213799	High	Scheduled Maint. (PM)	4/10/2012	4/11/2012	1	Generator Test Tuesday, April 10th @ 12:15pm
FO-213800	High	Scheduled Maint. (PM)	4/11/2012	4/12/2012	1	Generator Test Wednesday, April 11 @ 12:15 pm
FO-213804	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Test Tuesday, April 17 @ 7:15am
FO-213805	High	Scheduled Maint. (PM)	4/27/2012	4/28/2012	1	Generator Test Friday, April 27 @ 7:15am
FO-213806	High	Scheduled Maint. (PM)	4/13/2012	4/14/2012	1	Generator Test Friday, April 13 @ 7:15am
FO-213807	High	Scheduled Maint. (PM)	4/13/2012	4/14/2012	1	Generator Test Friday, April 13 @ 7:15am
FO-213808	High	Scheduled Maint. (PM)	4/27/2012	4/28/2012	1	Generator Test Friday, April 27 @ 10am
FO-213809	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Test Tuesday, April 17 @ 8:15am
FO-213810	High	Scheduled Maint. (PM)	4/17/2012	4/18/2012	1	Generator Test Tuesday, April 17 @ 8:15am
FO-216407	High	Scheduled Maint. (PM)	5/10/2012	5/11/2012	1	Generator Test Thursday, May 10 @ 7:15am
FO-216408	High	Scheduled Maint. (PM)	5/10/2012	5/11/2012	1	Generator Test Thursday, May 10 @ 7:15am
FO-216409	High	Scheduled Maint. (PM)	5/23/2012	5/24/2012	1	Generator Test Wednesday, May 23 @ 7:15am
FO-216410	High	Scheduled Maint. (PM)	5/16/2012	5/17/2012	1	Generator Test Wednesday, May 16 @ 10am
FO-216414	High	Scheduled Maint. (PM)	5/22/2012	5/23/2012	1	Generator Test Thursday, May 17 @ 8am
FO-216415	High	Scheduled Maint. (PM)	5/22/2012	5/23/2012	1	Generator Test Thursday, May 17 @ 8am
FO-216416	High	Scheduled Maint. (PM)	5/22/2012	5/23/2012	1	Generator Test Thursday, May 17 @ 8am
FO-216417	High	Scheduled Maint. (PM)	5/22/2012	5/23/2012	1	Generator Test Thursday, May 17 @ 8am
FO-216418	High	Scheduled Maint. (PM)	5/23/2012	5/24/2012	1	Generator Test Wednesday, May 23 @ 7:15am
FO-216419	High	Scheduled Maint. (PM)	5/4/2012	5/5/2012	1	Generator Test Friday, May 4 @2:15pm
FO-216422	High	Scheduled Maint. (PM)	5/9/2012	5/10/2012	1	Generator Test Wednesday, May 9 @ 12:15pm
FO-216428	High	Scheduled Maint. (PM)	5/11/2012	5/12/2012	1	Generator Test Friday, May 11 @ 7:15am
FO-216429	High	Scheduled Maint. (PM)	5/11/2012	5/12/2012	1	Generator Test Friday, May 11 @ 7:15am
FO-219222	High	Scheduled Maint. (PM)	6/1/2012	6/2/2012	1	Generator Test, June 1,2012 @ 7:15 AM
FO-219224	High	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	Generator Test, June 8, 2012 @ 7:15 AM

Finish Date Due Date

Total per Trade

FO-219225	High	Scheduled Maint. (PM)	6/8/2012	6/9/2012	1	Generator Test, June 8, 2012 @ 7:15 AM
FO-219228	High	Scheduled Maint. (PM)	6/27/2012	6/28/2012	1	Generator Test, June 26 @ 7:15 AM.
FO-219229	High	Scheduled Maint. (PM)	6/20/2012	6/21/2012	1	Generator Test, June 19, 2012 @ 7:15 AM.
FO-219231	High	Scheduled Maint. (PM)	6/14/2012	6/15/2012	1	Generator Test, June 14, 2012 @ 7:15 AM.
FO-219233	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Test, June 25, 2012 @ 8 AM.
FO-219234	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Test, June 25, 2012 @ 8 AM.
FO-219235	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Test, June 25, 2012 @ 8 AM.
FO-219236	High	Scheduled Maint. (PM)	6/26/2012	6/27/2012	1	Generator Test, June 25, 2012 @ 8 AM.
FO-219237	High	Scheduled Maint. (PM)	6/27/2012	6/28/2012	1	Generator Test, June 26, 2012 @ 7:15AM.
FO-219239	High	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	Generator Test, June 18, 2012 @ 9:15 AM.
FO-219240	High	Scheduled Maint. (PM)	6/12/2012	6/13/2012	1	Generator Test, June 11, 2012 @ 12:15 PM.
FO-219241	High	Scheduled Maint. (PM)	6/13/2012	6/14/2012	1	Generator Test, June 12, 2012 @ 12:15 PM.
FO-219245	High	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	Generator Test, June 18, 2012 @ 7:15 AM.
FO-219246	High	Scheduled Maint. (PM)	6/22/2012	6/23/2012	1	Generator Test, June 22, 2012 @ 7:15 AM.
FO-219248	High	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	Generator Tes, June 18, 2012 @ 8:15 AM.
FO-219249	High	Scheduled Maint. (PM)	6/19/2012	6/20/2012	1	Generator Test, June 18, 2012 @ 8:15.
FO-222252	High	Scheduled Maint. (PM)	7/20/2012	7/21/2012	1	Generator Test
FO-224213	High	Scheduled Maint. (PM)	8/8/2012	8/9/2012	1	Generator Test
FO-224233	High	Scheduled Maint. (PM)	8/28/2012	8/29/2012	1	Generator Test
FO-227348	High	Scheduled Maint. (PM)	9/18/2012	9/19/2012	1	Generator Test. Finished 12-10-12 PP.
FO-227385	High	Scheduled Maint. (PM)	9/18/2012	9/19/2012	1	Generator Test
FO-230395	High	Scheduled Maint. (PM)	10/11/2012	10/12/2012	1	Generator Test Finished 10/12/12 LT
FO-230397	High	Scheduled Maint. (PM)	10/11/2012	10/12/2012	1	Generator Test Finished 10/12/12 LT
FO-230411	High	Scheduled Maint. (PM)	10/16/2012	10/17/2012	1	Generator Test
FO-230417	High	Scheduled Maint. (PM)	10/11/2012	10/12/2012	1	Generator Test Finished 10/12/12 LT
FO-230782	High	Scheduled Maint. (PM)	10/5/2012	10/6/2012	1	Generator Test
FO-230785	High	Scheduled Maint. (PM)	10/23/2012	10/24/2012	1	Generator Test Finished 10/24/12 LT
FO-230787	High	Scheduled Maint. (PM)	10/23/2012	10/24/2012	1	Generator Test Finished 10/24/12 LT
FO-230789	High	Scheduled Maint. (PM)	10/23/2012	10/24/2012	1	Generator Test Finished 10/24/12 LT
FO-230791	High	Scheduled Maint. (PM)	10/23/2012	10/24/2012	1	Generator Test Finished 10/24/12 LT
FO-234243	Routine	Scheduled Maint. (PM)	11/28/2012	11/29/2012	1	Generator Test Finished 11/30/2012 LT
FO-234251	Routine	Scheduled Maint. (PM)	11/28/2012	11/29/2012	1	Generator Test Finished 11/30/2012 LT
FO-236585	Routine	Scheduled Maint. (PM)	12/19/2012	12/20/2012	1	Generator Test Finished 12/20/2012LT
FO-236587	Routine	Scheduled Maint. (PM)	12/28/2012	12/29/2012	1	Generator Test Finished 12/31/2012 LT
FO-236594	Routine	Scheduled Maint. (PM)	12/14/2012	12/15/2012	1	Generator Test Finished 12/17/2012 LT
FO-236595	Routine	Scheduled Maint. (PM)	12/14/2012	12/15/2012	1	Generator Test Finished 12/17/2012 LT
FO-237861	Routine	Scheduled Maint. (PM)	1/4/2013	1/5/2013	1	Generator Test Finished 1/7/2013 LT
FO-238024	Routine	Scheduled Maint. (PM)	1/10/2013	1/11/2013	1	Generator Test Finished 1/11/2013LT
FO-238026	Routine	Scheduled Maint. (PM)	1/10/2013	1/11/2013	1	Generator Test Finished 1/11/2013LT
FO-238027	Routine	Scheduled Maint. (PM)	1/11/2013	1/12/2013	1	Generator Test Finished 1/14/2013LT
FO-238029	Routine	Scheduled Maint. (PM)	1/11/2013	1/12/2013	1	Generator Test Finished 1/14/2013LT
FO-238031	Routine	Scheduled Maint. (PM)	1/10/2013	1/11/2013	1	Generator Test Finished 1/11/2013LT
FO-238053	Routine	Scheduled Maint. (PM)	1/8/2013	1/9/2013	1	Generator Test Finished 1/9/2013LT
FO-238060	Routine	Scheduled Maint. (PM)	1/8/2013	1/9/2013	1	Generator Test Finished 1/9/2013LT

Finish Date Due Date

Total per Trade

FO-238062	Routine	Scheduled Maint. (PM)	1/9/2013	1/10/2013	1	Generator Test Finished 1/10/2013LT
FO-238078	Routine	Scheduled Maint. (PM)	1/15/2013	1/16/2013	1	Generator Test Finished 1/17/2013 LT
FO-238082	Routine	Scheduled Maint. (PM)	1/16/2013	1/17/2013	1	Generator Test Finished 1/17/2013 LT
FO-238084	Routine	Scheduled Maint. (PM)	1/23/2013	1/24/2013	1	Generator Test Finished 1/24/2013 LT
FO-238085	Routine	Scheduled Maint. (PM)	1/25/2013	1/26/2013	1	Generator Test Finished 1/28/2013LT
FO-238087	Routine	Scheduled Maint. (PM)	1/25/2013	1/26/2013	1	Generator Test Finished 1/28/2013LT
FO-238099	Routine	Scheduled Maint. (PM)	1/15/2013	1/16/2013	1	Generator Test Finished 1/17/2013 LT
FO-238101	Routine	Scheduled Maint. (PM)	1/15/2013	1/16/2013	1	Generator Test Finished 1/17/2013 LT
FO-238103	Routine	Scheduled Maint. (PM)	1/23/2013	1/24/2013	1	Generator Test Finished 1/24/2013 LT
FO-238105	Routine	Scheduled Maint. (PM)	1/15/2013	1/16/2013	1	Generator Test Finished 1/17/2013 LT
FO-238623	Routine	Scheduled Maint. (PM)	1/7/2013	1/8/2013	1	Generator Test Finished 1-7-13 PP.
FO-238628	Routine	Scheduled Maint. (PM)	1/7/2013	1/8/2013	1	Generator Test Finished 1-7-13 PP.
FO-206086	High	Scheduled Maint. (PM)	2/10/2012	2/10/2012	0	Generator Test Thursday, February 9 @ 7:15amAlso check UPS Batteries, and fill as needed.
FO-206087	High	Scheduled Maint. (PM)	2/10/2012	2/10/2012	0	Generator Test Thursday, February 9 @ 7:15amAlso, check UPS Batteries, and fill as needed.
FO-222228	High	Scheduled Maint. (PM)	7/6/2012	7/6/2012	0	Generator Test
FO-222258	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222259	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222260	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-222261	High	Scheduled Maint. (PM)	7/25/2012	7/25/2012	0	Generator Test
FO-224228	High	Scheduled Maint. (PM)	8/22/2012	8/22/2012	0	Generator Test
FO-224230	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-224231	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-224232	High	Scheduled Maint. (PM)	8/29/2012	8/29/2012	0	Generator Test
FO-226843	High	Scheduled Maint. (PM)	9/12/2012	9/12/2012	0	Generator Test
FO-227354	High	Scheduled Maint. (PM)	9/18/2012	9/18/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227356	High	Scheduled Maint. (PM)	9/20/2012	9/20/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227358	High	Scheduled Maint. (PM)	9/27/2012	9/27/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227363	High	Scheduled Maint. (PM)	9/25/2012	9/25/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227365	High	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227367	High	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227369	High	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227371	High	Scheduled Maint. (PM)	9/26/2012	9/26/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227373	High	Scheduled Maint. (PM)	9/19/2012	9/19/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227377	High	Scheduled Maint. (PM)	9/27/2012	9/27/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227387	High	Scheduled Maint. (PM)	9/19/2012	9/19/2012	0	Generator Test. Finished 12-10-12 PP.
FO-227400	High	Scheduled Maint. (PM)	9/20/2012	9/20/2012	0	Generator Test. Finished 12-10-12 PP.
FO-229509	High	Scheduled Maint. (PM)	10/10/2012	10/10/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230393	High	Scheduled Maint. (PM)	10/17/2012	10/17/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230399	High	Scheduled Maint. (PM)	10/16/2012	10/16/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230401	High	Scheduled Maint. (PM)	10/18/2012	10/18/2012	0	Generator Test Finished 10/18/12 LS
FO-230403	High	Scheduled Maint. (PM)	10/5/2012	10/5/2012	0	Generator Test
FO-230404	High	Scheduled Maint. (PM)	10/17/2012	10/17/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230406	High	Scheduled Maint. (PM)	10/17/2012	10/17/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230409	High	Scheduled Maint. (PM)	10/10/2012	10/10/2012	0	Generator Test. Finished 12-10-12 PP.

			Finish Date	Due Date	Total per Trade	
FO-230415	High	Scheduled Maint. (PM)	10/5/2012	10/5/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230422	High	Scheduled Maint. (PM)	10/18/2012	10/18/2012	0	Generator Test Finished 10/19/12 LT
FO-230777	High	Scheduled Maint. (PM)	10/25/2012	10/25/2012	0	Generator Test. Finished 12-10-12 PP.
FO-230783	High	Scheduled Maint. (PM)	10/23/2012	10/23/2012	0	Generator Test Finished 10/24/12 LT
FO-230793	High	Scheduled Maint. (PM)	10/25/2012	10/25/2012	0	Generator Test. Finished 12-10*-12 PP.
FO-230800	High	Scheduled Maint. (PM)	10/5/2012	10/5/2012	0	Generator Test. Finished 12-10-12 PP.
FO-232903	High	Scheduled Maint. (PM)	11/13/2012	11/13/2012	0	Generator Test Finished 11/14/12 LT
FO-233530	High	Scheduled Maint. (PM)	11/8/2012	11/8/2012	0	Generator TestFinished 11/9/2012 LT
FO-233531	High	Scheduled Maint. (PM)	11/8/2012	11/8/2012	0	Generator TestFinished 11/9/2012 LT
FO-233534	High	Scheduled Maint. (PM)	11/20/2012	11/20/2012	0	Generator Test Finished 11/21/2012LT
FO-233535	High	Scheduled Maint. (PM)	11/20/2012	11/20/2012	0	Generator Test Finished 11/21/2012LT
FO-233536	High	Scheduled Maint. (PM)	11/9/2012	11/9/2012	0	Generator Test Finished 11/13/2012 LT
FO-233538	High	Scheduled Maint. (PM)	11/9/2012	11/9/2012	0	Generator Test Finished 11/13/2012 LT
FO-233625	High	Scheduled Maint. (PM)	11/20/2012	11/20/2012	0	Generator Test Finished 11/21/2012LT
FO-233632	High	Scheduled Maint. (PM)	11/15/2012	11/15/2012	0	Generator Test Finished 11/15/12 LS
FO-234247	Routine	Scheduled Maint. (PM)	11/28/2012	11/28/2012	0	Generator Test Finished 11/28/12 LS
FO-234248	Routine	Scheduled Maint. (PM)	11/28/2012	11/28/2012	0	Generator Test Finished 11/28/12 LS
FO-234249	Routine	Scheduled Maint. (PM)	11/28/2012	11/28/2012	0	Generator Test Finished 11/28/12 LS
FO-234250	Routine	Scheduled Maint. (PM)	11/28/2012	11/28/2012	0	Generator Test Finished 11/28/12 LS
FO-234252	Routine	Scheduled Maint. (PM)	11/15/2012	11/15/2012	0	Generator TestDetroit, MI 48227
FO-235418	Routine	Scheduled Maint. (PM)	12/11/2012	12/11/2012	0	Generator Test Finished 12/12/12 LT
FO-236034	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	Generator Test Finished 12/19/2012LT
FO-236038	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	Generator Test Finished 12/19/2012LT
FO-236039	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	Generator Test Finished 12/19/2012LT
FO-236100	Routine	Scheduled Maint. (PM)	12/18/2012	12/18/2012	0	Generator Test Finished 12/19/2012LT
FO-236101	Routine	Scheduled Maint. (PM)	12/20/2012	12/20/2012	0	Generator Test Finished 12/21/12 LT
FO-236110	Routine	Scheduled Maint. (PM)	12/19/2012	12/19/2012	0	Generator Test Finished 12/20/2012LT
FO-238055	Routine	Scheduled Maint. (PM)	1/10/2013	1/10/2013	0	Generator Test Finished 1/11/2013LT
FO-238080	Routine	Scheduled Maint. (PM)	1/15/2013	1/15/2013	0	Generator Test Finished 1/17/2013 LT
FO-238093	Routine	Scheduled Maint. (PM)	1/23/2013	1/23/2013	0	Generator Test
FO-238095	Routine	Scheduled Maint. (PM)	1/23/2013	1/23/2013	0	Generator Test
FO-238097	Routine	Scheduled Maint. (PM)	1/23/2013	1/23/2013	0	Generator Test Finished 1/23/2013 LT
FO-238107	Routine	Scheduled Maint. (PM)	1/16/2013	1/16/2013	0	Generator Test Finished 1/17/2013 LT
FO-216426	High	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	Generator Test Tuesday, May 15 @ 7:15am
FO-216431	High	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	Generator Test Tuesday, May 15 @ 8:15am
FO-216432	High	Scheduled Maint. (PM)	5/17/2012	5/16/2012	-1	Generator Test Tuesday, May 15 @ 8:15am
FO-222262	High	Scheduled Maint. (PM)	7/25/2012	7/24/2012	-1	Generator Test
FO-230414	High	Scheduled Maint. (PM)	10/18/2012	10/17/2012	-1	Generator Test Finished 10/18/12 LS
FO-234246	Routine	Scheduled Maint. (PM)	11/28/2012	11/27/2012	-1	Generator Test Finished 11/28/12 LS
FO-236108	Routine	Scheduled Maint. (PM)	12/13/2012	12/12/2012	-1	Generator Test Finished 12/13/12 LS
FO-238089	Routine	Scheduled Maint. (PM)	1/23/2013	1/22/2013	-1	Generator Test Finished 1/23/2013 LT
FO-238109	Routine	Scheduled Maint. (PM)	1/18/2013	1/17/2013	-1	Generator Test Finished 1/18/2013 LT
FO-227359	High	Scheduled Maint. (PM)	10/1/2012	9/29/2012	-2	Generator Test. Finished 12-10-12 PP.
FO-227361	High	Scheduled Maint. (PM)	10/1/2012	9/29/2012	-2	Generator Test. Finished 12-10-12 PP.

Finish Date Due Date

Total per Trade

FO-230778	High	Scheduled Maint. (PM)	10/29/2012	10/27/2012	-2	Generator Test Finished 10/29/12 LS
FO-230780	High	Scheduled Maint. (PM)	10/29/2012	10/27/2012	-2	Generator Test Finished 10/29/12 LS
FO-234244	Routine	Scheduled Maint. (PM)	11/26/2012	11/24/2012	-2	Generator Test Finished 11/26/12 LS
FO-234245	Routine	Scheduled Maint. (PM)	11/26/2012	11/24/2012	-2	Generator Test Finished 11/26/12 LS
FO-206117	High	Scheduled Maint. (PM)	2/21/2012	2/18/2012	-3	Generator Test Tuesday, February 21 @ 8:15 am
FO-206118	High	Scheduled Maint. (PM)	2/21/2012	2/18/2012	-3	Generator Test Tuesday, February 21 @ 8:15 am
FO-236041	Routine	Scheduled Maint. (PM)	12/10/2012	12/7/2012	-3	Generator Test Finished 12/10/12 LS
FO-236099	Routine	Scheduled Maint. (PM)	12/10/2012	12/7/2012	-3	Generator Test Finished 12/10/12 LS
FO-237832	Routine	Scheduled Maint. (PM)	1/7/2013	1/4/2013	-3	Generator Test Finished 1/8/2013LT
FO-230794	High	Scheduled Maint. (PM)	10/18/2012	10/13/2012	-5	Generator Test Finished 10/18/12 LS
FO-230796	High	Scheduled Maint. (PM)	10/18/2012	10/13/2012	-5	Generator Test Finished 10/18/12 LS
FO-233533	High	Scheduled Maint. (PM)	11/26/2012	11/21/2012	-5	Generator Test Finished 11/26/12 LS
FO-233634	High	Scheduled Maint. (PM)	11/26/2012	11/21/2012	-5	Generator Test Finished 11/26/12 LS
FO-206104	High	Scheduled Maint. (PM)	3/2/2012	2/25/2012	-6	Generator Test Friday, February 24 @ 10am
FO-213790	High	Scheduled Maint. (PM)	4/12/2012	4/6/2012	-6	Generator Test Thursday, April 12 @ 7:15am
FO-216412	High	Scheduled Maint. (PM)	5/10/2012	5/4/2012	-6	Generator Test Thursday, May 10 @ 7:15am
FO-236586	Routine	Scheduled Maint. (PM)	1/2/2013	12/27/2012	-6	Generator Test Finished 1/3/2013 LT
FO-210422	High	Scheduled Maint. (PM)	3/28/2012	3/21/2012	-7	Generator Test Tuesday, March 20 @ 7:15am
FO-210427	High	Scheduled Maint. (PM)	3/28/2012	3/21/2012	-7	Generator Test Tuesday, March 20 @ 8:15am
FO-210428	High	Scheduled Maint. (PM)	3/28/2012	3/21/2012	-7	Generator Test Tuesday, March 20 @ 8:15am
FO-216420	High	Scheduled Maint. (PM)	5/23/2012	5/16/2012	-7	Generator Test Tuesday, May 15 @9:15am
FO-233532	High	Scheduled Maint. (PM)	11/20/2012	11/8/2012	-12	Generator Test Finished 11/21/2012LT
FO-210415	High	Scheduled Maint. (PM)	3/16/2012	3/3/2012	-13	Generator Test Friday, March 16 @ 2:15 pm
FO-227375	High	Scheduled Maint. (PM)	10/3/2012	9/19/2012	-14	Generator Test Finished 10/3/12 LT
FO-227379	High	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	Generator Test. Finished 11-29-12 PP.
FO-227381	High	Scheduled Maint. (PM)	11/29/2012	9/15/2012	-75	Generator Test. Finished 11-29-12 PP.
FO-227350	High	Scheduled Maint. (PM)	11/29/2012	9/14/2012	-76	Generator Test. Finished 11-29-12 PP.
FO-227352	High	Scheduled Maint. (PM)	11/29/2012	9/14/2012	-76	Generator Test. Finished 11-29-12 PP.
FO-227388	High	Scheduled Maint. (PM)	11/29/2012	9/14/2012	-76	Generator Test. Finished 11-29-12 PP.
FO-227579	Emergency	Scheduled Maint. (PM)	11/29/2012	9/14/2012	-76	Generator Maintenance. Finished 11-29-12 PP.
FO-219238	High	Scheduled Maint. (PM)	11/29/2012	6/30/2012	-152	Generator Test, June 1, 2012 @ 2:15 AM. Finished 11-29-12 PP.
FO-219247	High	Scheduled Maint. (PM)	11/29/2012	6/23/2012	-159	Generator Test, June 22, 2012 @ 10 AM. Finished 11-29-12 PP.
FO-219226	Low	Scheduled Maint. (PM)	11/29/2012	6/15/2012	-167	Generator Test, June 14, 2012 @ 7:15 AM. Finished 11-29-12 PP.
FO-219227	High	Scheduled Maint. (PM)	11/29/2012	6/15/2012	-167	Generator Test, June 14, 2012 @ 7:15 AM. Finished 11-29-12 PP.

Total: 4150 of 6084 83%