

DRAFT Facilities Operations PM Analysis from 1/1/2015 through 1/31/2015

		Requested Finished Open WND				% Finished	
Engineering		368	359	-5	14	98%	
E - Auxiliary		37	37	-6	6	100%	
FO-304858	Finished	034-AHU-001	1/1/2015	2/27/2015	True	PM - Air Handling Unit	
FO-304859	Finished	034-AHU-002	1/1/2015	2/27/2015	True	PM - Air Handling Unit	
FO-304860	Finished	034-AHU-003	1/1/2015	2/27/2015	True	PM - Air Handling Unit	
FO-304861	Finished	034-AHU-004	1/1/2015	2/27/2015	True	PM - Air Handling Unit	
FO-304862	Finished	034-AHU-005	1/1/2015	2/27/2015	True	PM - Air Handling Unit	
FO-304863	Finished	034-SP-001	1/1/2015	12/31/2014	False	PM - Sump Pump	
FO-304864	Finished	034-SP-002	1/1/2015	1/30/2015	False	PM - Sump Pump	
FO-304865	Finished	034-SP-003	1/1/2015	1/30/2015	False	PM - Sump Pump	
FO-304866	Finished	034-SP-004	1/1/2015	1/30/2015	False	PM - Sump Pump	
FO-304879	Finished	104-MUA-001	1/1/2015	1/30/2015	False	PM - Air Handling Unit	
FO-304880	Finished	104-MUA-002	1/1/2015	1/30/2015	False	PM - Air Handling Unit	
FO-304881	Finished	115-MUA-001	1/1/2015	1/30/2015	False	PM - Air Handling Unit	
FO-304882	Finished	115-MUA-002	1/1/2015	1/30/2015	False	PM - Air Handling Unit	
FO-304883	Finished	115-MUA-003	1/1/2015	1/30/2015	False	PM - Air Handling Unit	
FO-304884	Finished	507-AIR-001	1/1/2015	1/30/2015	False	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-304885	Finished	992-ES-001*	1/5/2015	1/9/2015	False	PM - Emergency Shower/Eyewash Station	
FO-304886	Finished	127-MAU-005	1/3/2015	2/27/2015	True	Housing - Towers Kitchen Make Up Air PM	
FO-304887	Finished	134-CRS-001	1/1/2015	1/15/2015	False	PM - Condensate Return Pump	
FO-304888	Finished	134-CRS-002	1/1/2015	1/30/2015	False	PM - Condensate Return Pump	
FO-304895	Finished	134-ACU-001	1/1/2015	1/30/2015	False	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-304905	Finished	507-ACU-001	1/1/2015	1/30/2015	False	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-304907	Finished	134-FP-001	1/1/2015	1/9/2015	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
Opened test drain to activate fire/jockey pumps. Placed system back into normal operation.							
FO-304908	Finished	127-FP-001	1/1/2015	1/30/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-304909	Finished	115-FP-001	1/1/2015	1/30/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-304910	Finished	104-FP-001	1/1/2015	1/30/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-304911	Finished	507-FP-001	1/1/2015	1/30/2015	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-305051	Finished	501-GEN-001	1/13/2015	1/14/2015	False	Generator Maintenance, Monthly	
FO-305054	Finished	992-ES-001*	1/12/2015	1/16/2015	False	PM - Emergency Shower/Eyewash Station	
FO-305292	Finished	507-GEN-001	1/14/2015	1/15/2015	False	Generator Maintenance, Monthly	
FO-305294	Finished	992-ES-001*	1/19/2015	1/23/2015	False	PM - Emergency Shower/Eyewash Station	
FO-305645	Finished	104-GEN-001	1/27/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305647	Finished	127-GEN-001	1/27/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305649	Finished	127-GEN-002	1/27/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305651	Finished	127-GEN-003	1/27/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305653	Finished	127-GEN-004	1/27/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305657	Finished	536-GEN-001	1/21/2015	1/28/2015	False	Generator Maintenance, Monthly	
FO-305905	Finished	992-ES-001*	1/26/2015	1/28/2015	False	PM - Emergency Shower/Eyewash Station	
E - Command Center		3	3	0	0	100%	

Requested Finished Open WND									% Finished
FO-306021	Finished	612-AIR-003	1/13/2015	1/15/2015	False	16.00	Overhaul Air Compressor		
FO-306307	Finished	612-AIR-002	1/16/2015	1/19/2015	False	8.00	Overhaul Air Compressor		
FO-306308	Finished	612-AIR-001	1/16/2015	1/29/2015	False	16.00	Overhaul Air Compressor		
E - Director			1	1	0	0			100%
FO-304891	Finished	048-ACU-207	1/1/2015	3/30/2015	False	1.00	Vendor or Contractor Work		
E - MedPharm			15	15	0	0			100%
FO-304791	Finished	629-DHW-001	1/1/2015	3/27/2015	False		PM - Domestic Water Heater, Steam		
FO-304792	Finished	629-DHW-002	1/1/2015	3/27/2015	False		PM - Domestic Water Heater, Steam		
FO-304793	Finished	629-DHW-003	1/1/2015	3/27/2015	False		PM - Domestic Water Heater, Steam		
FO-304794	Finished	612-WSS-001	1/1/2015	1/22/2015	False	1.00	PM - Water Softener		
FO-304796	Finished	612-ACU-002	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-304797	Finished	612-ACU-001	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-304798	Finished	611-ACU-002**	1/1/2015	1/28/2015	False	0.50	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
Trane here on 12-9-14 & 12-10-14 for chiller maintenance									
FO-304799	Finished	611-ACU-001**	1/1/2015	1/28/2015	False	0.50	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
Trane here on 12-9-14 & 12-10-14 for chiller maintenance									
FO-304800	Finished	608-ACU-001	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-304801	Finished	603-ACU-002	1/1/2015	2/9/2015	False	10.00	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
Done, worst tubes ever. Used more brushes than any other cleaning.									
FO-304802	Finished	603-ACU-001	1/1/2015	2/24/2015	False	11.00	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
DONE. PUNCHED TUBES									
FO-304803	Finished	608-ACU-002	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-305278	Finished	609-GEN-001	1/20/2015	1/21/2015	False		Generator Maintenance, Monthly		
Checked fluids and battery									
FO-305641	Finished	611-GEN-001	1/23/2015	1/28/2015	False	0.50	Generator Maintenance, Monthly		
Electricians did generator test									
FO-305643	Finished	629-GEN-001	1/23/2015	3/27/2015	False		Generator Maintenance, Monthly		
E - North			23	23	0	0			100%
FO-304804	Finished	025-AIR-001	1/1/2015	1/26/2015	False	0.75	PM - Air Compressor, Reciprocating 5-40 H.P.		
FO-304805	Finished	025-HEX-001	1/1/2015	1/26/2015	False	0.50	PM - Heat Exchanger and Economizer		
FO-304806	Finished	025-HEX-002	1/1/2015	1/26/2015	False	0.50	PM - Heat Exchanger and Economizer		
FO-304807	Finished	046-AIR-001	1/1/2015	1/27/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.		
REFER TO WO FO-307020 SENT TO REF CREW AS REPAIR DUE TO PM/LPS									
FO-304808	Finished	049-AIR-001	1/1/2015	1/30/2015	False	1.25	PM - Air Compressor, Reciprocating 5-40 H.P.		
REFER TO WO FO-307564 SENT TO ELEC/LPS									
FO-304809	Finished	050-DRF-001	1/1/2015	1/5/2015	False	1.50	PM - Drinking Fountain and Water Cooler		
FO-304810	Finished	050-DRF-002	1/1/2015	1/5/2015	False	1.50	PM - Drinking Fountain and Water Cooler		
FO-304811	Finished	050-DRF-003	1/1/2015	1/5/2015	False	1.50	PM - Drinking Fountain and Water Cooler		
FO-304812	Finished	049-DHW-001	1/1/2015	1/27/2015	False	0.65	PM - Domestic Water Heater, Electric		
FO-304813	Finished	049-DHW-002	1/1/2015	1/27/2015	False	0.65	PM - Domestic Water Heater, Electric		
FO-304814	Finished	038-AIR-001	1/1/2015	1/6/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.		
Performed routine PM checked oil level, belts filter.									

Requested Finished Open WND

% Finished

FO-304815	Finished	039-AIR-001	1/1/2015	1/5/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM belts, filter, oil.							
FO-304816	Finished	039-AIR-002	1/1/2015	1/6/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Performed routine PM filters, oil, belts.							
FO-304817	Finished	026-AIR-001	1/1/2015	1/15/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304818	Finished	027-AIR-001	1/1/2015	1/20/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304819	Finished	036-AIR-001	1/1/2015	1/28/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304820	Finished	026-DRF-001	1/1/2015	1/20/2015	False	2.00	PM - Drinking Fountain and Water Cooler
FO-304821	Finished	048-AIR-001	1/1/2015	1/28/2015	False	0.65	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304822	Finished	048-AIR-002	1/1/2015	1/28/2015	False	0.65	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-305038	Finished	048-GEN-001	1/9/2015	1/15/2015	False	1.00	Generator Maintenance, Monthly
FO-305039	Finished	130-AHU-001	1/7/2015	1/15/2015	False	2.50	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-305655	Finished	130-GEN-001	1/28/2015	1/28/2015	False	1.00	Generator Maintenance, Monthly
FO-305903	Finished	130-AHU-001	1/21/2015	2/20/2015	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
E - Northeast			16	16	0	0	100%
FO-304823	Finished	193-CFP-001	1/6/2015	1/19/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-304824	Finished	193-CFP-002	1/6/2015	1/26/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-304825	Finished	509-AIR-001	1/1/2015	1/6/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked belts, oil, moisture trap, and drier							
FO-304826	Finished	510-AIR-001	1/1/2015	1/20/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
checked belts for wear and tension, checked oil level added as needed checked operation and moisture seperator							
FO-304827	Finished	193-GEN-001	1/2/2015	1/26/2015	False	1.00	Generator Maintenance, Monthly
FO-304828	Finished	193-GEN-002	1/2/2015	1/2/2015	False	1.00	Generator Maintenance, Monthly
FO-304829	Finished	193-GEN-003	1/2/2015	1/2/2015	False	1.00	Generator Maintenance, Monthly
FO-304830	Finished	193-GEN-004	1/2/2015	1/5/2015	False	1.00	Generator Maintenance, Monthly
FO-304831	Finished	067-ACU-109	1/1/2015	1/30/2015	False	1.00	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-305040	Finished	062-ACU-003	1/7/2015	1/27/2015	False	1.00	PM - Semi Anunal Air Handling Unit Inspection
FO-305279	Finished	510-HEX-001	1/15/2015	1/20/2015	False	1.00	PM - Heat Exchanger and Economizer
checked operation, checked for leaks, checked pump operation							
FO-305280	Finished	509-HWP-010	1/16/2015	2/4/2015	False	2.00	PB - B&G Series 100 Pump
Replace with new motor and pump							
FO-305281	Finished	203-GEN-001	1/20/2015	1/21/2015	False	1.00	Generator Maintenance, Monthly
FO-305282	Finished	527-GEN-001	1/15/2015	1/15/2015	False	1.50	Generator Maintenance, Monthly
Checked operation of mech. equip. checked fluid levels test ran unit under load							
FO-305283	Finished	-GEN-001 (Towa	1/14/2015	1/15/2015	False	1.00	Generator Maintenance, Monthly
FO-305638	Finished	066-GEN-001	1/28/2015	1/29/2015	False	1.00	Generator Maintenance, Monthly
E - Preventative Maintenance			191	182	1	8	95%
FO-302512	Finished	193-EXF-001	1/1/2015	1/6/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302513	Finished	612-RAF-001	1/1/2015	1/6/2015	False	4.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302514	Finished	612-RAF-002	1/1/2015	1/6/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302515	Finished	612-RAF-003	1/1/2015	1/7/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302516	Finished	612-RAF-004	1/1/2015	1/7/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-302517	Finished	612-RAF-005	1/1/2015	1/8/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302518	Finished	612-RAF-006	1/1/2015	1/9/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302519	Finished	612-RAF-007	1/1/2015	1/9/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302520	Finished	612-RAF-008	1/1/2015	1/10/2015	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-302521	Finished	001-FCU-1359	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302522	Finished	001-FCU-1366-1	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302523	Finished	001-FCU-1366-2	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302524	Finished	001-FCU-1366-3	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302525	Finished	001-FCU-1367-1	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302526	Finished	001-FCU-1367-2	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302527	Finished	001-FCU-1367-3	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302528	Finished	001-FCU-1373-1	1/1/2015	1/9/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302529	Finished	001-FCU-1373-2	1/1/2015	1/10/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302530	Finished	001-FCU-1373-3	1/1/2015	1/10/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302531	Finished	001-FCU-2103-1	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302532	Finished	001-FCU-2103-2	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302533	Finished	001-FCU-2103-3	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302534	Finished	001-FCU-2103-4	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302535	Finished	001-FCU-2103-5	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302536	Finished	001-FCU-2103-6	1/1/2015	1/16/2015	False	0.50	PM - Fan Coil/HV/AC Unit
FO-302537	Finished	001-FCU-2111	1/1/2015	1/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302538	Finished	001-FCU-2120	1/1/2015	1/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302539	Finished	001-FCU-2125	1/1/2015	1/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302540	Finished	001-FCU-2132	1/1/2015	1/10/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302541	Finished	001-FCU-2133	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302542	Finished	001-FCU-2304	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302543	Finished	001-FCU-2306	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302544	Finished	001-FCU-2308	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302545	Finished	001-FCU-2310	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302546	Finished	001-FCU-2314	1/1/2015	1/17/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302547	Finished	001-FCU-2318	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302548	Finished	001-FCU-2320	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302549	Finished	001-FCU-2337	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302550	Finished	001-FCU-2338	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302551	Finished	001-FCU-2342	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302552	Finished	001-FCU-2344	1/1/2015	1/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-302553	Finished	001-FCU-2346	1/1/2015	2/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit

INSPECT UNIT ,CHECK OPERATION, CHECK FILTER-OK.

FO-302554 Finished 001-FCU-2348 1/1/2015 2/24/2015 False 0.00 PM - Fan Coil/HV/AC Unit

THIS ROOM DOES NOT HAVE A CFC UNIT , RM 2346 SERVICES THIS ROOM , THIS ROOM SHOULD BE REMOVED FROM TMA.

FO-302555 Finished 001-FCU-2349 1/1/2015 2/24/2015 False 1.00 PM - Fan Coil/HV/AC Unit

INSPECT UNIT & OPERATION, AIR FILTER OK.

FO-302556 Finished 001-FCU-2357 1/1/2015 2/24/2015 False 0.00 PM - Fan Coil/HV/AC Unit

NO UNIT IN THIS ROOM, ROOM 2361 SERVICES THIS AREA. SHOULD BE REMOVED FROM TMA.

Requested Finished Open WND

% Finished

FO-302557	Finished	001-FCU-2361	1/1/2015	2/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & CHECK OPERATION, FILTER OK, FAN MOTOR BAD, W.O TO ELECTRICIANS TO REPLACE.							
FO-302558	Finished	001-FCU-2369	1/1/2015	2/24/2015	False	0.00	PM - Fan Coil/HV/AC Unit
NO UNIT IN THIS ROOM, ROOM 2371 UNIT SERVICES THIS AREA, SHOULD BE REMOVED FROM TMA.							
FO-302559	Finished	001-FCU-2371	1/1/2015	2/24/2015	False	1.00	PM - Fan Coil/HV/AC Unit
INSPECT & CHECK OPERATION, CHANGED AIR FILTER.							
FO-302560	Finished	046-FAP-001	1/1/2015	1/23/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302561	Finished	048-FAP-001	1/1/2015	1/24/2015	False	0.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302562	Finished	049-FAP-001	1/1/2015	1/22/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302569	Finished	156-FAP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302570	Finished	499-FAP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302571	Finished	620-FAP-001	1/1/2015	1/16/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302572	Finished	036-FP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302573	Finished	025-FP-001	1/1/2015	1/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302574	Finished	007-FP-001	1/1/2015	1/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302575	Finished	001-FP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302576	Finished	005-FAP-001	1/1/2015	1/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302577	Finished	040-FAP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302578	Finished	038-FAP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302579	Finished	028-FAP-001	1/1/2015	1/7/2015	False	4.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302580	Finished	026-FAP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302581	Finished	022-FAP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302582	Finished	017-FAP-001	1/1/2015	1/15/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302583	Finished	016-FAP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302584	Finished	003-FAP-001	1/1/2015	1/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302585	Finished	006-FP-001	1/1/2015	1/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302586	Finished	050-FAP-001	1/1/2015	1/24/2015	False	0.43	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302587	Finished	043-FAP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302588	Finished	042-FAP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302589	Finished	062-FP-001	1/1/2015	1/21/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302590	Finished	065-FP-001	1/1/2015	1/15/2015	False	1.20	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302591	Finished	068-FAP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302592	Finished	067-FP-001	1/1/2015	1/15/2015	False	1.40	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302593	Finished	089-FP-001	1/1/2015	1/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302594	Finished	082-FP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302595	Finished	080-FAP-001	1/1/2015	1/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302596	Finished	090-FP-001	1/1/2015	1/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302597	Finished	155-FP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302598	Finished	150-FAP-001	1/1/2015	1/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302599	Finished	167-FAP-001	1/1/2015	1/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302600	Finished	166-FP-001	1/1/2015	1/30/2015	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302601	Finished	140-FAP-001	1/1/2015	1/16/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302602	Finished	130-FP-001	1/1/2015	1/16/2015	False	0.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302603	Finished	193-FAP-001	1/1/2015	1/22/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-302604	Finished	189-FP-001	1/1/2015	1/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302605	Finished	510-FAP-001	1/1/2015	1/16/2015	False	0.42	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302606	Finished	509-FAP-001	1/1/2015	1/21/2015	False	0.47	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302607	Finished	504-FAP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302608	Finished	629-FP-001	1/1/2015	1/7/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302609	Finished	612-FP-001	1/1/2015	1/10/2015	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302610	Finished	611-FP-001	1/1/2015	1/8/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302611	Finished	609-FP-001	1/1/2015	1/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302612	Finished	603-FP-001	1/1/2015	1/16/2015	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302613	Finished	608-FP-001	1/1/2015	1/7/2015	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302614	Finished	612-AHU-014	1/1/2015	1/21/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302615	Finished	612-AHU-013	1/1/2015	1/21/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-302616	Finished	612-AHU-012	1/1/2015	1/22/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302617	Finished	612-AHU-011	1/1/2015	1/22/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302618	Finished	612-AHU-010	1/1/2015	1/23/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302619	Finished	612-AHU-009	1/1/2015	1/22/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302620	Finished	612-AHU-008	1/1/2015	1/23/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302621	Finished	612-AHU-007	1/1/2015	1/23/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302622	Finished	612-AHU-006	1/1/2015	1/26/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302623	Finished	612-AHU-005C	1/1/2015	1/26/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302624	Finished	612-AHU-005B	1/1/2015	1/26/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302625	Finished	612-AHU-005A	1/1/2015	1/27/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302626	Finished	612-AHU-004	1/1/2015	1/29/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302627	Finished	612-AHU-003	1/1/2015	1/29/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302628	Finished	612-AHU-002	1/1/2015	1/29/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302629	Finished	612-AHU-001	1/1/2015	1/30/2015	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-302630	Finished	074-FAP-001	1/1/2015	1/16/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302631	Finished	612-HVU-001	1/1/2015	1/15/2015	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-302632	Cancelled	166-HVU-001	1/1/2015		False		PM - Air Handling Unit (ANNUAL)
FO-302633	Finished	167-AHU-002	1/1/2015	1/28/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-302634	Finished	167-AHU-001	1/1/2015	1/28/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-302635	Finished	166-AHU-002	1/1/2015	1/27/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302636	Finished	166-AHU-001	1/1/2015	1/27/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302637	Finished	169-AHU-008	1/1/2015	1/30/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302638	Finished	169-AHU-007	1/1/2015	1/30/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302639	Finished	169-AHU-006	1/1/2015	1/30/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302640	Finished	169-AHU-005	1/1/2015	1/30/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302641	Finished	169-AHU-004	1/1/2015	1/29/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302642	Finished	169-AHU-003	1/1/2015	1/29/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302643	Finished	169-AHU-002	1/1/2015	1/29/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302644	Finished	169-AHU-001	1/1/2015	1/29/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-302645	Finished	003-AHU-008	1/1/2015	1/16/2015	False	1.00	Replace PRE-filters
FO-302646	Finished	003-AHU-007	1/1/2015	1/15/2015	False	2.00	Replace PRE-filters
FO-302647	Finished	003-AHU-006	1/1/2015	1/15/2015	False	2.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-302648	Finished	003-AHU-005	1/1/2015	1/15/2015	False	2.00	Replace PRE-filters
FO-302649	Finished	003-AHU-004	1/1/2015	1/14/2015	False	2.00	Replace PRE-filters
FO-302650	Finished	003-AHU-003	1/1/2015	1/14/2015	False	2.00	Replace PRE-filters
FO-302651	Finished	003-AHU-002	1/1/2015	1/14/2015	False	1.50	Replace PRE-filters
FO-302652	Finished	003-AHU-001	1/1/2015	1/13/2015	False	3.00	Replace PRE-filters
FO-302653	Finished	203-AHU-003	1/1/2015	1/31/2015	False	2.00	Replace PRE-filters
FO-302654	Finished	203-AHU-002	1/1/2015	1/27/2015	False	2.00	Replace PRE-filters
FO-302655	Finished	203-AHU-001	1/1/2015	1/27/2015	False	2.00	Replace PRE-filters
FO-302656	Finished	203-MAU-001	1/1/2015	1/31/2015	False	2.00	Replace PRE-filters
FO-302657	Finished	141-AHU-002	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302658	Finished	193-AHU-002	1/1/2015	1/21/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-302659	Finished	193-AHU-001	1/1/2015	1/20/2015	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-302660	Finished	193-AHU-003	1/1/2015	1/7/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-302661	Finished	193-AHU-005	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302662	Finished	193-AHU-004	1/1/2015	1/20/2015	False	3.00	Replace PRE-filters
FO-302663	Finished	193-AHU-006	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302664	Finished	193-AHU-007	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302665	Finished	193-AHU-008	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302666	Finished	193-AHU-009	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302667	Finished	193-AHU-010	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302668	Finished	193-AHU-011	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302669	Finished	193-AHU-012	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302670	Finished	193-AHU-013	1/1/2015	1/24/2015	False	0.50	Replace PRE-filters
FO-302671	Finished	096-SAF-FC1	1/1/2015	1/21/2015	False	2.00	Replace PRE-filters
FO-302672	Finished	096-SAF-B1	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302673	Finished	096-SAF-00E	1/1/2015	1/21/2015	False	3.00	Replace PRE-filters
FO-302674	Finished	096-SAF-001	1/1/2015	1/21/2015	False	3.00	Replace PRE-filters
FO-302675	Finished	096-RAF-010	1/1/2015	1/30/2015	False	3.00	Replace PRE-filters
FO-302676	Finished	096-RAF-00B	1/1/2015	1/29/2015	False	3.00	Replace PRE-filters
FO-302677	Finished	096-RAF-009	1/1/2015	1/29/2015	False	3.00	Replace PRE-filters
FO-302678	Finished	096-RAF-008	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302679	Finished	096-RAF-007	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302680	Finished	096-RAF-006	1/1/2015	1/30/2015	False	3.00	Replace PRE-filters
FO-302681	Finished	096-RAF-005	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302682	Completed	096-RAF-004	1/1/2015		True		Replace PRE-filters
FO-302683	Finished	096-RAF-003	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302684	Finished	096-RAF-002	1/1/2015	1/31/2015	False	3.00	Replace PRE-filters
FO-302685	Completed	078-ACU-003	1/1/2015		True		Replace PRE-filters
FO-302686	Completed	078-ACU-002B	1/1/2015		True		Replace PRE-filters
FO-302687	Completed	078-ACU-002A	1/1/2015		True		Replace PRE-filters
FO-302688	Completed	078-ACU-001	1/1/2015		True		Replace PRE-filters
FO-302689	Completed	091-AHU-002	1/1/2015		True		Replace PRE-filters
FO-302690	Completed	091-AHU-001	1/1/2015		True		Replace PRE-filters
FO-302691	Finished	499-AHU-007	1/1/2015	1/12/2015	False	3.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-302692	Finished	499-AHU-006	1/1/2015	1/12/2015	False	3.00	Replace PRE-filters
FO-302693	Finished	499-AHU-005	1/1/2015	1/15/2015	False	3.00	Replace PRE-filters
FO-302694	Finished	499-AHU-004	1/1/2015	1/16/2015	False	3.00	Replace PRE-filters
FO-302695	Finished	156-SAF-001	1/1/2015	1/29/2015	False	1.50	Replace PRE-filters
FO-302696	Finished	096-FP-001	1/1/2015	1/21/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302697	Finished	150-AHU-003	1/1/2015	1/28/2015	False	1.75	Replace PRE-filters
FO-302698	Finished	150-AHU-002	1/1/2015	1/28/2015	False		Replace PRE-filters
FO-302699	Finished	150-AHU-001	1/1/2015	1/29/2015	False	1.50	Replace PRE-filters
FO-302700	Finished	169-FAP-001	1/1/2015	1/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-302701	Finished	499-AHU-008	1/1/2015	1/12/2015	False	3.00	Replace PRE-filters
FO-302702	Finished	155-AHU-001	1/1/2015	2/25/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
Removed all old bag and prefilters, inspected for any problems in fan housing, installed 25 new bag and prefilters, disposed of old filters.							
FO-302703	Finished	155-AHU-004	1/1/2015	2/25/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-302704	Finished	155-AHU-003	1/1/2015	2/26/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
Removed old pre filters and bag filters, checked housings for problems, installed 25 new pre filters and bag filters, disposed of old filters.							
FO-302705	Finished	155-AHU-002	1/1/2015	2/26/2015	False	4.00	PM - Air Handling Unit (ANNUAL)
Removed old bag and prefilters, checked for problems in housings, installed 25 new pre filters and bag filters, disposed of old filters.							
FO-302706	Finished	155-AHU-005	1/1/2015	2/25/2015	False	3.00	Replace PRE-filters
FO-302707	Finished	166-HVU-001	1/1/2015	1/30/2015	False	1.50	Replace PRE-filters
FO-303324	Completed	499-SPARE	1/1/2015		True		Replace PRE-filters
E - South			29	29	0	0	100%
FO-304832	Finished	090-AIR-001	1/1/2015	1/20/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304833	Finished	090-AIR-002	1/1/2015	1/20/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304838	Finished	090-AIR-004	1/1/2015	1/21/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304847	Finished	096-HUM-002	1/2/2015	1/6/2015	False	1.00	PM - Humidifier
FO-304848	Finished	096-HUM-003	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304849	Finished	096-HUM-00B	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304850	Finished	096-HUM-010	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304851	Finished	096-HUM-002	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304852	Finished	096-HUM-003	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304853	Finished	096-HUM-00B	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304854	Finished	096-HUM-00E	1/2/2015	1/6/2015	False	0.00	PM - Humidifier
FO-304876	Finished	090-AIR-003	1/1/2015	1/21/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304889	Finished	090-AIR-541	1/1/2015	1/27/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304890	Finished	090-SSF-541	1/1/2015	1/13/2015	False	0.50	PM - Harmsco Side Stream Filter
FO-304896	Finished	090-ACU-403	1/1/2015	1/8/2015	False	1.00	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304897	Finished	090-ACU-402	1/1/2015	1/8/2015	False	0.50	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304898	Finished	090-ACU-401	1/1/2015	1/8/2015	False	0.50	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304899	Finished	022-ACU-001	1/1/2015	12/24/2014	False	1.00	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304900	Finished	007-ACU-002	1/1/2015	12/24/2014	False	0.25	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304901	Finished	007-ACU-001	1/1/2015	12/24/2014	False	0.25	PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-305041	Finished	090-ACU-CR2	1/8/2015	1/12/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2

Requested Finished Open WND

% Finished

FO-305042	Finished	090-ACU-CR2	1/8/2015	1/12/2015	False	1.00	PM - Semi Anunal Air Handling Unit Inspection
FO-305043	Finished	090-ACU-CR1	1/8/2015	1/12/2015	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-305044	Finished	007-GEN-001	1/8/2015	1/9/2015	False	0.50	Generator Maintenance, Monthly
FO-305046	Finished	007-GEN-002	1/8/2015	1/9/2015	False	0.50	Generator Maintenance, Monthly
FO-305053	Finished	090-GEN-002	1/8/2015	1/9/2015	False	1.00	Generator Maintenance, Monthly
FO-305285	Finished	090-GEN-001	1/20/2015	1/8/2015	False	1.00	Generator Maintenance, Monthly
FO-305298	Finished	006-GEN-001	1/15/2015	1/20/2015	False	2.00	Generator Maintenance, Monthly
FO-305636	Finished	089-GEN-001	1/21/2015	1/21/2015	False	1.00	Generator Maintenance, Monthly
E - Southeast			21	21	0	0	100%
FO-304834	Finished	022-HEX-001	1/1/2015	3/30/2015	False	1.00	PM - Heat Exchanger and Economizer
FO-304835	Finished	001-AIR-001	1/1/2015	2/23/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
change oil, lube mtr & replace air filters.							
FO-304836	Finished	001-DWBP-001	1/1/2015	2/23/2015	False	0.50	PM - Water Booster Pump
LUBE UNIT & CLEAN AREA.							
FO-304837	Finished	001-DWBP-002	1/1/2015	2/23/2015	False	0.50	PM - Water Booster Pump
LUBE UNIT & CLEAN AREA.							
FO-304844	Finished	071-HWP-024	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304845	Finished	071-HWP-025	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304846	Finished	071-HWP-026	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304855	Finished	189-AIR-001	1/1/2015	3/30/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304856	Finished	499-AIR-001	1/1/2015	3/30/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304871	Finished	071-HWP-217	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304872	Finished	071-HWP-218	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304873	Finished	071-HWP-219	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304874	Finished	071-HWP-221	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304875	Finished	071-HWP-220	1/1/2015	3/30/2015	False		PM - Heat Pumps (5057 Woodward)
FO-304902	Finished	001-ACU-003	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304903	Finished	001-ACU-002	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304904	Finished	001-ACU-001	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-304906	Finished	189-ACU-003	1/1/2015	3/27/2015	False		PM - York Chillers: Comprehensive PM Service for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-305288	Finished	637-GEN-001	1/20/2015	1/21/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-305290	Finished	637-GEN-002	1/20/2015	1/21/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-305904	Finished	082-HWH-001	1/23/2015	3/27/2015	False		PM - Domestic Water Heater, Gas
E - West			32	32	0	0	100%
FO-302708	Finished	080-SAF-02A	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302709	Finished	080-SAF-01A	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302710	Finished	080-SAF-018	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302711	Finished	080-SAF-017	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302712	Finished	080-SAF-016	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302713	Finished	080-SAF-015	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302714	Finished	080-SAF-014	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302715	Finished	080-SAF-013	1/1/2015	1/30/2015	False		Replace PRE-filters

Requested Finished Open WND

% Finished

FO-302716	Finished	080-SAF-012	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302717	Finished	080-SAF-011	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302718	Finished	080-SAF-010	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302719	Finished	080-SAF-009	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302720	Finished	080-SAF-008	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302721	Finished	080-SAF-007	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302722	Finished	080-SAF-006	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302723	Finished	080-SAF-005	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302724	Finished	080-SAF-004	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302725	Finished	080-SAF-003	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302726	Finished	080-SAF-002	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-302727	Finished	080-SAF-001	1/1/2015	1/30/2015	False		Replace PRE-filters
FO-304839	Finished	155-AIR-001	1/1/2015	1/23/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304840	Finished	003-AIR-001	1/1/2015	1/27/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
(1) compressors. Changed oil, oil filter, air filters. Inspected all controls, v-belts, wiped down equipment. JD							
FO-304841	Finished	003-AIR-003	1/1/2015	1/29/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304842	Finished	003-AIR-004	1/1/2015	1/29/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
(2) Compressors. Changed oil, air filters, lubed motors, inspected controls and belts. wiped down equipment. JD							
FO-304843	Finished	167-AIR-001	1/1/2015	1/28/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
(2) compressors. Changed oil and air filters, inspected belts wiped down equipment. JD							
FO-304857	Finished	150-AIR-001	1/1/2015	1/29/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304867	Finished	080-SP-001	1/1/2015	1/29/2015	False		PM - Sump Pump
FO-304868	Finished	080-SP-002	1/1/2015	1/29/2015	False		PM - Sump Pump
FO-304869	Finished	166-AIR-001	1/1/2015	1/29/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-304870	Finished	156-AIR-001	1/1/2015	1/29/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-305057	Finished	001 SPARE from	1/13/2015	1/14/2015	False		Generator Maintenance, Monthly
FO-305659	Finished	169-GEN-001	1/29/2015	1/30/2015	False		Generator Maintenance, Monthly

Trades	42	39	3	0	93%
---------------	-----------	-----------	----------	----------	------------

T - Electrician	37	35	2	0	95%
------------------------	-----------	-----------	----------	----------	------------

FO-304795	Finished	608-GEN-001	1/2/2015	1/2/2015	False		Generator Maintenance, Monthly
FO-304877	Finished	193-GEN-001	1/2/2015	1/5/2015	False	1.25	Generator Test
FO-304878	Finished	608-GEN-001	1/2/2015	1/2/2015	False	4.00	Generator Test
FO-304892	Finished	193-GEN-002	1/2/2015	1/5/2015	False	1.25	Generator Test
FO-304893	Finished	193-GEN-003	1/2/2015	1/5/2015	False	1.25	Generator Test
FO-304894	Finished	193-GEN-004	1/2/2015	1/5/2015	False	1.25	Generator Test
FO-305036	Created By PM Schedule	612-GEN-001	1/9/2015		False		Generator Maintenance, Monthly
FO-305037	Created By PM Schedule	612-GEN-002	1/9/2015		False		Generator Maintenance, Monthly
FO-305045	Finished	007-GEN-001	1/8/2015	1/8/2015	False	4.00	Generator Test
FO-305047	Finished	007-GEN-002	1/8/2015	1/8/2015	False	3.00	Generator Test
FO-305048	Finished	612-GEN-001	1/9/2015	1/9/2015	False	2.00	Generator Test

Requested Finished Open WND

% Finished

FO-305049	Finished	612-GEN-002	1/9/2015	1/9/2015	False	5.00	Generator Test
FO-305050	Finished	501-GEN-001	1/13/2015	1/13/2015	False		Generator Test
FO-305052	Finished	090-GEN-002	1/8/2015	1/8/2015	False	6.00	Generator Test
FO-305055	Finished	048-GEN-001	1/9/2015	1/9/2015	False	4.00	Generator Test
FO-305056	Finished	001 SPARE from	1/13/2015	1/13/2015	False	2.00	Generator Test
FO-305284	Finished	609-GEN-001	1/20/2015	1/20/2015	False	4.00	Generator Test Tuesday 1/20/2015 @ 7:15AM.
FO-305286	Finished	090-GEN-001	1/20/2015	1/20/2015	False	4.00	Generator Test Tuesday 1/20/2015 @ 9:30AM.
FO-305287	Finished	637-GEN-001	1/20/2015	1/20/2015	False	2.00	Generator Test Tuesday 1/20/2015 @ 9:15AM.
FO-305289	Finished	637-GEN-002	1/20/2015	1/20/2015	False	2.00	Generator Test Tuesday 1/20/2015 @ 9:15AM.
FO-305291	Finished	507-GEN-001	1/14/2015	1/14/2015	False	7.00	Generator Test
FO-305293	Finished	203-GEN-001	1/20/2015	1/20/2015	False	4.00	Generator Test Tuesday 1/20/2015 @ 9:15AM.
FO-305295	Finished	527-GEN-001	1/15/2015	1/15/2015	False	4.00	Generator Test
FO-305296	Finished	GEN-001 (Towa	1/14/2015	1/14/2015	False	4.00	Generator Test
FO-305297	Finished	006-GEN-001	1/15/2015	1/15/2015	False	4.00	Generator Test
FO-305637	Finished	089-GEN-001	1/21/2015	1/21/2015	False	4.00	Generator Test Wednesday 1/21/2015 @ 10AM.
FO-305639	Finished	066-GEN-001	1/28/2015	1/28/2015	False	4.00	Generator Test, Wednesday 1/28/2015 @ 7:15AM.
FO-305640	Finished	611-GEN-001	1/23/2015	1/23/2015	False	4.00	Generator Test Friday 1/23/2015 @ 7:15AM.
FO-305642	Finished	629-GEN-001	1/23/2015	1/23/2015	False	4.00	Generator Test Friday 1/23/2015 @ 10AM.
FO-305644	Finished	104-GEN-001	1/27/2015	1/27/2015	False	4.00	Generator Test Tuesday 1/27/2015 @ 10AM.
FO-305646	Finished	127-GEN-001	1/27/2015	1/27/2015	False	1.25	Generator Test Tuesday 1/27/2015 @ 8AM.
FO-305648	Finished	127-GEN-002	1/27/2015	1/27/2015	False	1.25	Generator Test Tuesday 1/27/2015 @ 8AM.
FO-305650	Finished	127-GEN-003	1/27/2015	1/27/2015	False	1.25	Generator Test Tuesday 1/27/2015 @ 8AM.
FO-305652	Finished	127-GEN-004	1/27/2015	1/27/2015	False	1.25	Generator Test Tuesday 1/27/2015 @ 8AM.
FO-305654	Finished	130-GEN-001	1/28/2015	1/28/2015	False	4.00	Generator Test Wednesday 1/28/2015 @ 7:15AM.
FO-305656	Finished	536-GEN-001	1/21/2015	1/21/2015	False	4.00	Generator Test Wednesday 1/23/2015 @ 7:15AM.
FO-305658	Finished	169-GEN-001	1/29/2015	1/29/2015	False	4.00	Generator Test Thursday 1/29/2015 @ 7:15AM.

T - Plumber			5	4	1	0		80%
FO-304360	Finished	042	1/1/2015	1/6/2015	False	0.50	PM - Main Drain with Copper Sulfate ,,,,,,,,,, MP/1-2-15 ,,,,,,,,,,	
FO-304361	Finished	527	1/1/2015	1/15/2015	False	1.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, MM/1-2-15 ,,,,,,,,,,	
FO-304362	Finished	608	1/1/2015	1/6/2015	False	2.50	PM - Waterless Urinals ,,,,,,,,,, MM/1-2-15 ,,,,,,,,,,	
FO-304363	Finished	049	1/1/2015	1/6/2015	False	0.50	PM - Waterless Urinals ,,,,,,,,,, MP/1-2-15 ,,,,,,,,,,	
FO-304364	Created By PM Schedule	090	1/1/2015		False	4.50	PM - Waterless Urinals ,,,,,,,,,, MP/1-2-15 ,,,,,,,,,,	

Report Total

410 398 -2 14

97%