

# \*DRAFT Facilities Operations PM DUE DATE Analysis from 3/1/2013 through 3/30/2013

Finish Date Due Date

Total per Trade

## Engineering

326 of 452 72%

### E - Afternoon Engineer

205 of 251 82%

FO-240864	Routine	Scheduled Maint. (PM)	3/6/2013	4/29/2013	54	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-242652	Routine	Scheduled Maint. (PM)	3/9/2013	4/15/2013	37	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243880	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243881	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243882	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243883	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243884	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243885	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243886	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243887	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243888	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243889	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243897	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243898	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243891	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243890	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243892	Routine	Scheduled Maint. (PM)	3/14/2013	4/18/2013	35	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243878	Routine	Scheduled Maint. (PM)	3/8/2013	4/11/2013	34	PM - Unit/Space Heater	False
FO-243879	Routine	Scheduled Maint. (PM)	3/8/2013	4/11/2013	34	PM - Unit/Space Heater	False
FO-243893	Routine	Scheduled Maint. (PM)	3/15/2013	4/18/2013	34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243894	Routine	Scheduled Maint. (PM)	3/15/2013	4/18/2013	34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243895	Routine	Scheduled Maint. (PM)	3/15/2013	4/18/2013	34	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-242626	Routine	Scheduled Maint. (PM)	3/2/2013	4/4/2013	33	PM - Fan Coil/HV/AC Unit	False
FO-242627	Routine	Scheduled Maint. (PM)	3/2/2013	4/4/2013	33	PM - Fan Coil/HV/AC Unit	False
FO-242628	Routine	Scheduled Maint. (PM)	3/2/2013	4/4/2013	33	PM - Fan Coil/HV/AC Unit	False
FO-243896	Routine	Scheduled Maint. (PM)	3/16/2013	4/18/2013	33	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-243899	Routine	Scheduled Maint. (PM)	3/16/2013	4/18/2013	33	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-242049	Routine	Scheduled Maint. (PM)	3/2/2013	4/3/2013	32	PM - Air Handling Unit	False
FO-243877	Routine	Scheduled Maint. (PM)	3/9/2013	4/9/2013	31	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-242613	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False
FO-242614	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	False

			Finish Date	Due Date				Total per Trade
FO-242615	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242616	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242617	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242618	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242619	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242620	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242621	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242622	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242623	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242625	Routine	Scheduled Maint. (PM)	3/2/2013	3/30/2013	28	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242611	Routine	Scheduled Maint. (PM)	3/7/2013	4/4/2013	28	PM - Unit/Space Heater		False
FO-242612	Routine	Scheduled Maint. (PM)	3/7/2013	4/4/2013	28	PM - Unit/Space Heater		False
FO-240903	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240926	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240929	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240958	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240967	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240931	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240968	Routine	Scheduled Maint. (PM)	3/6/2013	3/31/2013	25	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-242048	Routine	Scheduled Maint. (PM)	3/9/2013	4/3/2013	25	PM - Air Handling Unit		False
FO-243938	Routine	Scheduled Maint. (PM)	3/21/2013	4/15/2013	25	PM - Fan Coil/HV/AC Unit		False
FO-243940	Routine	Scheduled Maint. (PM)	3/21/2013	4/15/2013	25	PM - Fan Coil/HV/AC Unit		False
FO-243939	Routine	Scheduled Maint. (PM)	3/21/2013	4/15/2013	25	PM - Fan Coil/HV/AC Unit		False
FO-242080	Routine	Scheduled Maint. (PM)	3/1/2013	3/25/2013	24	PM - Fan Coil/HV/AC Unit		False
FO-240964	Routine	Scheduled Maint. (PM)	3/7/2013	3/31/2013	24	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240969	Routine	Scheduled Maint. (PM)	3/7/2013	3/31/2013	24	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240966	Routine	Scheduled Maint. (PM)	3/7/2013	3/31/2013	24	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-242633	Routine	Scheduled Maint. (PM)	3/8/2013	4/1/2013	24	PM - Fan Coil/HV/AC Unit		False
FO-242634	Routine	Scheduled Maint. (PM)	3/8/2013	4/1/2013	24	PM - Fan Coil/HV/AC Unit		False
FO-242635	Routine	Scheduled Maint. (PM)	3/8/2013	4/1/2013	24	PM - Fan Coil/HV/AC Unit		False
FO-242647	Routine	Scheduled Maint. (PM)	3/8/2013	4/1/2013	24	PM - Fan Coil/HV/AC Unit		False
FO-242078	Routine	Scheduled Maint. (PM)	3/2/2013	3/25/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-242646	Routine	Scheduled Maint. (PM)	3/9/2013	4/1/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-242649	Routine	Scheduled Maint. (PM)	3/9/2013	4/1/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-242650	Routine	Scheduled Maint. (PM)	3/9/2013	4/1/2013	23	PM - Fan Coil/HV/AC Unit		False

			Finish Date	Due Date				Total per Trade
FO-242651	Routine	Scheduled Maint. (PM)	3/9/2013	4/1/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243911	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243912	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243913	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243914	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243915	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243916	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243917	Routine	Scheduled Maint. (PM)	3/16/2013	4/8/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243941	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243942	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243943	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243944	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243945	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243946	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243947	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243948	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-243949	Routine	Scheduled Maint. (PM)	3/23/2013	4/15/2013	23	PM - Fan Coil/HV/AC Unit		False
FO-242624	Routine	Scheduled Maint. (PM)	3/8/2013	3/30/2013	22	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242047	Routine	Scheduled Maint. (PM)	3/8/2013	3/30/2013	22	PM - Air Handling Unit		False
FO-242086	Routine	Scheduled Maint. (PM)	3/6/2013	3/27/2013	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242087	Routine	Scheduled Maint. (PM)	3/6/2013	3/27/2013	21	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242051	Routine	Scheduled Maint. (PM)	3/7/2013	3/28/2013	21	PM - Unit/Space Heater		False
FO-242052	Routine	Scheduled Maint. (PM)	3/7/2013	3/28/2013	21	PM - Unit/Space Heater		False
FO-241544	Routine	Scheduled Maint. (PM)	3/6/2013	3/25/2013	19	PM - Air Handling Unit		False
FO-240930	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240959	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240957	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240911	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240902	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240904	Routine	Scheduled Maint. (PM)	3/13/2013	3/31/2013	18	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-243918	Routine	Scheduled Maint. (PM)	3/21/2013	4/8/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-243919	Routine	Scheduled Maint. (PM)	3/21/2013	4/8/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-243920	Routine	Scheduled Maint. (PM)	3/21/2013	4/8/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-243921	Routine	Scheduled Maint. (PM)	3/21/2013	4/8/2013	18	PM - Fan Coil/HV/AC Unit		False
FO-242077	Routine	Scheduled Maint. (PM)	3/8/2013	3/25/2013	17	PM - Fan Coil/HV/AC Unit		False

			Finish Date	Due Date				Total per Trade
FO-242083	Routine	Scheduled Maint. (PM)	3/8/2013	3/25/2013	17	PM - Fan Coil/HV/AC Unit		False
FO-241518	Routine	Scheduled Maint. (PM)	3/12/2013	3/29/2013	17	PM - Air Handling Unit		False
FO-240922	Routine	Scheduled Maint. (PM)	3/14/2013	3/31/2013	17	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240908	Routine	Scheduled Maint. (PM)	3/14/2013	3/31/2013	17	PM - Monthly Fire Alarm/Fire Protection System Test	All Future Pm's cancelled. cld 3-18-13	False
FO-240961	Routine	Scheduled Maint. (PM)	3/14/2013	3/31/2013	17	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240962	Routine	Scheduled Maint. (PM)	3/14/2013	3/31/2013	17	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-241514	Routine	Scheduled Maint. (PM)	3/7/2013	3/23/2013	16	PM - Air Handling Unit		False
FO-243908	Routine	Scheduled Maint. (PM)	3/23/2013	4/8/2013	16	PM - Fan Coil/HV/AC Unit		False
FO-243909	Routine	Scheduled Maint. (PM)	3/23/2013	4/8/2013	16	PM - Fan Coil/HV/AC Unit		False
FO-243910	Routine	Scheduled Maint. (PM)	3/23/2013	4/8/2013	16	PM - Fan Coil/HV/AC Unit		False
FO-241541	Routine	Scheduled Maint. (PM)	3/5/2013	3/20/2013	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-241542	Routine	Scheduled Maint. (PM)	3/5/2013	3/20/2013	15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240855	Routine	Scheduled Maint. (PM)	3/6/2013	3/21/2013	15	PM - Air Handling Unit		False
FO-240856	Routine	Scheduled Maint. (PM)	3/7/2013	3/21/2013	14	PM - Air Handling Unit		False
FO-240853	Routine	Scheduled Maint. (PM)	3/8/2013	3/22/2013	14	PM - Air Handling Unit		False
FO-240852	Routine	Scheduled Maint. (PM)	3/8/2013	3/22/2013	14	PM - Air Handling Unit		False
FO-242063	Routine	Scheduled Maint. (PM)	3/14/2013	3/28/2013	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242064	Routine	Scheduled Maint. (PM)	3/14/2013	3/28/2013	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242065	Routine	Scheduled Maint. (PM)	3/14/2013	3/28/2013	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242066	Routine	Scheduled Maint. (PM)	3/14/2013	3/28/2013	14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240854	Routine	Scheduled Maint. (PM)	3/6/2013	3/19/2013	13	PM - Air Handling Unit		False
FO-241517	Routine	Scheduled Maint. (PM)	3/5/2013	3/17/2013	12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242072	Routine	Scheduled Maint. (PM)	3/14/2013	3/26/2013	12	PM - Unit/Space Heater		False
FO-242071	Routine	Scheduled Maint. (PM)	3/14/2013	3/26/2013	12	PM - Unit/Space Heater		False
FO-242403	Routine	Scheduled Maint. (PM)	3/19/2013	3/31/2013	12	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-241516	Routine	Scheduled Maint. (PM)	3/5/2013	3/16/2013	11	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240890	Routine	Scheduled Maint. (PM)	3/9/2013	3/20/2013	11	PM - Air Handling Unit		False
FO-240107	Routine	Scheduled Maint. (PM)	3/1/2013	3/11/2013	10	PM - Air Handling Unit		False
FO-240866	Routine	Scheduled Maint. (PM)	3/12/2013	3/22/2013	10	PM - Air Handling Unit		False
FO-240951	Routine	Scheduled Maint. (PM)	3/21/2013	3/31/2013	10	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240128	Routine	Scheduled Maint. (PM)	3/1/2013	3/10/2013	9	PM - Air Handling Unit		False
FO-240129	Routine	Scheduled Maint. (PM)	3/1/2013	3/10/2013	9	PM - Air Handling Unit		False
FO-240956	Routine	Scheduled Maint. (PM)	3/22/2013	3/31/2013	9	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240955	Routine	Scheduled Maint. (PM)	3/22/2013	3/31/2013	9	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240950	Routine	Scheduled Maint. (PM)	3/22/2013	3/31/2013	9	PM - Monthly Fire Alarm/Fire Protection System Test		False

			Finish Date	Due Date				Total per Trade
FO-242636	Routine	Scheduled Maint. (PM)	3/23/2013	4/1/2013	9	PM - Fan Coil/HV/AC Unit		False
FO-242637	Routine	Scheduled Maint. (PM)	3/23/2013	4/1/2013	9	PM - Fan Coil/HV/AC Unit		False
FO-242638	Routine	Scheduled Maint. (PM)	3/23/2013	4/1/2013	9	PM - Fan Coil/HV/AC Unit		False
FO-240897	Routine	Scheduled Maint. (PM)	3/5/2013	3/13/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240898	Routine	Scheduled Maint. (PM)	3/5/2013	3/13/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240134	Routine	Scheduled Maint. (PM)	3/5/2013	3/13/2013	8	PM - Air Handling Unit, HV Type		False
FO-242629	Routine	Scheduled Maint. (PM)	3/27/2013	4/4/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242630	Routine	Scheduled Maint. (PM)	3/27/2013	4/4/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242631	Routine	Scheduled Maint. (PM)	3/27/2013	4/4/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242632	Routine	Scheduled Maint. (PM)	3/27/2013	4/4/2013	8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240099	Routine	Scheduled Maint. (PM)	3/9/2013	3/15/2013	6	PM - Air Handling Unit		False
FO-240865	Routine	Scheduled Maint. (PM)	3/12/2013	3/18/2013	6	PM - Air Handling Unit		False
FO-238804	Routine	Scheduled Maint. (PM)	3/1/2013	3/6/2013	5	PM - Air Handling Unit		False
FO-239496	Routine	Scheduled Maint. (PM)	3/7/2013	3/12/2013	5	PM - Air Handling Unit, HV Type		False
FO-239495	Routine	Scheduled Maint. (PM)	3/7/2013	3/12/2013	5	PM - Air Handling Unit, HV Type		False
FO-242085	Routine	Scheduled Maint. (PM)	3/28/2013	4/2/2013	5	PM - Air Handling Unit		False
FO-240857	Routine	Scheduled Maint. (PM)	3/5/2013	3/9/2013	4	PM - Unit/Space Heater		False
FO-242088	Routine	Scheduled Maint. (PM)	3/9/2013	3/13/2013	4	HEPA Filter Replacement at Applebaum Pharmacy Building		False
FO-240947	Routine	Scheduled Maint. (PM)	3/27/2013	3/31/2013	4	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240925	Routine	Scheduled Maint. (PM)	3/27/2013	3/31/2013	4	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240924	Routine	Scheduled Maint. (PM)	3/27/2013	3/31/2013	4	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-242648	Routine	Scheduled Maint. (PM)	3/28/2013	4/1/2013	4	PM - Fan Coil/HV/AC Unit		False
FO-239470	Routine	Scheduled Maint. (PM)	3/1/2013	3/4/2013	3	PM - Air Handling Unit		False
FO-240901	Routine	Scheduled Maint. (PM)	3/12/2013	3/15/2013	3	PM - Air Handling Unit, HV Type		False
FO-240916	Routine	Scheduled Maint. (PM)	3/28/2013	3/31/2013	3	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240914	Routine	Scheduled Maint. (PM)	3/28/2013	3/31/2013	3	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-240100	Routine	Scheduled Maint. (PM)	3/5/2013	3/7/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240861	Routine	Scheduled Maint. (PM)	3/12/2013	3/14/2013	2	PM - Fan Coil/HV/AC Unit		False
FO-240885	Routine	Scheduled Maint. (PM)	3/16/2013	3/18/2013	2	PM - Air Handling Unit		False
FO-240886	Routine	Scheduled Maint. (PM)	3/16/2013	3/18/2013	2	PM - Air Handling Unit		False
FO-240868	Routine	Scheduled Maint. (PM)	3/20/2013	3/22/2013	2	PM - Fan Coil/HV/AC Unit		False
FO-240869	Routine	Scheduled Maint. (PM)	3/20/2013	3/22/2013	2	PM - Fan Coil/HV/AC Unit		False
FO-240899	Routine	Scheduled Maint. (PM)	3/20/2013	3/22/2013	2	PM - Air Handling Unit		False
FO-242070	Routine	Scheduled Maint. (PM)	3/26/2013	3/28/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242069	Routine	Scheduled Maint. (PM)	3/26/2013	3/28/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False

			Finish Date	Due Date				Total per Trade
FO-242068	Routine	Scheduled Maint. (PM)	3/26/2013	3/28/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-239492	Routine	Scheduled Maint. (PM)	3/5/2013	3/6/2013	1	PM - Air Handling Unit, HV Type		False
FO-240132	Routine	Scheduled Maint. (PM)	3/5/2013	3/6/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240133	Routine	Scheduled Maint. (PM)	3/5/2013	3/6/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240870	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240871	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240872	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240862	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240863	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240896	Routine	Scheduled Maint. (PM)	3/14/2013	3/15/2013	1	PM - Air Handling Unit, HV Type		False
FO-241519	Routine	Scheduled Maint. (PM)	3/20/2013	3/21/2013	1	PM - Fan Coil/HV/AC Unit		False
FO-241520	Routine	Scheduled Maint. (PM)	3/20/2013	3/21/2013	1	PM - Fan Coil/HV/AC Unit		False
FO-241521	Routine	Scheduled Maint. (PM)	3/20/2013	3/21/2013	1	PM - Fan Coil/HV/AC Unit		False
FO-242056	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242057	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242058	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242059	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242060	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242061	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242062	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242067	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240892	Routine	Scheduled Maint. (PM)	3/28/2013	3/29/2013	1	PM - Air Handling Unit	ALSO, REFER TO WO FO-246155 SENT OT PIPE/LPS	False
FO-240944	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240943	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240942	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240941	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240940	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240939	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240938	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240900	Routine	Scheduled Maint. (PM)	3/27/2013	3/27/2013	0	PM - Air Handling Unit		False
FO-242053	Routine	Scheduled Maint. (PM)	3/28/2013	3/28/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-242054	Routine	Scheduled Maint. (PM)	3/28/2013	3/28/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-242055	Routine	Scheduled Maint. (PM)	3/28/2013	3/28/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-240893	Routine	Scheduled Maint. (PM)	3/29/2013	3/29/2013	0	PM - Air Handling Unit		False
FO-240125	Routine	Scheduled Maint. (PM)	3/12/2013	3/11/2013	-1	PM - Air Handling Unit		False

			Finish Date	Due Date				Total per Trade
FO-240126	Routine	Scheduled Maint. (PM)	3/12/2013	3/11/2013	-1	PM - Air Handling Unit		False
FO-240894	Routine	Scheduled Maint. (PM)	3/14/2013	3/13/2013	-1	PM - Air Handling Unit, HV Type		False
FO-240895	Routine	Scheduled Maint. (PM)	3/14/2013	3/13/2013	-1	PM - Air Handling Unit, HV Type		False
FO-240937	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240936	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240935	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240934	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240933	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240932	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240946	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240945	Routine	Scheduled Maint. (PM)	3/16/2013	3/15/2013	-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-240887	Routine	Scheduled Maint. (PM)	3/19/2013	3/18/2013	-1	PM - Air Handling Unit		False
FO-240888	Routine	Scheduled Maint. (PM)	3/19/2013	3/18/2013	-1	PM - Air Handling Unit		False
FO-241537	Routine	Scheduled Maint. (PM)	3/28/2013	3/27/2013	-1	PM - Air Handling Unit		False
FO-241538	Routine	Scheduled Maint. (PM)	3/28/2013	3/27/2013	-1	PM - Air Handling Unit		False
FO-239516	Routine	Scheduled Maint. (PM)	3/5/2013	3/3/2013	-2	PM - Monthly Fire Alarm/Fire Protection System Test		False
FO-238177	Routine	Scheduled Maint. (PM)	3/5/2013	3/3/2013	-2	PM - Fire Alarm System Test		False
FO-238176	Routine	Scheduled Maint. (PM)	3/6/2013	3/3/2013	-3	PM - Fire Alarm System Test		False
FO-240131	Routine	Scheduled Maint. (PM)	3/12/2013	3/9/2013	-3	PM - Air Handling Unit		False
FO-238824	Routine	Scheduled Maint. (PM)	3/5/2013	2/27/2013	-6	PM - Air Handling Unit, HV Type		False
FO-239490	Routine	Scheduled Maint. (PM)	3/5/2013	2/27/2013	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-239491	Routine	Scheduled Maint. (PM)	3/5/2013	2/27/2013	-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-239446	Routine	Scheduled Maint. (PM)	3/8/2013	3/2/2013	-6	PM - Air Handling Unit		False
FO-239447	Routine	Scheduled Maint. (PM)	3/8/2013	3/2/2013	-6	PM - Air Handling Unit		False
FO-239465	Routine	Scheduled Maint. (PM)	3/9/2013	3/1/2013	-8	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-239450	Routine	Scheduled Maint. (PM)	3/12/2013	3/4/2013	-8	PM - Air Handling Unit		False
FO-239451	Routine	Scheduled Maint. (PM)	3/12/2013	3/4/2013	-8	PM - Air Handling Unit		False
FO-238829	Routine	Scheduled Maint. (PM)	3/6/2013	2/25/2013	-9	PM - Air Handling Unit		False
FO-239448	Routine	Scheduled Maint. (PM)	3/11/2013	3/2/2013	-9	PM - Air Handling Unit		False
FO-238145	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False
FO-238146	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False
FO-238148	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False
FO-238149	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False
FO-238150	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False
FO-238151	Routine	Scheduled Maint. (PM)	3/5/2013	2/22/2013	-11	PM - Air Handling Unit		False

			Finish Date	Due Date				Total per Trade
FO-238147	Routine	Scheduled Maint. (PM)	3/6/2013	2/22/2013	-12	PM - Air Handling Unit		False
FO-238140	Routine	Scheduled Maint. (PM)	3/6/2013	2/22/2013	-12	PM - Air Handling Unit		False
FO-239466	Routine	Scheduled Maint. (PM)	3/13/2013	3/1/2013	-12	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-238822	Routine	Scheduled Maint. (PM)	3/5/2013	2/20/2013	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-238823	Routine	Scheduled Maint. (PM)	3/5/2013	2/20/2013	-13	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-238160	Routine	Scheduled Maint. (PM)	3/5/2013	2/20/2013	-13	PM - Air Handling Unit, HV Type		False
FO-238801	Routine	Scheduled Maint. (PM)	3/7/2013	2/21/2013	-14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-237926	Routine	Scheduled Maint. (PM)	3/2/2013	2/15/2013	-15	PM - Air Handling Unit		False
FO-237927	Routine	Scheduled Maint. (PM)	3/2/2013	2/15/2013	-15	PM - Air Handling Unit		False
FO-238802	Routine	Scheduled Maint. (PM)	3/8/2013	2/21/2013	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
<b>E - Area 1 Engineer</b>								<b>26 of 41 63%</b>
FO-246329	Routine	Scheduled Maint. (PM)	3/11/2013	5/28/2013	78	PM - Punch Tubes - Chiller/Absorber	both cillers were punched before they were put back in service.	False
FO-243521	Routine	Scheduled Maint. (PM)	3/15/2013	5/14/2013	60	PM - Centrifugal Pump, over 1 H.P.	Greased bearings.	True
FO-243522	Routine	Scheduled Maint. (PM)	3/15/2013	5/14/2013	60	PM - Centrifugal Pump, over 1 H.P.	Greased bearings	True
FO-243523	Routine	Scheduled Maint. (PM)	3/15/2013	5/14/2013	60	PM - Centrifugal Pump, over 1 H.P.	Greased bearings	True
FO-243524	Routine	Scheduled Maint. (PM)	3/15/2013	5/14/2013	60	PM - Cooling Tower, 500 - 1000 Tons	Cleaned tower, checked gear oil	True
FO-243525	Routine	Scheduled Maint. (PM)	3/15/2013	5/14/2013	60	PM - Cooling Tower, 500 - 1000 Tons	Cleaned tower checked gear oil	True
FO-243528	Routine	Scheduled Maint. (PM)	3/1/2013	4/29/2013	59	PM - Punch Tubes - Chiller/Absorber	complete	False
FO-243529	Routine	Scheduled Maint. (PM)	3/6/2013	4/29/2013	54	PM - Punch Tubes - Chiller/Absorber	completed	False
FO-243517	Routine	Scheduled Maint. (PM)	3/25/2013	5/14/2013	50	PM - Centrifugal Pump, over 1 H.P.		False
FO-243518	Routine	Scheduled Maint. (PM)	3/26/2013	5/14/2013	49	PM - Centrifugal Pump, over 1 H.P.		False
FO-242392	Routine	Scheduled Maint. (PM)	3/4/2013	4/2/2013	29	PM - Vacuum Pump		False
FO-243000	Routine	Scheduled Maint. (PM)	3/15/2013	4/7/2013	23	PM - Monthly AHU Inspection Clean Room Unit 1		False
FO-243537	Routine	Scheduled Maint. (PM)	3/14/2013	3/28/2013	14	PM - Centrifugal Pump, over 1 H.P.		False
FO-243548	Routine	Scheduled Maint. (PM)	3/16/2013	3/30/2013	14	PM - Centrifugal Pump, over 1 H.P.		False
FO-244263	Routine	Scheduled Maint. (PM)	3/21/2013	4/3/2013	13	PM - Domestic Water Heater, Steam		False
FO-242393	Routine	Scheduled Maint. (PM)	3/6/2013	3/18/2013	12	PM - Water Softener		False
FO-243555	Routine	Scheduled Maint. (PM)	3/21/2013	3/29/2013	8	PM - Centrifugal Pump, over 1 H.P.		False
FO-243556	Routine	Scheduled Maint. (PM)	3/21/2013	3/29/2013	8	PM - Centrifugal Pump, over 1 H.P.		False
FO-242999	Routine	Scheduled Maint. (PM)	3/15/2013	3/22/2013	7	Monthly AHU Inspection Clean Room Unit 2		False
FO-241811	Routine	Scheduled Maint. (PM)	3/3/2013	3/7/2013	4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-242983	Routine	Scheduled Maint. (PM)	3/19/2013	3/22/2013	3	PM - Unspecified	checked 1/3 and 2/3 valves hi/low side gage fo #244731 waiting for FITTERS to repair leaking steam strainer gasket.	False
FO-243351	Routine	Scheduled Maint. (PM)	3/14/2013	3/15/2013	1	Generator Maintenance, Monthly		False



			Finish Date	Due Date				Total per Trade
FO-243317	Routine	Scheduled Maint. (PM)	3/19/2013	3/20/2013	1	Generator Maintenance, Monthly		False
FO-243002	Routine	Scheduled Maint. (PM)	3/9/2013	3/9/2013	0	Generator Maintenance, Monthly		False
FO-243004	Routine	Scheduled Maint. (PM)	3/9/2013	3/9/2013	0	Generator Maintenance, Monthly		False
FO-243319	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Maintenance, Monthly		False
FO-241810	Routine	Scheduled Maint. (PM)	3/9/2013	3/7/2013	-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-241808	Routine	Scheduled Maint. (PM)	3/10/2013	3/7/2013	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-243313	Routine	Scheduled Maint. (PM)	3/19/2013	3/15/2013	-4	Generator Maintenance, Monthly	monthly maintenance done	True
FO-243315	Routine	Scheduled Maint. (PM)	3/19/2013	3/15/2013	-4	Generator Maintenance, Monthly	monthly maintenance done	True
FO-242370	Routine	Scheduled Maint. (PM)	3/21/2013	3/14/2013	-7	PM - Reverse Osmosis Water Softener System	switched supply pumps(run one at a time) 18mohm good film growth in storage tank softner tank has long existing leak at threads	False
FO-243338	Routine	Scheduled Maint. (PM)	3/28/2013	3/20/2013	-8	Generator Maintenance, Monthly	Checked fluids, battery and belts.	True
FO-243340	Routine	Scheduled Maint. (PM)	3/28/2013	3/20/2013	-8	Generator Maintenance, Monthly	Checked fluids, battery and belts.	True
FO-243355	Routine	Scheduled Maint. (PM)	3/28/2013	3/20/2013	-8	Generator Maintenance, Monthly	Inspected fluids, belts, and batteries.	True
FO-242391	Routine	Scheduled Maint. (PM)	3/15/2013	3/1/2013	-14	PM - Water/Air Cooled Condenser	Water washed air cooled coil	True
FO-241809	Routine	Scheduled Maint. (PM)	3/21/2013	3/7/2013	-14	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-241806	Routine	Scheduled Maint. (PM)	3/22/2013	3/7/2013	-15	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	REPLACED ALL FAN BELTS. ALL CRACKED	False
FO-241807	Routine	Scheduled Maint. (PM)	3/24/2013	3/7/2013	-17	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-241805	Routine	Scheduled Maint. (PM)	3/24/2013	3/7/2013	-17	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-235338	Routine	Scheduled Maint. (PM)	3/7/2013	2/7/2013	-28	PM - Centrifugal Pump, over 1 H.P.	check serviced cleaned/done	False
FO-236630	Routine	Scheduled Maint. (PM)	3/8/2013	2/6/2013	-30	PM - Absorption Unit		False
<b>E - Area 2 Engineer</b>								<b>56 of 73      77%</b>
FO-244877	Routine	Scheduled Maint. (PM)	3/25/2013	5/31/2013	67	PM - Water/Air Cooled Condenser		True
FO-244876	Routine	Scheduled Maint. (PM)	3/25/2013	5/31/2013	67	PM - Water/Air Cooled Condenser		True
FO-243590	Routine	Scheduled Maint. (PM)	3/22/2013	5/14/2013	53	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP , CHECK STRAINER , CHECK OPERATION , CLEAN AREA.	False
FO-243591	Routine	Scheduled Maint. (PM)	3/22/2013	5/14/2013	53	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP, CHECK STRAINER , CHECK OPERATION , CLEAN AREA.	False
FO-243592	Routine	Scheduled Maint. (PM)	3/22/2013	5/14/2013	53	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP, CHECK STRAINER, CHECK OPERATION, CLEAN AREA.	False
FO-243559	Routine	Scheduled Maint. (PM)	3/25/2013	5/14/2013	50	PM - Centrifugal Pump, over 1 H.P.	Checked the pump coupling, checked motor and pump alignment, lubricated pump and motor bearings, dusted off and cleaned motor and pump and the area around it. Will check the operation of the pump when we will fill up the system.	False

			Finish Date	Due Date	Total per Trade				
FO-243560	Routine	Scheduled Maint. (PM)	3/25/2013	5/14/2013	50	PM - Centrifugal Pump, over 1 H.P.	Checked pump coupling, checked pump and motor alignment, lubricated pump and motor bearings, cleaned pump,motor and area around it. will check pump operation when we fill up the system.	False	
FO-243617	Routine	Scheduled Maint. (PM)	3/26/2013	5/14/2013	49	PM - Centrifugal Pump, over 1 H.P.		False	
FO-243618	Routine	Scheduled Maint. (PM)	3/26/2013	5/14/2013	49	PM - Centrifugal Pump, over 1 H.P.		False	
FO-243584	Routine	Scheduled Maint. (PM)	3/27/2013	5/14/2013	48	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP, CHECK OPERATION, CLEAN AREA.	False	
FO-243585	Routine	Scheduled Maint. (PM)	3/27/2013	5/14/2013	48	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP, CHECK OPERATION , CLEAN AREA.	False	
FO-243586	Routine	Scheduled Maint. (PM)	3/27/2013	5/14/2013	48	PM - Centrifugal Pump, over 1 H.P.	LUBE MTR & PUMP, CHECK OPERATION, CLEAN AREA.	False	
FO-242398	Routine	Scheduled Maint. (PM)	3/1/2013	3/30/2013	29	PM - Vacuum Pump	vacuum not in service nor needed at this time .lubricated pump & motor no konwn beficiences at this time.	False	
FO-243022	Routine	Scheduled Maint. (PM)	3/8/2013	4/6/2013	29	PM - Sump Pump	put oil in cups checked for proper operation,Good known problems at this time.	False	
FO-243021	Routine	Scheduled Maint. (PM)	3/8/2013	4/6/2013	29	PM - Sump Pump	added oil to cups, checked operation.O.K at this time.no known problems.	False	
FO-244289	Routine	Scheduled Maint. (PM)	3/20/2013	4/18/2013	29	PM - Condensate Return System **Needs Task Sheet**		False	
FO-243607	Routine	Scheduled Maint. (PM)	3/19/2013	4/13/2013	25	PM - Sump Pump		False	
FO-243023	Routine	Scheduled Maint. (PM)	3/18/2013	4/5/2013	18	PM - Condensate Return System **Needs Task Sheet**	Perform pumps operational checks. Check for leaks and clean all safeties and drains.	False	
FO-243024	Routine	Scheduled Maint. (PM)	3/19/2013	4/5/2013	17	PM - Condensate Return System **Needs Task Sheet**		False	
FO-243012	Routine	Scheduled Maint. (PM)	3/21/2013	4/6/2013	16	PM - Condensate Return Pump	Serviced condensate return pump.	False	
FO-243020	Routine	Scheduled Maint. (PM)	3/7/2013	3/21/2013	14	PM - Domestic Water Heater, Gas	checked operation of heater & pumps in good working order.added small amount of oil to pump shaft.	False	
FO-244282	Routine	Scheduled Maint. (PM)	3/21/2013	4/4/2013	14	PM - Drinking Fountain and Water Cooler		False	
FO-243014	Routine	Scheduled Maint. (PM)	3/8/2013	3/21/2013	13	PM - Fan Coil/HV/AC Unit		False	
FO-243017	Routine	Scheduled Maint. (PM)	3/8/2013	3/21/2013	13	PM - Drinking Fountain and Water Cooler		False	
FO-243019	Routine	Scheduled Maint. (PM)	3/8/2013	3/21/2013	13	PM - Domestic Water Heater, Gas	checked heater operation good.added small amount of oil to shaft .no known problems at this time.	False	
FO-244283	Routine	Scheduled Maint. (PM)	3/22/2013	4/4/2013	13	PM - Drinking Fountain and Water Cooler		False	
FO-244284	Routine	Scheduled Maint. (PM)	3/22/2013	4/4/2013	13	PM - Drinking Fountain and Water Cooler		False	
FO-244285	Routine	Scheduled Maint. (PM)	3/22/2013	4/4/2013	13	PM - Drinking Fountain and Water Cooler		False	
FO-241269	Routine	Scheduled Maint. (PM)	3/4/2013	3/16/2013	12	PM - Sump Pump	CHECK OPERATION, LUBE & CLEAN AREA.	False	
FO-241270	Routine	Scheduled Maint. (PM)	3/4/2013	3/16/2013	12	PM - Sump Pump	CHECK OPERATION, LUBE & CLEAN AREA.	False	
FO-241284	Routine	Scheduled Maint. (PM)	3/4/2013	3/16/2013	12	PM - Sump Pump	CHECK OPERATION, LUBE & CLEAN AREA.	False	

			Finish Date	Due Date	Total per Trade			
FO-241285	Routine	Scheduled Maint. (PM)	3/4/2013	3/16/2013	12	PM - Sump Pump	CHECK OPERATION, LUBE & CLEAN AREA.	False
FO-244291	Routine	Scheduled Maint. (PM)	3/25/2013	4/2/2013	8	PM - Domestic Water Heater, Electric		False
FO-243608	Routine	Scheduled Maint. (PM)	3/21/2013	3/28/2013	7	PM - Drinking Fountain and Water Cooler		False
FO-241830	Routine	Scheduled Maint. (PM)	3/5/2013	3/7/2013	2	PM - Harmsco Side Stream Filter	Removed from service, flushed filters with water until cleaned and reinstalled filters and placed back in service.	False
FO-243009	Routine	Scheduled Maint. (PM)	3/19/2013	3/21/2013	2	PM - Unspecified	performed tasks on maintenance list	False
FO-240621	Routine	Scheduled Maint. (PM)	3/1/2013	3/2/2013	1	Generator Maintenance, Monthly	checked generators unit 1 off with water in oil contractors to check out	False
FO-242399	Routine	Scheduled Maint. (PM)	3/1/2013	3/2/2013	1	PM - Domestic Water Heater, Electric	heater & pump in good working order at this time.no need to add oil at this time.operation of domestic heater good .	False
FO-241831	Routine	Scheduled Maint. (PM)	3/6/2013	3/7/2013	1	PM - Harmsco Side Stream Filter	Isolated side stream filter valves, removed and cleaned filters, and returned Harmsco side stream back into service.	False
FO-241832	Routine	Scheduled Maint. (PM)	3/6/2013	3/7/2013	1	PM - Harmsco Side Stream Filter	Removed Harmsco side stream filter from service, washed filters, and placed Harmsco side stream filter back in-service.	False
FO-243348	Routine	Scheduled Maint. (PM)	3/19/2013	3/20/2013	1	Generator Maintenance, Monthly	added water to batteries	False
FO-243027	Routine	Scheduled Maint. (PM)	3/19/2013	3/20/2013	1	PM - Harmsco Side Stream Filter		False
FO-243016	Routine	Scheduled Maint. (PM)	3/20/2013	3/21/2013	1	PM - Fan Coil/HV/AC Unit		False
FO-241273	Routine	Scheduled Maint. (PM)	3/1/2013	3/1/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-241274	Routine	Scheduled Maint. (PM)	3/1/2013	3/1/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-241280	Routine	Scheduled Maint. (PM)	3/1/2013	3/1/2013	0	PM - Heat Exchanger and Economizer		False
FO-241281	Routine	Scheduled Maint. (PM)	3/1/2013	3/1/2013	0	PM - Heat Exchanger and Economizer		True
FO-241272	Routine	Scheduled Maint. (PM)	3/1/2013	3/1/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-241822	Routine	Scheduled Maint. (PM)	3/7/2013	3/7/2013	0	PM - Drinking Fountain and Water Cooler		False
FO-241826	Routine	Scheduled Maint. (PM)	3/8/2013	3/8/2013	0	PM - Heat Exchanger and Economizer	checked oper. OK	False
FO-241827	Routine	Scheduled Maint. (PM)	3/8/2013	3/8/2013	0	PM - Heat Exchanger and Economizer	# 1 is on line operating properly,#2 has a leak,fitters are scheduled for repair.	False
FO-243029	Routine	Scheduled Maint. (PM)	3/8/2013	3/8/2013	0	Generator Test Finished 3/08/13 MS		False
FO-243357	Routine	Scheduled Maint. (PM)	3/13/2013	3/13/2013	0	Generator Maintenance, Monthly		False
FO-243359	Routine	Scheduled Maint. (PM)	3/14/2013	3/14/2013	0	Generator Maintenance, Monthly		False
FO-243015	Routine	Scheduled Maint. (PM)	3/21/2013	3/21/2013	0	PM - Fan Coil/HV/AC Unit		False
FO-243354	Routine	Scheduled Maint. (PM)	3/21/2013	3/21/2013	0	Generator Maintenance, Monthly		False
FO-243636	Routine	Scheduled Maint. (PM)	3/28/2013	3/26/2013	-2	PM - Domestic Water Heater, Electric	CHECK UNIT OPERATION, BLOW DOWN TANK , CLEANED AREA.	False
FO-241276	Routine	Scheduled Maint. (PM)	3/4/2013	3/1/2013	-3	PM - Heat Exchanger and Economizer		False
FO-241277	Routine	Scheduled Maint. (PM)	3/4/2013	3/1/2013	-3	PM - Heat Exchanger and Economizer		False

			Finish Date	Due Date					Total per Trade	
FO-240583	Routine	Scheduled Maint. (PM)	3/4/2013	2/28/2013	-4	Generator Maintenance, Monthly	generator was down due to pump failure & suction issues.these problems have been corrected as of now.The oil level is good,some oil filters need to be changed dated 9-16-11.t2&t5. two of them.also the coolant filter needs to be changed dated 4-20-94.filter-wf2073-dca4. 8units.batteries seem to be in great working order at this time,two 31p-mhd,cca950.date-4-27-11 RC195. name of battery-Interstate.name of generator-Cummins Generator.1-800-969-3966 for company service.Generator seems to be in good working order at this time, no known problems.test run monday 8:30am to 9:00am.			False
FO-241275	Routine	Scheduled Maint. (PM)	3/5/2013	2/28/2013	-5	PM - Domestic Water Heater, Steam				False
FO-242395	Routine	Scheduled Maint. (PM)	3/19/2013	3/14/2013	-5	PM - Unspecified	performed tasks on maintenance list			False
FO-242396	Routine	Scheduled Maint. (PM)	3/19/2013	3/14/2013	-5	PM - Unspecified	performed tasks on maintenance list			False
FO-243026	Routine	Scheduled Maint. (PM)	3/26/2013	3/20/2013	-6	PM - Harmsco Side Stream Filter				False
FO-241278	Routine	Scheduled Maint. (PM)	3/8/2013	3/1/2013	-7	PM - Heat Exchanger and Economizer				False
FO-241279	Routine	Scheduled Maint. (PM)	3/8/2013	3/1/2013	-7	PM - Heat Exchanger and Economizer				False
FO-241833	Routine	Scheduled Maint. (PM)	3/14/2013	3/7/2013	-7	PM - Harmsco Side Stream Filter	Removed from service Harmsco side stream filter and washed all filters, then returned Harmsco side stream filter to service.			False
FO-241816	Routine	Scheduled Maint. (PM)	3/18/2013	3/9/2013	-9	PM - Centrifugal Pump, over 1 H.P.	performed tasks on maintenance check list.			False
FO-241817	Routine	Scheduled Maint. (PM)	3/18/2013	3/9/2013	-9	PM - Centrifugal Pump, over 1 H.P.	performed tasks on maintenance list.			False
FO-241818	Routine	Scheduled Maint. (PM)	3/18/2013	3/7/2013	-11	PM - Unspecified	performed tasks on maintenance list			False
FO-241819	Routine	Scheduled Maint. (PM)	3/18/2013	3/7/2013	-11	PM - Unspecified	performed tasks on maintenance list.			False
FO-243030	Routine	Scheduled Maint. (PM)	3/22/2013	3/8/2013	-14	Generator Maintenance, Monthly	I was off on illness, and log book shows D. Dennis covered my area. No entry that test was conducted or that Dennis was contacted for test.			True
FO-10008	Routine	Scheduled Maint. (PM)	3/25/2013			PM Vacuum pump system. Finished 4/4/13LT	see results for fo#16406			False
<b>E - Area 3 Auxiliary Eng</b>									<b>29 of 42</b>	<b>69%</b>
FO-243657	Routine	Scheduled Maint. (PM)	3/19/2013	5/14/2013	56	PM - Centrifugal Pump, over 1 H.P.	Lubricated bearings and checked operation (too early to fill lines)			False
FO-243658	Routine	Scheduled Maint. (PM)	3/19/2013	5/14/2013	56	PM - Centrifugal Pump, over 1 H.P.	Lubricated bearings and checked operation (too early to fill lines)			False
FO-243659	Routine	Scheduled Maint. (PM)	3/20/2013	5/14/2013	55	PM - Centrifugal Pump, over 1 H.P.	Lubricated bearings, checked packing and operation (too early to fill lines)			False
FO-243660	Routine	Scheduled Maint. (PM)	3/20/2013	5/14/2013	55	PM - Centrifugal Pump, over 1 H.P.	Lubricated bearings, checked packing and operation (too early to fill lines)			False
FO-243656	Routine	Scheduled Maint. (PM)	3/18/2013	4/29/2013	42	PM - Punch Tubes - Chiller/Absorber	Punched all tubes in early March.			False

			Finish Date	Due Date	Total per Trade			
FO-243661	Routine	Scheduled Maint. (PM)	3/21/2013	4/29/2013	39	PM - Cooling Tower, 500 - 1000 Tons	Cleaned and rinsed pans and inside, cleaned strainers, cleaned roof area, checked all drain valves, checked operation of fan blades and motor, checked operation of circulation pumps.	False
FO-244292	Routine	Scheduled Maint. (PM)	3/22/2013	4/9/2013	18	PM - Air Handling Unit	Lubricated bearings and motor, checked belts for proper tension, checked condition of filters/pre-filters, checked AHU and general area for cleanliness, checked motor for proper operation.	False
FO-244293	Routine	Scheduled Maint. (PM)	3/22/2013	4/9/2013	18	PM - Air Handling Unit	Lubricated bearings and motor, checked belts for proper tension, checked condition of filters/pre-filters, checked AHU and general area for cleanliness, checked motor for proper operation.	False
FO-244294	Routine	Scheduled Maint. (PM)	3/22/2013	4/9/2013	18	PM - Air Handling Unit	Lubricated bearings and motor, checked belts for proper tension, checked condition of filters/pre-filters, checked AHU and general area for cleanliness, checked motor for proper operation.	False
FO-243551	Routine	Scheduled Maint. (PM)	3/16/2013	3/31/2013	15	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	Changed filters, checked belts, lubed bearings and dampers.	False
FO-240905	Routine	Scheduled Maint. (PM)	3/27/2013	3/31/2013	4	PM - Monthly Fire Alarm/Fire Protection System Test	Assisted with fire test.	False
FO-240906	Routine	Scheduled Maint. (PM)	3/27/2013	3/31/2013	4	PM - Monthly Fire Alarm/Fire Protection System Test	Assisted and ran fire test.	False
FO-242407	Routine	Scheduled Maint. (PM)	3/12/2013	3/15/2013	3	PB - B&G Series 100 Pump	Checked coupler alignment, lubed bearings and tested controls.	False
FO-242408	Routine	Scheduled Maint. (PM)	3/12/2013	3/15/2013	3	PB - B&G Series 100 Pump	Checked coupler alignment, controls and lubed bearings.	False
FO-242409	Routine	Scheduled Maint. (PM)	3/12/2013	3/15/2013	3	PB - B&G Series 100 Pump	Checked alignment, lubed bearings and checked controls.	False
FO-242410	Routine	Scheduled Maint. (PM)	3/12/2013	3/15/2013	3	PB - B&G Series 100 Pump	Checked alignment, lubed bearings, and checked controls.	False
FO-242411	Routine	Scheduled Maint. (PM)	3/28/2013	3/31/2013	3	PM - Monthly Fire Alarm/Fire Protection System Test	Assisted with fire drill and tested fire pump.	False
FO-242412	Routine	Scheduled Maint. (PM)	3/28/2013	3/31/2013	3	PM - Monthly Fire Alarm/Fire Protection System Test	Ran fire test and tested fire pump.	False
FO-241834	Routine	Scheduled Maint. (PM)	3/4/2013	3/6/2013	2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Checked belts, dampers, controls and lubed bearing.	False
FO-243344	Routine	Scheduled Maint. (PM)	3/12/2013	3/13/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels and cleaned area.	False
FO-243346	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	Generator Maintenance, Monthly	Assisted with test, checked fluid levels and cleaned area.	False
FO-242405	Routine	Scheduled Maint. (PM)	3/21/2013	3/22/2013	1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Checked belts, dampers and lubed bearings.	False
FO-243328	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Maintenance, Monthly	Trapped resident in Ghafari elevator for the second straight month. Told elevator service company. Technician said they would be at the generator test next month.	False
FO-243330	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Maintenance, Monthly	generator ran without incident.	False

			Finish Date	Due Date	Total per Trade			
FO-243332	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Maintenance, Monthly	Generator down with a cracked engine block.	False
FO-243334	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Maintenance, Monthly	Generator ran without incident.	False
FO-243336	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Maintenance, Monthly	Generator ran without incident. Chatsworth did not switch from utility to generator power. C & IT called the front desk. They sid that the building network went down during the test.	False
FO-242406	Routine	Scheduled Maint. (PM)	3/15/2013	3/15/2013	0	PM - Fan Coil/HV/AC Unit	Changed filters, checked belts, controls and lubed bearings.	False
FO-243352	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Maintenance, Monthly	Assisted with test, checked equipment and cleaned area.	False
FO-242404	Routine	Scheduled Maint. (PM)	3/25/2013	3/22/2013	-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Cleaned and lubed unit	False
FO-241266	Routine	Scheduled Maint. (PM)	3/16/2013	3/3/2013	-13	Replace Chemistry PreFilters (AHU-1A/2A) North End	Changed pre- filters, checked belts and lube bearing and dampers.	False
FO-238174	Routine	Scheduled Maint. (PM)	3/20/2013	3/3/2013	-17	PM - Fire Alarm System Test	Assisted with fire test. Ran fire pump.	False
FO-236043	Routine	Scheduled Maint. (PM)	3/1/2013	12/30/2012	-61	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	Filters ordered and changed.	False
FO-236696	Routine	Scheduled Maint. (PM)	3/1/2013	12/19/2012	-72	Generator Maintenance	Test completed.	False
FO-233541	Routine	Scheduled Maint. (PM)	3/1/2013	12/2/2012	-89	Replace Chemistry PreFilters (AHU-1A/2A) North End	Filters ordered and changed.	False
FO-243284	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts and lubed bearings and dampers.	False
FO-243285	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts, lubed bearings and dampers.	False
FO-243286	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts, lubed bearings and dampers.	False
FO-243287	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts, lubed bearings and dampers.	False
FO-243288	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts, lubed bearings and dampers.	False
FO-243289	Routine	Scheduled Maint. (PM)	3/16/2013			Replace Chemistry pre-filters	Changed pre-filters, checked belts, lubed bearings and dampers.	False
FO-238175	Routine	Scheduled Maint. (PM)	3/27/2013			PM - Fire Alarm System Test	Ran fire test	False

#### E - Controls Engineer

4 of 39 10%

FO-242981	Routine	Scheduled Maint. (PM)	3/18/2013	3/24/2013	6	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-242982	Routine	Scheduled Maint. (PM)	3/18/2013	3/24/2013	6	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-243025	Routine	Scheduled Maint. (PM)	3/19/2013	3/24/2013	5	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-243008	Routine	Scheduled Maint. (PM)	3/19/2013	3/24/2013	5	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-243011	Routine	Scheduled Maint. (PM)	3/25/2013	3/24/2013	-1	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-243013	Routine	Scheduled Maint. (PM)	3/25/2013	3/24/2013	-1	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-243028	Routine	Scheduled Maint. (PM)	3/25/2013	3/24/2013	-1	PM - Air Compressor, Reciprocating 5-40 H.P.		False
FO-241815	Routine	Scheduled Maint. (PM)	3/11/2013	3/9/2013	-2	PM - Air Compressor, Reciprocating 5-40 H.P.		False

			Finish Date	Due Date				Total per Trade	
FO-243018	Routine	Scheduled Maint. (PM)	3/26/2013	3/24/2013	-2	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-238517	Routine	Scheduled Maint. (PM)	3/1/2013	1/31/2013	-29	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-238518	Routine	Scheduled Maint. (PM)	3/1/2013	1/31/2013	-29	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-239158	Routine	Scheduled Maint. (PM)	3/14/2013	2/10/2013	-32	PM - Air Dryer			False
FO-238516	Routine	Scheduled Maint. (PM)	3/14/2013	1/29/2013	-44	PM - Air Dryer			False
FO-239161	Routine	Scheduled Maint. (PM)	3/27/2013	2/11/2013	-44	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-238040	Routine	Scheduled Maint. (PM)	3/14/2013	1/24/2013	-49	PM - Air Dryer			False
FO-238529	Routine	Scheduled Maint. (PM)	3/27/2013	2/1/2013	-54	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-238531	Routine	Scheduled Maint. (PM)	3/27/2013	2/1/2013	-54	PM - Air Dryer			False
FO-237829	Routine	Scheduled Maint. (PM)	3/26/2013	1/19/2013	-66	PM - Air Dryer			False
FO-237819	Routine	Scheduled Maint. (PM)	3/26/2013	1/18/2013	-67	PM - Air Dryer			False
FO-237820	Routine	Scheduled Maint. (PM)	3/26/2013	1/18/2013	-67	PM - Air Dryer			False
FO-237821	Routine	Scheduled Maint. (PM)	3/26/2013	1/18/2013	-67	PM - Air Dryer			False
FO-237835	Routine	Scheduled Maint. (PM)	3/26/2013	1/18/2013	-67	PM - Air Dryer			False
FO-237836	Routine	Scheduled Maint. (PM)	3/26/2013	1/18/2013	-67	PM - Air Dryer			False
FO-237831	Routine	Scheduled Maint. (PM)	3/27/2013	1/19/2013	-67	PM - Air Dryer			False
FO-237830	Routine	Scheduled Maint. (PM)	3/27/2013	1/19/2013	-67	PM - Air Dryer			False
FO-237843	Routine	Scheduled Maint. (PM)	3/26/2013	1/16/2013	-69	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-237844	Routine	Scheduled Maint. (PM)	3/26/2013	1/16/2013	-69	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-237855	Routine	Scheduled Maint. (PM)	3/26/2013	1/16/2013	-69	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-234987	Routine	Scheduled Maint. (PM)	3/4/2013	12/17/2012	-77	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-234989	Routine	Scheduled Maint. (PM)	3/4/2013	12/17/2012	-77	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-234988	Routine	Scheduled Maint. (PM)	3/4/2013	12/17/2012	-77	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-235349	Routine	Scheduled Maint. (PM)	3/26/2013	12/20/2012	-96	PM - Air Compressor, Reciprocating 5-40 H.P.		Unit has been OOS for over a year. Needs approx \$1200 worth of Brehob service...no occupants have complained about lack of lab air.	False
FO-233493	Routine	Scheduled Maint. (PM)	3/21/2013	11/29/2012	-112	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-230690	Routine	Scheduled Maint. (PM)	3/5/2013	11/9/2012	-116	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-233507	Routine	Scheduled Maint. (PM)	3/26/2013	11/30/2012	-116	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-232796	Routine	Scheduled Maint. (PM)	3/22/2013	11/23/2012	-119	PM - Air Compressor, Reciprocating 5-40 H.P.			False
FO-230775	Routine	Scheduled Maint. (PM)	3/22/2013	11/13/2012	-129	PM - Air Compressor, Reciprocating 5-40 H.P.		ALSO REFER TO WO FO-245705 SENT TO REF CREW/LPS	False
FO-230760	Routine	Scheduled Maint. (PM)	3/25/2013	11/13/2012	-132	PM - Air Dryer			False
FO-230427	Routine	Scheduled Maint. (PM)	3/26/2013			PM - Air Dryer			False
E - Midnight Engineer								6 of 6	100%
FO-244822	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			False

			Finish Date	Due Date				Total per Trade
FO-244823	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-244824	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-244815	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-244817	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False
FO-244818	Routine	Scheduled Maint. (PM)	3/22/2013	4/11/2013	20	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		False

## Grounds

2 of 2 100%

### G - Moving/Storage

2 of 2 100%

FO-246623	Medium	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Grounds - Roll Infield & Outfield		False
FO-246621	Medium	Scheduled Maint. (PM)	3/28/2013	3/29/2013	1	Grounds - Roll Infield & Outfield		True

## Trades

25 of 29 86%

### T - Electrician

25 of 29 86%

FO-243003	Routine	Scheduled Maint. (PM)	3/8/2013	3/9/2013	1	Generator Test Finished 3/08/13 MS		False
FO-243001	Routine	Scheduled Maint. (PM)	3/8/2013	3/9/2013	1	Generator Test Finished 3/11/13 MS		False
FO-243356	Routine	Scheduled Maint. (PM)	3/12/2013	3/13/2013	1	Generator Test		False
FO-243343	Routine	Scheduled Maint. (PM)	3/12/2013	3/13/2013	1	Generator Test Finished 3/12/13 MS		False
FO-243345	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	Generator Test Finished 3/13/13 MS		False
FO-243358	Routine	Scheduled Maint. (PM)	3/13/2013	3/14/2013	1	Generator Test Finished 3/13/13 MS		False
FO-243314	Routine	Scheduled Maint. (PM)	3/14/2013	3/15/2013	1	Generator Test Finished 3/13/13 MS		False
FO-243316	Routine	Scheduled Maint. (PM)	3/14/2013	3/15/2013	1	Generator Test Finished 3/14/13 MS		False
FO-243350	Routine	Scheduled Maint. (PM)	3/14/2013	3/15/2013	1	Generator Test Finished 3/14/13 MS		False
FO-243320	Routine	Scheduled Maint. (PM)	3/20/2013	3/21/2013	1	Generator Test Finished 3/21/2013LT		False
FO-243323	Routine	Scheduled Maint. (PM)	3/22/2013	3/23/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243325	Routine	Scheduled Maint. (PM)	3/22/2013	3/23/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243329	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243331	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243333	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243335	Routine	Scheduled Maint. (PM)	3/26/2013	3/27/2013	1	Generator Test Finished 3/26/13 LT		False
FO-243322	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	Generator Test Finished 3/28/13 LT		False
FO-243341	Routine	Scheduled Maint. (PM)	3/27/2013	3/28/2013	1	Generator Test Finished 3/28/13 LT		False
FO-243312	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Test Finished 3/20/2013LT		False



		Finish Date		Due Date				Total per Trade
FO-243337	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Test Finished 3/20/2013LT		False
FO-243339	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Test Finished 3/20/2013LT		False
FO-243347	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Test Finished 3/20/2013LT		False
FO-243349	Routine	Scheduled Maint. (PM)	3/20/2013	3/20/2013	0	Generator Test Finished 3/21/2013LT		False
FO-243353	Routine	Scheduled Maint. (PM)	3/21/2013	3/21/2013	0	Generator Test Finished 3/26/2013LT		False
FO-243327	Routine	Scheduled Maint. (PM)	3/26/2013	3/26/2013	0	Generator Test Finished 3/26/13 LT		False
FO-243318	Routine	Scheduled Maint. (PM)	3/20/2013	3/19/2013	-1	Generator Test Finished 3/20/2013LT		False
FO-240604	Routine	Scheduled Maint. (PM)	3/5/2013	2/28/2013	-5	Generator Test		True
FO-239891	Routine	Scheduled Maint. (PM)	3/1/2013	2/2/2013	-27	Generator TestFinished 3/4/2013LT		False
FO-239860	Routine	Scheduled Maint. (PM)	3/1/2013	2/1/2013	-28	Generator TestFinished 3/4/2013LT		False

**Total: 353 of 483 86%**