

# DRAFT Facilities Operations PM Analysis from 6/1/15 through 6/30/15

Requested Finished Open WND

% Finished

Engineering			587	436	71	80				74%
E - Auxiliary			30	27	3	0				90%
FO-317581	Created By PM Schedule	034-AIR-001	6/1/2015			False		PM - Air Compressor, Reciprocating 5-40 H.P.		
FO-317582	Created By PM Schedule	034-AIR-002	6/1/2015			False		PM - Air Compressor, Reciprocating 5-40 H.P.		
FO-317590	Finished	134-AHU-001	6/1/2015	7/11/2015		False	0.75	PM - Air Handling Unit		
Checked shaft and blades for condition; greased motor and bearings; cleaned unit and filters.										
FO-317591	Finished	134-AHU-002	6/1/2015	7/11/2015		False	0.75	PM - Air Handling Unit		
Checked shaft and blades for condition; greased motor and bearings; cleaned unit and filters.										
FO-317592	Created By PM Schedule	127-MAU-005	6/1/2015			False		PM - Fan Coil/HV/AC Unit		
FO-317593	Finished	501-ACU-001	6/1/2015	7/31/2015		False		PM - Water/Air Cooled Condenser		
FO-317594	Finished	992-ES-001*	6/1/2015	6/5/2015		False		PM - Emergency Shower/Eyewash Station		
FO-317596	Finished	134-ACU-001	6/1/2015	6/15/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-317606	Finished	507-ACU-001	6/1/2015	6/15/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers		
FO-317611	Finished	134-FP-001	6/1/2015	7/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-317612	Finished	127-FP-001	6/1/2015	7/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-317613	Finished	115-FP-001	6/1/2015	7/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-317614	Finished	104-FP-001	6/1/2015	7/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-317615	Finished	507-FP-001	6/1/2015	7/1/2015		False		PM - Monthly Fire Alarm/Fire Protection System Test		
FO-317627	Finished	136-BSG-004	6/1/2015	8/28/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~		
FO-317628	Finished	136-BSG-003	6/1/2015	8/28/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~		
FO-317629	Finished	136-BSG-002	6/1/2015	8/28/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~		
FO-317630	Finished	136-BSG-001	6/1/2015	8/28/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~		
FO-317981	Finished	501-GEN-001	6/9/2015	6/10/2015		False		Generator Maintenance, Monthly		
FO-317983	Finished	992-ES-001*	6/8/2015	6/12/2015		False		PM - Emergency Shower/Eyewash Station		
FO-318495	Finished	507-GEN-001	6/10/2015	6/11/2015		False		Generator Maintenance, Monthly		
FO-318499	Finished	992-ES-001*	6/15/2015	6/19/2015		False		PM - Emergency Shower/Eyewash Station		
FO-319074	Finished	104-GEN-001	6/23/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319076	Finished	127-GEN-001	6/23/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319078	Finished	127-GEN-002	6/23/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319080	Finished	127-GEN-003	6/23/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319082	Finished	127-GEN-004	6/23/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319086	Finished	536-GEN-001	6/17/2015	6/24/2015		False		Generator Maintenance, Monthly		
FO-319230	Finished	992-ES-001*	6/22/2015	6/26/2015		False		PM - Emergency Shower/Eyewash Station		
FO-319766	Finished	992-ES-001*	6/29/2015	6/30/2015		False		PM - Emergency Shower/Eyewash Station		
E - MedPharm			44	34	9	1				77%
FO-317435	Finished	603-HEX-001	6/1/2015	8/6/2015		False	1.00	PM - Heat Exchanger and Economizer		
replaced gauge chem test ok										

Requested Finished Open WND

% Finished

FO-317436	Finished	603-HEX-002	6/1/2015	8/6/2015	False	0.50	PM - Heat Exchanger and Economizer	
test relief valves chem test ok gauge ok								
FO-317437	Finished	603-HEX-003*	6/1/2015	8/6/2015	False	1.00	PM - Heat Exchanger and Economizer	
checked glycol to sewer(none) cleaned unit temp out 118f								
FO-317439	Finished	603-SP-001*	6/1/2015	8/6/2015	False	0.50	PM - Sump Pump	
sand in sump GENERATOR INSTALL								
FO-317440	Finished	603-SP-002*	6/1/2015	8/6/2015	False	0.50	PM - Sump Pump	
DONE								
FO-317441	Finished	609-ECO-001	6/1/2015	6/18/2015	False		PM - Heat Exchanger and Economizer	
done								
FO-317442	Created By PM Schedule	611-AIR-001C**	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317443	Finished	611-HVU-001**	6/1/2015	8/14/2015	True	0.10	PM - Fan Coil/HV/AC Unit	
Unit is running but it is inaccessible due to stored tables and chairs in room.								
FO-317444	Finished	611-HVU-004**	6/1/2015	8/4/2015	False	1.50	PM - Fan Coil/HV/AC Unit	
Changed belts on unit. Greased motor & bearings.								
FO-317445	Created By PM Schedule	629-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317446	Finished	629-ROS-001	6/1/2015	6/16/2015	False	2.00	PM - Reverse Osmosis Water Softener System	
FO-317447	Finished	612-AIR-001	6/1/2015	7/1/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317448	Finished	612-AIR-002	6/1/2015	6/25/2015	False	0.50	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317449	Finished	612-AIR-003	6/1/2015	6/25/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317450	Finished	612-SP-001	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-317451	Finished	612-SP-002	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-317452	Finished	612-SP-003	6/1/2015	6/17/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-317453	Finished	603-HEX-004*	6/1/2015	8/6/2015	False	0.50	PM - Heat Exchanger and Economizer	
done								
FO-317454	Created By PM Schedule	611-AIR-001	6/1/2015		False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-317455	Finished	629-WSS-001	6/1/2015	6/16/2015	False	2.00	PM - Water Softener	
FO-317456	Finished	629-GFP-001	6/1/2015	6/30/2015	False	0.10	PM - Centrifugal Pump, over 1 H.P.	
FO-317457	Finished	629-GFP-002	6/1/2015	6/30/2015	False	1.00	PM - Centrifugal Pump, over 1 H.P.	
FO-317458	Finished	612-ACU-002	6/1/2015	6/19/2015	False	8.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-317459	Finished	612-ACU-001	6/1/2015	7/2/2015	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-317460	Finished	611-ACU-002**	6/1/2015	7/6/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
Trane performed PM maintenance checks								
FO-317461	Finished	611-ACU-001**	6/1/2015	7/6/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
Trane performed PM maintenance checks								
FO-317462	Finished	608-ACU-001	6/1/2015	6/5/2015	False	4.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	

Requested Finished Open WND

% Finished

FO-317463	Finished	603-ACU-002	6/1/2015	4/14/2015	False	9.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
punched tubes cleaned found leak(TRANE) lost liquid seal after TRANE made level adjustment							
FO-317464	Finished	603-ACU-001	6/1/2015	4/13/2015	False	10.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
punched tubes cleaned lost liquid after TRANE adjustment							
FO-317465	Finished	608-ACU-002	6/1/2015	6/5/2015	False	4.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317466	Finished	629-BSG-003	6/1/2015	6/24/2015	False	7.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317467	Created By PM Schedule	629-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317468	Created By PM Schedule	629-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317469	Created By PM Schedule	603-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317470	Created By PM Schedule	620-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317471	Created By PM Schedule	620-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317472	Finished	608-BSG-002	6/1/2015	6/30/2015	False	8.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317473	Finished	608-BSG-001	6/1/2015	6/30/2015	False	8.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317474	Created By PM Schedule	629-EOS-001	6/1/2015		False		Replace PRE-filters
FO-317960	Finished	603-CRP-001	6/6/2015	8/6/2015	False	0.50	PM - Condensate Return Pump
done unit offline							
FO-317961	Finished	603-CRP-002	6/6/2015	8/6/2015	False	0.50	PM - Condensate Return Pump
done							
FO-318458	Finished	609-GEN-001	6/16/2015	6/18/2015	False		Generator Maintenance, Monthly
checked fluids and battery							
FO-319070	Finished	611-GEN-001	6/26/2015	6/23/2015	False	0.50	Generator Maintenance, Monthly
Electricians performed monthly generator load test							
FO-319072	Created By PM Schedule	629-GEN-001	6/26/2015		False		Generator Maintenance, Monthly
<b>E - North</b>			<b>38</b>	<b>38</b>	<b>-1</b>	<b>1</b>	<b>100%</b>
FO-317475	Finished	140-AIR-001	6/1/2015	8/31/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317476	Finished	140-AIR-002	6/1/2015	6/24/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317477	Finished	050-AIR-001	6/1/2015	6/29/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317478	Finished	050-AIR-002	6/1/2015	6/29/2015	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317479	Finished	049-DWBP-001	6/1/2015	6/19/2015	False	0.50	PM - Water Booster Pump
FO-317480	Finished	049-DWBP-002	6/1/2015	6/19/2015	False	0.50	PM - Water Booster Pump
FO-317481	Finished	048-HEX-001	6/1/2015	6/25/2015	False	0.55	PM - Heat Exchanger and Economizer

**Requested Finished Open WND**

**% Finished**

FO-317482	Finished	048-HEX-002	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317483	Finished	027-HEX-001	6/1/2015	6/2/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-317484	Finished	027-HEX-002	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317485	Finished	027-HEX-003	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317486	Finished	027-HEX-004	6/1/2015	6/2/2015	False	0.75	PM - Heat Exchanger and Economizer
FO-317487	Finished	036-HEX-001	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317488	Finished	036-HEX-002	6/1/2015	6/2/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317489	Finished	048-DHW-001	6/1/2015	6/15/2015	False	0.40	PM - Domestic Water Heater, Steam
FO-317490	Finished	130-AIR-001	6/1/2015	7/21/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317491	Finished	046-HEX-001	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317492	Finished	046-HEX-002	6/1/2015	7/7/2015	False	1.50	PM - Heat Exchanger and Economizer
FO-317493	Finished	046-HEX-003	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317494	Finished	046-HEX-004	6/1/2015	6/22/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317495	Finished	046-HEX-005	6/1/2015	7/8/2015	False	2.50	PM - Heat Exchanger and Economizer
FO-317496	Finished	048-HEX-003	6/1/2015	6/15/2015	False	0.40	PM - Heat Exchanger and Economizer
FO-317497	Finished	048-DWBP-001	6/1/2015	6/15/2015	False	0.40	PM - Water Booster Pump
FO-317498	Finished	048-DWBP-002	6/1/2015	6/2/2015	False	0.40	PM - Water Booster Pump
FO-317499	Finished	049-HWP-001	6/1/2015	6/19/2015	False	0.45	PM - Water Booster Pump
FO-317500	Finished	062-AIR-001	6/1/2015	7/1/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317501	Finished	026-HEX-002	6/1/2015	6/10/2015	False	1.00	PM - Heat Exchanger and Economizer
FO-317502	Finished	026-ACU-004	6/1/2015	5/26/2015	False	1.00	PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317503	Finished	048-BSG-002	6/1/2015	7/9/2015	False	10.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317504	Finished	048-BSG-001	6/1/2015	8/12/2015	False	8.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317505	Finished Inspected boiler and refractory.	038-BSG-002	6/1/2015	8/10/2015	False	1.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317506	Finished Boiler #1 inspected by state and DJ Connely. Proceeding to close and put back on line.	038-BSG-001	6/1/2015	6/23/2015	False	4.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317507	Finished	026-BSG-002	6/1/2015	6/23/2015	True	80.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317508	Finished	026-BSG-001	6/1/2015	6/23/2015	False	80.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-318459	Finished Checked intake for debris removed as needed, checked overall operation of units.	043-AHU-INT	6/15/2015	7/21/2015	False	1.00	PM - Outside/Fresh Air Intake Screens
FO-318460	Finished	048-GEN-001	6/12/2015	6/12/2015	False	0.65	Generator Maintenance, Monthly
FO-319084	Finished	130-GEN-001	6/24/2015	6/25/2015	False	1.00	Generator Maintenance, Monthly
FO-319213	Finished	048-EW-001	6/18/2015	6/18/2015	False	0.25	PM - Emergency Shower/Eyewash Station - Annual Flow Test
<b>E - Northeast</b>			<b>26</b>	<b>26</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-317509	Finished	193-HEX-001	6/1/2015	6/1/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317510	Finished	193-HEX-002	6/1/2015	7/1/2015	False	0.50	PM - Heat Exchanger and Economizer
FO-317511	Finished	067-ACU-109	6/1/2015	7/6/2015	False	0.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317512	Finished	065-ACU-001	6/1/2015	6/18/2015	False		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317513	Finished	067-BSG-002	6/1/2015	8/27/2015	False	16.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

**Requested Finished Open WND**

**% Finished**

FO-317514	Finished	067-BSG-001	6/1/2015	7/22/2015	False	4.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317515	Finished	193-BSG-002	6/1/2015	8/31/2015	False	40.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317516	Finished	193-BSG-001	6/1/2015	8/31/2015	False	40.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317517	Finished	064-BSG-002	6/1/2015	6/22/2015	False	2.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317518	Finished	064-BSG-001	6/1/2015	6/22/2015	False	2.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317519	Finished	217-BSG-001	6/1/2015	6/9/2015	False	2.00	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
worked with Detroit boiler tech. inspection report in boiler room							
FO-317963	Finished	193-GEN-001	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317964	Finished	193-GEN-002	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317965	Finished	193-GEN-003	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-317966	Finished	193-GEN-004	6/5/2015	6/5/2015	False	1.00	Generator Maintenance, Monthly
FO-318461	Created By PM Schedule	203-GEN-001	6/16/2015	6/17/2015	False	0.50	Generator Maintenance, Monthly
FO-318462	Finished	062-DHW-006	6/12/2015	7/13/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-318463	Finished	062-DHW-005	6/12/2015	6/26/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-318464	Finished	062-DHW-004	6/12/2015	6/26/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-318465	Finished	062-DHW-003	6/12/2015	6/26/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-318466	Finished	062-DHW-002	6/12/2015	6/17/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-318467	Finished	062-DHW-001	6/12/2015	6/12/2015	False	1.00	PM - Domestic Water Heater, Gas
FO-319067	Finished	066-GEN-001	6/24/2015	6/22/2015	False	1.00	Generator Maintenance, Monthly
generator checked. coolant was low. distilled water added to prevent damage if unit is run. hose connections leak and look corroded. oil leak from gasket on North side of unit as well.							
FO-319088	Finished	527-GEN-001	6/18/2015	6/18/2015	False	1.50	Generator Maintenance, Monthly
completed test							
FO-319094	Finished	060-GEN-001A	6/25/2015	6/18/2015	False		Generator Maintenance, Monthly
no access. new unit. under warranty. I have not received a key yet.							
FO-319096	Finished	060-GEN-001B	6/25/2015	6/18/2015	False		Generator Maintenance, Monthly
no access. new unit. under warranty. I have not received a key yet.							
<b>E - Preventative Maintenance</b>			<b>264</b>	<b>153</b>	<b>33</b>	<b>78</b>	<b>58%</b>
FO-316179	Finished	005-EXF-013	6/1/2015	6/27/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316180	Finished	005-EXF-014	6/1/2015	6/27/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316181	Finished	050-RAF-001	6/1/2015	5/27/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316182	Completed	01-FCU-002HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316183	Completed	01-FCU-003HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316184	Completed	01-FCU-003LOB	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316185	Completed	01-FCU-004HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316186	Completed	01-FCU-005HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316187	Completed	01-FCU-006HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316188	Completed	01-FCU-007HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316189	Completed	01-FCU-008HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316190	Completed	01-FCU-009HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit

**Requested Finished Open WND**

**% Finished**

FO-316191	Completed	01-FCU-010HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316192	Completed	01-FCU-011HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316193	Completed	01-FCU-012HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316194	Completed	01-FCU-013HCF	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316195	Completed	001-FCU-3121	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316196	Completed	001-FCU-3129	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316197	Completed	001-FCU-3133-1	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316198	Completed	001-FCU-3133-2	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316199	Completed	001-FCU-3133-3	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316200	Completed	001-FCU-3133-4	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316201	Completed	001-FCU-3133-5	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316202	Completed	001-FCU-3134-1	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316203	Completed	001-FCU-3134-2	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316204	Completed	001-FCU-3134-3	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316205	Completed	001-FCU-3134-4	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316206	Completed	001-FCU-3141-1	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316207	Completed	001-FCU-3141-1A	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316208	Completed	001-FCU-3141-1B	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316209	Completed	001-FCU-3141-1C	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316210	Completed	001-FCU-3141-1D	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316211	Completed	001-FCU-3141-1E	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316212	Completed	001-FCU-3141-1F	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316213	Completed	001-FCU-3141-1G	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316214	Completed	001-FCU-3141-1H	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316215	Completed	001-FCU-3141-1I	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316216	Completed	001-FCU-3141-1J	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316217	Completed	001-FCU-3141-2	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316218	Completed	001-FCU-3141-3	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316219	Completed	001-FCU-3141-4	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316220	Completed	001-FCU-3141-5	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316221	Completed	001-FCU-3141-6	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316222	Completed	001-FCU-3141-7	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316223	Completed	001-FCU-3141-8	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316224	Completed	001-FCU-3141-9	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316225	Completed	001-FCU-3202	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316226	Completed	001-FCU-3203	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316227	Completed	001-FCU-3204	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316228	Completed	001-FCU-3207-1	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316229	Completed	001-FCU-3207-2	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316230	Completed	039-EXF-001	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316231	Completed	039-EXF-004	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316232	Completed	039-EXF-005	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316233	Finished	040-EXF-002	6/1/2015	5/16/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316234	Finished	040-EXF-003	6/1/2015	5/28/2015	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan



## Requested Finished Open WND

% Finished

FO-316279	Completed	067-EXF-004	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316280	Finished	008-EXF-001	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316281	Finished	008-EXF-002	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316282	Completed	001-FCU-3125	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316283	Completed	001-FCU-3125.1	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316284	Completed	001-FCU-3125.2	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316285	Completed	001-FCU-3125.3	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316286	Completed	001-FCU-3207.3	6/1/2015		True		PM - Fan Coil/HV/AC Unit
FO-316287	Finished	005-EXF-030	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316288	Finished	005-EXF-031	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316289	Finished	005-EXF-032	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316290	Finished	005-EXF-033	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316291	Finished	005-EXF-035	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316292	Finished	005-EXF-036	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316293	Finished	005-EXF-004	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316294	Finished	005-EXF-008	6/1/2015	6/23/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316295	Finished	005-EXF-015	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316296	Finished	005-EXF-020	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316297	Finished	005-EXF-025	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316298	Finished	005-EXF-026	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316299	Finished	005-EXF-027	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316300	Finished	005-EXF-028	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316301	Finished	005-EXF-029	6/1/2015	6/26/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316302	Finished	603-EXF-005	6/7/2015	7/1/2015	False	0.50	Animal Lab Filter Changes for Applelebaum
FO-316303	Finished	046-FAP-001	6/1/2015	6/24/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316304	Finished	048-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316305	Finished	049-FAP-001	6/1/2015	6/24/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316306	Finished	156-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316307	Finished	499-FAP-001	6/1/2015	6/16/2015	False	6.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316308	Finished	620-FAP-001	6/1/2015	6/10/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316309	Finished	036-FP-001	6/1/2015	6/8/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316310	Finished	025-FP-001	6/1/2015	6/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316311	Finished	007-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316312	Finished	001-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316313	Finished	005-FAP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316314	Finished	040-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316315	Finished	038-FAP-001	6/1/2015	6/5/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316316	Finished	028-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316317	Finished	026-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316318	Finished	022-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316319	Finished	017-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316320	Finished	016-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316321	Finished	003-FAP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316322	Finished	006-FP-001	6/1/2015	6/30/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test



**Requested Finished Open WND**

**% Finished**

FO-316323	Finished	050-FAP-001	6/1/2015	6/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316324	Finished	043-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316325	Finished	042-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316326	Finished	062-FP-001	6/1/2015	6/6/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316327	Finished	065-FP-001	6/1/2015	6/24/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316328	Finished	068-FAP-001	6/1/2015	6/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316329	Finished	067-FP-001	6/1/2015	6/22/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316330	Finished	089-FP-001	6/1/2015	6/29/2015	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316331	Finished	082-FP-001	6/1/2015	6/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316332	Finished	080-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316333	Finished	090-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316334	Finished	155-FP-001	6/1/2015	6/12/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316335	Finished	150-FAP-001	6/1/2015	6/9/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316336	Finished	167-FAP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316337	Finished	166-FP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316338	Finished	140-FAP-001	6/1/2015	6/14/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316339	Finished	130-FP-001	6/1/2015	6/6/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316340	Finished	193-FAP-001	6/1/2015	6/23/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316341	Finished	189-FP-001	6/1/2015	6/13/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316342	Finished	510-FAP-001	6/1/2015	6/4/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316343	Finished	509-FAP-001	6/1/2015	6/4/2015	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316344	Finished	504-FAP-001	6/1/2015	6/6/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316345	Finished	629-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316346	Finished	612-FP-001	6/1/2015	6/18/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316347	Finished	611-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316348	Finished	609-FP-001	6/1/2015	6/19/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316349	Finished	603-FP-001	6/1/2015	6/19/2015	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316350	Finished	608-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316351	Finished	603-AHU-009	6/1/2015	6/25/2015	False	6.00	Replace PRE-filters
FO-316352	Finished	603-AHU-008	6/1/2015	7/1/2015	False	3.00	Replace PRE-filters
FO-316353	Finished	603-AHU-007	6/1/2015	7/1/2015	False	3.00	Replace PRE-filters
FO-316354	Finished	603-AHU-006	6/1/2015	6/25/2015	False	6.00	Replace PRE-filters
FO-316366	Finished	637-AHU-004	6/1/2015	6/15/2015	False	3.00	Replace PRE-filters
FO-316367	Finished	637-AHU-003	6/1/2015	6/12/2015	False	3.00	Replace PRE-filters
FO-316368	Completed	637-AHU-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316369	Completed	637-AHU-001A	6/1/2015		False	0.00	Replace PRE-filters
FO-316370	Completed	637-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316371	Finished	074-FAP-001	6/1/2015	6/11/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316372	Finished	005-AHU-003	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316373	Finished	005-AHU-002	6/1/2015	6/17/2015	False	2.50	Replace PRE-filters
FO-316374	Finished	005-AHU-001	6/1/2015	6/17/2015	False	2.50	Replace PRE-filters
FO-316375	Finished	089-AHU-006	6/1/2015	6/11/2015	False	1.00	Replace PRE-filters
FO-316376	Finished	089-AHU-005	6/1/2015	6/11/2015	False	2.00	Replace PRE-filters
FO-316377	Finished	089-AHU-004	6/1/2015	6/11/2015	False	1.00	Replace PRE-filters

**Requested Finished Open WND**

**% Finished**

FO-316378	Finished	089-AHU-003	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316379	Finished	089-AHU-002	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316380	Finished	089-AHU-001	6/1/2015	6/12/2015	False	2.00	Replace PRE-filters
FO-316381	Finished	008-AHU-005	6/1/2015	6/8/2015	False	1.50	Replace PRE-filters
FO-316382	Finished	008-AHU-004	6/1/2015	6/8/2015	False	2.00	Replace PRE-filters
FO-316383	Finished	008-AHU-002	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316384	Finished	008-AHU-001	6/1/2015	6/22/2015	False	1.00	Replace PRE-filters
FO-316385	Finished	006-AHU-005	6/1/2015	6/24/2015	False	1.00	Replace PRE-filters
FO-316386	Finished	006-AHU-004	6/1/2015	6/15/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316387	Finished	006-AHU-003	6/1/2015	6/15/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316388	Finished	006-AHU-002	6/1/2015	6/18/2015	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-316389	Finished	006-AHU-001	6/1/2015	6/18/2015	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-316390	Finished	008-EXF-005	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316391	Finished	008-EXF-004	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316392	Finished	008-EXF-003	6/1/2015	6/30/2015	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316393	Completed	140-AHU-004	6/1/2015		False	0.00	Replace PRE-filters
FO-316394	Completed	140-AHU-003	6/1/2015		False	0.00	Replace PRE-filters
FO-316395	Completed	140-AHU-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316396	Completed	140-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316397	Completed	189-AHU-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316398	Completed	189-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316399	Completed	042-SAF-013	6/1/2015		False	0.00	Replace PRE-filters
FO-316400	Completed	042-SAF-012	6/1/2015		False	0.00	Replace PRE-filters
FO-316401	Completed	042-SAF-001	6/1/2015		True		Replace PRE-filters
FO-316402	Completed	042-AHU-001	6/1/2015		True		Replace PRE-filters
FO-316403	Completed	040-SAF-004	6/1/2015		True		Replace PRE-filters
FO-316404	Finished	040-SAF-003	6/1/2015	5/21/2015	False	1.50	Replace PRE-filters
FO-316405	Finished	040-SAF-002	6/1/2015	5/19/2015	False	1.00	Replace PRE-filters
FO-316406	Completed	039-SAF-009	6/1/2015		False	0.00	Replace PRE-filters
FO-316407	Completed	039-SAF-008	6/1/2015		False	0.00	Replace PRE-filters
FO-316408	Completed	039-SAF-007	6/1/2015		False	0.00	Replace PRE-filters
FO-316409	Completed	039-SAF-006	6/1/2015		False	0.00	Replace PRE-filters
FO-316410	Finished	039-SAF-005	6/1/2015	5/21/2015	False	1.00	Replace PRE-filters
FO-316411	Completed	039-SAF-004	6/1/2015		False	0.00	Replace PRE-filters
FO-316412	Completed	039-SAF-003	6/1/2015		False	0.00	Replace PRE-filters
FO-316413	Completed	039-SAF-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316414	Finished	039-SAF-001	6/1/2015	5/21/2015	False	2.00	Replace PRE-filters
FO-316415	Completed	038-SAF-004	6/1/2015		False	1.00	Replace PRE-filters
FO-316416	Completed	038-SAF-003	6/1/2015		False	0.00	Replace PRE-filters
FO-316417	Completed	038-SAF-002	6/1/2015		True		Replace PRE-filters
FO-316418	Completed	038-SAF-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316419	Completed	189-HVU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316420	Completed	189-HVU-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316421	Completed	043-HVU-001	6/1/2015		False	0.00	Replace PRE-filters

## Requested Finished Open WND

% Finished

FO-316422	Completed	043-AHU-003	6/1/2015		False	0.00	Replace PRE-filters
FO-316423	Completed	043-AHU-002	6/1/2015		False	0.00	Replace PRE-filters
FO-316424	Completed	043-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316427	Finished	096-FP-001	6/1/2015	6/17/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316428	Completed	085-ACU-001	6/1/2015		True		Replace PRE-filters
FO-316429	Finished	050-AHU-001	6/1/2015	6/29/2015	False	3.00	Replace PRE-filters
FO-316430	Completed	065-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316431	Completed	067-AHU-003	6/1/2015		False	0.00	Replace PRE-filters
FO-316432	Completed	067-AHU-001	6/1/2015		False	0.00	Replace PRE-filters
FO-316433	Finished	609-AHU-005	6/1/2015	6/18/2015	False	3.00	Replace PRE-filters
FO-316434	Finished	609-AHU-004	6/1/2015	6/18/2015	False	3.00	Replace PRE-filters
FO-316435	Finished	609-AHU-003B	6/1/2015	6/19/2015	False	3.00	Replace PRE-filters
FO-316436	Finished	609-AHU-003A	6/1/2015	6/19/2015	False	3.00	Replace PRE-filters
FO-316437	Finished	609-AHU-002	6/1/2015	6/23/2015	False	3.00	Replace PRE-filters
FO-316438	Finished	609-AHU-001	6/1/2015	6/24/2015	False	3.00	Replace PRE-filters
FO-316439	Completed	067-EXF-005	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316440	Completed	067-EXF-006	6/1/2015		True		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-316441	Finished	001-AHU-004O	6/1/2015	7/14/2015	False	2.00	Replace PRE-filters
FO-316442	Finished	001-AHU-003O	6/1/2015	7/14/2015	False	2.50	Replace PRE-filters
FO-316443	Completed	001-AHU-003ML	6/1/2015		False	0.00	Replace PRE-filters
FO-316444	Finished	001-AHU-002O	6/1/2015	7/14/2015	False	2.00	Replace PRE-filters
FO-316445	Completed	001-AHU-002ML	6/1/2015		False	0.00	Replace PRE-filters
FO-316446	Finished	001-AHU-002	6/1/2015	7/11/2015	False	2.00	Replace PRE-filters
FO-316447	Finished	001-AHU-001O	6/1/2015	7/11/2015	False	2.00	Replace PRE-filters
FO-316448	Completed	001-AHU-001ML	6/1/2015		False	0.00	Replace PRE-filters
FO-316449	Finished	001-AHU-001	6/1/2015	7/11/2015	False	3.00	Replace PRE-filters
FO-316450	Finished	169-FAP-001	6/1/2015	6/30/2015	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-316451	Finished	608-AHU-004	6/1/2015	6/10/2015	False	3.00	Replace PRE-filters
FO-316452	Finished	608-AHU-003	6/1/2015	6/10/2015	False	2.00	Replace PRE-filters
FO-316453	Finished	608-AHU-002	6/1/2015	6/9/2015	False	2.00	Replace PRE-filters
FO-316454	Finished	608-AHU-001	6/1/2015	6/9/2015	False	3.00	Replace PRE-filters
FO-316459	Finished	008-AHU-003	6/1/2015	6/9/2015	False	2.50	Replace PRE-filters

**E - South****49****49****0****0****100%**

FO-316465	Finished	007-AHU-007	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316466	Finished	007-AHU-006	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316467	Finished	007-AHU-005	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316468	Finished	007-AHU-004	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316469	Finished	007-AHU-003	6/13/2015	6/20/2015	False	2.00	Replace PRE-filters
FO-316470	Finished	007-EXF-002	6/13/2015	6/13/2015	False	2.00	Replace PRE-filters
FO-316471	Finished	007-EXF-001	6/13/2015	6/13/2015	False	2.00	Replace PRE-filters
FO-316472	Finished	007-AHU-002	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316473	Finished	007-AHU-001	6/13/2015	6/13/2015	False	4.00	Replace PRE-filters
FO-316474	Finished	007-BSG-004	6/1/2015	8/11/2015	False	1.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~

**Requested Finished Open WND**

**% Finished**

FO-316475	Finished	007-BSG-003	6/1/2015	6/3/2015	False	0.50	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316476	Finished	007-BSG-002	6/1/2015	6/3/2015	False	0.50	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-316477	Finished	007-BSG-001	6/1/2015	8/11/2015	False	1.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317520	Finished	022-AIR-001	6/1/2015	6/2/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.  Checked operation of the unit, checked for any unusual noise and vibration. Checked the belts and sheaves. Drained the main tank. checked the air filter and it was clean. Did not change oil this time, ( it was clear and was changed on last service. Checked operation of the air dryer and cleaned it's coils. checked the moisture and oil trap. Cleaned the equipment.
FO-317568	Finished	096-DWBP-001	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317569	Finished	096-DWBP-002	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317570	Finished	096-DHW-001	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317571	Finished	096-DHW-003	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317572	Finished	096-DHW-004	6/1/2015	6/5/2015	False	1.00	PM - Domestic Water Heater, Electric
FO-317573	Finished	096-DWBP-002	6/1/2015	6/5/2015	False	1.00	PM - Water Booster Pump
FO-317578	Finished	028-AIR-001	6/1/2015	7/24/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.  Checked operation of the unit. Checked oil level it was normal and clean, checked belts,checked air intake filters, drained condensation from air tank. Cleaned the equipment.
FO-317595	Finished	090-WSS-001	6/1/2015	6/1/2015	False	1.00	PM - Water Softener
FO-317597	Finished	090-ACU-403	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317598	Finished	090-ACU-402	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317599	Finished	090-ACU-401	6/1/2015	6/1/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317600	Finished	022-ACU-001	6/1/2015	7/31/2015	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317601	Finished	007-ACU-002	6/1/2015	6/24/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317602	Finished	007-ACU-001	6/1/2015	6/24/2015	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317610	Finished	096-ACU-001	6/1/2015	6/1/2015	False	10.00	PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-317631	Finished	090-BSG-004	6/1/2015	8/10/2015	False	2.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317632	Finished	090-BSG-003	6/1/2015	8/10/2015	False	2.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317633	Finished	090-BSG-002	6/1/2015	8/7/2015	False	40.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317634	Finished	090-BSG-001	6/1/2015	8/10/2015	False	2.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317635	Finished	016-BSG-002	6/1/2015	8/25/2015	False	16.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~  Shut down the boiler and let it cool down opened air vent and drained the boiler. Removed all hand holes and manhole and all inspection plugs and water level control and low and aux. low water cut outs. flushed the water side of tubes. Removed burner assembly and opened front outer door. opened rear door. Punched the tubes. repaired burner refractory and rear door refractory. Got the boiler ready for inspection. Using new gaskets and seals put the boiler back together, closed all hand holes and man hole, and all the plugs. filled up the boiler with soft water up to normal level and checked for any leaks. started up the boiler and warmed it up. informed the A.D. to send crew for flue gas analysis.
FO-317636	Finished	016-BSG-001	6/1/2015	7/3/2015	False	20.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~  Shut down the boiler and let it to cool off, opened, cleaned, repaired and closed the boiler according to PM task sheet. after closing the boiler filled it up with soft water and chemicals up to normal level and started and warmed it up, checked for any leaks. Put the boiler on line as stand by.

## Requested Finished Open WND

% Finished

FO-317652	Finished	028-BSG-001	6/1/2015	5/6/2015	False	0.50	Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
Detroit Boiler com. inspector checked Rands house boiler, it was ok and passed the inspection.							
FO-317974	Finished	096-DWBP-003	6/6/2015	6/18/2015	False	1.00	PM - Clayton Valves for Booster Pumps (UGL)
FO-317975	Finished	096-SP-001	6/6/2015	6/18/2015	False	1.00	PM - Sump Pump
FO-317976	Finished	096-DWBP-003	6/6/2015	6/23/2015	False	1.00	PM - Clayton Valves for Booster Pumps (UGL)
FO-317977	Finished	090-ACU-CR2	6/8/2015	6/16/2015	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-317978	Finished	090-ACU-CR1	6/8/2015	6/19/2015	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-317987	Finished	005-EW-001	6/4/2015	6/16/2015	False	1.00	PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-318468	Finished	096-CFP-003	6/13/2015	6/18/2015	False	1.00	PM - Chemical Feed/Metering Pump/Controller
FO-318482	Finished	007-GEN-001	6/11/2015	6/11/2015	False	0.50	Generator Maintenance, Monthly
FO-318484	Finished	007-GEN-002	6/11/2015	6/11/2015	False	0.50	Generator Maintenance, Monthly
FO-318486	Finished	090-GEN-001	6/16/2015	6/16/2015	False	1.00	Generator Maintenance, Monthly
FO-318498	Finished	090-GEN-002	6/11/2015	6/11/2015	False	1.00	Generator Maintenance, Monthly
FO-319065	Finished	089-GEN-001	6/17/2015	6/23/2015	False	1.00	Generator Maintenance, Monthly
FO-319090	Finished	006-GEN-001	6/18/2015	6/18/2015	False	0.60	Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>113</b>	<b>86</b>	<b>27</b>	<b>0</b>	<b>76%</b>
FO-317521	Finished	001-HEX-001SW	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM, CLEAN AREA.							
FO-317522	Finished	001-HEX-001WM	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM, CLEAN AREA.							
FO-317523	Finished	001-HEX-002SW	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM , CLEAN AREA.							
FO-317524	Finished	001-HEX-002WM	6/1/2015	6/23/2015	False	0.50	PM - Heat Exchanger and Economizer
CHECK SYSTEM , CLEAN AREA.							
FO-317526	Finished	071-ACU-003	6/1/2015	5/26/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-317527	Finished	071-ACU-006	6/1/2015	5/25/2015	False	1.00	PM - Fan Coil/HV/AC Unit
FO-317528	Finished	071-HWP-005	6/1/2015	5/26/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317529	Finished	071-HWP-006	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317530	Finished	071-HWP-007	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317531	Finished	071-HWP-008	6/1/2015	5/27/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317532	Finished	071-HWP-009	6/1/2015	5/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317533	Finished	071-HWP-010	6/1/2015	5/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317534	Finished	071-HWP-011	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317535	Finished	071-HWP-012	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317536	Finished	071-HWP-013	6/1/2015	5/4/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317537	Finished	071-HWP-014	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317538	Finished	071-HWP-015	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317539	Finished	071-HWP-016	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317540	Finished	071-HWP-017	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317541	Finished	071-HWP-018	6/1/2015	5/5/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317542	Finished	071-HWP-019	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317543	Finished	071-HWP-020	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317544	Finished	071-HWP-021	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317545	Finished	071-HWP-022	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)

# Requested Finished Open WND

% Finished

FO-317546	Finished	071-HWP-023	6/1/2015	5/6/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317547	Finished	071-HWP-187	6/1/2015	5/11/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317548	Finished	071-HWP-188	6/1/2015	5/11/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317549	Finished	071-HWP-189	6/1/2015	5/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317550	Finished	071-HWP-190	6/1/2015	5/12/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317551	Finished	071-HWP-191	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317552	Finished	071-HWP-192	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317553	Finished	071-HWP-193	6/1/2015	5/13/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317554	Finished	071-HWP-194	6/1/2015	5/14/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317555	Finished	071-HWP-195	6/1/2015	5/14/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317556	Finished	071-HWP-196	6/1/2015	5/15/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317557	Finished	071-HWP-197	6/1/2015	5/15/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317558	Finished	071-HWP-198	6/1/2015	5/18/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317559	Finished	071-HWP-199	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317560	Finished	071-HWP-200	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317561	Finished	071-HWP-201	6/1/2015	5/19/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317562	Finished	071-HWP-202	6/1/2015	5/20/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317563	Finished	071-HWP-203	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317564	Finished	071-HWP-204	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317565	Finished	071-HWP-205	6/1/2015	5/21/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317566	Finished	071-HWP-215	6/1/2015	5/28/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317567	Finished	071-HWP-216	6/1/2015	5/28/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-317574	Finished	016-SP-003	6/1/2015	6/17/2015	False	1.00	PM - Sump Pump

Checked the operation of the unit. Checked float switch for proper operation. Lubricated motor bearings.  
checked oil level in pump seal cavity and bearing. Checked motor and pump for proper alignment and possible vibration. cleaned the unit.

FO-317575	Finished	016-SP-004	6/1/2015	6/17/2015	False	1.00	PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	------	----------------

Checked the operation of the unit. Checked float switch for proper operation. Lubricated motor bearings.  
checked oil level in pump seal cavity and bearing. Checked motor and pump for proper alignment and possible vibration. cleaned the unit.

FO-317576	Finished	023-SP-001	6/1/2015	6/22/2015	False		PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	--	----------------

Checked operation of the unit, checked it's float switch operation. Lubricated motor bearings, checked pump bearing and seal oil level. checked the motor and pump for alignment . Cleaned the unit.

FO-317577	Finished	023-SP-002	6/1/2015	6/22/2015	False		PM - Sump Pump
-----------	----------	------------	----------	-----------	-------	--	----------------

Checked operation of the unit, checked it's float switch operation. Lubricated motor bearings, checked pump bearing and seal oil level. checked the motor and pump for alignment . Cleaned the unit.

FO-317579	Created By PM Schedule	189-HEX-001	6/1/2015		False		PM - Heat Exchanger and Economizer
-----------	------------------------	-------------	----------	--	-------	--	------------------------------------

FO-317584	Finished	071-HWP-222	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317585	Finished	071-HWP-223	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317586	Finished	071-HWP-224	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317587	Finished	071-HWP-225	6/1/2015	5/29/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	-----------	-------	------	---------------------------------

FO-317588	Finished	071-HWP-226	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317589	Finished	071-HWP-227	6/1/2015	6/1/2015	False	1.00	PM - Heat Pumps (5057 Woodward)
-----------	----------	-------------	----------	----------	-------	------	---------------------------------

FO-317603	Created By PM Schedule	001-ACU-003	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
-----------	------------------------	-------------	----------	--	-------	--	--

FO-317604	Created By PM Schedule	001-ACU-002	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
-----------	------------------------	-------------	----------	--	-------	--	--

FO-317605	Created By PM Schedule	001-ACU-001	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
-----------	------------------------	-------------	----------	--	-------	--	--

## Requested Finished Open WND

% Finished

FO-317607	Created By PM Schedule	189-ACU-003	6/1/2015		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-317608	Created By PM Schedule	609-ACU-002	6/1/2015		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317609	Created By PM Schedule	609-ACU-001	6/1/2015		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-317616	Created By PM Schedule	637-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317617	Created By PM Schedule	637-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317618	Created By PM Schedule	609-BSG-003	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317619	Created By PM Schedule	609-BSG-002	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317620	Created By PM Schedule	609-BSG-001	6/1/2015		False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317637	Created By PM Schedule	001-BSG-002	6/1/2015		False	0.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317638	Finished	001-BSG-001	6/1/2015	7/21/2015	False	32.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
OPEN , CLEAN & CLOSE #1 BOILER.							
FO-317639	Created By PM Schedule	189-BSG-003	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317640	Created By PM Schedule	189-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317641	Created By PM Schedule	189-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317642	Finished	071-BSG-002	6/1/2015	6/23/2015	False	8.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317643	Finished	071-BSG-001	6/1/2015	6/11/2015	False	8.00	Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317644	Created By PM Schedule	070-BSG-001*	6/1/2015		False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317647	Created By PM Schedule	504-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317648	Created By PM Schedule	085-BSG-002	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317649	Created By PM Schedule	085-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317651	Created By PM Schedule	068-BSG-001	6/1/2015		False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317967	Finished	001-CRP-001	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
CHECK OPERATION, CLEAN AREA.							
FO-317968	Finished	001-CRP-002	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
CHECK OPERATION, CLEAN AREA.							
FO-317969	Finished	001-CRP-003	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
CHECK OPERATION, CLEAN AREA.							
FO-317970	Finished	001-CRP-004	6/6/2015	6/29/2015	False	0.50	PM - Condensate Return Pump
CHECK OPERATION , CLEAN AREA.							
FO-317972	Created By PM Schedule	070-CRS-001*	6/5/2015		False		PM - Condensate Return Pump
FO-317973	Created By PM Schedule	070-CRS-002*	6/5/2015		False		PM - Condensate Return Pump

**Requested Finished Open WND**

**% Finished**

FO-317984	Finished	001-EW-001	6/4/2015	6/18/2015	False	0.50	PM - Emergency Shower/Eyewash Station - Annual Flow Test perform flow test
FO-317985	Finished	001-EW-002	6/4/2015	6/18/2015	False	0.50	PM - Emergency Shower/Eyewash Station - Annual Flow Test PERFORMED FLOW TEST.
FO-317986	Finished	001-EW-003	6/4/2015	6/18/2015	False	0.50	PM - Emergency Shower/Eyewash Station - Annual Flow Test performed flow test.
FO-318477	Created By PM Schedule	499-CFP-001	6/15/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-318478	Created By PM Schedule	499-CFP-002	6/15/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-318479	Created By PM Schedule	499-CFP-003	6/15/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-318480	Created By PM Schedule	499-CFP-004	6/15/2015		False		PM - Chemical Feed/Metering Pump/Controller
FO-318489	Finished	637-GEN-001	6/16/2015	6/18/2015	False		Generator Maintenance, Monthly checked fluids and battery
FO-318491	Finished	637-GEN-002	6/16/2015	6/18/2015	False		Generator Maintenance, Monthly checked fluids and battery
FO-319214	Finished	016-CRP-001	6/20/2015	7/2/2015	False	1.00	PM - Condensate Return Pump Checked operation of the unit, checked for any leaks, checked for any vibration and unusual noise. Checked the float switch operation. Cleaned the unit.
FO-319215	Finished	016-CRP-002	6/20/2015	7/2/2015	False	1.00	PM - Condensate Return Pump Checked operation of the unit, checked for any leaks, checked for any vibration and unusual noise. Checked the float switch operation. Cleaned the unit.
FO-319216	Finished	001-AHU-001	6/20/2015	7/16/2015	False	0.75	PM - Outside/Fresh Air Intake Screens CLEAN INTAKE SCREENS.
FO-319217	Finished	001-AHU-001O	6/20/2015	7/15/2015	False	0.75	PM - Outside/Fresh Air Intake Screens CLEAN AIR INTAKE SCREENS.
FO-319218	Finished	001-AHU-002	6/20/2015	7/16/2015	False	0.50	PM - Outside/Fresh Air Intake Screens CLEAN INTAKE SCREENS
FO-319219	Finished	001-AHU-002O	6/20/2015	7/15/2015	False	0.75	PM - Outside/Fresh Air Intake Screens CLEANING INTAKE SCREENS.
FO-319220	Finished	001-AHU-003O	6/20/2015	7/22/2015	False	1.00	PM - Outside/Fresh Air Intake Screens CLEAN AIR INTAKES.
FO-319221	Finished	001-AHU-004O	6/20/2015	7/22/2015	False	1.00	PM - Outside/Fresh Air Intake Screens CLEAN AIR INTAKES.
FO-319222	Finished	001-AHU-001	6/20/2015	8/11/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION, LUBE DAMPERS.
FO-319223	Finished	001-AHU-001O	6/20/2015	8/11/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE DAMPERS.
FO-319224	Finished	001-AHU-002	6/20/2015	8/11/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION , LUBE UNIT.
FO-319225	Finished	001-AHU-002O	6/20/2015	8/11/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE UNIT.
FO-319226	Finished	001-AHU-003O	6/20/2015	7/30/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE.
FO-319227	Finished	001-AHU-004O	6/20/2015	7/30/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE.



**Requested Finished Open WND**

**% Finished**

FO-319228	Finished	001-AHU-PRIM	6/20/2015	7/30/2015	False	0.50	PM - Outside/Fresh Air Intake Screens clean screens.
FO-319229	Finished	001-AHU-PRIM	6/20/2015	7/30/2015	False	0.50	PM - Air Intake Dampers (Old Main) CHECK OPERATION & LUBE.
FO-319643	Finished	071-EXF-001	6/27/2015	6/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319644	Finished	071-EXF-002	6/27/2015	6/29/2015	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
<b>E - West</b>			<b>23</b>	<b>23</b>	<b>0</b>	<b>0</b>	<b>100%</b>
FO-317525	Finished	155-HEX-001	6/1/2015	7/15/2015	False		PM - Heat Exchanger and Economizer
FO-317580	Finished	155-WFP-001	6/1/2015	7/1/2015	False		PM - Centrifugal Pump, over 1 H.P.
FO-317583	Finished	080-AIR-003	6/1/2015	7/27/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-317621	Finished	510-BSG-002	6/1/2015	8/28/2015	False	0.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317622	Finished	510-BSG-001	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317623	Finished	166-BSG-002	6/1/2015	6/15/2015	False	8.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~ Prepare boiler for inspection, remove all plugs and low water cut outs. Opened fire side and removed burner to combustion chamber.
FO-317624	Finished	166-BSG-001	6/1/2015	6/15/2015	False	8.00	Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~ Prepared boiler for inspection by removing all plugs and low water cutouts an removing fire side doors and burner to expose and inspect burner and combustion chamber.
FO-317625	Finished	155-BSG-002	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317626	Finished	155-BSG-001	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - High Pressure Boilers ~ Required Annually ~
FO-317645	Finished	003-BSG-002	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317646	Finished	003-BSG-001	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - Low Pressure Steam Boilers ~ Required Every 2 Yrs ~
FO-317650	Finished	078-BSG-001	6/1/2015	8/28/2015	False		Boiler Inspection Preparation - Hot Water Boilers ~ Required Every 3 Yrs ~
FO-317971	Finished	167-DHW-001	6/8/2015	6/10/2015	False	2.00	PM - Domestic Water Heater, Gas Inspected water heater, checked for leaks and wiped tank down. Used lase temp probe to check for accuracy of tank sensor. Tank 2F off of laser probe.
FO-317988	Finished	001 SPARE from	6/9/2015	6/11/2015	False		Generator Maintenance, Monthly
FO-318469	Finished	169-AHU-001	6/15/2015	6/30/2015	False		PM - Water/Air Cooled Condenser
FO-318470	Finished	169-AHU-002	6/15/2015	7/6/2015	False	2.00	PM - Water/Air Cooled Condenser Cleaned condenser, checked belts on RTU, inspected unit for leaks.
FO-318471	Finished	169-AHU-003	6/15/2015	7/6/2015	False	2.00	PM - Water/Air Cooled Condenser Cleaned condenser, inspected belts and checked for leaks.
FO-318472	Finished	169-AHU-004	6/15/2015	7/6/2015	False	2.00	PM - Water/Air Cooled Condenser Cleaned condenser coil, inspected belts and checked for leaks.
FO-318473	Finished	169-AHU-005x	6/15/2015	7/6/2015	False	2.00	PM - Water/Air Cooled Condenser Inspected unit, brand new, gave associate director filter size and serial number.
FO-318474	Finished	169-AHU-006x	6/15/2015	7/6/2015	False	1.00	PM - Water/Air Cooled Condenser Cleaned condenser, inspected unit and belts, checked for leaks.

**Requested Finished Open WND**

**% Finished**

FO-318475	Finished	169-AHU-007	6/15/2015	7/7/2015	False	1.00	PM - Water/Air Cooled Condenser
Cleaned condenser, inspected belts and checked for leaks.							
FO-318476	Finished	169-AHU-008	6/15/2015	7/7/2015	False	1.00	PM - Water/Air Cooled Condenser
Inspected brand new unit and gave filter sizes and serial number to associate director and checked for any signs of leaks.							
FO-319092	Finished	169-GEN-001	6/25/2015	6/29/2015	False		Generator Maintenance, Monthly

<b>Trades</b>	<b>43</b>	<b>38</b>	<b>5</b>	<b>0</b>	<b>88%</b>
---------------	-----------	-----------	----------	----------	------------

<b>T - Electrician</b>	<b>38</b>	<b>34</b>	<b>4</b>	<b>0</b>	<b>89%</b>
------------------------	-----------	-----------	----------	----------	------------

FO-317962	Created By PM Schedule	608-GEN-001	6/5/2015		False		Generator Maintenance, Monthly
FO-317979	Finished	193-GEN-001	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317980	Finished	501-GEN-001	6/9/2015	6/9/2015	False	4.00	Generator Test Tuesday 6/9/2015 @ 1PM.
FO-317982	Finished	608-GEN-001	6/5/2015	6/2/2015	False	4.00	Generator Test Tuesday 6/2/2015 @ 7:15AM.
FO-317989	Finished	193-GEN-002	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317990	Finished	193-GEN-003	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-317991	Finished	193-GEN-004	6/5/2015	6/4/2015	False	1.00	Generator Test Friday 6/5/2015 @ 2:15PM.
FO-318456	Created By PM Schedule	612-GEN-001	6/12/2015		False		Generator Maintenance, Monthly
FO-318457	Created By PM Schedule	612-GEN-002	6/12/2015		False		Generator Maintenance, Monthly
FO-318481	Finished	609-GEN-001	6/16/2015	6/16/2015	False	4.00	Generator Test Tuesday 6/16/2015 @ 7:15AM.
FO-318483	Finished	007-GEN-001	6/11/2015	6/11/2015	False	2.00	Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318485	Finished	007-GEN-002	6/11/2015	6/11/2015	False	2.00	Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318487	Finished	090-GEN-001	6/16/2015	6/16/2015	False	4.00	Generator Test Tuesday 6/16/2015 @ 9:30AM.
FO-318488	Finished	637-GEN-001	6/16/2015	6/16/2015	False		Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318490	Finished	637-GEN-002	6/16/2015	6/16/2015	False	2.00	Generator Test Tuesday 6/16/2015 @ 8:15AM.
FO-318492	Finished	612-GEN-001	6/12/2015	6/9/2015	False	2.00	Generator Test Tuesday 6/9/2015 @ 7:15 AM.
FO-318493	Finished	612-GEN-002	6/12/2015	6/9/2015	False	4.00	Generator Test Tuesday 6/9/2015 @ 7:15AM.
FO-318494	Finished	507-GEN-001	6/10/2015	6/10/2015	False	4.00	Generator Test Wednesday 6/10/2015 @ 1PM.
FO-318496	Finished	203-GEN-001	6/16/2015	6/16/2015	False	4.00	Generator Test Tuesday 6/16/2015 @ 9:15AM.
FO-318497	Finished	090-GEN-002	6/11/2015	6/11/2015	False	4.00	Generator Test Thursday 6/11/2015 @ 7:15AM.
FO-318500	Finished	048-GEN-001	6/12/2015	6/12/2015	False	4.00	Generator Test Friday 6/12/2015 @ 7:15AM.
FO-318501	Finished	001 SPARE from	6/12/2015	6/9/2015	False	4.00	Generator Test Tuesday 6/9/2015 @ 7:15AM.
FO-319066	Finished	089-GEN-001	6/17/2015	6/17/2015	False	4.00	Generator Test Wednesday 6/17/2015 @ 10AM.
FO-319068	Finished	066-GEN-001	6/24/2015	6/24/2015	False	4.00	Generator Test Wednesday 6/24/2015 @ 7:15AM
FO-319069	Finished	611-GEN-001	6/26/2015	6/23/2015	False	4.00	Generator Test Tuesday 6/23/2015 @ 7:15AM
FO-319071	Finished	629-GEN-001	6/26/2015	6/23/2015	False	4.00	Generator Test Tuesday 6/23/2015 @ 10AM
FO-319073	Finished	104-GEN-001	6/23/2015	6/23/2015	False	4.00	Generator Test Tuesday 6/23/2015 @ 10AM
FO-319075	Finished	127-GEN-001	6/23/2015	6/23/2015	False	1.00	Generator Test Tuesday 6/23/2015 @ 8AM
FO-319077	Finished	127-GEN-002	6/23/2015	6/23/2015	False	1.00	Generator Test Tuesday 6/23/2015 @ 8AM
FO-319079	Finished	127-GEN-003	6/23/2015	6/23/2015	False	1.00	Generator Test Tuesday 6/23/2015 @ 8AM
FO-319081	Finished	127-GEN-004	6/23/2015	6/23/2015	False	1.00	Generator Test Tuesday 6/23/2015 @ 8AM
FO-319083	Finished	130-GEN-001	6/24/2015	6/24/2015	False	4.00	Generator Test Wednesday 6/24/2014 @ 7:15AM
FO-319085	Finished	536-GEN-001	6/17/2015	6/17/2015	False	4.00	Generator Test Wednesday 6/17/2015 @ 7:15AM.

Completed 6-17-2015 SRP

**Requested Finished Open WND**

**% Finished**

FO-319087	Finished	527-GEN-001	6/18/2015	6/18/2015	False	4.00	Generator Test Thursday 6/18/2015 @ 7:15AM.
FO-319089	Finished	006-GEN-001	6/18/2015	6/18/2015	False	4.00	Generator Test Thursday 6/18/2015 @ 7:15AM.
FO-319091	Finished	169-GEN-001	6/25/2015	6/25/2015	False	4.00	Generator Test Thursday 6/25/2015 @ 7:15AM
FO-319093	Completed	060-GEN-001A	6/25/2015		False	2.00	Generator Test Thursday 6 25/2015 @ 1PM
FO-319095	Finished	060-GEN-001B	6/25/2015	6/24/2015	False	4.00	Generator Test Wednesday 6/24/2015 @ 9:30AM
This is the generator on the roof.							
<b>T - Plumber</b>			<b>5</b>	<b>4</b>	<b>1</b>	<b>0</b>	<b>80%</b>
FO-316083	Finished	042	6/1/2015	6/12/2015	False	2.00	PM - Main Drain with Copper Sulfate,,,,,,,,,,,,, DB/6-1-15 ,,,,,,,,,
FO-316084	Finished	527	6/1/2015	6/1/2015	False		*CANCELLED THIS MONTH JWT
PM - Main Drain with Copper Sulfate							
FO-316085	Not Finished	608	6/1/2015		False	5.00	PM - Waterless Urinals ,,,,,,,,,, MM/6-1-15 ,,,,,,,,,
FO-316086	Finished	049	6/1/2015	6/1/2015	False		*CANCELLED THIS MONTH JWT
PM - Waterless Urinals							
FO-316087	Finished	090	6/1/2015	6/1/2015	False		*CANCELLED THIS MONTH JWT
PM - Waterless Urinals							
<b>Report Total</b>			<b>630</b>	<b>474</b>	<b>76</b>	<b>80</b>	<b>75%</b>