

# Facilities Operations Work Orders Received 7/1/16 through 7/31/16

WO	Recieved	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1479</b>	
<b>Custodial</b>			<b>217</b>	
<b>Emergency</b>			<b>1</b>	
<b>C-Director</b>			<b>1</b>	
FO-353010	7/25/2016			ADDING CUST FOR CLEAN UP WDET NEWS RM HAS WATER IS STILL COMING DOWN FROM FRIDAY'S PROBLEM WORST THAN FRIDAY NOTE: NEWLY RENOVATED AREA CLNG TILES ARE WATER DAMAGED & SOME HAVE FALLEN, CARPET WATER DAMAGED, ETC)
<b>High</b>			<b>5</b>	
<b>C-Lighting</b>			<b>3</b>	
FO-351967	7/11/2016	7/12/2016		There is a light out in the "Vohm" area of the building - the area between the front lobby and the auditorium. Needs task completed as soon as possible, as they have a performance later today.
FO-352064	7/12/2016			Lab space, room # 006.10 Please replace burned out florescent light tubes.
FO-352830	7/21/2016	7/22/2016		SECOND REQUEST - MUST GO DURING BUSINESS HOURS - Room 0504.08 - LO.
<b>C-Materials</b>			<b>1</b>	
FO-352373	7/18/2016	7/19/2016		4th fl - Hudson-Webber Building - Please drop off 3 recycling bins and pick up 2 full recycling bins.
<b>C-Repair</b>			<b>1</b>	
FO-352972	7/22/2016			Requested by Houle on behalf of Medical School. Please assemble 2 hand sanitizers dispenser stands and insure operable-ability. Inform Houle when complete for transfer to School of Medicine. Need on Monday, July 25, 2016.
<b>Low</b>			<b>211</b>	
<b>C-Director</b>			<b>1</b>	
FO-352928	7/22/2016			2 boxes of "D" batteries.
<b>C-Lighting</b>			<b>76</b>	
FO-351363	7/1/2016	7/14/2016		Relamp Light Fixture
FO-351369	7/1/2016	7/6/2016		Third Floor of College of Education Building has lights out in the staff/clerical area. Contact Sheri Martini if further details are needed (577-1614).
FO-351632	7/5/2016	7/6/2016		8 fluorescent light bulbs replaced in Chemistry Building room 053. They cannot enter the room without the lab manager
FO-351690	7/6/2016	7/8/2016		Please replace burned out lights in room 0115.
FO-351725	7/6/2016	7/8/2016		Ceiling lights outside 2314 have burned out and need to be replaced. Thank you, Susan DLAR
FO-351726	7/6/2016			two lights out in main office space.
FO-351776	7/7/2016	7/15/2016		Room 1328 - Lights are flickering on and off.
FO-351796	7/7/2016	7/8/2016		Basement - North Stairwell - 2 LO
FO-351797	7/7/2016	7/13/2016		Lobby - 3 out of 6 fixtures are half blown.
FO-351798	7/7/2016	7/8/2016		Basement, room 002 - 3 LO
FO-351800	7/7/2016	7/8/2016		Stairwell between mezzanine and 1st fl - 1 flood light out.
FO-351802	7/7/2016	7/13/2016		two lights died one month ago, the bulb were changed but didn't work yet. Please send an electrician to fix this problem. thank you.
FO-351807	7/7/2016	7/12/2016		Recessed round ceiling light is out, just outside Ladies Room (1134) and Janitor closet and mechanical room
FO-351926	7/11/2016	7/13/2016		Room 2100 - Spot light on the painting is out.
FO-351935	7/11/2016	7/12/2016		2 lights out on first floor in the north east stair way near room 150
FO-351942	7/11/2016	7/13/2016		Light Changers, please change bulbs in basement Ladies restroom.
FO-351949	7/11/2016	7/13/2016		Elevator 3 (passenger) lights on the inside of the elevator that are out and need to be replaced.
FO-351964	7/11/2016	7/15/2016		REPLACE BURNT OUT CLNG LITES 2ND FLR SUPERVISORS' WOMENS LOCKER RM HAS NO CLNG LITES BREAKER CK'D BY ENGINEER ALREADY NOTE GO TO DISPATCH SEE SHIFT SUPERVISOR FOR ACCESS

WO	Recieved	Finished	Total	Request
FO-352024	7/11/2016	7/12/2016		Florescent lights need to be replaced. Thanks
FO-352189	7/13/2016	7/14/2016		Stairwell A - 2nd fl - 2 LO
FO-352208	7/14/2016	7/15/2016		3rd floor Ladies restroom has a light fixture that needs to be put back on the ceiling light above the faucet. Fixture is up against the wall. (LIGHT COVER)
FO-352274	7/14/2016	7/15/2016		Relam the following MD Labs: Fixtures are identified at entry door , starting from the left. MD Lab 2116 - inner lab relamp one fixture. MD Lab 2136: 1st row , 1st fixture 4th row, 1st & 3rd fixtures 5th row,
FO-352291	7/15/2016	7/15/2016		Lights need to be replaced in the first floor Ladies' Rooms. Room #s 033 and 035.
FO-352356	7/16/2016	7/18/2016		Room inside Lab 1530 needs a light bulb replacement.
FO-352357	7/16/2016	7/18/2016		Room inside Lab 1536 (attached to office 1530) needs a light bulb replacement.
FO-352360	7/17/2016	7/20/2016		Burnt out light in the 1st floor women's restroom.
FO-352377	7/18/2016	7/18/2016		President's Place - Kitchen light out & additional lights out.
FO-352386	7/18/2016	7/20/2016		322.09 Unisex Bathroom. Light over sink is out.
FO-352404	7/18/2016	7/19/2016		Rom 314 - 1 LO
FO-352405	7/18/2016	7/19/2016		3rd fl - Women's R/R - LO
FO-352418	7/18/2016	7/18/2016		Room 307 - 2 LO
FO-352415	7/18/2016	7/19/2016		Light bulb is strobing and creating a problem for lady sitting underneath the light. Can we have someone remove the bulb today.
FO-352427	7/18/2016	7/19/2016		Room 5374 - Flickering light bulb
FO-352424	7/18/2016	7/19/2016		Lights are flickering in Room 5374 - School of Medicine. Please replace.
FO-352422	7/18/2016	7/19/2016		Old Main, Stairwell E, between floor 1 and 2:  Ceiling lights blinking rapidly, like a strobe light.
FO-352640	7/19/2016	7/21/2016		Lighting crew- office 310.1 has light bulbs that need replaced.
FO-352650	7/19/2016	7/14/2016		Room 310.1 - Several burnt out light bulbs - Please replace.
FO-352678	7/19/2016	7/21/2016		replace several lamps that are not working in several rooms and hall of the office area
FO-352679	7/19/2016	7/22/2016		replace lamp that is not working in hall by the mens room
FO-352692	7/19/2016	7/20/2016		Light Changers, please replace bulbs in room 48.2.
FO-352694	7/19/2016	7/20/2016		two lights died, please help us with this.
FO-352787	7/20/2016	7/21/2016		MD Lab 2106 Relamp light fixture row 5, fixture 4 ; Md Lab 2115 - Inner Lab - re lamp 1 fixture; MD Lab 2125 - Row 4 relamp fixture 2 - 1 lamp; Row 5 relamp fixtre 5 - 1 lamp; MD Lab 2228 Row 2 Relamp fixture 2 - 1 lamp.
FO-352789	7/20/2016	7/21/2016		INSIDE STE 1300 REPLACE BURNT OUT Lighting in men's restroom needs replacing. NOTE: Fund auditing taking place 7/28/16. Work needs to be completed by 7/27/16.
FO-352790	7/20/2016	7/22/2016		RM 1200 REPLACE BURNT OU Lighting needs replacing above sled. NOTE: Fund auditing taking place 7/28/16. Work needs to be completed by 7/27/16.
FO-352795	7/20/2016	7/21/2016		Relamp two recessed light fixtures located in the vending area.
FO-352884	7/21/2016	7/22/2016		Light crew: please replace burned out ceiling light in south stairway. priority: low.
FO-352887	7/21/2016	7/27/2016		Relamp Room lighting fixtures as needed.
FO-352959	7/22/2016	7/26/2016		Room 117 - 3 of 9 fixtures need attention.
FO-352962	7/22/2016	7/25/2016		Between Men and Women's restroom on 1st fl - 2 fixtures out.
FO-352963	7/22/2016	7/25/2016		Cass side of the building - 2nd fl of ladies room.
FO-352964	7/22/2016	7/25/2016		Stair 4, exit 3 - 2 fixtures out.
FO-353019	7/25/2016	7/26/2016		Room 503 - 1 panel, 2 LO
FO-353020	7/25/2016	7/26/2016		Hallways near 509 - 1 panel, 2 LO.

WO	Recieved	Finished	Total	Request
FO-353029	7/25/2016	7/25/2016		Light in hallway in front of office needs to be replaced or tightened. It is currently flickering and dim.
FO-353070	7/25/2016	7/28/2016		Request for services to light bulb outages in the Library atrium(20), Open Study Area (7 bulbs, 5 recess lights,) over service desk top deco lights.  Thank you YR
FO-353072	7/25/2016	7/26/2016		3rd floor hall, there is a light flickering in front of the men's restroom that needs repair.
FO-353202	7/26/2016	7/29/2016		Gallery Room 328 - Missing a light.
FO-353205	7/26/2016	7/27/2016		Light Out in Office 203
FO-353206	7/26/2016	7/27/2016		Light out in suite 206 in front of exam room 7
FO-353211	7/26/2016	7/27/2016		Replace lamps infollowing class rooms ; Rm. 241- 1 lamp; Rm.242 - 1 lamp; R303 - 1 lamp; Rm.304 - 1 lamp; Rm305 - 1 lamp; Rm306 - 1 lamp; Rm.307 - 1 lamp; Rm. 308 - 1 lamp.
FO-353231	7/26/2016	7/27/2016		RM 101/conference room #3, at the front of the building. There is a light that needs to be replaced in the conference room.
FO-353250	7/26/2016	7/27/2016		Lights Out in Room 5324 - Fifth Floor of Scott Hall. Please replace.
FO-353309	7/27/2016	7/29/2016		Lighting crew-please change bulbs in 4th floor records room. Several tubes required
FO-353319	7/27/2016	7/29/2016		Rm. 3148 has a light out that needs to be replaced.
FO-353359	7/28/2016			Lights out. Please replace.Thank youDawn C.
FO-353360	7/28/2016			Rear entry by stairwell & door. Lights out.Please replace.Thank you.Dawn C.
FO-353361	7/28/2016			This is the break/lunch room.Lights out, please replace.
FO-353364	7/28/2016			Several lights out in hallway, please replace.
FO-353365	7/28/2016			Real Room Number 39.1. Lights out, please replace.
FO-353366	7/28/2016			Real Room Number 39.0. Lights out, please replace.
FO-353367	7/28/2016			Lights out, please replace.
FO-353368	7/28/2016			Real Room number 056.2. Lights out, please replace.
FO-353369	7/28/2016			Lights out, please replace.
FO-353370	7/28/2016			Lights out, please replace.
FO-353400	7/28/2016	7/29/2016		Main lobby - spotlight out over artwork.
FO-353432	7/29/2016	7/29/2016		Two Candelabra lights are out in the first floor lobby. Please replace.
<b>C-Materials</b>			<b>12</b>	
FO-351367	7/1/2016	7/7/2016		can you please remove and replace recycle bin in copy room 3304
FO-351779	7/7/2016	7/7/2016		Needs two Recycle Bins placed in the hallway near Suite 3094 - Faculty Administration Building.
FO-352056	7/12/2016	7/13/2016		Room 3094, hallway - 2 recycling bins need to be picked up and replaced.
FO-352188	7/13/2016	7/25/2016		3 Recycling bins picked up and replaced: 1 bin - 2nd fl hallways 1 bin - basement hallway 1 bin - Room 1360
FO-352269	7/14/2016	7/25/2016		Please empty recycle bin and replace.
FO-352674	7/19/2016	7/25/2016		Room 2155 - 1 recycling bin to be picked up and replaced.
FO-352733	7/20/2016	7/25/2016		1 Recycling bin to be picked up outside of room 4374.
FO-352734	7/20/2016	7/25/2016		Please pick up all extra recycling bins on 1st floor and 3rd floor.
FO-352744	7/20/2016	7/25/2016		Outside 3094 (hallway) - 2 recycling bins to be picked up and replaced.
FO-353022	7/25/2016	7/27/2016		Room 2108/work-room area - Pick up and replace recycling bin.
FO-353069	7/25/2016	7/27/2016		Room 3178 - Pick up and replace recycling bins.
FO-353330	7/27/2016	7/28/2016		4th fl hallway - please pick up and replace 3 recycling bins.
<b>C-Projects</b>			<b>4</b>	

WO	Recieved	Finished	Total	Request
FO-352094	7/12/2016	7/13/2016		Suite 2490 (Simulation Rm.) the floors need to be cleaned and waxed before the start of the new semester. Also, C2 pipeline students will be coming this Thursday, 7/14/16, if it could be swept prior to this Thursday. ***SEE RESULTS***
FO-352095	7/12/2016			Rm. 1233 (ADL Lab) the floor needs to be cleaned and waxed prior to the start of new semester.
FO-352340	7/15/2016			Floor needs scrubbing and waxing. CANCEL WORK ORDER PER DELORES COWEN.
FO-352342	7/15/2016			Floor needs stripping and waxing.
<b>C-Repair</b>			<b>28</b>	
FO-351592	7/5/2016	7/14/2016		Second floor men's bathroom spring hanging out of the towel dispenser
FO-351902	7/8/2016	7/14/2016		1st floor ladies restroom's 1st hand soap dispenser is broken and need repair.
FO-352026	7/12/2016	7/14/2016		Men's restroom 1st floor broken roll towel dispenser (broken spring)
FO-352166	7/13/2016	7/18/2016		The toilet paper dispenser in the 1st floor men's room is broken.
FO-352178	7/13/2016	7/14/2016		2nd floor Old main, Women's restroom: Third stall needs tissue dispenser.
FO-352179	7/13/2016	7/14/2016		2nd floor of Old Main: Women's restroom #2126,tissue paper dispenser needed.
FO-352193	7/14/2016	7/14/2016		The 2nd floor unisex restroom paper towel dispenser off the wall needs new 1
FO-352254	7/14/2016	7/18/2016		Women's 2nd floor restroom has a toilet tissue dispenser broken off of the 5th stall's wall that needs repair.
FO-352284	7/14/2016	7/18/2016		The soap dispenser in the 1st floor men's room is broken.
FO-352363	7/18/2016	7/18/2016		Front tire needs replaced on custodian cart.
FO-352423	7/18/2016	7/19/2016		Need two new Paper towel holders in both Men restrooms on the first floor. The ones in there seem to be broken.
FO-352652	7/19/2016	7/20/2016		BROKEN SOAP DISPENSERS IN BOTH 2ND FLOOR MEN'S RESTROOMS. (2 TOTAL)
FO-352779	7/20/2016	7/22/2016		4th floor women restroom paper towel dispenser handle broken.
FO-352780	7/20/2016	7/22/2016		4th floor mens restroom left soap dispenser broken
FO-352794	7/20/2016	7/22/2016		RM 1200 Paper towel dispenser needs to be installed next to sink near ballistics area. NOTE: Fund auditing taking place 7/28/16. Work needs to be completed by 7/27/16.
FO-352798	7/21/2016	7/22/2016		One of the soap dispensers in the ladies room on the 2nd floor restroom 210 is broken.
FO-352801	7/21/2016	7/22/2016		Next to room 1200 needs paper towel see Gena Fry.
FO-352825	7/21/2016	7/22/2016		Women's Rest Room Papertowel dispenser isn't working, please replace. Toilet seat in 1st stall is loose and needs repair.
FO-352826	7/21/2016	7/22/2016		Men's Rest Room Soap dispenser is broken off the wall, please repair.
FO-352890	7/22/2016	7/22/2016		Transport carpet extractor to Simons bldg & return today (7/22/16) at 11 a.m.
FO-353131	7/26/2016	7/26/2016		I need a (9-V), Battery to replace the bad battery in the (Digital, Multimeter) tester tool.
FO-353217	7/26/2016	7/28/2016		Vacuum will not charge.  Make:Nobles/ model #Scout 24 614231  Vacuum locate near time clock, behind stair well, across from restrooms.
FO-353221	7/26/2016			Repair needed for Advance Convertamatic # 1981773 located in Basement rm 0325. The center rear wheel is "froze" up, leaves marks on the floor.
FO-353225	7/26/2016			Paper towel holders broken in womens restrooms 3126 & 3342. 3rd floor Old Main
FO-353232	7/26/2016	7/27/2016		RM 113/WOMENS RR ON VENDING MACHINE HALLWAY WISE 1ST SOAP DISPINSER IS BROKEN
FO-353261	7/27/2016			Auto Scrubber: Sc1500 x20D/ Serial: 361016308196. Crack in the drain hose in the back. Leaks when vacuum is turned off. room# 1203
FO-353349	7/28/2016			nobles/GU12SMU Serial#090200293. Vacuum has very low suction power and kick stand is broken. Vacuum bag is removed. Danto Engineering 2nd Floor #2517.
FO-353362	7/28/2016	7/28/2016		7:48am, A request to transfer Supervisor's State work van (Dodge) #104657, Fuel/Station for refill of gas .

WO	Recieved	Finished	Total	Request
<b>C-Sector 01</b>			<b>7</b>	
FO-351693	7/6/2016	7/15/2016		We would like to schedule a floor mop and re-waxing for next week. Any morning will work since we will be running a summer camp and the room will be vacant. This also will include all of the interior rooms from the main lab.  Task is complete.
FO-352835	7/21/2016			12 D batteries for the hand sanitizers in sector 1.
FO-352872	7/21/2016			2 cases of dial soap.
FO-352875	7/21/2016			2 cases of dial soap.
FO-352876	7/21/2016			2 cases of dial soap.
FO-352880	7/21/2016			2 cases of dial soap.
FO-352881	7/21/2016			2 cases of dial soap.
<b>C-Sector 02</b>			<b>11</b>	
FO-351784	7/7/2016			Suite 2190 (Pharm Practice) needs carpet shampooed. Also shampoo conference Rm. 2140 and office 2134 and 2144 within the same suite. At least a day or 2 advance notice will be helpful.
FO-351793	7/7/2016			Please shampoo carpets in common areas (hallways) on the second and third floors. Must be completed before July 25 when classes start fall term. Can be done during daytime or evening hours. Please contact Krista Mitchell to schedule dates.
FO-351847	7/8/2016			Clean the carpeting in student lounge rooms 146 & 146.1.
FO-352147	7/13/2016			Rm. 1341 needs the floor stripped and waxed. There is ground in dirt on the floor that will not come up with regular mopping.
FO-352643	7/19/2016			4 cases of dial soap.
FO-352644	7/19/2016			3 cases of dial soap.
FO-352645	7/19/2016			2 cases of dial soap.
FO-352646	7/19/2016			3 cases of dial soap.
FO-352647	7/19/2016			2 boxes of white rags.
FO-353037	7/25/2016			Strip & wax Dr. Mueller's office inside room 5263 Scott Hall during the week of 8/8 while he is on vacation. Contact Joanne Kaiser in room 5374 Scott Hall to schedule work and for access to room. Her phone number is 7-6744.
FO-353043	7/25/2016	7/19/2016		Per Anthony M lab 340 was scrub & waxed in the basement. Per S.Johnson
<b>C-Sector 03</b>			<b>2</b>	
FO-352701	7/19/2016	7/26/2016		3 cases of dial soap.
FO-353248	7/26/2016			The Chair, Prof. Stephen J. Spurr, has asked that the carpet in the hallway (in front of 2150 FAB until the two double doors) needs to be cleaned badly. There are very big stains that must be removed. This same request was made previously but nothing w
<b>C-Sector 04</b>			<b>7</b>	
FO-352324	7/15/2016			Carpet cleaning. Terrible shape... please call or see Chris in room 3121 for room access.
FO-352334	7/15/2016	7/19/2016		1 case of dial soap.
FO-352335	7/15/2016	7/19/2016		2 cases of dial soap.
FO-352336	7/15/2016	7/19/2016		1 case of dial.
FO-352971	7/22/2016			The carpet needs to be cleaned in office 2118, it looks like someone spilled coffee on the floor.
FO-353046	7/25/2016			This is a blanket request to have the lunch rooms/lounge/kitchen areas of the listed floors cleaned/scrubbed/shampooed. 3rd, 4th, 9th, 10th, 13th, and 14th. Some areas are tiled and some are carpeted.
FO-353403	7/28/2016			please vacuum and deodorize the carpet at reception desk area at room 441.
<b>C-Sector 05</b>			<b>8</b>	
FO-351698	7/6/2016	7/15/2016		contact: Angela Windfield contact_email: jayangela@wayne.edu contact_ph: 7-2943 desired_date: 07/23/2016 funding_source: 127211 funding_year: 2016 has_this_been_submitted_before: ON preferred_billing_method: IRB project_description: Please vacuum

WO	Recieved	Finished	Total	Request
FO-352654	7/19/2016	7/20/2016		3 cases of dial soap.
FO-352655	7/19/2016	7/20/2016		3 cases of dial soap/
FO-352656	7/19/2016	7/20/2016		3 cases of dial soap.
FO-352657	7/19/2016	7/20/2016		2 cases of dial soap.
FO-352659	7/19/2016	7/20/2016		3 cases of dial soap.
FO-352660	7/19/2016	7/20/2016		2 boxes of white rags.
FO-352672	7/19/2016	7/20/2016		Can you please clean the carpets in room 553 (Journalism Office) and Rm 560 (Journalism Library).
<b>C-Sector 06</b>			<b>10</b>	
FO-351675	7/6/2016	7/19/2016		Spot/Whole carpet cleaning 1st floor hallway, near Einstein cart
FO-351676	7/6/2016			Spot/Whole carpet cleaning 2nd floor hallway, near DJK Center elevator
FO-351687	7/6/2016	7/18/2016		Spot/Whole carpet cleaning 1st Clinics offices (All Offices)
FO-352027	7/12/2016			Strip & wax all landings.
FO-352028	7/12/2016			Strip & wax all landings.
FO-352116	7/13/2016	7/28/2016		Needs four boxes of white rags.
FO-352414	7/18/2016			Please Shampoo Room 3109 the week of August 1st. The person will be on vacation during that time period and would like the shampoo job to be done before returning.Thanks so Much!
FO-352737	7/20/2016	7/29/2016		Strip & wax corridors on 4th floor.
FO-352774	7/20/2016	7/21/2016		1 roll of caution tape 1 roll of painters tape 1 box of rags 1 extension cord
FO-353282	7/27/2016	7/28/2016		4 boxes of white rags.
<b>C-Sector 07</b>			<b>9</b>	
FO-351377	7/1/2016	7/21/2016		Carpet cleaning in suite complex 5018 5019 and inner offices within that complex. Vacuum and shampoo carpet.
FO-351388	7/1/2016			Custodial-carpet cleaning Ground/movers
FO-351610	7/5/2016	7/6/2016		Trash has not been picked up since 6/10 and is overflowing in the reception area. Please send someone to collect and remove trash and to inspect the rest of the building to ensure proper custodial services have been performed.
FO-352343	7/15/2016			Hello, we need our floors waxed and carpet cleaned during the week of August 8th. The first floor wing/room 109 for speech-Language Center and Psychology clinic must be done during this week because Psychology will reopen August 15th. The east wing and
FO-352345	7/15/2016			Work Order Continued for east Wing:6. Carpet cleaning in the east wing "PLAY" area.7. Floor should be stripped and waxed in the east wing.8. Stripping and waxing of the center hallway in the east wing ground floor level.
FO-352346	7/15/2016			Please clean carpet in the audiology clinic in the basement room 002 during the week of August 8th.
FO-352706	7/19/2016	7/25/2016		Attention custodial: Shampoo carpet in faculty office 2356;
FO-353281	7/27/2016	7/27/2016		10 cases of dial soap delivered to 5057: for all sector 7 buildings.
FO-353305	7/27/2016			Attention Custodial:Please clean locker area, rooms 2412 and 3412. Forward to Robert Reeder.
<b>C-Sector 08</b>			<b>6</b>	
FO-351876	7/8/2016			Flooding around these area 1st Floor Henry Ford, Basement area and the South West Stairwell. Can you please provide us with these particular items, Dry Vacs and Floor Fan. Thank You!
FO-352089	7/12/2016			1 case of dial soap.
FO-352162	7/13/2016			R/R RM 00150/SUPERVISOR/COMMAND CTR/SVC CTR AREA WOULD LIKE TO HAVE CARPET AREAS SHAMPOOED
FO-352163	7/13/2016			R/R RM 00150/SUPERVISOR/COMMAND CTR/SVC CTR AREA WOULD LIKE TO HAVE FLR TILE AREA STRIPPED & WAXED

WO	Recieved	Finished	Total	Request
FO-352164	7/13/2016			R/R RM 00150/SVC CTR AREA WOULD LIKE TO HAVE CHRYSTAL'S OLD AREA DESK CLEANED FOR NEW PERSONNEL THAT WILL BECOMING IN
FO-352983	7/22/2016			The carpet needs to be cleaned in office 2207, it looks like someone spilled coffee on this floor as well.
<b>C-Sector 09</b>			<b>1</b>	
FO-351979	7/11/2016			Please clean coffee stain on carpet in room 225 in college of education. thank you
<b>Pest Controller</b>			<b>29</b>	
FO-351324	7/1/2016	7/6/2016	7/6/2016	R/R 3RD FLR MENS RR (ONLY ONE ON FLR) ROACH PROBLEM NEED TRAPS
FO-351359	7/1/2016	7/5/2016	7/5/2016	R/R RM 2103 NEED STICKY TRAPS
FO-351590	7/5/2016	7/6/2016	7/6/2016	1st floor men's room has an ant colony living up against the wall by the urinal and 1st stall.
FO-351681	7/6/2016	7/11/2016	7/11/2016	replace traps in all restrooms:Law Library Building
FO-351682	7/6/2016	7/11/2016	7/11/2016	replace traps in all restrooms:Law School Building
FO-351683	7/6/2016	7/11/2016	7/11/2016	replace traps in all restrooms:Law Classroom Building
FO-351679	7/6/2016	7/18/2016	7/18/2016	EXTERMINATION FOR BED BUGS IN ROOMS 2234 AND 2122. CONTACT CHARO IN ROOM 2146.
FO-351708	7/6/2016	7/8/2016	7/8/2016	EXTERMINATION FOR COCKROACHES. DESIGN SERVICES.
FO-351718	7/6/2016	7/11/2016	7/11/2016	BIRD FLYING AROUND LAW SCHOOL (COMING FROM AIR VENT IN ROOM 1255)
FO-352032	7/12/2016	7/13/2016		EXTERMINATION FOR WASPS. OUTSIDE OF FRONT ENTRANCE DOOR.
FO-352037	7/12/2016	7/13/2016		Remove wasp nest in the courtyard.
FO-352043	7/12/2016	7/12/2016	7/12/2016	RM 00121 (Bobby's Ofc) PLS CHANGE OUT STICKY TRAPS
FO-352073	7/12/2016	7/13/2016	7/13/2016	Dead bird outside by entry door (Palmer side).
FO-352083	7/12/2016	7/14/2016	7/14/2016	EXTERMINATON FOR COCKROACHES. ROOM 241.
FO-352111	7/13/2016	7/14/2016	7/14/2016	R/R RM 322/KITCHEN AREA FOUND MOUSE
FO-352125	7/13/2016	7/19/2016	7/19/2016	Large bug, possibly a cockroach, seen in office, room 316. Please put down traps and spray, if necessary.
FO-352190	7/13/2016	7/14/2016	7/14/2016	Courtyard - south end, upper corners of last two windows - please remove wasp nests.
FO-352212	7/14/2016	7/14/2016	7/14/2016	Dead mouse on trap in room 3008 in the Maccabees building.
FO-352310	7/15/2016	7/18/2016	7/18/2016	R/R RM 2701 BOTH THE RECEPTION AREA & THE FILE RM EVIDENCE OF ROACHES NEED SPRAY OR STICKY TRAPS
FO-352421	7/18/2016	7/19/2016	7/19/2016	EXTERMINATION FOR MICE. 1ST FLOOR DISPATCH OFFICE.
FO-352738	7/20/2016	7/20/2016	7/20/2016	R/R RM 7908 HAS MICE
FO-352849	7/21/2016	7/26/2016	7/26/2016	PEST CONTROL R/R RM 4100 (after wall has been torn down) ROACHES ARE COMING IN
FO-352874	7/21/2016	7/28/2016	7/28/2016	PEST CONTROL- R/R RM 00005 PLEASE CHANGE PEST GLUE TRAPS IN ROOM 5, PRIORITY MED
FO-353215	7/26/2016	7/26/2016	7/26/2016	gnats in the men's restroom.
FO-353274	7/27/2016	7/27/2016	7/27/2016	Please have the exterminator bring mouse traps to both Design Services reception area and to the stockroom. Mice have been found in both locations. Thanks! Sandy
FO-353300	7/27/2016	7/27/2016	7/27/2016	RM 5016 NEED TO EXTERMINATE FOR MICE
FO-353357	7/28/2016			Corner conference room of Disabilities Services, Room 1628, is enclosed two sides by windows. Presently many small dead gnats (and one larger bug) are on the window sills. Many more such gnats were cleaned from the sill earlier. It appears the two win
FO-353386	7/28/2016			EXTERMINATION FOR COCKROACHES. 2ND FLOOR LADIES RESTROOM.
FO-353440	7/29/2016			Purdy Library 4th Floor. Room 446Staff reported a Cockroach sighting in their office.Thank you.

## Engineering

595

## Emergency

20

## E - Auxiliary

4

FO-352889 7/21/2016 7/22/2016

CK LEAK IN HVAC IN & AROUND WIRING (Per Req #287075)

WO	Recieved	Finished	Total	Request
FO-352941	7/22/2016			WDET NEWS RM HAS WATER POURING DOWN FROM CLNG DON'T KNOW IF ITS COMING FROM AN APT
FO-352970	7/22/2016			WDET NEWS RM ALARM IS STILL BEEPING FROM EARLIER WATER ISSUE
FO-353007	7/25/2016			WDET NEWS RM HAS WATER IS STILL COMING DOWN FROM FRIDAY'S PROBLEM WORST THAN FRIDAY NOTE: NEWLY RENOVATED AREA CLNG TILES ARE WATER DAMAGED & SOME HAVE FALLEN, CARPET WATER DAMAGED, ETC)
<b>E - Command Center</b>			<b>4</b>	
FO-352195	7/14/2016	7/14/2016		EMERGENCY CONTROLS R/R RM 30/BSMT MECH RM AIR COMPRESSOR #2 IS DOWN NEED PORTABLE COMPRESSOR (Since AIR #1 is still down from earlier this year)
FO-353278	7/27/2016			EMERGENCY CONTROL R/R RM 1195/MECH BLR RM #3 BOILER WILL NOT LIGHT OFF FLAME FAILURE
FO-353296	7/27/2016			EMERGENCY CONTROL R/R RM 00425/MECH BLR RM #1 BOILER LOW LOW WTER CUT OUT HAS FAILED NOT TRIPPED BURNER OFF
FO-353298	7/27/2016	7/27/2016		EMERGENCY CONTROL R/R RM 4505/MECH RM RAD EDC AREA NOT WORKING
<b>E - Midnight</b>			<b>1</b>	
FO-352976	7/25/2016			EMERGEMNCY R/R BSMT AREA FAP FIRE ALARM IS ACTIVE NOW HOWEVER MIDNITE SHIFT HAS FIRE ALARM TROUBLE
<b>E - North</b>			<b>1</b>	
FO-353003	7/25/2016			FAP ALARM HAS SOUNDED AGAIN PEOPLE HAVE EVACUATED BLDG PLS CK ALREADY SPOKE W/ELECS'
<b>E - Northeast</b>			<b>2</b>	
FO-352834	7/21/2016	7/21/2016		ALL 3 BLDGS KNAPP, SKILLMAN & FREER HAVE NO WATER
FO-353293	7/27/2016			FAP FIRE ALARM ACTIVE
<b>E - Preventative Maintenance</b>			<b>2</b>	
FO-351828	7/7/2016	7/7/2016		EMPLOYEE ENTRANCE DOOR OFF OF CASS AVE ISN'T CLOSING ALL THE WAY WHEN USED
FO-353073	7/25/2016	7/26/2016		RM 111 CK DOOR LOCK LOCKING PEOPLE IN
<b>E - South</b>			<b>3</b>	
FO-351766	7/7/2016	7/7/2016		BOMB THREAT. CHECK MECHANICAL ROOM PER PUBLIC SAFETY.
FO-351767	7/7/2016	7/7/2016		BOMB THREAT. CHECK MECHANICAL ROOM PER PUBLIC SAFETY.
FO-352200	7/14/2016	7/14/2016		EMERGENCY ELEC R/R BLDG POWER FAIL THRU OUT BLDG CK ALL EQUIP
<b>E - Southeast</b>			<b>1</b>	
FO-352047	7/12/2016			EMERGENCY CALLED SCHINDLER ELEV CO FOR #1/SVC-FREIGHT ELEV ENTRAPMENT BTWN FLRS 1/2 REF #53350172
<b>E - West</b>			<b>2</b>	
FO-352249	7/14/2016	7/15/2016		BURNING SMELL THROUGHOUT BUILDING INCLUDING ROOM 135.
FO-353387	7/28/2016	7/28/2016		RM 154/CLASS DOOR IS LOCKED NEED ACCESS DUE TO CLASS IS STARTING
<b>High</b>			<b>264</b>	
<b>E - Auxiliary</b>			<b>19</b>	
FO-351321	7/1/2016	7/1/2016		FAP FIRE TROUBLE ALARM
FO-351593	7/5/2016	7/6/2016		EMERGENCY POWER EQUIPMENT ROOM NORTH DOOR 107E ALARM PANEL ZONE 36.
H-59192	7/7/2016	7/7/2016	7/7/2016	The vent is blowing out hot air when the thermometer is on low temperatures (air conditioning). authenticated user: Nicole Fry - eq0918 requester ip address: 141.217.23.177
H-59222	7/8/2016			water is draining inside elevator furthest from front desk authenticated user: Angelica Reyna - ag8310 requester ip address: 141.217.23.202
FO-351909	7/11/2016	7/14/2016		APT 415 TOILET ISN'T WORKING



WO	Recieved	Finished	Total	Request
H-59251	7/11/2016	7/13/2016	7/13/2016	The air conditioning/heating system is not working properly in the room. authenticated user: Faith Basheer - fp3620 requester ip address: 141.217.23.242
H-59277	7/12/2016	7/18/2016	7/18/2016	Air vent needs to be cleaned. Dust particles are coming out when the air blows. authenticated user: Nicole Fry - eq0918 requester ip address: 141.217.23.177
H-59291	7/14/2016			A/C is not workingauthenticated user: Meyyappan Nachiappan - fy7781requester ip address: 141.217.23.173
FO-352299	7/15/2016	7/15/2016		FIRE TROUBLE ALARM.
H-59308	7/16/2016			Toilet tank leakauthenticated user: Ameer Al Shawk - fo9327requester ip address: 141.217.23.173
H-59307	7/18/2016			The toilet is not flushing properly. The pressure is low. authenticated user: Nicole Fry - eq0918requester ip address: 141.217.23.177
H-59316	7/18/2016			Leak under the sinkauthenticated user: Sai Prakash Reddy Konda - fr1213requester ip address: 141.217.232.170
H-59355	7/19/2016		7/20/2016	The bathroom light is gone completely.I want it to be fixed as soon as possible. The issue has been reported at least 2 times before but still has yet to be fixed. authenticated user: Sneha Gaikwad - fz6412 requester ip address: 141.217.23.173
FO-352943	7/22/2016			DETROIT YOGU LAB HAS LOW WATER PRESSURE
H-59414	7/25/2016	7/26/2016	7/26/2016	air not working authenticated user: Rheana Allen - fh1699 requester ip address: 141.217.23.177
H-59431	7/25/2016			AC is not getting cold and it would be on all the time. I have submitted a service request in May about the AC not working with similar complaints. It felt it was fixed for the month of July, but lately only lukewarm air is coming out.Your help on the
H-59434	7/26/2016			shower tap is leaking heavilyauthenticated user: Yi Zheng - eq7076requester ip address: 35.16.0.93
FO-353235	7/26/2016	7/26/2016		HIGH TEMP. ALARM. DATA ROOM 222. (224.1)
H-59469	7/27/2016			Resident says faucet in bathroom is dripping. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.173
<b>E - Command Center</b>			<b>31</b>	
FO-351685	7/6/2016	7/7/2016		Please have controls replace transducer on ahu-11 for face and bypass dampers. priority high.  Transducer = RP7517-B1024
FO-351789	7/7/2016			R/R PH/MECH RM AC-11,has insuffient air pressure,needs 15-18 psi to operate controls;AC-11 priority HIGH.
FO-351790	7/7/2016			R/R PH/MECH RM AC-10,has insuffient air pressure,needs 15-18 psi to operate controls;AC-10,also. priority HIGH.
FO-351809	7/7/2016		7/13/2016	Refrg. Crew: R/R RM 00495/MECH BLR RM Boiler #2 had "flame failure" on and off the last two weeks, and Wednesday and Thursday this week. Please check and correct the problem. High Priority.
FO-351813	7/7/2016	7/7/2016		Please troubleshoot domestic hot water heater on 2nd floor that serves the cages washing area.
FO-351849	7/8/2016			A/C Controls, R/R RM PENTHOUSE please wire controls for AHU-1 damper motors. (Electricians have provided wiring and conduit). Priority: high
FO-351969	7/11/2016	7/26/2016		Controls/Fridge(High) R/R RM 00101 RTU 7 not cooling room 101. This room has classes daily this week from 11am to 4pm. Repair as needed. see engineer to assist.
FO-351972	7/11/2016	7/15/2016		Trade: Command Center - Refrig Crew Priority: High R/R PENTHOUSE Please repair AC unit for the east elevator room in the Chemistry penthouse. Unit will not reset from hi-head. Compressor will attempt to start three times, condenser fan will turn. C
FO-351971	7/11/2016			Controls/Fridge(High) R/R RM 00101 RTU 8 not cooling room 101. This room has classes daily this week from 11am to 4pm. Repair as needed. see engineer to assist.

WO	Recieved	Finished	Total	Request
FO-352023	7/12/2016		7/25/2016	Boiler Section: High Priority. R/R PENTHOUSE Please repair refractory surface on the rear cone on steam boiler # 1 Location: PH N.E.
FO-352157	7/13/2016			control's section- R/R 4TH FLR please repair the following rooms Pneumatic control issues which will not allow the damper actuators to release the control air pressure to allow air flow to these rooms.4101,4109, 4110,4084, these are Honeywell Pneumatic
FO-352149	7/13/2016			controls- pneumatic control in ceiling not releasing air pressure to allow damper actuator to open for room to receive air flow. High Priority. Room stat seems to be working. air pressure holds damper closed. When stat is set to low temperature setting a
FO-352161	7/13/2016			High Priority, R/R RM 00010.10/MECH RM please have Controls inspect DX unit on AHU2 for proper operation. Unit is starting to trip off from "Low Suction Pressure" fault.
FO-352285	7/15/2016	7/15/2016		R/R RTU CHILLER #1 - #2 CIRCUIT WILL NOT RESET STAYING IN ALARM
FO-352295	7/15/2016			AC Shop- R/R LOAD DOCK please check operation of heat pump 2-11. Compressor not pulling in. Suite very warm. High Priority
FO-352296	7/15/2016			AC Shop- R/R LOAD DOCK please check operation of heat pump 1-73. Fan not starting. Suite very warm. High Priority
FO-352319	7/15/2016			RESTORE COOLING FOR ELEVATORS. (AIR CONDITIONING UNIT IS BLOWING HOT AIR) (ELEVATOR MACHINE ROOM)
FO-352361	7/18/2016	7/18/2016		trade seimens priority high please service air handler #6 return fan speed drive will not run in auto mode maybe program problem
FO-352777	7/20/2016			CONTROLSR/R RM 205/DATA CLOSET-IDF I'm getting high temp discharging from ACCU 3 @ 91 degrees, ACCU 5 @ 85, ACCU 6 discharging @ 82. Please have controls look at these units.
FO-352886	7/20/2016	7/25/2016		Refrig. Crew: R/R RM 14200.60 please check and or repair fan coil unit to Rm. 14200.6, reset unit no luck, priority high
FO-352808	7/21/2016	7/22/2016		See Frank Van Oppens. Unit #2 has iced up will not run.
FO-352814	7/21/2016			Trade: Command Center Priority: High R/R RM 00000.62/MECH BLR RM Boiler 4 is in alarm and will not start. Fireeye reports "check amplifier".
FO-353014	7/22/2016	7/22/2016		REFRIG CREW, R/R ROOF COMPRESSORS WILL NOT CYCLE ON FOR #1 ROOFTOP UNIT, PLEASE TROUBLESHOOT. (FOR RM 00124) PRIORITY-HIGH
FO-352929	7/22/2016			Controls (Med High) R/R E. SIDE (OUTSIDE) Boiler #2 probe wires shorting out. Replace bad wire and connectors.
FO-352950	7/22/2016			1ST FLR IS EXTREMELY COLD. Especially the reception area served by AHU-3 and VAV's 104A-E  NOTE: Reception area supply diffusers ALSO blow directly onto occupants. They report the boxes sporadically blow high volumes of air.  Please troubleshoot box
FO-353065	7/25/2016			Trade: Command Center Priority: High R/R RM 00000.62/MECH BLR RM Boiler 4 will not start. There may be a problem with the blower motor.
FO-353227	7/26/2016			Refg. Crew (A. Waller): R/R RM 00495/MECH BLR RM Boiler # 1 is shutting-down on flame failure on the average of one failure per day. Please repair. High Priority.
FO-353228	7/26/2016			Refg Crew (A. Waller): R/R RM 00495/MECH BLR RM Please perform a flu gas analyzes test on boiler #1 burner. High Priority.
FO-353236	7/26/2016	7/26/2016		The only running compressor on RTU for Ruether tripped and won't start. Please check.
FO-353316	7/27/2016			AC Shop, R/R 4TH FLR please check pressures on HP 4-7. Unit not cooling
FO-353385	7/28/2016			R/R MAIL PROCESSING RM - A/C not working, condenser fans run, compressors run, evaporator fan not operating. priority high

WO	Recieved	Finished	Total	Request
<b>E - MedPharm</b>			<b>91</b>	
FO-351310	7/1/2016			DOCK AREA CONTROL BOX TAMPER ALARM IS ACTIVE
FO-351327	7/1/2016			RM 6238 WALK IN COLD RM HAS A HI TEMP ALARM
FO-351395	7/1/2016			1ST FLR HALLWAY OUTSIDE OF ELEC/CLOSET RM 1270 THERE IS A BUZZING/KNOCKING NOISE COMING FROM CLNG
FO-351606	7/5/2016	7/6/2016		NO POWER IN WALL OUTLETS. ROOM 6374.
FO-351621	7/5/2016	7/6/2016		CEILING LEAK. ROOM 3375.
FO-351664	7/6/2016	7/6/2016		HIGH HUMIDITY IN ALL BASEMENT ANIMAL ROOMS.
FO-351700	7/6/2016	7/6/2016		HIGH TEMP. ROOM AF24.
FO-351762	7/7/2016			HIGH TEMPS. IN ALL 5TH FLOOR ANIMAL ROOMS.
FO-351763	7/7/2016	7/11/2016		HIGH TEMP. ALARM. ROOM 4252.
FO-351773	7/7/2016			Rm. 3112 - the electrical outlets are not working and need repair.
FO-351777	7/7/2016			HIGH TEMPS. ALL 2ND FLOOR ANIMAL ROOMS.
FO-351778	7/7/2016	7/7/2016		CEILING LEAK HALLWAY BETWEEN ROOMS 0221 AND 0225.
FO-351788	7/7/2016			RM 109 AIR FLOW SYS FAN IS BLOWING TOO FORCEFUL
FO-351875	7/8/2016			RM 8244 HAS A CLNG LEAK
FO-351887	7/8/2016			RM 109 AIR FLOW SYS FAN IS STILL BLOWING TOO FORCEFUL
FO-351891	7/8/2016	7/12/2016		HIGH HUMIDITY. ROOM 423.
FO-351892	7/8/2016			HIGH TEMPS. ALL 2ND FLOOR ANIMAL ROOMS.
FO-351917	7/11/2016			RM 416 DOORS HAS A WHISTLING NOISE
FO-351945	7/11/2016	7/12/2016		COLD ROOM IS WARM. 3RD FLOOR SOUTH WEST SIDE OF BUILDING.
FO-351946	7/11/2016	7/12/2016		FIRE ALARM.
FO-352057	7/12/2016	7/25/2016		CEILING LEAK. ROOM 2105.
FO-352060	7/12/2016			Incubator on 4th floor needs repair.
FO-352072	7/12/2016			ATRIUM DRINK FOUNT HAS LOW WATER PRESSURE
FO-352077	7/12/2016			RM 2190 IS TOO COLD
FO-352103	7/13/2016			FAP FIRE ALARM BOX @ SECURITY'S DESK IS IN ALARM SINCE EARLY MIDNITE 2AM
FO-352117	7/13/2016			HIGH TEMPS. IN ALL 4TH FLOOR ANIMAL ROOMS.
FO-352128	7/13/2016			LOADING DOCK IS STILL PAD LOCKED
FO-352156	7/13/2016			RM 103 IS EXTREMELY HOT
FO-352167	7/13/2016			ENTIRE 1ST FLR IS EXTREMELY COLD
FO-352175	7/13/2016			TRIPPED FUSE. ROOM 3250.
FO-352197	7/14/2016			FAP FIRE ALARM BOX @ SECURITY'S DESK IS IN ALARM SINCE EARLY THIS MORN AGAIN SAME AS YESTERDAY
FO-352210	7/14/2016			RM 110 AIR IS BLOWING TOO HARD IN ON OCCUPANTS
FO-352221	7/14/2016			FIRE TROUBLE ALARM.
FO-352223	7/14/2016			ENTIRE 3RD FLR POWER SURGE/BUMP
FO-352241	7/14/2016			RM 6205 IS TOO HOT
FO-352243	7/14/2016			RM 403 HAS HI TEMP
FO-352244	7/14/2016			RM 403 HAS HI HUMIDITY
FO-352251	7/14/2016	7/25/2016		FOUL SMELL IN ROOM 527 AND SURROUNDING AREAS.
FO-352287	7/15/2016	7/15/2016		ENTIRE ANIMAL QUARTERS BOTH SMALL ANIMAL/LARGE HAVE HI HUMIDITY PROBLEM
FO-352288	7/15/2016	7/15/2016		BSMT HALLWAY OUTSIDE OF RM 221 HAS A CLNG LEAK CLNG TILES HAVE BEEN REMOVED & A BARREL PLACED UNDERNEATH
FO-352301	7/15/2016	7/15/2016		RM 00413/DLAR HAVE HI HUMIDITY PROBLEM
FO-352302	7/15/2016	7/15/2016		RM 00413/DLAR HI TEMP
FO-352326	7/15/2016			RM 00519/DLAR HI TEMP

WO	Recieved	Finished	Total	Request
FO-352327	7/15/2016			RM 00520/DLAR POSSIBLE FLR DRAIN BACKED UP (OCCUPANTS MOPPED UP CLEAR WATER)
FO-352333	7/15/2016			RM 118 WEST WALL OUTLET NEEDS RESETTNG
FO-352362	7/18/2016	7/25/2016		ALL ELEVATORS ARE NOT WORKING.
FO-352397	7/18/2016	7/18/2016		HIGH TEMP. ROOM 408.
FO-352639	7/19/2016	7/19/2016		HIGH HUMIDITY. ROOMS 243 & 247.
FO-352651	7/19/2016	7/20/2016		HIGH TEMP. ROOM 0413.
FO-352669	7/19/2016	7/25/2016		HIGH TEMP. AND HIGH HUMIDITY. ROOM 403.
FO-352684	7/19/2016	7/19/2016		HIGH TEMP. ROOM 0408.
FO-352696	7/19/2016	7/25/2016		HIGH TEMP. ALARM. ROOM 6238.
FO-352771	7/20/2016	7/30/2016		HIGH TEMP. ALARM. COLD ROOM 2330.1.
FO-352836	7/21/2016			RM 403 HAS HI TEMP
FO-352837	7/21/2016			RM 412 HAS HI TEMP
FO-352838	7/21/2016			RM 403 HAS HI HUM
FO-352839	7/21/2016			RM 200.13 HAS HI HUM
FO-352845	7/21/2016			RM 9228 AUTOCLAVE ISN'T WRKNG (VENDOR CAME OUT 7/20/16) SINCE THEN THE AUTOCLAVE HASN'T WORKED
FO-352862	7/21/2016			RM 9126 ONLY SINK IS LKNG (PLEASE ISOLATE WATER WO TO PLUMBERS)
FO-352897	7/22/2016			FAP FIRE ALARM ACTIVE AGAIN @ 1ST FLR SECURITY DESK (NOTE: Pub Safe panel isn't showing alarm)
FO-352901	7/22/2016			RM 7212 WALK IN COLD RM BOX HAS A HI TEMP ALARM
FO-352912	7/22/2016			RM 403 HAS A HI TEMP PROBLEM
FO-352913	7/22/2016			RM 403 HAS HI HUMIDITY PROBLEM ALSO
FO-352915	7/22/2016			RM 200.02 HAS HI HUMIDITY PROBLEM ALSO
FO-352933	7/22/2016			2ND FLR RMS AF-12 THRU AF-32 HAVE HI TEMPS 75/76
FO-352934	7/22/2016			2ND FLR RMS AF-12 THRU AF-32 HAVE HI HUMIDITY 60%
FO-352936	7/22/2016			RM 414 AIR PRESSURE IS VERY HI CAUSING ENTRY DOOR TO STAY OPEN/CARPENTERS HAVE ALREADY INVESTIGATED & ITS NOT A PROBLEM FOR THEM TO REPAIR
FO-352939	7/22/2016			RM 9228 AUTOCLAVE NOW THEY ARE SAYING THERE IS NO STEAM GOING TO AUTOCLAVE
FO-352999	7/25/2016			RM 403 HAS HI HUMIDITY AGAIN TODAY NEVER LOWER FRIDAY & THURSDAY
FO-353000	7/25/2016			RM 403 HAS A HI TEMP PROBLEM
FO-353001	7/25/2016			ENTIRE 400/ANIMAL QUARTERSHAS A HI TEMP PROBLEM STILL
FO-353002	7/25/2016			ENTIRE STE 200.00 HAS HI TEMP PROBLEM STILL
FO-353004	7/25/2016			CAFETERIA IS EXTREMELY HOT ORIENTATION WILL BE HELD THIS MORN
FO-353025	7/25/2016			R/R RM 00121/GROSS ANATOMY LAB CEILING IS LKNG
FO-353028	7/25/2016			RM 103 IS TOO HOT
FO-353030	7/25/2016			RM 427.3 IS TOO HOT
FO-353125	7/26/2016			RM 403 HAS HI HUMIDITY AGAIN TODAY TUESDAY NEVER LOWER MONDAY (FO-352999), FRIDAY (FO-352913),& THURSDAY (FO-352836)
FO-353126	7/26/2016			RM 403 HAS A HI TEMP PROBLEM AGAIN TODAY TUESDAY NEVER LOWER MONDAY (FO-353000), FRIDAY (FO-352912), THURSDAY (FO-352836)
FO-353128	7/26/2016			ENTIRE 400/ANIMAL QUARTERS HAS A HI TEMP PROBLEM STILL SAME AS MONDAY/FRIDAY
FO-353129	7/26/2016			ENTIRE STE 200.00/ANIMAL QUARTERS HAS HI TEMP PROBLEM STILL SAME AS MONDAY/FRIDAYT
FO-353134	7/26/2016			ENTIRE 400/ANIMAL QUARTERS HAS A HI HUMIDITY PROBLEM STILL SAME AS MONDAY/FRIDAY
FO-353135	7/26/2016			ENTIRE STE 200.00/ANIMAL QUARTERS HAS HI HUMIDITY PROBLEM STILL SAME AS MONDAY/FRIDAYT
FO-353223	7/26/2016	7/27/2016		RM 2230 HAS LOW STEAM PRESSURE

WO	Recieved	Finished	Total	Request
FO-353226	7/26/2016	7/27/2016		BSMT HAS LOW STEAM PRESSURE
FO-353246	7/26/2016			RM 225 NO POWER IS GOING TO THE CAGEWASH
FO-353297	7/27/2016			NO STEAM IN CAGE WASHER. ROOM 451B.
FO-353299	7/27/2016			NO POWER TO RACK WASHER. ROOM 0225.
FO-353337	7/27/2016			CK WATER PRESSURE IN RESTROOM
FO-353424	7/29/2016			1ST FLR BY GUARD'S DESK FAP FIRE ALARM IS ACTIVE
FO-353427	7/29/2016			LOW TEMP. ALARM. ROOM 471.
FO-353435	7/29/2016			FIRE TROUBLE ALARM.
<b>E - North</b>			<b>13</b>	
FO-351385	7/1/2016	7/1/2016		RM 216 CEILING TILES ARE SATURATED & BUBBLING UP
FO-351844	7/8/2016	7/8/2016		FIRE TROUBLE ALARM.
FO-351869	7/8/2016	7/8/2016		RM 4116 HAS A CLNG LEAK
FO-352079	7/12/2016	7/12/2016		3RD FLR WOODCOCK SIDE NEED BREAKER RESET
FO-352108	7/13/2016	7/14/2016		1ST FLR CIRCULATION DESK AREA HAS A CLNG LEAK
FO-352112	7/13/2016	7/13/2016		RM 4130 HAS A CLNG LEAK
FO-352114	7/13/2016	7/13/2016		CEILING LEAK. ROOM 4236.
FO-352155	7/13/2016	7/13/2016		CEILING LEAK. ROOM 4069.
FO-352217	7/14/2016	7/14/2016		RM 116 IS TOO COLD CK T-STAT
FO-352683	7/19/2016			TOO COLD. ROOM 100.
FO-352751	7/20/2016			RM 3198 HAS COLD AIR BLOWING DOWN ON OCCUPANT
FO-352842	7/21/2016	7/21/2016		RM 3198 HAS COLD AIR STILL BLOWING DOWN ON OCCUPANT
FO-353280	7/27/2016	7/27/2016		HANDICAP ENTRANCE OFF OF HANDICAP RAMP IS STUCK OPEN
<b>E - Northeast</b>			<b>21</b>	
FO-351313	7/1/2016	7/1/2016		FAP FIRE PANEL IS BEEPING
FO-351605	7/5/2016	7/5/2016		FIRE TROUBLE ALARM.
FO-351609	7/5/2016	7/6/2016		MRS. WILSON NEED ACCESS TO THE CARRIAGE HOUSE. ALARM SOUNDING
FO-351612	7/5/2016			FIRE TROUBLE ALARM.
FO-351839	7/8/2016	7/8/2016		FIRE TROUBLE ALARM.
FO-351918	7/11/2016	7/11/2016		GENERATOR GATE IS LOCKED & GROUNDS DEPT NEEDS ACCESS TO CLEAN
FO-351929	7/11/2016	7/11/2016		POSSIBLE CEILING LEAK. (BOXES WERE WET). 1ST FLOOR NEAR PROPERTY OFFICE.
FO-351952	7/11/2016	7/12/2016	7/12/2016	RM 101 IS TOO HOT
FO-351953	7/11/2016	7/11/2016	7/11/2016	BLDG VERY HUMID
FO-351959	7/11/2016	7/11/2016		2ND FLR SUPERVISORS' WOMENS LOCKER RM HAS NO CLNG LITES CK BREAKER
FO-352021	7/12/2016	7/12/2016		GRNDS/COMMON AREA EXH FAN BELT IS MAKING NOISE ABOUT TO BREAK
FO-352135	7/13/2016	7/13/2016	7/13/2016	FAP FIRE TROUBLE ALARM
FO-352219	7/14/2016	7/14/2016	7/14/2016	RM 315 HAS A CLNG LEAK COMING FROM SOMEWHERE
FO-352714	7/20/2016	7/20/2016	7/20/2016	FIRE ALARM.
FO-352731	7/20/2016			RM 3638 IS TOO HOT
FO-352740	7/20/2016			ENTIE STR 4100 IS FREEZING
FO-352861	7/21/2016	7/21/2016		2ND FLR BACK OFCS' LOST FANS
FO-352935	7/22/2016	7/22/2016		2ND FLR INVESTIGATORS' OFC IS TOO HOT
FO-353058	7/25/2016	7/28/2016		RM 330 ONE OF THE AHU IS LEAKING BADLY
FO-353447	7/29/2016	7/29/2016		FAP FIRE ALARM IS BEEPING
FO-353449	7/29/2016			ARCHIVES AREA IS TOO HOT
<b>E - Preventative Maintenance</b>			<b>32</b>	
FO-351641	7/5/2016			NO POWER IN WALL OUTLETS. ROOM 265.
FO-351645	7/5/2016	7/8/2016		DOOR BELL SOUNDING. ROOM 226.

WO	Recieved	Finished	Total	Request
FO-351730	7/6/2016	7/8/2016		BLOWN FUSE. 3RD FLOOR HALLWAY NEAR ROOM 3250 (WHERE COOLER IS PLUGGED IN)
FO-351821	7/7/2016			WALL OUTLETS ARE NOT WORKING. GARAGE AREA.
FO-351823	7/7/2016	7/7/2016		HANDICAP DOOR BUTTON IS NOT WORKING.
FO-351827	7/7/2016			RM 4200 IS TOO COLD
FO-351897	7/8/2016	7/8/2016		RM 4127 LOST POWER IN WALL OUTLET EITHER E/W WALL
FO-351899	7/8/2016	7/8/2016		RECORDS DEPT @ PUB SAFE NEED BREAKER RESET
FO-351900	7/8/2016	7/8/2016		fap fire trouble alarma active again
FO-352082	7/12/2016	7/12/2016		TOO HOT. 2ND FLOOR ANIMAL ROOMS.
FO-352084	7/12/2016	7/12/2016		RM 116 IS TOO HOT
FO-352088	7/12/2016	7/13/2016		LOUD BANGING NOISE. ROOM 1231.
FO-352181	7/13/2016	7/14/2016		HIGH TEMP. ALARM. ROOM 6238.
FO-352182	7/13/2016	7/14/2016		FIRE ALARM PANEL IS BEEPING. 1ST FLOOR.
FO-352183	7/13/2016	7/13/2016		HERMAN NELSON PANEL IS FALLING OFF. ROOM 112.
FO-352186	7/13/2016	7/13/2016		FIRE TROUBLE ALARM.
FO-352280	7/14/2016	7/21/2016		LIGHTS WILL NOT COME ON. ROOM 100.
FO-352338	7/15/2016	7/16/2016		FRANK WO WEN TO PIPE HOWEVER NEED BLDG ENG TO CK PERIODICALLY R/R RM 315 REPAIR FAN COIL UNIT THAT'S LKNG IN CLNG (ENG HAS IT ISOLATED)
FO-352349	7/15/2016	7/16/2016		REHEAT COIL LEAKING. COORIDOR OUTSIDE OF ROOM 0221.
FO-352429	7/18/2016	7/18/2016		LOUD BEEPING ALARM SOUND COMING FROM ROOM 4173.
FO-352707	7/19/2016	7/20/2016		KEY STUCK IN DOOR LOCK. ROOM 3310.
FO-352709	7/19/2016	7/20/2016		WATER FOUNTAIN CONTINUOUSLY RUNNING. 2ND FLOOR BETWEEN THE MEN AND WOMEN RESTROOMS.
FO-352710	7/19/2016	7/20/2016		WATER COMING UP FROM FLOOR DRAIN. BASEMENT ROOM 520.
FO-352782	7/20/2016	7/21/2016		RM 2151 HAS A CLNG LEAK COMING THRU LITE FIXUTRE
FO-352785	7/20/2016	7/14/2016		RM 423.2 KITCHENNET AREA SINK IS LKNG FROM UNDERNEATH
FO-352867	7/21/2016	7/22/2016		FAP FIRE TROUBLE ALARM PLS RESET
FO-352888	7/21/2016	7/22/2016		2ND FLR WEST WING IS EXTREMELY HOT AGAIN
FO-352968	7/22/2016	7/22/2016		FAP FIRE TROUBLE ALARM ACTIVE
FO-353347	7/27/2016	7/28/2016		FIRE PANEL BEEPING. 1ST FLOOR.
FO-353348	7/27/2016	7/28/2016		room is very hot and now the humidity is causing problems with experiments.
FO-353474	7/29/2016	7/30/2016		SOUND OF RUNNING WATER IN CEILING. ROOM 2600.
FO-353476	7/29/2016	7/30/2016		EYEWASH IS NOT WORKING. ROOM 10.
<b>E - South</b>			<b>23</b>	
FO-351314	7/1/2016	7/12/2016		FAP FIRE TROUBLE ALARM
FO-351322	7/1/2016	7/1/2016		FAP FIRE TROUBLE ALARM
FO-351382	7/1/2016	7/5/2016		RM 3330 ACU STOPPED WORKING
FO-351389	7/1/2016	7/5/2016		RM 2177 IS TOO HOT
FO-351583	7/5/2016	7/5/2016		FIRE ALARM SOUNDING IN ROOMS 1600 AND 1100.
FO-351633	7/5/2016	7/6/2016		2 COPPER PIPES LEAKING AT CHILLER. LAB 60.
FO-351674	7/6/2016	7/7/2016		0227-0247 something is wrong with the ventilation of facility. Facility is quiet, no air movement sounds. ALL rooms are positive to the corridor/should be negative. High priority please.
FO-351843	7/8/2016	7/8/2016		RM 00030/LAB ONLY FUMEHOOD ISN'T FUNCTIONING CAUSING LAB EQUIP/TESTS TO FAIL
FO-351883	7/8/2016	7/8/2016		FIRE TROUBLE ALARM.
FO-351882	7/8/2016	7/19/2016		fap fire trouble alarma active
FO-351911	7/11/2016	7/11/2016		RM 105 IS TOO COLD
FO-352036	7/12/2016	7/12/2016		SECOND DOOR WON'T OPEN. ROOM 260. SEE JACKIE FOR DETAILS.
FO-352050	7/12/2016	7/12/2016		RM 4173/ELEC-MECH RM HAS A VERY LOUD NOISE COMING FRONM INSIDE

WO	Recieved	Finished	Total	Request
FO-352173	7/13/2016	7/13/2016		CEILING PIPE LEAK. ROOM 1342.
FO-352204	7/14/2016	7/18/2016		RM 2100 IS TOO HOT
FO-352206	7/14/2016	7/18/2016		RM 3100 IS TOO HOT
FO-352235	7/14/2016	7/14/2016		BLDG APPR 10:38am POWER SURGE/BUMP
FO-352240	7/14/2016	7/14/2016		RM 1210 IS EXTREMELY HOT
FO-352329	7/15/2016	7/18/2016		3RD FLR HAS NO WATER FLOW
FO-352330	7/15/2016	7/18/2016		1ST FLR HAS LOW WATER PRESSURE
FO-352755	7/20/2016	7/26/2016		RM 2151 HAS A CLNG LEAK COMING THRU LITE FIXUTRE
FO-353423	7/29/2016	7/29/2016		RM 1311 IS TOO HOT (SRVR RM)
FO-353425	7/29/2016	7/29/2016		FAP FIRE ALARM IS BEEPING
<b>E - Southeast</b>			<b>28</b>	
FO-351810	7/7/2016			FIRE TROUBLE ALARM.
FO-351811	7/7/2016	7/7/2016		RM 00156 HAS AN OLD CEILING LEAK THAT HAS MOLD ON CLNG TILES & A WHITE SUBSTANCE COVERING CLASS RM DESK
FO-351878	7/8/2016			1ST FLR HANDICAP BATHROOM HAS NO HOT WATER
FO-351884	7/8/2016			1ST FLR HALLWAY ON THE OTHER SIDE OF RM 125 HAS WATER ON FLR DON'T KNOW WHERE ITS COMING FROM
FO-351915	7/11/2016	7/11/2016		RM 00159 HAS AN OLD CEILING LEAK THAT HAS MOLD ON CLNG TILES & A WHITE SUBSTANCE COVERING CLASS RM DESK
FO-352030	7/12/2016			LIGHT FIXTURE IS BEEPING/BEATING. AUDITORIUM.
FO-352113	7/13/2016			FAP FIRE ALARM ACTIVE W/RESET
FO-352137	7/13/2016			RM 6402.11 HAS NO ACU IT STOPPED WRKNG
FO-352138	7/13/2016			RM 6409.5 HAS NO ACU IT STOPPED WRKNG
FO-352170	7/13/2016			RM 2220/CONF RM LOST POWER IN WALL OUTLETS
FO-352171	7/13/2016			RM 2225/OFC RM LOST POWER IN WALL OUTLETS
FO-352202	7/14/2016			ENTIRE BLDG IS TOO HOT
FO-352225	7/14/2016			BLDG APPR 10:38am POWER SURGE/BUMP
FO-352232	7/14/2016			BLDG CK FAP FIRE TROUBLE ALARM APPR 10:38am POWER SURGE/BUMP
FO-352286	7/15/2016			BLDG IS TOO HOT
FO-352633	7/19/2016			LIGHT BEEPING OUTSIDE OF ROOM 343.
FO-352637	7/19/2016			ALARM SOUNDING. AUDITORIUM. 1ST FLOOR.
FO-352729	7/20/2016	7/20/2016		RM 1134 ACU IS MAKING A NOISE & HAS A FREE-ON SMELL COMING FROM IT
FO-352840	7/21/2016			RM 4108 IS STILL TOO HOT. NO AIR.
FO-352855	7/21/2016			FAP FIRE TROUBLE ALARM
FO-352907	7/22/2016			RM 00012 INSIDE LAB BEHIND THE AUTOCLAVE AN ALARM IS ACTIVE W/HI PITCH NOISE
FO-352932	7/22/2016			1ST FLR HALLWAY OUTSIDE OF RM 1372 CLNG IS LKNG
FO-353214	7/26/2016	7/26/2016		RM 1162 3RD WINDOW ACU IS MAKING A RACKET UNABLE TO WATCH FILM
FO-353242	7/26/2016	7/26/2016		RM 3201 THERE IS A TICKING SOUND COMING FROM AIR VENTS
FO-353286	7/27/2016	7/27/2016		Electrical outlets on far side of room not working. Please check all outlets in the room by 7/29. Need electricity working for new equipment being installed.
FO-353291	7/27/2016	7/27/2016		Outside hydraulic lift for loading dock is not working. Please check both for repair.
FO-353294	7/27/2016			BLDG EMERGENCY WATER SHUT DOWN APPR 11AM TODAY
FO-353422	7/29/2016			RM 1114 IS EXTREMELY HOT (CLASS STARTS @8:30)
<b>E - West</b>			<b>6</b>	
FO-351865	7/8/2016	7/11/2016		1ST FLR IS TOO HOT
FO-351866	7/8/2016	7/11/2016		1ST FLR IS TOO HOT
FO-351893	7/8/2016	7/11/2016		FIRE TROUBLE ALARM.
FO-352018	7/12/2016	7/13/2016		1ST FLR HALLWAY BTWN RMS 118-120 CLNG IS LKNG

WO	Recieved	Finished	Total	Request
FO-352949	7/22/2016			STADIUM STANDS ON SOUTH SIDE WATER SPIGOT NOT WORKING
FO-353013	7/25/2016			ENTIRE BLDG HAS NO AIR FLOW IT IS GETTING HOT
<b>Medium</b>			<b>111</b>	
<b>E - Auxiliary</b>			<b>10</b>	
FO-351699	7/6/2016	7/6/2016		TOO WARM. BUILDING.
FO-351719	7/6/2016	7/8/2016		NO AIR. TOO HOT. SUITE 303.
FO-351724	7/6/2016	7/8/2016		NO AIR. TOO HOT. ROOM 208.
FO-351761	7/7/2016	7/8/2016		TOO WARM. ROOM 005
FO-351822	7/7/2016	7/7/2016		TOO HOT. BASEMENT.
FO-351836	7/8/2016	7/13/2016		TOO HOT. ROOM 005 (SOUTH SIDE OF BUILDING)
FO-351842	7/8/2016	7/11/2016		TOO HOT. BUILDING
H-59285	7/14/2016	7/15/2016	7/15/2016	Starbucks - low water pressure to pipes in back area. Water is drizzling out and there is no temperature.
H-59416	7/22/2016			the food waste disposer under the water tank in the kitchen stops working authenticated user: Wei Wang - fi4564requester ip address: 141.217.203.132
H-59420	7/23/2016			The air conditioner is not working.authenticated user: Aja Johnson - fi6887requester ip address: 35.16.66.248
<b>E - Command Center</b>			<b>17</b>	
FO-351629	7/5/2016	7/6/2016		COMMAND CTR, PLEASE MODIFY PROGRAM FOR CHILLERS CONDENSING WATER VALVES MCH2CV & MCH3CV, THEY ARE MODULATING WHEN THE CHILLERS ARE IN SERVICE & THE TOWER FANS ARE ON, THEY ARE CONTERPRODUCTIVE AND SHOULD BE OFF. PRIORITY-MEDIUM
FO-351636	7/5/2016	7/6/2016		COMMAND CTR, PLEASE MODIFY CHILLER PROGRAM TO ENABLE 2ND CHILLER ON IF OAT IS ABOVE 85 DEGS. PRIORITY-MEDIUM
FO-351739	7/7/2016		7/12/2016	Controls, Medium, Please repair or replace air motor that controls exhaust fan dampers to EXF-274. Possible pneumatic control issue.
FO-351769	7/7/2016	7/8/2016		Trade: Controls/Siemens Priority: Med On the EDC chiller graphic please remove this statement "Alarm point must be commanded off after chiller is reset", this does not have to be done since this was changed some time ago. This statement is located above
FO-351868	7/8/2016	7/11/2016		Trade: Command Center Priority: Medium R/R PENTHOUSE Please add alarm to the static pressure for the north basement exhaust system (F007.11.EA02.ESP). Please set alarm at 1.00". Alarm should be RENO.
FO-351961	7/11/2016	7/12/2016		A/C unit that supports the penthouse elevator machine room is not functioning.
FO-352198	7/14/2016	7/18/2016		Trade: Command Center Priority: Medium R/R BSMT pressure sensor. Point indicates it has failed. F007.10.PWL.SUP.PRS2
FO-352261	7/14/2016	7/20/2016		2nd stage compressor will not cycle on.
FO-352271	7/14/2016			On start-up pilot is flickering. Please adjust, see Pete Smolenyak for details.
FO-352294	7/15/2016			AC Shop- R/R LOAD DOCK please wrap ductwork from heat pump. excessive condensation dripping onto floor. Medium Priority
FO-352749	7/20/2016			Trade: Command Center Priority: Medium R/R RM 00000.62/MECH BLR RM Please perform burner tune up on boiler #2. Boiler is now online after annual inspection.
FO-352759	7/20/2016	7/25/2016		pls calibrate check repair test aab 4th floor box 428 as nesc.
FO-352807	7/21/2016	7/22/2016		2nd stage compressor will not start
FO-353113	7/26/2016			CONTROLS R/R BLDG BOILER #1 RUNS ON LOCAL ONLY NOT REMOTE PLS REPAIR
FO-353114	7/26/2016			CONTROLS R/R BLDG BOILER #2 RUNS ON LOCAL ONLY NOT REMOTE PLS REPAIR



WO	Recieved	Finished	Total	Request
FO-353320	7/27/2016			Controls: MED PriorityR/R PENTHOUSE Please resolve the erratic steam flow readings on the steam boiler steam flow meter. Readings are not accurate, they do not reflect actual steam flow.
FO-353321	7/27/2016			Controls: MED Priority (FOR CHILLERS)Please shorten the time delay when using sys mode to shut down system and restart. At present it has a delay of around 20 minutes. After discussion with the JCI/York tech a restart delay of 5 minutes is more than ade
<b>E - MedPharm</b>			<b>18</b>	
FO-351613	7/5/2016			TOO COLD. ROOM 3122.
FO-351703	7/6/2016			TOO COLD. ROOMS 322.13, 322.14 & 322.15.
FO-351717	7/6/2016	7/20/2016		AUTOCCLAVE MAKING NOISE. ROOM 9228.
FO-351943	7/11/2016			TOO COLD. ROOM 2190.
FO-352136	7/13/2016	7/25/2016		HIGH TEMPS. AND HIGH HUMIDITY. ROOM 403 (ANIMAL ROOMS)
FO-352226	7/14/2016	7/25/2016		POWER SURGE. ROOM 8374.
FO-352231	7/14/2016	7/14/2016		POWER SURGE ON THE 2ND AND 3RD FLOORS ALSO POSSIBLY THE ENTIRE BUILDING.
FO-352298	7/15/2016	7/15/2016		TOO HOT. 2ND FLOOR.
FO-352317	7/15/2016			AIR CONDITIONING UNIT IS BLOWING HOT AIR. (ELEVATOR MACHINE ROOM)
FO-352739	7/20/2016	7/25/2016		LIGHTS GOING OFF AND ON. ROOM 1128.
FO-352773	7/20/2016	7/30/2016		TOO HOT. ROOM 412.
FO-352816	7/21/2016			TOO HOT. ROOM 5361.
FO-352817	7/21/2016			CEILING LEAK. ROOM 5361.
FO-353333	7/27/2016	7/30/2016		AUTOCCLAVE IS NOT WORKING. ROOM 9228.
FO-353336	7/27/2016	7/30/2016		TOILET IS NOT FLUSHING PROPERLY. LADIES RESTROOM. ROOM 1378 LAST STALL.
FO-353363	7/28/2016	7/30/2016		TOO HOT. ROOM 5234.
FO-353455	7/29/2016			TOO COLD. ROOM 306 AND SURROUNDING AREAS.
FO-353456	7/29/2016			TOO COLD. ROOM 125.
<b>E - North</b>			<b>17</b>	
FO-351582	7/5/2016	7/5/2016		NO AIR IN ROOM 122.
FO-351623	7/5/2016	7/5/2016		TOO COLD. BUILDING.
FO-351689	7/6/2016	7/6/2016		TOO HOT. ROOM 112.
FO-351710	7/6/2016	7/8/2016		TOO HOT. A/C NOT WORKING. ROOM 122.
FO-351757	7/7/2016	7/8/2016		TOO COLD. BUILDING
FO-351888	7/8/2016	7/8/2016		Guest say it chilly in this room. They would like the temperature adjusted.  Thank you.
FO-351920	7/11/2016	7/13/2016		TOO COLD. ROOM 3041.
FO-351930	7/11/2016			TOO COLD. ROOM 3054.
FO-352038	7/12/2016	7/12/2016		TOO HOT. ROOM 124 AND 1ST FLOOR HALLWAY.
FO-352115	7/13/2016	7/13/2016		NO AIR ON THE 4TH FLOOR. INCLUDING PROVOST OFFICE ROOM 4092.
FO-352215	7/14/2016	7/14/2016		TOO HOT. ROOM 122.
FO-352389	7/18/2016	7/18/2016		STRANGE SOUND COMING FROM VENTS. 4TH FLOOR MEN'S RESTROOM.
FO-352395	7/18/2016	7/18/2016		TOO COLD. ROOM 100.
FO-352412	7/18/2016			My office is very cold. any help would be appreciated.
FO-352411	7/18/2016			WATER ON FLOOR POSSIBLE PLUGGED TOILET. 4TH FLOOR MEN'S RESTROOM. PLEASE CONFIRM.
FO-353301	7/27/2016	7/27/2016		TOO COLD. AUDITORIUM.
FO-353312	7/27/2016			TOO HOT. ROOM 237.
<b>E - Northeast</b>			<b>16</b>	
FO-351619	7/5/2016	7/5/2016	7/5/2016	A/C IS NOT WORKING. ROOMS 243, 273, 283, 287, 289, & 291.
FO-351626	7/5/2016	7/5/2016	7/5/2016	Conference room # 420 is extremely hot. Please cool down.
FO-351631	7/5/2016	7/5/2016	7/5/2016	Peter Frade request that the entire building be cooled down for the next three days.

WO	Recieved	Finished	Total	Request
FO-351707	7/6/2016	7/6/2016	7/6/2016	Our building is warm. Please cool it down. Thank you.
FO-351850	7/8/2016	7/8/2016		TOO HOT. ROOM 113.
FO-352061	7/12/2016	7/12/2016	7/12/2016	TOO COLD. ROOMS 47 & 83.
FO-352062	7/12/2016	7/13/2016		TOO HOT. ROOM 120.
FO-352133	7/13/2016	7/15/2016		TOO WARM. OPEN VENTS. ROOMS 120 AND 122.
FO-352237	7/14/2016			NO AIR. ROOM A204.
FO-352242	7/14/2016	7/15/2016		Office 2414 is uncomfortably hot, temperature gage does not impact temperature.
FO-352388	7/18/2016	7/18/2016		TOO WARM. ROOMS 120 & 122.
FO-352695	7/19/2016			There is very minimal airflow in the occupied office areas of this building. There are no windows to open, and consequently it gets ridiculously hot in the summer, and extremely cold in the winter. The HVAC system needs to be repaired.
FO-353240	7/26/2016	7/26/2016		TOO HOT. 2ND FLOOR INVESTIGATION ROOM.
FO-353275	7/27/2016	7/27/2016		TOO COLD. ROOM 1200.
FO-353315	7/27/2016	7/27/2016		HIGH HUMIDITY. DISPATCH OFFICE.
FO-353317	7/27/2016	7/28/2016		NO AIR. 1ST FLOOR MAIL ROOM.
<b>E - Preventative Maintenance</b>			<b>11</b>	
FO-351638	7/5/2016	7/11/2016		TOO HOT. BUILDING
FO-351642	7/5/2016			A/C is out in lab 2327. Please have building engineer take a look at this issue.
FO-351723	7/6/2016	7/8/2016		TOO HOT. ROOM 5617.
FO-351728	7/6/2016	7/6/2016		TOO HOT. ROOM 9311.
FO-351976	7/11/2016	7/11/2016		TOO HOT. 14TH FLOOR.
FO-351977	7/11/2016			TOO HOT. 1ST FLOOR HALLWAY.
FO-352191	7/13/2016	7/14/2016		BLOWERS ARE OFF. ROOM 385.
FO-352350	7/15/2016	7/15/2016		FUME HOOD #5 BACKFLOW PREVENTER LAKS WHEN WATER IS TURNED ON. LAB. 220.
FO-352784	7/20/2016	7/21/2016		TOO COLD. ROOM 3638.
FO-353257	7/26/2016	7/27/2016		PROBLEM WITH DISTILLED WATER. HALLWAY ON THE 6TH FLOOR. CONTACT DAVID BARNETT FOR MORE DETAILS.
FO-353473	7/29/2016	7/30/2016		TOO HOT. ROOM 2218.
<b>E - South</b>			<b>6</b>	
FO-351607	7/5/2016	7/6/2016		Air conditioner is out in lab 1330. Please have building engineering take a look at it.
FO-351672	7/6/2016	7/6/2016		TOO HOT. AUDITORIUM (DANTO)
FO-351890	7/8/2016	7/12/2016		Research lab is over 90 degrees and the temp is causing problems with their research. We need additional portable air conditioners. One was brought here last week but it isn't large enough. They plan on running experiments all weekend and need this del
FO-352044	7/12/2016	7/12/2016		TOO HOT IN ROOMS 2104, 2105, 2106 & 21073 (INSIDE SUITE 2100)
FO-352824	7/21/2016	7/22/2016		TOO HOT. ROOM 3217.
FO-353307	7/27/2016	7/28/2016		A/C UNIT IS VERY NOISY. ROOM 3330B.
<b>E - Southeast</b>			<b>9</b>	
FO-351604	7/5/2016			TOO HOT. ROOM 5016.
FO-351785	7/7/2016			This is one of Computer Science labs. There is no air and it is extremely hot. The temp is at 84 degrees. It appears that the whole Maccabees building is not receiving any air.
FO-352132	7/13/2016	7/13/2016		TOO HOT. TURN AIR ON. (BUILDING)
FO-352207	7/14/2016			No air; Room is extremely hot.
FO-352211	7/14/2016			TOO HOT. ROOMS 9312 & 9310.
FO-352253	7/14/2016			NO AIR IN ROOMS 227 AND 229.
FO-352690	7/19/2016			TOO HOT. NO AIR. ROOM 4108.
FO-353238	7/26/2016			TOO HOT. ROOM 4108. (PLEASE CALL KATHY WILSON AT 7-0290)
FO-353354	7/28/2016	7/28/2016		TOO WARM. ROOM 1162.
<b>E - West</b>			<b>7</b>	

WO	Recieved	Finished	Total	Request
FO-351702	7/6/2016	7/7/2016		TOO COLD. ROOMS 308, 328, 358 & 368.
FO-351783	7/7/2016	7/8/2016		TOO HOT. ROOM 1154.
FO-352129	7/13/2016	7/15/2016		TOO WARM. ROOM 1154.
FO-352055	7/14/2016	7/15/2016		TOO HOT. ROOM 1154 AND SURROUNDING AREA.
FO-352741	7/20/2016			TOO HOT. ROOM 2100.
FO-352761	7/20/2016			Compressor needs to be replaced. Compressor is mechanically seized.  NOTE: Both compressors were replaced in 2013 via P0633042 for a cost of \$24,588
FO-353334	7/27/2016			TOO HOT. ROOM 372.
<b>Low</b>			<b>199</b>	
<b>E - Auxiliary</b>			<b>58</b>	
H-59138	7/1/2016	7/5/2016		The garbage disposal is not working authenticated user: Michelle Talukder - ev6408 requester ip address: 141.217.23.174
H-59145	7/2/2016	7/2/2016		The water pressure is reduced and the toilet will not flush. Tried informing the front desk that this is a building issue, not a unit issue, but he said I needed to complete this request. authenticated user: Janice Ranson - eh9405 requester ip address:
H-59140	7/3/2016	7/6/2016		fix/change (new) waste disposer authenticated user: Shiuan Chang - fm7304 requester ip address: 35.16.6.4
H-59155	7/3/2016			Please fix the Kitchen sink erator. authenticated user: Sampurna Guhathakurta - fx2485requester ip address: 35.16.62.92
H-59169	7/5/2016	7/6/2016		The bathroom sink is leaking heavily and the pipes may have to be fastened. If this could be done soon I would appreciate it as it is difficult to constantly clean up. authenticated user: Andrianna Mckendrick - ge2344 requester ip address: 107.77.192.21
H-59164	7/5/2016	7/7/2016	7/7/2016	Air Conditioner needs to be fixed authenticated user: Alize Whitfield - fw5510 requester ip address: 141.217.23.242
H-59173	7/5/2016			Air conditioning button is not workingauthenticated user: Stephanie Stoiko - fh5195requester ip address: 141.217.23.171
H-59165	7/6/2016	7/7/2016	7/7/2016	Loud buzzing coming from pipe in the shower when it is used authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.177
H-59174	7/6/2016	7/7/2016	7/7/2016	garbage disposal still clogged n lounge 235 - ghafari
H-59191	7/6/2016			There is a pipe leaking in the 27-wing storage room on the 8th floor.authenticated user: Julie Malear - fg9040requester ip address: 141.217.23.171
H-59193	7/6/2016			Air conditioning unit won't emit cool air, they change the temperature but no change in actual temperature. authenticated user: Chester Fleming - fc0603requester ip address: 141.217.23.172
H-59219	7/6/2016	7/8/2016	7/8/2016	Shower head came off and it will only work in one spot authenticated user: Abigail Landskroener - fk9925 requester ip address: 141.217.23.209
H-59204	7/7/2016	7/13/2016		waste disposer get fixed on Wednesday, but it's leaking ( disposer has a crack) authenticated user: Shiuan Chang - fm7304 requester ip address: 35.16.6.4
H-59207	7/7/2016			loud noise coming from toilet when flushedauthenticated user: Michelle Talukder - ev6408requester ip address: 141.217.23.173
FO-351804	7/7/2016	7/8/2016		PLEASE CALL JOE RASAK WITH CNIT AT 577-0381.
H-59254	7/8/2016	7/8/2016	7/8/2016	SubWay  AC is not working authenticated user: Jamone Lewis - em8190 requester ip address: 141.217.23.171
H-59224	7/8/2016	7/12/2016	7/12/2016	Student states that the AC isn't working in their room. authenticated user: Dijon Williams - fk3806 requester ip address: 141.217.23.176

WO	Recieved	Finished	Total	Request
H-59257	7/8/2016	7/14/2016	7/14/2016	The air conditioning unit is not working. The red light is on and the air does not come on at all. authenticated user: Asia Hightower - ev4173 requester ip address: 66.87.115.226
H-59225	7/8/2016	7/13/2016	7/13/2016	Air conditioner is not working. Ac setting is on and fan is working, no cold air blows out. authenticated user: Carly Malburg - fh1228 requester ip address: 141.217.23.176
H-59260	7/10/2016	7/14/2016	7/14/2016	Thermostat in the activity room is not working. authenticated user: Mahpara Khan - fh3271 requester ip address: 141.217.23.171
H-59230	7/10/2016			bathroom sink leak authenticated user: Sifat Noman - fd7475requester ip address: 141.217.233.154
H-59246	7/11/2016	7/13/2016		Resident just moved in and kitchen sink has no running water. Please resolve as soon as possible. Thank you! authenticated user: Angelica Reyna - ag8310 requester ip address: 141.217.23.202
H-59249	7/11/2016	7/13/2016		Garbage disposal is not working authenticated user: Angelica Reyna - ag8310 requester ip address: 141.217.23.202
H-59250	7/12/2016			Water pressure is low in showerauthenticated user: JaNel Stephens-Dantzler - eo2346requester ip address: 141.217.23.177
H-59261	7/12/2016			Ceiling is leaking in bathroom every time I take a shower. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.173
H-59270	7/12/2016	7/20/2016	7/20/2016	Air con. Is broken and needs to be fixed authenticated user: Alize Whitfield - fw5510 requester ip address: 141.217.23.242
H-59271	7/13/2016			Shower head is constantly drippingauthenticated user: Abigail Landskroener - fk9925requester ip address: 141.217.23.209
H-59290	7/14/2016			Engineers: Toilet tank is not filling up. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.173
H-59288	7/14/2016			mechanical check authenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.202
H-59303	7/15/2016	7/18/2016	7/18/2016	Bulbs out in bathroom. Replace it but still not working. Balance Issue. authenticated user: Alize Whitfield - fw5510 requester ip address: 141.217.23.242
H-59332	7/15/2016	7/15/2016	7/15/2016	310 a/c not working authenticated user: Ariel Ferguson - ft9701 requester ip address: 141.217.23.171
H-59304	7/15/2016	7/20/2016	7/20/2016	Air conditioner is still broken.Stuck in fan mood and not blowing out cold or hot air. authenticated user: Alize Whitfield - fw5510 requester ip address: 141.217.23.242
H-59325	7/15/2016	7/20/2016	7/20/2016	Thermostat is not working. Room is 80 degrees F. authenticated user: Mahpara Khan - fh3271 requester ip address: 141.217.23.225
H-59309	7/16/2016			Outlet replaced in the hallway authenticated user: Ameer Al Shawk - fo9327 requester ip address: 141.217.23.173
H-59305	7/18/2016	7/18/2016	7/18/2016	Air conditioning system in her room is not working. She turned the air down to 60 degrees and it still blows out warm air. authenticated user: Kenneth Scott - fg6035 requester ip address: 141.217.23.179
H-59328	7/18/2016	7/20/2016	7/20/2016	Blown switch at the cereal section in cafeteria authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.171
H-59320	7/18/2016			Kitchen sink garbage disposer is clogged and hence not working when the switch is turned on. authenticated user: Meyyappan Nachiappan - fy7781requester ip address: 141.217.23.173
H-59315	7/18/2016	7/19/2016	7/19/2016	Air conditioner is broken authenticated user: Abigail Landskroener - fk9925 requester ip address: 141.217.23.209
H-59319	7/18/2016			Cold water flow in the Bathroom Sink Tap is slow. Water sprays from the kitchen sink tap. Please help fix the issue at the earliestauthenticated user: Swati Verma - eu2860requester ip address: 141.217.232.142
FO-352632	7/19/2016	7/20/2016		PLEASE CALL THE FRONT DESK. REGARDING OVERFLOWING TOILET IN ROOM 817.

WO	Recieved	Finished	Total	Request
H-59322	7/19/2016			AC is not workingauthenticated user: Vinod Kumar Ranganatha - fx8982requester ip address: 141.217.23.173
H-59333	7/19/2016			Ceiling in the restroom needs to be repaired. A request from James Broner the plumber.  authenticated user: Amanda Funk - fi7020requester ip address: 141.217.23.171
H-59356	7/20/2016			Someone came out to fix my light, they arrived while I was gone & claimed they fixed the bulb when I turned on the light, the light bulb flicked off, half the light is only working now and this is the third time I'm sending a request to get my bathroom li
H-59354	7/20/2016	7/27/2016	7/27/2016	Shower head constant dripping authenticated user: Abigail Landskroener - fk9925 requester ip address: 141.217.23.209
H-59362	7/20/2016			Dunkin Donuts: The handicap button does not open the door.
FO-352898	7/22/2016	7/22/2016		NEED ACCESS TO DATA CLOSET 1ST FLR (PH #313-515-9209)
H-59409	7/22/2016			My bathroom shower is not working and I have alreday submitted a work request but no one has come up and solved the issue yet. So I am resubmitting the request again, please solve the issue.authenticated user: Vinod Kumar Ranganatha - fx8982requester ip
H-59426	7/22/2016	7/26/2016	7/26/2016	Air conditioning is not working, Has put in multiple work orders, still has not been fixed. authenticated user: Chester Fleming - fc0603 requester ip address: 141.217.23.172
H-59415	7/22/2016	7/27/2016		Air Conditioner not working authenticated user: Abigail Landskroener - fk9925 requester ip address: 141.217.23.209
H-59417	7/23/2016			Please fix the unbalanced temperature among rooms. We see different width of openings of horizontal blades in AC vent:Master bedroom (Anthony Wayne Dr side) is much hotter than living room with narrower blade openings.Second bedroom (smaller room) is mu
H-59433	7/26/2016			IMPORTANT... The lights in the kitchen do not work. authenticated user: Ni'Esha Wright - fh3756requester ip address: 35.16.99.117
H-59471	7/27/2016			Resident would like the main kitchen light to be checked out. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.173
FO-353332	7/27/2016			PLEASE CALL ANGELICA AT 577-1241.
H-59475	7/28/2016			CEILING IS LEAKING AT FRONT DESK. ALSO TILE FELL FROM CEILING WHERE IT IS LEAKING FROM. WHICH IS LOCATED ON THE LEFT SIDE OF THE DESK.authenticated user: Joanna Berry - fa3511requester ip address: 141.217.23.192
H-59491	7/28/2016			AC unit not working.authenticated user: Andrew Moore - fh0457requester ip address: 35.16.101.251
H-59488	7/28/2016			ac unit not working.authenticated user: Andrew Moore - fh0457requester ip address: 35.16.101.251
H-59489	7/28/2016			ac unit not working.authenticated user: Andrew Moore - fh0457requester ip address: 35.16.101.251
H-59487	7/28/2016			ac unit not working.authenticated user: Andrew Moore - fh0457requester ip address: 35.16.101.251
<b>E - Command Center</b>			<b>32</b>	
FO-339198	7/1/2016			Boiler Crew- R/R RM 00195/MECH BLR RM please repair panel door to boiler #1. Will not latch properly.
FO-351625	7/5/2016		7/26/2016	PS4- AC unit in the parking office on Level 1 is leaking into the office. Please send someone out to repair asap. bpn  A. Waller - Please check for condensate drainage issues and advise. -CLD
FO-351815	7/7/2016			A/C shop Please repair Heat pump unit #1-55 5th floor room 5016 too hot.
FO-351818	7/7/2016			A/C Shop R/R RM 8405.5 Please repair Heat pump #1-105 8th floor room 8405.5
FO-351829	7/7/2016	7/13/2016		Chill process water loop is hot. Temperature of the recirculating water is too warm to be useful.
FO-352045	7/12/2016	7/13/2016		Refg. Crew/Controls: R/R 00124 Room stat is set to 55 degrees. B.A.S. is showing room set-point at 75 degrees, and room is at 75 degrees. However, V.A.V C124 discharge is showing 62 degrees. I placed Siemens room set-point in manual at 70 degrees to
FO-352176	7/13/2016	7/19/2016		The air-conditioning on the second floor does not appear to be working again. We have it set for 70 degrees but the temperature is 79 degrees.

WO	Recieved	Finished	Total	Request
FO-352228	7/14/2016			BAS Section: R/R PENTHOUSE Please write PPCL coding for ahus 4/5 and exhaust fans 4/5 to allow for a 25% reduction in static pressure for UNOCC. Set up scheduling, trending.
FO-352229	7/14/2016			BAS Section: R/R PENTHOUSE Please write PPCL coding for ahus 4/5 and exhaust fans 4/5 to allow for a 25% reduction in static pressure for UNOCC. Set up scheduling, trending.
FO-352239	7/14/2016			Controls section-R/R room 116 is having a problem keeping the stat temperature setting. it is part of the first floor Herman nelson system which is in the cooling mold only now. the stat should be turning the unit off when the room reaches stat temperatu
FO-352258	7/14/2016			BAS section: R/R BSMT please troubleshoot chiller 3 add/drop PPCL. Chiller not regulating correctly.
FO-352270	7/14/2016			A/C in engineer's office has failed. Repair or replace. please advise.
FO-352320	7/15/2016	7/18/2016		BAS Section: R/R PENTHOUSE Please replace memory card for panel UGL 84. Unable to effectively collect trend data.
FO-352666	7/19/2016	7/20/2016		Controls: Room vav box C124 wall stat is set to the lowest setting, that being 55 degrees. I manually placed room temperature at 71 degrees, and room stays at 71 degrees. However, If I place room stat back to Auto-None setting, vav controls automatical
FO-352665	7/19/2016	7/19/2016		Please replace cam spring on burner assembly.
FO-352712	7/20/2016			Trade: Command CenterPriority: MediumPlease perform burner tune up on boiler #3. Boiler is now online after annual inspection.
FO-352841	7/21/2016			No air. Extremely hot.
FO-352917	7/22/2016	7/25/2016		BAS/Siemens- R/R RM 00187.01/MECH RM Replace failed mixed air sensor on UA1 in the basement.
FO-352954	7/22/2016	7/25/2016		R/R ATRIUM/LOBBY Please have BAS replace stat AO.310.
FO-353047	7/25/2016	7/26/2016		BAS Section: R/R PENTHOUSE Please reprogram chiller plant PPCL to remove emergency priority and replace with smoke priority. Locking up Bacnet/PPCL.
FO-353051	7/25/2016	7/25/2016		Boiler OCC Supplies Vendor: DJ Conley PO: P0742663  Water column Gaskets (8-hole) DL Conley Part # 853-268-8H Qty: 10  Water Column Gaskets (4-hole) DJ Coney Part # 853-555 Qty: 10  Refractory Patch (3 gallon Pail) DJ Conley Part #: TBD Q
FO-353254	7/26/2016			BAS COMMAND CENTER-R/R 4TH FLR NO CONTROL AIR TO WEATHERMASTER TERIMNALS RMS 411,413 &415 CAN'T FIND PROBLEM NEED SOME ASSISTENCE PRIORITY HIGH
FO-353313	7/27/2016	7/28/2016		BAS section: R/R RM 00110 please repair/replace tec heating valve actuator/rewire.
FO-353326	7/27/2016	7/28/2016		BAS Section: R/R PENTHOUSE Please troubleshoot ahu 7 Ramp/pressurization PPCL, as well as check smoke damper positions.
FO-353327	7/27/2016			Bas Section: R/R RM 00010.30 please replace 2 2464 tecs in open study area. error code 128 indicates failure.
FO-353421	7/28/2016			Unit keeps tripping
FO-353402	7/28/2016		7/28/2016	CANCELLED BY REQUESTER  CONTROLS R/R Room 5463 and inner room must be negative to the hall. Carol Dargin must call Honeywell in to do this. Send this request to the command center per Mark Bobbick.
FO-353394	7/28/2016		7/28/2016	Test Work Order
FO-353397	7/28/2016	7/28/2016		Test Work Order

WO	Recieved	Finished	Total	Request
FO-353431	7/29/2016	7/29/2016		Shop Supplies
FO-353438	7/29/2016			Replace cond fan motor
FO-353452	7/29/2016			PARTS FOR ACU IN RM 1114
<b>E - MedPharm</b>			<b>10</b>	
FO-351320	7/1/2016			Office is too hot. No airflow
FO-352039	7/12/2016			The air conditioning has been very cold the past two days, is it possible to turn it down a little?
FO-352194	7/13/2016			Please adjust the air flow of room 256.
FO-352312	7/15/2016			Please help me close the main switch for left water pipe. We do not want to use left water pipe any more. Thank you.
FO-352382	7/18/2016			Inside Suite 206, room 219 and exam room 3, has a problem with the lock on the door, when the key is inserted it will not turn to lock the door.
FO-352383	7/18/2016			Inside suite 206, hallway sink is leaking when in use
FO-352406	7/18/2016	7/18/2016		PIPE LEAK FROM CAGE WASH HALLWAY OUTSIDE OF ROOM 221.
FO-352728	7/20/2016			There was water spilled or a leak in this lab that leaked down to the 4th floor New lab 4331. Appears that there is a crack in the floor that need attention.
FO-352760	7/20/2016	7/20/2016		No air - extremely hot. This issue has been going on now for several weeks.
FO-353404	7/28/2016			NEED ASSISTANCE RE:CONVERSION OF BLDG NEW PHONE SYS UNDER TOM EDWARDS PROJECT CALL 407-6469
<b>E - North</b>			<b>15</b>	
FO-351364	7/1/2016	7/1/2016		Rm 122 HR Office Region B Too Hot in the office.
FO-351361	7/1/2016	7/1/2016		RM 4116 HAS A CEILING LEAK
FO-351881	7/8/2016	7/8/2016		Ceiling tiles are wet, possible water leak in C. Campagna's office.
FO-352031	7/12/2016	7/12/2016		Room 216 plaster ceiling has or had leak above window, plaster debris on window ledge. We need leak & debris repaired to have employee to move in. Please have bldg. engineer see Amy in Art to advise.
FO-352101	7/12/2016			We are hosting another orientation session tomorrow, July 13, starting at 7am in Com Arts Auditorium. On previous orientation dates the room has been uncomfortably cold. We would like to request that the temperature in the auditorium is warmer tomorrow
FO-352370	7/18/2016	7/18/2016		NEED ACCESS TO ROOM 122.
FO-352899	7/22/2016	7/22/2016		Purdy Library, 2nd Floor, Room 231 Staff report that area is too cold. Please adjust the temperature. Thank you.
FO-352902	7/22/2016			It is very warm in rooms 102 and 105. The air conditioning is not working at all in room 102.
FO-352944	7/22/2016			Ceiling leak in 1321.5 Old Maun
FO-352948	7/22/2016			Ceiling leak in hallway outside of 1372. Building Engineer checked on it earlier, but it is dripping heavily again. Ceiling tile may collapse soon.
FO-353036	7/25/2016	7/25/2016		Purdy Library, 1st Floor Room 122 - Offices of Human Resources Region B.  Staff report area is rather warm. Please adjust the temperature. Thank you.
FO-353053	7/25/2016	7/26/2016		Rm 439 Low water pressure in the 4th floor (Custodial closet).
FO-353233	7/26/2016	7/26/2016		PLEASE CALL BRANDON REGARDING AIR CONDITIONING.
FO-353262	7/27/2016	7/29/2016		Water dripping from ceiling in thoroughfare between science/med microform and general microform area on first floor Purdy near north/east exit door. Waste basket in catching drips now.
FO-353391	7/28/2016	7/28/2016		BEEPING SOUND COMING FROM LOBBY.
<b>E - Northeast</b>			<b>17</b>	
FO-351325	7/1/2016	7/1/2016		2ND FLR HALLWAY OUTSIDE OF RM 256 CLNG IS KNG
FO-351594	7/5/2016	7/5/2016	7/5/2016	Third floor water cooled air conditioner is not working. It is plugged in, but the display is not showing anything. Please repair or replace.

WO	Recieved	Finished	Total	Request
FO-351656	7/6/2016	7/6/2016		FIRE TROUBLE ALARM.
FO-351826	7/7/2016	7/12/2016		This is in the storage area 120 for FP&M Archives. The A/C is not working.
FO-351838	7/8/2016	7/8/2016		TOO HOT. 2ND FLOOR.
FO-351874	7/8/2016	7/8/2016	7/8/2016	Anatomy lab room 223 is extremely hot. Please cool down.
FO-351940	7/11/2016	7/11/2016	7/11/2016	Water cooled AC unit on third floor is not cooling sufficiently. Unit is now working and set to cool, but air coming out is not very cool. Second floor unit is having the same problem. Please investigate and correct.
FO-352141	7/13/2016	7/13/2016		please do thermostat check in room 116. contact Mary Barden at 577-1664 for details of problem with temperatures. thank you
FO-352176	7/13/2016	7/19/2016		The air-conditioning on the second floor does not appear to be working again. We have it set for 70 degrees but the temperature is 79 degrees.
FO-352308	7/15/2016	7/15/2016		CALL LT. SMITH AT 577-6059
FO-352947	7/22/2016			R/R HANDICAP DOOR 209 1S The front door of the building keeps getting stuck open and we have to push a button on the door handler to close it.
FO-353123	7/25/2016			There's something leaking into the women's bathroom from the ceiling.
FO-353408	7/28/2016			We would like someone to check on the air-conditioning on the second floor of Tierney House. We believe it might not be working again. The HIGH Staff office is 80 degrees and Mrs. Wilson's office is very warm, too.
FO-353434	7/29/2016			PLEASE CALL GREGORY WITH DTE AT 586-289-3235. NEED TO READ METER.
FO-353463	7/29/2016			DTE NEED ACCESS TO METER RM PLS CALL 586-914-2270
FO-353464	7/29/2016			DTE NEED ACCESS TO METER RM PLS CALL 586-914-2270
FO-353465	7/29/2016			DTE NEED ACCESS TO METER RM PLS CALL 586-289-3235
<b>E - Preventative Maintenance</b>			<b>23</b>	
FO-351640	7/5/2016	7/5/2016		The office is freezing cold. Rooms 4109 and 4107 are pumping out freezing air into the suite space.Thank you,Jackie
FO-351644	7/5/2016	7/5/2016		MEET REPRESENTATIVE FROM EVOLA IN THE BASEMENT OF SCIENCE HALL.
FO-351819	7/7/2016	7/8/2016		Please have university plumbers repair a backflow for an autoclave
FO-351829	7/7/2016	7/13/2016		Chill process water loop is hot. Temperature of the recirculating water is too warm to be useful.
FO-351830	7/7/2016			When entering through the door for room 2348, the sink one the first island to the right needs to be serviced. The drain is clogged (some of our smaller lab items like magnetic stir bars blunt end needles fell through the screen and are stuck in the
FO-351975	7/11/2016	7/11/2016		bldg sewer smell
FO-351978	7/11/2016	7/11/2016		PLEASE CALL EDDIE AT 7-6600.
FO-352092	7/12/2016			MEET PATRICK ERNE IN THE LOBBY.
FO-352273	7/14/2016	7/15/2016		Air is Out
FO-352281	7/14/2016	7/15/2016		AT&T NEED ACCESS TO BASEMENT.
FO-352703	7/19/2016	7/20/2016		ATT NEED ACCESS TO BUILDING.
FO-352708	7/19/2016	7/20/2016		PLEASE CALL ALEX STEPHENS AT 577-2093. REGARDING CONTRACTORS NEEDING ACCESS TO MECHANICAL ROOM.
FO-352783	7/20/2016			Belt Order;  3L350 Qty: 2
FO-352786	7/20/2016	7/21/2016		can you please come check lock in office 3253, key gets stuck in and its very (very) hard to pull out?
FO-352788	7/20/2016			Belt Order  FC270 Qty: 1
FO-352961	7/22/2016			AC unit in room 109 is not cooling and turns on and off by itself. Please repair or replace. Unit is quite old and has had problems in the past.



WO	Recieved	Finished	Total	Request
FO-352966	7/22/2016			Belt Order  5L-480 Qty: 1
FO-352969	7/22/2016			A/C unit not working properly.
FO-353253	7/26/2016	7/26/2016		URGENT. Please check the power supply to the storage area in the basement for Sue's Convenience Store. Tenant is reporting no power and stores inventory in the basement. Charge index if necessary is 113233.
FO-353260	7/26/2016	7/26/2016		PLEASE CALL BRANDON AT 7-2768.
FO-353341	7/27/2016	7/28/2016		West hallway outlet is not working. It's the outlet nearest the west exit on the 1st floor.
FO-353415	7/28/2016	7/28/2016		There is a water leak in the ceiling.
FO-353475	7/29/2016			DTE NEED TO READ METER.
<b>E - South</b>			<b>12</b>	
FO-351378	7/1/2016	7/1/2016		RM 2548 CK BREAKER lights are out, please come and take a look.
FO-351611	7/5/2016	7/5/2016		No DI water in the lab.
FO-351657	7/5/2016	7/6/2016		lock and key to room 2170 is not working properly.
FO-351781	7/7/2016	7/7/2016		NEED ACCESS TO READ METER. PLEASE CALL.
FO-352078	7/12/2016	7/13/2016		Fume hood fan is very noisy. They cannot hear the emergency laboratory phone when it rings. Is there a way to build a enclosure around it to help silence it?
FO-352192	7/13/2016	7/14/2016		Water is leaking under the doors into receiving from the condensate pumps again.
FO-352309	7/15/2016	7/19/2016		CONTACT JOE @77919 FOR AT&T NEED ACCESS TO SMALL BLDG BEHIND BIO SCI
FO-352378	7/18/2016	7/18/2016		FUME HOOD #7 SINK LEAKS AT BOTTOM WHEN FAUCET IS TURNED ON. LAB. 230.
FO-352387	7/18/2016	7/18/2016		TELEPHONE CONTRACTOR NEED ACCESS TO PHONE ROOM.
FO-352762	7/20/2016	7/20/2016		MEET DWSD IN LOBBY NEED ASSISTANCE FOR LOCATING METER
FO-352833	7/21/2016	7/21/2016		RM 1528 C&IT SVC TECH NEEDS ASSISTANCE TO CK ACU (586-894-8273)
FO-352937	7/22/2016	7/27/2016		Lab 3330 has a loud noise coming from the vents where the AC comes out. Its working but loud noise is being reported. Would like someone to come take a look.
<b>E - Southeast</b>			<b>22</b>	
FO-351326	7/1/2016			RM 6303 ACU DOESN'T WORKING UNTIL 12 THEN IT STARTS UP
FO-351735	7/6/2016			The entire 14th floor says their is no air and it is extremely hot.
FO-351795	7/7/2016			NEED TO VERIFY WHICH ELEV IS DOWN FREIGHT/PASS
FO-351936	7/11/2016	7/11/2016		Air conditioning in rooms 101 and 111 not working.
FO-351937	7/11/2016			RM 6203.1 NEED BREAKER RESET
FO-352126	7/13/2016			PLEASE VERIFY A BROKEN WINDOW.
FO-352230	7/14/2016			No air: room is extremely hot.
FO-352375	7/18/2016	7/18/2016		The air conditioner is not working.
FO-352726	7/20/2016			The hose to the bottlewasher filler has come off, needs to be fitted back on. Thank you, Susan
FO-352772	7/20/2016	7/21/2016		Air conditioning is not working.
FO-352810	7/21/2016			METAL STRIP IS HANGING FROM CEILING. 12TH FLOOR EAST END OF BUILDING.
FO-352850	7/21/2016			RM 14200.60 VERIFY WHICH ACU IS W/BLDG OR STANDY BY FOR EQUIP ONLY
FO-353011	7/25/2016			All of my animal rooms are between 76-78 degrees today. Humidity is alright. Susan
FO-353012	7/25/2016	7/25/2016		It is 82 degrees in this office. Too hot.
FO-353048	7/25/2016	7/26/2016		Ceiling is leaking again in the hallway outside of room 1372 Old Main. This is a repeat issue from Friday 7/22/16.  Please forward to Ken Brandt.
FO-353050	7/25/2016			Air Conditioning not working in offices - 13203.1, 13203.2, and 13203.3. Thermostat isn't working. Thank you!
FO-353054	7/25/2016			No air; extremely hot.
FO-353213	7/26/2016			Men's restroom on 3rd floor has a smell inside the vent in the first stall. Also there is a urinal that is clogged. Custodian placed bag over clogged urinal.

WO	Recieved	Finished	Total	Request
FO-353302	7/27/2016	7/27/2016		Air conditioning in rooms 114, 116, and 120 is not working.
FO-353388	7/28/2016	7/28/2016		Loud ticking sound is coming from the ceiling continuously. Please repair.
FO-353389	7/28/2016	7/28/2016		The air conditioning in rooms 114, 116, 120, 123, 124, and 136 is not working.
FO-353451	7/29/2016			Air conditioning is not working in rooms 123, 124, and 136.
<b>E - West</b>			<b>10</b>	
FO-351734	7/6/2016	7/8/2016		Conference room air conditioning unit not working.
FO-352216	7/14/2016	7/18/2016		AC unit not working in office. Electrician (Frank) called.
FO-352416	7/18/2016			Entire building is warm
FO-352756	7/20/2016	7/22/2016		All lights have been out in office for the past couple of days. Breaker might need resetting.
FO-352854	7/21/2016	7/21/2016		No air flow in office; office is very hot
FO-352856	7/21/2016	7/21/2016		Lab is extremely cold -- 63 degrees
FO-352857	7/21/2016	7/22/2016		Lab is extremely cold -- 64 degrees
FO-352858	7/21/2016	7/22/2016		Lab is extremely cold -- 64 degrees
FO-353426	7/29/2016	7/29/2016		PLEASE CALL GREGORY AT DTE AT 586-289-323. NEED TO LOCATE 4TH METER.
FO-353457	7/29/2016			NEED ACCESS TO READ METER. PLEASE CALL GREGORY AT 586-289-3235.
<b>Routine</b>			<b>1</b>	
<b>E - MedPharm</b>			<b>1</b>	
FO-351316	7/1/2016			EM 4461 ENGINEER TO VERIFY WHICH BACKFLOW PREVENTER FOR THIS AREA- medium Priority- R/R RM 4461 Repair leaking backflow preventer in lab 4461.
<b>Grounds</b>			<b>5</b>	
<b>Low</b>			<b>5</b>	
<b>G - Physical Grounds</b>			<b>5</b>	
FO-351391	7/1/2016			Request for tree trimming on tree located on Cass Avenue - closest to the stage door of the Hilberry. Can all the tree branches/leaves please be trimmed above the height of the lollipop lights at entrance to stage door and away from the building? Please
FO-352127	7/12/2016			Outside of parking structure 1 on the side facing Cass and AAB, a trash can was hit by a car and now is junk. It needs to be removed.
FO-352680	7/19/2016			Remove the tree that is growing on the overhang area at the north doors that face chemistry..
FO-353066	7/25/2016			Spread mulch in the early childhood center playground for the Fall Semester. Grounds request
FO-353323	7/27/2016			Power wash and clean the dock area behind McGregor on Monday, 8/1/16.
<b>Trades</b>			<b>662</b>	
<b>Emergency</b>			<b>43</b>	
<b>T - Carpenter</b>			<b>16</b>	
FO-351328	7/1/2016	7/1/2016		EMERGENCY CARP R/R RM 3122/OFC UNABLE TO UNLOCK DOOR W/KEY (NEED ACCESS ASAP)
FO-351387	7/1/2016	7/1/2016		EMERGENCY CARP R/R RM 309/MENS RR OUTSIDE ENTRY DOOR HANDLE IS MISSING
FO-351786	7/7/2016	7/20/2016		KEY FOR DRIVE SHAFT FELL OUT OF EXECUTIVE GARAGE GATE.
FO-351880	7/8/2016	7/8/2016		EMERGENCY CARP R/R RM 258 ENTRY DOOR ISN'T LATCHING CLOSE (Believe its the door jam itself) **SECURITY ISSUE*
FO-351912	7/10/2016	7/11/2016		Old Main - East Main Entry Door 001-01E Door is not securing properly, triggering alarms to Public Safety
FO-351913	7/11/2016	7/11/2016		Old Main - East Main Entry Door 001-02E Door is not securing properly, triggering alarms to Public Safety

WO	Recieved	Finished	Total	Request
FO-351923	7/11/2016	7/11/2016		Urgent - The main door to Suite 4900 will not unlock. We have a coded key pad that shows it unlocked but the trigger in the door doesn't disengage itself. We've had this problem before.  Jackie
FO-351938	7/11/2016	7/11/2016		CARP R/R 5TH FLR WEST SECURITY DOOR (Off of Elevs) INSIDE DOOR HANDLE & CIRCULAR CYLINDER ARE BOTH LOOSE
FO-351956	7/11/2016	7/11/2016		EMERGENCY CARP (Cell #734-609-6688) R/R RM 3133 ENTRY DOOR UNABLE TO LOCK DOOR (SECURITY ISSUE)
FO-352110	7/13/2016	7/13/2016		R/R Office 3157: Door lock is jammed and key is not functioning. Unable to gain access to the office.
FO-352263	7/14/2016	7/15/2016		EMERGENCY CARP R/R RM 00053 ENTRY DOOR LOCK ISN'T LATCHING CLOSE *SECURITY ISSUE*
FO-352806	7/21/2016	7/21/2016		CLOSE DAMAGED AIR DIFFUSER. 1ST FLOOR ATRIUM SOUTH SIDE OF BUILDING.
FO-352910	7/21/2016	7/21/2016		EMERGENCY CARP R/R RM 3022/OFC Core Damaged Key #: 31 BF3 Key Holder ID: Felicia Douglas. Core is damaged; spins completely around, unable to lock door. Located office room #3022 Spoke w/Dave K regarding warranty on door locks. Says that this shoul
FO-352903	7/22/2016	7/21/2016		EMERGENCY/CARP R/R RM 335 UNABLE TO UNLOCK DOOR NEED ACCESS ASAP
FO-353284	7/27/2016	7/28/2016		EMERGENCY EXIT DOOR IS NOT LOCKING. CASS ENTRANCE.
FO-353396	7/28/2016	7/28/2016		DOOR HANDLE HAS BROKEN OFF. DOOR 155-05-E.
<b>T - Electrician</b>			<b>13</b>	
FO-351308	7/1/2016	7/1/2016		Electrician EMERGENCY R/R RM SB47-00000.62/MECH BLR RM Fire pump tripped on motor overload, please repair  EMERGENCY 7/1/16 lps: Spoke w/John C doesn't say which pump so I'm using FP-001
FO-351587	7/5/2016	7/5/2016		Room No. S-B - EP - Dimmer switch is broken
FO-351618	7/5/2016	7/5/2016		WALL OUTLET SPARKS. HOT KITCHEN. SEE DABNEY.
FO-351922	7/11/2016	7/25/2016		SERVICE SUPPLY FAN #10 SPEED DRIVE IS NOT WORKING. PENTHOUSE
FO-351950	7/11/2016	7/22/2016		NO AUDIBLE ALARMS IN PENTHOUSE DURING FIRE ALARMS.
FO-352104	7/13/2016	7/22/2016		EMERGENCY ELEC R/R RM 4258 PLS CHNG OUT THE SMOKE HEAD IN FIRY SYS CAUSING FAP FIRE ALARM BOX @ SECURITY'S DESK TO BE IN ALARM SINCE EARLY MIDNITE 2AM
FO-352201	7/14/2016	7/14/2016		EMERGENCY ELEC R/R BLDG POWER FAIL THRU OUT BLDG CK ALL EQUIP
FO-352209	7/14/2016	7/22/2016		EMERGENCY ELEC R/R 1ST FLR PLS CK FIRE SYS CAUSING FAP FIRE ALARM BOX @ SECURITY'S DESK TO BE IN ALARM SINCE EARLIER THAT MORN
FO-352234	7/14/2016	7/14/2016		NO POWER IN BUILDING.
FO-352716	7/20/2016	7/20/2016		FAULT ON FIRE SYSTEM. FIRE ALARM.
FO-352846	7/21/2016	7/21/2016		ELEC R/R RM 9228 CK POWER SUPPLY THAT LEADS TO AUTOCLAVE BLDG ENG CK'D BREAKER-OK. ELECS' TROUBLESHOOT POWER ON OUR END. IF ITS AUTOCLAVE ISSUE PLS LET OCCUPANTS KNOW TO CALL VENDOR BACK (VENDOR CAME OUT 7/20/16)
FO-352977	7/25/2016	7/25/2016		EMERGENCY ELEC R/R BLDG FAP FIRE ALARM PANEL UNABLE TO RESET
FO-352979	7/25/2016	7/26/2016		EMERGEMNCY/ELEC R/R BSMT AREA FAP FIRE ALARM IS ACTIVE NOW HOWEVER MIDNITE SHIFT HAS FIRE ALARM TROUBLE
<b>T - Pipefitter</b>			<b>6</b>	
FO-351759	7/7/2016	7/7/2016		SUPPLY WATER LINE TO COOLING TOWER LEAKING. LOCATED ABOVE SERVER ROOM.,,,,,,,,,,,,,, CB/7/7 ,,,,,,,,,,,,,,
FO-351764	7/7/2016	7/7/2016		Ceiling leak inside entrance door off ally ,,,,,,,,,,,,,, JH/7/7 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-351863	7/8/2016	7/8/2016		GASKET LEAK ON NON RETURN VALVE ON BOILER #2.....JH/RC....7-8-16
FO-352978	7/25/2016	7/25/2016		**TURNED OVER TO SHAMBAUGH FIRE PROTECTION 7/25 DB/*JT  EMERGENCY PIPEFITTERS R/R BLDG FAP FIRE PUMP #1/MAIN ISOLATION VALVE IS LEAKING BAD.....CB.....7/25/16
FO-353279	7/27/2016			REPAIR CONTROL AIR LINE ON AIR HANDLER AC5C. ROOM 3220. .... ME/7/27 .....
FO-353283	7/27/2016			EMERGENCY PIPE R/R RM 00000.62/MECH BLR RM DISCONNECT PIPING FOR WATER SOFTNER ..... CB/7/27 .....
<b>T - Plumber</b>			<b>8</b>	
FO-351319	7/1/2016	7/1/2016		EMERGENCY/PLUM R/R RM 00413 FLR DRAIN IS PLUGGED ..... MM/7/1 .....
FO-352068	7/12/2016	7/12/2016		EMERGENCY PLUM R/R RM 00153/TARTER SHOP BOTH SINK DRAINS ARE PLUGGED (Note: there is an event today need cleared ASAP pls).....TT/MF
FO-352328	7/15/2016			PLUM R/R RM 1362/MENS RR ALL 4 URINALS AREN'T FLUSHING DRAINS ARE PLUGGING UP STARTING TO STINK ..... TT/7/15 .....
FO-352372	7/18/2016	7/18/2016		BUSTED SPRINKLER SUPPLY LINE. BASEMENT MECHANICAL ROOM 0530.....TT.....7/18/16
FO-352765	7/20/2016			EMERGRNCY/PLUMB R/R RM 00354/GROSS LAB SINK TO THE FAR (R) 1 OUT OF 2 SINKS THAT HAVE A GARBAGE DISPOSAL SHOOTS UP/OUT DEBRIS WHEN IN USE.....TT.....7/20/16
FO-353288	7/27/2016			TOILET PLUGGED AND OVERFLOWING. 3RD FLOOR MEN'S RESTROOM. .... MM/7/27 .....
FO-353306	7/27/2016			PLUM R/R WDET @ FRONT ENTRANCE ONLY WOMENS RR ONLY TOILET ISN'T FLUSHING ..... MM/7/27 .....
FO-353450	7/29/2016			EMERGENCY PLUM R/R RM 00148/WOMENS RR 4TH STALL TOILET IS CON'T FLUSHING @ VERY HIGH & FAST RATE ABOUT TO OVERFLOW.....TT.....7/29/16
<b>High</b>			<b>166</b>	
<b>T - Carpenter</b>			<b>36</b>	
FO-351384	7/1/2016	7/5/2016		R/R 3RD FLR HALLWAY OUTSIDE OF RM 313 SEVERAL FLR TILES ARE BUCKLING UP CAUSING TRIP HAZARD
FO-351586	7/5/2016	7/7/2016		MAIN ENTRANCE HANDICAP DOOR BUTTON IS NOT WORKING. DOOR WILL NOT OPEN.
FO-351585	7/5/2016	7/22/2016		Carpenters, please construct scaffolds needed in Lectures Halls. Blue Lecture Hall rm. 3312 Green Lecture Hall rm. 3324 Jaffar Lecture Hall rm. 3356 See Pat Bologna for direct locations in rooms.
FO-351646	7/6/2016	7/6/2016		AAB - Southeast Stairwell Exit - Door 062-08 South - door is not properly securing, setting off alarms each night to Public Safety
FO-351712	7/6/2016	7/7/2016		Office door key is sticking in the lock and is difficult to turn.
FO-351740	7/7/2016	7/8/2016		Rackham Bldg - Doors 1 & 2 North are not properly securing, triggering alarms to Public Safety
FO-351835	7/8/2016	7/11/2016		Trade: Carpenter Priority: High Door 08W need door closer adjustment.
FO-351963	7/11/2016	7/12/2016		PUTNAM SIDE HANDICAP DOOR BUTTON IS NOT WORKING.
FO-351966	7/11/2016	7/12/2016		PUTNAM SIDE HANDICAP DOOR IS STAYING OPEN AND SOMETIMES LOCKING, THINKS THIS COULD BE BECAUSE THE LOCK IS NOT ALIGNED UP CORRECTLY.
FO-352022	7/12/2016	7/13/2016		CARP R/R INSIDE HANDICAP ENTRY DOOR BUTTON FOR DOOR #071-008E WORKS INTERMENTENTLY
FO-352058	7/12/2016	7/13/2016		WOODWARD ENTRANCE DOOR STAYS OPEN.
FO-352245	7/14/2016	7/15/2016		R/R RM 6258 KEYS ARE STICKING IN DOOR LOCK VERY HARD TO MANEUVER TO UNLOCK/LOCK DOOR

WO	Recieved	Finished	Total	Request
FO-352355	7/16/2016	7/19/2016		Request Carpenter to reattach 2 door closer to 2 separate doors located in the Studio Theatre (Downstairs from Hilberry)  There are 2 doors that have the door closer unattached and they need to be reattached.  High Priority Please : One of the doors
FO-352391	7/18/2016			Trade: CarpenterPriority: HighPlease repair the wall that surrounds the cooling towers. Brick work has pulled away from the vertical posts and is leaning towards the edge of the roof. Wall will fall over the edge when it breaks completely free.
FO-352393	7/18/2016	7/19/2016		please have locksmith check key and lock for building coordinator at mazurek. key sticking in locks room 219 exam room #3. HIGH PRIORITY
FO-352426	7/18/2016			PROJECTION SCREEN WILL NOT GO UP, STUCK IN DOWN POSITION. ROOM 116.
FO-352725	7/20/2016	7/25/2016		*****ADDING CARPENTERS***** Please have carpenters open up wall to add backing to support Lav. See Troy Taylor OR Mike Fredrick lavatory sink is falling off the wall in the Unisex bathroom across from the 4th floor Conference room.....DB.....,7/19/16
FO-352730	7/20/2016	7/22/2016		CARP R/R RM 00414/DLAR ENTRY DOOR ISN'T CLOSING COMPLETELY
FO-352732	7/20/2016	7/21/2016		R/R RM 00133/DISPATCH Door handle on north lobby door to dispatch doesn't return to detent.
FO-352746	7/20/2016	7/21/2016		1st floor NE stairwell (stair D, 190.16) door handle is broken. The handle is in the 'push down' position and does not go back up once the door shuts. Jackie Baldyga- room 169. 7-2057 for more information
FO-352778	7/20/2016	7/21/2016		please have carpenters make a cover for a hole in the upper roof to prevent water from entering the penthouse down below. high priority.
FO-352797	7/20/2016	7/21/2016		R/R RM 3253 KEYS ARE STICKING IN DOOR LOCK CAN ONLY MANEUVER DOOR LOCK WHEN UNLOCKING/LOCKING CANNOT REMOVE KEY TO LOCK UP can you please come check lock in office 3253, key gets stuck in and its very (very) hard to pull out?
FO-352865	7/21/2016	7/26/2016		Replace damaged ceiling tiles in Chief Holt's office
FO-352938	7/22/2016	7/25/2016		R/R BSMT/Stairwell "A" in the basement. Door handle will not engage. You can not open the door when trying to go from the basement to the first floor. Please fix ASAP due to school starting on Monday July 25, 2016
FO-352952	7/22/2016			CARPENTERS (OKAY FOR MONDAY MORN HANDICAP ELECTRICITY SHUT OFF FOR NOW STILL CAN PULL DOOR OPEN TO GET IN **SEE RESULTS**) R/R HANDICAP DOOR #209 01S TROUBLESHOOT DOOR CLOSURE & INSIDE/OUTSIDE PUSH BUTTONS DOORS STICKS OPEN WHEN ACTIVATING BUTTONS
FO-352981	7/25/2016	7/26/2016		CARP R/R ENT DOOR #060-005N CORE KEEPS TURNING UNABLE TO ENTER THE BLDG
FO-352982	7/25/2016	7/26/2016		CARP R/R 2ND FLR MENS RR (Right off of elevs) OUTSIDE ENTRY DOOR HANDLE IS BROKEN
FO-352998	7/25/2016	7/26/2016		R/R ENTRY DOOR #091 02W The arm on the main entrance door is broken. There is no way to make sure the door stays closed while it is unlocked, and the handicap access will not work. I had a note left on my door that said it broke Saturday.
FO-353064	7/25/2016			R/R RM 2216 Lock on ladies restroom is not releasing when you leave. Someone may get trapped in the room.
FO-353067	7/25/2016	7/26/2016		CARP R/R HANDICAP ENTRY DOOR #071-02N (PUTNAM SIDE) BOTH INSIDE/OUTSIDE PUSH BUTTONS AREN'T WORKING
FO-353068	7/25/2016	7/26/2016		CARP R/R HANDICAP ENTRY DOOR #155-01E (ON CAMPUS SIDE ENT) BOTH INSIDE/OUTSIDE PUSH BUTTONS AREN'T WORKING
FO-353216	7/26/2016	7/28/2016		DAMAGED AND MISSING FLOOR TILES. TRIP HAZARD. 3RD FLOOR NEAR ELEVATOR.
FO-353290	7/27/2016	7/28/2016		Loading dock double doors into hallway will not open
FO-353295	7/27/2016			Outside hydraulic lift for loading dock is not working. Please check both for repair. HYDRAULIC LEAK.
FO-353384	7/28/2016			CARPENTRY DEPT- PLEASE REPAIR ENTRANCE DOOR HANDLE DOOR 155 05 E, EAST SIDE OF BLDG,HANDLE ABOUT TO FALL OFF PRIORITY HIGH

WO	Recieved	Finished	Total	Request
FO-353410	7/28/2016	7/28/2016		R/R RM 4900 Our front/main door's lock will not disengage again after we enter the code. We have it propped open for now but please send someone to fix it. 7/28/16 lps: Spoke w/Jackie to initiate another req w/acct # under Just Do It. For the Key Pad
<b>T - Electrician</b>			<b>59</b>	
FO-351309	7/1/2016	7/1/2016		**ADDING LABORER: Please pick up piping debris in basement , See Troy Taylor if needed  BSMNT NEAR FILTERS ACTIVE LEAK FROM RISING PIPE ,,,,,,,,,,,,,, *TT/JH/6-2-16 ,,,,,,,,,,,,,
FO-351318	7/1/2016	7/1/2016		Trade: Electrician Priority: High R/R RM 00000/62/MECH BLR RM Sanitary sump pump #1 in the Chemistry sub-basement is not running. Please repair.
FO-351323	7/1/2016	7/1/2016		Reinstall wooden gate arm broken off on entrance to upstairs parking.(downstairs near stockroom)
FO-351381	7/1/2016	7/13/2016		EMERGENCY ELEC R/R RM 2548 PLS CK LITE SWITCH BREAKER IS OK HOWEVER NO LITES lights are out, please come and take a look.
FO-351655	7/6/2016	7/6/2016		Light Pole hit by Public Safety Vehicle.  Location between St. Andrews Church and PS #2.  Marked with cones and caution tape.
FO-351659	7/6/2016	7/7/2016		Please change out LIGHTS in the painters cage-lockup on 3rd floor.
FO-351660	7/6/2016	7/6/2016		Time for Laborer to drop off and pick up Generator for temp power for Market Day. Wednesday, 10:30 am to 3:00 pm.
FO-351661	7/6/2016	7/6/2016		Meet DTE and Engineering basement main gear room Wednesday 7:00 am. Put Building power back into full service.
FO-351677	7/6/2016	7/6/2016		Trade: Laborer Priority: High  Please deliver a pallet of water softener salt on Thursday 7-7-16. I will be off on Friday and it takes two of us to hustle the salt.
FO-351741	7/7/2016	7/7/2016		fire alarm panel in trouble. will not reset.
FO-351742	7/7/2016			Laborer, please move a pedestal fan to room 431 State Hall. Until repairs are made on AHU in building. Bring back after repair.
FO-351791	7/7/2016			Electrician R/R PH please troubleshoot #3 cooling tower fan,it will not start.Priority High
FO-351846	7/8/2016	7/8/2016		trade electrician priority high R/R PENTHOUSE please service air handler unit #6 return air fan speed drive not working
FO-351873	7/8/2016	7/11/2016		R/R RM 1030 LOST POWER AGAIN TO WALL OUTLET THAT SUPPLIES POWER TO THE 3 CAGED ROBOTS (has had no power for a couple of days believe it started w/power bump last week)
FO-351885	7/8/2016	7/11/2016		EMERGENCY ELEC R/R LOBBY/RM 1315 FAP NEEDS BATTERIES UNABLE TO SILENCE ALARM fap fire trouble alarma active
FO-351901	7/8/2016			ELEC R/R RM 1200/CONF RM UNABLE TO TURN OFF LITES
FO-352106	7/13/2016	7/19/2016		Deliver one pallet of salt, 4 gasket kits, 8 Lokor 5-gal, 2 Halchlor C 5-gals, 2 Oxycor S1100 5-gals to Chatsworth boiler room
FO-352109	7/13/2016	7/14/2016		ELECTRICIANS: R/R RM 4545 Please repair south light switch in room 4545 bad short. HIGH.
FO-352134	7/13/2016			ELECTRICIANS TO REMOVE 2 EXIT SIGNS 12TH FLOOR EAST OF THE LOBBY SEE PAT OR ED
FO-352142	7/13/2016			Please inspect and repair Emergency Exit lighting pods throughout the building. Some are in need of their batteries being replaced.
FO-352143	7/13/2016			Emergency light inside the Welcome Center Auditorium is consistently beeping, please see if we can get this to stop, we have several symposiums this week from the Vice President of Research office.
FO-352158	7/13/2016			Trade: Electricians Priority: High R/R BLDG/1ST FLR Please repair fire alarm system. There are troubles that will not reset.

WO	Recieved	Finished	Total	Request
FO-352160	7/13/2016			ELECTRICIANS, R/R RM 00347.10 PLEASE CORRECT FAULT ON FIRE ALARM PANEL. PRIORITY-HIGH
FO-352236	7/14/2016			REPAIR FIRE ALARM. (FIRE TROUBLE ALARMS).
FO-352264	7/14/2016			Electrician R/R RM 6102/MECH RM repair AHU-4 VFD fault after power outage. (POWER BUMP APPR 10:38AM) (says okay for Friday Morn)
FO-352331	7/15/2016	7/15/2016		Mark Bobick Requested WSU. Electrician, Due to SPARKING & ARCING Up around COOLING TOWER.
FO-352371	7/18/2016	7/19/2016		please have laborer deliver 1 pallet of salt for cooling towers. high priority.
FO-352390	7/18/2016	7/18/2016		Electricians, meet Travis from PM Tech and let him in Generator to repair low coolant sensor.
FO-352428	7/18/2016	7/19/2016		please have laborer deliver 4 kegs of halochlor to the penthouse #327323 high priority.
FO-352626	7/19/2016	7/19/2016		Electricians  Repair/Replace transformer in electrical room 4173 is making loud buzzing noise.  HIGH PRIORITY
FO-352638	7/19/2016	7/19/2016		Electricians, meet PM Tech and open generator gate and building for generator repairs.
FO-352698	7/19/2016	7/20/2016		REPAIR LIGHT FIXURE. LIGHT BEEPING OUTSIDE OF ROOM 343.
FO-352724	7/20/2016	7/21/2016		trade electricians priority high R/R PENTHOUSE please service air handler unit #8 located in pint house area supply fan speed drive is in alarm
FO-352796	7/20/2016	7/22/2016		R/R 4TH FLR HALLWAY OUTSIDE OF RM 427 2 EMERGENCY LITING NEEDS BATTERIES REPLACED CON'T BEEPING
FO-352800	7/21/2016			Trade: Electrician Priority: High Fire alarm in trouble. City Tie
FO-352844	7/21/2016	7/22/2016		ELECTRICIANS R/R 2ND FLR SUPERVISOR/WOMENS LOCKER RM (ONLY SUPERVISORS WOMENS LOCKER RM) BURNT OUT LITES WERE REPLACED & NOW THERE IS STILL NO LITES CK BREAKER/POWER TO CLNG LITES
FO-352864	7/21/2016	7/26/2016		**ADDING ELECTRICIAN: 1st floor mens room by Guard Plumber needs solenoid to urinal bank disconnected for Plumber to install, please rewire. See Mike McAlinden  Mens room 1st floor guard side repair toilets ,,,,,,,,,, MM/7/7 ,,,,,,,,,
FO-352927	7/22/2016	7/25/2016		trade electricians priority high R/R PENTHOUSE please service air handler #8 speed drive is in alarm and will not start unit on the supply fan
FO-352922	7/22/2016	7/25/2016		ELEC R/R RM 3125/CLASS RM LITE SWITCH ISN'T WRKNG
FO-353061	7/25/2016	7/26/2016		Electrician R/R BLDG repair generator over current alarm. Priority high. Generator may not start on next outage.
FO-353063	7/25/2016	7/27/2016		Electrician R/R PENTHOUSE repair cooling tower #3 high speed. Trips overload. EQUIP NOT AVAIL IN TMA SYS
FO-353115	7/26/2016	7/26/2016		ELEC R/R ERM 1131 (Pls note WO stats Rm 1209 however, system has above Rm #) REPAIR TAMPER SWITCH IN FIRE ALARM PANEL RM 1209 WO #FO-352975-Repair fire panel trouble at Law School, "1st Floor tamper, fire equipment room".{Phil/Steve assigned on 7/25/16}
FO-353224	7/26/2016	7/27/2016		Electricians: R/R RM 00495/MECH BLR RM Please repair/replace wet vacuum on-off toggle switch. High Priority.
FO-353222	7/26/2016			Electricians meet Fire Alarm Systems of Mich 4th floor. Troubleshoot short in circuit 58.
FO-353245	7/26/2016			ELECTRICIANS, R/R LOBBY PLEASE REPAIR TROUBLE CONDITION ON FIRE ALARM PANEL. PRIORITY-HIGH

WO	Recieved	Finished	Total	Request
FO-353267	7/26/2016	7/27/2016		Electricians, High, R/R BSMT STORAGE AREA No power to basement storage area, reset breaker and heard popping sound in panel. Store on 1st floor stores supplies in storage area.
FO-353269	7/27/2016	7/27/2016		James deliver the 2 fans to the Reuther Library first thing in the morning. James knows what fans to bring to the Library. See Mark B for the locations of the fans.
FO-353289	7/27/2016			Electrician, meet Henrietta at Elevator. Trouble shoot (2) light fixtures. After 9:30 am Wed.
FO-353328	7/27/2016	7/27/2016		Electricians, meet in main switch room, verify spare 250a breaker is available. Wed 2:30 pm.
FO-353350	7/28/2016	7/27/2016		No power to rack washer rm0225. Electricians please check power.
FO-353351	7/28/2016			ELEC R/R RM 3232/WOMENS RR ONLY HAND DRYER IS CON'T RUNNING WILL NOT SHUT-OFF
FO-353353	7/28/2016			ELECTRICIANS, R/R RM 00347.10 PLEASE CORRECT FAULT ON FIRE ALARM PANEL, (ckt:1 dev:21 sprinkler water flow , 2nd flr B east) PRIORITY-HIGH
FO-353419	7/29/2016			Electricians check Fire Alarm panel. The panel is in trouble.
FO-353428	7/29/2016			Trade: Electrician Priority: High Follow Up To FO 353425 R/R 1ST FLR Please reset fire alarm trouble for configuration error.
FO-353433	7/29/2016			R/R 1ST FLR FAP please have electricians check visual alarm on the 6th floor. visual alarm 2-sig-15. alarm sounding on 1st floor. high priority.
FO-353446	7/29/2016			Trade; Electrician Priority: High R/R PENTHOUSE Speed drive not working for AHU#8 supply fan, please repair or replace.
FO-353453	7/29/2016			Lights are blinking in Room 4705. Please correct problem. There are 4 lights out along back wall...This will be handled by electricians....
FO-353467	7/29/2016			Electrician, verify power to SF-6. Penthouse mech room.
FO-353478	7/30/2016			Laborer, pick up and transport wooden barriers to rear dock of Bookstore.
<b>T - Locksmith</b>			<b>6</b>	
FO-351576	7/5/2016	7/25/2016		New Key Lost / Stolen Key #: SL-147 Key Holder ID: Jackie Wiertella Qty: 2  action: 2-SL-147 DESK KEYS
FO-351648	7/6/2016	7/8/2016		New Key Lost / Stolen Key #: LS04 Key Holder ID: Kimberly Rize Qty: 1  action: 1- Cabinet key
FO-352805	7/19/2016	7/28/2016		New Key New Space Assignment Key #: 110766 Key Holder ID: Mark Gibbons Qty: 1  action: Need key to access Carriage house for cabling contractor and installation of Cameras.



WO	Recieved	Finished	Total	Request
FO-352743	7/20/2016	7/20/2016		<p>New Key New Staff Member Key #: 31 BE3 Key Holder ID: Theresa Y. Hill / Jhonny Jean-Lewis Qty: 3</p> <p>action: Please duplicate 3 keys for room 0155 in the IBio building. This is a request for Dr. Baker . Thank you! Account #: 146655</p>
FO-353044	7/25/2016			<p>New Key New Staff Member Key #: B311 Key Holder ID: Jason Davis Qty: 1</p> <p>action: New key for football building restrooms for contractor sign-out. Need asap. Account #: N/A</p>
FO-353378	7/28/2016			<p>New Key Lost / Stolen Key #: 27282 Key Holder ID: Julie Miller Qty: 2</p> <p>action: 2-KEYS # 27282 for room 4282</p> <p>High Priority</p>
<b>T - Painter</b>				<b>1</b>
FO-352148	7/13/2016	7/15/2016		<p>please have painters remove chipped paint from filter box so I can remove and replace filters to facilitate air movement in lab. high priority.</p>
<b>T - Pipefitter</b>				<b>16</b>
FO-351376	7/1/2016	7/6/2016		<p>Trade: Pipefitter Priority: High R/R RM 00000.62/MECH BLR RM The domestic hot water heat Exchanger in the Chemistry boiler room is leaking water into the condensate. Please repair..... ME/7/1 .....</p>
FO-351768	7/7/2016	7/7/2016		<p>FITTERS: Please inspect / replace Stop Valve on AHU#8. Leaking. HIGH..... JH/7/7 .....</p>
FO-352145	7/13/2016	7/14/2016		<p>CEILING PIPE LEAK. ROOM 10.06.....JH.....1-13-16</p>
FO-352196	7/14/2016	7/14/2016		<p>Trade: Pipefitter Priority: High R/R RM 1342/CLASS RM Blow out condensate pipe from A/C unit to slop sink in this lab 1342, condensate is dripping from A/C unit on to a high cost laser. .... ME/7/14 .....</p>
FO-352199	7/14/2016	7/14/2016		<p>Trade: Pipefitter Priority: High R/R BSMT Please replace leaking isolation valve and change actuator for the control valve to a 3 - 8 psi spring range from the present 10 - 15 psi spring range. See engineer for the exact location. General location is</p>
FO-352293	7/15/2016	7/18/2016		<p>Trade: Pipefitter Priority: High R/R RM 3025 Please repair or replace faulty DanFoss valve for the window convector in lab 3025 - Science Building. .... JH/7/15 .....</p>
FO-352305	7/15/2016			<p>PIPEFITTERS R/R BSMT HALLWAY OUTSIDE OF RM 221 REPAIR MAIN STEAM LINE STM TRAP IN CLNG - LEAKING (NOTE: TILES HAVE BEEN REMOVED &amp; A BARREL PLACED UNDERNEATH ..... CB/7/15 .....</p>
FO-352337	7/15/2016	7/18/2016		<p>PIPE R/R RM 315 REPAIR FAN COIL UNIT THAT'S LKNG IN CLNG (ENG HAS IT ISOLATED).....ME.....7/18/16</p>
FO-352358	7/17/2016	7/18/2016		<p>Fitters: please repair or replace leaking trap, isolation valves are closed, priority high.....JH.....7/18/16</p>
FO-352359	7/17/2016	7/19/2016		<p>Fitters: please seal drain pan to cage washer exhaust exchange and remove drain line to see if pan is plugged, priority high.....JH.....7/18/16</p>

WO	Recieved	Finished	Total	Request
FO-352764	7/20/2016	7/21/2016		Hot water coming out of taps is scalding hot. Too hot. This is the 2nd time in a week. Investigate why,,,,,JH,,,,,7/20/16 this is happening.
FO-352775	7/20/2016	7/22/2016		Trade: Pipefitter Priority: High Please repair or replace 1 1/4" Honeywell steam valve. The stem is sticking and is very hard to move. Valve is located in the plenum for AHU #2. Contact engineer for the exact location.,,,,,,,,,,,,,, *JH/ME/7/21
FO-352991	7/24/2016	7/25/2016		Fitters: R/R RM 2230 Please repair or replace bad steam trap, on drip leg from main steam line to autoclave, Priority high,,,,,,,,,JH,,,,,,7/25/16
FO-353016	7/25/2016	7/25/2016		Fitters R/R PENTHOUSE please repair leak in steam coil on AHU-1. Priority: high,,,,,,,,,CB,,,,,7/25/16
FO-353040	7/25/2016			Steamfitter R/R RM 00121/LAB please replace leaking 3/way hydronic valve above ceiling. Priority HIGH FO-353025 ,,,,,,,,,, ME/7/26 ,,,,,,,,,,
FO-353382	7/28/2016			Fitters please repair leak in steam coil on AHU-1. Priority: high,,,,,,,,,ME,,,,,,7/29/16
<b>T - Plumber</b>			<b>45</b>	
FO-351386	7/1/2016			Trade: Plumber Priority: High R/R RM 00000.62/MECH/BLR Please repair or replace sanitary sump pump #1 located in the Chemistry sub-basement. Seal is leaking. Bearings are noisy. Check valve is leaking through causing the pump to rotate backwards wh
FO-351392	7/1/2016	7/5/2016		ON July 5TH turn water off or remove handle of listed drinking fountains and sinks at: -Matthaei fountain outside room 251 -Manoogian kitchen sink in room 597 -Lande sink in room 458 -Engineering fountain outside room 2310 **See Attached Email ,,,,,,
FO-351574	7/5/2016	7/5/2016		chk leak under kitchen sink....TT
FO-351694	7/6/2016	7/7/2016		CEILING LEAK. ROOM 2038. ,,,,,,,,,, *TT/JH/7/6 ,,,,,,,,,,
FO-351771	7/7/2016	7/8/2016		Do walk through 1st thing Friday 7/8 from water shut down at: -Beecher -5447 -5425 -5435 -Mort Sci ,,,,,,,,, DB/7/7 ,,,,,,,,,,
FO-351799	7/7/2016	7/8/2016		R/R 3RD FLR DRINK FOUNT NEAR RM 00331 THE LOWER LEVEL (Handicap) FOUNT IS PLUGGED & LEAKING FROM UNDERNEATH ,,,,,,,,,, TT/7/7 ,,,,,,,,,,
FO-351832	7/8/2016	7/8/2016		please pump out loading dock (flooded)....MM
FO-351840	7/8/2016	7/8/2016		Plumbers: Please repair or replace sump pump next to AHU-1 in mechanical room, it has failed overnight and flooded the mechanical room. Priority: high.....TT
FO-351854	7/8/2016	7/8/2016		Please check water upstairs, in particular, the restrooms and the water in the laundry tub outside of Doug O'Brien's office. Brown and sludgy. Thanks, Sandy....DB...
FO-351921	7/11/2016	7/12/2016		FAUCET CONTINUOUSLY RUNNING. ROOM 0413.MM
FO-351931	7/11/2016	7/12/2016		HOT WATER IS TOO HOT. 2ND FLOOR.MM
FO-352034	7/12/2016	7/12/2016		Plumbers: R/R RM 00018/MECH RM Floor drain next to domestic booster pumps in lower level mechanical room is backing-up. Please clear floor drain. High Priority.GS...7-12-16
FO-352041	7/12/2016	7/13/2016		Plumbers- R/R 10TH FLR please change 10th floor backflow preventer drain line from direct to indirect. High Priority FOR COT ON 11TH FLR HOWEVER DRAIN IS LOCATED 10TH FLR.....DB...7-13-16
FO-352154	7/13/2016	7/14/2016		FAUCET LEAK. LEFT SINK. 3RD FLOOR MEN'S RESTROOM.....TT
FO-352278	7/14/2016	7/14/2016		Walk through all bathrooms after DWSD water shut down on 7/14 at 10:00am ,,,,,,,,,, DB/7/14 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-352279	7/14/2016			R/R RM 304/WOMENS RR (INSIDE STE 300) ONLY SINK THE FAUCET IS LKNG & ALSO SINK DRAIN IS PLUGGED ,,,,,,,,,,MM/7/15 ,,,,,,,,,,
FO-352354	7/16/2016	7/18/2016		Plumbers  Repair leaking backflow preventer on Fume Hood #5,,,,,,,,,GS,,,,,,,,7/18/16  High Priority
FO-352352	7/17/2016	7/18/2016		*DUPLICATE/REFER TO WORK ORDER FO#352372 JWT  Repair leak from lawn sprinkler supply line located in basement pump room 0530 at UGL. Water is leaking from the plastic threads of a flow meter above the fire pump. Perhaps 1/4 gallon per minute. Floor drai
FO-352392	7/18/2016	7/21/2016		please have plumbers repair leaking faucet across room 212.10 in mazurek. high priority,,,,,,,,,MM,,,,,,,,7/18/16
FO-352394	7/18/2016			URINALS NOT FLUSHING PROPERLY. LOW WATER PRESSURE. MEN'S RESTROOM. ROOM 1362,,,,,,,,,MM,,,,,,,,7/18/16
FO-352398	7/18/2016	7/19/2016		Trade: Plumber Priority: High Follow Up to FO 352378 Please repair leak from sink across from fume hood #7. Leak appears to be coming from the trap,,,,,,,,,TT,,,,,,7/18/16
FO-352408	7/18/2016	7/18/2016		Purdy Library 4th Floor Women's restroom: toilet flushed continuously (looks like the valve is stuck). Please repair,,,,,,,,,TT,,,,,,,,7/18/16  Thank you.
FO-352629	7/19/2016	7/19/2016		PLUGGED SINK. 1ST FLOOR MEN'S RESTROOM NEAR LUNCH ROOM,,,,,,,,,TT,,,,,,7/19/16
FO-352641	7/19/2016	7/19/2016		Please plunge the toilets in the men's room by the lunchroom, 1st Floor, by Design & Construction,,,,,,,,,TT,,,,,,7/19/16 Svcs. Thanks!
FO-352667	7/19/2016	7/25/2016		lavatory sink is falling off the wall in the Unisex bathroom across from the 4th floor Conference room,,,,,,,,,DB,,,,,,,,7/19/16
FO-352715	7/20/2016	7/25/2016		WATER COMING UP FROM FLOOR DRAIN. ROOM 0520,,,,,,,,,TT,,,,,,7/20/16  **POWERVAC ADDED TO CAMERA AND JET 7/22 JWT
FO-352723	7/20/2016	7/21/2016		PLUM R/R RM 2139/UNISEX RR ONLY TOILET IS PLUGGED ABOUT TO OVERFLOW,,,,,,,,,MM,,,,,,,,7/20/16
FO-352776	7/20/2016	7/21/2016		Trade: Plumber Priority: High Please repair leak from the sewer line in the plenum. See engineer for the exact location and easiest method to get there. Line is about 6" and is different from the one just repaired. ,,,,,,,,,TT/7/21 ,,,,,,
FO-352812	7/21/2016			Plumbers: Domestic booster pump #2 shaft seals are leaking and need replacement. Please repair. High Priority. ,,,,,,,,,,GS/7/21 ,,,,,,,,,,
FO-352863	7/21/2016			PLUMBERS R/R RM 9126 ONLY SINK IS LKNG (BLDG ENG ISOLATED WATER) ,,,,,,,,,,MM/7/22 ,,,,,,,,,TTTTTTTTTTTT
FO-352990	7/24/2016			Plumbers: R/R RM 2241 Please repair or replace leaking patch on 1" copper, Priority High.....GS,,,,,7/25/16
FO-353005	7/25/2016	7/26/2016		R/R 3RD FLR WOMENS RR (Only one on flr) OFF OF ELEV ONLY SINK IS LEAKING FROM UNDERNEATH,,,,,,,,,TT,,,,,,7/25/16
FO-353006	7/25/2016	7/26/2016		R/R RM 2105 ONLY SINK IS LEAKING FROM UNDERNEATH.....GS.....7/25/16
FO-353052	7/25/2016	7/26/2016		PLUM R/R 2ND FLR WOMENS RR (Only one on flr) ONLY TOILET CON'T FLUSHING.....TT.....7/25/16
FO-353234	7/26/2016			BROWN WATER IN TOILETS. 3RD AND 4TH FLOOR RESTROOMS,,,,,,,,,GS/ 7/26 ,,,,,,,,,TTTTTTTTTTTT
FO-353251	7/26/2016			Please do walk through Stadium Aux building and check all plumbing fixtures from scheduled water shut down from 7/26 ,,,,,,,,,,GS/7/26 ,,,,,,,,,,
FO-353285	7/27/2016			FAUCET CONTINUOUSLY RUNNING. ROOM 2800. ,,,,,,,,,,DB/7/27 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-353344	7/27/2016			TOILET IS GURGLING. 2ND FLOOR UNISEX RESTROOM..... MM/7/28 .....
FO-353395	7/28/2016			**WORK IN PROGRESS JWT 7/28  BACKFLOW PREVENTER LEAKING BADLY. ROOM 9228. .... DB/7/28 .....
FO-353409	7/28/2016			Plumbers, R/R 4TH FLR/N please repair glass drain inside 4th floor pipe chase 4N. Priority: high.....MM.....7/29/16
FO-353436	7/29/2016			PLUGGED SINK. CUSTODIAL CLOSET. ROOM 382.....GS.....7/29/16
FO-353437	7/29/2016			R/R 1ST FLR Breezeway WOMENS RR ONE OF THE TOILETS CON'T RUNNING WILL NOT SHUT OFF.....TT.....7/29/16
FO-353454	7/29/2016			PLUN R/R RM 2353 ONLY EYE WASH IS PLUGGED UP .....MM.....7/29/16
FO-353458	7/29/2016			Faucet dripping in kitchen.....GS.....7/29/16
FO-353471	7/29/2016			PLUM R/R RM 8244 REPAIR LEAKING CEILLING DRAIN PIPE IN RM
<b>T - Roofing</b>			<b>3</b>	
FO-351362	7/1/2016			ROOFER/CONTRACTOR R/R 2ND FLR HALLWAY OUTSIDE OF RM 256 REPAIR ROOF LEAK
FO-352140	7/13/2016			ROOF LEAK. ROOM 4236.
FO-352169	7/13/2016			ROOF LEAK. ROOM 4069.
<b>Medium</b>			<b>91</b>	
<b>T - Carpenter</b>			<b>20</b>	
FO-351600	7/5/2016	7/13/2016		please open up wall near radiator on 7-6-16 at 7:30 am, see Corey if u need more info (fo351227)
FO-351770	7/7/2016	7/8/2016		Locksmith: please repair door lock on the door to mechanical room 24 on 1st floor next to stairway #3. keys don't work on it.. Priority: med.
FO-351808	7/7/2016			Carpenters:Please repair the rusted-out fence post near the entrance of the Law Library lobby. See Engineer for proper location. Medium Priority.
FO-351951	7/11/2016	7/15/2016		Trade: Carpenters Priority: Medium Please repair or replace the right side hinge. The window will not close properly.
FO-351960	7/11/2016	7/12/2016		Trade: Carpenter Priority: Medium Construct baffle across the lower set of cooling coils in AHU #1. Contact engineer for details. Percy 313-590-7142 or John 313-804-1557 or 313-684-1706.
FO-352042	7/12/2016	7/13/2016		Carpenters-please adjust entry door -071-02N- door rubbing on jamb. Medium priority
FO-352348	7/15/2016			DOOR HARD TO CLOSE. DUE TO SWELLING. ROOM 23.
FO-352353	7/17/2016	7/19/2016		Adjust door closers on the two main entrance doors on Woodward on the east side of I-bio. Oftentimes the doors do not latch, sending alarm to Public Safety. Doors #211-01-E and #211- 02-E.
FO-352630	7/19/2016			CARPENTERS,PLEASE REPAIR CRUMBLING CONCRETE IN COURTYARD AT PLANETARIUM EMERGENCY EXIT DOOR. (TRIP HAZARD)PRIORITY-MEDIUM
FO-352682	7/19/2016	7/20/2016		DOOR WON'T CLOSE PROPERLY. ROOM 3125.
FO-352687	7/19/2016	7/20/2016		Door to 102.1 does not close or open easily. Sticks and is getting harder and harder to open
FO-352745	7/20/2016			room 3628 door does not latch/lock properly and door closer needs repair
FO-352813	7/21/2016	7/21/2016		Trade: Carpenter Priority: Medium Basement mechanical room 0332 door will not lock please repair.
FO-352819	7/21/2016			Trade: Carpenter Priority: MediumDoor to east penthouse mechanical room will not lock. This door is located in the stairwell in the center of the old lab wing.
FO-352869	7/21/2016	7/27/2016		CARPENTERS, R/R RM 00111 PLEASE REPAIR DOOR LATCH PLATE. PRIORITY-MEDIUM
FO-352925	7/22/2016	7/25/2016		CARP R/R INSIDE STE 443 RM 449 ENTRY DOOR IS STICKING @ TOP VERY HARD TO OPEN/CLOSE DOOR

WO	Recieved	Finished	Total	Request
FO-353124	7/25/2016	7/27/2016		Carpenters: R/R RM 00111 Inside door handle not fully opening latch causing door to not open. Priority: Medium
FO-353220	7/26/2016	7/27/2016		WINDOW BLINDS WILL NOT GO UP. ROOM B-C.
FO-353252	7/26/2016			CARPENTERS,PLEASE REPLACE SUSPENDE CEILING IN JANITORS CLOSET.PRIORITY-MEDIUM
FO-353393	7/28/2016			CARPENTERS: Please repair door closer on 5th floor door at stairwell B. MED.
<b>T - Electrician</b>			<b>32</b>	
FO-351366	7/1/2016	7/8/2016		Electricians, R&R strobe units in (2) walk in coolers 3rd floor.
FO-351608	7/5/2016	7/6/2016		Trade: Laborer Priority: Medium Please deliver the following chemicals to the loading dock at Engineering: 6 pails of Halochlor 2 boxes of dip slides FO-327253
FO-351635	7/5/2016	7/26/2016		Fire Alarm in trouble. Electricians R&R panel. Non construction related.
FO-351637	7/5/2016	7/6/2016		RM 4131 OUTLETS NOT WORKING IN THE BACK OF ROOM PLEASE CHECK ALL OUTLETS  ***** Engineer investigated Reference FO-349414  Indication is that this is new construction. Coverplates on many outlets are falling off.  The break
FO-351736	7/7/2016			Electricians, Medium, Please replace motor to toilet exhaust fan 004 in mechanical room.
FO-351737	7/7/2016			Electricians, Medium, Please replace defective motor to exhaust fan 007 in mechanical room 253.
FO-351787	7/7/2016			Time to take Ford Transit for oil change.
FO-351812	7/7/2016	7/7/2016		Time for Laborer to take truck to Public Safety and Campus Collision for incident report and pictures taken at collision shop.
FO-351870	7/8/2016	7/11/2016		Time for Laborer to take blue pull behind Genie lift to softball field to repair hitting cage netting. Monday 11th 9:30am.
FO-351879	7/8/2016	7/11/2016		ELECTRICIANS: R/R PENTHOUSE Please remove temporary power panel from AHU#8. MED.
FO-351877	7/8/2016			Electricians verify strobe units in all cold storage rooms in Chemistry building labs.
FO-352153	7/13/2016	7/15/2016		Please Remove All Material That Doesn't Belong In The Main Electrical Primary Rm. 1st. Floor, Vacuum Outside The Transformers, Primary Switches & Main Switch Gear.
FO-352252	7/14/2016			Pick up and return to storage 3 boxes of 4" PVC fittings from 10th floor electrical room. See Gerry for location if needed
FO-352276	7/14/2016	7/18/2016		Light fixture marked for electrician - This work needs to ber completed by start of classes on July 25, 2016
FO-352292	7/15/2016			3rd floor unisex bathroom 1 light out...ther is 1 EP in this restroom.. the entrance is very Dim...
FO-352304	7/15/2016	7/18/2016		2 Exterior Wall Lts. (West Side) Not Working. Walk Alley Between Rands Hse. & Purdy Lib.
FO-352316	7/15/2016	7/18/2016		New LED Light Pole Not Working Fountain Area. It Will be Tagged. Please Check For Power? Warranty ?
FO-352347	7/15/2016			Suite 1200 - 1 LO... There Are 2 EP's in this area
FO-352402	7/18/2016	7/20/2016		Laborer Med Priority Please deliver the following chemicals to the SW corner of Physics basement by rm 55.  1 Keg of Lokor 2000tm 1 keg of halochlor  4 5 gal pails of Nitroklenz.
FO-352419	7/18/2016	7/20/2016		trade labor priority medium please deliver 1-55gal drum of lokor 1-55gal drum of aquaklean and 1-55gal drum of halochlor

WO	Recieved	Finished	Total	Request
FO-352699	7/19/2016	7/22/2016		Trade: Laborer Priority: Medium Please supply one pallet of salt to the Chemistry sub-basement. Standing FO 327231
FO-352831	7/21/2016			Laborer to support Carpenter shop in cement demo/work in courtyard. The cement landing from emergency exit from planetarium needs repair. See Pat C.
FO-352873	7/21/2016			ELECTRICAL DEPT- R/R 5TH FLR HALLWAY BANK OF LIGHTS OUT IN HALLWAY OUTSIDE OF CONFERENCE RM 595 PLEAE REPAIR PRIORITY MED
FO-352879	7/21/2016	7/22/2016		Electricians: R/R 1ST FLR Please replace broken light switch for ceiling lights at west end of hall way, it is loose and turns off by itself. priority: med.
FO-352866	7/21/2016	7/22/2016		**ADDING LABORER: Remove debris demoed fixtures out of bathroom 103.1 or 105.1. See Gerry if needed  Plumbers: please cap off and seal water and sewer lines and remove sink and toilet in the out of service rest room 103.1.( attention: Jerry). Priority:
FO-352906	7/22/2016	7/26/2016		Deliver: 8-5 gal of Aquaklean 5-5gal of Halochlor 12 bags of salt for the water softner
FO-352997	7/25/2016	7/26/2016		Electricians: R/R RM 00016/MECH RM Please repair or replace light fixture in mechanical room close to sink, changed bulbs, no luck. priority: med.
FO-353116	7/26/2016			EMERGENCY ELEC R/R BLDG FIRE ALARM PANEL TROUBLE SHORT CIRCUIT
FO-353209	7/26/2016	7/27/2016		ELECTRICIANS: R/R RM 3240 Please check power/ breaker circuit in room 3240 (print not showing correct breaker). MED.
FO-353244	7/26/2016			pls repair exh fan motor circuit
FO-353310	7/27/2016			ELECTRICIANS, NO POWER TO WEST OUTLET, PLEASE REPAIR.( FO-353286) PRIORITY-MEDIUM
FO-353477	7/30/2016			Meet Henrietta at 9:30 Monday 8-1 front entrance elevator. Phone number 577-4882.
<b>T - Laborer</b>			<b>1</b>	
FO-352185	7/13/2016	7/15/2016		Laborer to Assist Electricians In Removing Material From Main Primary Electrical Rm. 1st. Floor. *PLEASE SEE DON BROWN* DUE TO SAFETY.
<b>T - Painter</b>			<b>2</b>	
FO-351871	7/8/2016	7/11/2016		Time for Ken Cappuccillo to support laborer with job at softball field. Monday 11th 9:30 am.
FO-353392	7/28/2016			PAINTERS: Please paint southeast stairwell walls in Auditorium due to molding water leak. MED.
<b>T - Pipefitter</b>			<b>6</b>	
FO-352653	7/19/2016	7/19/2016		Trade: PipeFitters Priority: Medium  Please repair/replace the leaking trap cover gasket on the trap in the projection booth ceiling.,,,,,,,,,,CB,,,,,,,,,7/19/16
FO-352697	7/19/2016			Disconnect steam line to absorber and disconnect condensate return to allow Trane to service unit.,,,,,,,,,,JH,,,,,,,,,7/20/16
FO-352992	7/25/2016	7/25/2016		Pipefitters: R/R LOWER ROOF Please repair broken grease line on exhaust fan #1 for the animal quarters. Priority: Medium.,,,,,,,,,,ME,,,,,,,,,7/25/16
FO-353303	7/27/2016			Trade: PipeFitters Priority: Medium/Low R/R RM 3025/LAB Please repair and/or replace the trane b1 trap on a convector in the room. It is marked with T on masking tape. ,,,,,,,,,,JH/7/27 ,,,,,,,,,,
FO-353304	7/27/2016			Trade: PipeFitters Priority: Medium/Low R/R RM 3025.20/OFC Please repair and/or replace the trane b1 trap on a convector in the room. It is marked with T on masking tape. ,,,,,,,,,,JH/7/27 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-353325	7/27/2016			FITTERS, R/R RM 00347 SURGE TANK DRAIN LINE PLUGGED, PLEASE CORRECT. PRIORITY-MEDIUM ,,,,,,,,,, ME/7/28 ,,,,,,,,,,
<b>T - Plumber</b>			<b>30</b>	
FO-351317	7/1/2016			trade plumbers priority medium R/R R 00530/MECH RM please service domestic hot water regulating valve leaking near pumps in basement area ,,,,,,,,,, TT/7/1 ,,,,,,,,,,
FO-351360	7/1/2016	7/1/2016		Plumbers: R/R ROOF Please unplug southeast roof drain for auditorium 101, it is plugged up. Priority: med. ,,,,,,,,,, GS/7/1 ,,,,,,,,,,
FO-351397	7/1/2016	7/6/2016		PLUM R/R RM 2313/WOMENS RR 3RD STALL FROM DOOR TOILET WILL NOT FLUSH ,,,,,,,,, MM/7/6 ,,,,,,,,,,
FO-351620	7/5/2016	7/6/2016		MIDDLE SINK LEAKING AT SPOUT. ROOM 4151. ,,,,,,,,,, TT/7/6 ,,,,,,,,,,
FO-351624	7/5/2016	7/7/2016		HOT WATER IS WARM. 1ST FLOOR DEAN'S OFFICE. ,,,,,,,,,, GS/7/6 ,,,,,,,,,,
FO-351691	7/6/2016	7/7/2016		Sink located in this restroom is draining very slowly.,,,,,,,,,, GS/ 7/7 ,,,,,,,,,,
FO-351910	7/9/2016	7/14/2016		Trade : plumber Priority: Medium R/R RM 3438 Leaking faucet.,,,,,,,,,, MM/7/14 ,,,,,,,,,,
FO-352054	7/12/2016	7/13/2016		PLUGGED TOILET. 2ND FLOOR UNISEX RESTROOM..MM....7-13-16
FO-352086	7/12/2016			please r&r sink piping in Tartar room, see Troy T if any questions.....TT
FO-352119	7/13/2016	7/19/2016		Plumbers: R/R RM 00110/WOMENS RR please secure lose toilets in ladies room110.( attention: Jerry). Priority: med.....GS
FO-352120	7/13/2016	7/14/2016		Plumbers: please repair or replace sink faucets that don't work. priority: med.....GS...7-13-16
FO-352121	7/13/2016	7/20/2016		Plumbers: please secure lose toilets in ladies room 210. priority: med.( attention: Jerry).....GS.....7-13-16
FO-352139	7/13/2016	7/14/2016		Please Replace Drinking Fountain H2O Filter In Electrical Shop. (Last Service Date 8/14/2014) Thanks, Don Brown.....MM....1-13-16
FO-352151	7/13/2016	7/14/2016		Trade: Plumber Priority: Medium Please replace cover plate for sewer line clean out in the plenum of fan #2. Contact engineers for the exact location. Percy 313-590-7142, John 313-804-1557 or 313-684- 1706.....TT.....7-13-16
FO-352165	7/13/2016			take all listed drinking fountains out of service per WSU OEHS department by turning off water supply to unit or removing handle, see attached e-mail for all buildings and locations **Identify on email if water supply was isolated or handle was removed
FO-352168	7/13/2016	7/14/2016		R/R RM 00050/MENS RR ONE OF THE URINALS WILL NOT FLUSH,,,,,,,,, MM/7/14 ,,,,,,,,,
FO-352306	7/15/2016	7/22/2016		R/R Room 111 in Lande Building, @ FRONT OF LAB the tape over the sink is dripping and can not be stopped.,,,,,,,,,, MM/7/15 ,,,,,,,,,,
FO-352344	7/15/2016	7/21/2016		PLUGGED SINK. LAB. 5229.,,,,,,,,,MM,,,,,7/18/16
FO-352627	7/19/2016	7/21/2016		Trade: Plumber Priority: Medium Urinal of the wall. Circulation desk requesting quick response.,,,,,,,,,,GS,,,,,7/19/16
FO-352628	7/19/2016	7/21/2016		Trade: Plumber Priority: Medium Bad Sloan valve on toilet (left Hand side),,,,,,,,,,GS,,,,,7/19/16 Need diaphragm kit
FO-352722	7/20/2016	7/22/2016		plumber R/R RM 00106/MENS RR repair low urinal flush in men's room basement. ,,,,,,,,,GS,,,,,7/20/16
FO-352829	7/21/2016	7/22/2016		PLUMBER R/R RM 423.2 KITCHENNET AREA REPAIR THE INSTANT H.W. DISPENSER LEAKING @ THE SUPPLY LINE WHEN IN USE (SINK IS LKNG FROM UNDERNEATH) ,,,,,,,,,, TT/7/21 ,,,,,,,,,,
FO-352843	7/21/2016	7/22/2016		PLUMBER R/R 3RD FLR WOMENS RR (ONLY ONE OF FLR) 1ST SINK IS DRAINING SLOWLY ,,,,,,,,, TT/7/21 ,,,,,,,,,,
FO-352896	7/22/2016	7/25/2016		PLUM R/R RM 5625/BREAK RM KITCHEN SINK IS LEAKING @ BOTTOM OF GOOSE NECK FAUCET WHEN IN USE ,,,,,,,,,, MM/7/22 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-352911	7/22/2016	7/25/2016		R/R 1ST FLR womens lavatory (only one on flr) sink has a single lever faucet, and there is a leak on this faucet that is tracking down to the floor, and keeping the floor and carpeting outside of the door wet. We need to have the ball valve mechanism repl
FO-352924	7/22/2016			Evaluate if there are any outside hose bibs available for Grounds to water plants with and are they in working order ,,,,,,,,,, MM/ 7/22 ,,,,,,,,,,
FO-352953	7/22/2016			On Danto side 2nd floor Men's restroom need to replace cartridge for waterless unrial,,,,,,,,TT,,,,,7/25/16
FO-353210	7/26/2016			PLUGGED TOILET. MEN'S RESTROOM NEXT TO MECHANICAL ROOM 1360. ,,,,,,,,,, MM/7/26 ,,,,,,,,,,
FO-353237	7/26/2016			FAUCETS CONTINUOUSLY RUNNING. ROOM 5324,,,,,,,,,,,,,,,,, MM/7/26 ,,,,,,,,,,
FO-353276	7/27/2016			CHANGE FILTER IN BOTTLED WATER FOUNTAIN. LOWER LEVEL. ,,,,,,,,,, TT/7/27 ,,,,,,,,,,
<b>Low</b>				<b>353</b>
<b>T - Carpenter</b>				<b>72</b>
FO-351365	7/1/2016	7/5/2016		R/R RM 3370 REPAIR The lock to office 3370 is stripped.
FO-351595	7/5/2016	7/22/2016		please remove metal lathe plaster ceiling of first floor bathroom (fo350040)
FO-351596	7/5/2016	7/15/2016		replace ceiling tiles outside room 8306 (fo350652)
FO-351597	7/5/2016	7/11/2016		please replace ceiling tiles in basement room 48 (fo349836)
FO-351598	7/5/2016	7/15/2016		replace ceiling tiles min basement womens restroom (fo350088)
FO-351601	7/5/2016	7/7/2016		replace 2x2 ceiling tile in basement at mech room entrance (fo350757)
FO-351630	7/5/2016	7/13/2016		Bumper is falling off wall on 2nd floor near the observation room# 212. Please reattach.
FO-351695	7/6/2016			second floor Men's room door is hitting frame when closing.
FO-351704	7/6/2016			TEAM LEADER TIME ( JULY 2016 )
FO-351715	7/6/2016	7/8/2016		Door 608-19W intermittently stays ajar; scrapes threshold.
FO-351722	7/6/2016	7/13/2016		Door 499-23S stays ajar after being opened. The door scrapes door 24S. Both doors actually face east and can be accessed via the stairwell near the auditorium's stage.
FO-351834	7/8/2016	7/11/2016		Applebaum - 3rd Floor - Reader Door at East Freight Elevator Corridor is not securing properly, triggering alarms to Public Safety
FO-351856	7/8/2016	7/12/2016		Carpenters R&R ceiling access door lock, broken womens restroom 1st floor north end, see jerry if u have questions
FO-351857	7/8/2016			open up to carpenters to repair drywall above main entry way*****Please repair the leak coming from the room above main entry to building ,,,,,,,,,, JH/7/1 ,,,,,,,,,,
FO-351889	7/8/2016	7/8/2016		Re-attach downspout on the north side of the breezeway between Alumni House and the McGregor Conference Hall. Thanks
FO-351896	7/8/2016	7/8/2016		Safety training meeting for Carpenter Shop
FO-351914	7/11/2016	7/22/2016		CARPENTERS, R/R RM 00145/CLASS RM PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-351919	7/11/2016			CARPENTERS, R/R RM 00159 PLEASE REPAIR WATER DAMAGED CEILING AT WINDOW COVE.PRIORITY-LOW
FO-351939	7/11/2016	7/13/2016		Repair cabinet door has broken at hinge. Located in lobby at 1209 Law School.
FO-351962	7/11/2016	7/12/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR ROOM 0402. PRIORITY-LOW
FO-352059	7/12/2016	7/13/2016		Carpenters- please remove ceiling tile and gridwork on lower level ceiling, east end of 12 th floor lobby
FO-352096	7/12/2016	7/15/2016		The door to our computer lab in the basement (room 001) keep sticking and will not automatically close.
FO-352099	7/13/2016	7/13/2016		CARPENTERS TO ANCHOR THE SHOT PUT RING IN THE SHOT PUT RING CIRCLE NEEDS TO BE DONE WEDNESDAY 7/13/2016 ( SEE JEASON CLARK )
FO-352100	7/13/2016			CARPENTER TO FRAME 2 BLUE PRINTS PER DAVE KUFFNER
FO-352105	7/13/2016	7/15/2016		CARPENTER TO HELP JAMES THE LABORER TO RELOCATE MATERIAL @ THE LOADING DOCK



WO	Recieved	Finished	Total	Request
FO-352124	7/13/2016	7/22/2016		Purdy Library 1st Floor, Room 229 (Located within 231 Office Suite)  Ceiling tile fell - glue came loose. Please reattach.  Thank you.
FO-352130	7/13/2016	7/18/2016		R/R RM 00132/STORAGE Please repair double door between storage areas on Antoinette. Doors are out of alignment and will not close properly. Can prevent alarm for area from being set.
FO-352177	7/13/2016	7/25/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR ROOM 0120. PRIORITY-LOW
FO-352220	7/14/2016	7/19/2016		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY @ ROOM 1321. PRIORITY-LOW
FO-352238	7/14/2016	7/18/2016		Door code for the FP&M Service Center area/Engineers was changed , but old code was not "cleared" out. Now both new and old codes work to open the door. Please clear old code.
FO-352313	7/15/2016			Please make arrangements to clean the painted floor in empty lab. Researcher would like work done the week of 7/18 if possible. Contact Dr. Zhengqing Hu at zh@med.wayne.edu or 577-0675 to schedule work.
FO-352323	7/15/2016			R/R door hardware on door #07E
FO-352399	7/18/2016	7/27/2016		Purdy Library 2nd Floor Door to Stair #1 is squeaking. Please repair.  Thank you.
FO-352417	7/18/2016	7/18/2016		CARPENTER TO HELP THE LABORER REMOVE THE CUT OFFS & EXTRA LUMBER FROM ROOF TOP HAND RAIL & DECKING JOB
FO-352420	7/18/2016	7/18/2016		CARPENTER TO REPAIR ROOF TOP DOOR WOULD NOT OPEN
FO-352649	7/19/2016			Carpenters please extend wooden shelf unit in Electrical shop main desk area. See Paul for exact location.
FO-352685	7/19/2016	7/27/2016		please re-hang vertical window blind in room 349. vertical window blind has fallen from the window prop. thank you
FO-352700	7/19/2016	7/28/2016		CARPENTERS TO TIGHTEN LECTOR HALL SEATS 2ND & 3RD FLOORS
FO-352748	7/20/2016	7/25/2016		CARPENTERS TO REPLACE DAMAGED LOCKER HANDLES BASEMENT STUDENT LOCKERS
FO-352758	7/20/2016	7/21/2016		R/R RM 00233 Door lock is hard to turn. Key goes in, but sometimes will not turn and gets stuck in the lock.
FO-352791	7/20/2016	7/28/2016		R/R INSIDE STE 1300/RECEIVING REPLACE MISSING/DAMAGED ceiling tile in men's restroom needs replacing. NOTE: Fund auditing taking place 7/28/16. Work needs to be completed by 7/27/16.
FO-352799	7/21/2016	7/28/2016		CARPENTERS TO FASTEN WALL PANELS TO THE 2ND & 3RD FLOOR LECTOR HALL WALLS
FO-352815	7/21/2016			R/R RM 00150/SVC CTR AREA MY 3 DRAWER FILE CABINET LOCK HAS PULLED OUT OF CORE AGAIN
FO-352827	7/21/2016			CARPENTERS, PLEASE REPAIR CRACKING RETAINING WALL NORTHWEST CORNER OF WARREN COURTYARD.PRIORITY-LOW
FO-352868	7/21/2016	7/25/2016		R/R RM 00116.10 PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-352871	7/21/2016	7/21/2016		CARPENTERS, R/R RM 00151 PLEASE REPLACE WATER DAMAGED CEILING TILES. PRIORITY-LOW
FO-352956	7/22/2016			*ADDING CARPENTER: Please add backing board and trim where needed to install 3 drink fountain bottle fillers in basement 2en and 3rd floors *See Troy for location and detail  Install 3 double drinking fountains with bottle fillers at agreed locations
FO-352973	7/24/2016	7/25/2016		The threshold on the outside entrance door 039-06-W, located at the reflecting pond entrance to Community Arts is heaved and preventing the door from opening/closing correctly.

WO	Recieved	Finished	Total	Request
FO-353027	7/25/2016	7/26/2016		R/R INSIDE RM 00050.10 SUPPLY CLOSET DOOR Lock to be repaired IF BROKEN (basement lab #50 supply closet. Core: 11 BEST VA 16) (CALL JASMINE FOR A TIME SHE CAN MEET W/LOCKSMITH REGARDING SHE IS IN RM 133 OR CALL 577-0237)
FO-353039	7/25/2016	7/25/2016		Kresge Library R/R 1st Floor North East Corner Open Study Area One ceiling tile missing, two others show old water damage. Please replace. Thank you.
FO-353034	7/25/2016			look at all classroom and mechroom doors on 3rd floor, adjust and lubercate all closers,hinges and locksets, make sure all work properly.
FO-353055	7/25/2016			Carpenters time for scaffold build and tear down main stairwell. See Marty and Jeff for direct locations.
FO-353212	7/26/2016	7/27/2016		All keys are getting stuck in room 154 door lock. Managed to get them out but lock needs help please.
FO-353270	7/27/2016			CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAYS @ RMS 4340, 4228 & 4218. PRIORITY-LOW
FO-353271	7/27/2016			CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY @ RM 1372.PRIORITY-LOW
FO-353272	7/27/2016	7/28/2016		Kresge Exit Door  Exterior Door 027 07W cover to door hanger has fallen off. Please see Circulation staff (at the Purdy Desk) for the cover that fell off.
FO-353311	7/27/2016	7/28/2016		CARPENTERS, STAIRWELL DOOR STICKING AT BOTTOM, PLEASE REPAIR,( 3RD FLR STAIRWELL-F) PRIORITY-LOW.
FO-353331	7/27/2016			CARPENTERS, PLEASE REPLACE WATER DAMAGED HALLWAY CEILING TILES @ RM 3225.PRIORITY-LOW
FO-353322	7/27/2016			R/R 4TH FLR please replace ceiling tile just outside 4th floor men's restroom(456)-please check for possible leaks for cause of tile stains. thank you
FO-353342	7/27/2016	7/28/2016		R/R RM 00312 Wall base molding has come loose and the base of the wall is exposed. Please repair.
FO-353343	7/27/2016			CARPENTERS TO CLEAN OUT CARPENTERS WILLIE TELLIS VAN FOR BRUCE LANGLEY TO USE
FO-353376	7/28/2016			Professor Brumley is having difficulty gaining entry to her office. We tried a few different keys and still the same thing so we're thinking its the core that needs to be repaired.
FO-353411	7/28/2016			R/R RM 1140/SEMINAR RM First door to Room 1140, LAB A, is squeaking and needs attention
FO-353412	7/28/2016			R/R RM 4100 NEED WATER DAMAGED CLNG TILES REPLACED
FO-353413	7/28/2016			R/R RM 4092 NEED WATER DAMAGED CLNG TILES REPLACED
FO-353414	7/28/2016			R/R RM 113/WOMENS RR (VENDING MACHINE HALLWAY AREA) ENTRY DOOR AFTER PUTTNG CODE IN DOOR LATCH/LOCK IS HANGING UP
FO-353439	7/29/2016			FIRE EXT PIN MISSING; [3230]; SENTRY 10LBS., ABC: FIRE EXT: ABC; [0ZV99]: NERAR RM 0402 BSMT HALLWAY (ORM #000858)  SEE ATTACHMENT
FO-353441	7/29/2016			FIRE EXT MISSING EXTINGUISER; [0ZVB5]; INSIDE SHP/REC AREA BSMT/BLDG E HALLWAY (ORM #000859)  SEE ATTACHMENT
FO-353442	7/29/2016			FIRE EXT PIN MISSING; [0ZVCS]; SENTRY 10LBS. ABC: FIRE EXT: ABC [0ZVCK] INSIDE NW STRWL 3 FLR: BLDG E (ORM #000860)  SEE ATTACHMENT
FO-353443	7/29/2016			FIRE EXT PIN MISSING; [5410]; SENTRY 10LBS. ABC: FIRE EXT: ABC [3814] NEAR SW STRWL 1ST FLR: BACK STAGE (ORM #000862)  SEE ATTACHMENT
FO-353444	7/29/2016			FIRE EXT MISSING EQUIP; [015ZM]; BSMT (ORM #000863)  SEE ATTACHMENT

WO	Recieved	Finished	Total	Request
FO-353472	7/29/2016			R/R Rm. 2254 - the key sticks in the core when you try to unlock it. I have the core listed as 15 BDA5 and the key number is 33236. Please repair.
<b>T - Electrician</b>			<b>118</b>	
FO-351312	7/1/2016			Administrative Time for July 2016
FO-351383	7/1/2016			Laborer to pick up and transport the scrap metal pile in the Grounds Yard on Piquette Street to our designated metal recycling company.
FO-351394	7/1/2016	7/1/2016		**ADDING LABORER: Assist the Plumber clearing roof drain. See Gerry
				Clear roof drain. See Jim (Laborer) for location ,,,,,,,,,, GS/ 7/1 ,,,,,,,,,
FO-351393	7/1/2016	7/1/2016		Clean and remove wood and debris from roof of State Hall.
FO-351396	7/1/2016			Room 5540 - LO
FO-351584	7/5/2016	7/5/2016		Laborer: Please remove leaves and broken tree branches off the roof of lecture hall 101. priority: low
FO-351589	7/5/2016	7/5/2016		Laborer: Please remove old and heavy spare parts from mechanical room 015. Priority: low
FO-351599	7/5/2016	7/5/2016		please replace light switch near entry door of pipe shop. switch will not stay on
FO-351602	7/5/2016			laborer please patch holes in brick outside of 14th floor freight elevator see Jerry S for exact location...
FO-351622	7/5/2016			Relamp exterior recessed light fixtures at outside of building entrance. 2-3 lamps are out.
FO-351647	7/6/2016			Gilmour Mall - several sidewalk lights burned out
FO-351653	7/6/2016	7/6/2016		LIGHTS OUT INSIDE NORTH ELEVATOR.
FO-351670	7/6/2016	7/15/2016		the south facing clock in the hallway near room 243 is no longer working.
FO-351701	7/6/2016	7/12/2016		Deliver one pallet of salt to Chatsworth boiler room.
FO-351709	7/6/2016	7/6/2016		LABORER TO TAKE LUMBER OVER TO THE ROOF OF CHEMISTRY
FO-351714	7/6/2016	7/12/2016		Work Order to cover time to take truck to Canfield Equipment for estimate on the lift gate.
FO-351716	7/6/2016			Time for Electricians to R&R clocks throughout campus for the month of July 2016.
FO-351720	7/6/2016	7/8/2016		Please have Jim deliver chemicals to Mott.
FO-351721	7/6/2016	7/8/2016		Please have Jim deliver chemicals to KCI
FO-351732	7/6/2016			There are 2 small rooms inside of 3250 that have about 3 or 4 lights out that need replacing.
FO-351738	7/7/2016			Electricians, High, Please replace motor to roof top exhaust fan 005 on North side of roof. Enter roof thru mechanical room 253
FO-351743	7/7/2016	7/7/2016		Time for Electricians monthly safety meetings for July 2016.
FO-351775	7/7/2016			Room 4709 - 3 LO There are 3 EP's in this area...
FO-351792	7/7/2016	7/8/2016		Laborer "JIM" R/R RM PH please deliver to PH- 1) 6-KEGS of LOCOR chemicals.Priority HIGH.
FO-351806	7/7/2016	7/15/2016		R/R RM 00150/OFC Please replace the batteries in all the light fixtures in room 150. They are beeping loud. NOTE: It has been 5 years and the batteries should be replaced every 5 years in these fixtures.
FO-351805	7/7/2016	7/14/2016		3rd fl - top of stairwell - 1/2 fixture is out in the fishbowl - south wall
FO-351848	7/8/2016	7/12/2016		Laborer "JIM" R/R PH please deliver 1) 4 kegs of HALOCHLOR to PH priority high
FO-351845	7/8/2016			Student Lounge Room's 146 & 146.1 Relamp light Fixture as need and replace fixture lens. Second also send to electricians - Lights in Student lounge room 146 Lights are all blinking when turned on.
FO-351872	7/8/2016	7/12/2016		Trade: Laborer Priority: Medium R/R RM 00000.62/MECH BLR RM Please deliver 1) 4 kegs of Lokor to the Chemistry sub-basement. Standing FO 327231
FO-351894	7/8/2016	7/11/2016		Please have Maintenance Laborer take fiberglass tank and parts from FP&M Stockroom to basement , Shapero. See Lynda Kinder/Larry Cook with any questions.
FO-351928	7/11/2016	7/13/2016		pls deliver barrel of lokor & aquaclean to comp center

WO	Recieved	Finished	Total	Request
FO-351932	7/11/2016			Suite 1150, Room 1169 - 5 LO
FO-351958	7/11/2016			3363 in the back, there are 2 panels with a total 6 lights out that need replacing.
FO-351974	7/11/2016			ELECTRICIANS,R/R BSMT PLEASE HARDWIRE FLUORECENT LIGHTING & INSTALL WALL MOUNTED LIGHT SWITCH IN BSMT. CURRENTLY ALL LIGHTING FIXTURES ARE RAN FROM EXTENSION CORDS.(SAFETY ISSUE)PRIORITY-LOW
FO-351973	7/11/2016			We have many lights burned out on the first floor. Including but not limited to rooms 114, 124, and the men's bathroom.
FO-352035	7/12/2016	7/20/2016		Handyman: R/R RM 00016/MECH RM Please deliver 1) 6 pails of cooling tower chemical Aquaklean odp, to Prentis bldg. mechanical room 016.
FO-352051	7/12/2016			R/R RM 444.20-4th floor, cubicle 444.20, there is a ceiling light (emergency light) that is consistently beeping. It is very annoying. Please see if we can stop the beeping.
FO-352063	7/12/2016	7/13/2016		Electrician//laborer- R/R LOAD DOCK please deliver heat pump from stock room to loading dock at Maccabees (5057 woodward))
FO-352065	7/12/2016			EMERGENCY/ELEC R/R RM 4173/ELEC-MECH RM TROUBLESHOOT & REPAIR WHY TRANSFORMER IS MAKING A LOUD NOISE
FO-352085	7/12/2016	7/19/2016		Trade: Laborer Priority: Medium R/R RM 00000.62/MECH BLR RM Please deliver to the Chemistry sub-basement. 1) 2 K OF HALOCHLOR 2) 1 K OF LOKOR
FO-352107	7/13/2016	7/19/2016		Deliver 3 gasket kits to boiler room
FO-352159	7/13/2016	7/18/2016		Trade: Laborer Priority: Medium R/R RM 00000.62/MECH BLR RM Please deliver softener tank from shop stock to the Chemistry sub-basement.
FO-352184	7/13/2016			LABORER TO SUPPLY & PICKUP A GENERATOR FOR THE FARMERS FOOD MARKET ON WEDNESDAY OF EVERY WEEK FOR THE ENTIRE SEASON
FO-352214	7/14/2016			LABORER, R/R BSMT/MECH RM PLEASE REMOVE MISC DEBRIS FROM BSMT MECH ROOM, SEE ENGINEER FOR DETAILS.PRIORITY-LOW
FO-352233	7/14/2016			electrician R/R RM 2118 please r/r wall outlet
FO-352259	7/14/2016	7/21/2016		Lights out in the following areas: 1st floor - front door and ladies room. 3rd floor 2 lights room 315. 4th floor - 2 lights room 422
FO-352267	7/14/2016			ElectricianR/R BSMT repair light switch in boiler room. Won't shut off.
FO-352275	7/14/2016	7/21/2016		R/R RM 261 In hallway on the 2nd floor, a wall clock is ticking, I think one of the clock hands are broke. Can we get this fixed so it will stop making this noise.
FO-352272	7/14/2016	7/18/2016		Please have Maintenance Laborer take Eldon Water tank (72" tall) from Shapereo to Chemistry building.
FO-352290	7/15/2016	7/19/2016		Re-secure electrical panel serving sprinkler system located in the tunnel between Community Arts loading dock and McGregor. Box was knocked off by a delivery cart. Concrete wall, plastic box.
FO-352297	7/15/2016			Rm. 267 2-EP's, & Rm. 271 2-EP's Please Repair Lt. Fixtures.
FO-352321	7/15/2016			Pick up New Transformer From Stock Rm.& Install New Transformer 4th Floor North Side Electrical Room.
FO-352322	7/15/2016			Pick up New Transformer From Stock Rm. & Install New Transformer 3rd. Floor North Side Electrical Rm.
FO-352351	7/16/2016			Please check motor starter overload settings on Condensate Transfer Pump #1 located in Mechanical Room #10 at Shaver Music. The starter has been found tripped on several occasions. The starter is the one on the left side in the panel, and is assumed to se
FO-352379	7/18/2016	7/18/2016		Electrician please check out lamp/light fixture. Henrietta will meet at back entrance after 10 am.
FO-352384	7/18/2016	7/22/2016		There is a beeping noise that can be heard near stair #4 at DJ Keith/Law School. 4 beeps, then pause for 20 seconds, repeats. Please send someone with good ears to stop the beeping.

WO	Recieved	Finished	Total	Request
FO-352385	7/18/2016	7/22/2016		The disconnect serving AHU-1K, (DJ Keith), at Law keeps tripping out. It trips numerous times per week and must be reset via momentary contact switch. Please make adjustment to correct. Send the "A" team. Mechanical room located on third floor, north/west
FO-352410	7/18/2016	7/25/2016		Time for electricians to put together a parts list to repair the heat trace on cooling tower on roof.
FO-352430	7/18/2016	7/22/2016		Fume hood lights out.  Fume hood 3: 1 light out Fume hood 4: 1 light out
FO-352431	7/18/2016	7/19/2016		Fume hood lights out in room 220  Fume hood 2 - 1 light fume hood 3 - 1 light fume hood 4- 2 lights fume hood 5- 1 light fume hood 6 - 3 lights fume hood 7 - 1 light fume hood 11- 2 lights fume hood 12 - 1 light fume hood 13 - 1 light
FO-352432	7/18/2016			Break room ceiling light, 2 lights burnt out
FO-352433	7/18/2016			Ceiling lights near fume hoods out in lab 220  1 light out near fume hood 5 2 lights out near fume hood 10
FO-352631	7/19/2016			The stairwell landing light next to Rose Foster's office has 1 electrical problem. It's between the 1st floor and the basement.
FO-352688	7/19/2016			The wall light across from room 1600 has 1 electrical problem. It's a mercury bulb.
FO-352689	7/19/2016			The hallway outside of the elevators has 1 electrical problem. (3rd floor)
FO-352718	7/20/2016	7/20/2016		Laborer transport new lens covers from USB to mech room basement of Fitness.
FO-352719	7/20/2016			Time for Laborer to exercise portable generators for the month of July.
FO-352720	7/20/2016			Time for Laborer to transport work truck to and from repair facilities for the month of July.
FO-352721	7/20/2016	7/20/2016		Electricians R&R wall clock near room 1355.
FO-352735	7/20/2016			Suite 1200 - Fluorescent light out....There Are 2 EPs in this area
FO-352753	7/20/2016	7/21/2016		Please have Laborer Pick up debris from circulating pump job in Room 100. See Don Bear for details.
FO-352757	7/20/2016			Some light need replacing in the basement lab.
FO-352792	7/20/2016			Garage lighting needs to be replaced (half have been done so far). NOTE: Fund auditing taking place....these are lights that need an electrician...lights have EP's 7/28/16. Work needs to be completed by 7/27/16.
FO-352793	7/20/2016			About 10 long tube lights out in DALNET Offices, Suite 2210. This suite of offices has key pad entry, entry numbers not known to Circ Desk staff. May buzz in when DALNET Staff available. Some in earlier than 8:30am, as early as 7:15am
FO-352811	7/21/2016	7/22/2016		R/R RM 2125 Clock in MD Lab 2125 is not working.
FO-352832	7/21/2016	7/22/2016		LABORER, PLEASE DELIVER COOLING TOWER CHEMICALS. (FO-327301) 2-PAILS EACH, 1) 2-PAILS LOKOR 2000M-P - 17010060 2) 2-PAILS HALOCHLOR C - 17010100 3) 2-PAILS AQUAKLEAN ODP - 17010106 PRIORITY-MEDIUM
FO-352821	7/21/2016			Range 80 has 2 electrical problems. (Basement)
FO-352823	7/21/2016			Room 1535 has only 1 electrical problems. I tagged 2 earlier. 3 hours later the 1 fixture came on.
FO-352877	7/21/2016	7/22/2016		Handyman: R/R RM 00050/MECH RM Please remove heavy and old spare junk parts from mechanical room. priority: low.
FO-352883	7/21/2016			Room 48.2 - 2 EP

WO	Recieved	Finished	Total	Request
FO-352893	7/21/2016			R/R RM 00054/LAB EP LITES IN RM CUSTODIAL LITE TECH HAS ALREADY REPLACED LITES & NOW THEY ARE BURNT OUT AGAIN WO FO-351802 (DAVID GLENN LITE TECH REPAIRED 7/7/16) two lights died one month ago, the bulb were changed but didn't work yet. Please send an
FO-352894	7/21/2016			R/R 2ND FLR HALLWAY/STRWL Public Safety - 2nd Floor main lobby / stairway area - several lights behind the ceiling molding are burned out, requires electricians for repair and scaffolding for access point per Paul Prouty.
FO-352955	7/22/2016	7/25/2016		*ADDING LABORER: Deliver 3 drinking fountain bottle filling units from Holden Trades lock up as needed to Chemistry *Also clean up debris and dispose as needed See Troy and Mike for locations and detail  Install 3 double drinking fountains with bott
FO-352958	7/22/2016			*ADDING ELECTRICIAN: Please relocate 110 volt electrical outlet for basement drinking fountain bottle filler to be installed See Troy for location and detail  Install 3 double drinking fountains with bottle fillers at agreed locations -1ea basemen
FO-352965	7/22/2016			Laborer clean up / kill weeds / throw out trash inside all generator enclosures - campus wide
FO-352967	7/22/2016			Laborer to remove / kill ivy wall at Chemistry Building.
FO-352975	7/24/2016			Repair fire panel trouble at Law School, "1st Floor tamper, fire equipment room".
FO-352993	7/25/2016			Need lights changed in Rooms 10304 and 10304.4 on the 10th Floor - English Department. Both rooms have electrical problems. Room 10304.4 is completely dark.
FO-353015	7/25/2016			trade labor priority medium R/R PENTHOUSE please deliver 1) 1-55gal drum of lokor 2) 1-55gal drum of halochlor 3) 1-55drum of aquakleans and 4) 25 bags of salt thank you
FO-353018	7/25/2016	7/26/2016		Trade: Laborer Priority: Medium R/R LOADING DOCK Please deliver the following chemicals to the Eng EDC Bldg. loading dock: 1) 4 pails of Lokor 2) 2 pails of AquaKlean Use FO-327253
FO-353021	7/25/2016			Hallway near 508 - one of the light covers is missing....Covers to be ordered by engineers
FO-353023	7/25/2016			Room 2100/Honors college - 5 dome lights out.
FO-353032	7/25/2016			LABORER: R/R Please deliver 1) one pallet of salt to Pharmacy. Med.
FO-353033	7/25/2016	7/26/2016		LABORER: R/R PENTHOUSE Please deliver chemicals to Pharmacy 1) 3 pails LOKOR 2) 3 pails HALOCHLOR MED.
FO-353127	7/26/2016			The hallway between STAIR A and the elevators has 1 electrical problem. (2nd floor)
FO-353130	7/26/2016			The loading dock has 1 electrical problem.
FO-353133	7/26/2016			The hallway between STAIR A and the elevators has 1 electrical problem. (5th floor)
FO-353203	7/26/2016			Gallery Room 306.4 - Missing 2 lights.
FO-353204	7/26/2016			Gallery Room 306.5 - Missing a light.
FO-353207	7/26/2016			Gallery Room 310 - Missing a light.
FO-353208	7/26/2016			Gallery Room 302 - Missing a light.
FO-353218	7/26/2016			R/R RM 00305/CLASS RM Clock is not functioning.
FO-353241	7/26/2016			R/R 3RD FLR OFF OF ELEV Door bell button in lobby of third floor is operating intermittently. Can we get it repaired, please?
FO-353243	7/26/2016	7/27/2016		pls delivery 6 pails of lokor to the comp center and 1 box of dip slides

WO	Recieved	Finished	Total	Request
FO-353292	7/27/2016			As you enter the stage, immediately to the right is a table we call the ASM desk. The fluorescent light above that table is not working. Please check and repair.
FO-353314	7/27/2016			R/R LOADING DOCK Please have labor cut up wooden ladders on loading dock and dispose of material.
FO-353318	7/27/2016			LABORER TO PICKUP MATERIALS VARIOUS LOCATIONS.
FO-353329	7/27/2016			Take the fan from State Hall and deliver it to the Skillman building. Return to are shops when the Retro crew is finished with it.
FO-353352	7/28/2016			Laborer pick up and transport light poles from Matthaai construction areas back to USB roof storage area. Total of (4) light poles.
FO-353372	7/28/2016			please deliver 1) 4 drums of halochlor to the penthouse scott hall. high priority.
FO-353373	7/28/2016			please have laborer deliver 1) 4 drums of aquaclean to the penthouse. high priority.
FO-353374	7/28/2016			please have laborer deliver a 1) pallet of salt #327323 to room 100. high priority.
FO-353398	7/28/2016			Two to three lights are out on the second floor near Room 221. Please replace.
FO-353405	7/28/2016			Range 161 has 1 electrical problem.
FO-353406	7/28/2016			Range 236 has 1 electrical problem. (2nd floor)
FO-353407	7/28/2016			Range 321 has 1 electrical problem. (2nd floor)
FO-353420	7/29/2016			Electricians, meet PM Tech and let them in garage area. Make sure they have access to roof for generator repair.
FO-353459	7/29/2016			There are 2 lights out in the hallway near room 263 outside the coach office.
<b>T - Handyman</b>			<b>1</b>	
FO-353229	7/26/2016			Please repair broken soap dispenser in the 1st floor hall leading to the TV Studio.
<b>T - Laborer</b>			<b>2</b>	
FO-352087	7/12/2016	7/14/2016		Use fork lift, move stored item to garage.
FO-352332	7/15/2016	7/18/2016		Remove building materials and debris from the roof of Chemistry.
<b>T - Locksmith</b>			<b>57</b>	
FO-351575	7/1/2016	7/8/2016		New Key New Space Assignment Key #: 4483 Key Holder ID: Delores Cowen Qty: 3  action: New Additional staff member
FO-351615	7/1/2016	7/11/2016		New Key Lost / Stolen Key #: Master 109745 Key Holder ID: Theresa Y. Hill Qty: 2  action: Please duplicate 2 keys for this key number. Account #: 146655
FO-351654	7/5/2016	7/6/2016		New Key Lost / Stolen Key #: 92605 Key Holder ID: Kathryn Maysen Qty: 3  action: Key 92605, core 29A6.5, room 3157 (this room was unavailable on the drop down menu)

WO	Recieved	Finished	Total	Request
FO-351711	7/5/2016	7/11/2016		<p>New Key New Space Assignment Key #: 7866 Key Holder ID: James Peters Qty: 3</p> <p>action: 2 duplicate keys for employees needing access to a new area please Account #: 135343</p>
FO-351652	7/5/2016	7/12/2016		<p>New Key New Staff Member Key #: 76811 Key Holder ID: Fallon Lindsey Qty: 1</p> <p>action: Fallon is a new staff member in the Office of Admissions and Enrollment Management Services Account #: 132941</p>
FO-351651	7/5/2016	7/11/2016		<p>New Key Lost / Stolen Key #: 106229-7 Key Holder ID: Student Center Qty: 1</p> <p>action: The key is damaged and does not open doors without wiggling the key. Please make a replacement key. Account #: 227149</p>
FO-351649	7/5/2016	7/11/2016		<p>New Key Lost / Stolen Key #: 8BK8 Key Holder ID: Chelsea Richardson Qty: 2</p> <p>action: Keys to communal equipment space.</p>
FO-351705	7/6/2016			KEYS & CORES ( JULY 2016 )
FO-351706	7/6/2016	7/27/2016		LOCKSHOP TRAINING ( JULY 2016 )
FO-351794	7/7/2016	7/12/2016		<p>New Key Lost / Stolen Key #: 25271 Key Holder ID: Sharon Pepe Qty: 4</p> <p>action: Key for freight elevator to transport animals.</p>
FO-351860	7/7/2016	7/11/2016		<p>Replacement Lost / Stolen Key #: UM326 Key Holder ID: Martha Hayward Qty: 2</p> <p>action: request for 2 keys #UM326</p>
FO-351837	7/7/2016	7/12/2016		<p>New Key New Space Assignment Key #: 38082 Key Holder ID: Leo T./Llauna Parker Qty: 2</p> <p>action: keys for 300.03 Kresge</p>



WO	Recieved	Finished	Total	Request
FO-351895	7/8/2016	7/18/2016		R&R core in Room 1001 Chatsworth. It should be split between 14A-1 (engineers) and 14D-1 (Telecommunications.Core mark 14A1/14D1. The engineers key works but the Telecommunications key 25299 does not. Per Mike Pines
FO-352067	7/12/2016	7/18/2016		New Key New Staff Member Key #: 72538 Key Holder ID: Dawn Cochrane Qty: 15  action: This is the key used for entrance to the elevator or the stairwell from the first floor lobby area. We need this many new key cuts because many people need these t
FO-352053	7/12/2016	7/19/2016		New Key New Space Assignment Key #: 27642 Key Holder ID: Heritage Transport - Wayne County Qty: 4  action: Heritage has 4 new vans to transport cadaver to our building.
FO-352071	7/12/2016	7/18/2016		Replace cores in doors 2305 & 2305.1 Pharmacy Building. The core mark is 15BDB-12. No keys are required.
FO-352098	7/12/2016	7/18/2016		New Key New Staff Member Key #: 10GAF-9 Key Holder ID: Gwyn Kropp Qty: 2  action: Keys to be picked up by SOM courier.
FO-352097	7/12/2016	7/15/2016		New Key New Staff Member Key #: 10GAF-10 Key Holder ID: Gwyn Kropp Qty: 2  action: Keys to be picked up by SOM courier.
FO-352150	7/13/2016	7/15/2016		New Key Lost / Stolen Key #: 122E Key Holder ID: Eddie Dickson Qty: 1  action: Need one key for a Allsteel File cabinet. Account #: 228400
FO-352152	7/13/2016	7/15/2016		New Key Lost / Stolen Key #: 7AN-1 Key Holder ID: Debra Mazur Qty: 5  action: 5-Keys for Rm. 3235
FO-352203	7/13/2016	7/15/2016		New Key Lost / Stolen Key #: 7672.3 and .4 Key Holder ID: Lynette Rae Qty: 2  action: Need keys for room 7217 the interior office of Lab/Room 7215 Scott Hall Account #: 133751

WO	Recieved	Finished	Total	Request
FO-352368	7/14/2016	7/19/2016		<p>New Key New Space Assignment Key #: 10AB3-1 Key Holder ID: Joanne Kaiser Qty: 2</p> <p>action: Keys for room 8239 for Dr. Robert Lasley who recently moved into this room from Elliman. Account #: 133871</p>
FO-352367	7/15/2016	7/20/2016		<p>New Key New Staff Member Key #: 76876.15 Key Holder ID: Crystal Akefe Qty: 1</p> <p>action: Key for new employee</p>
FO-352365	7/15/2016	7/20/2016		<p>New Key Lost / Stolen Key #: 2167- Key Holder ID: Sharon Miller, Delores Tennille Qty: 4</p> <p>action: Need 4 keys for an instructor's office. There are a number of people in this office. One, however, has lost his key.</p> <p>Thank you.</p>
FO-352663	7/18/2016	7/28/2016		<p>New Key Lost / Stolen Key #: 67367 Key Holder ID: Matthew Allen Qty: 5</p> <p>action: would like to request 5 copies of key #67367. Account #: 125021</p>
FO-352661	7/18/2016	7/28/2016		<p>New Key Lost / Stolen Key #: 111513 Key Holder ID: Sharon Pepe Qty: 4</p> <p>action: It is Room 4343, not available in the drop down menu.</p>
FO-352658	7/18/2016			<p>ReplacementLost / StolenKey #: H201Key Holder ID: Division of Engineering Technology Main OfficeQty: 3action: Request file cabinet keys for rm. 1024, Hybrid Formula Lab. Key#H201Account #: 121921</p>
FO-352677	7/18/2016	7/20/2016		<p>New Key New Space Assignment Key #: 8BJ10 Key Holder ID: Joyce Benjamins Qty: 2</p> <p>action: 2 additional keys for Elliman Room 2128.</p>
FO-352676	7/18/2016	7/21/2016		<p>New Key New Space Assignment Key #: 10 al42 Key Holder ID: Joseph Fiore Qty: 5</p> <p>action: We would like this lab to be kept locked when not in use.</p>

WO	Recieved	Finished	Total	Request
FO-352675	7/18/2016	7/21/2016		<p>New Key New Space Assignment Key #: 10at29 Key Holder ID: Joseph Fiore Qty: 5</p> <p>action: We need keys for new lab assignments.</p>
FO-352673	7/18/2016	7/28/2016		<p>New Key New Space Assignment Key #: 7911--2 Key Holder ID: Joseph Fiore Qty: 5</p> <p>action: We need keys for new lab assignments.</p>
FO-352691	7/19/2016	7/19/2016		<p>New Key Lost / Stolen Key #: 109112 Key Holder ID: Tony Holt Qty: 2</p> <p>action: 2- Master keys for Tierney Mansion &amp; Carriage House</p>
FO-352713	7/19/2016	7/20/2016		<p>New Key New Staff Member Key #: 76811 Key Holder ID: Melvin Lunkins Qty: 1</p> <p>action: new key Account #: 132941</p>
FO-352742	7/20/2016			<p>New KeyNew Staff MemberKey #: 109745Key Holder ID: Theresa Y. HillQty: 2 action: Please duplicate 2 keys. This is for IT personnel in the IBio building. Thank you!Account #: 146655</p>
FO-352766	7/20/2016			<p>New KeyNew Staff MemberKey #: 28026Key Holder ID: Terrie PickeringQty: 2 action: 2 duplicate keys for room 429Account #: 1-26780</p>
FO-352802	7/20/2016			<p>New Key Lost / Stolen Key #: 65662 Key Holder ID: Tyneshia McFarland Qty: 2</p> <p>action: We need two(2) keys made for room 2112, 5700 Cass Ave, 2nd floor. Thanks Mr. Pines</p>
FO-352767	7/20/2016			<p>New KeyNew Staff MemberKey #: 15730Key Holder ID: Terrie PickeringQty: 3 action: duplicate keys for room 334 ManoogianAccount #: 1-26780</p>
FO-352768	7/20/2016			<p>New KeyNew Staff MemberKey #: 13873Key Holder ID: Terrie PickeringQty: 2 action: duplicate keys for room 346 ManoogianAccount #: 1-26780</p>
FO-352769	7/20/2016			<p>New KeyNew Staff MemberKey #: 15734Key Holder ID: Terrie PickeringQty: 2 action: duplicate keys for room 348 ManoogianAccount #: 1-26780</p>
FO-352804	7/20/2016			<p>New KeyNew Space AssignmentKey #: 30694 / B-60Key Holder ID: College of Engineering Dean's OfficeQty: 3 action: To fill Key Requests.</p>
FO-353045	7/25/2016			<p>Replacement Lost / Stolen Key #: Arrowood Desk - Key #005 Key Holder ID: Dawn Medley Qty: 2</p> <p>action: Need to order two desk keys for new Associate Vice President of Enrollment Management Account #: 170701</p>

WO	Recieved	Finished	Total	Request
FO-353138	7/25/2016			Core Change Lost / Stolen Key #: core 17AAA57    key 33859 Key Holder ID: Donnella Johnson Qty: 2 cores 2 keys  action: Please return the emergency core to the front desk. Account #: 228200
FO-353137	7/25/2016	7/27/2016		Core Change Lost / Stolen Key #: Core 17AAB35 Key Holder ID: Donnella Johnson Qty: 2 cores 2 keys  action: Please return the emergency core to the front desk. Thanks Account #: 228200
FO-353136	7/25/2016	7/27/2016		Core Change Damaged Key #: Core 17AC11    Key 33943 Key Holder ID: Donnella Johnson Qty: 3 keys 2 cores  action: No emergency core used. Account #: 228200
FO-353132	7/25/2016	7/27/2016		Core Change Lost / Stolen Key #: Core 17AAD12    Key 340098 Key Holder ID: Donnella Johnson Qty: 2 cores 2 keys  action: Please return the emergency core back to the front desk, Thanks Account #: 228200
FO-353266	7/26/2016			New KeyLost / StolenKey #: 22819Key Holder ID: Paul BishopQty: 3action: New Faculty assignment.
FO-353383	7/26/2016			New KeyNew Staff MemberKey #: 64802Key Holder ID: Paul BishopQty: 3action: New faculty members.
FO-353219	7/26/2016			New Key Damaged Key #: 18684 Key Holder ID: Amy Hays Qty: 3  action: Need 3 master keys for Art building Key# 18684 (previously Key # 18719 was used in error which is for room 157)
FO-353265	7/26/2016			New KeyLost / StolenKey #: 31318 - G-39Key Holder ID: College of Engineering Dean's OfficeQty: 3action: To fill Key Requests.
FO-353264	7/26/2016			New KeyNew Staff MemberKey #: 64807Key Holder ID: Paul BishopQty: 3action: new faculty member
FO-353263	7/26/2016	7/27/2016		Core Change Lost / Stolen Key #: Core 17BAL-7    Key 110636 Key Holder ID: Angelica Reyna Qty: 2 cores 4 Keys  action: Emergency core used (#11) please return to the front desk Thanks Account #: 228156
FO-353399	7/27/2016			New KeyLost / StolenKey #: 23099-3 and B346Key Holder ID: Paul ReaseQty: 2/eaaction: Request that key opens front door and other doors Account #: 300710
FO-353381	7/27/2016			New KeyNew Staff MemberKey #: 77975Key Holder ID: Sonya ScottQty: 4action: Requesting some additional keys for Kinesiology faculty using our building. The key opens 4505, 4512 and 4514.

WO	Recieved	Finished	Total	Request
FO-353380	7/27/2016			New KeyLost / StolenKey #: 33675Key Holder ID: Sonya ScottQty: 5action: Rm. 1225 used by Kinesiology, are requesting add'l keys for faculty/GRAs.
FO-353379	7/27/2016			New KeyLost / StolenKey #: 77973Key Holder ID: Sonya ScottQty: 5action: Rm. 4505 used by Kinesiology, are requesting add'l keys for faculty/GRAs.
FO-353460	7/29/2016			New KeyNew Staff MemberKey #: 27682Key Holder ID: Assistant Professor BrownQty: 5action: Key being requested for new Assistant Professor Account #: 126731
FO-353461	7/29/2016			New KeyNew Staff MemberKey #: 64805Key Holder ID: Paul BishopQty: 3action: Keys for new faculty member
<b>T - Painter</b>			<b>21</b>	
FO-351579	7/5/2016	7/27/2016		**ADDING PLASTERER; Repair wall/ceiling in 1st floor janitor closet when plumbing repair is complete *see Troy (Plumber) for detail  PLUMBERS, PART-B PLEASE REPAIR PIPE LEAK IN CEILING OF JANITORS CLOSET. PRIORITY-MEDIUM,,,,,,,,,TT/4-26-16,,,,,,,,
FO-351580	7/5/2016			CLEAN & PAINT OVER GRAFITTI FOR THE MONTH OF JULY.
FO-351581	7/5/2016			PAINTING BIDS, & MAINETENACE JOBS FOR THE MONTH OF JULY.
FO-351627	7/5/2016			Trade; Painter PART-B Priority; Low Please scrape and paint the cooling tower pipes on both the high and the low roofs at Chemistry. Cooling towers pipes are rusty and need to be protected from deterioration.
FO-351758	7/7/2016			Paint walls in law library.
FO-351820	7/7/2016			Trade: PainterPriority: LowPlease repaint the decking, beams, handrails, etc. around the cooling towers at Chemistry.
FO-352052	7/12/2016	7/28/2016		To painters. Area above windows has peeling paint and plaster, please repair.
FO-352369	7/18/2016	7/28/2016		Second floor Men's restroom the wall needs some (Holes"), fill. The Roll towel dispenser was move up to secure back to wall. This is part of request from Chemistry, building front office area with (FO-351592 / Completed).
FO-352425	7/18/2016	7/28/2016		PAINTERS TO PAINT / STAIN 2 PICTURE FRAMES SEE STEPHEN ON COLOR CHOICE
FO-352636	7/19/2016			Clean cage area & organize material in Alphabetical order. 3rd floor paint shop.
FO-352870	7/21/2016			PAINTERS,R/R RM 00151 PLEASE PATCH/PAINT WATER DAMAGED WINDOW COVE.PRIORITY-LOW
FO-352945	7/22/2016			Scrape, Patch, Prime & paint to finish ceiling in locker room #1324.
FO-352946	7/22/2016			Scrape, Prime & Paint to finish Black, 2-Emergency Phone Stands, Located; northeast corner & Near Westside parking entrance.
FO-353071	7/25/2016			R/R 4TH FLR please repair - paint is bubbled and cracked on wall just outside of 4th floor Men's restroom(456)
FO-353117	7/26/2016			Scrape, Prime & Paint to finish all exterior handrail.
FO-353118	7/26/2016			Scrape, Prime & Paint to finish all exterior handrail.
FO-353119	7/26/2016			Clean & Paint over all graffiti, in Men's & Women's Bathroom 1st, 2nd, & 3rd floors.
FO-353120	7/26/2016			Clean & Paint to finish all Graffiti in men's & Women's bathroom all floors.
FO-353249	7/26/2016	7/28/2016		PAINTER/GRAFFITTI R/R BLDG/OUTSIDE EAST SIDE OF BLDG THERE IS GANG SLANG WRITTEN NEED PAINTING POL REP #W-162080060
FO-353445	7/29/2016			PAINTERS TO REPAINT REPAIRED DOOR & DOOR JAMB CASS AVE EMERGENCY EXIT DOOR 1ST FLOOR
FO-353448	7/29/2016			PAINTERS TO PAINT ALL HANDRAILS CAMPUS WIDE
<b>T - Pipefitter</b>			<b>28</b>	
FO-351380	7/1/2016	7/5/2016		Please repair the leak coming from the room above main entry to building ,,,,,,,,,, JH/7/1 ,,,,,,,,,,,,,,,,,,,,,
FO-351650	7/6/2016	7/6/2016		items needed to stock in van that was just returned from being stolen,,,,,,,,,,,,,,,,,CB/7-6 ,,,,,,,,,,,,,,,,,,,,,,,,
FO-351916	7/11/2016	7/12/2016		PIPEFITTER R/R RM 1163 HOT WATER HEATING VALVE IS LEAKING ON #3 FLR FAN COIL UNIT CAUSING CLNG TO LEAK IN CLASS RM 159 (Eng has leak isolated for now)JH
FO-351947	7/11/2016	7/12/2016		Fitters extend condensate drain to sewer. See engineer....ME

WO	Recieved	Finished	Total	Request
FO-351955	7/11/2016			prep for delivery of coils, help unload, stage and get parts order list...AHU#2
FO-352080	7/12/2016	7/13/2016		Fitter repair broken PVC drain line on chiller #3.....JH..7-13-16
FO-352102	7/13/2016	7/13/2016		shop time to clean and straighten.....ME
FO-352122	7/13/2016	7/13/2016		STEAMFITTERS-PLEASE UNPLUG CHILLED WATER CONDENSATE DRAIN IN CHILLER UNIT PRIORITY MED.....ME....7-13-16
FO-352131	7/13/2016	7/14/2016		FITTERS: Please repair steam trap on AHU#8 Humidifier. MED.....JH.....7-13-16.
FO-352213	7/14/2016			FITTERS, R/R RM 1321 PLEASE INSULATE HWH PIPING ABOVE CEILING IN HALLWAY @ ROOM 1321. PRIORITY-LOW ..... CB/7/14 .....
FO-352247	7/14/2016	7/15/2016		Fitter, please repair leak in steam coil on AHU-1. .... *JH/ME/7/14 .....
FO-352277	7/14/2016			*ADDING BONDI 7/15/16 JWT  Trade: Pipe Coverer Priority: Low Follow up to FO 352192 R/R RM 00033.20 Please cover uninsulated chiller lines near AHU #3 and in the hall way outside the mechanical space. Water is dripping on floor and creating a saf
FO-352282	7/15/2016	7/18/2016		**ADDING PIPEFITTER: Please assist Jim (Laborer) moving some chemicals. See Jim for detail ..... JH/7/15 .....  Please have Maintenance Laborer take Eldon Water tank (72" tall) from Shapereo to Chemistry building.
FO-352325	7/15/2016			Steam Trap Replacement Material for Pipe Shop ..... JH/7/15 .....
FO-352413	7/18/2016	7/20/2016		Trade: Pipe fitter Priority: Low Run blow down piping with shut off valves from high/low/alarm float chambers to floor drain on DA tank and condensate surge tank.....,ME.....,7/19/16
FO-352664	7/19/2016	7/19/2016		please repair drain line on ahu#1, cracked/broken.....CB....7-19-16
FO-352747	7/20/2016	7/20/2016		please repair leak on condensate line near boiler room, see Engineer for exact location...CB...7-20-16
FO-352891	7/21/2016	7/14/2016		processing time for assisting abatement company....CB.....
FO-352852	7/21/2016	7/21/2016		R/R leaking AC in Pipe Shop break room ..... JH/7/21 .....
FO-352853	7/21/2016	7/21/2016		Clear debris from pipe racks and organize pipe sizes ..... ME/7/21 .....
FO-352909	7/22/2016	7/22/2016		please repair chilled water coil leak on ahu#1 in penthouse.....
FO-352994	7/25/2016	7/25/2016		Fitter R/R RM 00012 repair condensate pump seal on #2B. Attention Ron Clark.....,JH.....,7/25/16
FO-353035	7/25/2016	7/26/2016		Purdy Library, 1st Floor Water leak from ceiling same place as reported in work order FO-338898 (Finished as of May 12 2016). ..... JH/ 7/26 .....
FO-353255	7/26/2016	7/26/2016		please repair busted drain lines on several herman nelson units in basement mechanical room ..... CB/7/26 .....
FO-353355	7/28/2016			Fitters please replace leaking air vent on chill water supply to AC-2,and air vent on condensing pumps (6)&(7),in PH. .... JH/7/28 .....
FO-353371	7/28/2016			Cut up old coils that are in crates located in mechanical room 100. Cut into sections that will fit In between pickup wheel wells. *Also assist Laborer at later date when his truck repairs are complete to load coils for scrap yard ..... ME/
FO-353462	7/29/2016			please repair airtrol valve on chilled water syatem ahu#2...leaking/.....CB...7-29-16
FO-353470	7/29/2016			condensate drain plugged unit 2-15-N room 231  Water dripping from ceiling in thoroughfare between science/med microform and general microform area on first floor Purdy near north/east exit door. Waste basket in catching drips now.
<b>T - Plumber</b>			<b>54</b>	
FO-351311	7/1/2016			Administrative Time for July 2016
FO-351368	7/1/2016	7/1/2016		Clear roof drain. See Jim (Laborer) for location ..... GS/ 7/1 .....
FO-351591	7/5/2016	7/5/2016		Second floor men's restroom handicap toilet seat very loose.TT

WO	Recieved	Finished	Total	Request
FO-351663	7/6/2016			R/R chiller unit on 1st floor north side ..... GS/7/6 .....
FO-351680	7/6/2016			Trade: Plumbers Priority: Low  Please replace 2 butterfly valves for the city water in and out of the domestic hot water heater. The valves do NOT hold! This will require a building water shutdown. .... TT/7/6 .....
FO-351684	7/6/2016	7/8/2016		Second floor unisex toilet is gurgling and the tank is not filling, so the toilet does not flush properly all the time. Please repair..... MM/7/6 .....
FO-351688	7/6/2016	7/6/2016		Check bathrrom fixtures: 5th floor womens room toilet 7th floor mens room urinal 8th floor mens sink ..... MM/7/6 .....
FO-351733	7/7/2016	7/11/2016		1st floor women's, 2nd stall from wall leaks when flushed. .... MM/7/7 .....
FO-351774	7/7/2016	7/11/2016		We need the plumbers to check a pressure release valve in the storage area that keeps pushing water out of it whenever a toilet is flushed in the morning. .... TT/7-7 .....
FO-351780	7/7/2016	7/8/2016		1st floor women's locker room - 1st sink has a constant faucet stream and the 2nd stall's toilet leaks. .... MM/7/7 .....
FO-351782	7/7/2016	7/25/2016		Mens room 1st floor guard side repair toilets ..... MM/7/7 .....
FO-351831	7/7/2016	7/8/2016		R/R RM 00105/MENS RR Cold water handle of right faucet in 1st floor men's room is broken.....MM...
FO-351852	7/8/2016	7/11/2016		repair leaking kitchen faucet in room 122.....JS/ 7/11 .....
FO-351853	7/8/2016	7/11/2016		repair leaking toilet tank 1st floor north restroom...JS....
FO-351858	7/8/2016	7/8/2016		please repair loose toilet seat 3rd floor mens restroom.....TT
FO-351898	7/8/2016			R/R 4TH FLR UNISEX RR The sink in the unisex bathroom (the one across from the Conference Room , no room number) is loose from the wall.DB
FO-351941	7/11/2016	7/11/2016		Toilet in the men's restroom has been bagged for months. Please repair as soon as possible. Thank you.MM.....7-11-16
FO-351944	7/11/2016	7/19/2016		Please repair toilet in the FP&M Stockroom. Damage due to water shut down 7/7/2016. See Lynda Kinder/Marcus Darty.....TT
FO-351948	7/11/2016	7/14/2016		DRINKING FOUNTAINS NEED FILTERS CHANGED. HALLWAY OUTSIDE OF ROOMS 208 AND 253....MM
FO-351957	7/11/2016	7/12/2016		R/R RM 2216/RR Toilet hard to flush in ladies restroom.....MM...7-12-16
FO-352048	7/12/2016	7/13/2016		R/R BSMT (BOTH MENS/WOMENS RR) This request is for Plumber to install screen on drain in mens and womens restroom subbasement Knapp building, only one restroom by the door as you enter on the left. Many roaches come thru those drains, pretty disgusting.
FO-352118	7/13/2016			Plumbers: Please replace cracked and rusted old cast iron sewer lines in mechanical rooms 14 & 15, sometime sewer gas can be smelled in air plenums. priority: med.....GS....7-13-16
FO-352123	7/13/2016	7/14/2016		Plumbers: R/R RM 00332/MENS RR please cap off urinal water lines. Priority: Low. (attention: Jerry).....GS...7-13-16
FO-352266	7/14/2016	7/15/2016		R/R RM 1349/WOMENS RR Toilet in the first stall of the women's restroom is flushing continuously. .... GS/7/14 .....
FO-352268	7/14/2016	7/15/2016		R/R RM 2348/CLASS Lab sink doesn't drain properly. Water backs up even when the faucet is on very low. There are no obvious blockages from what we can see/access..... GS/7/14 .....
FO-352341	7/15/2016	7/20/2016		R/R 1ST FLR UNISEX RR RIGHT BEHIND GLASS DOORS @ VESTIBULE LOBBY NEED TOILET SEAT REPLACED.....TT.....7/18/16
FO-352380	7/18/2016			Plumbers  In room 411 Run a city water line and hose connection to roof by McQuay chiller for coil cleaning.....TT.....7/18/16
FO-352381	7/18/2016			Plumbers  From boiler room Run a city water line and hose connection to roof top chiller for coil cleaning.....GS.....7/18/16
FO-352668	7/19/2016	7/20/2016		The seat on the toilet is falling apart. Can it be replaced? Users request an elevated seat, if possible.....DB.....7/19/16

WO	Recieved	Finished	Total	Request
FO-352686	7/19/2016	7/22/2016		drinking fountain outside women's bathroom (rm 116) on the second floor of Freer House is not working. Water barely comes out,,,,,,MM,,,,,7/19/16
FO-352693	7/19/2016	7/20/2016		Plumbers: please cap off and seal water and sewer lines and remove sink and toilet in the out of service rest room 103.1.( attention: Jerry). Priority: low,,,,,,GS,,,,,7/19/16
FO-352705	7/19/2016	7/21/2016		First small stall toilet is not flushing in Main Ladies' Room in Academic Senate Suite, Room 1600. Custodial has it cleaned with a bag over it. Basic hours for Suite 1600 are 8:30m-5:00pm,,,,,,GS,,,,,7/20/16
FO-352736	7/20/2016			R/R RM 2304/DLAR Eye wash station is inoperable. One of the plastic covers has broken off and needs to be replaced. Thank you, Susan,,,,,,MM,,,,,7/20/16
FO-352750	7/20/2016			Second floor unisex bathroom toilet is gurgling not the tank is not filling (again). The toilet does not flush fully when this happens. This is an ongoing problem, as I have reported this multiple times in the last year. Please investigate and find a p
FO-352763	7/20/2016	7/22/2016		Right hand sink is draining slowly,,,,,,GS,,,,,7/20/16
FO-352781	7/20/2016	7/22/2016		4th floor men's restroom. Left sink needs a new battery. ,,,,,,TT/7/21 ,,,,,,
FO-352803	7/21/2016	7/22/2016		On Danto side in t he basement Men's restroom sink stop-up. ,,,,,,TT/7/21 ,,,,,,
FO-352828	7/21/2016	7/22/2016		R/R 1ST FLR (Only Mens RR) One of the urinals in the men's bathroom flushes but will not drain. I put a trash bag over it so it will not be used,,,,,,GS/7/21 ,,,,,,
FO-352818	7/21/2016	7/22/2016		TOILET SEAT IS LOOSE. 4TH FLOOR WOMEN'S RESTROOM. HANDICAP STALL,,,,,TT/7/21 ,,,,,,
FO-352851	7/21/2016	7/22/2016		PLUMBER R/R RM 00249 leaking sink It is on the front bench near the door. The box of goggles is soaked. Can they shut that sink off? We don't use it. ,,,,,,TT/7/22 ,,,,,,
FO-352951	7/22/2016			Install 3 double drinking fountains with bottle fillers at agreed locations -1ea basement -1ea 2nd floor -1ea 3rd floor ,,,,,,TT/7/22 ,,,,,,
FO-352995	7/25/2016			R/R RM 1234/Ladies Room, Room 1234, toilet is continuously flushing in small stall. Does eventually stop, but not right away,,,,,,GS,,,,,7/25/16
FO-353049	7/25/2016			R/R 2ND FLR/Women's 2nd floor restroom - The last sink closest to the Mack side has a constant stream running from the faucet,,,,,,MM///7/25/16
FO-353057	7/25/2016			R/R RM 2327/CLAS RM The cold water faucet at the slop sink, immediately to your left when you walk in to the door seizes up and will not turn on. Thank you. ,,,,,,TT /7/26 ,,,,,,
FO-353062	7/25/2016			R/R RM 2132 Sink is stopped up in ladies restroom and running slow.,,,,,,MM/7/26 ,,,,,,
FO-353112	7/26/2016			Danto engineering building: 1st(1531) and second floor(2523) men's urinals(bags covering)Need new filter. ,,,,,,TT/ 7/26 ,,,,,,
FO-353239	7/26/2016			3rd floor men's restroom in the back last stall has a bag over it and the 2nd stall need a toilet seat. ,,,,,,TT/7/26 ,,,,,,
FO-353256	7/26/2016			Purdy Library 3rd Floor Water Fountain located near stair #2 is bagged and has an Out of Order sign. Please repair. Thank you.
FO-353324	7/27/2016			R/R RM 2216/RESTROOM Sink stopped up in ladies restroom,,,,,,MM/ 7/28 ,,,,,,
FO-353338	7/27/2016			R/R RM 1234 Sink faucet is dripping in Ladies Room, Room 1234, Extended Study Center. ,,,,,,MM/7/28 ,,,,,,
FO-353358	7/28/2016			PLUM R/R RM 2125 SINK INSIDE LAB IS LKNG FROM UNDERNEATH @ DRAIN (Unknow sink need to inquire inside lab) ,,,,,,MM/7/28 ,,,,,,
FO-353429	7/29/2016			R&R faucets in 3rd floor men's room.,,,,,,TT,,,,,7/29/16
FO-353430	7/29/2016			Sink plugged in men's room in the basement. ,,,,,,TT,,,,,7/29/16
FO-353469	7/29/2016			Loose faucet in room 5420.06.
<b>Routine</b>			<b>9</b>	
<b>T - Electrician</b>			<b>8</b>	
FO-351662	7/1/2016			PS#1 ROUTINE CHECK 7/1 THRU 7/31/16
FO-351665	7/1/2016			PS#2 ROUTINE CHECK 7/1 THRU 7/31/16
FO-351666	7/1/2016			PS#3 ROUTINE CHECK 7/1 THRU 7/31/16



WO	Recieved	Finished	Total	Request
FO-351667	7/1/2016			PS#4 ROUTINE CHECK 7/1 THRU 7/31/16
FO-351668	7/1/2016			PS#5 ROUTINE CHECK 7/1 THRU 7/31/16
FO-351669	7/1/2016			PS#6 ROUTINE CHECK 7/1 THRU 7/31/16
FO-351671	7/6/2016			VARIOUS CAMPUS LOTS ROUTINE CHECK 7/1 THRU 7/31/16
FO-352882	7/21/2016	7/25/2016		Electricians: R/R 1ST FLR HALLWAY Please repair or replace light switch for ceiling lights on 1st floor in front of room 109. priority: low.
<b>T - Plumber</b>			<b>1</b>	
FO-351315	7/1/2016	7/6/2016		Plumbers- medium Priority- R/R RM 4461 Repair leaking backflow preventer in lab 4461..... DB/7/1 .....

**Scheduled Maint. (PM) 674**

**Engineering 562**

**Low 1**

**E - Preventative Maintenance 1**

FO-353335 7/27/2016 Belt Order:  
AHU-2  
B50 Qty: 2

**Routine 561**

**E - Auxiliary 42**

FO-350467	7/1/2016	7/20/2016		PM - Air Handling Unit
FO-350468	7/1/2016	7/19/2016		PM - Air Handling Unit
FO-350469	7/1/2016	7/27/2016		PM - Air Handling Unit
FO-350470	7/1/2016	7/25/2016		PM - Air Handling Unit
FO-350471	7/1/2016	7/27/2016		PM - Air Handling Unit
FO-350472	7/1/2016	7/26/2016		PM - Sump Pump
FO-350473	7/1/2016	7/26/2016		PM - Sump Pump
FO-350474	7/1/2016	7/26/2016		PM - Sump Pump
FO-350475	7/1/2016		7/26/2016	PM - Sump Pump
FO-350490	7/1/2016			PM - Air Handling Unit
FO-350491	7/1/2016			PM - Air Handling Unit
FO-350492	7/1/2016			PM - Air Handling Unit
FO-350493	7/1/2016			PM - Air Handling Unit
FO-350494	7/1/2016			PM - Air Handling Unit
FO-350497	7/1/2016	7/15/2016		PM - Water Booster Pump
FO-350498	7/1/2016			PM - Water Booster Pump
FO-350499	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350501	7/1/2016			PM - Water Booster Pump
FO-350502	7/1/2016			PM - Water Booster Pump
FO-350503	7/1/2016			PM - Water Booster Pump
FO-350504	7/1/2016			PM - Condensate Return Pump
FO-350505	7/1/2016			PM - Condensate Return Pump
FO-350517	7/1/2016	7/15/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350527	7/1/2016	7/15/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350529	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-350530	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-350531	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-350532	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-350533	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-350500	7/4/2016	7/8/2016		PM - Emergency Shower/Eyewash Station
FO-350917	7/7/2016	7/7/2016		Generator Maintenance, Monthly
FO-351081	7/11/2016	7/15/2016		PM - Emergency Shower/Eyewash Station
FO-350889	7/12/2016	7/13/2016		Generator Maintenance, Monthly
FO-350891	7/13/2016	7/14/2016		Generator Maintenance, Monthly
FO-351403	7/18/2016	7/22/2016		PM - Emergency Shower/Eyewash Station
FO-350897	7/20/2016	7/20/2016		Generator Maintenance, Monthly
FO-352007	7/25/2016			PM - Emergency Shower/Eyewash Station
FO-351998	7/26/2016			Generator Maintenance, Monthly
FO-352000	7/26/2016			Generator Maintenance, Monthly
FO-352002	7/26/2016			Generator Maintenance, Monthly
FO-352004	7/26/2016			Generator Maintenance, Monthly
FO-352006	7/26/2016			Generator Maintenance, Monthly
<b>E - MedPharm</b>			<b>35</b>	
FO-350287	7/1/2016			PM - Domestic Water Heater, Steam
FO-350288	7/1/2016			PM - Domestic Water Heater, Steam
FO-350289	7/1/2016			PM - Domestic Water Heater, Steam
FO-350290	7/1/2016			PM - Sump Pump
FO-350291	7/1/2016			PM - Water Softener
FO-350292	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350293	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350294	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350295	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350296	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350297	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350298	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350299	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350300	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350301	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350302	7/1/2016			PM - Emergency Shower/Eyewash Station
FO-350304	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350305	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350306	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350307	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350308	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350309	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350310	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350311	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350312	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350313	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350314	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350303	7/5/2016			Generator Maintenance, Monthly
FO-350315	7/5/2016			Generator Maintenance, Monthly
FO-351077	7/10/2016			PM - Emergency Shower/Eyewash Station
FO-350885	7/12/2016			Generator Maintenance, Monthly
FO-350887	7/12/2016			Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-350900	7/19/2016			Generator Maintenance, Monthly
FO-351980	7/26/2016			Generator Maintenance, Monthly
FO-351981	7/26/2016			Generator Maintenance, Monthly
<b>E - North</b>			<b>34</b>	
FO-350316	7/1/2016	7/26/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350317	7/1/2016	7/26/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350318	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350319	7/1/2016			PM - Heat Exchanger and Economizer
FO-350320	7/1/2016			PM - Heat Exchanger and Economizer
FO-350321	7/1/2016	7/27/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350322	7/1/2016	7/26/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350323	7/1/2016	7/27/2016		PM - Domestic Water Heater, Electric
FO-350324	7/1/2016	7/27/2016		PM - Domestic Water Heater, Electric
FO-350325	7/1/2016	7/28/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350326	7/1/2016	7/28/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350327	7/1/2016	7/28/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350328	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350329	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350330	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350331	7/1/2016			PM - Harmsco Side Stream Filter
FO-350332	7/1/2016			PM - Harmsco Side Stream Filter
FO-350333	7/1/2016	7/12/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350334	7/1/2016	7/14/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350335	7/1/2016			Vendor or Contractor Work
FO-350336	7/1/2016	7/11/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350337	7/1/2016	7/13/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350338	7/1/2016	7/11/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350339	7/1/2016	7/20/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350340	7/1/2016	7/20/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350341	7/1/2016	7/20/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350342	7/1/2016	7/18/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350343	7/1/2016	7/18/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350344	7/1/2016	6/28/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350345	7/1/2016	6/28/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350346	7/1/2016	6/28/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350347	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350902	7/12/2016	7/12/2016		Generator Maintenance, Monthly
FO-352461	7/27/2016			Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>59</b>	
FO-350348	7/1/2016	7/11/2016		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-350349	7/1/2016	7/8/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350350	7/1/2016			PM - Water/Air Cooled Condenser
FO-350351	7/1/2016	7/11/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350352	7/1/2016	7/14/2016	7/14/2016	PM - Centrifugal Pump, over 1 H.P.
FO-350353	7/1/2016	7/15/2016	7/15/2016	PM - Centrifugal Pump, over 1 H.P.
FO-350354	7/1/2016	7/15/2016	7/15/2016	PM - Centrifugal Pump, over 1 H.P.
FO-350355	7/1/2016	7/15/2016	7/15/2016	PM - Centrifugal Pump, over 1 H.P.
FO-350356	7/1/2016	7/19/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350357	7/1/2016			PM - Water/Air Cooled Condenser
FO-350358	7/1/2016			PM - Water/Air Cooled Condenser
FO-350359	7/1/2016			PM - Water/Air Cooled Condenser
FO-350360	7/1/2016			PM - Water/Air Cooled Condenser
FO-350361	7/1/2016			PM - Water/Air Cooled Condenser
FO-350362	7/1/2016			PM - Water/Air Cooled Condenser
FO-350363	7/1/2016			PM - Water/Air Cooled Condenser
FO-350364	7/1/2016			PM - Water/Air Cooled Condenser
FO-350365	7/1/2016			PM - Water/Air Cooled Condenser
FO-350366	7/1/2016			PM - Water/Air Cooled Condenser
FO-350367	7/1/2016			PM - Water/Air Cooled Condenser
FO-350368	7/1/2016			PM - Water/Air Cooled Condenser
FO-350369	7/1/2016			PM - Water/Air Cooled Condenser
FO-350370	7/1/2016			PM - Water/Air Cooled Condenser
FO-350371	7/1/2016			PM - Water/Air Cooled Condenser
FO-350372	7/1/2016			PM - Water/Air Cooled Condenser
FO-350373	7/1/2016			PM - Water/Air Cooled Condenser
FO-350374	7/1/2016	7/1/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350375	7/1/2016	7/11/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350376	7/1/2016	7/27/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350377	7/1/2016	7/26/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350378	7/1/2016	7/6/2016	7/8/2016	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350379	7/1/2016	7/6/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350380	7/1/2016	7/6/2016		Clean condenser coils
FO-350381	7/1/2016	7/7/2016		Clean condenser coils
FO-350382	7/1/2016	7/7/2016		Clean condenser coils
FO-350383	7/1/2016	7/28/2016		Replace PRE-filters
FO-350384	7/1/2016	7/26/2016		Replace PRE-filters
FO-350385	7/1/2016	7/30/2016		Replace PRE-filters
FO-350386	7/1/2016	7/30/2016		Replace PRE-filters
FO-350387	7/1/2016	7/27/2016		Replace PRE-filters
FO-350388	7/1/2016	7/30/2016		Replace PRE-filters
FO-350903	7/1/2016	7/11/2016		Generator Maintenance, Monthly
FO-350911	7/1/2016	7/11/2016		Generator Maintenance, Monthly
FO-350913	7/1/2016	7/1/2016		Generator Maintenance, Monthly
FO-350915	7/1/2016	7/11/2016		Generator Maintenance, Monthly
FO-350934	7/1/2016	7/6/2016		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-350935	7/1/2016	7/6/2016		Generator Maintenance, Monthly
FO-350926	7/7/2016	7/7/2016		Generator Maintenance, Monthly
FO-350928	7/7/2016	7/7/2016		Generator Maintenance, Monthly
FO-350930	7/7/2016	7/7/2016		Generator Maintenance, Monthly
FO-350933	7/7/2016	7/7/2016		Generator Maintenance, Monthly
FO-351078	7/7/2016	7/7/2016		PM - Semi Anunal Air Handling Unit Inspection
FO-350907	7/13/2016	7/8/2016		Generator Maintenance, Monthly
FO-351398	7/15/2016			PM - Heat Exchanger and Economizer
FO-350893	7/19/2016	7/19/2016		Generator Maintenance, Monthly
FO-350899	7/21/2016	7/21/2016		Generator Maintenance, Monthly
FO-352477	7/27/2016			Generator Maintenance, Monthly
FO-352480	7/28/2016	7/28/2016		Generator Maintenance, Monthly
FO-352481	7/28/2016	7/29/2016		Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>223</b>	
FO-338420	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338421	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338422	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-338426	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344078	7/1/2016	7/27/2016		Replace PRE-filters
FO-344079	7/1/2016	7/27/2016		Replace PRE-filters
FO-344080	7/1/2016	7/27/2016		Replace PRE-filters
FO-346533	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346534	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346535	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346536	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346662	7/1/2016		5/31/2016	Replace PRE-filters
FO-346667	7/1/2016			Replace PRE-filters
FO-346668	7/1/2016			Replace PRE-filters
FO-346675	7/1/2016	5/23/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-346676	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348743	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348744	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348745	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348746	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348747	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348748	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348749	7/1/2016	7/19/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348750	7/1/2016	7/13/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348751	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348752	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348753	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348754	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348755	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348756	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348757	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348758	7/1/2016	7/5/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348759	7/1/2016	7/5/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Page 62 of 72

WO	Recieved	Finished	Total	Request
FO-348807	7/1/2016	7/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348808	7/1/2016	7/20/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348809	7/1/2016	7/20/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348810	7/1/2016	7/20/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348811	7/1/2016	7/7/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348812	7/1/2016	7/21/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348813	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348814	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348815	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348816	7/1/2016	7/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348817	7/1/2016	7/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348818	7/1/2016	7/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348819	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348820	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348821	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348822	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348823	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348824	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348825	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348826	7/1/2016	7/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348827	7/1/2016	7/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348828	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348829	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348830	7/1/2016	7/6/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348831	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348832	7/1/2016	7/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348833	7/1/2016	7/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348834	7/1/2016	7/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348835	7/1/2016	7/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348836	7/1/2016	7/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348837	7/1/2016	7/7/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348838	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-348839	7/1/2016	7/20/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348840	7/1/2016	7/7/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348841	7/1/2016	7/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348842	7/1/2016	7/29/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348843	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348844	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348845	7/1/2016			PM - Monthly Fire Alarm/Fire Protection System Test
FO-348846	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348847	7/1/2016	7/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348848	7/1/2016	7/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348849	7/1/2016	7/12/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348850	7/1/2016	5/17/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348851	7/1/2016	5/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348852	7/1/2016	5/20/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348853	7/1/2016	5/26/2016		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-348854	7/1/2016	5/24/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348855	7/1/2016	5/23/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348856	7/1/2016			Replace PRE-filters
FO-348857	7/1/2016	7/28/2016		Replace PRE-filters
FO-348858	7/1/2016			Replace PRE-filters
FO-348859	7/1/2016			Replace PRE-filters
FO-348860	7/1/2016			Replace PRE-filters
FO-348861	7/1/2016			Replace PRE-filters
FO-348862	7/1/2016			Replace PRE-filters
FO-348863	7/1/2016			Replace PRE-filters
FO-348864	7/1/2016			Replace PRE-filters
FO-348865	7/1/2016			Replace PRE-filters
FO-348866	7/1/2016			Replace PRE-filters
FO-348867	7/1/2016	7/14/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348868	7/1/2016	7/7/2016		Replace PRE-filters
FO-348869	7/1/2016	7/7/2016		Replace PRE-filters
FO-348870	7/1/2016	7/20/2016		Replace PRE-filters
FO-348871	7/1/2016		7/1/2016	Replace PRE-filters
FO-348872	7/1/2016	7/28/2016		Replace PRE-filters
FO-348873	7/1/2016	7/27/2016		Replace PRE-filters
FO-348874	7/1/2016	7/14/2016		Replace PRE-filters
FO-348875	7/1/2016	7/11/2016		Replace PRE-filters
FO-348876	7/1/2016	7/13/2016		Replace PRE-filters
FO-348877	7/1/2016		7/1/2016	Replace PRE-filters
FO-348878	7/1/2016			Replace PRE-filters
FO-348879	7/1/2016			Replace PRE-filters
FO-348880	7/1/2016			Replace PRE-filters
FO-348881	7/1/2016			Replace PRE-filters
FO-348882	7/1/2016			Replace PRE-filters
FO-348883	7/1/2016			Replace PRE-filters
FO-348884	7/1/2016			Replace PRE-filters
FO-348885	7/1/2016			Replace PRE-filters
FO-348886	7/1/2016			Replace PRE-filters
FO-348887	7/1/2016	7/28/2016		Replace PRE-filters
FO-348888	7/1/2016	7/28/2016		Replace PRE-filters
FO-348889	7/1/2016	7/28/2016		Replace PRE-filters
FO-348890	7/1/2016	7/28/2016		Replace PRE-filters
FO-348891	7/1/2016	7/28/2016		Replace PRE-filters
FO-348892	7/1/2016	7/27/2016		Replace PRE-filters
FO-348893	7/1/2016	7/27/2016		Replace PRE-filters
FO-348894	7/1/2016	7/27/2016		Replace PRE-filters
FO-348895	7/1/2016	7/27/2016		Replace PRE-filters
FO-348896	7/1/2016	7/26/2016		Replace PRE-filters
FO-348897	7/1/2016	7/26/2016		Replace PRE-filters
FO-348898	7/1/2016	7/26/2016		Replace PRE-filters
FO-348899	7/1/2016	7/26/2016		Replace PRE-filters
FO-348900	7/1/2016	7/14/2016		Replace PRE-filters



WO	Recieved	Finished	Total	Request
FO-348901	7/1/2016	7/14/2016		Replace PRE-filters
FO-348902	7/1/2016	7/13/2016		Replace PRE-filters
FO-348903	7/1/2016	7/12/2016		Replace PRE-filters
FO-348904	7/1/2016	7/12/2016		Replace PRE-filters
FO-348907	7/1/2016	7/15/2016		Replace PRE-filters
FO-348908	7/1/2016	7/19/2016		Replace PRE-filters
FO-348909	7/1/2016	7/19/2016		Replace PRE-filters
FO-348911	7/1/2016	7/7/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348912	7/1/2016	7/7/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348913	7/1/2016	7/7/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348914	7/1/2016	7/8/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348915	7/1/2016			Replace PRE-filters
FO-348916	7/1/2016	7/13/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348917	7/1/2016		5/31/2016	Replace PRE-filters
FO-348918	7/1/2016		5/31/2016	Replace PRE-filters
FO-348919	7/1/2016		5/31/2016	Replace PRE-filters
FO-348920	7/1/2016	7/28/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348921	7/1/2016			Replace PRE-filters
FO-348922	7/1/2016			Replace PRE-filters
FO-348923	7/1/2016			Replace PRE-filters
FO-348924	7/1/2016			Replace PRE-filters
FO-348925	7/1/2016	7/16/2016		Replace PRE-filters
FO-348926	7/1/2016			Replace PRE-filters
FO-348928	7/1/2016	7/20/2016		PM - Monthly Fire Alarm/Fire Protection System Test
FO-348956	7/1/2016	7/15/2016		Replace PRE-filters
FO-348957	7/1/2016	7/14/2016		Replace PRE-filters
FO-348960	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348961	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348962	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348963	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348964	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348965	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348966	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348967	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348968	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348969	7/1/2016	7/22/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348970	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348971	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348972	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348973	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348974	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348975	7/1/2016	7/21/2016		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-348980	7/1/2016	7/21/2016		Replace PRE-filters
FO-348981	7/1/2016	7/6/2016		Replace PRE-filters
FO-348982	7/1/2016	7/6/2016		Replace PRE-filters
FO-348983	7/1/2016	7/6/2016		Replace PRE-filters
FO-351573	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-348959	7/1/2016	7/14/2016		Replace PRE-filters
FO-350153	7/1/2016	7/28/2016		UBW-001-600 (Need to add to TMA Equipment Inventory) Replace PRE-filters
<b>E - South</b>			<b>39</b>	
FO-350389	7/1/2016	7/25/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350390	7/1/2016	7/28/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350393	7/1/2016	7/29/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350397	7/1/2016	7/19/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350398	7/1/2016	7/19/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350399	7/1/2016	7/19/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350452	7/1/2016	7/21/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350453	7/1/2016	7/21/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350454	7/1/2016	7/21/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350455	7/1/2016	7/7/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350456	7/1/2016	7/7/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350457	7/1/2016	7/7/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350458	7/1/2016	7/7/2016		PM - Centrifugal Pump, over 1 H.P.
FO-350466	7/1/2016	7/8/2016	7/1/2016	PM - Monthly AHU Inspection Clean Room Unit 1
FO-350495	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350496	7/1/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-350506	7/1/2016	7/14/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350507	7/1/2016	7/12/2016		PM - Harmsco Side Stream Filter
FO-350513	7/1/2016	7/19/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350514	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350515	7/1/2016	7/13/2016		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350518	7/1/2016	7/28/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350519	7/1/2016	7/28/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350520	7/1/2016	7/28/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350521	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350522	7/1/2016	7/27/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350523	7/1/2016	7/27/2016		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350919	7/6/2016			Generator Maintenance, Monthly
FO-350921	7/6/2016	7/7/2016		Generator Maintenance, Monthly
FO-350873	7/7/2016	7/14/2016		Generator Maintenance, Monthly
FO-351079	7/8/2016	7/7/2016		Monthly AHU Inspection Clean Room Unit 2
FO-351080	7/8/2016	7/7/2016		PM - Semi Anunal Air Handling Unit Inspection
FO-351083	7/9/2016	7/6/2016		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-350871	7/14/2016	7/14/2016		Generator Maintenance, Monthly
FO-350875	7/14/2016	7/20/2016		Generator Maintenance, Monthly
FO-350896	7/14/2016	7/14/2016		Generator Maintenance, Monthly
FO-350923	7/14/2016	7/14/2016		Generator Maintenance, Monthly
FO-350877	7/20/2016	7/26/2016		Generator Maintenance, Monthly
FO-350909	7/21/2016	7/21/2016		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>92</b>	
FO-350391	7/1/2016			PM - Heat Exchanger and Economizer

WO	Recieved	Finished	Total	Request
FO-350392	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350400	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350401	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350402	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350403	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350404	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350405	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350406	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350407	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350408	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350409	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350410	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350411	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350412	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350413	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350414	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350415	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350416	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350417	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350418	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350419	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350420	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350421	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350422	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350423	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350424	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350425	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350426	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350427	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350428	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350429	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350430	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350431	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350432	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350433	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350434	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350435	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350436	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350437	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350438	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350439	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350440	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350441	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350442	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350443	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350444	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350445	7/1/2016			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-350446	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350447	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350459	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350460	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350461	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350462	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350463	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350465	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350480	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350481	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350482	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350483	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350484	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350485	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350486	7/1/2016			PM - Heat Pumps (5057 Woodward)
FO-350487	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350488	7/1/2016			PM - Fan Coil/HV/AC Unit
FO-350508	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350509	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350510	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350516	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350524	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350525	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350526	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-350528	7/1/2016			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-351082	7/9/2016			PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-351399	7/15/2016			PM - Chemical Feed/Metering Pump/Controller
FO-351400	7/15/2016			PM - Chemical Feed/Metering Pump/Controller
FO-351401	7/15/2016			PM - Chemical Feed/Metering Pump/Controller
FO-351402	7/15/2016			PM - Chemical Feed/Metering Pump/Controller
FO-350881	7/19/2016			Generator Maintenance, Monthly
FO-350883	7/19/2016			Generator Maintenance, Monthly
FO-351983	7/23/2016			PM - Domestic Water Heater, Gas
FO-351985	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351986	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351987	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351988	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351989	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351990	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351991	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351992	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351993	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351994	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-351995	7/24/2016			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

E - West

37

WO	Recieved	Finished	Total	Request
FO-350394	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350395	7/1/2016			PM - Unspecified
FO-350396	7/1/2016			PM - Unspecified
FO-350448	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350449	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350450	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350451	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350464	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350476	7/1/2016	7/11/2016		PM - Sump Pump
FO-350477	7/1/2016	7/11/2016		PM - Sump Pump
FO-350478	7/1/2016			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350479	7/1/2016	7/29/2016		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-350511	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350512	7/1/2016			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-350534	7/1/2016	7/7/2016		Replace PRE-filters
FO-350535	7/1/2016	7/7/2016		Replace PRE-filters
FO-350536	7/1/2016	7/7/2016		Replace PRE-filters
FO-350537	7/1/2016	7/7/2016		Replace PRE-filters
FO-350538	7/1/2016	7/7/2016		Replace PRE-filters
FO-350539	7/1/2016	7/7/2016		Replace PRE-filters
FO-350540	7/1/2016	7/8/2016		Replace PRE-filters
FO-350541	7/1/2016	7/8/2016		Replace PRE-filters
FO-350542	7/1/2016	7/8/2016		Replace PRE-filters
FO-350543	7/1/2016	7/8/2016		Replace PRE-filters
FO-350544	7/1/2016	7/8/2016		Replace PRE-filters
FO-350545	7/1/2016	7/8/2016		Replace PRE-filters
FO-350546	7/1/2016	7/11/2016		Replace PRE-filters
FO-350547	7/1/2016	7/11/2016		Replace PRE-filters
FO-350548	7/1/2016	7/11/2016		Replace PRE-filters
FO-350549	7/1/2016	7/11/2016		Replace PRE-filters
FO-350550	7/1/2016	7/18/2016		Replace PRE-filters
FO-350551	7/1/2016	7/18/2016		Replace PRE-filters
FO-350552	7/1/2016	7/18/2016		Replace PRE-filters
FO-350553	7/1/2016	7/18/2016		Replace PRE-filters
FO-350905	7/12/2016			Generator Maintenance, Monthly
FO-351984	7/24/2016			PM - Sump Pump
FO-352611	7/28/2016			Generator Maintenance, Monthly

## Trades

112

### Routine

112

#### T - Electrician

71

FO-350879	7/1/2016	7/8/2016		Generator Test
FO-350910	7/1/2016	7/8/2016		Generator Test
FO-350912	7/1/2016	7/8/2016		Generator Test
FO-350914	7/1/2016	7/8/2016		Generator Test
FO-350931	7/1/2016	7/8/2016		Generator Test
FO-350932	7/1/2016	7/8/2016		Generator Test

WO	Recieved	Finished	Total	Request
FO-350555	7/4/2016	7/18/2016		PM - Sump Pump
FO-350556	7/4/2016	7/18/2016		PM - Sump Pump
FO-350557	7/4/2016	7/18/2016		PM - Sump Pump
FO-350558	7/4/2016	7/18/2016		PM - Sump Pump
FO-350559	7/4/2016	7/18/2016		PM - Sump Pump
FO-350560	7/4/2016	7/18/2016		PM - Sump Pump
FO-350489	7/5/2016	7/5/2016		Generator Test
FO-350554	7/5/2016	7/5/2016		Generator Test
FO-350918	7/6/2016	7/6/2016		Generator Test
FO-350920	7/6/2016	7/6/2016		Generator Test
FO-350916	7/7/2016	7/7/2016		Generator Test
FO-350924	7/7/2016	7/7/2016		Generator Test
FO-350925	7/7/2016	7/7/2016		Generator Test
FO-350927	7/7/2016	7/7/2016		Generator Test
FO-350929	7/7/2016	7/7/2016		Generator Test
FO-351084	7/11/2016			PM - Sump Pump
FO-351085	7/11/2016			PM - Sump Pump
FO-351086	7/11/2016			PM - Sump Pump
FO-351087	7/11/2016			PM - Sump Pump
FO-351088	7/11/2016			PM - Sump Pump
FO-351089	7/11/2016			PM - Sump Pump
FO-350884	7/12/2016	7/12/2016		Generator Test
FO-350886	7/12/2016	7/12/2016		Generator Test
FO-350888	7/12/2016	7/12/2016		Generator Test
FO-350901	7/12/2016	7/12/2016		Generator Test
FO-350904	7/12/2016	7/12/2016		Generator Test
FO-350890	7/13/2016	7/13/2016		Generator Test
FO-350906	7/13/2016	7/13/2016		Generator Test
FO-350872	7/14/2016			Generator Test
FO-350874	7/14/2016			Generator Test
FO-350876	7/14/2016	7/19/2016		Generator Test
FO-350895	7/14/2016	7/14/2016		Generator Test
FO-350922	7/14/2016	7/14/2016		Generator Test
FO-351404	7/18/2016			PM - Sump Pump
FO-351405	7/18/2016			PM - Sump Pump
FO-351406	7/18/2016			PM - Sump Pump
FO-351407	7/18/2016			PM - Sump Pump
FO-351408	7/18/2016			PM - Sump Pump
FO-351409	7/18/2016			PM - Sump Pump
FO-350870	7/19/2016	7/19/2016		Generator Test
FO-350880	7/19/2016	7/19/2016		Generator Test
FO-350882	7/19/2016	7/19/2016		Generator Test
FO-350892	7/19/2016	7/19/2016		Generator Test
FO-350878	7/20/2016	7/20/2016		Generator Test
FO-350894	7/20/2016	7/20/2016		Generator Test
FO-350898	7/21/2016	7/21/2016		Generator Test
FO-350908	7/21/2016	7/21/2016		Generator Test

WO	Recieved	Finished	Total	Request
FO-352008	7/25/2016			PM - Sump Pump
FO-352009	7/25/2016			PM - Sump Pump
FO-352010	7/25/2016			PM - Sump Pump
FO-352011	7/25/2016			PM - Sump Pump
FO-352012	7/25/2016			PM - Sump Pump
FO-352013	7/25/2016			PM - Sump Pump
FO-351996	7/26/2016	7/26/2016		Generator Test
FO-351997	7/26/2016	7/26/2016		Generator Test
FO-351999	7/26/2016	7/26/2016		Generator Test
FO-352001	7/26/2016	7/26/2016		Generator Test
FO-352003	7/26/2016	7/26/2016		Generator Test
FO-352005	7/26/2016	7/26/2016		Generator Test
FO-352014	7/26/2016	7/26/2016		Generator Test
FO-352566	7/27/2016			Generator Test
FO-352567	7/27/2016	7/27/2016		Generator Test
FO-352610	7/28/2016			Generator Test
FO-352613	7/28/2016			Generator Test
FO-352614	7/28/2016			Generator Test
<b>T - Plumber</b>			<b>41</b>	
FO-349097	7/1/2016			PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/7/1 ,,,,,,,,,,
FO-349098	7/1/2016	7/1/2016		*CANCELLED JWT
				PM - Main Drain with Copper Sulfate
FO-349099	7/1/2016	7/1/2016		*CANCELLED JWT
				PM - Waterless Urinals
FO-349100	7/1/2016	7/1/2016		*CANCELLED JWT
				PM - Waterless Urinals
FO-349101	7/1/2016	7/1/2016		*CANCELLED JWT
				PM - Waterless Urinals
FO-351329	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351330	7/1/2016	7/21/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351331	7/1/2016	7/21/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351332	7/1/2016	7/26/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351333	7/1/2016	7/21/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16.
FO-351334	7/1/2016	7/21/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351335	7/1/2016	7/22/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351336	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351337	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351338	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351339	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351340	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351341	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351342	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351343	7/1/2016	7/22/2016		PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351344	7/1/2016	7/14/2016		PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,,DB,,,,,7/6/16
FO-351345	7/1/2016	7/15/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351346	7/1/2016	7/15/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351347	7/1/2016	7/12/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16

WO	Recieved	Finished	Total	Request
FO-351348	7/1/2016	7/15/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351349	7/1/2016	7/12/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351350	7/1/2016	7/11/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351351	7/1/2016	7/12/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351352	7/1/2016	7/11/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351353	7/1/2016	7/7/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351354	7/1/2016	7/8/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351355	7/1/2016	7/11/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351356	7/1/2016	7/7/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351357	7/1/2016	7/7/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,6/7/16
FO-351358	7/1/2016	7/7/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/6/16
FO-351851	7/1/2016	7/8/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/7/16
FO-352984	7/1/2016	7/26/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB7/25/16
FO-352985	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352986	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352987	7/1/2016	7/26/2016		PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16
FO-352988	7/1/2016			PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,7/25/16

**Total: 2153**