

# Facilities Operations Work Orders Received 7/1/15 through 7/31/15

WO	Recieved	Finished	Total	Request
<b>Maint. Work Order</b>			<b>1705</b>	
<b>Custodial</b>			<b>245</b>	
<b>High</b>			<b>3</b>	
<b>C-Relief</b>			<b>1</b>	
FO-321263	7/7/2015			Unit is running Hot in Paint shop break room.
<b>Pest Controller</b>			<b>2</b>	
FO-320980	7/2/2015	7/14/2015	7/14/2015	R/R RM 2226 THERE IS A INFESTATION OF TINY SPIDERS & SPIDER WEBS ACCUMULATING IN HER OFC COMING FROM CLNG (SAYS THAT SHE CLEARS WEBSS OUT EVERY MORNING THE COME BACK AGAIN NEXT DAY)
FO-323049	7/28/2015	7/28/2015	7/28/2015	Remove a wasp nest in tree located at the N/E corner of the Hecker-Smiley Mansion.
<b>Medium</b>			<b>11</b>	
<b>C-Repair</b>			<b>1</b>	
FO-322878	7/24/2015			MENS RM WITHIN SUITE SOAP DISPENSER NOT WORKING
<b>Pest Controller</b>			<b>10</b>	
FO-321492	7/10/2015	7/14/2015	7/14/2015	RM 1001 PLEASE SPRAY OR SET TRAPS FOR COCK ROACHES
FO-321523	7/10/2015	7/28/2015	7/28/2015	PEST CONTROL- mouse seen in basement by stairwell next to lavatory.
FO-322013	7/15/2015	7/20/2015		STE 2701 NEEDS TO BE SPRAYED FOR BED BUGS
FO-322180	7/17/2015	7/17/2015	7/17/2015	PLEASE REPLACE GLUE TRAPS...LADIES RESTROOM NEAR VENDING MACHINES, BOBBY SMITH OFFICE, & HALLWAY NEAR VENDING MACHINE.
FO-322327	7/20/2015	7/27/2015	7/27/2015	1ST FL NEEDS TO BE SPRAYED OR TRAPS SET FOR ROACHES
FO-322531	7/21/2015	7/27/2015	7/27/2015	1ST FL CASS ENTRANCE NEEDS TO BE SPRAYED OR TRAPS FOR ROACHES. PLEASE CONTACT THERESA HILL 577-1417 OR 313-617-6720 TO DISCUSS
FO-322617	7/21/2015	7/23/2015	7/23/2015	ENTRANCE POD NEEDS TO BE SPRAYED AND TRAPS FOR RODENTS & FLIES
FO-322618	7/21/2015	7/23/2015	7/23/2015	ENTRANCE POD NEEDS TO BE SPRAYED AND TRAPS FOR RODENTS & FLIES
FO-322664	7/22/2015	7/23/2015	7/23/2015	2ND FL LAB B YELLOW JACKET BEE PROBLEM
FO-323117	7/28/2015			LAB B PLEASE EXTERMINATE FOR HORNETS COMING IN THROUGH VENT
<b>Low</b>			<b>231</b>	
<b>C-Director</b>			<b>1</b>	
FO-323081	7/28/2015	7/28/2015		2 rolls of blue tape.
<b>C-Lighting</b>			<b>75</b>	
FO-320840	7/1/2015	7/3/2015		lights are out in ladies rest room
FO-320874	7/1/2015	7/2/2015		In the UGL first floor near room 1510 in the hallway there is a light fixture corner hanging down.
FO-320877	7/1/2015	7/3/2015		Lights out in main office and Dr. Hazelett's office. approx.3
FO-320906	7/1/2015	7/6/2015		There is a light out on the third floor of the woman's restroom in the chemistry building.
FO-320917	7/1/2015	7/3/2015		MD Lab 2136 -interior Lab Relamp fixture MD Lab 2116 - 2 Light fixtures relamp -Interior Lab - 2Light Fixtures need relamping. MD Lab 2106 - Fixture had a flicker when turned on. MD Lab 2228 - Interior Lab 1 fixture needs relamping MD Lab 2248 -Inter
FO-320918	7/1/2015	7/3/2015		Hall way adjacent to room 2358 - Relamp Light fixture
FO-320919	7/1/2015	7/3/2015		2238 - Conference Room 2238 - Relamp southwest light fixture. Conference Room 2216 Relamp 4 ceiling fixt5ures . relamp 3 recessed incandescent light fixtures. Conference Room 2206 -Relamp 5 light fixtures.
FO-320924	7/1/2015	7/3/2015		Class room 3125 - Relamp two lighting fixtures.
FO-320932	7/1/2015	7/3/2015		Some light bulbs need to be replaced.
				Thank you. Dawn C.
FO-320935	7/1/2015	7/7/2015		lighting crew replace lights in animal facility in hallway outside AF-32

WO	Recieved	Finished	Total	Request
FO-320997	7/6/2015	7/6/2015		Light Changer please replace bulbs in basement ladies restroom.
FO-321006	7/6/2015	7/7/2015		We have a few lights out in room 121
FO-321270	7/7/2015	7/9/2015		In women's restroom, the light over the far left sink is out.
FO-321281	7/7/2015	7/9/2015		Good morning, The light directly over the employees desk went out and needs to be changed or fixed. Office # 13202.2 13th floor, Maccabees. Thank you for your help.
FO-321286	7/7/2015	7/8/2015		MECH RM 0410 (3) LIGHTS OUT IN CHASEWAY WITHIN GLASS FIXTURE
FO-321308	7/7/2015	7/10/2015		lights out
FO-321334	7/8/2015	7/8/2015		In chemistry building, room 169 there is two lights out.
FO-321353	7/8/2015	7/10/2015		Light bulbs in elevator need to be replaced. It is 1 bulb towards the back of the elevator.
FO-321352	7/8/2015	7/9/2015		Rm. 4341 has about 6 lights out that need to be replaced
FO-321367	7/8/2015	7/16/2015		Relamp three (3) recessed ceiling lighting fixtures in the public serving area of the cafeteria.
FO-321381	7/8/2015	7/10/2015		Replacement of 24 neon lights. changed out 36 bulbs...
FO-321400	7/9/2015	7/9/2015		4th floor ladies room, a light is out and needs replacing.
FO-321427	7/9/2015	7/10/2015		The light is out in the entrance to the Student Service suite of the Graduate School.
FO-321426	7/9/2015	7/9/2015		please replace lights in stairwell next to old freight elevator in shipping receiving.
FO-321470	7/9/2015	7/23/2015		Lights in the hallway leading down ramp to 3315 and 3317 need to be replaced.
FO-321489	7/10/2015	7/23/2015		Real Room Number is 125. Some light sets are either going out or are out behind Cubicle #6 and around by Cubicle #4. Please either check them or replace. Thank you. Dawn C.
FO-321513	7/10/2015	7/10/2015		Light in public elevator needs replacing. 2 lights out.
FO-321538	7/10/2015	7/13/2015		The covers for the light fixtures in the women's restroom are falling down. One fell and broke and another is cracked.
FO-321854	7/13/2015	7/8/2015		3rd floor - room 325 - 2 lights out.
FO-321919	7/14/2015	7/17/2015		3 blown out "sky lights" up front by the windows, check for dim bulbs also
FO-321921	7/14/2015	7/17/2015		2 front "sky lights" (up front by the windows and podiums). Check for dim bulbs also
FO-321923	7/14/2015	7/17/2015		1 Sky light out, (right above podium, up by window) please check for dim bulbs also
FO-321924	7/14/2015	7/17/2015		2 Sky lights out, (right above podium, up by window) please check for dim bulbs also
FO-321925	7/14/2015	7/17/2015		2 bulbs out, please check for dim bulbs also
FO-321926	7/14/2015	7/17/2015		1 ceiling bulb blown out...please check for dim bulbs also
FO-321927	7/14/2015	7/17/2015		Classroom 307, please check for dim bulbs Classroom 308, has 2 bulbs out
FO-321928	7/14/2015	7/17/2015		1 blown out bulb up in the very front
FO-321929	7/14/2015	7/17/2015		Computer lab has 3 blown out bulbs
FO-321935	7/14/2015	7/14/2015		Rm. 3146 (an office) has 3 light bulbs out that need replacing.
FO-321939	7/14/2015	7/14/2015		Rm. 0250 4 long light bulbs and 3 short light bulbs out that need replacing.
FO-322015	7/15/2015	7/15/2015		In Beecher house there are 2 candle lobbors out in the lobby and one out on the first floor.
FO-322023	7/15/2015	7/17/2015		Re-lamp fixture in room 114.
FO-322054	7/15/2015	7/15/2015		Relamp Light fixture in 1st floor corridor - adjacent to rooms 1309 -1310
FO-322057	7/15/2015	7/20/2015		Anatomy Lab Room 223 has several broken light fixture covers that need replacing.
FO-322077	7/16/2015	7/16/2015		The 3 flood lights at the loading dock (basement entrance) are out
FO-322159	7/17/2015	7/17/2015		2ND FLOOR CORRIDOR IN FRONT OF ELEVATOR THE LIGHT IS OUT. PLEASE REPLACE.
FO-322184	7/17/2015	7/17/2015		There are a couple of lights out in room 114 in the college of education.
FO-322544	7/21/2015	7/22/2015		We have a bank of fluorescent lights that are not working.
FO-322552	7/21/2015	7/21/2015		MEN'S RESTROOM 14TH FLOOR NEAR SERVICE ELEVATOR THE LIGHT OUT OVER SINK.
FO-322564	7/21/2015	7/21/2015		Rm. 3607 - a light has burned out in a faculty member's office and needs to replacing.
FO-322571	7/21/2015	7/22/2015		1ST FLOOR LIGHT NEEDS REPLACING NEAR GUARD DESK AND CORRIDOR.

WO	Recieved	Finished	Total	Request
FO-322598	7/21/2015			Please change light bulbs.
FO-322683	7/22/2015	7/23/2015		6th floor, suite 6304 - 2 lights out in the hallway of this suite.
FO-322764	7/23/2015	7/24/2015		Relamp Ligt Fixture inside entry door.
FO-322770	7/23/2015	7/23/2015		2nd floor - Women's R/R - energy saver bulb is out.
FO-322779	7/23/2015	7/28/2015		Light bulbs need to be replaced throughout the 1st floor. Rooms 1100, 1139, 1200, 1236, 1300, 1311, east stairwell and shower room between restrooms.
FO-322791	7/23/2015	7/23/2015		Hallway light is not working outside of office #13201.3. Thank you.
FO-322799	7/23/2015	7/28/2015		Rest room in Receiving area needs new light bulbs.
FO-322798	7/23/2015	7/24/2015		11th floor - unisex restroom 1100.1 - light out.
FO-322810	7/23/2015	7/24/2015		Light is out inside bathroom door at the entry/exit. see FO-322764
FO-322811	7/23/2015	7/24/2015		light is out in hallway outside 2358.
FO-322842	7/24/2015	7/27/2015		UGL Lights in need of replacement: in front of elevator on first floor: 4 ceiling box lights; first floor over ceiling: 2 flood lights in lobby nearest to elevators; Second floor: 12 tube lights
FO-322912	7/27/2015	7/27/2015		Light Changers please replace bulbs in basement women's restroom.
FO-322929	7/27/2015	7/28/2015		fluorescent light in 4th floor hall needs changing. It is located in front of computer lab room#422.
FO-322935	7/27/2015	7/28/2015		Re-lamp approx. 4 light fixtures in room 130, Mechanical room.
FO-322960	7/27/2015	7/28/2015		5TH FLOOR MEN'S RESTROOM LIGHT OUT. IT'S NEAR SERVICE ELEVATOR. PLEASE REPLACE.
FO-322961	7/27/2015	7/28/2015		2ND FLOOR CORRIDOR NEAR WOMEN'S RESTROOM AND THE SERVICE ELEVATOR. PLEASE REPLACE.
FO-323028	7/27/2015	7/28/2015		Light bulbs need to be replaced
FO-323090	7/28/2015			5th floor, room 5102 - 2 lights out.
FO-323164	7/29/2015	7/29/2015		Light bulb needs to be changed in the kitchenette. Thank you.
FO-323182	7/29/2015			LIGHT KEEPS FLICKERING. ROOM 1328.
FO-323250	7/30/2015	7/30/2015		Light out near Men's restroom 2nd floor UGL.
FO-323286	7/30/2015	7/31/2015		please replace light bulbs out in room 57. please see staff in rm 114 or 411 for entry to room 57, it has set alarm. thank you
FO-323302	7/30/2015			Re-lamp all fixture in room 281 mezzanine.
FO-323309	7/30/2015			7 of the 14 lamps in the 1st floor hallway are burned out. One of the lamps has been tagged since 8/14/2013 for repair.
<b>C-Materials</b>			<b>9</b>	
FO-320902	7/1/2015	7/1/2015		in Danto engineering there is a full large recycle bin in the electrical engineering department suit 3100.
FO-320974	7/2/2015	7/7/2015		Removal of trash bin in the hallway. Bin is located at 3116 FAB. Thank You. You can use Jana Jefferson as a secondary contact.
FO-321029	7/6/2015	7/7/2015		Room 300 - recycling needs to be picked up and replaced. *Request was placed 3 weeks ago and requester says hasn't been picked up.*
FO-322004	7/15/2015	7/3/2015		Requesting a large recycle bin for room 458 of the lande building.
FO-322188	7/17/2015	7/20/2015		Please pick up and drop off a recycle bin in the engineering building room number 2108.
FO-322246	7/20/2015	7/21/2015		Equipment Transfer: (AdVance / Adphibian) For service check/repairs. From: (UGL), 3rd. floor room # 3520 To: Main Office Stockroom
FO-322512	7/20/2015	7/21/2015		Need to empty full recycling bin in 711 HWCRC. There is an extra one in there now, and one that is full.
FO-322840	7/24/2015	7/24/2015		Request to have recycle bin in Room 1255 for Sarah Garrison removed and emptied. Will not need back. Thanks
FO-323276	7/30/2015			Rm 1328 FAB Copy & Mail room. Need two recycling bins. Existing bin is full. Access key is avail in Career Services 1001 FAB
<b>C-Projects</b>			<b>1</b>	

WO	Recieved	Finished	Total	Request
FO-322709	7/22/2015			Please strip and wax lab floors. Please note, this is a very large open lab concept suite and will take 2 or 3 days to complete. Also note, must be done during evening hours. Please contact Krista Mitchell at 577-9028 to discuss and schedule.
<b>C-Repair</b>			<b>29</b>	
FO-320881	7/1/2015	7/9/2015		Per custodial service soap dispenser in the 1st floor ladies room is broken and needs replacing.
FO-320928	7/1/2015	7/9/2015		repair toilet paper holder in men's restroom, basement, near elevator, only restroom there. thank you
FO-320930	7/1/2015	7/8/2015		ADVANCE AUTO SCRUBBER #070906144, NO WATER COMING OUT OF MACHINE. PLEASE REPAIR.
FO-321050	7/6/2015	7/9/2015		In State Hall Men's rooms 230 & 232 both roll towel dispensers are broken.
FO-321067	7/7/2015	7/9/2015		Adphibian Nilfisk Advance Auto Scrubber; Ser. no. 1000000480 located in rm. 3520: Request to replace the rubber stripping on squeegee. I placed the squeegee over in the main office stockroom outside your cage area. Once completed, I will pick back up fro
FO-321246	7/7/2015			Rm. 3520: Adphibian Nilfisk Advance Auto Scrubber; Ser. no. 1000000480: Janitor informed me that this auto scrubber has not been utilized for at least two (2) years however after a thorough cleaning of tank area; I had him to utilize it last night (Mon. 7
FO-321495	7/10/2015	7/10/2015		please ignore this work order its for demonstrative purposes.tyhdftydyt
FO-321521	7/10/2015			The auto scrubber keeps shutting down and the code "21" appears on the screen. There are also 2 gray broken clamps on the pad holder that needs to be replaced. The machine is located in the basement of the Community Arts building.
FO-321536	7/10/2015			The auto scrubber in Faculty Administration Bld. has 3 holes in the back hose. The cable to the squeegee is broken. The auto scrubber is located near the employee door on the first floor behind the stairs.
FO-321553	7/10/2015			Sector 3 Rm. 3520: Windsor carpet extractor; Model CLP; Ser, # 441276-EQ: This machine has been stored in this room area for over 2 years; janitor states he has never used it. Can you please check/inspect to see if this machine is workable? Thanks Collee
FO-321554	7/10/2015			Sector 3 (Room #3520); Hoover Power Max (Orange Colored)Wet/Dry Vac; Model C2129; Ser. #1000000480; Janitor has never utilized this machine & states this machine has been present in janitor closet 2 years. Can you check to see if it's workable? Thanks Co
FO-321848	7/13/2015	7/21/2015		The roll towel dispenser is broken on the third floor in the women's restroom next to room 351.  The roll towel dispenser in the women's restroom on the second floor next to room 251 is also broken.  The toilet paper dispenser in the men's restroom in
FO-321967	7/14/2015	7/20/2015		In the FAB building the buffer has a block that needs to be repaired/replaced. The machine is located on the first floor, near the employee entrance, behind the stairs.
FO-322143	7/16/2015	7/16/2015		NEW EQUIPMENT REQUEST: TRANSFER (2), TWO VACUUMS CLEANER TO NEW BUILDING (IBio), PART OF (FO319280). A.)(Sanitaire/M#SC887/Ser.#1415002882) B.) (Sanitaire/M#SC887/Ser.#1415002887)  Approved/Authorized By: Geneva, Guice
FO-322186	7/17/2015	7/17/2015		NEED TO ORDER SOME AUTO SCRUBBER PARTS FOR SERVICE REPAIRS. (FO321536 and FO321521) FROM: (ALLIED-EAGLE SUPPLY CO./PO693931) AUTHORIZED/APPROVED BY: GENEVA GUICE
FO-322190	7/17/2015	7/17/2015		A REQUEST FOR RESTROOMS DISPENSERS KEYS IS NEEDED.
FO-322212	7/17/2015	7/21/2015		I need 12 batteries for 3 hand sanitizers in Old main. Size D
FO-322221	7/17/2015	7/17/2015		Need to order parts for floor machine 17" driver pad from allied eagle supplies. P.S.: This is part of (FO321967)
FO-322249	7/20/2015	7/21/2015		Noble auto- scrubber missing a set of screws for the recovery tank. Basement cage Scott Hall
FO-322250	7/20/2015	7/21/2015		4th floor men's room of Scott Hall Soap Dispenser broken needs replacing.
FO-322281	7/20/2015			Custodial / grounds Replace broken paper towel dispenser in the mech. Rm. priority low
FO-322303	7/20/2015	7/21/2015		The restroom needs a new soap dispenser room 105 unisex restroom & 3rd floor unisex restroom.
FO-322508	7/21/2015	7/21/2015		Need to Replace Toilet tissue dispenser at the stadium in the men's lockerroom restroom last stall.

WO	Recieved	Finished	Total	Request
FO-322558	7/21/2015	7/22/2015		(Area should be men's bathroom near lecture room 138) Soap dispensers -- currently they are all broken and an open bottle of soap sits by the sinks. Paper towel dispensers -- these too are currently broken, with the plexi-glass cracked in half
FO-322721	7/23/2015			I need a beater bar for a vaccuum at the stadium.
FO-322834	7/24/2015			MEN'S RESTROOM #0120, LAST STALL THE TISSUE DISPENSER IS BROKEN. PLEASE REPAIR.
FO-322858	7/24/2015			R/R RM 113/WOMENS RR (VENDING MACHINE HALLWAY SIDE) PAPER TOWEL DISPENSER LEVER IS BROKEN
FO-322875	7/24/2015			The soap dispenser in the 4th floor men's room is broken.
FO-323201	7/30/2015			ADVANCE VACUUM, SERISL #1907677, MODEL #ADVAC 12, THE PLUG NEEDS REPLACING. BROKEN OFF. VACUUM IN STOCK ROOM 021 BASEMENT OF 5057 WOODWARD.
<b>C-Sector 01</b>			<b>12</b>	
FO-321024	7/6/2015	7/8/2015		Clean first floor tile from front doors to elevator lobby. Task is complete.
FO-321031	7/6/2015	7/10/2015		2 cases of dial soap task is complete
FO-321032	7/6/2015	7/10/2015		2 cases of dial soap. Task is complete
FO-321033	7/6/2015	7/10/2015		2 cases of dial soap Task is complete
FO-321034	7/6/2015	7/10/2015		Hilberry & Bonstelle - 2 cases of dial soap Task is complete
FO-321035	7/6/2015	7/10/2015		Rands House & Linsell House - 1 case of dial soap. Task is complete
FO-321036	7/6/2015	7/10/2015		Thompson home and Mackenzie house - 1 case of dial soap. Task is complete
FO-321272	7/7/2015	7/8/2015		2nd floor, Room 2310 (Writ-Zone): Request to have room vacuumed. Task is complete.
FO-322096	7/16/2015	7/18/2015		OFFICES 433 and 435 need carpet shampooed. Please supply Mary Wood with some possible afternoon dates for this work. Task s complete We also cleaned the carpet in room 111. W.J.
FO-322589	7/21/2015			6 cases of dial soap.
FO-322825	7/23/2015			This room has been out of service for years. It now is coming back online for teaching/research and needs custodial service to strip and wax the floor and to start regular trash service. Please schedule strip and wax with Greg Kish 7-3098 **PLEASE CALL
FO-323285	7/30/2015			Since the researchers have moved in they are not getting full custodial service. Several labs called about mopping and sweeping, etc. not being done.
<b>C-Sector 02</b>			<b>18</b>	
FO-320982	7/2/2015	7/20/2015		Room 2361 - Please shampoo carpet. Please contact Crystal Parker at 577-1412 to schedule time and date. Please note, must be done during daytime hours.
FO-321371	7/8/2015	7/22/2015		Shampoo carpet in Rm. 5211 (break room). No matter what shift.
FO-321908	7/14/2015	7/22/2015		Requesting to have the floor washed and waxed in Rm. 2527. Would like it done as soon as possible, as they are expecting some new equipment.
FO-321922	7/14/2015	7/20/2015		Please arrange to thoroughly clean rooms 458 & 462 Lande. Carpet needs to be cleaned and all flat surfaces need to be wiped down. Need work done by the end of August for faculty to move in. Rooms are unlocked for access.
FO-322024	7/15/2015			Physical Therapy Classroom 1236 - requesting to have floor stripped and waxed.
FO-322025	7/15/2015	7/24/2015		Physical Therapy Classroom 1250 - requesting to have floor stripped and waxed.
FO-322099	7/16/2015	7/20/2015		Room 2361 - Please shampoo carpet throughout office. Please note, must be done during daytime hours. Please contact Krystal Parker at 7-1415 to schedule time and date.
FO-322583	7/21/2015	7/21/2015		Please strip and wax lab 4126
FO-322582	7/21/2015			6 cases of dial soap.
FO-322584	7/21/2015			4 cases of dial soap.
FO-322585	7/21/2015			4 cases of dial soap.

WO	Recieved	Finished	Total	Request
FO-322586	7/21/2015			4 cases of dial soap.
FO-322587	7/21/2015			4 cases of dial soap.
FO-322588	7/21/2015			95 W. & 60 W. Hancock - 3 cases of dial soap.
FO-322692	7/22/2015	7/22/2015		Striped and waxed room 8212 in Scott Hall
FO-322695	7/22/2015	7/22/2015		shampooed front of office waiting area, room 1600
FO-323202	7/30/2015	7/23/2015		Please scrub room 5333 of Scott Hall.
FO-323203	7/30/2015	7/28/2015		Please scrub and wax lab 8112 of Scott Hall.
<b>C-Sector 03</b>			<b>11</b>	
FO-320965	7/2/2015	7/21/2015		Please vacuum and (wash) clean carpets. Per Walter Fitz-Herbert Edwards, requested the room to be serviced in the afternoon on July 20th at/after 6pm.
FO-322590	7/21/2015	7/22/2015		1 case of dial soap.
FO-322591	7/21/2015	7/22/2015		1 case of dial soap.
FO-322592	7/21/2015	7/22/2015		1 case of dial soap.
FO-322593	7/21/2015	7/22/2015		1 case of dial soap.
FO-322595	7/21/2015	7/22/2015		1 case of dial soap.
FO-322596	7/21/2015	7/22/2015		1 case of dial soap.
FO-322599	7/21/2015	7/22/2015		1 case of dial soap.
FO-322602	7/21/2015	7/22/2015		1 case of dial soap.
FO-322820	7/23/2015			Shampoo carpets in faculty offices 2005 F/AB; 2037 F/AB; 2067 F/AB
FO-323269	7/30/2015			please vacuum reception area and dust out under the front desk. please also vacuum copy machine area and the walk space throughout the office. please do this after 5pm. thank you
<b>C-Sector 04</b>			<b>5</b>	
FO-321337	7/8/2015	7/8/2015		2 cases of dial soap
FO-321338	7/8/2015	7/8/2015		2 cases of dial soap
FO-321339	7/8/2015	7/8/2015		1 cases of dial soap
FO-321340	7/8/2015	7/8/2015		1 cases of dial soap
FO-322830	7/24/2015	7/24/2015		Office #2307 to be shampooed (emergency project request) by Sheila White in rm. 2204. //Schedule for Friday, July 24, 2015 at/after 3pm
<b>C-Sector 05</b>			<b>11</b>	
FO-321321	7/7/2015	7/15/2015		Please vacuum carpet in closet 1520.01  Closet is currently empty
FO-321332	7/8/2015	7/23/2015		wash and wax floors in Rooms 4156 and 4164.
FO-321351	7/8/2015	7/24/2015		Schedule carpet cleaning for 60-station computer labs, rooms 308, 328, 358, 368, small control room between labs and office area, room 385, which includes smaller rooms 381, 388, 388.1, 390, and 391.  We would like to schedule between now and the end o
FO-322574	7/21/2015	7/23/2015		Room 2322 - There is a calcium build up on the floor that needs to be cleaned up.
FO-322576	7/21/2015	7/23/2015		Engineering/Danto - 4 cases of dial soap.
FO-322577	7/21/2015	7/23/2015		3 cases of dial soap.
FO-322594	7/21/2015			Per Karen Wilson's request, we are trying to have the entire College of Engineering's carpet cleaned before classes begin. This would include all of the departments in the college. Please give me a call for the details.
FO-322578	7/21/2015	7/23/2015		4 cases of dial soap.
FO-322579	7/21/2015	7/23/2015		3 cases of dial soap.
FO-322581	7/21/2015	7/23/2015		2 boxes of white rags
FO-322743	7/23/2015	7/23/2015		The building is Danto we are clean and front windows on Warren side.
<b>C-Sector 06</b>			<b>5</b>	
FO-321524	7/10/2015			2 cases of gojo soap
FO-321525	7/10/2015			2 cases of gojo soap
FO-322662	7/22/2015			2 cases of gojo soap.

WO	Recieved	Finished	Total	Request
FO-322663	7/22/2015			2 cases of gojo soap.
FO-322862	7/24/2015	7/31/2015		Please shampoo Room#3157. We have faculty moving into that office. Thank you.
<b>C-Sector 07</b>			<b>12</b>	
FO-321499	7/10/2015	7/13/2015		one case of dial soap
FO-321500	7/10/2015	7/13/2015		two cases of dial soap
FO-321502	7/10/2015	7/13/2015		3 cases of dial soap
FO-321503	7/10/2015	7/13/2015		2 cases of dial soap
FO-321504	7/10/2015	7/13/2015		1 cases of dial soap
FO-321505	7/10/2015	7/13/2015		1 cases of dial soap
FO-321547	7/10/2015			Hello, we need our floors waxed during the week of August 10th. The first floor wing/room 109 for the Speech-Language Center and Psychology clinic must be done during doing this week because Psychology will reopen August 17th. The east wing and ground f
FO-321549	7/10/2015			Work Order Continued for East Wing:  3. Carpet cleaning in the east wing area. 4. The floor in the east wing should be stripped and waxed also. 5. Stripping and waxing of the center hallway in the east wing-ground floor level.
FO-321548	7/10/2015			Please clean carpet in the audiology clinic in the basement room 002 during the week of August 10th.
FO-322243	7/20/2015	7/24/2015		Custodial Request to clean floor-There are dead roaches & debris strewn across the floor
FO-322573	7/21/2015	7/28/2015		Room # 2117 and 2119 - carpet needs to be cleaned on July 28, 2015.
FO-322868	7/24/2015	7/31/2015		The floors in the Elaine L. Jacob Gallery, room 0402 of Old Main, will need to be cleaned and washed. We have an exhibition opening Friday, July 31st. The floors will need to be cleaned either Thursday night or Friday morning. Thank you!
<b>C-Sector 08</b>			<b>8</b>	
FO-321356	7/8/2015			carpet in front of Dr. Frade's office between room 328.2 and room 329 needs cleaning. It was wet from the last ceiling leak in Dr. Frade's office and is starting smell bad.
FO-321517	7/10/2015			Shampoo Carpet, Room is armed in 1321 Old Main, this work must be done on the weekends between 5pm on Friday and before Monday morning, for access to this room please contact Lee during the week so that he can provide you with a pin code to open the room.
FO-321592	7/13/2015			Stock Issue Request: 1 Tyvek suit
FO-322787	7/23/2015			Please shampoo the carpet as soon as possible.
FO-323095	7/28/2015			5 cases of dial soap.
FO-323096	7/28/2015			FPM Building - 2 cases of dial soap.
FO-323097	7/28/2015			4 cases of dial soap 4 cases of gojo soap
FO-323116	7/28/2015			Steam clean the walls and floors in the restrooms on the 1st floor and 2nd floor. This would be both Men's and Women's restrooms.
<b>C-Sector 09</b>			<b>4</b>	
FO-321626	7/13/2015	7/24/2015		Scrub and wax floor in the MD Labs of Scott5 Hall - Rm's 2106 ,2258, 2116,, 2248, 2136, 2228, 2115, 2343, 2125, 2333,2135, 2323
FO-322628	7/21/2015	7/25/2015		Met with Yolanda at Shiffman Library on Mon. 7/20/15. She request to have the main Northside 1st floor open common area carpeting shampooed/extracted on Friday, July 24, 2015 at/after 6pm. Library closes at 8pm however this area will be closed to the stude
FO-322984	7/27/2015			Room 0340 (computer lab) in the LRC needs to have the floor cleaned and waxed.
FO-323200	7/30/2015			Strip/wax Lab 3108 Dept. of Pharmacology on 3rd floor open common area
<b>Pest Controller</b>			<b>30</b>	
FO-320962	7/2/2015			Stock issue: 1 Tyvak suit.
FO-321010	7/6/2015	7/6/2015	7/6/2015	Wasp nest in pole on Anthony Wayne Drive
FO-321061	7/6/2015	7/8/2015	7/8/2015	EXTERMINATION FOR ROACHES. ROOMS 131, 135 & 137.
FO-321065	7/6/2015	7/7/2015	7/7/2015	Cockroaches found in lobby area at greeting station and the cubicle closes to elevators.

WO	Recieved	Finished	Total	Request
FO-321266	7/7/2015	7/7/2015	7/7/2015	EXTERMINATION FOR ROACHES. ROACHES SEEN BY WINDOW. ROOM 3105.
FO-321294	7/7/2015	7/8/2015	7/8/2015	Ants & flies are a problem at the Athletic Softball Facility. Bob Ostrowski has specs. Thank You. Bob Ostrowski
FO-321320	7/7/2015	7/8/2015	7/8/2015	we have reports that there is a mouse in this room.
FO-321396	7/9/2015	7/10/2015	7/10/2015	Please take care of bed bugs in room 2209 of the AAB building.
FO-321397	7/9/2015	7/10/2015	7/10/2015	Please take care of possum at the music aux building.
FO-321430	7/9/2015	7/10/2015	7/10/2015	EXTERMINATION FOR ROACHES. ROOMS 6305 AND 5018.
FO-321458	7/9/2015	7/10/2015	7/10/2015	PLEASE REMOVE BEEHIVE AT POLE BY 1ST BASE DOUGOUT.
FO-321520	7/10/2015	7/10/2015		EXTERMINATION FOR BED BUGS. ROOM 2701.
FO-322063	7/15/2015			R/R 1ST FLR HALLWAY OUTSIDE OF RMS 1313-1323 A LARGE BUG (ROACH/WATER BUG) CRAWLING ON WALL
FO-322145	7/16/2015			R/R RM 315/SMALL CONF RM NEED FILLED STICKY TRAPS PICKED UP & REPLACED (MOUSE)
FO-322195	7/17/2015			No particular area really just the whole basement on LawCan we have pest control come spray and replace traps.
FO-322223	7/17/2015	7/20/2015		Please treat AAB for bed bugs on Saturday July 18, 2015 and Sunday July 19, 2015 for 8 hours each day.
FO-322533	7/21/2015	7/21/2015	7/21/2015	Stock issue: 5 Tyvek suits
FO-322687	7/22/2015	7/22/2015	7/22/2015	Treat/Remove bees on the south side of building
FO-322739	7/23/2015	7/23/2015	7/23/2015	PEST CONTROL- R/R OUTSIDE OF BLDG PLEASE INVESTIGATE BIG RAT HOLE BY OUTSIDE GAS METER SOUTH EAST SIDE OF BLDG PRIORITY MED
FO-322865	7/24/2015			Pest control: please apply pest control for roaches in mechanical rooms 15 and 24.
FO-322866	7/24/2015			Pest control: please apply pest control for roaches in mechanical room 50.
FO-322928	7/27/2015	7/28/2015	7/28/2015	EXTERMINATION FOR RATS. HEAR RAT SQUEEKING IN CEILING. ROOM 5018.
FO-322952	7/27/2015	7/27/2015	7/27/2015	R/R RM 441 WOULD LIKE YOU TO SPRAY AS A PRECAUTIONARY MEASURE FOR BED BUGS (a worker has them @ home)
FO-322956	7/27/2015			PEST CONTROL, R/R RM 347.10 PLEASE SPRAY FOR ANTS. PRIORITY-HIGH.
FO-322987	7/27/2015	7/28/2015	7/28/2015	EXTERMINATION FOR GNATS. ROOM 416.
FO-323039	7/28/2015			There is a roach that is in office 1155 and 1157. Offices in the Business annex need to be spray for bugs. Thank you.
FO-323238	7/30/2015			EXTERMINATION FOR MICE. BREAK ROOM. ROOM 4000.02.
FO-323253	7/30/2015			EXTERMINATION FOR ROACHES. LADIES RESTROOM. NEAR VENDING MACHINES.
FO-323283	7/30/2015			room is infested with ants
FO-323284	7/30/2015			Room is infested with biting mites

## Engineering

610

### Emergency

21

#### E - Auxiliary

3

FO-321621 7/13/2015 7/14/2015 FAP FIRE ALARM/FIRE TROUBLE ALARM ACTIVE

FO-322052 7/15/2015 7/15/2015 FIRE ALARM IS ACTIVE

H-53325 7/20/2015 A/C not working. Has been looked at already, but not fixed.

#### E - Command Center

3

FO-320955 7/2/2015 7/2/2015 AIR HANDLER UNIT #1 WILL NOT RUN IN AUTO. PENTHOUSE. EDC BLDG. CONTACT DARNELL FOR MORE DETAILS.

FO-322669 7/22/2015 7/22/2015 LEAK ON HIGH PRESSURE AIR LINE. 4TH FLOOR ROOM 4130.

FO-323141 7/29/2015 7/30/2015 AC UNIT ON ROOF, END UNIT RUNS INTERMITTENTLY POSSIBLY BAD CONDENSING FAN MOTOR

#### E - MedPharm

4



WO	Recieved	Finished	Total	Request
FO-320972	7/2/2015	7/15/2015		CHECK FIRE CONTROL ON EXHAUST FAN #10. (CONTACT ENGINEER FOR MORE DETAILS)(MULTI-TASK)  Completed 7-2-2015 SRP
FO-321895	7/14/2015	7/14/2015		Vacuum pump is not working in the building. NEED 3 NEW FUSES: ECSR-70. (Multi-task)
FO-321980	7/14/2015	7/14/2015		EMERGENCY ELEC R/R RM 0401/MECH RM AHU #1 TRANSFORMER KEEPS TRIPPING CAUSING VARIOUS RMS TO OVERHEAT
FO-322675	7/22/2015	7/22/2015		RM 3250 LOSS POWER BREAKER NEEDS TO BE RESET
<b>E - North</b>			<b>3</b>	
FO-320895	7/1/2015	7/1/2015		DOORS WON'T CLOSE. DOOR #140-10-WEST. (FACING F.A.B. BUILDING). (MULTI-TASK)
FO-321511	7/10/2015	7/10/2015		4252 & 4256 CIRCUIT BREAKER NEEDS RE-SETTING
FO-322788	7/23/2015	7/31/2015		FIRE ALARM
<b>E - Northeast</b>			<b>1</b>	
FO-322680	7/22/2015	7/22/2015		R/R RM 223/LAB 1 OUT OF 3 SINKS SINK IS PLUGGED UP & WATER WILL NOT SHUT OFF (NOTE: THIS IS A DIFFERENT SINK FROM LAST WEEK-WILL HAVE ENGINEER SHUT WATER OFF) *refer to rejected req #269849 1 OOS (directly across from door) was running constantly and cou
<b>E - Preventative Maintenance</b>			<b>1</b>	
FO-322069	7/15/2015	7/16/2015		1ST FL W.SIDE CARD READER DOOR WONT SECURE. LATCH IS BROKEN
<b>E - South</b>			<b>5</b>	
FO-321051	7/6/2015	7/6/2015		EMERGENCY PLUMBER R/R CTR OF 4TH FLR HALLWAY NEAR RM 460 THERE IS A LEAKING FLR DRAIN FOR PENTHOUSE CAUSING CLNG TO LEAK DOWN THE WALL...DB/TT....7-6-15....
FO-321620	7/13/2015	7/13/2015		0504.1 WATER IS POURING DOWN FROM CLNG
FO-321959	7/14/2015	7/14/2015		RM 2335 CLNG HAS WATER POURING THRU IT
FO-322271	7/20/2015	7/20/2015		WOOD BOARD IS HANGING FROM CEILING. ROOM 333. (MULTI-TASK)
FO-322774	7/23/2015	7/29/2015		FAP FIRE ALARM ACTIVE
<b>E - Southeast</b>			<b>1</b>	
FO-322931	7/27/2015	7/27/2015		RM 1336 WATER POURING THRU CLNG NEAR LITE FIXTURE
<b>High</b>			<b>290</b>	
<b>E - Auxiliary</b>			<b>15</b>	
H-53130	7/1/2015			A/C IS NOT WORKING ONLY HEAT KEEPS BLOWING OUT OF VENT.authenticated user: Joanna Berry - fa3511requester ip address: 141.217.23.225
H-53174	7/6/2015	7/7/2015	7/15/2015	Ashley Hepp 07/15/2015 12:08 - Ceiling is dripping above the kitchen sink authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
FO-321284	7/7/2015	7/9/2015		Campus Health Center, patient room 4 air conditioning leaking.
H-53208	7/8/2015	7/9/2015	7/15/2015	Ashley Hepp 07/15/2015 12:57 - When I run the hot water, but not the cold water, while I take a shower, a very loud noise begins. authenticated user: Jessica Weaver - fi2693 requester ip address: 35.16.77.142
H-53266	7/14/2015			Pipe under kitchen sink is leaking. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210
H-53290	7/16/2015			Air in room is not working. The air blowing out of the vents is cool to luke warm, but not cold like it normally is.authenticated user: Justin Yemm - ef4839requester ip address: 141.217.23.214
H-53312	7/19/2015			A/C(cooling unit) does not work. this is the third time i am submitting a maintenance request.authenticated user: Animesh Raut - fk2213requester ip address: 35.16.76.217
H-53314	7/20/2015			Pipe under bathroom sink is leaking. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.214
H-53331	7/21/2015			Water is not coming out of sink in kitchen. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
H-53339	7/21/2015			Toilet is flushing outward instead of inward. authenticated user: Dalas Stewart - fs3804 requester ip address: 141.217.23.187
H-53354	7/23/2015			Engineer never returned to finish sink repairs. Please complete repairs. authenticated user: Tamika Davis - eq2532 requester ip address: 141.217.23.210
H-53426	7/28/2015			The kitchen sink pipes are leaking onto the floor. authenticated user: Naveed Hoda - ef1189 requester ip address: 141.217.232.237
FO-323184	7/29/2015	7/30/2015		TRANSMITTER BLDG EQUIP ALARM IS ACTIVE OVER HEATING OVER 92degree
H-53464	7/30/2015			A/C doesn't work Since the main fan maintenance on Monday there is no cool air coming from the AC Thank you authenticated user: Antowan Zyada - fo5804 requester ip address: 35.16.70.169
H-53486	7/30/2015			AIR CONDITIONER IS BROKEN!!! FIX ASAP! THANK YOU authenticated user: Chevonne Abrams - eh3331 requester ip address: 141.217.23.191
<b>E - Command Center</b>			<b>22</b>	
FO-321282	7/7/2015	7/7/2015		trade siemens controls priority high please service #2 hydronic boiler water temperature too high three way valve may be leaking by will go past the set point temperature
FO-321342	7/8/2015			Honeywell: Please repair/ replace bad damper drive for CVV 202, and check for any other problems with operation that may require additional repairs. High Priority.
FO-321345	7/8/2015	7/9/2015		boilers & controls -insight will not come through on the computer.no way to see system at this time. called mark to start chiller system from shop. condenser water to hot, fan in hand position because it would not start in auto.system keeps shutting down
FO-321385	7/8/2015	7/14/2015		Controls  Repairs to fume hood, it failed inspection.  High Priority
FO-321386	7/8/2015	7/14/2015		Controls  Repair to Fume Hood, it fail inspection.  High Priority
FO-321387	7/8/2015	7/16/2015		Controls  Repair #4 Fume Hood, face velocity low and in alarm.  High Priority.
FO-321422	7/9/2015	7/13/2015		Control Engineer; High R/R RM 2218 Please repair heat pump #2-11 located on the second floor. The unit will not switch over to the heat mode, possibly the reversing valve is stuck. The temperature set point was 75 degrees and the ambient tempera
FO-321625	7/13/2015	7/21/2015		Ac Controls High; R/R RM 5018 Compressor not starting HWP-009 1-51, 5th floor, Unit serves rm. 5018.
FO-322002	7/15/2015			Honeywell: Control panel for AHU-3 located in the small closet next to room 3369 is out and the control points that were in the desk top Honeywell computer in Law School mechanical room 3133 are missing. Please repair. High Priority.
FO-322152	7/16/2015	7/23/2015		Trade: Command Center Priority: High Follow Up To FO 321903 R/R RM 453 Replace actuator motor for constant volume box supplying the cold rooms on the north side of the 4th floor.
FO-322168	7/17/2015	7/20/2015		Trade: Command Center Priority: High Please repair return fan status on AHU #5. Status is blinking on and off.
FO-322169	7/17/2015	7/23/2015		Trade: Command Center Priority: High Please run calibration on fume hoods 7, 11 & 12 in lab 230. Fume hood sensors indicate 80 fpm of flow. Measured values (engineer and EVH) show 60 - 70 fpm. Notify engineer when complete - 684-1706.

WO	Recieved	Finished	Total	Request
FO-322206	7/17/2015	7/21/2015		Refg.Crew: R/R RM 00021/GEN LECT RM Please repair vav box controls for 021a and 021B. Set point is 70 degrees but damper drive and air flow is not lowering room temperature below 76 degrees. High Priority.
FO-322304	7/20/2015	7/27/2015		CONTROLS (HIGH HIGH)  ROOM 100 Steam Hot WATER HEATER #2 (middle heater) will not regulate the temp. Check replace repair controls. Temp has been as high as 220 degrees.
FO-322522	7/21/2015	7/21/2015		BAS controls- high priority- Chilled Water control valve on AHU#2 is malfunctioning.
FO-322538	7/21/2015			COMMAND CENTER, PLEASE PERFORM A FLUE GAS ANALYSIS ON # 1 BOILER. PRIORITY-HIGH
FO-322647	7/22/2015	7/22/2015		Trade: Command Center Priority: High R/R RM 00000.62/MECH BLR RM Chiller #1 is not starting. Condenser water is commanded to open but the valve is not opening.
FO-322850	7/24/2015			Trade: Command Center Priority: High. R/R PH/ROOF AREA Please change the sequence of cooling tower operation. Please take CT 3 out of the lead group and substitute #1 or 2. CT #3 is leaking from the side and usage should be minimized. Currently CT
FO-323068	7/28/2015			Trade: Controls/Boilers Priority: High 090-BSG-002 After putting boiler #2 back together after OCC it will not fire, please trouble shoot and repair.
FO-323076	7/28/2015			R/R RM 203 AHU 006 located on the third floor does not deliver cold air, ambient air only. checked filter OK, checked condenser water flow OK, reset unit at the machine and the thermostat, Does not make any change. this unit cools the office of Hillary Ra
FO-323092	7/28/2015			Controls AC, High, R/R RM 5102 repair or replace as needed Heat Pump 1-58, near room 5102. Compressors runs for about 30 seconds before tripping.
FO-323147	7/29/2015	7/30/2015		AC UNIT WILL NOT COME ON. CONTROL VOLTAGE WILL NOT PULL CONTACTOR IN AC UNIT SECOND FROM END ON THE ROOF.
<b>E - MedPharm</b>			<b>71</b>	
FO-320926	7/1/2015	7/2/2015		FAP FIRE TROUBLE ALARM ACTIVE
FO-320967	7/2/2015	7/3/2015		FUME HOOD IS NOT WORKING. (2ND FUME HOOD FROM THE RIGHT) ROOM 5113.1.
FO-320971	7/2/2015	7/3/2015		FIRE TROUBLE ALARM
FO-320977	7/2/2015	7/2/2015		RM 0225/DIRTY CAGEWASH RM HAS A CLNG LEAK
FO-321030	7/6/2015	7/6/2015		ALARM SOUNDING. ROOM 4321.
FO-321262	7/7/2015	7/7/2015		RM 7271 TOO HOT
FO-321264	7/7/2015	7/7/2015		POSSIBLE LEAK. WATER ON FLOOR. ROOM 9228. PLEASE CHECK.
FO-321275	7/7/2015	7/24/2015		TOO HOT. ROOM 1209.
FO-321289	7/7/2015			LOUD NOISE COMING FROM VENTILATION SYSTEM. ROOM 254.
FO-321290	7/7/2015	7/7/2015		VERY BAD SMELL. ROOM 264.
FO-321291	7/7/2015	7/7/2015		FIRE DOOR ALARM. 1ST FLOOR.
FO-321296	7/7/2015	7/8/2015		TOO COLD. ROOM 3330.
FO-321300	7/7/2015	7/8/2015		TOO HOT. ROOM 6205.
FO-321368	7/8/2015	7/9/2015		TOO COLD. ROOM 2602.1 (INSIDE OF ROOM 2602)
FO-321402	7/9/2015	7/9/2015		1ST FLR HALLWAY DOOR BTWN GUARD'S DESK & CAFETERIA DOOR ALARM IS SNDNG AGAIN
FO-321410	7/9/2015	7/13/2015		PIPE LEAK AT WALL NEAR AUTOCLAVE. ROOM 8337.
FO-321432	7/9/2015	7/9/2015		WATER DETECTOR ALARM SOUNDING. BASEMENT MECHANICAL ROOM SOUTHWEST.
FO-321441	7/9/2015	7/9/2015		RM 5613 & 5617 TOO HOT
FO-321588	7/13/2015			RM 0250 IS TOO HOT
FO-321612	7/13/2015	7/13/2015		LEAK COMING FROM SINK PIPE IN ROOM 457. PLEASE VERIFY.
FO-321857	7/13/2015	7/14/2015		RM 200.01/DLAR HAS HI HUMDITY
FO-321858	7/13/2015	7/14/2015		RM 200.03/DLAR HAS HI HUMDITY

WO	Recieved	Finished	Total	Request
FO-321859	7/13/2015	7/14/2015		RM 200.05/DLAR HAS HI HUMDITY
FO-321971	7/14/2015	7/14/2015		RM 125 IS TOO HOT
FO-321968	7/14/2015	7/15/2015		EYEWASH WATER IS TOO WARM. ROOM 2105.
FO-321972	7/14/2015	7/14/2015		RM 277 IS TOO HOT
FO-321973	7/14/2015	7/14/2015		RM 330 IS TOO HOT
FO-322048	7/15/2015	7/23/2015		RM 310 IS TOO COLD
FO-322049	7/15/2015	7/23/2015		3RD FLR IS TOO COLD
FO-322060	7/15/2015	7/17/2015		1ST FLR HALLWAY OUTSIDE OF RM 1201 HAS AN ELECTRICAL SMELL
FO-322062	7/15/2015			RM 3210 COLD RM HIGH TEMP ALARM
FO-322105	7/16/2015	7/17/2015		FUME HOOD HAS NO AIR FLOW. ROOM 7223.
FO-322133	7/16/2015	7/17/2015		HIGH TEMP. ALARM. ROOM 8337
FO-322211	7/17/2015	7/17/2015		RM 200.02/DLAR HAS HI HUMIDITY
FO-322213	7/17/2015	7/20/2015		RM 200.04/DLAR HAS HI HUMIDITY
FO-322214	7/17/2015	7/20/2015		RM 200.09/DLAR HAS HI HUMIDITY
FO-322215	7/17/2015	7/20/2015		RM 200.10/DLAR HAS HI HUMIDITY
FO-322216	7/17/2015	7/20/2015		RM 200.14/DLAR HAS HI HUMIDITY
FO-322217	7/17/2015	7/20/2015		RM 200.15/DLAR HAS HI HUMIDITY
FO-322218	7/17/2015	7/20/2015		RM 411/DLAR HAS HI HUMIDITY
FO-322219	7/17/2015	7/20/2015		RM 413/DLAR HAS HI HUMIDITY
FO-322220	7/17/2015	7/20/2015		RM 415/DLAR HAS HI HUMIDITY
FO-322225	7/17/2015	7/17/2015		AHU3 DISCHARGE HIGH TEMP. ALARM.
FO-322226	7/17/2015	7/17/2015		VERY HIGH HUMIDITY IN BASEMENT - INCLUDING ALL ANINAL ROOMS.
FO-322261	7/20/2015	7/23/2015		Room 309 computer lab - Please investigate - No power at computer stations 50 and 51.
FO-322294	7/20/2015	7/21/2015		TOO HOT. ROOM 2258 (LAB.).
FO-322306	7/20/2015	7/20/2015		POWER BUMP.
FO-322309	7/20/2015	7/20/2015		POWER BUMP.
FO-322535	7/21/2015			CONTROLS (HIGH)  EQUIPMENT: CH001  YORK CHILLER CHILL WATER TEMP SET POINT IS MODULATING SPORADICALLY. RANGING FROM 42 TO 52 DEGREES. CHECK REMOTE CONTROL SETTINGS. REPROGRAM TO MAINTAIN A CLOSER TEMP SPAN. UNIT IS MODULATING TO FREQUENTLY FROM HIGH
FO-322603	7/21/2015	7/21/2015		RM 0247/DLAR (Pigs Rm) IS EXTREMELY COLD
FO-322607	7/21/2015	7/23/2015		BOTH INNER/OUTER HANDICAP DOORS ARE STUCK OPEN
FO-322606	7/21/2015	7/21/2015		NATURAL GAS SMELL. 1ST AND 4TH FLOORS.
FO-322682	7/22/2015			TOO WARM. ROOM 2156.
FO-322681	7/22/2015	7/22/2015		RM 1241 TOO COLD
FO-322708	7/22/2015			RM 2602.1 IS TOO COLD
FO-322777	7/23/2015			RM 5229 FUME HOOD LIGHT OUT
FO-322782	7/23/2015	7/24/2015		RM 206/SERVER RM IS EXTREMELY HOT
FO-322871	7/24/2015			FAP FIRE TROUBLE ALARM
FO-322908	7/27/2015			CAFETERIA 1350 TOO HOT
FO-322911	7/27/2015			TOO HOT. GREEN LECTURE HALL AND JAFAR HALL.
FO-322945	7/27/2015			RM 7130 LOUD BUZZING NOISE
FO-322950	7/27/2015			RM 6205 IS TOO HOT
FO-323043	7/28/2015	7/28/2015		BSMNT 0247 LOW TEMP
FO-323060	7/28/2015	7/28/2015		TOO HOT. ROOM 0133.

WO	Recieved	Finished	Total	Request
FO-323066	7/28/2015	7/28/2015		RM 0514 & 0515 LOUD WHISTLING NOISE WHEN DOOR IS CLOSED
FO-323143	7/29/2015			RM 5229 BOTH CHEMICAL FUMEHOODS LITES ARE OUT
FO-323153	7/29/2015	7/29/2015		RM 514 THE AIR EXCHANGE W/IN RM AFTER HAS BEEN SHUT TIGHT IT WHISTLES THRU OUT LAB CAUSING RAT RM DISTURBANCE
FO-323155	7/29/2015	7/29/2015		RM 515 THE AIR EXCHANGE W/IN RM AFTER HAS BEEN SHUT TIGHT IT WHISTLES THRU OUT LAB CAUSING RAT RM DISTURBANCE
FO-323169	7/29/2015			RM 143.1/SERVER RM IS EXTREMELY HOT COULD BE DAMAGING
FO-323171	7/29/2015			TOO HOT. ROOM 6205.
FO-323262	7/30/2015			RM 8337 HIGH TEMP ALARM
<b>E - North</b>			<b>48</b>	
FO-320872	7/1/2015	7/1/2015		TOO COLD. ROOM 317
FO-320960	7/2/2015	7/2/2015		BLDG TOO COLD
FO-320978	7/2/2015	7/2/2015		TOO COLD. ROOM 2077.
FO-321016	7/6/2015	7/6/2015		CARRIAGE HSE ACU STOPPED WRKNG
FO-321037	7/6/2015	7/21/2015		POWER BUMP.
FO-321039	7/6/2015	7/6/2015		POWER BUMP.
FO-321519	7/10/2015			ADDING ELEC R/R RM 215 (to gain access to Rm 215 go thru Rm 247) NEED ELECS' TO CK AN ALL EQUIP ALARM W/DIGITAL NO RESET VPS alarm sounding in IT server room- something related to the VPS and the digital clocks  Completed 7-14-2015 SRP
FO-321596	7/13/2015	7/13/2015		TOO COLD. BUILDING.
FO-321597	7/13/2015	7/13/2015		TOO COLD. BUILDING.
FO-321603	7/13/2015	7/13/2015		AUDITORIUM TOO COLD
FO-321617	7/13/2015	7/13/2015		CEILING GRATE IS OPEN. ROOM 4231.
FO-321932	7/14/2015	7/14/2015		BLOWN FUSE. ROOM 4101.
FO-321936	7/14/2015	7/14/2015		RM 4099 OUTLETS NOT WORKING
FO-322021	7/15/2015	7/15/2015		CEILING CRATE IS OPEN. ROOM 4321. (2ND REQUEST)
FO-322109	7/16/2015	7/16/2015		RM D TOO HOT, EVENT TODAY
FO-322129	7/16/2015	7/16/2015		RM 105 TOO HOT
FO-322177	7/17/2015	7/17/2015		TOO HOT. ROOM 105.
FO-322178	7/17/2015	7/17/2015		BSMNT RM 21 TOO HOT
FO-322269	7/20/2015	7/20/2015		TOO HOT. WOODCOCK SIDE ON ALL FLOORS.
FO-322272	7/20/2015	7/20/2015		RM 3303/3305 TOO HOT
FO-322276	7/20/2015	7/31/2015		compressor unit will come on 10 minutes then trips
FO-322302	7/20/2015	7/20/2015		TOO HOT. A/C NOT WORKING. ROOM 2226.
FO-322310	7/20/2015	7/21/2015		POWER BUMP ALL EQUIP OFF LINE
FO-322314	7/20/2015	7/21/2015		POWER BUMP ALL EQUIP OFF LINE
FO-322317	7/20/2015	7/20/2015		POWER BUMP.
FO-322318	7/20/2015	7/20/2015		POWER BUMP.
FO-322529	7/21/2015	7/21/2015		A/C IS NOT WORKING. ROOM 150.
FO-322545	7/21/2015	7/21/2015		RM 2226 TOO HOT
FO-322568	7/21/2015	7/21/2015		BLDG IS TOO HOT
FO-322569	7/21/2015	7/21/2015		RM 105 IS TOO HOT
FO-322646	7/22/2015	7/22/2015		POWER BUMP.
FO-322658	7/22/2015	7/22/2015		BUZZING NOISE COMING FROM ROOM 3261.
FO-322668	7/22/2015	7/22/2015		TOO HOT. WOODCOCK WING. ALL FLOORS.
FO-322693	7/22/2015	7/31/2015		unit will not cool

WO	Recieved	Finished	Total	Request
FO-322783	7/23/2015	7/23/2015		The temperature in room 167 located in suite 146 needs to be adjusted again. It has dropped to 67 degrees making it cold in that office.  Thank you.
FO-322856	7/24/2015	7/24/2015		MIDDLE MAIN ENTRY DOOR IS STICKING HARD TO OPEN & LOCK
FO-322857	7/24/2015	7/24/2015		RM 255 HAS NO AIR TOO HOT
FO-322876	7/24/2015	7/24/2015		RM 3198 TOO HOT
FO-322903	7/27/2015	7/27/2015		RM 2074 AND 2077 TOO HOT
FO-322943	7/27/2015	7/27/2015		RM 105 TOO HOT
FO-323073	7/28/2015	7/28/2015		TOO HOT. ROOM 2040.
FO-323089	7/28/2015	7/28/2015		RM 1193 HAS A LOUD NOISE COMING FROM CLNG AIR VENT
FO-323170	7/29/2015	7/29/2015		TOO HOT. ROOM 3094.
FO-323174	7/29/2015	7/29/2015		2ND FLR IS TOO HOT
FO-323232	7/30/2015	7/30/2015		ROOM 150 Art Bldg. SOMEONE TURNED OFF THE AC AND IT IS REALLY HOT IN THE OFFICE. PLEASE TURN THE AC BACK ON!!!
FO-323245	7/30/2015	7/30/2015		TOO WARM. ROOM 2242.
FO-323256	7/30/2015	7/30/2015		RM 2226 TOO HOT PLEASE UPDATE LAKISHA 7-5471
FO-323291	7/30/2015	7/31/2015		Room air vent is buzzing and has not stopped. Second day in a row
<b>E - Northeast</b>			<b>19</b>	
FO-320959	7/2/2015			FIRE TROUBLE ALARM.  Completed 7-2-2015 SRP
FO-321260	7/7/2015	7/7/2015		BLDG TOO HOT 1ST FL VERY HUMID
FO-321261	7/7/2015	7/7/2015		TOO WARM. ROOM 115.
FO-321399	7/9/2015	7/9/2015		FIRE TROUBLE ALARM.
FO-321522	7/10/2015			There is a water leak in the room, which appears to be coming from the air conditioner/heating unit overhead, and just inside of the door. It is causing plaster to fall from around the inspection door.Painters cannot finish repairs until this leak is stop
FO-321590	7/13/2015	7/13/2015		FREER HSE 3RD FLR HAS A BUZZING SOUND COMING FROM THE ATTIC
FO-321905	7/14/2015	7/15/2015		COOLER RM 214 HIGH TEMP ALARM
FO-322079	7/16/2015	7/16/2015		TOO WARM. MEZZANINE
FO-322200	7/17/2015			FIRE TROUBLE ALARM. (MULTI-TASK)  Completed 7-20-2015 SRP
FO-322227	7/17/2015	7/21/2015		MDF RM IN DISPATCH HUMIDIFIER ALARM SOUNDING
FO-322256	7/20/2015	7/20/2015		TOO HOT. ROOM 115.
FO-322510	7/21/2015	7/21/2015		FIRE TROUBLE ALARM.
FO-322566	7/21/2015			FIRE TROUBLE ALARM UNABLE TO STOP ALARM SO DISABLED  Completed 7-24-2015 SRP
FO-322926	7/27/2015	7/30/2015		RM 225 TOO HOT
FO-323063	7/28/2015	7/31/2015		RM 203 & 206 TOO HOT
FO-323067	7/28/2015	7/30/2015		ROOF HATCH ALARM.
FO-323239	7/30/2015	7/30/2015		FIRE TROUBLE ALARM
FO-323241	7/30/2015	7/30/2015		RM 202 & 203 NO AIR, TOO HOT
FO-323243	7/30/2015	7/31/2015		1ST FL TOO HOT
<b>E - Preventative Maintenance</b>			<b>54</b>	
FO-320937	7/1/2015	7/1/2015		RM 2139/UNISEX RR ONLY TOILET IS PLUGGED
FO-320940	7/1/2015			AC unit has stopped working. Please repair or replace.
FO-320939	7/1/2015	7/1/2015		RM 223 AIR NOT WORKING
FO-320988	7/2/2015	7/9/2015		FIRE ALARM SOUNDING 1ST FLOOR BEHIND CIRCULATION DESK.

WO	Recieved	Finished	Total	Request
FO-320989	7/2/2015	7/3/2015		AF28A LOW TEMP ALARM
FO-321060	7/6/2015	7/6/2015		TOO HOT. ROOM 598.
FO-321063	7/6/2015	7/6/2015		WALL OUTLETS ARE NOT WORKING. ALL THE OUTLETS ON THE RIGHT SIDE. ROOM 4171.
FO-321309	7/7/2015	7/8/2015		RM 4621 TOO COLD
FO-321310	7/7/2015	7/8/2015		RM 1348 DISH WASHER SINK HAS WATER SHOOTING OUT FO IN PROGRESS WITH PLUMBER CAN YOU PLEASE TURN WATER OFF
FO-321313	7/7/2015	7/8/2015		HVAC Chiller is not working properly. Our room is normally 5-10 degrees cooler than it currently is. Please investigate and rectify the issue.  Thanks in advance, Andrew Murrell
FO-321380	7/8/2015	7/9/2015		DOOR 071-02-NORTH IS STUCK OPEN.
FO-321462	7/9/2015	7/9/2015		RM 0514 HIGH TEMP ALARM
FO-321466	7/9/2015	7/10/2015		4TH FLR NORTH BRIDGE GOING TOWARD PRESIDENTS' OFC THE 1ST SUPPORT BEAM ON SOUTH SIDE OF NORTH BRIDGE IS PULLING LOOSE
FO-321473	7/9/2015	7/9/2015		LAB 0330 AIR NOT WORKING, TOO HOT THEY CAN HEAR WATER RUNNING BUT NO ACTUAL WATER
FO-321540	7/10/2015	7/13/2015		RM 30 DI WATER NOT WORKING
FO-321864	7/13/2015	7/13/2015		Office 1101 is very hot. Thermostat was put on very low and still is too hot. The vent were checked and it appears there is no airflow whatsoever. This needs to be checked. Thank you.
FO-321868	7/13/2015	7/13/2015		RM 2602.1 TOO COLD
FO-321981	7/14/2015	7/14/2015		RM 275 TOO COLD
FO-321985	7/14/2015	7/15/2015		CLOGGED TOILET. 1ST FLOOR WOMEN'S RESTROOM.
FO-321991	7/14/2015	7/14/2015		2ND FL COLD RM NEXT TO RM 2151 (RM NOT NUMBERED) RM IS TOO HOT
FO-322157	7/16/2015	7/17/2015		ART LAB 3141 PAINT BRUSH STUCK IN DRAIN, SEE LAUREN IN RM 3121 OR CHRIS IN 3121
FO-322231	7/17/2015	7/17/2015		ANIMAL QUARTERS HIGH HUMIDITY
FO-322232	7/17/2015			MDF RM IN DISPATCH HUMIDIFIER ALARM SOUNDING
FO-322233	7/17/2015	7/18/2015		SOMETYPE OF ALARM @1ST FLR IS ACTIVE PANEL SAYS TROUBLE
FO-322234	7/17/2015			4TH FL HALLWAY CEILING LEAK
FO-322235	7/17/2015			LAB 4167 TOO HOT
FO-322319	7/20/2015			FIRE TROUBLE ALARM.
FO-322321	7/20/2015			CEILING LEAK. ROOM 404.
FO-322322	7/20/2015			DUE TO POWER BUMP. AIR CONDITIONING IS NOT WORKING, AND DOORS ARE NOT CLOSING PROPERLY DUE TO AIR PRESSURE.
FO-322324	7/20/2015	7/20/2015		RM 322 TOO HOT
FO-322331	7/20/2015			101 OFFICE BLOCK AIR WAS NOT RESTORED AFTER POWER BUMP
FO-322623	7/21/2015	7/21/2015		RM 247 DOOR LOCK NOT LATCHING, UNABLE TO SECURE RM
FO-322625	7/21/2015	7/17/2015		FIRE ALARM BUZZING POWER PUMP
FO-322627	7/21/2015	7/17/2015		ALARM NEEDS TO BE RESET
FO-322717	7/22/2015	7/23/2015		WALL OUTLETS ARE NOT WORKING. ROOM 1030.
FO-322887	7/24/2015	7/24/2015		3RD FL CORNER OFFICE AT END OF HALL, AC LEAKING SEE SHAWN FOR DETAILS
FO-322979	7/27/2015	7/27/2015		TOO HOT. ROOM 4117.
FO-322982	7/27/2015	7/27/2015		Purdy Library, 2nd Floor, Room 240 Men's Room located in Stairwell #1  Toilet flushing non-stop. Please repair.  Thank you.
FO-322985	7/27/2015	7/27/2015		ELECTRICAL BURNING SMELL. 1ST FLOOR FRONT VESTIBULE.
FO-322988	7/27/2015	7/27/2015		TOO HOT. 2ND FLOOR INCLUDING ROOM 2041.

WO	Recieved	Finished	Total	Request
FO-323108	7/28/2015	7/28/2015		TOO HOT. ROOM 322.
FO-323115	7/28/2015	7/29/2015		TOO COLD. ROOM 231.6.
FO-323120	7/28/2015	7/28/2015		BACK EXIT DOOR NOT CLOSING
FO-323183	7/29/2015	7/30/2015		RM 112 TOO COLD
FO-323185	7/29/2015	7/30/2015		RM 5234 TOO HOT
FO-323187	7/29/2015	7/30/2015		BSMT STUDIO S HAS SEVERAL CLNG PIPES THAT ARE LEAKING
FO-323194	7/29/2015	7/30/2015		RM 7334 ACTIVE CEILING LEAK
FO-323196	7/29/2015	7/29/2015		RECEPTION AREA HALLWAY ALARM PANEL IN ALARM
FO-323197	7/29/2015	7/30/2015		143.1 ALARM SOUNDING ONE SIDE OF RM IS TOO HOT
FO-323198	7/29/2015	7/29/2015		POSSIBLE POWER BUMP
FO-323230	7/30/2015			CALLED SCHINDLER ELEV CO FOR BLDG POWER BUMP HAPPEN APPR 3:11AM CAUSING #1/FREIGHT & #2/WEST ELEVS TO GO INTO FIRE MODE 1ST FLR DOORS OPEN (2 BUMPS HAPPEN YESTERDAY/THIS MORN) REF #49296533
FO-323299	7/30/2015			MACK SIDE ALARM SOUNDING
FO-323304	7/30/2015			14200.5 & 14200.9 TOO HOT
FO-323305	7/30/2015	7/30/2015		3RD FL 3054 AND SURROUNDING AREA TOO HOT
<b>E - South</b>			<b>42</b>	
FO-320904	7/1/2015	7/3/2015		AIR VACUUM SYSTEM IS DOWN
FO-320914	7/1/2015	7/1/2015		RM 113 TOO COLD
FO-320953	7/2/2015	7/2/2015		FIRE ALARM SOUNDING. BASEMENT
FO-320961	7/2/2015	7/3/2015		BLDG AIR VACUUM SYSTEM IS STILL DOWN
FO-321017	7/6/2015	7/7/2015		FIRE ALARM SOUNDING AFFECTING BASEMENT WINDOWS CONTACT MARILYN FOR EXACT WINDOWS.
FO-321038	7/6/2015	7/6/2015		ALARM SOUNDING. 1ST FLOOR.
FO-321253	7/7/2015	7/7/2015		TOO HOT. BUILDING
FO-321267	7/7/2015	7/14/2015		DOORS NOT CLOSING. AIR PRESSURE PROBLEM. ALL ENTRANCE DOORS TO BUILDING.
FO-321327	7/8/2015	7/8/2015		TOO WARM. AUDITORIUM ROOM 1507. DANTO BUILDING.
FO-321366	7/8/2015	7/8/2015		RM 453 WALK IN COLD RM BOX STOPPED WRKNG
FO-321391	7/9/2015	7/14/2015		SOUND OF WATER IN CEILING. ROOM 3100. PLEASE CHECK.
FO-321398	7/9/2015	7/10/2015		BEEPING NOISE COMING FROM THE EMERGENCY RESPONSE ROOM. ROOM 1100.
FO-321449	7/9/2015	7/16/2015		LAB 0330 AIR NOT WORKING, TOO HOT
FO-321496	7/10/2015			RM 450 WALK IN COLD RM BOX HAS A PIPE LEAK IN THE COMPRESSOR
FO-321531	7/10/2015			RM 2171 CK NON WORKING CHEMICAL FUMEHOODS
FO-321532	7/10/2015			RM 2177 CK NON WORKING CHEMICAL FUMEHOODS
FO-321537	7/10/2015			Hallway light switch closest to the exit doors towards Life Science is broken. Someone shoved paper in it to keep the lights on in the hallway. If paper is removed lights turn off.
FO-321577	7/13/2015	7/14/2015		FIRE ALARM PANEL SOUNDING. 1ST FLOOR.
FO-321594	7/13/2015	7/13/2015		WATER SUPPLY PIPE LEAK. ROOM 1355. PLEASE VERIFY.
FO-321595	7/13/2015	7/13/2015		TOO HOT. ROOMS 334 AND 234.
FO-321607	7/13/2015	7/13/2015		LOW TEMP. ALARMS. ROOMS 26 AND 27.
FO-321631	7/13/2015	7/13/2015		RM 419 A FAINT SMELL OF NATURAL GAS
FO-321903	7/14/2015	7/16/2015		PIPE LEAK. COLD ROOM. ROOM 450.
FO-322012	7/15/2015	7/17/2015		WALL OUTLETS ARE NOT WORKING. ROOM 2151.
FO-322022	7/15/2015	7/15/2015		RM 275 TOO COLD
FO-322031	7/15/2015	7/16/2015		BLOWN FUSE. ROOM 3100
FO-322131	7/16/2015		7/16/2015	LAB 230 FUME HOOD # 7,11,12 NEED FLOW TURNED UP. THEY FAILED INSPECTION
FO-322138	7/16/2015	7/17/2015		BEEPING NOISE COMING FROM COLD ROOM. ROOM 4130.
FO-322189	7/17/2015	7/17/2015		LAB 120 LEFT WATER LINE LEAKING ON FH 13



WO	Recieved	Finished	Total	Request
FO-322315	7/20/2015	7/21/2015		POWER BUMP.
FO-322316	7/20/2015	7/20/2015		POWER BUMP.
FO-322575	7/21/2015	7/21/2015		RM 133 HAS A CEILING STEAM LEAK ALSO LEAKING WATER ABOVE WALK IN REFRIGERTOR (if need access contact Greg) **SEE RESULTS**
FO-322699	7/22/2015	7/22/2015		RM 140/LAB FUMEHOOD #6 (PANEL) IS GIVING A GENERAL FAILURE MESSAGE
FO-322702	7/22/2015	7/27/2015		RM 140/LAB FUMEHOOD #4 IS BEEPING
FO-322735	7/23/2015	7/29/2015		TOO HOT. ROOM 1100.
FO-322736	7/23/2015	7/29/2015		TOO HOT. ROOM 3100.
FO-322755	7/23/2015	7/23/2015		TOO HOT. ROOM 146.
FO-322793	7/23/2015	7/31/2015		LAB 0162 PLEASE TURN WATER BACK ON FOR DI WATER SYSTEM
FO-323134	7/29/2015	7/29/2015		3RD FLR IS EXTREMELY HOT NO AIR FLOW
FO-323152	7/29/2015	7/31/2015		LAB 4159/4167 TOO HOT AND HUMID
FO-323165	7/29/2015	7/29/2015		FIRE TROUBLE ALARM
FO-323233	7/30/2015	7/30/2015		FIRE TROUBLE ALARM.
<b>E - Southeast</b>			<b>13</b>	
FO-320900	7/1/2015	7/1/2015		RM 3317 & 3372 TOO COLD
FO-320966	7/2/2015	7/2/2015		RM 0319 OUTLETS ON SOUTH WALL NOT WORKING
FO-321407	7/9/2015			RM 2218 IS TOO COLD *SEE RESULTS*
FO-321408	7/9/2015	7/9/2015		RM 2212 IS TOO COLD
FO-321604	7/13/2015	7/14/2015		NO AIR. ROOM 5018.
FO-321912	7/14/2015	7/14/2015		RM 5018 IS STILL TOO HOT
FO-322187	7/17/2015			RM 3214 ACU FAN ISN'T WORKING
FO-322924	7/27/2015	7/27/2015		BSMNT FIRE TROUBLE ALARM
FO-322946	7/27/2015	7/27/2015		NO AIR. ROOM 1134, 1137, 133 & 1145.
FO-323079	7/28/2015	7/28/2015		RM 5102 ACU IS BLOWING OUT HOT AIR INSTEAD OF COLD
FO-323163	7/29/2015	7/29/2015		TOO HOT. CONFERENCE ROOM 6202.
FO-323257	7/30/2015			Compliance Office / room is too cold
FO-323268	7/30/2015			TOO COLD. ROOM 2316.
<b>E - West</b>			<b>6</b>	
FO-321328	7/8/2015	7/8/2015		TOO COLD. LOBBY, AUDITORIUM ROOMS 100 AND 150.
FO-321914	7/14/2015	7/14/2015		TOO COLD. (COLD AIR BLOWING FROM VENT) ROOM 1148.
FO-322108	7/16/2015			CEILING A/C UNIT IS MAKING A VERY LOUD NOISE. ROOM 1148.
FO-322548	7/21/2015	7/22/2015		RM 1030 LOST POWER IN WALL OUTLETS (ROBOT UNIT AREA)
FO-323266	7/30/2015	7/30/2015		PROBLEM WITH FUME HOOD. ROOM 19.3.
FO-323267	7/30/2015			LAB 19.3 HIGH HUMIDITY
<b>Medium</b>			<b>55</b>	
<b>E - Auxiliary</b>			<b>9</b>	
FO-320908	7/1/2015	7/17/2015		Inspect/repair/advise the air conditioning unit at WDET transmitter. Possible problem with generator
H-53206	7/7/2015	7/8/2015	7/15/2015	Ashley Hepp 07/15/2015 12:53 - The sink drain on the right side of the sink won't drain right (very, very slow) and the garbage disposal (also on right side) won't work. authenticated user: Autumn Patty - ev9883 requester ip address: 108.247.213.87
H-53272	7/14/2015			Air conditioner is broken and will not produce cold air. This service request was submitted by an RA authenticated user: Anthony Kurcz - ez7811 requester ip address: 141.217.23.218

WO	Recieved	Finished	Total	Request
H-53307	7/19/2015			When the shower is running, it leaks through the floor into room 503. The guest in 503 is the one that reported the problem. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.218
H-53381	7/25/2015			Water will not come out of the shower head because the lever that controls the shower and the bath is missing. authenticated user: Isabell Groves - fb2096 requester ip address: 141.217.23.210
H-53457	7/28/2015			Outlet in bedroom AB (Larger bedroom) does not work. It is the outlet near the bedroom door.  authenticated user: Tamika Davis - eq2532 requester ip address: 141.217.23.214
H-53458	7/29/2015			The ac in the apartment was not working before the repairs. It only blew out the air from the apartment. Vent might also need to be cleaned. authenticated user: Aja Pettiford - fi6887 requester ip address: 35.16.70.212
H-53476	7/29/2015			Garbage disposal not working authenticated user: Minna Cheng - fk8161 requester ip address: 35.16.73.145
H-53467	7/30/2015			Hello, I would like to request for three 2-prong outlets in my unit be converted to 3-prong outlets. An appliance that I purchased can not be used in my bedroom because there are NO 3-prong outlets in the room. Using an adapter would be dangerous and a
<b>E - Command Center</b>			<b>27</b>	
FO-320905	7/1/2015	7/1/2015		trade seimens priority medium R/R PENTHOUSE please service chill water pump setting on chill water pump #1 in pent house area
FO-314171	7/1/2015			CONTROLS, COOLING TOWER MAKEUP CONTROLLER FAILED, PLEASE REPAIR. PRIORITY-MEDIUM
FO-311899	7/1/2015			Replace Heat Pump - RM 10303.3
FO-320991	7/3/2015	7/6/2015		trade seimens priority medium R/R RM PENTHOUSE WEST please service air handler #8 will not run in auto position even after reset
FO-321404	7/9/2015	7/10/2015		trade seimens priority medium R/R PENTHOUSE please service bypass valve for cooling tower located in pent house area needs to stay open at 4.ma
FO-321413	7/9/2015	7/9/2015		trade seimens priority medium R/R RM 6152/MECH RM please service air handler unit #2 showing alarm status but fan is running no belts are broke and its showing discharge is ok also check linkage is connected
FO-321451	7/9/2015		7/13/2015	trade seimens priority medium R/R RM 6149/MECH RM please service air handler unit #3 supply fan keeps tripping off ive reset this unit three times today not sure whats causing it to go off
FO-321459	7/9/2015	7/13/2015		Refrig Group,  Please help locate and repair leak in main air supply to thermostat in rm 1209.  See Engineer comments in FO-321275 for work already completed by engineer.
FO-321480	7/10/2015			Trade: Command Center Priority: Medium Please repair failed water meter on BAS system (F007.36.BLR.WTR.FLW).
FO-321555	7/11/2015	7/24/2015		Repair #1 boiler at University Towers. The starter for the burner forced draft fan trips on startup.  #2 boiler is in service.
FO-321558	7/12/2015	7/13/2015		Repair #2 boiler at State Hall. Mod motor is not moving. Boiler will not fire.
FO-321891	7/14/2015	7/20/2015		Trade: Controls/Siemens Priority: Medium Siemens panel 11 point F90.11.AHU.ALM is in an alarm condition and I do not know why. Please investigate. This panel is located in the EDC Penthouse Chiller Plant.
FO-322028	7/15/2015			BAS section: please install two dual duct tec controllers and associated devices/stats for lab/set up. Priority medium.
FO-322065	7/15/2015	7/16/2015		Trade: Command Center Priority: Medium R/R RM 277 Please update BAS graphics. Graphics for 277 are currently located in 275. Please move to 277
FO-322191	7/17/2015	7/23/2015		Trade: Command Center Priority: Medium R/R RM 3040 Please supply 2 packages (10 per package) of Siemans part 180-896 (preassembled pneumatic tubing kit) to repair leaking thermostat tubing.

WO	Recieved	Finished	Total	Request
FO-322207	7/17/2015			Trade: Controls/Siemens Priority: Medium R/R RM 2348 #1 fume hood in lab 2348 is in alarm registering high flow, please trouble shoot and repair. The other two fume hoods in this lab are normal and they are tied into the same exhaust duct work.
FO-322230	7/17/2015	7/23/2015		Trade: Command Center Priority: Medium R/R Lab 220 fume hoods 1, 2, 3, 6, 7, 8, 12, 13, 14 did not pass EVH inspection. Please repair. Sash sensors appear to be in working order.
FO-322242	7/20/2015	7/23/2015		Trade: Controls/Siemens Priority: Medium 090-ACU-402 EDC York Chiller #2 the run time is not updating, it has been at 23 hours for quite some time now.
FO-322283	7/20/2015			refrigeration dept. repair AHU # 1 it does not cool
FO-322572	7/21/2015	7/22/2015		Trade: Command Center Priority: Medium R/R RM 00028/MECH RM Please repair or replace AOP for the face and bypass damper on AHU #1. AOP is always bleeding air.
FO-322754	7/23/2015	7/28/2015		Trade: Controls Priority: Medium 090-ACU-402 R/R RM 4505/MECH RM Chiller system is shutting down for no apparent reason, I had to place the SYS #2 Enable point on in operator priority to get the system running again.
FO-322756	7/23/2015	7/29/2015		Trade: Controls Priority: Medium 090-ACU-402 R/R RM 4505/MECH RM Please look at the chiller system chilled water supply set point (F090.11.CHL.SSP) it seems high to me. Today the outside air temperature is 72 and the set point is 50. UNABLE TO LOCATE R
FO-322947	7/27/2015	7/31/2015		Purdy Library 1st Floor, Office Suite 122 reset phase monitors, put fan on using t-stat compressors won't come on
FO-322953	7/27/2015			REFRIG CREW , R/R (FOR RM 5403) ROOFTOP AC UNIT FOR THE ELEVATOR EQUIPMENT ROOM IS ICING UP , PLEASE CORRECT. PRIORITY-MEDIUM
FO-322973	7/27/2015	7/28/2015		Reprogram energy recovery system, (ERS) settings to cool incoming air when OAT is >77 degrees at Elliman.  Any questions, contact Ed Nisnevich.
FO-323069	7/28/2015			Trade: Controls/Boilers Priority: Medium 090-BSG-002 Perform post combustion test on Boiler #2.
FO-323132	7/29/2015	7/30/2015		CONTROLS: R/R ROOF PLEASE CHECK THE EXHAUST FANS 1-5 CONTROLS (FANS ARENT RUNNING IN AUTO) PRIORTIY MED EXH FAN #5 EQ NOT AVAIL IN TMA SYS
<b>E - MedPharm</b>			<b>4</b>	
FO-322259	7/20/2015	7/21/2015		Please make sure all steam is shut off to autoclave. OEHS has shut machine down due to leaks and mold growth in room.
FO-322604	7/21/2015	7/23/2015		AUTOClave IS NOT WORKING. ROOM 8337.
FO-322792	7/23/2015	7/23/2015		Air pressure in room 0507 is zero - should be negative to the hallway. Also, rooms 0514 and 0515 pressure is too high (door whistles).
FO-323125	7/29/2015			Replace condenser water pump coupling.
<b>E - North</b>			<b>8</b>	
FO-321616	7/13/2015	7/13/2015		The temperature is very cold in this department. We are walking around with fleeces and sweaters. Could we have the temperature adjusted? Thank you very much.
FO-322008	7/15/2015	7/15/2015		Temperature is very cold in this suite. We would like the temperature adjusted.  Thank you.
FO-322038	7/15/2015	7/15/2015		RM 317 TOO COLD
FO-322122	7/16/2015	7/15/2015		RM 317 TOO COLD 2ND REQUEST PLEASE UPDATE RASHIDA 7-5380
FO-322278	7/20/2015	7/20/2015		LOBBY ALARM SOUNDING

WO	Recieved	Finished	Total	Request
FO-322286	7/20/2015	7/20/2015		High pitched whistling sound in room
FO-322547	7/21/2015	7/21/2015		Air conditioning isn't working.
FO-322667	7/22/2015	7/22/2015		RM 334 TOO HOT
<b>E - Northeast</b>			<b>2</b>	
FO-322660	7/22/2015	7/22/2015		RM 115 TOO HOT OVER 80, PLEASE SEE CAROL
FO-322760	7/23/2015	7/24/2015		Repair thermostat in room 313 Northwest corner by cubicle 41. Unit is making a loud noise every now and again.
<b>E - Preventative Maintenance</b>			<b>5</b>	
FO-321379	7/8/2015	7/8/2015		Room very hot and humid.
FO-322320	7/20/2015	7/21/2015		air conditioner not working again. Was just recently worked on.
FO-322328	7/20/2015			RM 108 AC NOT WORKING
FO-322829	7/23/2015			Ceiling mounted exhaust fan has stopped working.
FO-323118	7/28/2015			RM 230 AC UNIT'S NOT WORKING, BLOWING HOT AIR
<b>Low</b>			<b>244</b>	
<b>E - Area 1 Engineer</b>			<b>1</b>	
FO-321486	7/10/2015	7/10/2015		Good morning, I have a young lady who heard loud rustling in her office. She checked all her drawers and cupboards, no droppings. Then she heard loud foot steps run through the wall and ceiling. She is very upset! Could someone please check into it when t
<b>E - Auxiliary</b>			<b>121</b>	
H-53135	7/1/2015	7/1/2015	7/15/2015	Ashley Hepp 07/15/2015 14:54 - Air condition is broken. authenticated user: Marcus Beeler - fi1640 requester ip address: 141.217.23.218
H-53138	7/1/2015	7/2/2015	7/15/2015	Ashley Hepp 07/15/2015 09:44 - A/C is not working. authenticated user: Christopher Ozog - fi3944 requester ip address: 141.217.230.87
H-53137	7/2/2015	7/2/2015	7/15/2015	Ashley Hepp 07/15/2015 09:39 - Major leaking in sinks at Towers Cafe. authenticated user: Julie Malear - fg9040 requester ip address: 141.217.23.186
H-53152	7/2/2015	7/9/2015	7/15/2015	Ashley Hepp 07/15/2015 13:00 - Resident is requesting new shower head authenticated user: Nicole Fry - eq0918 requester ip address: 141.217.23.210
H-53155	7/2/2015	7/6/2015	7/15/2015	Ashley Hepp 07/15/2015 09:48 - There is a leak in the ceiling right outside of the bathroom. I'm not sure how the leak got started. authenticated user: Jonathan Solomon - ft1235 requester ip address: 141.217.23.205
H-53168	7/3/2015	7/6/2015	7/15/2015	Ashley Hepp 07/15/2015 09:56 - Food waste disposer doesn't work. Thank you. authenticated user: Boshen Zhang - fc5991 requester ip address: 141.217.233.78
H-53170	7/4/2015	7/6/2015	7/15/2015	The garbage mincing device in the sink doesn't work. Strange noise from it. authenticated user: Yueyang Zhang - fc3659 requester ip address: 141.217.232.181
H-53159	7/5/2015	7/8/2015	7/15/2015	Ashley Hepp 07/15/2015 15:33 - The exhaust fan in the bathroom (at the far end of the hallway) has started making noises/is louder than it normally used to be, and I don't think is working correctly. authenticated user: Juhi Kushwaha - fk4773 requeste
H-53156	7/6/2015	7/6/2015	7/15/2015	Ashley Hepp 07/15/2015 09:45 - Shower head is leaking authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.218
FO-321000	7/6/2015	7/31/2015		Campus Health Center patient room #3 air conditioner leaking water; puddle on floor
H-53163	7/6/2015	7/7/2015	7/15/2015	Ashley Hepp 07/15/2015 11:22 - Disposal in kitchen "exploded"?

WO	Recieved	Finished	Total	Request
H-53165	7/6/2015	7/10/2015	7/15/2015	Ashley Hepp 07/15/2015 15:26 - Handle of the sink is loose.
H-53188	7/6/2015	7/7/2015	7/15/2015	Ashley Hepp 07/15/2015 11:25 - I have sent the requests and got a reply to separate them. This is for the food disposal blender under the sink. It started leaking yesterday. Thanks authenticated user: Xiaoyang Li - fp6057 requester ip address: 146.9.2
H-53184	7/7/2015	7/15/2015	7/15/2015	Ashley Hepp 07/15/2015 12:10 - My kitchen sink will not drain properly. It may be due to an issue with the garbage disposal. authenticated user: Jessica Weaver - fi2693 requester ip address: 70.194.35.194
H-53185	7/7/2015	7/7/2015	7/15/2015	Toilet bump does not work. authenticated user: Yueyang Zhang - fc3659 requester ip address: 141.217.232.181
H-53200	7/7/2015	7/10/2015	7/15/2015	Ashley Hepp 07/15/2015 15:27 - The kitchen faucet on the sink has become disconnected from the sink authenticated user: Ryan Price - es1721 requester ip address: 141.217.220.120
H-53201	7/7/2015	7/8/2015	7/15/2015	Ashley Hepp 07/15/2015 15:31 - The bathroom exhaust fan in the bathroom at the far end of the hallway isn't working properly and is making noises. authenticated user: Juhi Kushwaha - fk4773 requester ip address: 141.217.220.221
H-53202	7/8/2015	7/10/2015	7/15/2015	Ashley Hepp 07/15/2015 15:29 - The electric outlet in the kitchen (next to the stove) is broken. Needs to be replaced. Thank you in advance. authenticated user: Lea Yazigi - eh2382 requester ip address: 141.217.220.122
H-53198	7/8/2015	7/9/2015	7/15/2015	Ashley Hepp 07/15/2015 13:03 - My AC is having issues again. It's constantly running, and I don't believe it stops. It sounds like it's going to switch on the cooler air, but then it stops. authenticated user: Thomas Wolf - fj0736 requester ip address
H-53222	7/8/2015			Sink and closet faulty.authenticated user: Sohrab Sukhu - fr4260requester ip address: 141.217.59.50
H-53223	7/8/2015			Kitchen Sink Leakingauthenticated user: Santhosh Kumar Kalikota - fq6166requester ip address: 35.16.197.132
H-53224	7/9/2015	7/9/2015	7/15/2015	Ashley Hepp 07/15/2015 13:05 - constant shower leak in room 628 - Ghafari
H-53225	7/9/2015			Flush in the main bathroom(Which has bath tub) doesn't work at allauthenticated user: Sai Bindu - fn8337requester ip address: 136.2.1.113
H-53237	7/10/2015			Outlets in the room are not working. authenticated user: Danielle Henry - ew4467requester ip address: 141.217.23.191
H-53227	7/10/2015			The pipe under the kitchen sink is leaking.authenticated user: Christian Oliver Avila - ez7149requester ip address: 141.217.59.60
H-53230	7/10/2015			Toilet continuously runs unless the handle is pulled upwardsauthenticated user: Celia Staniak - ev6281requester ip address: 141.217.23.210
H-53243	7/10/2015			Bathroom flush not working.authenticated user: Darshan Bangalore Suresh - fr0796requester ip address: 35.16.199.54
H-53235	7/10/2015	7/12/2015	7/15/2015	Ashley Hepp 07/15/2015 15:23 - The trap under the bathroom needs replacement. authenticated user: Ashley Fry - ej8471 requester ip address: 141.217.23.210
H-53247	7/11/2015			toilet as often overflowed. the flush doesn't cutoff as it should. So please solve this problem at earliest as we cant use that toilet.authenticated user: Shantanu Nalavade - ft5111requester ip address: 35.16.196.215
H-53252	7/12/2015			The air conditioning is broken authenticated user: - requester ip address: 141.217.224.119
H-53240	7/12/2015			Air conditioner is not and will not blow out cold air.authenticated user: Jamone Lewis - em8190requester ip address: 141.217.23.225
H-53241	7/12/2015			Air conditioner isn't working, only blowing out warm air. PLEASE DO NOT IGNORE THIS ONE SHEILA.authenticated user: Jasmynn Brown - fk4951requester ip address: 141.217.23.191

WO	Recieved	Finished	Total	Request
H-53255	7/13/2015			The air conditioning unit is not working and they have tried to reset it multiple times. Also there may be mold in the D suite on the ceiling.authenticated user: Mark Teague - eg3572requester ip address: 141.217.224.236
H-53273	7/13/2015			The Ceiling light, its bulb is burnt out in the hallway of the apartment.authenticated user: Julia Kamenko - fc8584requester ip address: 35.16.199.167
H-53275	7/13/2015			kitchen disposer is not workingauthenticated user: Ayse Karaca - ek6995requester ip address: 35.16.197.51
H-53260	7/13/2015			Thermostat is nearly falling off the wall and needs to be sealed back in place. authenticated user: William Alexander - ew0056requester ip address: 35.16.106.3
H-53258	7/13/2015			Air conditioning in this apartment is not working.
H-53261	7/13/2015			Air conditioning not workingauthenticated user: Aarti Sajnani - ez8543requester ip address: 141.217.23.186
H-53270	7/13/2015			Remove ceiling fan in kitchen authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210
H-53263	7/13/2015			Air conditioning not working in suiteauthenticated user: Omar Ahsan - fa4601requester ip address: 141.217.224.90
H-53268	7/14/2015			Towers 449 - AC not working
H-53269	7/14/2015			Towers 918 - AC not working
H-53277	7/14/2015			Towers 907 AC not working
H-53278	7/14/2015			Towers 808 AC not working
H-53281	7/14/2015			Bathroom has leaking ceiling. authenticated user: Marcus Beeler - fi1640 requester ip address: 141.217.23.187
H-53295	7/16/2015			The water in sink and shower smells a little weird in the room.authenticated user: Faith Basheer - fp3620requester ip address: 141.217.23.225
H-53289	7/16/2015			HIGH IMPORTANCEAs i moved in to the new apaartment, none of the STOVE IS WORKING, it doesn't warm at all stays cool and there is no bulb in the fridgeauthenticated user: Syed Hussain - eb4032requester ip address: 35.16.192.90
H-53293	7/17/2015			Important bathroom: water in the bath Tub doesn't go through the drain. authenticated user: Syed Hussain - eb4032requester ip address: 35.16.194.63
H-53296	7/17/2015			Towers 908 AC not working.
H-53298	7/18/2015			The air conditioning is not getting to parts of the room. Conference guest suggested that it might be a duct problem. The problem has been reported previously. authenticated user: Elliott Blatt - fo7891requester ip address: 141.217.23.186
H-53297	7/18/2015			The air is not working in the Fourth Floor Study Lounge nearest to the back hallway elevator.authenticated user: Olivia Wyche - fo3784requester ip address: 141.217.23.225
H-53303	7/20/2015			air conditioning stopped working 2 days after last service request was completedauthenticated user: Omar Ahsan - fa4601requester ip address: 141.217.224.90
H-53304	7/20/2015			The A/C in the 5th floor study lounge is nonfunctional. The unit does not display anything, even when manually reset by holding the up and down arrows.authenticated user: Tevin Monroe - fh3994requester ip address: 141.217.225.234
H-53322	7/20/2015			Towers CD apartment 238 - AC not working. I was hoping someone could come take a look at my apartment air conditioning on Monday. Our temperature was higher than usual yesterday, and even though we turned the AC on super-low, it didn't impact the apartme
H-53328	7/20/2015			*Engineer- Constant drip from the shower. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.218
H-53333	7/20/2015			*Engineer- Constant drip from the shower. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.218
H-53330	7/21/2015			Kitchen crusher unit is not functioning properly and also leaking.Probably needs to be replaced.authenticated user: Rahuldev Gurudev - fi6922requester ip address: 141.217.220.250
H-53334	7/21/2015			The air conditioning turns on when the room becomes warm; however, the AC is not cold and the room does not decrease in temperature while the AC is running. authenticated user: Jake Clor - ff6066 requester ip address: 35.16.194.208

WO	Recieved	Finished	Total	Request
H-53335	7/21/2015			The air conditioning turns on when the room becomes warm; however, the AC is not cold and the room does not decrease in temperature while the AC is running. authenticated user: Jake Clor - ff6066 requester ip address: 35.16.194.208
H-53336	7/21/2015			Light fixture over kitchen sink is flickering and making popping noises. VACANT ROOMauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53349	7/23/2015			Air conditioner is not working wellauthenticated user: Shiva Sudhan Ramthilak - fp9833requester ip address: 35.16.193.61
H-53350	7/23/2015			7th floor utility closet hot water faucet is broken. Water will not turn off.
H-53351	7/23/2015			Power is out in the kitchen
H-53372	7/25/2015			Bathroom (outer one)'s fan is broke and there is mold in the sink cupboard.authenticated user: Joshua Kong - fs9503requester ip address: 35.16.71.141
H-53368	7/25/2015			Washroom flush leakage problem Please respond as soon as possibleauthenticated user: Navyatha Paruchuri - fq9975requester ip address: 35.16.67.20
H-53371	7/25/2015			The Flush tank of the toilet (in 2nd bathroom) makes wierd noise after flushing.authenticated user: Abishek Kanagali - fs4533requester ip address: 35.16.72.160
H-53364	7/26/2015			In the bedroom located nearest to the door, the outlet on the near right wall has a broken cover panel that fell off and needs to be replaced. Please change the broken electrical panel as soon as possible as the outlet can shock people without the cover.
H-53378	7/26/2015			Hello,There has been a leak in my ceiling that has been causing water damage for the last two years, which I have previously reported. This morning, I noticed that a 6 inch by 8 inch portion of the ceiling had fallen down where the water damage was.Eng
H-53359	7/26/2015			A/C is not working in the room. The air is not blowing out cold. authenticated user: William Alexander - ew0056requester ip address: 141.217.23.191
H-53358	7/26/2015			Air Conditioner/Thermostat is not working.authenticated user: Mahpara Khan - fh3271requester ip address: 141.217.23.186
H-53360	7/26/2015			The ventilation in the room is not circulating. Room smells bad because the moisture is not escaping somewhere from the restroom. Vent in restroom is not working. authenticated user: William Alexander - ew0056requester ip address: 141.217.23.191
H-53367	7/27/2015			The outlet in the bedroom closest to the entrance on the near left wall does not work. Nothing plugged in it gets electrical power, even with the switch turned on and off. Please ensure that the electrical power is functioning. Thank you. Please note that
H-53363	7/27/2015			The air conditioning unit is not working. It only blows out hot air and the room temperature was 90 degrees.authenticated user: Mark Teague - eg3572requester ip address: 141.217.23.186
H-53423	7/27/2015			There is a red light on the thermostat and the air conditioning is not working.authenticated user: Kelly Beall - fz0226requester ip address: 141.217.83.147
H-53366	7/27/2015			Towers 948 - short light ballint out.
H-53376	7/27/2015			Towers 1115 needs new shower light ballit.
H-53392	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53393	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53394	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53395	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53406	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53407	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53408	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53409	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53410	7/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53427	7/27/2015			Shower is very noisy and water flow is reducedauthenticated user: Sonal Joshi - ec9262requester ip address: 35.16.87.33

WO	Recieved	Finished	Total	Request
H-53435	7/28/2015			Hi Team,Water Issues In the Morning:It seems the water do not flow normally in the morning between 7 to 9. It is causing a lot of inconvenience as everyone has to start their day at this point of time. I will appreciate prompt action on this matter.
H-53434	7/28/2015			My water doesn't get cold, only hot water. authenticated user: Jasmynn Brown - fk4951requester ip address: 141.217.23.225
H-53432	7/28/2015			replace pea trap to sink in gold n greens near the grill area.
H-53433	7/28/2015			leak coming from ceiling near sink area going into main serving area, gold n greens
H-53437	7/28/2015			Flush not working in bathroom authenticated user: Naveen Rajkumar - fs1514requester ip address: 141.217.220.197
H-53453	7/28/2015			Water dripping from kitchen faucet. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.214
H-53442	7/29/2015			Conference guests in room 518, air conditioning has been down since Sunday. I need a maintenance worker to repair it as soon as possible to ensure a comfortable stay for our guests. Thanks.Niyahauthenticated user: Niyah Riggins - fr0933requester ip ad
H-53444	7/29/2015			Air conditioning is not workingauthenticated user: Olivia Wyche - fo3784requester ip address: 141.217.23.225
H-53443	7/29/2015			Shower room lightauthenticated user: Grace Peng - fy6527requester ip address: 35.16.192.75
H-53440	7/29/2015			The first outlet on the right side of the wall (under the desk)is out of work.authenticated user: Laizhi Qian - fc6583requester ip address: 141.217.220.222
H-53445	7/29/2015			Bad Ballice in long light in hall way in front of 845; already has new lightauthenticated user: Chester Fleming - fc0603requester ip address: 141.217.23.186
H-53470	7/29/2015			Every morning since the last plumbing fixes, there has been water outage. No hot water (sometimes no water at all) from showers, kitchen sink and wash basin. authenticated user: Kaushik Innamuri - fr6209requester ip address: 12.165.188.171
H-53471	7/29/2015			Kitchen light out. Staff said it needs Needs ballast.authenticated user: Anthony Eid - eh2083requester ip address: 35.16.195.115
H-53472	7/29/2015			Hot water doesn't flow properly from Basin taps, showers and tap in bath-tub, in both the bathrooms. Sometimes same problem occurs with cold water as well. Have observed this especially in morning, for last 3-4 days.authenticated user: Sai Bindu - fn8337
H-53466	7/29/2015			Activity room air conditioners are not working and resident with health concern is having an event in the room. Please repair as soon as possible. Contact maintenance supervisor Patrick Armstrong if AC's are irreparable. authenticated user: Naijamah Alla
H-53478	7/30/2015			Bathroom 2 shower not working properlyauthenticated user: Neeraja Purandare - fi7856requester ip address: 141.217.220.234
H-53487	7/30/2015			PLEASE FIX AIR CONDITIONER AND LIGHT IN ROOM!!! BOTH ARE BROKEN authenticated user: Chevonne Abrams - eh3331 requester ip address: 141.217.23.191
H-53488	7/30/2015			A/C IS BROKEN authenticated user: Joanna Berry - fa3511 requester ip address: 141.217.23.225
H-53489	7/30/2015			a/c is broken authenticated user: Joanna Berry - fa3511 requester ip address: 141.217.23.225
FO-323251	7/30/2015			Engineer James Oman working 8 hours OT at 1.5X rate to catch-up on backlog of work. Rebill to Housing.
H-53509	7/30/2015			The back of the toilet leaks every time I flush. It's not bad now, but I thought I might mention it as it will most likely get worse as time goes on. authenticated user: Tara Delecce - fi0645 requester ip address: 141.217.84.90
H-53510	7/30/2015			Bathtub, shower, and sink in bathroom all leak. authenticated user: Saralyn Beckius - fy1036 requester ip address: 141.217.173.34
FO-323303	7/30/2015	7/30/2015		COMPANY IS DOING EXCAVATION @SOUTHEND OF SCB THERES' SPRINKLER FLOODING NEED WATER TURNED OFF/PH #410-0311
H-53508	7/30/2015			My air conditioner is not working, it never started back working since it was supposed to be fixed. Please help soon. Thank you. authenticated user: La'Toinetta Duhart - ei2630 requester ip address: 35.16.195.192



WO	Recieved	Finished	Total	Request
H-53490	7/30/2015			AC unit is acting up. Needs to be looked at. authenticated user: Thomas Wolf - fj0736 requester ip address: 35.16.199.15
H-53491	7/30/2015			My AC unit isn't working properly. It's blowing out warmer air than it should be blowing out. authenticated user: Thomas Wolf - fj0736 requester ip address: 35.16.199.15
H-53492	7/30/2015			A?C is no longer working inn this room as well as the floor. The A/C seems to be operating on a fan mode instead. authenticated user: JaNel Stephens-Dantzler - eo2346 requester ip address: 141.217.23.191
H-53493	7/30/2015			A?C is no longer working in this room. The A/C seems to be operating on a fan mode instead. authenticated user: JaNel Stephens-Dantzler - eo2346 requester ip address: 141.217.23.191
H-53494	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53495	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53496	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53497	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53498	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53499	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
H-53500	7/30/2015			The lounges on all the floors need to be looked at for their AC units. authenticated user: Thomas Wolf - fj0736 requester ip address: 141.217.23.225
<b>E - Command Center</b>			<b>32</b>	
FO-320889	7/1/2015			check repair condenser fan circuit 2nd stage roof rtu
FO-320891	7/1/2015	7/3/2015		BAS section: R/R PENTHOUSE please Troubleshoot tower bypass valve programming: valve is in full bypass at start up, needs to be open.
FO-311900	7/1/2015			Replace Heat Pump RM 10304.40
FO-320952	7/2/2015	7/14/2015		Please supply & install OA Temp/Humidity Sensor for Fitness Center
FO-321271	7/7/2015			A/C Controls please troubleshoot Titus mixing box blowing continuous cold air.
FO-321365	7/8/2015	7/13/2015		Control Engineer; Medium R/R RM 5102 Please check the refrigerant pressures in the heat pump #1-58-071-HWP-016. The compressor is cycling frequently.
FO-321622	7/13/2015	7/27/2015		To refrigeration dept., R/R RM 425/MECH-BLR RM BOLLer #1 pilot light is not stable during pilot trial. Shuts off early in cycle causing flame failure. Possible pilot solenoid or regulator. Please repair or replace.
FO-321630	7/13/2015	7/15/2015		CONTROLS R/R RM 290.01 please r/r compressor that is not working on Ocean Aire portable AC 2nf fl. lobby at beecher. Compressor does not come on at all. May be capacitor. parts for model PWC1211:  O17-003Capacitor 45 MFD 240 V.  020-003Compressor,
FO-321851	7/13/2015			Trade: Controls/Siemens Priority: Medium R/R BLDG Please trouble shoot the fume hoods in the following labs that failed certification recently: Lab in old lab wing; 2322 EDC Labs: 3546, 3542, 2550, 2530, 2534. The Strobic exhaust fans that serve these

WO	Recieved	Finished	Total	Request
FO-321874	7/13/2015	7/14/2015		BASEs: R/R RM 162/MECH RM Please synchronize cooling tower fan and 3-way valve controls. (Comp.Center chilled water plant).  Priority:low
FO-321897	7/14/2015	7/27/2015		REFRIG CREW- R/R RM 000116/MECH RM please r/r ACU 008 this unit services the IT room and condenser is in the pump room. Low side is iced up. suspect low charge.
FO-321904	7/14/2015	7/20/2015		R/R RM 00153 Repair AC unit in Tartar Shop...REFRIGERATION CONTROL TO CK THE REFRIGERANT CHARGE. ACU IS BLOWING OUT HOT AIR ONLY
FO-322026	7/15/2015	7/16/2015		BAS section: Please replace failed field panel (MEC16) in penthouse: not active/no communication. serves ahu 1 High priority
FO-322027	7/15/2015			BAS section: please replace heating valve actuator, Mott ahu 1. actuator failed.medium priority
FO-322066	7/15/2015	7/16/2015		Trade: Command Center Priority: Medium R/R RM 275 Please update BAS graphics. Graphics for rm 275 are currently located in rm 273 Please move to 275
FO-322150	7/16/2015	7/23/2015		Salvage parts prior to disposal.
FO-322515	7/21/2015			HONEYWELL please r/r control valve for reheat to conference room. Room overheated badly. Manual valve before control valve is closed currently. Please see engineer.
FO-322518	7/21/2015			CONTROLS please investigate and repair pneumatic leak on 1/3 steam valve to HEX2. Suspect diaphragm . valve is a Honeywell MP953C 1018 2 9920.
FO-322698	7/22/2015	7/30/2015		Controls R/R RM 330 inspect no voltage to reheat control valve room 330.
FO-322808	7/23/2015	7/24/2015		R/R RM 206 please have controls adjust ac-3 and ac6 on graphics ac-3 thermostat # is608-04.AC3 rm-t. High priority.
FO-322809	7/23/2015		7/23/2015	R/R RM 206 please have controls adjust ac-3 and ac6 on graphics ac-3 thermostat # is608-04.AC3 rm-t. High priority.
FO-322867	7/24/2015	7/28/2015		BAS- R/R RM 235 Please repair stat in room 235 which controls room 255 which are over heating. stat showing no power. 90f in room.
FO-322892	7/26/2015	7/27/2015		Adjust schedule on Sundays to start one AHU at 0900 hours in cooling season to enable chiller for General Lectures church services. Services start at 1101 hours.
FO-323047	7/28/2015			CONTROLS BAS SIEMENS- please check coiling coil sensor AHU1 at 5425 Woodward. Point on Siemens is inaccurate and indicates a problem.
FO-323050	7/28/2015			Vendor Purchase: Grainger  #5TU10 - Dewalt Cutoff Wheel (pack of 4) Qty: 1 pk \$45.15/pk  5YYB80 - Unistrut 10ft 1-5/8" Qty: 6 \$38.38/ea
FO-323072	7/28/2015			Boiler Parts Vendor Purchase: D. J. Conley  Part # 868-94: Capscrew 5/8" Qty: 20 \$2.50 ea  Part # 881-2254: NeonLamp, Red Qty: 10 \$22.50 ea  Part # 953-48: Handhole Yoke Qty: 5 \$28.45 ea  Part # 833-3182: Overload R

WO	Recieved	Finished	Total	Request
FO-323103	7/28/2015			Controls R/R BLDG repair intermittent cabinet failures for chillers.
FO-323104	7/28/2015	7/29/2015		Controls R/R PENTHOUSE investigate high static loop on AH-1
FO-323105	7/28/2015	7/30/2015		Controls R/R BSMT change chiller start/stop program based on leaving temperature.
FO-323139	7/29/2015			Honeywell: R/R RM 1215 lease reinstall subsystem data points for ZN MNGR P3 as all points that control all Law School vav boxes are missing on the Honeywell desktop computer. High Priority!
FO-323272	7/30/2015			Please purchase high head impeller from Burt Process equipment for a glycol pump.  Part #: 0343-306 \$ 40.52 Qty: 1
FO-323290	7/30/2015			Honeywell/refg crew:\nR/R 3RD FLR - AHU-3 control panel is showing a power failure and will not energize the fan motor through the Honeywell controls. Please correct and restart AHU-3. HIGH PROIRTY
<b>E - MedPharm</b>			<b>16</b>	
FO-320867	7/1/2015	7/1/2015		Room is too cold
FO-320910	7/1/2015	7/9/2015		animal rooms need ceiling filters changed
FO-321443	7/9/2015	7/9/2015		RECORDING REQ FROM THIS MORN TO MEET W/CONTRACTOR
FO-321915	7/14/2015	7/21/2015		Steam escaping from autoclave into the room
FO-321916	7/14/2015	7/14/2015		AF-14 HAS HI HUMDITY
FO-321917	7/14/2015	7/14/2015		AF-22 HAS HI HUMDITY
FO-321918	7/14/2015	7/14/2015		AF-26 HAS HI HUMDITY
FO-321953	7/14/2015	7/14/2015		RM 243/DLAR HAS HI HUMIDITY
FO-321954	7/14/2015	7/14/2015		RM 247/DLAR HAS HI HUMIDITY
FO-322045	7/15/2015	7/15/2015		ELDON WTR IND IS HERE TO TEST THE WATER SUPPLY
FO-322135	7/16/2015	7/16/2015		Fume hood is in continuous alarm, but has adequate air flow rate. Can adjustments be made to re calibrate the airflow sensor?
FO-322666	7/22/2015	7/22/2015		RM 0243 HAS LOW HUMIDITY
FO-322854	7/24/2015	7/24/2015		Replace log book. Obtain dust masks.
FO-323084	7/28/2015			INQUIRY RE: WASH MACHINE
FO-323252	7/30/2015			NEED DOOR # TO MAIN ENTRY DOORS @ LOBBY
FO-323297	7/30/2015			Engineer- low priority- R/R RM 00187.01 please repair DHWH-2 for the cage wash machine.
<b>E - North</b>			<b>15</b>	
FO-320866	7/1/2015	7/1/2015		replace belts on fan B85 5L 880
FO-321002	7/6/2015	7/14/2015		MEET W/FIRE INSPECTION CO @ PUB SAFE
FO-321506	7/10/2015	7/10/2015		While cleaning out a storage room in the basement of the law library, we discovered a 3 ft. x 3 ft. hole in the ground. The cement has been removed and dirt is exposed. Please see Mary Bonk for questions. Room 1301, ex. 7-6177
FO-321585	7/13/2015	7/13/2015		BLDG IS TOO COLD
FO-321955	7/14/2015	7/14/2015		PLD SVC MAN NEEDS ACCESS TO HI/VOLTAGE RM 1ST FLR (PRIMARY RM) 313-475- 3352
FO-322209	7/17/2015	7/21/2015		RM 103 AIR VENT GRID FELL OUT OF WALL NEEDS TO BE PUT BACK
FO-322284	7/20/2015	7/20/2015		Parts taken from stock room for CW coil on ahu 1 at alumni.
FO-322835	7/24/2015	7/27/2015		AC unit stand alone window insert, zero-cold air, running HOT! PAINT SHOP BREAKROOM.
FO-322909	7/27/2015	7/27/2015		RM 2242 IS TOO HOT
FO-322910	7/27/2015	7/27/2015		RM 3198 IS TOO HOT
FO-322927	7/27/2015	7/27/2015		RM 3178 IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-322936	7/27/2015	7/27/2015		Purdy Library 1st Floor, Office Suite 122 (Human Resources)  Staff reported that Air Conditioning is not on. Area becoming quite warm.  Please adjust temperature.  Thank you.
FO-323082	7/28/2015	7/28/2015		Extremely hot in the Development suite, can you please bring large box fan.
FO-323133	7/29/2015	7/29/2015		Please adjust temperature: too hot
FO-323246	7/30/2015	7/31/2015		Please adjust temperature in IT Suite: too hot
<b>E - Northeast</b>			<b>9</b>	
FO-321012	7/6/2015	7/6/2015		1st floor is very cold.
FO-321395	7/9/2015	7/7/2015		S & M FIRE PROTECTION CO NEED ACCESS/ASSISTANCE FOR THE TRAILERS 248-331-3939
FO-321406	7/9/2015	7/14/2015		Water cooled AC unit in second floor lobby is not cooling, and temperature display appears to be set to Celsius.
FO-322043	7/15/2015	7/16/2015		The water in the restrooms and labs on the 2nd floor do not get hot. The ladies restroom will get slightly warm but not hot.
FO-322101	7/16/2015	7/16/2015		The belt on the exhaust fan on the North end of the building, next to the Battery room is broken. Please change belt.
FO-322267	7/20/2015	7/20/2015		3rd and 4th floor offices and conference rooms are to hot. The halls are comfortable.
FO-322870	7/24/2015	7/24/2015		Fire panel alarm is continually going off inside front door of the Skillman Building. Please turn off
FO-323085	7/28/2015	7/28/2015		1st floor is very cool. Please warm it up. Thank you
FO-323210	7/29/2015	7/30/2015		The last several days, room 404 has been sweltering. Please cool it off.
<b>E - Preventative Maintenance</b>			<b>18</b>	
FO-319593	7/1/2015	6/26/2015		Filter Order  95 Hancock - Wood Shop Unit
FO-321376	7/8/2015	7/8/2015		Water leaking from ceiling in women's restroom!
FO-321382	7/8/2015	7/8/2015		The hoods didn't pass the inspection test and we start noticing some rust on the equipment inside them.
FO-321383	7/8/2015	7/8/2015		The hoods didn't pass the inspection test and we start noticing some rust on the equipment inside them.
FO-321438	7/9/2015	7/23/2015		Belt Order for Engineering EF's  A27 Qty: 15 A28 Qty: 15 5L340 Qty: 10 5L350 Qty: 10 AX33 Qty: 10
FO-321440	7/9/2015	7/23/2015		Belt Order for Eng. Tech  3L200 Qty 10 4L190 Qty: 10
FO-321445	7/9/2015	7/23/2015		Belt Order for HVU-4  A58 Qty: 2
FO-321533	7/10/2015	7/28/2015		Filters for DLAR
FO-321545	7/10/2015	7/28/2015		Belt Order for AHU-1 & AHU-2  Return Fans Bx116 Qty: 8  Supply Fans B110 Qty: 8  Note: 2 belts per fan; 1 set for change and 1 spare set for each fan

WO	Recieved	Finished	Total	Request
FO-321872	7/13/2015	7/14/2015		RM 416 ONE OF THE CUBICLES LOST POWER PLS CK BREAKER
FO-322684	7/22/2015	7/28/2015		Air Compressor Belt Order 4L470 Qty: 2
FO-322718	7/22/2015	7/23/2015		RM 388 IS TOO HOT
FO-322816	7/23/2015	7/24/2015		In the Unisex bathroom one of the toilets is leaking.
FO-322815	7/23/2015	7/24/2015		Handicap toilet in woman's bathroom is loose and not bolted properly to floor.
FO-323191	7/29/2015			There is a pipe leak from black electrical box in the storage room.
FO-323298	7/30/2015			Rooms 2146 & 2148 are unbearably hot and the thermostat in their offices are not working properly. It needs to be looked at. Thank you.
FO-323300	7/30/2015			1ST FLR EMERGENCY EXIT DOOR NEAR RM 113 CK LITE TO DOOR ALARM
FO-323301	7/30/2015	7/30/2015		A/C running but not cooling all parts of the building.
<b>E - South</b>			<b>22</b>	
FO-321335	7/8/2015	7/8/2015		There is a rattle in a fan or mechanical unit that is distracting when you are trying to hear the lecturer. Please look into this.
FO-321409	7/9/2015			Fan on fume hood is so loud they cannot hear when their telephone rings.
FO-321450	7/9/2015	7/9/2015		PLD SVC MAN IS HERE NEEDS ASSISTANCE PLS CALL 313-971-2778
FO-321482	7/10/2015	7/15/2015		Hoods 5, 6, 7, 9, 10, 12, 13 are all running low at ranges of 40-60 FPM.
FO-321484	7/10/2015	7/15/2015		Fume hood 3 is running low at 36 FPM
FO-321485	7/10/2015			Fume hood 3 is running low at 24 FPM
FO-321507	7/10/2015			NO POWER IN WALL OUTLETS. BASEMENT MECHANICAL ROOM AND SURROUNDING AREAS. (MULTI-TASK)
FO-321530	7/10/2015	7/10/2015		Total Compensation & Wellness Suite 3638 Circuit fuse not working Cubicle in the four cubicle section (next to one of the tall cubicles) No electronics are able to be turned on while plugged into the outlet
FO-321975	7/14/2015	7/17/2015		gas valve leaking on lab bench
FO-322046	7/15/2015	7/15/2015		Permanently fix the Rands House 1st floor (ACC) entry door.
FO-322107	7/16/2015			Office 2148 on the 2nd floor has a thermostat that is broken/not working. Please contact Kayla Marshall with any further questions at 7-3843. Thank you.
FO-322113	7/16/2015	7/31/2015		It's starting to get very cold in this suite. Could we please have the temperature adjusted? thank you.
FO-322127	7/16/2015	7/17/2015		Fume Hoods in both 2530 & 2534 didn't pass the inspection test and need to be checked. They also have some rust on them. Please contact Ayad Nancy at 7-0900 with any questions. Thank you.
FO-322130	7/16/2015	7/28/2015		Periodically there is water leaking from the ceiling of the women's bathroom near the freight elevator on the 2nd floor. Thank you.
FO-322291	7/20/2015	7/20/2015		Vendor to provide access panel and replace fire link.
FO-322843	7/24/2015	7/24/2015		PLD NEED ACCESS TO PRIMARY RM PH #971-2778
FO-322907	7/27/2015	7/27/2015		Lab 3340 AC pipes/ceiling are leaking. Thanks.
FO-322932	7/27/2015	7/27/2015		There are a total of 14 outlets in the office (first room on your left when walking into the lab) that are currently not working. We will needs these outlets to be up and running as soon as possible. Thank you!
FO-322968	7/27/2015	7/27/2015		Air Conditioning not working. Very warm.
FO-322969	7/27/2015	7/27/2015		Air Conditioning not working. Hot.
FO-323098	7/28/2015	7/28/2015		meet w/siemens
FO-323099	7/28/2015	7/28/2015		meet w/ATT
<b>E - Southeast</b>			<b>7</b>	

WO	Recieved	Finished	Total	Request
FO-321357	7/8/2015	7/8/2015		A/C is not cooling. Thermostat is flashing 'change filter'
FO-321528	7/10/2015			Water leaking onto floor. Not sure it is coming from behind the wall, from pipes, ceiling or roof. Thank you, Susan
FO-321938	7/14/2015			We have a welding exhaust hood with articulating arm that the cover on the arm is frayed and worn through. As a result the exhaust hood is no longer removing welding fumes. Could the covering be replaced?
FO-322102	7/16/2015	7/16/2015		EXPERT SVCS NEED ACCESS TO RMS IN BSMT PH #734-756-8948
FO-322549	7/21/2015	7/21/2015		refrigerator leaking, need to turn the water source off so it doesn't leak to the rooms below
FO-322757	7/23/2015	7/23/2015		RM 6303 IS TOO HOT
FO-323275	7/30/2015			C&IT WILL NEED TO GET ACCESS TO ROOF AREA AROUND 1:30PM PLS CALL 601-3112
<b>E - West</b>			<b>3</b>	
FO-321455	7/9/2015	7/9/2015		PHOENEX REF IS HERE TO REPAIR BODY COOLER IN CADAVER RM THEY NEED ACCESS TO ROOF
FO-321896	7/14/2015			Repair AC unit in Tartar Shop...This is a second request. Unit is blowing out hot air only. Please see Bob Ostrowski on specs. Thank You.
FO-323029	7/27/2015	7/31/2015		Could you have the building engineers turn off some machines, such as fans, to cut down the background noise on Friday, 7/31.
<b>Grounds</b>			<b>4</b>	
<b>High</b>			<b>1</b>	
<b>G - Moving/Storage</b>			<b>1</b>	
FO-322719	7/16/2015	7/23/2015		Need movers to move office furniture (desk, bookshelf, and file cabinet moved form room 250 to room 238. Need this completed the week of July 20-24th.  Dorothy Carter 07/22/2015 15:54 - Received approval from Shelley Clifton to charge account index 135
<b>Low</b>			<b>3</b>	
<b>G - Moving/Storage</b>			<b>1</b>	
FO-322691	7/6/2015			pick up and e-waste a Ricoh Copier, machine ID# 10902583, located at: UPG Livonia Psychiatry Clinic Address: 16836 Newburgh Road, Livonia MI 48154. Contact Person: PAMELA PETER,for date to do this, 734-464-4220 Dorothy Carter 07/22/2015 12:31 - Approv
<b>G - Physical Grounds</b>			<b>2</b>	
FO-321274	7/7/2015	7/10/2015		Grounds Issue: By Reuther Library-Lawn irrigation system is leaking into area where concrete flat work is in progress
FO-321870	7/13/2015	7/27/2015		Remove debris, leaves, and kill weeds in generator fenced in area.
<b>Trades</b>			<b>846</b>	
<b>Emergency</b>			<b>41</b>	
<b>T - Carpenter</b>			<b>18</b>	
FO-320895	7/1/2015	7/1/2015		DOORS WON'T CLOSE. DOOR #140-10-WEST. (FACING F.A.B. BUILDING). (MULTI-TASK)
FO-320957	7/2/2015	7/2/2015		EMERGENCY CARP R/R OUTSIDE OF BLDG SOUTH SIDE (New Edition Area) HANCOCK ENTRANCE NEED TO MEET W/PUB SAFE @9:30AM TO CUT CHAINS OFF OF ABANDON BIKES @ BIKE RACK
FO-321014	7/6/2015	7/6/2015		EMERGENCY CARP R/R PUTNAM ENTRY DOOR #071-02N DOOR CLOSURE ARM HAS BROKEN OFF DOOR IS STANDING OPEN
FO-321026	7/6/2015	7/6/2015		R/R 2ND FLR STRWL (A) DOOR/DOOR HINGES SCREWS ARE COMING LOOSE
FO-321526	7/10/2015	7/10/2015		EMERGENCY CARP R/R ENTRY DOOR #155 05E METAL TRIM FROM UPPER DOOR FRAME IS HANGING DOWN

WO	Recieved	Finished	Total	Request
FO-321527	7/10/2015	7/10/2015		EMERGENCY CARP R/R ENTRY DOOR #155 05W METAL TRIM FROM UPPER DOOR FRAME IS HANGING DOWN
FO-321535	7/10/2015	7/10/2015		KEY SPINS IN DOOR LOCK. BACK DOOR OF ROOM 150.
FO-322051	7/15/2015	7/15/2015		EMERGENCY CARP R/R 1ST FLR HALLWAY DOOR BTWN MAIN BLDG & ANNEX BLDG DOOR ISN'T LATCHING CLOSED SECURITY ISSUE *SEE ENGINEER DAGHIGH* Permanently fix the Rands House 1st floor (ACC) entry door.
FO-322053	7/15/2015	7/16/2015		EMERGENCY CARP R/R RM 101.1/STORAGE CLOSET BELIEVED TO BE BEHIND RM 101 DOOR LOCK WILL NOT UNLOCK STUDENTS NEED ACCESS ASAP
FO-322147	7/16/2015	7/16/2015		EMERGENCY CARP R/R ENTRY DOOR #130 03W DOOR CLOSURE CAME LOOSE UNABLE TO CLOSE DOOR
FO-322271	7/20/2015	7/20/2015		WOOD BOARD IS HANGING FROM CEILING. ROOM 333. (MULTI-TASK)
FO-322551	7/21/2015	7/21/2015		R/R ENTRY Door #089 16E needs alignment. Latch bolt doesn't extend fully into strike. Causes alarms. See Justina in room 1360 for key to disarm the panic bar.
FO-322641	7/22/2015	7/29/2015		CARPENTERS  Repair Lab 1536 roll-up door, stuck open, will not close.  Emergency
FO-322665	7/22/2015	7/22/2015		EMERGENCY CARP R/R RM 322.09/UNISEX RR ENTRY DOOR LOCK KEEPS LOCKING PEOPLE IN
FO-322847	7/24/2015	7/24/2015		DOOR WON'T LOCK. ROOM 46.4
FO-322869	7/24/2015	7/29/2015		carpenters- R/R BLDG ENTRANCE DOOR #036 02E front door. middle door not closing properly. BLDG ENG UNABLE TO GET DOOR # WRKNG ON REQ. AFTER BROWSING TMA SYS LOCATED DOOR #036-02E
FO-323129	7/29/2015	7/29/2015		EMERGENCY CARP R/R RM 206 MASTER KEY HAS BEEN LOCKED UP INSIDE THIS RM NEED IT ASAP
FO-323131	7/29/2015	7/29/2015		KEY STUCK IN DOOR LOCK. ROOM 102.
<b>T - Electrician</b>			<b>15</b>	
FO-320947	7/2/2015	7/1/2015		POWER FAILURE OLD MAIN DEAD EDC DEAD.
FO-320948	7/2/2015	7/2/2015		POWER FAILURE, OLD MAIN DEAD, EDC DEAD.
FO-320972	7/2/2015	7/15/2015		CHECK FIRE CONTROL ON EXHAUST FAN #10. (CONTACT ENGINEER FOR MORE DETAILS)(MULTI-TASK)  Completed 7-2-2015 SRP
FO-320999	7/6/2015	7/7/2015		ELEC/EMERG R/R BSMT FIRE/SMOKE DETECTOR BSMT DUCT DETECTOR SUPPLY 1B (ACTIVE)  Completed 7-7-2015 SRP
FO-321488	7/10/2015	7/14/2015		EMERGENCY ELEC R/R BLDG FAP FIRE SYSTEM HAS NO POWER TO IT  Completed 7-14-2015 SRP
FO-321490	7/10/2015	7/10/2015		EMERGENCY ELEC R/R RM 6152/MECH RM ON/OFF SWITCH IS CAUSING UNIT TO SHUT-OFF
FO-321994	7/14/2015	7/16/2015		**ADDING ELECTRICIAN: Disconnect and re-connect power to domestic hot water heater room 1140. See Gerry (Plumber) *New tank being delivered 10:00am 7/15/15 JWT  (**) PO REQ DK 7/14 Plumbers: Law School hot water tank, located in the chiller room, i
FO-322036	7/15/2015	7/15/2015		EMERGENCY ELEC R/R RM 2151 HAS MULTIPLE WALL OUTLETS NOT WORKING RESET BREAKER STILL NO POWER TO OUTLETS (NOTE: STUDENTS UNABLE TO COMPLETE RESEARCH DUE TO NO POWER PLS REPAIR)

WO	Recieved	Finished	Total	Request
FO-322210	7/17/2015	7/18/2015		EMERGENCY ELEC R/R BLDG FAP FIRE SYSTEM HAS NO POWER TO IT  Completed 7-14-2015 SRP
FO-322550	7/21/2015	7/21/2015		AIR HANDLER UNIT #5 RETURN AIR FAN VFD. CONTACT ENGINEER FOR DETAILS.
FO-322562	7/21/2015	7/21/2015		R/R RM 1030 PANEL #S2 ISN'T BEING ENERGIZE FROM THE KEY SWITCH CAUSING LOST POWER IN WALL OUTLETS (ROBOT UNIT AREA)
FO-322644	7/22/2015	7/22/2015		BOILERS WON'T START. (CONTACT ENGINEER FOR MORE DETAILS)
FO-322731	7/23/2015	7/23/2015		SMOKE DETECTOR IN 2ND FLR. NORTH EAST STAIRWELL GOING INTO ALARM REPEATELY. DETECTOR IS INSTALLED ON 15-FOOT CEILING SURFACE.  Completed 7-23-2015 SRP
FO-322751	7/23/2015			EMERGENCY Electrician ADDING CONTRACTOR FIFE PEARCE R/R PH Please have FIFE Pearce (Ron Weiss) replace RIBOCON,with VFD,(313-369-2560).Also Charles Redmond notified. priority High
FO-323123	7/29/2015			FIRE PANEL NEED REPLACING, IN ALARM GROUND FAULT.
<b>T - Pipefitter</b>			<b>5</b>	
FO-321307	7/7/2015	7/8/2015		REPAIR COPPER AIR LINE. AIR HANDLER UNIT #4. MECHANICAL ROOM.....EA/7-8-15
FO-321969	7/14/2015	7/14/2015		EMERGENCY/PIPEFITTERS R/R RM 2335 UNPLUG CONDENSATE DRAIN LINE ON #ACU 2335 CAUSING CLNG LEAK JH/7-14-15
FO-321969	7/14/2015	7/14/2015		EMERGENCY/PIPEFITTERS R/R RM 2335 UNPLUG CONDENSATE DRAIN LINE ON #ACU 2335 CAUSING CLNG LEAK JH/7-14-15
FO-322010	7/15/2015	7/15/2015		Provide temporary cooling in mechanical room 32 AH#12 for Presidents Apartment CB/7-15-15
FO-322536	7/21/2015	7/21/2015		PRINT RM NEAR CONF RM 3 CEILING LEAK.....ME.....7/21/15
<b>T - Plumber</b>			<b>3</b>	
FO-321051	7/6/2015	7/6/2015		EMERGENCY PLUMBER R/R CTR OF 4TH FLR HALLWAY NEAR RM 460 THERE IS A LEAKING FLR DRAIN FOR PENTHOUSE CAUSING CLNG TO LEAK DOWN THE WALL...DB/TT....7-6-15....
FO-322679	7/22/2015	7/23/2015		R/R RM 223/LAB 1 OUT OF 3 SINKS SINK IS PLUGGED UP & WATER WILL NOT SHUT OFF (NOTE: THIS IS A DIFFERENT SINK FROM LAST WEEK-WILL HAVE ENGINEER SHUT WATER OFF) DB/7-22-15
FO-322958	7/27/2015	7/27/2015		**REFER TO FO#323064  EMERGENCY PLUM R/R BSMT RESTAURANTS STORAGE CLOSET FLR DRAINS ARE BACKING UP RAW SEWAGE AGAIN
<b>High</b>			<b>235</b>	
<b>T - Carpenter</b>			<b>55</b>	
FO-320886	7/1/2015	7/2/2015		DOOR 050-4-EAST STAYS AJAR AND RUBBING DOOR FRAME.
FO-320896	7/1/2015	7/2/2015		Keys are sticking in the lock to the main door of the 1st floor suite. Leading from hallway to room 124.
FO-320973	7/2/2015	7/30/2015		CONTRACTOR/RAYNOR OVERHEAD DOOR CORP. R/R DOCK AREA Header to Door needs to be fixed. Bent from a truck backing into it. Trucks are unable to back into the dock, and are having to unload their trucks from outside. The Header is just bent a little maki
FO-321004	7/6/2015	7/7/2015		R/R RM 2125 ENTRY DOOR LOCK IS VERY HARD TO MANUEVER WAS ABLE TO UNLOCK DOOR HOWEVER NEEDS TO BE CK FOR LOCKING DOOR LATER
FO-321008	7/6/2015	7/7/2015		DOOR WON'T LOCK. 1ST FLOOR ENTRANCE DOOR NEAR WAITING ROOM.
FO-321009	7/6/2015	7/7/2015		Key is sticking inside of the lock. The key can be inserted and operates fairly easily, but is difficult to remove.
FO-321280	7/7/2015	7/9/2015		Fix hole in "tent" that goes around the 1st floor exterior of the building. Homeless people have figured out that it is a great place to stay at night and over the weekend.
FO-321297	7/7/2015	7/8/2015		Carpenters: please repair door to restroom 330, the door rubbing on to the door jamb. Priority: low
FO-321304	7/7/2015	7/8/2015		RM 5151 BROKEN LOCK



WO	Recieved	Finished	Total	Request
FO-321322	7/7/2015	7/9/2015		Trade: CarpenterPriority: HighPlease adjust door closer on Door 10N.Need extra push to clear the alarm at Public Safety.
FO-321330	7/8/2015	7/8/2015		DOOR IS SWELLING AND HARD TO OPEN. ENTRANCE DOOR TO TEACHING COMMONS ROOM 150.
FO-321388	7/8/2015	7/10/2015		Trade: CarpenterPriority: HighBroken door closer on door 2N which is also a handicap door. Public safety secured door for overnight.
FO-321389	7/9/2015	7/10/2015		Trade: CarpenterPriority: HighDoor 23N won't secure. Need extra push to latch.Once door is opened from inside it will stay open till it is pushed again from outside.
FO-321429	7/9/2015	7/10/2015		5TH FL WOMENS RM UNABLE TO OPEN DOOR WITHIN RESTROOM TO EXIT TO HALLWAY SAFETY ISSUE
FO-321467	7/9/2015	7/13/2015		The key is difficult to insert into the front doorlock. (Lubricating oil might be needed??)
FO-321465	7/9/2015	7/13/2015		CARP R/R 4TH FLR NORTH BRIDGE GOING TOWARD PRESIDENTS' OFC THE 1ST SUPPORT BEAM ON SOUTH SIDE OF NORTH BRIDGE IS PULLING LOOSE
FO-321468	7/9/2015	7/10/2015		There is a piece of base molding that has come loose at the turn of the ramp to get to dance studios in room 3317 and 3315. It need to be glued back on.
FO-321469	7/9/2015	7/13/2015		The door connecting room 3315 & 3317 is broken and won't close properly.
FO-321550	7/10/2015	7/13/2015		**ADDING CARPENTER: Provide access in drywall to access drain repair room 1530. See Don Bear  CEILING LEAK. ROOM 1530..... *DB/JH/7-9-15.....
FO-321599	7/13/2015			STE 4200 HALLWAY DOOR NOT CLOSING PROPERLY SEE LISA FOR DETAILS 7-8813
FO-321948	7/14/2015	7/14/2015		WOMEN'S RM 170 ENTRANCE DOOR WON'T CLOSE
FO-321961	7/14/2015	7/15/2015		Door lock is jammed. Keys are not opening door.
FO-321962	7/14/2015			The handicap buttons to the Law Library internal doors are not operational. Both handicap buttons are not working. Please see Mary Bonk with questions. 7-6177
FO-321976	7/14/2015	7/15/2015		LOCKSMITH: PLEASE REPAIR DOOR KNOB TO WEST EXIT DOOR IN ELECRTICAL ROOM PRIORITY HIGH
FO-322016	7/15/2015	7/16/2015		DOOR #19-W IS NOT CLOSING. STAYS AJAR.
FO-322070	7/15/2015	7/16/2015		LAB 9108 LEFT DOOR NOT CLOSING PROPERLY
FO-322076	7/15/2015	7/27/2015		please repair door closer arm, this a secure issues due to the swipe card this area 130-03W.
FO-322086	7/16/2015	7/17/2015		Adding Carpenter: Please replace ceiling tiles outside RM 114 in hallway  BSMNT HALLWAY LEAK OUTSIDE RM 111 & 113 ..... JH/7-14-15 .....
FO-322103	7/16/2015	7/17/2015		TRIP HAZARD - CARPET/TILE COMING UP. ROOM 114.2.
FO-322106	7/16/2015			RM 4101 KEY GETS JAMMED IN LOCK
FO-322111	7/16/2015	7/17/2015		KEYS VERY HARD TO GO INTO DOOR LOCK. ROOM 1116.
FO-322182	7/17/2015	7/20/2015		DOOR DOES NOT OPEN. FRONT HANDICAP OUTSIDE DOOR #609-05-NORTH.
FO-322241	7/19/2015	7/20/2015		Doors on North Entrance / Door 12 North does not secure when someone walks out. Need to be adjusted
FO-322279	7/20/2015	7/22/2015		CARPENTERS (HIGH)  REPAIR 2 HATCHES ON AHU #1 AIR SUPPLY DUCT
FO-322292	7/20/2015	7/21/2015		RM 17 BRACKET COMING APART FROM WALL
FO-322307	7/20/2015	7/21/2015		RM 7 KEY GETS STUCK IN LOCK, DIFFICULT TO TURN
FO-322323	7/20/2015	7/21/2015		RM 12002.11 DOOR LOCK NOT CATCHING
FO-322524	7/21/2015	7/22/2015		ADDING CARPENTER** Please have carpenters replace ceiling tiles in hallway outside men's room 3238  3RD FL HALLWAY OUTSIDE MENS RM 3238 CEILING LEAK, TILES HAVE COLLAPSED DUE TO WATER DAMAGE....ME...7/20/15
FO-322614	7/21/2015	7/22/2015		R/R BOTH INNER/OUTER HANDICAP DOORS #608 03N PLS TROUBLESHOOT WHY DOORS/PUSH BUTTONS ARE CAUSING OPEN POSITION INTERMENTENTLY THROUGH OUT DAYUCK OPEN

WO	Recieved	Finished	Total	Request
FO-322640	7/22/2015	7/22/2015		Please have the Locksmiths to repair door lock in room 247, the lock willn't lock.This is for the locksmiths Department.
FO-322749	7/23/2015	7/27/2015		The handicapped ramp on the northeast corner is separating from the wall, and rats are nesting in the gap between the wall and the cement walkway. Please consider this an urgent request for pest control, and re-sealing this gap until some more permanent r
FO-322922	7/27/2015	7/27/2015		NORTHWEST ENTRANCE HANDICAP DOOR BUTTONS (IN AND OUT)ARE NOT WORKING.
FO-322971	7/27/2015	7/29/2015		R/R INSIDE handicap button FOR ENTRY DOOR #053 24E WILL NOT OPEN DOOR
FO-322970	7/27/2015			ASAP 2nd Floor Men's Bathroom piping renovation Carpenter support:  - set up scaffold in 1st floor men's room near urinals - Remove ceiling grid in 1st floor men's room above urinals - Remove cinder block wall that urinals are on in the 2nd floor men
FO-323041	7/28/2015	7/29/2015		RIGHT SIDE FRONT ENTRANCE DOOR (CASS AVE.) IS NOT LOCKING PROPERLY AND SOMETIMES HARD TO OPEN. CONTACT TAQUANDRA FOR MORE DETAILS.
FO-323083	7/28/2015	7/29/2015		FRONT ENTRANCE INTERIOR DOOR HANDLE IS BROKEN OFF SEE ANITA FOR DETAILS
FO-323091	7/28/2015	7/29/2015		R/R RM 215/CLASS RM OUTSIDE ENTRY ADA DOOR HANDLE IS VERY HARD TO MANEUVER OPENNING/CLOSING DOOR
FO-323101	7/28/2015	7/29/2015		Door 082-12N scrapes door frame and intermittently stays ajar. Door closer needs to be secured to door better.
FO-323102	7/28/2015	7/29/2015		Door 082-10N stays ajar.
FO-323128	7/29/2015	7/30/2015		BOTH DOORS ARE STICKING (HARD TO OPEN) ROOM 101.
FO-323159	7/29/2015	7/30/2015		R/R BLDG ENT Door 089-04E scrapes door frame and intermittently stays ajar. Door is out of alignment; latch bolt doesn't align with the strike plate very well. Causes alarm issues sometimes.
FO-323199	7/29/2015			Remove marble sill over urinals in men's room 107 and set on saw horse to make plumbing repairs accessible. See Gerry for direction. *Kevin aware of job
FO-323247	7/30/2015			Carpenters R/R RM 106 DOOR IS DRAGGING HARD TO CLOSE/OPEN ADJUST DOOR CLOSURE/hinges on door to shipping and receiving
FO-323248	7/30/2015			R/R ENTRY DOOR #008 05W Staff entrance door west side of building does not always close securely and is often found accessible when it should be locked.
FO-323293	7/30/2015			R/R INSIDE handicap button FOR INNER DOOR TO BLDG ENTRY DOOR #053 24E WILL NOT OPEN DOOR
<b>T - Electrician</b>			<b>69</b>	
FO-320838	7/1/2015			Trade: ElectricianPriority: HighFire alarm in trouble.Panel making constant buzzing noise.
FO-320890	7/1/2015	7/10/2015		Electricians: R/R PENTHOUSE repair/replace chill water pump 1 vsd: not responding to 4-20 ma remote signal.
FO-320903	7/1/2015	7/1/2015		Meet the Technician from Simplex, and assist him in the clock repair.  Completed 7-1-2015 SRP
FO-320949	7/2/2015	7/2/2015		Engineer called for Generator Trouble, the generator is in alarm, and need service.
FO-320954	7/2/2015	7/2/2015		REPAIR ONGOING PROBLEM WITH LIGHTS. SEE ANNE IN DESIGN SERVICES.
FO-320959	7/2/2015			FIRE TROUBLE ALARM.  Completed 7-2-2015 SRP
FO-320998	7/6/2015	7/7/2015		Repair/Re-lamp fixtures in the Gross Anatomy Lab.
FO-321058	7/6/2015	7/15/2015		trade labor priority high R/R PENTHOUSE AREA please deliver two pallets of salt to the ugl pint house area for new water softner that has been installed thank you FO-297735
FO-321251	7/7/2015	7/8/2015		ELECTRICIANS: PLEASE REPAIR FRONT DOOR EXTERIOR ENTRY LIGHTS , (DOORWAY AREA VERY DARK)

WO	Recieved	Finished	Total	Request
FO-321252	7/7/2015	7/7/2015		ALARM SOUNDING. 1ST FLOOR.  Completed 7-7-2015 SRP
FO-321279	7/7/2015	7/8/2015		Several fluorescent light fixtures have lamps that are flickering in our office area making it very hard to work. The lighting crew has replaced the lamps and still have the same issues.
FO-321323	7/8/2015			Electricians Replace bad light switch, for 1st floor south corridor lights, light switch located outside lab 1040.HIGH PRIORITY
FO-321331	7/8/2015	7/8/2015		Check, and Set clocks as needed throughout building.  Completed 7-8-2015 SRP
FO-321346	7/8/2015	7/8/2015		In the Switchgear room in the south Sub-Station, or in Sub 49 in the basement there's a UPS Battery, I need the Model, and Serial number off of it noted on the work order.  Completed 7-8-2015 SRP
FO-321390	7/9/2015	7/10/2015		ALARM SOUNDING. 1ST FLOOR.  Completed 7-10-2015 SRP
FO-321414	7/9/2015	7/10/2015		R/R RM 00010/MECH RM please have electricians check generator alarm. the generator is in alarm due to low oil pressure on generator.
FO-321418	7/9/2015	7/10/2015		**ADDING LABORER: Transport coring machine from Pipe Shop to Science Hall. See Mike Pummill or Gerry for location  lower floor drain to be level with floor. Currently the floor drain is @ 3/4" above floor grade and water can not drain. Please lower dra
FO-321509	7/10/2015	7/13/2015		R/R BSMT HALLWAY OUTSIDE RM 217 Exit sign in hallway outside of room is blinking on and off.
FO-321516	7/10/2015	7/10/2015		To electricians, R/R RM 00025/MECH RM condensate pump #1 motor is seized up and won't run. just hums when power applied. Please repair or replace.
FO-321519	7/10/2015			ADDING ELEC R/R RM 215 (to gain access to Rm 215 go thru Rm 247) NEED ELECS' TO CK AN ALL EQUIP ALARM W/DIGITAL NO RESET VPS alarm sounding in IT server room- something related to the VPS and the digital clocks  Completed 7-14-2015 SRP
FO-321537	7/10/2015			Hallway light switch closest to the exit doors towards Life Science is broken. Someone shoved paper in it to keep the lights on in the hallway. If paper is removed lights turn off.
FO-321583	7/13/2015	7/13/2015		trade electricans priority high please service fire alarm panel at ugl lobby first floor its in bypass mode and keeps going off in alarm  Completed 7-13-2015 SRP
FO-321623	7/13/2015	7/14/2015		Electricians: R/R RM 00016/MECH RM There is no power to Ex. Fans # 2, it seems the lines are disconnected inside the underground conduits. Priority: high. EQ NOT AVAIL IN TMA SYS/LPS
FO-321627	7/13/2015	7/14/2015		trade electricans priority high R/R ROOF EXH FAN THAT CONTROLS 2 FUMEHOODS IN RM 2177 please service three exhaust fans on roof that services the fume hoods in the lab areas here at bio-science motor not working**NOTE 3 OUT OF 7 EXH FANS ON ROOF ARENT
FO-321624	7/13/2015	7/14/2015		Electricians: R/R RM 00016/MECH RM There is no power to Ex. Fans # 3, it seems the lines are disconnected inside the underground conduits. Priority: high. EQ NOT AVAIL IN TMA SYS/LPS
FO-321628	7/13/2015	7/14/2015		trade electricans priority high R/R ROOF EXH FAN THAT CONTROLS 2 FUMEHOODS IN RM 2177 please service three exhaust fans on roof that services the fume hoods in the lab areas here at bio-science motor not working **NOTE 3 OUT OF 7 EXH FANS ON ROOF AREN
FO-321629	7/13/2015	7/15/2015		trade electricans priority high R/R ROOF EXH FAN THAT CONTROLS 2 FUMEHOODS IN RM 2177 please service three exhaust fans on roof that services the fume hoods in the lab areas here at bio-science motor not working **NOTE 3 OUT OF 7 EXH FANS ON ROOF AREN

WO	Recieved	Finished	Total	Request
FO-321876	7/13/2015	8/24/2015		**ADDING LABORER: Pick up scrap , debris and sweep 3rd floor room. See Gerry for location  lower floor drain to be level with floor. Currently the floor drain is @ 3/4" above floor grade and water can not drain. Please lower drain for proper drainage.
FO-321902	7/14/2015	7/14/2015		Repair lights as needed in the Gross Anatomy Lab.
FO-321934	7/14/2015	7/16/2015		Rm. 3145, 9 lights are out and need replacing again. Workers heard popping noise & smelled burning. Note: these were recently replaced.
FO-321995	7/14/2015	7/16/2015		**ADDING LABORER: Please assist in transporting new hot water heater to room 1140. Also remove old heater and debris. See Gerry (Plumber) *New Tank being delivered at 10:00am 7/15 JWT  (**) PO REQ DK 7/14 Plumbers: Law School hot water tank, locate
FO-322014	7/15/2015	7/16/2015		6TH FL MECH RM PANEL LPB6 B PHASE NOT HOT
FO-322034	7/15/2015	7/20/2015		fire panel wont reset,  Completed 7-20-2015 SRP
FO-322078	7/16/2015	7/16/2015		Please repair Mall light ,light down need electrical department to disconnect power source for repairs.
FO-322082	7/16/2015	7/22/2015		Pick up used Bus Duct/scrap metal in basement hallway, and bring back to Stock Rm. to go in scrap metal bins.
FO-322132	7/16/2015	7/17/2015		LAB 3153 CEILING LIGHTS NOT WORKING
FO-322198	7/17/2015	7/17/2015		Electricians needed to assist Centerline Electricians to access Bus Duct on 3rd floor feeding power to the Lecture Halls.
FO-322200	7/17/2015			FIRE TROUBLE ALARM. (MULTI-TASK)  Completed 7-20-2015 SRP
FO-322260	7/20/2015	7/20/2015		Electricians: please check control air compressor for old wing mechanical room, it keeps tripping out. Priority: High.
FO-322313	7/20/2015	7/21/2015		Trade: Electricians Priority: High Please make needed repairs to #2 lab air compressor starter. It appears that the contactor has fused in the on position.
FO-322513	7/20/2015			Electricians:Please R/R smoke detector in N-E stairwell at 2nd floor- repeatedly tripping. Priority:high
FO-322514	7/20/2015			Electricians:Please check strobe light- it didn't work during active fire alarm, all other strobe light are OK.Priority:medium
FO-322566	7/21/2015			FIRE TROUBLE ALARM UNABLE TO STOP ALARM SO DISABLED  Completed 7-24-2015 SRP
FO-322616	7/21/2015	7/22/2015		Make a list of material needed to run a 208V circuit from the UPS Panel, to the Server Rm. in the IT area where Jason sits, and record estimated time to do job.
FO-322642	7/22/2015			Electricians: Please repair or replace control air compressor motor #2 that keeps tripping the control panel breaker. High Priority.
FO-322645	7/22/2015	7/22/2015		Transport gas welder to Scott Hall dock for repair. See Eric for assistance  Repair broken bumper on south side of loading dock ,,,,,,,,,,,,,, EA/7-22-15 ,,,,,,,,,,,,,,
FO-322733	7/23/2015			Please check the Fire system at the Panel , fire pump will run but pull station alarm won't sound..This is for the Electrical Department.
FO-322746	7/23/2015	7/24/2015		Vacuum pump is not working in the building. NEED 3 NEW FUSES: ECSR-70. (Multi-task)
FO-322747	7/23/2015	7/24/2015		EMERGENCY ELEC R/R RM 0401/MECH RM AHU #1 TRANSFORMER KEEPS TRIPPING CAUSING VARIOUS RMS TO OVERHEAT
FO-322758	7/23/2015	7/23/2015		Meet Phil from Simplex, and assist him in correcting Fire Panel.  Completed 7-23-2015 SRP

WO	Recieved	Finished	Total	Request
FO-322761	7/23/2015	7/23/2015		Check Fire Alarm Panel for By-Pass, make sure it's in By-Pass for the Duct Detector Circuit, and not the entire building.  Completed 7-23-2015 SRP
FO-322768	7/23/2015	7/23/2015		R/R RM PH AREA please have laborer deliver FROM SCOTT HALL TO HUDSON WEBER 1) 15 BAGS salt to Hudson webber building. pick up 15 bags of salt at scott hall and deliver to the loading dock at Hudson webber .
FO-322844	7/24/2015	7/24/2015		Elect. High Priority R/R RM 00027/MECH RM AHU #6 is off line no power at screen and unit will not start
FO-322851	7/24/2015			Electrician R/R RM 536 please troubleshoot controls for trash pump #1 rm.536 ,engineers reset every day. priority High
FO-322861	7/24/2015	7/28/2015		**ADDING LABORER: ASAP In basement mechanical room : -Set up scaffold -Hilti out concrete wall around drain pipe -Remove debris *See Gerry for location and assistance if needed  Sewage backing up in 1st floor restrooms ladies 102 & Men's (no
FO-322894	7/26/2015	7/27/2015		R/R BSMT Please repair the fire system ,the panel is ringing in the basement ,display indicates ground fault..  This is for the Eletrical Dept.  Completed 7-27-2015 SRP
FO-322902	7/27/2015	7/27/2015		**ADDING LABORER: Transport gas welder to and from location on main mall between Mcgregor and Education. See Jim Hill  PIPEFITTERS TO REPAIR VERTICAL RAILS ON HANDRAIL AT THE BASE A PIECE OF SQUARE STOCK NEEDS TO BE WELDED IN PLACE WEST SIDE ( SEE BILL
FO-322938	7/27/2015	7/27/2015		Trade: Electrician Priority: High R/R PENTHOUSE Cooling tower fan #5 will not run in auto. The BAS relay is pulling in with the relay making contact. The HOA switch shows signs of water damage. EQUIP # ISN'T AVAIL IN TMA SYS/LPS
FO-323404	7/27/2015			The stage lighting in St. Andrew's is not working. Please find out what is wrong with the lights and fix them for a scheduled event early next week. Thanks!Dorothy Carter 07/27/2015 15:42 - Please have your Business Manager e-mail ad4634@wayne.edu to a
FO-323031	7/28/2015			Electricians:Please repair fire alarm sound system. During fire alarm test it did not work correctly.Priority:high
FO-323032	7/28/2015			Electricians:Fire alarm panel in trouble mode: ground fault.Priority:high
FO-323015	7/28/2015	7/27/2015		Time for Utilities Instrumentation to repair the Main Switch Gear.
FO-323046	7/28/2015			Electrician repair EF-11 fan timer 3rd floor mechanical room. Fan does not shut off.
FO-323055	7/28/2015			Trade: LaborerPriority: HighStanding FO 297706 for the cooling towersPlease deliver to the sub-basement:1 pallet of salt4 kegs of Halochlor4 kegs of Aquaklenz4 kegs of LochorThanks
FO-323075	7/28/2015	7/31/2015		Elect. R/R RM 178 Fire panel in north lobby has a reoccurring alarm possible battery problem priority low.  Completed 7-31-2015 SRP
FO-323078	7/28/2015	7/29/2015		ELECTRICIANS, R/R RM 5403/MECH RM PLEASE TROUBLESHOOT MOTOR ON COOLING AIR HANDLER. PRIORITY-HIGH.
FO-323148	7/29/2015			Electrician R/R RM 5229 please replace lights in BOTH CHEMICAL fume hoodS.FO-323143,priority High ,suspect bad,ballast.
FO-323156	7/29/2015			Time to attend training for the Lighting Controls.
FO-323254	7/30/2015			Clean up and remove plumbing debris from mens restroom 107. See Gerry
<b>T - Locksmith</b>			<b>8</b>	
FO-321011	7/6/2015	7/13/2015		Make 3 keys each of X2930, and X2954. This is for the Electricians to do the Generator Tests every month, and as it is now they don't have access to the Building to run the test.

WO	Recieved	Finished	Total	Request
FO-321364	7/8/2015	7/14/2015		New KeyNew Space AssignmentKey #: Key B-200Key Holder ID: Gabriella SiKoraQty: 4action: Please provide (4) Four exterior building Keys and deliver to Mark Gibbons,(577-0478) on behalf of Gabriella SiKora.Account #: N/A
FO-322059	7/15/2015	7/20/2015		New KeyLost / StolenKey #: 109745Key Holder ID: Antonio YanceyQty: 2action: 2-Master Keys (Rush)
FO-322301	7/20/2015	7/23/2015		New Key Lost / Stolen Key #: 111R Key Holder ID: Emmylou Garza-Prisby Qty: 3  action: HIGH PRIORITY - NEED BY WEDNESDAY, JULY 22. Overhead storage door slammed and latched, but won't open-we have no key. Desk sticker is HON DG9PG3-38141 S. Accou
FO-322671	7/22/2015			Please unlock and rekey lock on file cabinet in Pipe Shop office. See John Towle
FO-322705	7/22/2015	7/22/2015		Please get door next to room 249 open. Corey is chasing a steam leak and the core to this door is missing and door will not open. See Corey Blair for location
FO-322712	7/22/2015	7/22/2015		New Key New Staff Member Key #: 60858-2 Key Holder ID: David McGrann Qty: 1  action: 5206.1 Room. Urgent, complete by Friday, July 24
FO-322863	7/24/2015	7/28/2015		New KeyNew Space AssignmentKey #: TBDKey Holder ID: Aramark/ SCB BAOQty: 3action: copies, please. Priority High!
<b>T - Painter</b>			<b>2</b>	
FO-321992	7/14/2015	7/20/2015		**ADDING PAINTER : Please seal floor in area around floor drain room 8337. See Mike McAlinden if needed  Plumber Please seal floor drain,water getting on floor. FO-321410,priority high. .... MM/7-9-15 .....
FO-322965	7/27/2015			PAINTERS R/R PH please caulk floor drain south side of #1 chill water pump. Water leaking down drain pipe in ceiling of 9th floor,outside rm.9224.priority High;Refer to (fo-322713,ceiling leak )
<b>T - Pipefitter</b>			<b>25</b>	
FO-320942	7/1/2015	7/13/2015		Trade: Pipefitter Priority: High Please repair steam leaks at the heat exchanger and bypass valve for the hydronic heat exchanger in the boiler room..... EA/ 7-1-15 .....
FO-321013	7/6/2015			CEILING LEAK. 1ST FLOOR ROOM 136.....ME.....7-6-15
FO-321301	7/7/2015	7/9/2015		RM 2335 CEILING LEAK.....ME/7-8-15
FO-321412	7/9/2015	7/9/2015		Room 3142, CMMG Interactive area has ceiling leak. Steady drip with a bucket under it..... EA/7-9-15 .....
FO-321515	7/10/2015			(**) PO REQ DK Heating hot water heat exchanger #2 leaking at front seal. Please have pipefitters repair or replace ..... ME/7-10-15 .....
FO-321576	7/13/2015	7/13/2015		LEAK COMING FROM MECHANICAL ROOM. 3RD FLOOR ATRIUM NEAR ROOM 3217.....JH/7-13-15 .....
FO-321605	7/13/2015	7/13/2015		RM 410 CEILING LEAK ..... EA/7-13-15 .....
FO-321978	7/14/2015	7/15/2015		BSMNT HALLWAY LEAK OUTSIDE RM 111 & 113 ..... JH/7-14-15 .....
FO-322011	7/15/2015	7/16/2015		Pipe fitters: please replace faulty water meter on cooling tower make up line, the new meter in on my work bench at Perntis bldg Priority: high.....JH.....7/15/15
FO-322061	7/15/2015	7/16/2015		Fitters please evaluate steam leak on autoclave in room 423. (Refer to Work order number FO-321915) Priority: High ..... ME/7-15-15 .....
FO-322174	7/17/2015			steam fitters- repair or replace malfunctioning float valve on Surge Tank in boilerroom.....ME.....7/17/
FO-322251	7/20/2015	7/20/2015		CEILING LEAK. ROOM 4032.....ME....7/20/15

WO	Recieved	Finished	Total	Request
FO-322255	7/20/2015	7/20/2015		3RD FL HALLWAY OUTSIDE MENS RM 3238 CEILING LEAK, TILES HAVE COLLAPSED DUE TO WATER DAMAGE....ME...7/20/15
FO-322270	7/20/2015	7/21/2015		FITTERS (HIGH)  HYDRONICS (HOT SUPPLY) LINE BY CEMENT COLUMN LEAKING. LEAK IS INCREASING EVER WEEK. REPAIR/REPLACE.....ME.....7/20/15
FO-322615	7/21/2015			Trade: Pipefitters Priority: High Follow up to FO 322575 R/R RM 133 Please repair steam leak above walk in cooler in Life Science 133. Steam is isolated in the utility tunnel in the basement. .... EA/7-22-15 .....
FO-322648	7/22/2015			To pipe fitters. R/R RM 00004.10 There is a three inch OS&Y valve for steam isolation on the heating hot water pumps in room 10. The seals on this valve have failed and it is leaking steam and water all over. Please repair or replace. ....
FO-322650	7/22/2015			(**) PO REQ DK 7/24  **PUMP 1, 2, 3 To pipe fitters. R/R RM 00425/MECH BLR RM On boiler feed water tank entire common header for discharge of pumps is scaling up. Replace this line and fittings. Also, replace six 1-1/2" elbows on inlets and discharg
FO-322651	7/22/2015	7/22/2015		*THIS REQUEST WAS ADDED TO FO#322650 JWT  To pipe fitters. R/R RM 00425/MECH BLR RM On boiler feed water tank entire common header for discharge of pumps is scaling up. Replace this line and fittings. Also, replace six 1-1/2" elbows on inlets and disch
FO-322653	7/22/2015	7/22/2015		*This request was added to FO#322650 JWT  To pipe fitters. R/R RM 00425/MECH BLR RM On boiler feed water tank entire common header for discharge of pumps is scaling up. Replace this line and fittings. Also, replace six 1-1/2" elbows on inlets and disc
FO-322896	7/27/2015			Steamfitters R/R RM 0100/MECH RM please replace High pressure steam trap,blowing through. priority high..... ME/7-27-15 .....
FO-322897	7/27/2015			Fitters, R/R PENTHOUSE please replace vent on steam trap on AHU-3, middle coil..... JH/7-27-15 .....
FO-323146	7/29/2015			RM 1318 ACTIVE CEILING LEAK ..... EA/7-29-15 .....
FO-323158	7/29/2015	7/30/2015		EMERGEMCY PIPEFITTERS R/R RM 2335 ACU CONDENSATE PIPE IS LKNG ..... ME/7-29-15 .....
FO-323186	7/29/2015			Leak coming from ceiling ..... *GS/ME/7-29-15 .....
FO-323255	7/30/2015			BSMNT 325 PIPE LEAKING ..... EA/7-30-15 .....
<b>T - Plumber</b>			<b>76</b>	
FO-320871	7/1/2015			(**) PO REQ DK PLATES / MIXING VALVES  MENS FACULTY LOCKER RM 2 SHOWERS NOT WORKING MIDDLE SHOWER IS COLD ..... GS/7-1-15 .....
FO-320888	7/1/2015	7/13/2015		PLUGGED TOILET. 1ST FLOOR MEN'S RESTROOM. DANTO BUILDING. ROOM 1531..... MP/7-1-15 .....
FO-320912	7/1/2015	7/2/2015		2nd floor urinal is overflowing onto the floor ..... GS/7-1-15 .....
FO-320936	7/1/2015	7/6/2015		In the 2nd floor men's restroom, the middle urinal's handle is coming unscrewed and needs repair ..... MM/7-2-15 .....
FO-320963	7/2/2015	7/13/2015		The women's bathroom on the 3rd floor right when you get off the elevators middle stall that does not flush. Thank you. .... MP/7-2-15 .....
FO-320968	7/2/2015	7/6/2015		TOILET WON'T FLUSH. 1ST FLOOR WOMEN'S RESTROOM. .... MM/7-2-15 .....
FO-321025	7/6/2015	7/13/2015		R/R RM 272/WOMENS RR 2ND STALL TOILET IS PLUGGED UP ..... MM/7-9-15 .....
FO-321028	7/6/2015	7/14/2015		FAUCET CONTINUOUSLY RUNNING. 2ND FLOOR LADIES RESTROOM. .... GS/7-9-15 .....

WO	Recieved	Finished	Total	Request
FO-321258	7/7/2015	7/8/2015		TOILET LEAKING AT BOTTOM. 1ST FLOOR OLD LADIES RESTROOM. HANDICAP STALL.....MP...7-7-15
FO-321268	7/7/2015			(**) PO REQ DK 7/13 RM 1348 DISH WASHER SINK HAS WATER SHOOTING OUT....MM....7-7-15
FO-321285	7/7/2015	7/8/2015		7TH FL MENS RM URINAL OVERFLOWING....DB/TT...7-7-15
FO-321324	7/8/2015			Plumbers: Please repair leaking cold water supply piping in the ceiling where the access panel is located inside the men's rest room. High Priority. .... DB/7-9-15 .....
FO-321325	7/8/2015			Please have plummers repair-replace leaking hot water hose on bottle washer. water on floor. high priority .... DB/7-9-15 .....
FO-321329	7/8/2015			(**) PO REQ DK 7/30 please have electricians check the contactor on circulating pump 35 caontactors wont pull in to start pump 35 circulating pump in pipefitters cage.  OPEN TO PLUMBERS:  Have Plumbers remove/Repair Circulating Pump .....
FO-321350	7/8/2015	7/13/2015		CEILING LEAK. ROOM 1530..... *DB/JH/7-9-15.....
FO-321425	7/9/2015	7/24/2015		Plumber Please seal floor drain,water getting on floor. FO-321410,priority high. .... MM/7-9-15 .....
FO-321452	7/9/2015	7/16/2015		PLUM R/R 3RD FLR MENS RR NEAR CLASS RM 314 3 URINALS HAVE PLASTIC OVER THEM HOWEVER THEY ARE BEING USED & NOW IT IS FILTHY & SMELLY ..... GS/7-14-15 .....
FO-321463	7/9/2015	7/10/2015		PLUM R/R 1ST FLR (ATRIUM AREA) WOMENS RR 2ND STALL TOILET ISN'T WRKNG (BAG OVER IT) ..... DB/7-10-15 .....
FO-321464	7/9/2015	7/10/2015		PLUM R/R 1ST FLR (ATRIUM AREA) MENS RR HANDICAP STALL TOILET ISN'T FLUSHING BELIEVE FLUSH HANDLE IS BROKEN-PEOPLE ARE STILL USING IT & NOW IT IS FULL & STINKING ..... DB/7-10-15 .....
FO-321539	7/10/2015	7/13/2015		1ST FL WOMENS RM LEFT SINK NOT WORKING, NEEDS BATTERIES ..... MM/7-10-15 .....
FO-321581	7/13/2015	7/14/2015		PLUMBERS R/R RM 586/MENS RR PLEASE REPAIR HANDICAP TOILET 5TH FLOOR ..... MM/7-13-15 .....
FO-321582	7/13/2015	7/14/2015		PLUMBERS R/R RM 586/MENS RR PLEASE REPAIR URINAL #1 PRIORITY HIGH ..... MM/7-13-15 .....
FO-321591	7/13/2015	7/15/2015		TOILET OUT OF ORDER. LADIES RESTROOM. ROOM 118..... MM/7-13-15 .....
FO-321593	7/13/2015	7/15/2015		(**) PO REQ DK 7/14 Plumbers: Law School hot water tank, located in the chiller room, is leaking from the top of the tank. Please repair or replace. High Priority. .... GS/7-13-15 .....
FO-321855	7/13/2015	7/14/2015		Plumbers, High, Clear clogged floor drain near condensate discharge piping on fan AH-4 ..... MM/7-13-15 .....
FO-321865	7/13/2015	7/14/2015		Trade: Pipefitter Priority: High Follow up to FO 321631 Please repair gas valve(s) that are leaking on the right hand bench. Gas is isolated at the valve located on the south end of this bench. Contact John 313-684-1706 or Percy 313-590-7142 if you
FO-321933	7/14/2015	7/15/2015		In the back room of lab 3250 the tap is not running any cold water. It is btw. the eye wash station and the autoclave. Need asap as this is used often. .... MM/7-14-15 .....
FO-321970	7/14/2015			HALLWAY 3RD FL NEAR ELEV WATER FOUNTAIN NOT WORKING ..... MM/7-14-15 .....
FO-321983	7/14/2015	7/15/2015		trade plumbers priority high please replace gas valve in lab 4164 its leaking at the base and at the bottom of the valve gas leak ..... DB/7-14-15 .....
FO-321982	7/14/2015			Seal around drain near AH#11. Pipefitter has rerouted piping that was going to this drain that was causing RM 9320 CEILING LEAK, LEAKING OVER EQUIPMENT. See Marty Elwart if needed ..... DB/7-14-15 .....



WO	Recieved	Finished	Total	Request
FO-322000	7/15/2015	7/17/2015		PLUMBERS  Repair/Replace Lab 30 distill water faucet, not working.  HIGH PRIORITY,,,,,,,,,,,,,DB/7-15-15,,,,,,,,,,,,,
FO-322003	7/15/2015	7/16/2015		Plumbers: Please repair men's rest room toilet. Toilet is paged with plastic bag. High Priority. ,,,,,,,,,,,,,DB/7-15-15,,,,,,,,,,,,,
FO-322040	7/15/2015	7/15/2015		BREAK RM 464 CLOGGED SINK,,,,,,,,,,,,,DB/7-15-15,,,,,,,,,,,,,
FO-322094	7/16/2015			Plumbers please troubleshoot eyewash stations in labs,2115,2126 suspect mixing valve problems, water is hot.FO-321968,priority High.....DB.....7/16/15
FO-322119	7/16/2015	7/17/2015		3rd floor ladies' restroom-fix first sink from entrance-standing water.....DB....7/16/15
FO-322134	7/16/2015	7/20/2015		Ladies restroom across from Magherio Conference Center (141 Mazurek) has a toilet that has been bagged for at least 2 weeks. Please repair. It is the 1st stall.....MM.....7/16/15
FO-322158	7/16/2015	7/17/2015		sink in the anatomy lab is backing up. the disposal comes on and make noise but is not turning. The sink is located on the back wall by the cooler.....DB.....7/17/15
FO-322192	7/17/2015	7/17/2015		LOADING DOCK IS FLOODING.....MM.....7/17/15
FO-322201	7/17/2015	7/17/2015		Trade: Plumbers Priority: High Follow Up to FO 322189 Lab 120 - Fume Hood 13: Water is leaking from the backflow preventer for the left hand side water supply to the fume hood. Please repair.....DB.....7/17/15
FO-322202	7/17/2015			LAB 252 SINK ACROSS FROM FUME HOOD 3&4, HOT WATER HANDLE IS FALLING OFF.....DB....7/17/15
FO-322262	7/20/2015	7/21/2015		2ND FL MENS RM MIDDLE STALL PLUGGED.....MM.....7/20/15
FO-322297	7/20/2015	7/21/2015		VERY LEAKY FAUCET. ROOM 4323.....DB.....7/21/15
FO-322298	7/20/2015	7/21/2015		CLOGGED SINK. MEN'S RESTROOM. ROOM 9109.....DB.....7/21/15
FO-322299	7/20/2015	7/21/2015		URINAL OVERFLOWS WHEN FLUSHED. MEN'S RESTROOM. ROOM 9109.....DB.....7/21/15
FO-322325	7/20/2015	7/21/2015		RESTROOM 326 URINAL IS BAGGED, URINAL BACKS UP WITH SOMETHING GREEN.....MM.....7/21/15
FO-322517	7/21/2015			PLUMBERS please r/r hot water circ pump. Received complaint of no hot water on 2nd floor. circ pump is extremely hot. It is a B&G LR-15BWR 106514 1H90.....GS.....7/21/15
FO-322523	7/21/2015	7/21/2015		1st Floor Men's Restroom. 1st stall flush valve leaking. 2nd stall toilet is loose @ floor. .....MM.....7/21/15
FO-322608	7/21/2015			Trade: Plumbers Priority: Very High Please repair sanitary sump pump #2. Pump is very noisy.....MP....7/22/15
FO-322673	7/22/2015	7/22/2015		MENS RM 5101 URINAL CONSTANTLY RUNNING,,,,,,,,,,,,,MM/7-22-15,,,,,,,,,,,,,
FO-322674	7/22/2015	7/23/2015		TOILETS IS NOT FLUSHING. 1ST FLOOR HANDICAP RESTROOM.....DB/7-23-15 ,,,,,,,,,,,,,
FO-322678	7/22/2015	7/22/2015		*DUPLICATE / REFER TO FO#322679  R/R RM 223/LAB 1 OUT OF 3 SINKS SINK IS PLUGGED UP & WATER WILL NOT SHUT OFF (WILL HAVE ENGINEER SHUT WATER OFF),,,,,,,,,,,,,DB/7-22-15,,,,,,,,,,,,,
FO-322685	7/22/2015	7/22/2015		*DUPLICATE / REFER TO FO#319874  NO COLD WATER. ROOM 0225. ,,,,,,,,,,,,,MM/7-23-15,,,,,,,,,,,,,
FO-322686	7/22/2015	7/24/2015		WARM WATER GOING INTO AUTO WATER FILLER. ROOM 0221.....MM/7-23-15 ,,,,,,,,,,,,,
FO-322690	7/22/2015	7/24/2015		LAB 2352 FAUCET LEAKING,,,,,,,,,,,,,MM/7-23-15,,,,,,,,,,,,,
FO-322720	7/22/2015	7/23/2015		Women's bathroom, water leaking from sink/wall area, some water on the floor and the wall.....MM/7-23-15,,,,,,,,,,,,,
FO-322734	7/23/2015	7/23/2015		faucet leaking room 0351 ,,,,,,,,,,,,,MM/7-23-15,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-322763	7/23/2015	7/27/2015		Plumber; High Please replace the bad diaphragm on the flush valve for the toilet in the unisex restroom located on the eighth floor. The wter is isolated at the toilet. ,,,,,,,,,,,,,, MP/7-23-15 ,,,,,,,,,,,,,,
FO-322775	7/23/2015	7/27/2015		R/R RM 7101 ALL URINALS AREN'T FLUSHING ,,,,,,,,,,,,,, MM/7-23-15 ,,,,,,,,,,,,,,
FO-322833	7/24/2015			Plumbers  Repair leaking wall mounted toilet in ladies restroom on 4th floor.  HIGH PRIORITY ,,,,,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,,,,,
FO-322893	7/24/2015	7/27/2015		R/R RM 108/JANITORS CLOSET Sewage coming up from drain located in the floor of the janitors closet, room 108.,,,,,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,,,,,
FO-322937	7/27/2015	7/29/2015		Kresge Library, 1st Floor, Photography Studio  Ceiling leak (smells like urine) three ceiling tiles soaked and crumbled to floor.  Please repair.  See Richard at the Circulation Desk of additional information is needed.  Thank you. ,,,,,,,,,,,,,,
FO-322983	7/27/2015	7/30/2015		LONG TOILET FLUSHES. LADIES RESTROOM HANDICAP STALL. ROOM 1360.,,,,,,,,,,,,,, MM/7-28-15 ,,,,,,,,,,,,,,
FO-323030	7/28/2015	7/27/2015		**DUPLICATE / REFER TO FO#323061  Plumbers: Please unplug all 3 sinks in women r/r. Priority:high
FO-323040	7/28/2015	7/30/2015		PIPE LEAKS WHEN TOILET IS FLUSHED. 2ND FLOOR MEN'S RESTROOM. LAST STALL. ,,,,,,,,,,,,,, MP/ 7-29-15 ,,,,,,,,,,,,,,
FO-323058	7/28/2015	7/29/2015		PLUMBERS-PLEASE RERAIR DRINKING FOUNTAIN OUTSIDE OF AUDITORUIM BEEN DOWN FOR A WHILE,PRIORITY HIGH ,,,,,,,,,,,,,, DB/7-29-15 ,,,,,,,,,,,,,,
FO-323065	7/28/2015			2nd floor Men's restroom handicap toilet overflowed. Please snake out. Also investigate possibility of installing toilets with tanks on 2nd floor due to low water pressure.,,,,,,,,,,,,,, MP/7-29-15 ,,,,,,,,,,,,,,
FO-323061	7/28/2015			BSMNT SOUTH WOMENS RM (3) SINKS PLUGGED ,,,,,,,,,,,,,, MP/7-29-15 ,,,,,,,,,,,,,,
FO-323062	7/28/2015	7/29/2015		2ND FL WATER FOUNTAIN PLUGGED ,,,,,,,,,,,,,, MM/7-28-15 ,,,,,,,,,,,,,,
FO-323137	7/29/2015	7/29/2015		FLOOR DRAIN (TRENCH) WON'T STOP FLUSHING. ROOM 0239.,,,,,,,,,,,,,, MM/7-29-15 ,,,,,,,,,,,,,
FO-323142	7/29/2015	7/30/2015		1st floor men's restroom both toilet and sink clopped up been let this for week ,,,,,,,,,,,,,, MP/7-29-15 ,,,,,,,,,,,,,,
FO-323145	7/29/2015	7/29/2015		4TH FL LADIES RM 2ND STALL TOILET PLUGGED ,,,,,,,,,,,,,, MM/7-29-15 ,,,,,,,,,,,,,,
FO-323150	7/29/2015			3RD FL OUTSIDE RM 355 DRINKING FOUNTAIN HAS LOW WATER PRESSURE ,,,,,,,,,,,,, DB/ 7-29-15 ,,,,,,,,,,,,,,
FO-323151	7/29/2015			4TH FL OUTSIDE RM 484 DRINKING FOUNTAIN HAS LOW WATER PRESSURE ,,,,,,,,,,,,, DB/7-29-15 ,,,,,,,,,,,,,,
FO-323178	7/29/2015	7/31/2015		TOILET WILL NOT FLUSH. 2ND FLOOR WOMEN'S RESTROOM. MIDDLE STALL. ROOM 2432.,,,,,,,,,,,,,, MM/7-29-15 ,,,,,,,,,,,,,,
FO-323186	7/29/2015			Leak coming from ceiling ,,,,,,,,,,,,,, *GS/ME/7-29-15 ,,,,,,,,,,,,,,
FO-323295	7/30/2015			5215 SINK LEAKING UNDERNEATH ,,,,,,,,,,,,,, MM/7-30-15 ,,,,,,,,,,,,,,
<b>Medium</b>			<b>113</b>	
<b>T - Carpenter</b>			<b>24</b>	
FO-320839	7/1/2015	7/2/2015		Carpenter; MediumPlease repair the bad door handle on the door leading into the electrical closet located in the mechanical hallway of the first floor.
FO-321018	7/6/2015	7/7/2015		Carpenters: please repair handicap sliding door ( 01601E), this door has to be kept manually open all the time, and this will cause to over heat the hallway and stairway. Priority: Med.
FO-321377	7/8/2015	7/14/2015		WINDOW BLINDS BEADED STRING IS BROKEN. ROOM 110.
FO-321453	7/9/2015	7/10/2015		locksmith Med. PriorityLock will not lock

WO	Recieved	Finished	Total	Request
FO-321471	7/9/2015	7/16/2015		A portion of the tile floor in the dance costume room is peeled and cracked. It is the part directly in front of the washer and the utility sink. New tile needs to be put down and glued.
FO-321487	7/10/2015	7/13/2015		Repair bottom medal molding at the base of the door. See Bob Ostrowski on specs. Thank You. Bob Ostrowski
FO-321508	7/10/2015			Remove grate on the east corner of John R and E. Ferry at Freer House so that grounds department can remove weeds and greenery.
FO-321510	7/10/2015	7/22/2015		The gate at the Piquette yard is stuck.
FO-321552	7/10/2015	7/14/2015		3rd floor, main entrance doors, all glass doors are sticking very badly and you have to pull to open the door. They are also scrapping along the ceiling.
FO-321899	7/14/2015	7/15/2015		Carpenters: please repair door lock on entrance door # 01621N, the locking mechanism is loose and hard to lock and unlock it. Priority: med.
FO-322120	7/16/2015	7/16/2015		Anatomy Lab Room 223 has several broken light fixture covers that need replacing.  OPEN TO CARPENTERS:  Cut 5 Light Fixture Lens for frames provided by Lamp Changer Mike.
FO-322826	7/16/2015			Repair/replace cracked drain tile on pool deck by seat #49. Please reference D. O'Brien on this item. Bob Ostrowski has specs. if needed. Thank you. Bob OstrowskiDorothy Carter 07/23/2015 16:14 - Per Doug O'Brien, this is maintenance work. Passing thi
FO-322228	7/17/2015	7/21/2015		Trade: CarpentersPriority: MediumPlease repair "building cozy" (plastic sheeting) at the SW corner (Second and Warren) of Life Science.
FO-322280	7/20/2015	7/20/2015		Doors 15 East & 16 East won't secure after being used. Door 15E scrapes mullion. Door 16E won't secure because latch bolt won't fully extend into strike plate's pocket. See Justina in room 1360 for key to disarm panic bars.
FO-322526	7/21/2015	7/30/2015		ADDING CARPENTERS** Please have carpenters replace ceiling tiles in Room 4032.  CEILING LEAK. ROOM 4032.....ME....7/20/15
FO-322570	7/21/2015	7/22/2015		WOMEN'S RESTROOM EAST WING 1ST FLOOR THE CARPET IS RIPPED IN SEVERAL PLACES. PLEASE REPAIR OR REPLACE WITH TILE.
FO-322639	7/22/2015	7/23/2015		Trade: CarpenterPriority: MediumDoor lock malfunction. Door no. 091-11S.
FO-322745	7/23/2015			ASAP **ADDING CARPENTER : Please provide access ASAP in cinder block wall near room 249 for steam leak repair and replace with access door big as possible for future repairs. See Eric for location  Trade: Pipefitters Priority: High Follow up to FO
FO-322951	7/27/2015	7/29/2015		Carpenters: R/R RM 10507 please remove ceiling tile and grid in hallway near room 10507Light fixture near room 10507, for heat pump installation. Area needs to be made larger. Contact Andy or Gordie for details. Medium Priority
FO-322980	7/27/2015	7/28/2015		Purdy Library 4th Floor, Room 433  Metal bracket at bottom of door is loose and dragging on floor. Difficult to open and close. Please repair.  Thank you.
FO-323048	7/28/2015			Carpenters can you please build scaffold in stairwell D for ceiling repairs..see Corey for exact location,.....MUST BE COMPLETED BY NO LATER THEN 8-4-15 AT 2:OOPM.....thanks
FO-323100	7/28/2015	7/29/2015		Carpenters, Medium, Repair inner saloon style door, Men's Lav across from Rm. 5315. Hinge mount screws stripped out.
FO-323126	7/29/2015	7/30/2015		Carpenter repair door lock for room 173. You have to pull hard while unlocking to open the door.
FO-323161	7/29/2015	7/29/2015		Carpenters: Please repair entrance door 01601E, it stops working and has to be reset several times a day. Priority: med.

T - Electrician

29

WO	Recieved	Finished	Total	Request
FO-320941	7/1/2015	7/2/2015		<p>*ADDING ELECTRICIAN : Disconnect domestic hot water heat exchanger 3rd floor mechanical room . See Marty Elwart</p> <p>Provide bypass on HWH in 3rd floor mechanical room prior to repairs being made on heat exchanger</p> <p>NEED HOT WATER TANK TURNED ON. 4TH FLOOR</p>
FO-320944	7/2/2015	7/6/2015		Sylvia Morrisen need for us to clean out the Phone Closet on the second floor for the new phone system to be installed.
FO-320950	7/2/2015	7/2/2015		Time for Safety meeting for the month of July, 2015.
FO-321333	7/8/2015			Electrician; MediumPlease repair the Building Clock located outside the Woodward Entrance. The clock is not running.
FO-321428	7/9/2015	7/14/2015		Please have Dennis deliver 25 bags of salt for boiler water softener to 3rd floor mechanical room.
FO-321431	7/9/2015	7/10/2015		need clean up in the area of the fresh air intake by PLD room ...see Don B for exact location.....Trade: Plumber Priority: Medium Pump out water from fresh air intake by PLD room, clear drain if it has one. There is lots
FO-321434	7/9/2015	7/10/2015		<p>please disconnect both sump pumps in room 179...see Don B if u need help.....</p> <p>(**) PO REC DK (Steel)</p> <p>Install new sump pump rm 179 that has been received from FO#298137 ,,,,,,,,,, DB/ 7-1-15,,,,,,,,,</p>
FO-321584	7/13/2015	7/13/2015		<p>Fire panel re-charge for backup battery is in fault.</p> <p>Completed 7-13-2015 SRP</p>
FO-321600	7/13/2015	7/15/2015		<p>Electrician</p> <p>R/R 3RD FLR restore power to hot water heater #2 3rd floor mechanical room.</p> <p>EQ NOT AVAIL IN TMA SYS/LPS</p>
FO-321601	7/13/2015			Electrician R/R BLDG repair alarms for smoke heads throughout the building.EQ NOT AVAIL IN TMA SYS/LPS
FO-322084	7/16/2015	7/20/2015		In the Mechanical Rm. 027 there's a motor that need to be taken to the metal bins in the Stock Rm.
FO-322089	7/16/2015	7/17/2015		<p>Adding Electrician: No Power @ receptacle for Garbage Grinder</p> <p>Purdy Library 3rd Floor, Room 331</p> <p>Sink plugged, not draining properly,,,,,,,,,,,,, MM/7-15-15 ,,,,,,,,,,</p> <p>Please repair.</p> <p>Thank you.</p>
FO-322151	7/16/2015	7/20/2015		Need motion sensors adjusted in the room. Please contact Ellen Cope for assistance at 7-0409. Thank you.
FO-322239	7/19/2015	7/22/2015		<p>Repair fire alarm panel trouble: "T-0001 P02B04L1I015 +ADDR ERR T0001-0001 1st Flr Smk Det by Ticket Office"</p> <p>Completed 7-22-2015 SRP</p>
FO-322330	7/20/2015	7/23/2015		There is an electrical issue in the ceiling above the stall. It dates back to last summer.
FO-322329	7/20/2015	7/23/2015		Problem exist with the electrical outlet that computer number 51 is connected to. The keyboard has a sign on it that says temporarily unavailable. (a ticket was placed with MSIS, they already checked it out and identified the problem as being with the ele
FO-322605	7/21/2015			<p>Elect. High Priority</p> <p>R/R ROOF Please check VFD on PRV #3 on roof. Unit will stall out and not turn fan. Note: Repeat of earlier problem FO-319913</p>
FO-322612	7/21/2015	7/23/2015		Fan on Chiller serving WDET will not start. See engineer Greg Ray
FO-322748	7/23/2015	7/27/2015		<p>RM 5113 EXHAUST FAN #10 TROUBLESHOOT &amp; REPAIR MOTOR PROBLEM, FAN WON'T START</p> <p>RM 5113 NO SUCTION ON FUME HOODS, STRONG ODOR WITHIN RM</p>
FO-322780	7/23/2015	7/24/2015		Light switch in the west stairwell is broke.
FO-322913	7/27/2015			<p>Trade: Electrician Priority: Medium</p> <p>R/R OUTSIDE The following exterior light pole lights are not working:</p> <p>Poles: 22, 18, 17, 12, 11, 10, 8, 4, 3</p>

WO	Recieved	Finished	Total	Request
FO-322939	7/27/2015	7/29/2015		Electricians: R/R RM 10304 please re-locate disconnect for heat pump 2-68. Contact Andy or Gordie for details. Medium Priority REFER TO WO FO-311900
FO-322949	7/27/2015			Electricians: R/R RM 10507 please re-locate Light fixture near room 10507, for heat pump installation. Contact Andy or Gordie for details. Medium Priority
FO-323258	7/30/2015	7/31/2015		1 of 2 requests for clock repair ... Wall clock not working in Honors Suite, Room 2100 of UGL nearest to women's restroom. See Honors Receptionist or Stuart May.  Completed 7-31-2015 SRP
FO-323259	7/30/2015	7/31/2015		1 of 2 requests for clock repair ... Wall clock not working in Honors Suite, Room 2100 of UGL nearest to women's restroom. See Honors Receptionist or Stuart May.  Completed 7-31-2015 SRP
FO-323260	7/30/2015	7/31/2015		2 of 2 regarding clock repair in UGL Clock in LAB A on First Floor of UGL, Room 1140, in need of repair. NOTE: one or two clocks on UGL Third Floor will need repair and will be reported when recarpeting of Third Floor is completed.  Completed 7-31-2
FO-323263	7/30/2015			Deliver 3 heat pumps to 5057 Woodward. See Gordie Bush or Andy McAlpine for delivery location.
FO-323264	7/30/2015			Deliver 1 heat pump to Thompson Home. See Gordie Bush or Andy McAlpine for delivery location.
FO-323270	7/30/2015			Please have laborer deliver four 5 gallon pails of Halochlor to Community Arts room 25.
<b>T - Locksmith</b>			<b>1</b>	
FO-322975	7/27/2015			Please provide a private key and/or change lock core on the wooden tool cabinet located in the boiler room at 5425 Woodward for engineer Maureen Kemp.
<b>T - Painter</b>			<b>2</b>	
FO-321436	7/9/2015	7/17/2015		ADDING PAINTER:to seal floor under sink in old tin shop..see Don B for location...  ADDING PLUMBERS: R/R PAINT SHOP SINKS PLEASE CK IF ANY DRAINS ARE LEAKING INTO SVC CTR/CK CLNG IN THE SVC CTR R/R RM 150 IN BTWN LORETTA'S & LARRY'S DESK AGAINST WAL
FO-322326	7/20/2015	7/24/2015		243 has a large hole in the wall. It is located in the front of the room, under the whiteboard.
<b>T - Pipefitter</b>			<b>24</b>	
FO-320925	7/1/2015	7/21/2015		Tag #090-HVU-001 Replace leaking steam stop valve to H&V unit #1 in the easst penthouse..... JH/ 7-1-15 .....
FO-320927	7/1/2015	7/31/2015		Trade: Pipefitter Priority: Medium R/R Skywalk to Science Hall & Life Science, the ceiling convector on the north end has a plugged coil, not letting flow through..... JH/7-1-15 .....
FO-320987	7/2/2015			(**) PO REQ DK 7/30 Fitter replace leaking steam control valve on hot water heater #2 3rd floor mechanical room..... JH/7-2-15 .....
FO-321255	7/7/2015	7/15/2015		PF Med Priority Please secure all floor grates in basement mechanical area...(unsafe working condition)..... EA/7-9-15 .....
FO-321269	7/7/2015	7/10/2015		Fitter repair remote grease fittings on exhaust fans 3B, 2A, & 1B..... JH/7-9-15 .....
FO-321373	7/8/2015	7/9/2015		Pipefitter; medium Please clear the clogged condensate drain line coming from the A/C Unit-071-ACU-003 located in the hallway by the passenger elevators. .... JH/7-9-15 .....
FO-321579	7/13/2015	7/15/2015		STEAM FITTERS- R/R RM 200/MECH RM PLEASE INSTALL DRAIN LINE TO CHIILLED WATER BASIN AHU3, CONDENSTATE FROM COILS FLOODING MECHROOM. MED PRIORITY ..... JH/7-13-15 .....

WO	Recieved	Finished	Total	Request
FO-321598	7/13/2015			(**) PO REQ DK 7/30 Pipe fitters: please replace leaking feed water bypass valve on boiler # 2. Priority: med. ,,,,,,,,,,,,, JH/7-13-15 ,,,,,,,,,,,,,,
FO-321866	7/13/2015	7/14/2015		Trade: Pipefitter Priority: Medium Boiler #1 - Please modify LWCO blowdown and gage glass blowdown to eliminate excessive 90 degree fittings. ,,,,,,,,,,,,,, JH/7-13-15 ,,,,,,,,,,,,,,
FO-322149	7/16/2015	7/23/2015		Fitter repair leaking strainer in ceiling room 271.,,,,,,,,,,,,,, JH/7-22-15 ,,,,,,,,,,,,,,
FO-322194	7/17/2015			steam fitters- med priority- Please repair leaking tube bundles in Heat Exchanger 1 and Heat Exchanger 2 .....JH.....7/17/15
FO-322222	7/17/2015	7/20/2015		Repiar small leak in feed water line Boiler # 1.....EA.....7/17/15
FO-322224	7/17/2015			Replace surface blow down solenoid valve.....EA.....7/17/15
FO-322282	7/20/2015	7/21/2015		Pipe is leaking in back of room 2106. Currently water is being captured with a blue recycle can.....JH.....7/20/15
FO-322532	7/21/2015	7/22/2015		FITTERS (MED)  BOILERS 1 AND 2 HOT WATER RETURN VALVES ON REAR OF BOILERS NOT SEALING. REWMOVE AND INSPECT REPALCE IF NEEDED. PLEASE SEE ENGINEER.....JH.....7/21/15
FO-322706	7/22/2015			FITTERS Please disconnect heating coil on south VAV in room 4545 MED.,,,,,,,,,,,,,, JH/7-22-15 ,,,,,,,,,,,,,,
FO-322707	7/22/2015	7/23/2015		Trade: Pipefitter Priority: medium 090-HEX-007 Please repair steam leak on heat exchanger #7 located in the EDC penthouse mechanical room. ,,,,,,,,,,,,,, JH/7-22-15 ,,,,,,,,,,,,,,
FO-322714	7/22/2015	7/23/2015		**THIS IS BEING CONTRACTED OUT/JWT  INSTALL MISSING INSULATION ON CHILL WATER LINES FOR AHU UNITS IN MECHANICAL ROOM 3320. CONDENSTAION FROM PIPE CAUSING ISSUES ,,,,,,,,,,,,,, ME/7-22-15 ,,,,,,,,,,,,,,
FO-322715	7/22/2015			FITTERS  REPAIR LEAKING HYDRONICS PIPE IN ROOM 100 IN FRONT OF MAINTENANCE SINK ,,,,,,,,,,,,, EA/7-22-15 ,,,,,,,,,,,,,,
FO-322716	7/22/2015			FITTERS  REPAIR LEAKING STEAM LINE IN ROOM 100. STEAM LINE IS LOCATED IN THE FENECED ELECTRICAL CLOSURE TO THE LEFT AS SOON AS YOU ENTER THE ROOM. SEE ENGINEER ,,,,,,,,,,,,,, EA/7-22-15 ,,,,,,,,,,,,,,
FO-322859	7/24/2015			Pipefitters -- Priority Medium Condensate pumps need new seal ,,,,,,,,,,,,,, RC/7-27-15 ,,,,,,,,,,,,,,
FO-323057	7/28/2015	7/30/2015		PIPEFITTERS please replace bad steam trap over AHU1 in basement 5425 Woodward. engineer marked w/ rag. ,,,,,,,,,,,,,, ME/7-29-15 ,,,,,,,,,,,,,,
FO-323077	7/28/2015	7/29/2015		Need pipefitters to attach controls to relocated VAV in room ,,,,,,,,,,,,,, ME/ 7-29-15 ,,,,,,,,,,,,,,
FO-323228	7/30/2015			steam fitters- med priority- repair leaking steam flange on cage wash water heater (DHWH-1). ,,,,,,,,,,,,, EA/7-30-15 ,,,,,,,,,,,,,,
<b>T - Plumber</b>			<b>32</b>	
FO-320931	7/1/2015			Plumber; MediumPlease repair or replace the fifty gallon gas hot water heater that is leaking. The tank is located in the mechanical room where the city water comes into the building.
FO-320994	7/6/2015	7/21/2015		Plumber; Medium R/R RM 00195/MECH-BLR RM Please replace the bad back pressure drain line from the #1 Water Booster Pump 071-DWBP-001.,,,,,,,,,,,,,, GS/7-9-15 ,,,,,,,,,,,,,,
FO-321358	7/8/2015	7/10/2015		Plumber repair small water leak under kitchen sink at water filter.,,,,,,,,,,,,,, MM/7-9-15 ,,,,,,,,,,,,,
FO-321359	7/8/2015	7/10/2015		Plumber repair leaking faucet at lab sink.,,,,,,,,,,,,,, MM/7-9-15 ,,,,,,,,,,,,,,
FO-321363	7/8/2015	7/10/2015		Plumber repair long flush in second stall woman's rest room basement ,,,,,,,,,,,,,, MM/7-9-15 ,,,,,,,,,,,,,
FO-321378	7/8/2015	7/20/2015		MENS & WOMENS RM HAVE STALLS WITH LOOSE TOILET SEATS ,,,,,,,,,,,,,, MP/7-9-15 ,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-321401	7/9/2015			Plumb. Med. Priority R/R RM 00035/MECH RM Please run drain line to sewer from catch basin nw corner of mech. rm. water from seepage through wall creating safety hazard ,,,,,,,,,, MM/7-9-15
FO-321483	7/10/2015	7/17/2015		(**) PO REQ DK 7/15 Plumbers: Please repair water leak on domestic water line to 4th floor restrooms, the leak is boiler room. Priority: med. ,,,,,,,,,, GS/7-10-15 ,,,,,,,,,,
FO-321557	7/12/2015			Repair sump pump #1 at loading dock of Scott Hall. The pump it tripping out the motor starter. Reported by Robert Clemons. Posted by Ballou.,,,,,,,,,, GS/7-13-15 ,,,,,,,,,,
FO-321964	7/14/2015	7/28/2015		Plumbers: please repair leak on domestic hot water supply after heat exchanger. Priority: med.,,,,,,,,,, GS/7-14-15 ,,,,,,,,,,
FO-321989	7/14/2015	7/15/2015		Outside of the first floor women's bathroom (room 1010) there used to be a drinking fountain. It was removed, but the pipes are still there. The cap that was put on has fallen into the pipe and now the opening is putting a smell of sewer into the hallwa
FO-322009	7/15/2015	7/16/2015		Purdy Library 3rd Floor, Room 331  Sink plugged, not draining properly.,,,,,,,,,, MM/7-15-15 ,,,,,,,,,,  Please repair.  Thank you.
FO-322179	7/17/2015			*LOWERED PRIORITY / WORK IN PROGRESS JWT  REPAIR SUMP PUMP. ALARM SOUNDING. BASEMENT. CONTACT ENGINEER FOR MORE DETAILS.....GS....7/17/15
FO-322179	7/17/2015			*LOWERED PRIORITY / WORK IN PROGRESS JWT  REPAIR SUMP PUMP. ALARM SOUNDING. BASEMENT. CONTACT ENGINEER FOR MORE DETAILS.....GS....7/17/15
FO-322229	7/17/2015	7/20/2015		Trade: Plumbers Priority: Medium Please repair back flow protector for the cold water line for fume hood 9 in lab 220 on the right hand side.....MP.....7/20/15
FO-322238	7/17/2015	7/22/2015		Please repair ceiling leak on 4th floor at the front of the elevators in ceiling.....GS....7/20/15  This is for the pluming Department.
FO-322248	7/20/2015	7/21/2015		PLUGGED SINK. 5TH FLOOR LADIES RESTROOM.....MM.....7/20/15
FO-322557	7/21/2015			Leaking Domestic water line.Turn work order over to plumber.....MM.7/21/15  Pipe is leaking in back of room 2106. Currently water is being captured with a blue recycle can.....JH.....7/20/15
FO-322677	7/22/2015	7/22/2015		**DUPLICATE WORK ORDER / REFER TO FO#322678 R/R RM 223/LAB 2 OUT OF 3 SINKS HAVE DRIPPING FAUCETS
FO-322689	7/22/2015	7/27/2015		Mens locer room 114. Please fix/repair/replace broken shower handle in mens shower. Fix prior to school starting August 3, 2015 ,,,,,,,,,, MM/7-23-15 ,,,,,,,,,,
FO-322696	7/22/2015	7/24/2015		R/R RM 2377/WOMENS RR REPAIR BAGGED TOILET ,,,,,,,,,, MM/7-23-15 ,,,,,,,,,,
FO-322700	7/22/2015	7/24/2015		R/R 2ND FLR MENS RR NEAR ELEVS' REPAIR BAGGED URINAL ISN'T FLUSHING ,,,,,,,,, MM/7-23-15 ,,,,,,,,,,
FO-322701	7/22/2015	7/24/2015		R/R 3RD FLR MENS RR NEAR ELEVS' REPAIR BAGGED TOILET ,,,,,,,,,, MM/7-23-15 ,,,,,,,,, ,,,,,,,,,,
FO-322860	7/24/2015			Plumber -- Priority Medium Eye wash in boiler room leaking ,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,
FO-322977	7/27/2015			Plumbers -- Priority Medium R/R RM 00045/MECH RM Floor drains in Pump and Fan rooms plugged ,,,,,,,,,, GS/7-29-15 ,,,,,,,,,,
FO-323056	7/28/2015			PLUMBERS please r/r missing backflow preventer in lawn sprinkler line. Also please repair leak NW corner of West side Lawn (suspected sprinkler line leak). -Spoke to Jerry- ,,,,,,,,,, GS/7-29-15 ,,,,,,,,,,
FO-323140	7/29/2015	7/30/2015		R/R RM 1302/MENS RR 1ST STALL TOILET ISN'T FLUSHING ,,,,,,,,,, MM/7-29-15 ,,,,,,,,, ,,,,,,,,,,
FO-323179	7/29/2015	7/30/2015		PLUMBERS-PLEASE REPAIR TOILET#1 IN REST ROOM MED PRIORITY ,,,,,,,,,, MM/7-29-15 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-323180	7/29/2015	7/30/2015		PLUMBERS-PLEASE REPAIR TOILET#1 IN REST ROOM MED PRIORITY MENS REST ROOM ,,,,,,,,,, MM/7-29-15 ,,,,,,,,,
FO-323274	7/30/2015			In the 1st floor ladies restroom, complaint that the 1st stall's handle is broken and piping is coming apart from the wall (just received complaint today),,,,,,,,,, MM/7-30-15 ,,,,,,,,,
FO-323280	7/30/2015			please adjust flow on drinking fountain, 1st floor next to mech. room ,,,,,,,,,, MM/7-30-15 ,,,,,,,,,
FO-323281	7/30/2015			please investigate no cold water at sink in back end of paint shop.....DB/TT.....7-30-15
<b>T - Roofing</b>			<b>1</b>	
FO-322525	7/21/2015			Trade: RoofersPriority: MediumPlease repair roof leak... in the door and to the left.
<b>Low</b>			<b>450</b>	
<b>T - Carpenter</b>			<b>63</b>	
FO-320911	7/1/2015	7/6/2015		Door will not lock from the inside. This is NOT an emergency, unit is unoccupied. Please send a locksmith 7/1/15 lps: Chng to Est for Main
FO-320915	7/1/2015			TEAM LEADER TIME ( JULY 2015 )
FO-321247	7/7/2015	7/7/2015		ASSIGN CARPENTERS TO REPLACE THE CEILING TILE IN THE WOMENS RESTROOM IN THE BASEMENT NEXT TO THE ELEVATORS
FO-321276	7/7/2015	7/9/2015		Trade: Carpenters or PaintersPriority: MediumPlease repair drywall in the E- W hallway near room 460 (near the women's restroom). Wall was damaged by a pipe leak. Follow up to FO321051.
FO-321295	7/7/2015	7/8/2015		Carpenters: please repair door to restroom 232, the door rubbing on to the door jamb. Priority: low.
FO-321298	7/7/2015	7/8/2015		Carpenters: please replace damaged and stained ceiling tiles on 3rd floor near room 318. Priority: low.
FO-321349	7/8/2015	7/9/2015		Requesting carpenter to come out and check a file cabinet that will not close properly.
FO-321439	7/9/2015			carpenters : please replace ceiling tiles above Loretta's desk see Don B for location....  ADDING PLUMBERS: R/R PAINT SHOP SINKS PLEASE CK IF ANY DRAINS ARE LEAKING INTO SVC CTR/CK CLNG IN THE SVC CTR R/R RM 150 IN BTWN LORETTA'S & LARRY'S DESK AGA
FO-321442	7/9/2015	7/22/2015		please install a 16x16 access door on hallway wall next to room 315....see Jerry S for location if needed
FO-321446	7/9/2015	7/9/2015		CARPENTERS TO REPAIR KIOSK SIGN IN FRONT OF LIFE SCIENCE / BIO- SCIENCE BUILDINGS
FO-321460	7/9/2015	7/10/2015		FORK LIFT TRAINING CLASS
FO-321481	7/10/2015	7/14/2015		SAFTEY TIME FOR THE MONTH OF JULY.
FO-321497	7/10/2015	7/16/2015		OPEN TO CARPENTERS, please replace broken ceiling tile in room 422..... Ceiling tiles have fallen down in room 422. They are waterlogged,,,,,,,,,,,,, *DB/ME/6-29-1
FO-321498	7/10/2015			OPEN UP TO CARPENTERS.... can you please cut 3 pieces of 3/4 inch plywood 16x16 and deliver them to the pipe shop for Jerry Samancas..... DK 6-1 (** ) PO REQ #2
FO-321501	7/10/2015			OPEN UP TO CARPENTERS.....need scaffolding on 3rd floor see Jerry S for exact location..... REQ #2 DK 6-10-15 (** ) PO (**) PO REQ DK 4-15-15
FO-321512	7/10/2015	7/21/2015		R/R 2ND FLR HALLWAY Please replace damaged, loose asbestos floor tile in the hallway outside office 2207. 7/10/15 lps: Per Al K send to Carp Shop first
FO-321514	7/10/2015	7/23/2015		Carpenters:Please fill-in a section of cement flooring that was uncovered in storeroom. about a section 3 to 4 feet square and a depth of about 3 inches. Hole appears to be old and may have been opened by a contractor that never finished the job. Low p
FO-321602	7/13/2015	7/14/2015		Purdy Library R/R RM 338 ADJUST DOOR Door sticking in frame; difficult to open.  Please adjust or repair.  Thank you.
FO-321618	7/13/2015	7/13/2015		CARPENTERS TO REPAIR CEILING TILE 1ST FLOOR WEST SIDE NEAR BATHROOMS



WO	Recieved	Finished	Total	Request
FO-321619	7/13/2015	7/20/2015		CARPENTERS TO REPLACE CEILING TILES 4TH FLOOR HALLWAYS CEILING TILES OUTSIDE THE FREIGHT ELEVATORS
FO-321867	7/13/2015			<p>Purdy Library R/R RM 127 1st Floor Room 127 (near exit 8) Wide gaps around window allow rain to enter. Please caulk.</p> <p>See Richard at the Check Out desk if additional information is needed.</p> <p>Thank you.</p>
FO-321894	7/14/2015	7/21/2015		CARPENTERS, PLEASE SECURE #2 FFC UNIT TO WALL.PRIORITY-LOW.
FO-321898	7/14/2015	7/22/2015		CARPENTERS, PLEASE SECURE #3 FFC UNIT TO WALL. PRIORITY-LOW.
FO-321940	7/14/2015			In Rm. 0250 one of the middle floor tiles need replacing.
FO-321950	7/14/2015	7/15/2015		R/R RM/STE 354 ADJUST DOOR/DOOR CLOSURE @ Rear (north) door to suite is not closing completely. Security issue. Please adjust closer.
FO-321979	7/14/2015			Broken glass door, in the breeze way between McGregor and Alumni. w151950030
FO-321957	7/14/2015	7/16/2015		Repair door to PLD substation located in basement level of Engineering and labeled 9. The door is very hard to open. PLD must be contacted for access: (313) 961-1364.
FO-321988	7/14/2015	7/30/2015		R/R BSMT The pexiglass for the Building Basement Evacuation Plan located by the basement stairway, just outside of rooms 41 - 49 is broke and needs replacing.
FO-322005	7/15/2015	7/21/2015		CARPENTERS, PLEASE CORRECT BINDING EXTERIOR DOOR # 001-14-W. PRIORITY-LOW.
FO-322100	7/16/2015	7/17/2015		WOMEN'S RESTROOM IN BASEMENT ON CASS SIDE THE HANDICAP LOCK IS BROKEN. PLEASE REPAIR.
FO-322124	7/16/2015			R/R 3RD FLR All of the office signs on this floor are slowly falling off the walls. It appears as though the double-sided tape that was used to attach them next to each office door is gradually losing its adhesion. Some have fallen off, others are hanging
FO-322208	7/17/2015	7/20/2015		Requesting a 7 foot rod for the grounds department for the measuring of trees and the like. please contact Carla Crawford when its ready at 7-6954.
FO-322539	7/21/2015	7/24/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN ROOMS 4404 & 4406. PRIORITY-LOW
FO-322619	7/21/2015	7/22/2015		Fix hole on south west corner in the "tent" that goes around the 1st floor exterior of the building. Homeless people have figured out that it is a great place to stay at night and over the weekend.
FO-322597	7/21/2015	7/22/2015		CARPENTERS, PLEASE REPAIR BINDING WOOD DOUBLE DOORS IN HALLWAY NEAR STAIRWELL F 2ND FLOOR. (ATTN: ED)PRIORITY-LOW
FO-322600	7/21/2015	7/22/2015		CARPENTERS, PLEASE REPAIR BINDING METAL DOUBLE DOORS IN STAIRWELL-F 3RD FLOOR. (ATTN: ED). PRIORITY-LOW
FO-322601	7/21/2015	7/29/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY OF B-SECTION. PRIORITY-LOW.
FO-322620	7/21/2015	7/22/2015		CARPENTERS TO INSTALL RED FIRE EXTINGUISHER HOLDER & HANGER ROOM # 140.07
FO-322661	7/22/2015	7/23/2015		The door to the suite on the east wing (there is no room number but is the only room on that side of the building with a big rug in front of the door) will not close properly. When people close the door it will not shut on it's own like it use to and it
FO-322694	7/22/2015	7/23/2015		R/R RAMP boards that are coming up on landing and ramp to Training Trailer. Note: One board is in front of the main entrance door.
FO-322713	7/22/2015			CARPENTERSREPLACE BAD CEILING TILE OUTSIDE OF ROOM 9224

WO	Recieved	Finished	Total	Request
FO-322722	7/23/2015			CARPENTERS TO CRATE UP LCN CLOSERS TO BE REBUILT FOR THE UP & COMING YEAR. Model# 3@ 4642FP 5@ 4642 3@ 4820LH 1@ 4825RH 1@ 4822LH 1@ 4822RH 1@ 4820FP 1@ 2614/300G 16 Total Closers
FO-322796	7/23/2015	7/24/2015		CARPENTERS TO PROVIDE ACCESS TO THE NORTH WINDOW WELLS TO REPLACE THE BROKEN GLASS
FO-322807	7/23/2015	7/24/2015		R/R ROOF AREA please have carpenters repair roof hatch in chiller room penthouse. bolts that allow door to latch near pistons are loose.
FO-322806	7/23/2015	7/24/2015		carpenters...please install 16 x16 access door in hallway next to room 315, see Jerry Samancas if you have any questions...
FO-322818	7/23/2015	7/23/2015		CARPENTERS TO REPAIR DOOR CLOSER ROOM #347
FO-322838	7/24/2015	7/29/2015		R/R RM 150/SVC CTR AREA PLS MOUNT PUSH PIN BULLETIN BOARD AGAINST CUBCLE'S PANEL (see Loretta for exact location)
FO-322839	7/24/2015			R/R RM 150/SVC CTR AREA NEED TO FABRICATE A PLEXIGLASS SCREEN FOR DESK (see Loretta for specifics)
FO-322890	7/26/2015	7/27/2015		Adjust hinges on door to McGregor pond pump room located inside the cold kitchen in the basement. The door scrapes against the tile floor.
FO-322891	7/26/2015	7/27/2015		Repair door to staff lavatory room 008, located in the basement level of Kresge Library, near the elevator. The hinges are thrown due to misuse of door stop in hinge area. Also provide a wooden or kick-down door stop to prevent recurrence.
FO-322895	7/27/2015			Purdy Library R/R RM 134 1st Floor GLUE Torn carpet; Trip hazard. Please repair.  See Richard at the Check Out Desk if additional information is needed.  Thank you.
FO-322934	7/27/2015	7/28/2015		R/R RM 2340 non-functioning lock and handle on closet door. There are three closet doors; this is the one on the right.
FO-323054	7/28/2015			Carpenters please demo blockwall for hose bib connection access in womes south bathroom far left stall, red crayon square*****(**) PO REQ DK 6-2-15  Repair 3 Wall hydrants at WSU Stadium @ South & east walls,,,,,,,,,GS4/24/15,,,,,,,,,,
FO-323086	7/28/2015	7/29/2015		R/R RM 2134/Men's bathroom, door retractor broken away from the door. Please repair.
FO-323160	7/29/2015	7/30/2015		R/R BLDG ENT Door 089-02E scrapes threshold. Door is hard to open per students.
FO-323166	7/29/2015	7/29/2015		CARPENTERS TO REPLACE WATER DAMAGED CEILING TILES E BUILDING ENTRANCE OUTSIDE JACOB'S GALLERY
FO-323167	7/29/2015	7/30/2015		CARPENTERS, EXTERIOR DOOR # 001-18-W IS BINDING IN THE AFTERNOON SUN, PLEASE CORRECT. (ATTN: BRUCE).PRIORITY-LOW
FO-323168	7/29/2015	7/30/2015		CARPENTERS, STEEL ENTRANCE DOOR BINDING ALSO KEY CORE STICKING , PLEASE REPAIR.PRIORITY-LOW
FO-323177	7/29/2015			Carpenters: please replace missing ceiling tile in the hallway in front of room 301. priority: low.
FO-323278	7/30/2015			R/R MAIN ENTRY LOBBY DOORS please have carpenters readjust inner main entrance doors closest to guard desk glass doors, 612-04-4, doors are squeaking loud when opened and closing
FO-323277	7/30/2015			Carpenters please replace 3 damaged ceiling tiles in 1st floor photo studio.....see jerry if you have questions
FO-323282	7/30/2015			Screen for window on west side of the room has fallen off and is on the lawn. Please re-install screen.
FO-323292	7/30/2015			R/R RM 3219 Please check lock: have to force key in and have trouble getting key out. Prof Henning's is worried the key will break off.

T - Electrician

148

WO	Recieved	Finished	Total	Request
FO-320833	7/1/2015	7/31/2015		Time to repair clocks throughout campus.  Completed 7-31-2015 SRP
FO-320834	7/1/2015			Time for Laborer to clean shops for the Trades.
FO-320835	7/1/2015			Time for Team Leader Administrative time.
FO-320885	7/1/2015	7/22/2015		Gyms 109, 110, and 111 has 1 light out in each gym (Electricians need the lift to reach the lights. 1 light out in the over hang as you enter gym 109.
FO-320933	7/1/2015	7/27/2015		electrician R/R RM 271 repair several lights in lab 271
FO-320969	7/2/2015			Suite 227 in State Hall is being leased to Inside Out, a tenant and nonprofit organization. The suite hasn't been used in many years and some of the light bulbs need to be replaced. If it is not a bulb issue, then please address the issue with t
FO-320970	7/2/2015	7/20/2015		R/R Room 310 has an automatic switch to control shutting off the lights when the room is unoccupied, but it takes a very long time to shut off. Can it be adjusted to shut off after a minute or two, please?  This has been adjusted once, but they're compl
FO-320979	7/2/2015			Women locker rooms 12 lights out. South staircase 2 lights out. Training room 1 light out. There is 1 EP in the training room, There is 1 EP in the varsity swim team locker room... There is 2 EP in the womens locker room. this will be turned over
FO-320986	7/2/2015	7/9/2015		Electrician disconnect power to hot water heater #2 3rd floor mechanical room
FO-321021	7/6/2015	7/9/2015		Please re-wire ahu#2 in penthouse.....ATT. Pat and Don
FO-321022	7/6/2015			need Duct Hoist delivered to Life Sciences mech room.....
FO-321041	7/6/2015	7/21/2015		Repair clock in room #320  Completed 7-21-2015 SRP
FO-321042	7/6/2015	7/21/2015		Repair clock in DLAR hallway.  Completed 7-21-2015 SRP
FO-321044	7/6/2015	7/13/2015		Repair clock in hallway near room 1333.  Completed 7-13-2015 SRP
FO-321045	7/6/2015	7/16/2015		Repair clock in cafeteria.  Completed 7-16-2015 SRP
FO-321057	7/6/2015			Please have Maintenance Laborer take scrap metal to recycling yard.
FO-321059	7/6/2015	7/6/2015		Time for new employee to attend Orientation to begin work.
FO-321278	7/7/2015	7/21/2015		4 light bulbs are out and need to be replaced above the cubicle in the main area of suite 3660.... This area is dim do to lights out...this will go to the electricians...There is two Ep's over cubicle...outside office 3650
FO-321288	7/7/2015			Room 029 Basement - 2 EPs - In both the fixtures the tombstones are loose.
FO-321299	7/7/2015	7/7/2015		Tools needed in the Electric shop.
FO-321305	7/7/2015	7/9/2015		Repair bad clock on 3rd floor near service elevator.  Completed 7-9-2015 SRP
FO-321306	7/7/2015	7/10/2015		Repair bad clock on 3rd floor near study area.  Completed 7-10-2015 SRP
FO-321326	7/8/2015			In Karmanos building there is one fixture out in room AF-32.  Comments: DLAR Hallway.

WO	Recieved	Finished	Total	Request
FO-321336	7/8/2015	7/16/2015		The hallway clock above the door to 3125 Old Main has not been working for a couple weeks now. It is stuck on 5:00. (I wish it were that time for real)  Completed 7-16-2015 SRP
FO-321343	7/8/2015			Laborer- Low priority- Please deliver Tower treatment chemicals1 40 gal barrel of AquaKlean1 40 gal. barrel of Lokor1 40 gal. barrel of Halochlor 4 5 gal pails of NitroKlenz
FO-321344	7/8/2015	7/8/2015		Time for PM Technologies to make repair on Generator #14 found during maintenance inspections.
FO-321355	7/8/2015			Electricians - Low. R/R RM 00029/MECH RM Please install 115v receptacle on load side of power switch that is on the large compressed air dryer in main mechanical room to accommodate automatic blowdown. (Old engineering bldg. basement)
FO-321361	7/8/2015	7/15/2015		Two fluorescent lights are out in room 398,one outside of room 381, 380, 375, 367. please replace lights out. thank you
FO-321369	7/8/2015	7/9/2015		R/R RM 00025/MECH RM Please have laborer deliver 1) 4 (four) five gallon pails of Lokor to rm. 25 comm. Arts
FO-321374	7/8/2015	7/16/2015		LABORER: R/R PENTHOUSE Please deliver 1) 1 pallet of SALT to the Pharmacy Penthouse. MED.
FO-321375	7/8/2015	7/9/2015		Replace bad clock in basement near room #077.  Completed 7-9-2015 SRP
FO-321405	7/9/2015	7/17/2015		R/R RM 363 Repair blinking light in faculty office as soon as possible. Work order FO-319512 was submitted a month ago. Looks like the lighting tech changed bulb and it worked for awhile but is now blinking again. Faculty needs the light to work.
FO-321423	7/9/2015	7/29/2015		Multiple lights out in room 160 of manoogian.
FO-321433	7/9/2015	7/10/2015		Trade: Electrician Priority: Medium R/R BSMT Please repair or replace hallway clock near room 77. Hands are not moving.  Completed 7-10-2015 SRP
FO-321437	7/9/2015	7/9/2015		Pick up debris from plumbing repair . See Gerry (plumber) for location
FO-321457	7/9/2015	7/9/2015		Time to attend training for HiLo.
FO-321491	7/10/2015	7/21/2015		LABORER  DELIVER TO SCOTT HALL: R/R RM 00100/MECH RM 1) 20 PAILS NITROKLENZ 17010050 20 PAILS 2) 10 PAILS LOKOR 17010106 10 PAILS  FO#297763
FO-321494	7/10/2015	7/20/2015		OPEN TO ELECTRICIANS please re-wire steam condensate pump in room 025, see Ron C if needed..... (**) PO REQ DK
FO-321507	7/10/2015			NO POWER IN WALL OUTLETS. BASEMENT MECHANICAL ROOM AND SURROUNDING AREAS. (MULTI-TASK)
FO-321587	7/13/2015	7/14/2015		DENNIS: R/R PENTHOUSE Please deliver 1) 2 DRUMS of LOKOR to PHARMACY PENTHOUSE MED.
FO-321606	7/13/2015	7/16/2015		florescent light bulbs needed in hallway of suite 201. There is 1 electrical problem.
FO-321613	7/13/2015	7/13/2015		Time for Electricians to attend Training for UPS System in building.
FO-321856	7/13/2015	7/22/2015		Elevator #2 - 3 Lights Out
FO-321901	7/14/2015	7/17/2015		ELECTRICIANS- R/R GARAGE please r/r disconnect switch for AHU 1 in driveway that is not connected to anything and will not switch.
FO-321910	7/14/2015	7/17/2015		Women's restroom. (Basement)
FO-321911	7/14/2015	7/20/2015		Hallway between the elevators and STAIR A. (4th floor)

WO	Recieved	Finished	Total	Request
FO-321930	7/14/2015			2 fixtures over the stairwell outside room 226 has 2 electrical problems. A scaffold will be required.
FO-321931	7/14/2015	7/21/2015		In Rooms 3145 and 3250 have lights that are out and need replacing. Room 3145 has 1 electrical problem. Room 3250 has 1 electrical problem.
FO-321945	7/14/2015			Please change 2 lights and repair broken light cover in the Athletic Training Room. See Bob Ostrowski for specs. There is one EP as you come in the training room.... and in edition to this,(3) lens covers will be ordered by Eugene Owens...
FO-321946	7/14/2015	7/14/2015		Repair clock located in room 124.  Completed 7-14-2015 SRP
FO-321947	7/14/2015	7/16/2015		Repair clock near 1st floor Cass Avenue door.  Completed 7-16-2015 SRP
FO-321951	7/14/2015	7/28/2015		Hallway outside of room 1505.
FO-321952	7/14/2015	7/30/2015		Hallway along side of room 3341.
FO-321958	7/14/2015	7/16/2015		Trade: Laborer Priority: Medium R/R RM 00000.62/MECH-BLR RM Please deliver on pallet of salt for the chiller cooling tower at Chemistry. Standing FO 297706
FO-322006	7/15/2015	7/17/2015		Repair 3rd floor clock near east stairwell.  Completed 7-17-2015 SRP
FO-322007	7/15/2015	7/17/2015		Repair 3rd floor clock west side.  Completed 7-17-2015 SRP
FO-322047	7/15/2015	7/28/2015		Room 9374 - Several burnt out bulbs in office. Please replace. There are 2 electrical problems in room 9374.
FO-322067	7/15/2015			rm 3337.1 inner men's bathroom lights out. There is 1 electrical problem.
FO-322085	7/16/2015	7/21/2015		LABORER  DELIVER TO SCOTTHALL R/R RM 00100/MECH RM 1) 1 PALLET WATER SOFTENER SALT 17010010  FO#297763
FO-322088	7/16/2015			Range 7. (basement)
FO-322092	7/16/2015			Trade: Laborer Priority: Medium R/R RM 00000.62/MECH-BLR RM Please deliver 1) 2 (Two) keg of Lokor and 2) 2 (Two) keg of Aquaklean for the chilled water system. Standing FO 297706
FO-322095	7/16/2015			R/R PH/MECH RM please have electricians replace on off switch on exhaust fan 48, will not stop or start exhaust fan.
FO-322115	7/16/2015	7/22/2015		LABORER, R/R SUB-D/MECH RM PLEASE REMOVE COPPER PIPING FROM AIR INTAKE AREA AND DELIVER TO PIPE SHOP. ( 4 SECTIONS 1 1/2 X 20 FT). PRIORITY-LOW.
FO-322125	7/16/2015	7/17/2015		Hallway between rooms 113 and 115.
FO-322126	7/16/2015	7/21/2015		Elevator light in the Damon Keith wing.  Completed 7-21-2015 SRP
FO-322153	7/16/2015	7/22/2015		Clean out the men, and women first floor restrooms.
FO-322173	7/17/2015	7/20/2015		fo-297744 please have the laborer deliver 1 pallet of salt to scott hall. minus 10 bags to Hudson webber building. please have dennis inform engineer prior to delivery to Hudson webber for key and delivery point thank you. please call or page 577-1590- 68
FO-322175	7/17/2015	7/30/2015		Relamp light Fixture in stairwell F at the First Floor
FO-322181	7/17/2015	7/20/2015		Elect. Med Priority R/R RM 00055/MECH RM Pick up second motor in area of Engineers office

WO	Recieved	Finished	Total	Request
FO-322183	7/17/2015	7/22/2015		In Manoogian room 487 there are two lights out, there are 2 lights out in room 495 and 2 lights out in room 494, these two rooms are with in suit 487. on the fourth floor hallway outside of room 473 two lights out, and on the fifth floor stairway close to
FO-322257	7/20/2015	7/27/2015		fo-297763 please have a pallet of aquaclean delivered to the pent house. thankyou
FO-322258	7/20/2015	7/22/2015		fo-297763 please have a pallet of haloclor delivered to the penthouse thankyou
FO-322265	7/20/2015			Repair/replace 3 burnt out spot lights on 1 floor inside front (north) entrance. There are 3 electrical problems.
FO-322263	7/20/2015	7/22/2015		Repair bad clock near room #1369.  Completed 7-22-2015 SRP
FO-322264	7/20/2015	7/28/2015		Repair bad clock in room #2268.  Completed 7-28-2015 SRP
FO-322266	7/20/2015	7/27/2015		Repair bad clock in room #2106.  Completed 7-27-2015 SRP
FO-322268	7/20/2015	7/30/2015		please have elecreicians check power on computer #50 and #51 no power and can't reset strip.
FO-322274	7/20/2015	7/23/2015		Laborer to assist Electricians in moving One Man Lift to Matthaiei to repair Lights, and help take it back to UGL when job is complete.
FO-322293	7/20/2015	7/23/2015		Laborer to spray Roundup/Weed Killer to get rid of vines growing around Building. Photo included.
FO-322516	7/21/2015	7/21/2015		ELECTRICIANS please fuse and test SF1 in electrical room west side of building, behind ROTC wing.  Completed 7-21-2015 SRP
FO-322519	7/21/2015	7/29/2015		The Donor Gallery has 6 electrical problems. (1st floor)
FO-322520	7/21/2015			STAIR B. (2nd floor)
FO-322521	7/21/2015	7/29/2015		Hallway in front of the elevators. (4th floor)
FO-322540	7/21/2015			ELECTRICIANS, PLEASE REPLACE BAD EXIT SIGNS IN BSMT AREA.PRIORITY-LOW
FO-322541	7/21/2015			ELECTRICIANS,PLEASE REPLACE BAD HALLWAY EMERGENCY LIGHTING ON 1ST FLOOR.PRIORITY-LOW
FO-322542	7/21/2015	7/23/2015		There is a broken electrical floor receptacle, in the middle of the office. Can the receptacle get replaced and another one added side by side. ( The floor box is able to hold 2 Receptacles but the other port is empty. Thank You
FO-322609	7/21/2015	7/28/2015		Repair clock in room #310.
FO-322610	7/21/2015	7/28/2015		Repair clock in room #2105.  Completed 7-28-2015 SRP
FO-322611	7/21/2015	7/30/2015		Repair clock near room #2276.  Completed 7-30-2015 SRP
FO-322649	7/22/2015	7/22/2015		R/R RM 00425/MECH-BLR RM Have laborer deliver 1) eight bags of salt to Music boiler room. Thank you.
FO-322652	7/22/2015			Hallway in front of the exercise equipment and the tables and chairs. (1st floor)
FO-322654	7/22/2015			Light over the exercise equipment. (3rd floor)
FO-322655	7/22/2015	7/23/2015		Back porch light.
FO-322670	7/22/2015	7/23/2015		EP! - 1st floor - chandeliers have multiple sockets out.
FO-322672	7/22/2015			R/R RM 112/ASSEMBLY AUD 1ST floor Auditorium (slanted floor) has a ceiling light that is beeping every 3 seconds. Vice President of Research is in there doing a symposium today and the beeping is very annoying.
FO-322710	7/22/2015			Lighting -- Priority Medium Lights out in main hallway. They are all HID lights.
FO-322740	7/23/2015	7/23/2015		Repair #4 Generator at the Computer Science Bldg.

WO	Recieved	Finished	Total	Request
FO-322753	7/23/2015	7/23/2015		R/R RM 00025/MECH RM Please have laborer deliver the following to comm. Arts rm. 25. 1) 1-5 gal. of Lokor 2) 3-5 gal. of Aquaklean, 3) 3- 5 gal. of Halochlor. Thank you.
FO-322752	7/23/2015			1 EP - Front Entrance - fixture out as soon as you come through the door.
FO-322759	7/23/2015	7/27/2015		please deliver 1 pallet of aquaclean to penthouse scott hall. 297963 high priority.
FO-322771	7/23/2015	7/27/2015		R/R RM PH AREA please have laborer deliver TO SCOTT HALL 1) 1 PALLET OF AQUAKLEAN ODP.
FO-322762	7/23/2015			Room 1515.
FO-322765	7/23/2015			In Stair 3 there is a light outside of the Emergency door.
FO-322766	7/23/2015			Range 277. (2nd floor)
FO-322767	7/23/2015	7/27/2015		2nd floor - 8 footer fluorescent light out.
FO-322769	7/23/2015	7/27/2015		Women's restroom. (2nd floor)
FO-322772	7/23/2015	7/27/2015		There are 4 EP's in the studio, just as you enter the suite...#4113 Just as you get off the elevator.
FO-322817	7/23/2015	7/23/2015		Repair for Generator at EDC to complete Maintenance work.
FO-322819	7/23/2015	7/23/2015		Take truck in for Oil Change.
FO-322841	7/24/2015			Note: laborer delivered cooling tower chemicals to wrong building. Please have the 1) 3 chemical drums of Aquaklean 2) 1 drum Halochlor removed from the stairwell of the Music building and properly delivered to room 25 of the Community Arts building.
FO-322877	7/24/2015	7/27/2015		1 Ep - 2nd floor, outside of the copier room 2325, but closer to the stairwell exit door.
FO-322880	7/24/2015	7/28/2015		2 EPs - Front Lobby, two flood lights are out. They're aimed at the tile design in the front lobby.
FO-322881	7/24/2015	7/28/2015		Repair bad clock near 2nd floor elevator.  Completed 7-28-2015 SRP
FO-322883	7/24/2015	7/27/2015		Room 9374 - Light out. 2 electrical problems since 7-15-15. See FO-322047
FO-322888	7/24/2015	7/28/2015		The light above the desk in 2410.1 is burned out on one side and flickering on the other. Please repair between the hours of 8:30am and 10:00pm.  Thanks in advance, Andy
FO-322900	7/27/2015			Room 1535 has 2 electrical problems.
FO-322901	7/27/2015			Room 1545 has 2 electrical problems.
FO-322904	7/27/2015	7/30/2015		DENNIS: R/R PENTHOUSE Please deliver 1) one pallet of SALT to PHARMACY penthouse. LOW
FO-322906	7/27/2015			DENNIS: R/R PENTHOUSE Please deliver 2) two DRUMS of LOKOR to the Pharmacy Penthouse. LOW
FO-322905	7/27/2015	7/27/2015		LABORER TO MOVE MAN LIFT FROM MATTHAEI
FO-322914	7/27/2015			ELECTRICIANS,R/R RM 00171/CLASS RM PLEASE REPLACE DEFECTIVE TIME CLOCK.PRIORITY-LOW
FO-322915	7/27/2015	7/28/2015		R/R RM 2343 Clocks not Working:  Completed 7-28-2015 SRP
FO-322917	7/27/2015			R/R RM 2248/MD Lab (clock working ,but one hour behind);
FO-322919	7/27/2015			R/R RM 2106 Clocks not Working: .
FO-322920	7/27/2015	7/30/2015		R/R RM 2206/CONF RM Clocks not Working:  Completed 7-30-2015 SRP
FO-322921	7/27/2015	7/28/2015		R/R RM JAFAR LECT HALL Clocks not Working: North Clock;  Completed 7-28-2015 SRP

WO	Recieved	Finished	Total	Request
FO-322923	7/27/2015	7/30/2015		R/R 2ND FLR Clocks not Working: 2nd Fl. South East corridor; west face clock. High priority to repair.  Completed 7-30-2015 SRP
FO-322930	7/27/2015			LABORER, R/R RM 00021/MECH RM PLEASE DELIVER 1) 30 GAL BARREL OF HALOCHLOR (#17010100). FO-297751. PRIORITY-LOW.
FO-322972	7/27/2015			2nd Floor Men's Bathroom piping renovation Laborer support:  -Remove debris as needed from 1st and 2nd floor men's bathroom.  -Transport material from stockroom to location as needed  *See Don Bear for detail  *Use this work order till end of proj
FO-322978	7/27/2015	7/29/2015		Laborer --Priority Medium R/R RM 00045/MECH RM Electrical fixtures in Fan Room need to be removed.
FO-323044	7/28/2015	7/29/2015		Stairwell light across from the Guard's desk has an electrical problem. (1st floor)
FO-323045	7/28/2015	7/30/2015		The lights inside of the Guard's desk has an electrical problem. (1st floor)
FO-323052	7/28/2015			OPEN UP TO ELECTRICIANS, please unhook wires to 5 gallon heater in basement under sink*****(**) PO REQ DK 7/2  PLUMBERS- R/R RM 00010/BSMT MECH RM please r/r 6 gal HWT in basement at university services in cabinet under sink. Leaking. ,,,,,,,
FO-323074	7/28/2015			ElectricianR/R 2ND FLR HALLWAY repair light in hallway outside AF-31 animal facility.
FO-323127	7/29/2015			Entrance light to room 9312. I had to remove the lights because they were flickering.
FO-323130	7/29/2015	7/30/2015		Please have Electricians move electrical outlet located over microwave in the FP&M Stockroom three feet to the right. Air Conditioner when turned on drips and could cause an electrical problem. See Lynda Kinder /Marcus Darty for details.
FO-323149	7/29/2015			Room 1550.
FO-323176	7/29/2015	7/30/2015		There are 3 electrical problems in the grounds' department.
FO-323181	7/29/2015			Electricians: R/R 3RD FLR HALLWAY please replace missing ceiling light fixtures in the hallway in front of room 307. priority: low.
FO-323229	7/30/2015			Please pick up chill water coil in penthouse and return to stockroom. See Jim hill for asstance if needed
FO-323234	7/30/2015			Repair the switch in room 1525.
FO-323235	7/30/2015			Hallway outside of range 150.
FO-323236	7/30/2015			Hallway outside of range 71. (Basement)
FO-323242	7/30/2015	7/31/2015		2nd Floor - 1 EP - The fixture is a canister light on the 2nd floor landing to the left of the stairwell going up.
FO-323244	7/30/2015	7/31/2015		1st Floor, Women's R/R - The fixture is located over the last stall. New bulbs have been installed.
FO-323249	7/30/2015	7/30/2015		Room 108 Janitor's Closet - 1 EP - Fixtures at the end of the room. New bulbs have been installed.
FO-323279	7/30/2015	7/31/2015		electricians, please investigate reason there is no power to the 110 outlets in south end basement womens restroom.....see Mike P if you have any questions...
FO-323296	7/30/2015			Electrician R/R 3RD FLR repair AH-3-B supply fan does not run.

**T - Locksmith**

**120**



WO	Recieved	Finished	Total	Request
FO-320945	7/1/2015	7/13/2015		<p>New Key New Staff Member Key #: 7892 Key Holder ID: Tonya Whitehead Qty: 1</p> <p>action: In addition to the key for the animal room, I will need a key to the freight elevator to transport animals.</p>
FO-320916	7/1/2015	7/6/2015		KEYS & CORES ( JULY 2015 )
FO-320946	7/1/2015	7/13/2015		<p>New Key New Staff Member Key #: A9CB-25 Key Holder ID: Gabrielle SiKora (R-FaST) Qty: 3</p> <p>action: In addition to Rm.351, Please provide (3) keys for 363 (A9CB-7).</p> <p>Let me know if you have any questions - Thank you!</p>
FO-320956	7/2/2015	7/13/2015		<p>New Key Damaged Key #: 401 Key Holder ID: Cathy Kendra / Deb Ashcraft Qty: 4</p> <p>action: Need extra keys for personnel working at Elliman.</p>
FO-320983	7/2/2015			<p>New KeyDamagedKey #: LL24Key Holder ID: Joe HuttingQty: 2action: This key is used for access panels throughout the building.</p>
FO-320984	7/2/2015	7/13/2015		<p>New Key New Space Assignment Key #: 13266 Key Holder ID: Brandon Parker Qty: 10</p> <p>action: Please deliver via courier to Scott Hall for pickup. Account #: 134841</p>
FO-321053	7/6/2015	7/20/2015		<p>New KeyNew Space AssignmentKey #: X2791Key Holder ID: Leo A. Tomaszewski/Matt WisotskyQty: 2action: need keys for A/V storerooms.</p>
FO-321054	7/6/2015	7/20/2015		<p>New Key Lost / Stolen Key #: OE 22 Key Holder ID: Leo A. Tomaszewski Qty: 1</p> <p>action: Lost my key.</p>
FO-321023	7/6/2015	7/20/2015		please make 3 keys (x3172) for pipe shop.....
FO-321055	7/6/2015			<p>New KeyLost / StolenKey #: N/AKey Holder ID: Business OperationsQty: 2action: La Pita, the retail space at Parking Structure 6, has non-standard and non-WSU lock sets and key sets. These should be brought to the WSU standard. Please contact la</p>
FO-321056	7/6/2015	7/10/2015		<p>Replacement Lost / Stolen Key #: 820 Key Holder ID: Marsherry Jarrett Qty: 1</p> <p>action: Replacement of a master key for building coordinator. I would like to request as soon as possible. Account #: 121921</p>

WO	Recieved	Finished	Total	Request
FO-321249	7/6/2015	7/15/2015		New Key Lost / Stolen Key #: 17623 Key Holder ID: Valeria Cook Qty: 6  action: Note: Department is Center for Urban Studies
FO-321259	7/7/2015	7/6/2015		LOCKSMITH TO RETREIVE BUILDING MASTER KEY SET KEY STUCK IN THE CORE CUSTODIAL CLOSET 1ST FLOOR SOUTH SIDE NEAR ELEVATORS
FO-321303	7/7/2015	7/20/2015		New KeyLost / StolenKey #: 9FA77Key Holder ID: Ric DelgadoQty: 1action: Room floods during heavy rains, engineer has to contact locksmith for entry. Room 119.
FO-321302	7/7/2015	7/14/2015		New KeyLost / StolenKey #: 37473Key Holder ID: Joanne LewanQty: 1action: Please replace a key to Joanne, as she has lost her key to enter the office.Account #: 165102
FO-321392	7/8/2015			New KeyLost / StolenKey #: 11LC3.4, 11LC3.5, 11LC3.6, 11LC3.7, 11LC3.8Key Holder ID: Valeria CookQty: 2 for eachaction: Please provide 2 keys for each Office/Core Mark:Room 1916: 11LC3.4, Room 1912: 11LC3.5, Room 1908: 11LC3.6, Room 1904: 11LC
FO-321476	7/9/2015	7/14/2015		New KeyNew Staff MemberKey #: 28198Key Holder ID: Rob LatvaQty: 2action: Two keys. One for Graduate Assistant - Maddy Sweeney and the other for our on duty supervisor.Account #: 227980
FO-321477	7/9/2015	7/14/2015		New KeyNew Staff MemberKey #: D-22xKey Holder ID: Karen WilsonQty: 5action: Please start with key 30786.30
FO-321518	7/10/2015	7/14/2015		New KeyLost / StolenKey #: 66288-1Key Holder ID: Dr. Donal O'LearyQty: 1action: new key
FO-321572	7/10/2015	7/13/2015		New KeyNew Staff MemberKey #: 10A 3.13Key Holder ID: Chacko George/Dr. LanierQty: 3action: Please issue 3 new keys for the above room (Key# 90449)Account #: 133601
FO-321573	7/10/2015	7/13/2015		New KeyNew Staff MemberKey #: AA2 56 Key Holder ID: Tonya WhiteheadQty: 1action: New Student in lab
FO-321574	7/10/2015	7/20/2015		New KeyLost / StolenKey #: K020Key Holder ID: Katherine TremblayQty: 2action: Key for Knoll desk at workstation 341.46 Welcome Center. Key# 020. Thank you, Mike!!!
FO-321850	7/13/2015	7/13/2015		New KeyLost / StolenKey #: 15B/EA33Key Holder ID: On hand for the Business OfficeQty: 3action: The current keys numbered 33364 that I have on hand are supposed to be for Rm. 5132, but they do not work. The core number above may help for making repl
FO-321852	7/13/2015	7/27/2015		ReplacementLost / StolenKey #: 104EKey Holder ID: SonyaQty: 2action: No key is on hand for a locked desk in Rm. 3135 & a researcher needs to get files out of the desk.
FO-321860	7/13/2015	7/13/2015		New KeyLost / StolenKey #: 63218Key Holder ID: Lilly Hatzis / Theresa HIIIQty: 5action: please cut 5 keys for office 6409.5
FO-321861	7/13/2015	7/13/2015		New KeyLost / StolenKey #: 63212Key Holder ID: Lilly Hatzis / Theresa HIIIQty: 2action: replacement keys
FO-321888	7/13/2015			New KeyNew Staff MemberKey #: Key# 877 Core# A9ABC-1Key Holder ID: Joe RasakQty: 1action: 2) Have been assigned to our electronic techs. I need 1) additional one for our network building engineer. See 2014 work order # 75317.
FO-321889	7/13/2015	7/13/2015		New KeyLost / StolenKey #: ABA2Key Holder ID: Dr. Richard PiersonQty: 1action: Thanks, Mike!
FO-321941	7/14/2015	7/13/2015		New KeyNew Staff MemberKey #: 7AA7A 3Key Holder ID: Robin BoyleQty: 2action: High priority. The professor is here and needs access to his office.
FO-322072	7/15/2015	7/24/2015		New KeyLost / StolenKey #: 33515Key Holder ID: Sonya ScottQty: 3action: Above keys are for Rm. 4127. To have some on-hand.
FO-322073	7/15/2015	7/24/2015		New KeyNew Staff MemberKey #: 11LC3.13, 11LC3.12, 11LC3.10, 11LC3.3, 11LC3.S, Key Number 17623Key Holder ID: Valeria CookQty: 3 keys for (11LC3.13, 11LC3.12, 11LC3.10) 2 keys for (11LC3.3, 11LC3.2) and 1 key for key number 17623action: Note: Depart
FO-322074	7/15/2015	7/24/2015		New KeyNew Space AssignmentKey #: 11LC4.10Key Holder ID: Valeria CookQty: 2action: Note: Department is Center for Urban Studies. Mike, if you need to see the e-mail between Ramona Washington and Deb Brazen that mentions the request above pleas

WO	Recieved	Finished	Total	Request
FO-322075	7/15/2015	7/24/2015		New KeyLost / StolenKey #: 17024, 17023--1, UTB, 65593-24Key Holder ID: Roger KempaQty: 2 1 1 1action: 2 of 17024, 1 of 17023--1, 1 of UTB(freight elevator 4th floor),1 of 65593-24(1st floor)Account #: 160010
FO-322071	7/16/2015			Lock shop training for Jeff Hammell
FO-322160	7/16/2015	7/21/2015		New KeyNew Staff MemberKey #: 23742Key Holder ID: Barb NorganQty: 2action: Leave keys for Med School courier pick up.
FO-322161	7/16/2015	7/21/2015		New KeyNew Staff MemberKey #: 23743Key Holder ID: Barb NorganQty: 2action: Leave keys for Med School courier pick up.
FO-322162	7/16/2015	7/22/2015		New Key New Staff Member Key #: 7732 Key Holder ID: Barb Norgan Qty: 2  action: Leave keys for Med School courier pick up.
FO-322240	7/17/2015	7/23/2015		New KeyNew Staff MemberKey #: 7A33.2Key Holder ID: James CarrQty: 2action: Keys for new faculty member, needed by 7/30/15. Thanks.
FO-322580	7/21/2015	7/23/2015		New KeyNew Space AssignmentKey #: 109507Key Holder ID: Debra MazurQty: 3action: request 3 keys for this sub-master#2 for Criminal Justice.Account #: 126401
FO-322630	7/21/2015	7/29/2015		New KeyNew Staff MemberKey #: 76857--2Key Holder ID: Conrad HuntQty: 1action: This is for a new employee within the Kado Clinical Skills center located inside of the Mazurek Education Commons
FO-322631	7/21/2015	7/29/2015		New KeyLost / StolenKey #: G-8xKey Holder ID: Karen WilsonQty: 5action: Key #31287
FO-322632	7/21/2015	7/29/2015		New KeyNew Staff MemberKey #: A-101Key Holder ID: Karen WilsonQty: 5action: Key #30480
FO-322633	7/21/2015	7/29/2015		New KeyNew Staff MemberKey #: F-7xKey Holder ID: Karen WilsonQty: 5action: Key #31029
FO-322723	7/22/2015	7/23/2015		New KeyNew Staff MemberKey #: 33517Key Holder ID: Sonya ScottQty: 3action: There are no more keys on hand for room 4131. Would like to have at least 3 on hand when we get down to 0.
FO-322725	7/22/2015	7/23/2015		New KeyNew Staff MemberKey #: 33515Key Holder ID: Sonya ScottQty: 3action: There are no more keys on hand for room 4127. Would like to have at least 3 on hand when we get down to 0.
FO-322724	7/22/2015	7/23/2015		New KeyNew Staff MemberKey #: 33571Key Holder ID: Sonya SocttQty: 3action: There are no more keys on hand for room 4341. Would like to have at least 3 on hand when we get down to 0.
FO-322726	7/22/2015	7/23/2015		New KeyNew Staff MemberKey #: A-66Key Holder ID: Karen WilsonQty: 5action: Please call when completed.
FO-322727	7/22/2015	7/27/2015		New KeyLost / StolenKey #: B-59Key Holder ID: Karen WilsonQty: 5action: Key for room number 2519 was not in the system. Key # 30693
FO-322728	7/22/2015	7/27/2015		New KeyLost / StolenKey #: A-68Key Holder ID: Karen WilsonQty: 5action: Key is for room 2558. The door was not in the system. Core
FO-322729	7/22/2015	7/27/2015		New KeyLost / StolenKey #: A-64Key Holder ID: Karen WilsonQty: 5action: Please call when ready for pick up.
FO-322730	7/22/2015	7/28/2015		New KeyLost / StolenKey #: A-108Key Holder ID: Karen WilsonQty: 5action: The door was not listed in the system. Key #30487 needed for door #3152 core # A-108.
FO-322732	7/22/2015	7/27/2015		New KeyNew Staff MemberKey #: A-125Key Holder ID: Karen WilsonQty: 5action: Please call when done.
FO-322794	7/23/2015	7/23/2015		New KeyNew Staff MemberKey #: Block KeyKey Holder ID: Patrick ShortelQty: 1action: Block key required for Lighting Retrofit Crew working in Life Science
FO-322795	7/23/2015	7/28/2015		New KeyNew Staff MemberKey #: Block KeyKey Holder ID: Sue and JayQty: Two (2)action: Lighting Retrofit Crew will be working in Science Hall installing new lights.
FO-322797	7/23/2015	7/28/2015		New KeyNew Staff MemberKey #: 3XKey Holder ID: Charlyce JacksonQty: 4action: We wish to order additional f office keys for the department main office front door. We have several new employees that need access.Account #: 127211
FO-322832	7/23/2015			New KeyNew Space AssignmentKey #: Key #14A28Key Holder ID: Brenca ContractorsQty: 1action: Please provide One key for roof access during construction.

WO	Recieved	Finished	Total	Request
FO-322848	7/24/2015			New KeyLost / StolenKey #: .50 and .49 Key Holder ID: Jessica Orzga and Donald Neal  Qty: 3 of each action: We will 3 coppies of key #84237 and #84235 created for the laboratory in room #133. I did not see this room in the drop down menu which
FO-322864	7/24/2015			New KeyNew Staff MemberKey #: 7AA/1J35Key Holder ID: Amanda HalinQty: 2action: Need keys for the chair room transition.
FO-322889	7/26/2015			Repair worn mortise lock core on engineer's office door, room 023 located in basement of Lande. Existing key is OE22. The door is very difficult to lock/unlock.
FO-322954	7/27/2015			New KeyLost / StolenKey #: X1027Key Holder ID: Dave BarnettQty: 1action: Needs key to dock gate.
FO-322955	7/27/2015			New KeyLost / StolenKey #: X2426, SMMP12, 73777Key Holder ID: Rosemary Foster  Qty: 5 eachaction: Keys are for entry to room 212 on the second floor of Skillman and the X2426 is the entry to the second floor suite.Account #: 444497
FO-323016	7/27/2015			New KeyLost / StolenKey #: 20678Key Holder ID: Lynnetta R SmithQty: 3action: Need additional theatre master keys
FO-323017	7/27/2015			New KeyLost / StolenKey #: 73012Key Holder ID: Lynnetta R SmithQty: 3action: Need additional dance master key
FO-323018	7/27/2015	7/30/2015		New KeyLost / StolenKey #: B462Key Holder ID: Lynnetta R SmithQty: 5action: Need additional keys for Hilberry Theatre
FO-323019	7/27/2015			New KeyLost / StolenKey #: MLKey Holder ID: LynnettaQty: 5action: Need additional ML padlock keys. Didn't see an option for padlocks under area.
FO-323020	7/27/2015	7/30/2015		New KeyLost / StolenKey #: X146Key Holder ID: Lynnetta R SmithQty: 5action: Hilberry interior doors
FO-323022	7/27/2015	7/29/2015		New KeyLost / StolenKey #: B444Key Holder ID: Lynnetta R SmithQty: 5action: Bonstelle Entry Door
FO-323023	7/27/2015	7/30/2015		New KeyLost / StolenKey #: 16908Key Holder ID: Lynnetta R SmithQty: 5action: Need additional keys for the booth. Not sure what the room number is.
FO-323024	7/27/2015	7/30/2015		New KeyLost / StolenKey #: 20713Key Holder ID: Lynnetta R SmithQty: 5action: Sound Lab key
FO-323025	7/27/2015	7/30/2015		New KeyLost / StolenKey #: 20717Key Holder ID: Lynnetta R SmithQty: 6action: Design Lab
FO-323026	7/27/2015			New KeyNew Staff MemberKey #: 30AD-18, 108049Key Holder ID: Aramark. Issued through Nick Board.Qty: 4action: Please make 4 keys to room 140, core 30AD-18.Account #: 227101
FO-323070	7/28/2015	7/29/2015		New KeyNew Space AssignmentKey #: 23285.10 thru 23285.24Key Holder ID: several nursing facultyQty: 15action: Need additional keys made- this room is a shared faculty space
FO-323122	7/28/2015			New KeyNew Staff MemberKey #: 37800Key Holder ID: LynnettaQty: 7action: Interior door
FO-323204	7/29/2015			New KeyNew Staff MemberKey #: UnknownKey Holder ID: David NjusQty: 4action: Please change entry door cores into Lab 2168 & 2178. Pleas include interior office doors 2178.1 & 2178.2. Five keys will be required.Account #: 164351
FO-323205	7/29/2015			New KeyNew Staff MemberKey #: Brown Box KeyKey Holder ID: Pat ShortelQty: 1action: Brown Box Key for Lighting retrofit Crew - New Building to Retrofit
FO-323206	7/29/2015			Core ChangeLost / StolenKey #: 1616EJ16 Key Holder ID: Eric JohnsonQty: 2 Cores, 4 Keysaction: 1- mailbox core1- room core4- keysAccount #: 228184
FO-323207	7/29/2015			Core ChangeLost / StolenKey #: 16EG5 Key Holder ID: Eric JohnsonQty: 2 Cores, 4 Keysaction: 1-mailbox core1-room core4- keysAccount #: 228184
FO-323333	7/29/2015			Core Change Lost / Stolen Key #: 16EG9 Key Holder ID: Eric Johnson Qty: 2 cores, 4 keys  action: 1-mailbox core 1-room core 4-keys Account #: 228184
FO-323208	7/29/2015			New KeyLost / StolenKey #: 16EF31 Key Holder ID: Eric JohnsonQty: 2 cores, 6 keysaction: 1-mailbox core1- room core6- keysAccount #: 228184

WO	Recieved	Finished	Total	Request
FO-323209	7/29/2015			Core ChangeLost / StolenKey #: 16ED9 Key Holder ID: Eric JohnsonQty: 2 cores, 6 keysaction: 1-mailbox core1-room core6-keysAccount #: 228184
FO-323334	7/29/2015			Core ChangeLost / StolenKey #: 16ED55 Key Holder ID: Eric JohnsonQty: 2 cores, 4 keysaction: 1-mailbox core1-room core4- keysAccount #: 228184
FO-323335	7/29/2015			Core ChangeLost / StolenKey #: 16EB14 Key Holder ID: Eric JohnsonQty: 2 cores, 4 keysaction: 1- mailbox core1-room core4-keysAccount #: 228184
FO-323214	7/29/2015			New KeyLost / StolenKey #: 16EB21 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323215	7/29/2015			New KeyLost / StolenKey #: 16ED53 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323216	7/29/2015			New KeyLost / StolenKey #: 16EG27 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323217	7/29/2015			New KeyLost / StolenKey #: 16EC3 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323218	7/29/2015			New KeyLost / StolenKey #: 16EC34 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323219	7/29/2015			New KeyLost / StolenKey #: 16EC44 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323220	7/29/2015			New KeyLost / StolenKey #: 16EC6 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323221	7/29/2015			New KeyLost / StolenKey #: 16ED23 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323222	7/29/2015			New KeyLost / StolenKey #: 16EE29 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323223	7/29/2015			New KeyLost / StolenKey #: 16EE34 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323224	7/29/2015			New KeyLost / StolenKey #: 16EE8 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323225	7/29/2015			New KeyLost / StolenKey #: 16EE19 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323226	7/29/2015			New KeyLost / StolenKey #: 16EE20 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323227	7/29/2015			New KeyLost / StolenKey #: 16EF39 Key Holder ID: Eric JohnsonQty: 1 key  action: 1 key madeAccount #: 228184
FO-323311	7/29/2015			New KeyLost / StolenKey #: 16EF43 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323312	7/29/2015			New KeyLost / StolenKey #: 16EF21 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323313	7/29/2015			New KeyLost / StolenKey #: 16EF45 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323314	7/29/2015			New KeyLost / StolenKey #: 16EF37 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323315	7/29/2015			New KeyLost / StolenKey #: 16EF12 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323316	7/29/2015			New KeyLost / StolenKey #: 16EH14 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323317	7/29/2015			New KeyLost / StolenKey #: 16EH39 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323318	7/29/2015			New KeyLost / StolenKey #: 16EH12 Key Holder ID: Eric JohnsonQty: 1 key  action: 1 key madeAccount #: 228184
FO-323321	7/29/2015			New KeyLost / StolenKey #: 16EH11 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323322	7/29/2015			New KeyLost / StolenKey #: 16EH6 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323323	7/29/2015			New KeyLost / StolenKey #: 16EH19 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184

WO	Recieved	Finished	Total	Request
FO-323319	7/29/2015			New KeyLost / StolenKey #: 16EH30 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323324	7/29/2015			New KeyLost / StolenKey #: 16EH16 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323325	7/29/2015			New KeyLost / StolenKey #: 16EJ21 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323320	7/29/2015			New KeyLost / StolenKey #: 16EJ8 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323326	7/29/2015			New KeyLost / StolenKey #: 16EK4 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323327	7/29/2015			New KeyLost / StolenKey #: 16EK16 Key Holder ID: Eric JohnsonQty: 1 keyaction: 1 key madeAccount #: 228184
FO-323328	7/29/2015			New KeyLost / StolenKey #: 16EL16 Key Holder ID: Eric JohnsonQty: 1 key  action: 1 key madeAccount #: 228184
FO-323329	7/29/2015			New KeyLost / StolenKey #: 16EL5 Key Holder ID: Eric JohnsonQty: 1 key action: 1 key madeAccount #: 228184
FO-323330	7/29/2015			New KeyLost / StolenKey #: 16EL12 Key Holder ID: Eric JohnsonQty: 2 keysaction: 2 keys madeAccount #: 228184
FO-323212	7/29/2015			New KeyNew Staff MemberKey #: D-24xKey Holder ID: Karen WilsonQty: 5action: Please call when ready to pick up. Thank you.
FO-323213	7/29/2015			New KeyLost / StolenKey #: A-101Key Holder ID: Karen WilsonQty: 5action: Please call when ready to pick up.
FO-323331	7/30/2015			ReplacementLost / StolenKey #: 209EKey Holder ID: Pam LetkowskiQty: 2action: HDN file cabinet key
FO-323332	7/30/2015			New KeyLost / StolenKey #: 128EKey Holder ID: Pam LetkowskiQty: 2action: HDN file cabinet key
<b>T - Painter</b>			<b>26</b>	
FO-320868	7/1/2015			HANDYMAN TIME ( JULY 2015 )
FO-320869	7/1/2015			HANDYMAN TO SCRAPE GLUE OFF REPLACEMENT TILES 1ST FLOOR BATHROOMS
FO-320993	7/6/2015	7/14/2015		Plaster repair & paint ceiling in woman's bathroom on 3rd floor.
FO-320995	7/6/2015			CLEAN & PAINT GRAFFITI OVER ENTIRE CAMPUS FOR THE MONTH OF JULY.
				CLEAN & PAINT GRAFFITI OVER THE ENTIRE CAMPUS.. FOR THE MONTH OF JULY.
FO-321248	7/7/2015			THERE ARE 2 SPOTS THAT NEED PLASTER REPAIR IN THE HILBERRY LOBBY ABOVE THE DOORS HANCOCK SIDE
FO-321287	7/7/2015	7/15/2015		Paint Consolidation.
FO-321481	7/10/2015	7/14/2015		SAFTEY TIME FOR THE MONTH OF JULY.
FO-321862	7/13/2015	7/21/2015		FIRE EXTINGUISHER: EQUIP #: [5890]: SENTRY 10LBS. ABC:FIRE; LOCATION: [01518]: INSIDE GREENHOUSE:005; 4TH FLR DISCREPANCY DETAILS: MISSING EXTINGUISHER (ORM/DISCREPANCY # 000817) SEE ATTACHMENT
FO-321863	7/13/2015	7/21/2015		FIRE EXTINGUISHER: EQUIP #: [3477]: GENERAL 20LBS. ABC:FIRE EXT:ABC; LOCATION: [3478]: IN RM 140:007-1ST FLR; RM 140 DISCREPANCY DETAILS: DISCREPANCY FOR 3477; CORRECTIVE ACTION: NEED RECHARGE (ORM/DISCREPANCY # 000819) SEE ATTACHMENT. REMOVE THE USED

WO	Recieved	Finished	Total	Request
FO-321987	7/14/2015	7/15/2015		R/R RM 00050/COMP LAB (SUMMER CAMP) INSIDE COMPUTER LAB MENS RR PLEASE REMOVE GRAPHIC GRAFFITTI INSIDE MENS RM POL INCIDENT REP #W151950067
FO-322068	7/15/2015	7/21/2015		R/R RM 150/SUPERVISORS' OFC NEED TWO BOXES OF COPY PAPER
FO-322613	7/21/2015	7/22/2015		Painters to paint the door & frame inside & out in room 2322 also paint the wall above the door. the wall is bone in color. also there is a lot of drywall dust on the block that needs to be cleaned from drywall repair. paint is located 3rd floor cage
FO-322643	7/22/2015	7/23/2015		Paint Exterior Railings Black on Eastside elevation.. Prime an Paint to finish.
FO-322697	7/22/2015			Patch, Sand, Prime & Paint all upper walls on the 2nd floor, of the entire corridor, north end.
FO-322831	7/24/2015	7/30/2015		HANDYMAN TO DELIVER 16 ADA CLOSERS TO IDN TO BE REBUILT
FO-322836	7/24/2015			Scrape, Prime & Paint all benches campus wide
FO-322837	7/24/2015			Scrape, Prime & Paint all steel, fan hoods, vent hoods,
FO-322852	7/24/2015			PAINTERS TO PAINT NEW INSTALLED ACCESS DOOR IN HALLWAY NEXT TO ROOM # 315, PLUS 7 EXISTING DOORS.
FO-322873	7/24/2015			Paint the exterior handrails on the east and west sides of the building.
FO-322874	7/24/2015			Paint the exterior rusty doors on the east side of the building.
FO-322918	7/27/2015			PAINTERS, PLEASE PATCH/PAINT DAMAGED DRYWALL IN WINDOW COVE.PRIORITY-LOW
FO-323112	7/28/2015	7/29/2015		PAINTER TO CLEAN MENS ROOM 1ST FLOOR
FO-323113	7/28/2015	7/29/2015		PAINTER TO CLEAN THE WOMENS 1ST FLOOR BATHROOM
FO-323124	7/29/2015	7/29/2015		Clean & Paint over Graffiti in women's & men's, Bathroom - 1st & 2nd floor.
FO-323172	7/29/2015			paint doors and frames and partitions in the Men's and Ladies room.
FO-323173	7/29/2015			Paint Exterior oval window frame next to main entrance.
<b>T - Pipefitter</b>			<b>47</b>	
FO-320892	7/1/2015	7/1/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....7-1-15
FO-320893	7/1/2015	7/1/2015		processing time for hot work permits.....CB.....7-1-15
FO-320996	7/3/2015	7/13/2015		please have pipefitters R/R PH repair union on safety valve drain line leaking on penthouse floor,,,,,,,,,,,,,,,,,,,,, EA/7-9-15 ,,,,,,,,,,,,,,
FO-321347	7/8/2015	7/17/2015		Steamfitters- Low priority Please install air vents on chiller #1 and #2, See Engineer for details,,,,,,,,,,,,,,,,,,,,, EA/7-9-15 ,,,,,,,,,,,,,,,,,,,,,
FO-321478	7/9/2015	7/9/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....7-9-15
FO-321479	7/9/2015	7/9/2015		get bills of lading and post notifications for Friday's abatement job's.....CB.....7-9-15
FO-321551	7/9/2015	7/9/2015		Fork Lift Training ,,,,,,,,,,,,,, EA/7-9-15 ,,,,,,,,,,,,,,
FO-321541	7/10/2015	7/10/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....7-10-15
FO-321542	7/10/2015	7/10/2015		get access supervise and follow up 2 abatement jobs.....CB.....7-10-15
FO-321543	7/10/2015	7/10/2015		investigate 9 abatement jobs on campus.....7-10-15
FO-321544	7/10/2015	7/10/2015		processing time for hot work permit for contractor.....CB.....78-10-15
FO-321853	7/13/2015	7/13/2015		Shop Time to clean / organize ,,,,,,,,,,,,,, ME/7-13-15 ,,,,,,,,,,,,,,
FO-321877	7/14/2015			Relocate blowdown tank from penthouse to mechanical room 100 in basement. See John Towle for detail ,,,,,,,,,,,,,, JH/ 7-13-15
FO-321893	7/14/2015	7/16/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #2 FFC UNIT. PRIORITY-LOW..... ME/7-14-15 ,,,,,,,,,,,,,,
FO-321900	7/14/2015	7/16/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #1 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, ME/7-14-15
FO-321974	7/14/2015	7/14/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....7-14-15.....
FO-321977	7/14/2015	7/14/2015		site visit with OEHS rep. to sample some material so it can be checked for asbestos....CB.....7-14-15
FO-321993	7/14/2015	7/16/2015		Install hangers on stainless condensate return 3rd floor hall ,,,,,,,,,,,,,, JH/7-14-15 ,,,,,,,,,,,,,,
FO-321996	7/14/2015	7/17/2015		R/R leaking flanged 3/way valve in basement mechanical room . See Corey Blair for location ,,,,,,,,,,,,, ME/7-14-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-322044	7/15/2015			Pipe fitters: please repair steam leaks on 3 flanges on steam main line to PRVs. Priority: low.....EA...7/15/15
FO-322163	7/16/2015	7/16/2015		processing time for paperwork, e-mails, phone calls, etc...../..CB.....7-16-15
FO-322164	7/16/2015	7/16/2015		take contractor to quote some insulation jobs.....CB.....7-16-15
FO-322090	7/16/2015	7/16/2015		Repair leak in northeast corner of lab near radiant panels. End user notes ceiling tiles have been.....JH.....7/16/15 replaced multiple times, but leak still exists.
FO-322148	7/16/2015			(**) PO REQ DK 7/3 Fitter repair leaking hot water heater #2 3rd floor mechanical room ..... ME/7-22-15 .....
FO-322196	7/17/2015	7/20/2015		steam fitters- low priority- repair leaking steam trap on unit heater in penthouse mechanical room.....JH.....7/17/15
FO-322543	7/21/2015	7/22/2015		FITTERS , PLEASE REPLACE LEAKING HWH CONTROL VALVE ON # 2 FFC UNIT. PRIORITY-LOW.....JH.....7/21/15
FO-322563	7/21/2015	7/21/2015		processing time for paperwork, e-mails, phone calls, etc.....CB....7-21-15
FO-322565	7/21/2015	7/21/2015		look at some asbestos jobs at some buildings on campus.....CB.....7-21-15
FO-322636	7/22/2015	7/22/2015		Repair broken bumper on south side of loading dock ..... EA/7-22-15 .....
FO-322704	7/22/2015	7/24/2015		steamfitters- low priority- R/R RM 3237/MECH RM repair replace leaking steampipe to unit heater #3..... ME/7-22-15 .....
FO-322813	7/23/2015	7/23/2015		processing time for paperwork, e-mails, phone calls, etc.....CB...7-23-15
FO-322845	7/24/2015	7/24/2015		Clear drain on drain pan for AH#3 in mechanical room 3237 ..... EA/7-24-15 .....
FO-322853	7/24/2015	7/27/2015		PIPEFITTERS TO REPAIR VERTICAL RAILS ON HANDRAIL AT THE BASE A PIECE OF SQUARE STOCK NEEDS TO BE WELDED IN PLACE WEST SIDE ( SEE BILL MCDONALD FOR LOCATION ) .....JH/7-27-15 .....
FO-322879	7/24/2015			(**) PO REQ DK 7/30 Install wilo recirculation pump in basement mechanical room ..... JH /7-24-15 .....
FO-322916	7/27/2015	7/27/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #2 FFC UNIT. PRIORITY-LOW ..... EA/7-27-15 .....
FO-322948	7/27/2015	7/28/2015		To pipefitters. Cooling coil and chilled water lines to and from AHU-1 are plugged and restricting flow. Unable to maintain temps in building. Please flush and replace coil and lines as needed..... JH/7-27-15 .....
FO-322957	7/27/2015	7/27/2015		Install blow down valve off strainer for SF-9 mechanical room 25 ..... ME/7-27-15 .....
FO-322966	7/27/2015	7/28/2015		FITTERS, R/R SUB B/MECH RM PLEASE REPLACE LEAK @ AIR VENT ON HWH LINE. PRIORITY-LOW ..... ME/7-27-15 .....
FO-322967	7/27/2015			Fitters, R/R PENTHOUSE please repair/replace pre-heat valve on AHU-4. Valve leaks thru (controls & diaphragm are good). ..... EA/7-27-15 .....
FO-322963	7/27/2015	7/27/2015		Install strainer blowdown valve for SF-7 mechanical room 25 ..... ME/ 7-27-15 .....
FO-322964	7/27/2015	7/27/2015		Install valves on strainers for SF-2 mechanical room 25 ..... ME/7-27-15 .....
FO-323107	7/28/2015	7/28/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....7-28-15
FO-323110	7/28/2015	7/28/2015		met with Bill Kemp, to go over impact on fire and safety regulations for closing down stairwell D.....CB.....7-28-15
FO-323111	7/28/2015	7/28/2015		finish chasing down required signateures for impact report for this Thursdays job.....CB.....7-28-15
FO-323287	7/30/2015	7/30/2015		processing time for paperwork, e-mails, phone calls, etc.....CB....7-30-15
FO-323288	7/30/2015	7/30/2015		post all notifications in 4 buildings for upcoming abatement job's.....CB.....7-30-15
FO-323289	7/30/2015	7/30/2015		pick up bills of lading for abatement jobs and discuss possible mold remediation at Old Main building.....CB.....7-30-15
<b>T - Plumber</b>			<b>46</b>	
FO-320938	7/1/2015	7/20/2015		ADDING PLUMBERS: R/R PAINT SHOP SINKS PLEASE CK IF ANY DRAINS ARE LEAKING INTO SVC CTR/CK CLNG IN THE SVC CTR R/R RM 150 IN BTWN LORETTA'S & LARRY'S DESK AGAINST WALL CLNG TILES ARE WET DO BELIEVE FLR IN PAINT SHOP GETS WET FROM VEHICLES THAT ARE PARK



WO	Recieved	Finished	Total	Request
FO-320958	7/2/2015	7/31/2015		Administrative Time for JULY 2015
FO-320985	7/2/2015	7/7/2015		R/R RM 113/WOMENS RR 1ST SINK NEED TO REPAIR BOTH HOT/COLD FAUCET KNOBS FAUCET KEEPS DRIPPING ,,,,,,,,,, MM/7-2-15 ,,,,,,,,,
FO-321454	7/2/2015	7/2/2015		Check on leak in island outside behind building ,,,,,,,,,, GS/7-2-15 ,,,,,,,,,
FO-321066	7/6/2015	7/13/2015		Men Restroom (1st stall): Water keeps rising up to the top of the basin after each flush // Custodian plunged a good 4/5 times however the water kept flowing up to the very top of basin. I am concerned about a possible overflow onto the floor area. Can y
FO-321265	7/7/2015	7/20/2015		WOMEN'S RESTROOM 1ST FLOOR IN THE 3RD STALL THE TOILET SEAT NEED TO BE REPLACED. THE SEAT IS STAINED.,,,,,,,,,, MP/7-9-15 ,,,,,,,,,
FO-321293	7/7/2015	7/14/2015		Repair urinal in men's restroom. Bob Ostrowski has specs. Thank You. Bob Ostrowski ,,,,,,,,,, GS/7-9-15 ,,,,,,,,,
FO-321370	7/8/2015	7/10/2015		Rm. 5211 - Garbage disposal needs repair ,,,,,,,,,, MM/7-9-15 ,,,,,,,,,
FO-321411	7/9/2015	7/27/2015		R/R RM 3040 Water is leaking from the trap of the first left sink in 3040 Sci. Hall. There is a paper attached to the sink.,,,,,,,,,, MP/7-9-15 ,,,,,,,,,
FO-321415	7/9/2015			Replace water pressure regulators on both domestic water booster pumps. Rebuilding existing did not work, ,,,,,,,,,, DB/7-9-15.,,,,,,,,,
FO-321416	7/9/2015	7/10/2015		R/R 2nd floor ladies restroom, the disability stall's toilet handle is broken and needs repair.,,,,,,,,,, MM/7-9-15 ,,,,,,,,,
FO-321417	7/9/2015	7/30/2015		R/R LOADING DOCK Flooded from the rain - needs to be pumped out.,,,,,,,,,, MM/7-9-15 ,,,,,,,,,
FO-321419	7/9/2015	7/13/2015		R/R RM 00105/MENS LOCKER RM men's shower is not working in men's locker room ,,,,,,,,, MM/7-9-15 ,,,,,,,,,
FO-321421	7/9/2015	7/22/2015		Replace molded ceiling tile in hallway outside of room. Check for possible leak. 0225.01 ,,,,,,,,, *MM/JH/ 7-9-15 ,,,,,,,,,
FO-321456	7/9/2015			Cinder block is wet from ceiling to floor at the entrance of the department. Not sure if this is condensation or a pipe that is leaking. Around the corner of the wall (approximately 18 inches) a leak was reported on May 29. This has never been addressed
FO-321890	7/13/2015	7/17/2015		Middle sink in women's staff bathroom on 1st flr is leaking at bottom of pipe.,,,,,,,,,, MM/7-14-15 ,,,,,,,,,
FO-322020	7/15/2015	7/16/2015		1ST FLOOR MEN'S RESTROOM THE SINK LEAK WATER FROM THE ELBOW. PLEASE REPAIR.,,,,,,,,,, MM/7-15-15 ,,,,,,,,,
FO-322197	7/15/2015	7/23/2015		In room 057 the slop sink is slowly draining and needs to be snaked.,,,,,,
FO-322056	7/15/2015			Check drain line on 2nd floor master bathroom. Leak showing up in ceiling of front room.....DB.....7/15/15
FO-322083	7/16/2015	7/22/2015		R&R lav faucet on Women's 2nd FI bathroom Left faucet does not work.....GS.....7/16/15.
FO-322091	7/16/2015	7/16/2015		**DUPLICATE REFER TO FO#307771 JWT  Replace sink in Lab 340.3 that was previously removed by WSU trades for repairs. Match existing.....DB.....7/16/15 lab finishes.
FO-322116	7/16/2015	7/20/2015		PLUMBERS, PLEASE CLEAR FLOOR DRAIN IN OUTSIDE AIR INTAKE AREA. PRIORITY-LOW.....MM.....7/16/15
FO-322117	7/16/2015	7/20/2015		R/R RM 456/men's rr -fix right side sink-water does not run-.....MP....7/16/15
FO-322118	7/16/2015	7/21/2015		R/R RM 456/men's rr fix urinal-part fell off tank thank you.....GS....7/16/15
FO-322634	7/21/2015			Men's bathroom, #309 3rd floor, has several urinals out of service
FO-322629	7/21/2015			(**) PO REQ DK 7/30 Basement Women Restroom (East facing Cass Ave.): Water is continuously dripping from the faucets at the 1st two connected sinks. Washers may be needed. Thanks ,,,,,,,,,, MM/7-22-15 ,,,,,,,,,
FO-322635	7/21/2015			First floor men's bathroom, #109, has been completely out of service for several weeks
FO-322637	7/21/2015			First floor men's bathroom, #102, has been completely out of service for several weeks
FO-322638	7/21/2015			First floor women's bathroom, #102, has been completely out of service for several weeks

WO	Recieved	Finished	Total	Request
FO-322703	7/22/2015	7/24/2015		*REFER TO FO#322845  plumbers- low- R/R RM 3237/MECH RM replace plugged drainline on fan#3 with serviceable drainline. Please see engineer for details.,,,,,,,,,,,,,, MM/7-23-15 ,,,,,,,,,,,,,,
FO-322711	7/22/2015	7/23/2015		In the 2nd floor men's restroom, the 1st urinal takes a long time to flush.,,,,,,,,,,,,,, MM/7-23-15 ,,,,,,,,,,,,,,
FO-322790	7/23/2015			Trade: Plumber Priority: Low Sink is draining slowly 1st floor men's rest room in EDC.,,,,,,,,,,,,,, GS/7-27-15 ,,,,,,,,,,,,,,
FO-322800	7/23/2015			Reinsulate pipe repair on description below:  repair water leak on domestic water line to 4th floor restrooms, the leak is boiler room. Priority: med. ,,,,,,,,,,,,,, GS/7-23-15 ,,,,,,,,,,,,,,
FO-322801	7/23/2015			please repair/replace zurn optyc faucet in room 419.....GS/7-23-15 ,,,,,,,,,,,,,,
FO-322804	7/23/2015			please repair/replace 4 leaking faucets in womens staff restroom romm 233..... GS/7-23-15 ,,,,,,,,,,,,,
FO-322821	7/23/2015	7/28/2015		R/R RM 4117 ONE OF THE SINKS IN LAB HAS A LEAKY FAUCET ,,,,,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,,,,
FO-322822	7/23/2015	7/28/2015		R/R RM 4259 ONE OF THE SINKS IN LAB HAS A LEAKY FAUCET ,,,,,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,,,,
FO-322933	7/27/2015	7/29/2015		R/R RM 133 We have a leaky faucet (in the room to your far right when walking into the lab) that needs to be fixed. When the water is running the pipe below the sink leaks into the cabinet. Thank you! ,,,,,,,,,,,,,, MM/7-27-15 ,,,,,,,,,,,,,,
FO-322989	7/27/2015	7/27/2015		**REFER TO FO#323064  Water coming from out the basement area (Restaurant storage unit) nearest Sector 9 Supervisor Office # 130. Custodian extracted the water up only to see that 45 minutes later; a lot of / more water was present right outside Superv
FO-323080	7/28/2015	7/29/2015		1ST FLOOR WOMEN'S RESTROOM THE DOOR IS LOCKED AND THE TOILET IS CLOGGED. THIS IS THE 4TH STALL. PLEASE UNCLOG. ,,,,,,,,,,,,,, MM/7-28-15 ,,,,,,,,,,,,,,
FO-323087	7/28/2015			Hilti: To provide quote for coring machine part to adapt a 12" core bit Needed for floor drain projects ,,,,,,,,,,,,,, DB/7-28-15 ,,,,,,,,,,,,,,
FO-323093	7/28/2015	7/31/2015		R/R 2ND FLR HALLWAY NEXT TO ROOM 254 MANOOGIAN Replace filter on water bottle filling station. Filter is now on red. For correct filter info, see FPM archive documents for Manoogian 2nd floor renovation. ,,,,,,,,,,,,, DB/7-28-15 ,,,,,,,,,,,,,,
FO-323094	7/28/2015	7/31/2015		R/R 2ND FLR HALLWAY ACROSS FROM ROOM 205 MANOOGIAN Replace filter on water bottle filling station. Filter is now on red. For correct filter info, see FPM archive documents for Manoogian 2nd floor renovation. ,,,,,,,,,,,,, DB/7-28-15 ,,,,,,,,,,,,,,
FO-323114	7/28/2015			Install new sump pump rm 179 that has been received from FO#298137 ,,,,,,,,,,,,,, DB/7-28-15 ,,,,,,,,,,,,,,
FO-323135	7/29/2015	7/30/2015		R/R 1st floor ladies restroom has two toilets bagged and out of service (stopped up). Please fix as soon as possible as odors are emitting from them.,,,,,,,,,,,,,, MM/7-29-15 ,,,,,,,,,,,,,,
FO-323175	7/29/2015			HECKLER HSE/5510 WOODWARD R/R 2ND FLR MRS. J. WILSON STE HER PERSONAL RR NEEDS A NEW TOILET SEAT ,,,,,,,,,,,,, GS/7-29-15 ,,,,,,,,,,,,,,
<b>Routine</b>			<b>7</b>	
<b>T - Electrician</b>			<b>7</b>	
FO-320875	7/1/2015			PS#1 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320876	7/1/2015			PS#2 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320878	7/1/2015			PS#3 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320879	7/1/2015			PS#4 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320880	7/1/2015			PS#5 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320882	7/1/2015			PS#6 Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15
FO-320883	7/1/2015			Various Campus Lots Electrician Monthly ROUTINE CHECK for 7/1 THRU 7/31/15

WO	Recieved	Finished	Total	Request
<b>Scheduled Maint. (PM)</b>			<b>579</b>	
<b>Engineering</b>			<b>538</b>	
<b>Routine</b>			<b>538</b>	
<b>E - Auxiliary</b>			<b>43</b>	
FO-319685	7/1/2015			PM - Air Handling Unit
FO-319686	7/1/2015			PM - Air Handling Unit
FO-319687	7/1/2015			PM - Air Handling Unit
FO-319688	7/1/2015			PM - Air Handling Unit
FO-319689	7/1/2015			PM - Air Handling Unit
FO-319690	7/1/2015			PM - Sump Pump
FO-319691	7/1/2015			PM - Sump Pump
FO-319692	7/1/2015			PM - Sump Pump
FO-319693	7/1/2015			PM - Sump Pump
FO-319755	7/1/2015			PM - Air Handling Unit
FO-319756	7/1/2015			PM - Air Handling Unit
FO-319757	7/1/2015			PM - Air Handling Unit
FO-319758	7/1/2015			PM - Air Handling Unit
FO-319759	7/1/2015			PM - Air Handling Unit
FO-319760	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319761	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319763	7/1/2015			PM - Water Booster Pump
FO-319764	7/1/2015			PM - Water Booster Pump
FO-319765	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319772	7/1/2015			PM - Water Booster Pump
FO-319773	7/1/2015			PM - Water Booster Pump
FO-319774	7/1/2015			PM - Water Booster Pump
FO-319775	7/1/2015			PM - Condensate Return Pump
FO-319776	7/1/2015			PM - Condensate Return Pump
FO-319821	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319838	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319842	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-319843	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-319844	7/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-319845	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-319846	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-319767	7/6/2015	7/10/2015		PM - Emergency Shower/Eyewash Station
FO-319768	7/13/2015	7/17/2015		PM - Emergency Shower/Eyewash Station
FO-319749	7/14/2015			Generator Maintenance, Monthly
FO-319750	7/15/2015			Generator Maintenance, Monthly
FO-319754	7/15/2015			Generator Maintenance, Monthly
FO-319769	7/20/2015	7/24/2015		PM - Emergency Shower/Eyewash Station
FO-319770	7/27/2015	7/31/2015		PM - Emergency Shower/Eyewash Station
FO-319739	7/28/2015			Generator Maintenance, Monthly
FO-319740	7/28/2015			Generator Maintenance, Monthly
FO-319741	7/28/2015			Generator Maintenance, Monthly
FO-319742	7/28/2015			Generator Maintenance, Monthly
FO-319743	7/28/2015			Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
<b>E - MedPharm</b>			<b>33</b>	
FO-319608	7/1/2015			PM - Domestic Water Heater, Steam
FO-319609	7/1/2015			PM - Domestic Water Heater, Steam
FO-319610	7/1/2015			PM - Domestic Water Heater, Steam
FO-319611	7/1/2015			PM - Sump Pump
FO-319627	7/1/2015	7/20/2015		PM - Water Softener
FO-319698	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319700	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319701	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319702	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319703	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319704	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319705	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319706	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319707	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319708	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319709	7/1/2015			PM - Emergency Shower/Eyewash Station
FO-319795	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319796	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319797	7/1/2015	7/9/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319831	7/1/2015	7/9/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319832	7/1/2015	7/9/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319833	7/1/2015	7/6/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319834	7/1/2015	7/6/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319835	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319836	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319837	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319841	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319699	7/10/2015			PM - Emergency Shower/Eyewash Station
FO-319747	7/10/2015			Generator Maintenance, Monthly
FO-319748	7/10/2015			Generator Maintenance, Monthly
FO-319784	7/21/2015	7/28/2015		Generator Maintenance, Monthly
FO-319737	7/24/2015			Generator Maintenance, Monthly
FO-319738	7/24/2015			Generator Maintenance, Monthly
<b>E - North</b>			<b>39</b>	
FO-319599	7/1/2015	6/23/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319600	7/1/2015	6/23/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319603	7/1/2015	7/22/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319604	7/1/2015	7/2/2015		PM - Heat Exchanger and Economizer
FO-319605	7/1/2015	7/2/2015		PM - Heat Exchanger and Economizer
FO-319614	7/1/2015	6/30/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319615	7/1/2015	6/30/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319620	7/1/2015	6/19/2015		PM - Domestic Water Heater, Electric
FO-319621	7/1/2015	6/19/2015		PM - Domestic Water Heater, Electric
FO-319631	7/1/2015	6/24/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319632	7/1/2015	7/22/2015		PM - Air Compressor, Reciprocating 5-40 H.P.

WO	Recieved	Finished	Total	Request
FO-319633	7/1/2015	7/22/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319648	7/1/2015	7/1/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319649	7/1/2015	7/15/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319650	7/1/2015	7/15/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319655	7/1/2015	7/22/2015		PM - Drinking Fountain and Water Cooler
FO-319729	7/1/2015	7/7/2015		PM - Harmsco Side Stream Filter
FO-319730	7/1/2015	7/21/2015		PM - Harmsco Side Stream Filter
FO-319778	7/1/2015	6/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319779	7/1/2015	6/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319783	7/1/2015	6/22/2015		Vendor or Contractor Work
FO-319802	7/1/2015	6/29/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319803	7/1/2015	6/29/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319807	7/1/2015	6/29/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319808	7/1/2015	6/18/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319809	7/1/2015	6/18/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319810	7/1/2015	6/18/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319811	7/1/2015	6/30/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319812	7/1/2015	6/30/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319813	7/1/2015	7/8/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319814	7/1/2015	7/8/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319815	7/1/2015	7/8/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319820	7/1/2015	6/9/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319785	7/10/2015	7/10/2015		Generator Maintenance, Monthly
FO-319651	7/18/2015	7/2/2015		PM - Condensate Return Pump
FO-319652	7/18/2015	7/2/2015		PM - Condensate Return Pump
FO-319653	7/18/2015	7/6/2015		PM - Condensate Return Pump
FO-319654	7/18/2015	7/6/2015		PM - Condensate Return Pump
FO-319746	7/22/2015	7/22/2015		Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>47</b>	
FO-319622	7/1/2015	7/13/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319623	7/1/2015	7/15/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319658	7/1/2015	7/17/2015		PM - Water/Air Cooled Condenser
FO-319659	7/1/2015	7/13/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319660	7/1/2015	7/21/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319661	7/1/2015	7/21/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319662	7/1/2015	7/21/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319663	7/1/2015	7/21/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319665	7/1/2015	7/8/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319668	7/1/2015			PM - Water/Air Cooled Condenser
FO-319669	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser

WO	Recieved	Finished	Total	Request
FO-319670	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319671	7/1/2015	6/26/2015		PM - Water/Air Cooled Condenser
FO-319672	7/1/2015			PM - Water/Air Cooled Condenser
FO-319673	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319674	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319675	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319676	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319677	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319678	7/1/2015	7/21/2015		PM - Water/Air Cooled Condenser
FO-319679	7/1/2015	7/17/2015		PM - Water/Air Cooled Condenser
FO-319680	7/1/2015	7/17/2015		PM - Water/Air Cooled Condenser
FO-319681	7/1/2015	7/17/2015		PM - Water/Air Cooled Condenser
FO-319682	7/1/2015	7/1/2015		PM - Water/Air Cooled Condenser
FO-319683	7/1/2015	7/1/2015		PM - Water/Air Cooled Condenser
FO-319684	7/1/2015	7/13/2015		PM - Water/Air Cooled Condenser
FO-319728	7/1/2015	6/22/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319799	7/1/2015	7/13/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319805	7/1/2015	7/28/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319806	7/1/2015	7/28/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319840	7/1/2015	7/16/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll& Absorber Chillers
FO-319868	7/1/2015	7/13/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-320524	7/1/2015	7/8/2015		Clean condenser coils
FO-320525	7/1/2015	7/8/2015		Clean condenser coils
FO-320526	7/1/2015	7/13/2015		Clean condenser coils
FO-319786	7/3/2015	7/13/2015		Generator Maintenance, Monthly
FO-319790	7/3/2015	7/13/2015		Generator Maintenance, Monthly
FO-319791	7/3/2015	7/13/2015		Generator Maintenance, Monthly
FO-319792	7/3/2015	7/13/2015		Generator Maintenance, Monthly
FO-319762	7/7/2015	7/13/2015		PM - Semi Anunal Air Handling Unit Inspection
FO-319788	7/8/2015	6/22/2015		Generator Maintenance, Monthly
FO-319664	7/15/2015	7/8/2015		PM - Heat Exchanger and Economizer
FO-319771	7/16/2015	6/16/2015		Generator Maintenance, Monthly
FO-319751	7/21/2015	7/21/2015		Generator Maintenance, Monthly
FO-319736	7/22/2015	7/22/2015		Generator Maintenance, Monthly
FO-319869	7/23/2015	7/23/2015		Generator Maintenance, Monthly
FO-319870	7/23/2015	7/23/2015		Generator Maintenance, Monthly
<b>E - Preventative Maintenance</b>			<b>207</b>	
FO-318502	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318503	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318504	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318505	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318506	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318507	7/1/2015	7/31/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318508	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318509	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan



WO	Recieved	Finished	Total	Request
FO-318605	7/1/2015	7/15/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318606	7/1/2015	7/15/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318607	7/1/2015	7/15/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318608	7/1/2015	7/15/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318609	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318610	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318611	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318612	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318613	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318614	7/1/2015	7/16/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318615	7/1/2015	7/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318616	7/1/2015	7/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318617	7/1/2015	7/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318618	7/1/2015	7/31/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318619	7/1/2015	7/31/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318620	7/1/2015	7/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318621	7/1/2015	7/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318622	7/1/2015	7/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318623	7/1/2015	7/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318624	7/1/2015	7/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318625	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318626	7/1/2015	7/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318627	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318628	7/1/2015	7/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318629	7/1/2015	7/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318630	7/1/2015	7/10/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318631	7/1/2015	7/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318632	7/1/2015	7/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318633	7/1/2015	7/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318634	7/1/2015	7/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318635	7/1/2015	7/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318636	7/1/2015	7/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318637	7/1/2015	7/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318638	7/1/2015	7/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318639	7/1/2015	7/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318640	7/1/2015	7/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318641	7/1/2015	7/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318642	7/1/2015	7/18/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318643	7/1/2015	7/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318644	7/1/2015	7/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318645	7/1/2015	7/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318646	7/1/2015	7/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318647	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318648	7/1/2015	7/18/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318649	7/1/2015	7/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318650	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318651	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test



WO	Recieved	Finished	Total	Request
FO-318652	7/1/2015	7/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318653	7/1/2015	7/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318654	7/1/2015	7/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318655	7/1/2015	7/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318656	7/1/2015	7/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318657	7/1/2015	7/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318658	7/1/2015	7/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318659	7/1/2015	7/18/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318660	7/1/2015	7/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318661	7/1/2015	7/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318662	7/1/2015	7/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318663	7/1/2015	7/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318664	7/1/2015	7/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318665	7/1/2015	7/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318666	7/1/2015	7/29/2015		Replace PRE-filters
FO-318667	7/1/2015	7/29/2015		Replace PRE-filters
FO-318668	7/1/2015	7/17/2015		Replace PRE-filters
FO-318669	7/1/2015	7/17/2015		Replace PRE-filters
FO-318670	7/1/2015	7/17/2015		Replace PRE-filters
FO-318671	7/1/2015	7/30/2015		Replace PRE-filters
FO-318672	7/1/2015	7/30/2015		Replace PRE-filters
FO-318673	7/1/2015	7/30/2015		Replace PRE-filters
FO-318674	7/1/2015	7/30/2015		Replace PRE-filters
FO-318675	7/1/2015	7/30/2015		Replace PRE-filters
FO-318676	7/1/2015	7/30/2015		Replace PRE-filters
FO-318677	7/1/2015	7/30/2015		Replace PRE-filters
FO-318678	7/1/2015	7/30/2015		Replace PRE-filters
FO-318679	7/1/2015	7/7/2015		Replace PRE-filters
FO-318680	7/1/2015	7/27/2015		Replace PRE-filters
FO-318681	7/1/2015	7/13/2015		Replace PRE-filters
FO-318682	7/1/2015	7/13/2015		Replace PRE-filters
FO-318683	7/1/2015	7/14/2015		Replace PRE-filters
FO-318684	7/1/2015	7/14/2015		Replace PRE-filters
FO-318685	7/1/2015	7/15/2015		Replace PRE-filters
FO-318686	7/1/2015	7/27/2015		Replace PRE-filters
FO-318687	7/1/2015	7/30/2015		Replace PRE-filters
FO-318688	7/1/2015	7/28/2015		Replace PRE-filters
FO-318689	7/1/2015	7/28/2015		Replace PRE-filters
FO-318690	7/1/2015	7/28/2015		Replace PRE-filters
FO-318691	7/1/2015	7/28/2015		Replace PRE-filters
FO-318692	7/1/2015	7/30/2015		Replace PRE-filters
FO-318693	7/1/2015			Replace PRE-filters
FO-318694	7/1/2015			Replace PRE-filters
FO-318695	7/1/2015			Replace PRE-filters
FO-318696	7/1/2015			Replace PRE-filters
FO-318697	7/1/2015	7/30/2015		Replace PRE-filters
FO-318698	7/1/2015	7/30/2015		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-318699	7/1/2015	7/30/2015		Replace PRE-filters
FO-318700	7/1/2015	7/30/2015		Replace PRE-filters
FO-318701	7/1/2015	7/30/2015		Replace PRE-filters
FO-318702	7/1/2015	7/30/2015		Replace PRE-filters
FO-318703	7/1/2015	7/30/2015		Replace PRE-filters
FO-318704	7/1/2015	7/30/2015		Replace PRE-filters
FO-318705	7/1/2015	7/31/2015		Replace PRE-filters
FO-318706	7/1/2015	7/30/2015		Replace PRE-filters
FO-318707	7/1/2015	7/31/2015		Replace PRE-filters
FO-318708	7/1/2015	7/30/2015		Replace PRE-filters
FO-318709	7/1/2015	7/24/2015		Replace PRE-filters
FO-318710	7/1/2015	7/23/2015		Replace PRE-filters
FO-318711	7/1/2015	7/24/2015		Replace PRE-filters
FO-318712	7/1/2015	7/24/2015		Replace PRE-filters
FO-318713	7/1/2015	7/23/2015		Replace PRE-filters
FO-318714	7/1/2015	7/23/2015		Replace PRE-filters
FO-318715	7/1/2015	7/23/2015		Replace PRE-filters
FO-318716	7/1/2015	7/23/2015		Replace PRE-filters
FO-318717	7/1/2015	7/24/2015		Replace PRE-filters
FO-318718	7/1/2015	7/24/2015		Replace PRE-filters
FO-318719	7/1/2015	7/29/2015		Replace PRE-filters
FO-318720	7/1/2015	7/24/2015		Replace PRE-filters
FO-318721	7/1/2015	7/24/2015		Replace PRE-filters
FO-318722	7/1/2015	7/24/2015		Replace PRE-filters
FO-318723	7/1/2015	7/24/2015		Replace PRE-filters
FO-318724	7/1/2015			Replace PRE-filters
FO-318725	7/1/2015			Replace PRE-filters
FO-318726	7/1/2015			Replace PRE-filters
FO-318727	7/1/2015			Replace PRE-filters
FO-318728	7/1/2015	7/22/2015		Replace PRE-filters
FO-318729	7/1/2015	7/22/2015		Replace PRE-filters
FO-318730	7/1/2015	8/1/2015		Replace PRE-filters
FO-318731	7/1/2015	7/31/2015		Replace PRE-filters
FO-318732	7/1/2015	7/31/2015		Replace PRE-filters
FO-318733	7/1/2015	7/29/2015		Replace PRE-filters
FO-318734	7/1/2015	7/7/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318735	7/1/2015	7/7/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318736	7/1/2015	7/6/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318737	7/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-318738	7/1/2015	7/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318746	7/1/2015	7/24/2015		Replace PRE-filters
FO-318747	7/1/2015	7/24/2015		Replace PRE-filters
FO-318748	7/1/2015	7/24/2015		Replace PRE-filters
FO-318749	7/1/2015	7/31/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-318750	7/1/2015	8/1/2015		Replace PRE-filters
FO-316355	7/1/2015	6/26/2015		Replace PRE-filters
FO-316356	7/1/2015	7/3/2015		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-316357	7/1/2015	7/14/2015		Replace PRE-filters
FO-316358	7/1/2015	7/14/2015		Replace PRE-filters
FO-316359	7/1/2015	7/7/2015		Replace PRE-filters
FO-316360	7/1/2015	7/10/2015		Replace PRE-filters
FO-316361	7/1/2015	7/25/2015		Replace PRE-filters
FO-316362	7/1/2015	7/13/2015		Replace PRE-filters
FO-316363	7/1/2015	7/14/2015		Replace PRE-filters
FO-316364	7/1/2015	7/15/2015		Replace PRE-filters
FO-316365	7/1/2015	7/8/2015		Replace PRE-filters
FO-316426	7/1/2015	7/18/2015		Replace PRE-filters
FO-316425	7/1/2015	7/31/2015		Replace PRE-filters
<b>E - South</b>			<b>36</b>	
FO-319601	7/1/2015	7/27/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319602	7/1/2015	7/28/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319613	7/1/2015	7/28/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319624	7/1/2015	7/6/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319625	7/1/2015	7/6/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319626	7/1/2015	7/6/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319635	7/1/2015	7/22/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319636	7/1/2015	7/22/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319637	7/1/2015	7/22/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319638	7/1/2015	7/22/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319639	7/1/2015	7/24/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319640	7/1/2015	7/24/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319641	7/1/2015	7/24/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319642	7/1/2015	7/24/2015		PM - Centrifugal Pump, over 1 H.P.
FO-319731	7/1/2015	7/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319780	7/1/2015	7/23/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319782	7/1/2015	7/22/2015		PM - Harmsco Side Stream Filter
FO-319804	7/1/2015	7/6/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319816	7/1/2015	7/31/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319817	7/1/2015	7/17/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319822	7/1/2015	7/17/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319823	7/1/2015	7/15/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319824	7/1/2015	7/22/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319825	7/1/2015	7/3/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319826	7/1/2015	6/24/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319827	7/1/2015	6/24/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319667	7/8/2015	7/17/2015		PM - Monthly AHU Inspection Clean Room Unit 1
FO-320735	7/8/2015	7/21/2015		Monthly AHU Inspection Clean Room Unit 2
FO-320736	7/8/2015	7/30/2015		PM - Semi Anunal Air Handling Unit Inspection
FO-319732	7/9/2015	7/10/2015		Generator Maintenance, Monthly
FO-319733	7/9/2015	7/10/2015		Generator Maintenance, Monthly
FO-319753	7/9/2015	7/10/2015		Generator Maintenance, Monthly
FO-319781	7/9/2015	7/15/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-319734	7/14/2015	7/21/2015		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-319735	7/15/2015	7/17/2015		Generator Maintenance, Monthly
FO-319789	7/16/2015	7/17/2015		Generator Maintenance, Monthly
<b>E - Southeast</b>			<b>95</b>	
FO-318518	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318519	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318520	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318521	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318522	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318523	7/1/2015	7/13/2015		PM - Fan Coil/HV/AC Unit
FO-318524	7/1/2015	7/13/2015		PM - Fan Coil/HV/AC Unit
FO-318525	7/1/2015	7/13/2015		PM - Fan Coil/HV/AC Unit
FO-318526	7/1/2015	7/14/2015		PM - Fan Coil/HV/AC Unit
FO-318527	7/1/2015	7/14/2015		PM - Fan Coil/HV/AC Unit
FO-318528	7/1/2015	7/14/2015		PM - Fan Coil/HV/AC Unit
FO-318529	7/1/2015	7/27/2015		PM - Fan Coil/HV/AC Unit
FO-318530	7/1/2015	7/27/2015		PM - Fan Coil/HV/AC Unit
FO-318531	7/1/2015	7/27/2015		PM - Fan Coil/HV/AC Unit
FO-318532	7/1/2015	7/27/2015		PM - Fan Coil/HV/AC Unit
FO-318534	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318535	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318536	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318537	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318538	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318539	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318540	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318541	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318542	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318543	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318544	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318545	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318546	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318547	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318548	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318549	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318550	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318551	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318552	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318553	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318554	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318555	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318556	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318557	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318558	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318559	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318560	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318561	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318562	7/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-318563	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318564	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318565	7/1/2015			PM - Fan Coil/HV/AC Unit
FO-318589	7/1/2015	7/31/2015		PM - Fan Coil/HV/AC Unit
FO-319607	7/1/2015	7/10/2015		PM - Heat Exchanger and Economizer
FO-319612	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319645	7/1/2015	6/15/2015		PM - Heat Pumps (5057 Woodward)
FO-319646	7/1/2015	6/15/2015		PM - Heat Pumps (5057 Woodward)
FO-319647	7/1/2015	6/15/2015		PM - Heat Pumps (5057 Woodward)
FO-319656	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319657	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319710	7/1/2015	6/16/2015		PM - Fan Coil/HV/AC Unit
FO-319711	7/1/2015	6/17/2015		PM - Fan Coil/HV/AC Unit
FO-319712	7/1/2015	6/17/2015		PM - Heat Pumps (5057 Woodward)
FO-319713	7/1/2015	6/17/2015		PM - Heat Pumps (5057 Woodward)
FO-319714	7/1/2015	6/17/2015		PM - Heat Pumps (5057 Woodward)
FO-319715	7/1/2015	6/18/2015		PM - Heat Pumps (5057 Woodward)
FO-319716	7/1/2015	6/18/2015		PM - Heat Pumps (5057 Woodward)
FO-319722	7/1/2015	6/24/2015		PM - Fan Coil/HV/AC Unit
FO-319723	7/1/2015	6/25/2015		PM - Fan Coil/HV/AC Unit
FO-319793	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319794	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319798	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319819	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319828	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319829	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319830	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319839	7/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-319777	7/9/2015	6/18/2015		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-319724	7/15/2015	6/26/2015		PM - Chemical Feed/Metering Pump/Controller
FO-319725	7/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-319726	7/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-319727	7/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-319744	7/16/2015	7/29/2015		Generator Maintenance, Monthly
FO-319745	7/16/2015	7/29/2015		Generator Maintenance, Monthly
FO-319606	7/23/2015			PM - Domestic Water Heater, Gas
FO-319717	7/24/2015	6/19/2015		PM - Chemical Feed/Metering Pump/Controller
FO-319718	7/24/2015	6/22/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319719	7/24/2015	6/22/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319720	7/24/2015	6/23/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-319721	7/24/2015	6/24/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321878	7/24/2015	7/1/2015		PM - Chemical Feed/Metering Pump/Controller
FO-321879	7/24/2015	7/2/2015		PM - Chemical Feed/Metering Pump/Controller
FO-321880	7/24/2015	7/2/2015		PM - Chemical Feed/Metering Pump/Controller
FO-321881	7/24/2015	7/7/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

WO	Recieved	Finished	Total	Request
FO-321882	7/24/2015	7/8/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321883	7/24/2015	7/8/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321884	7/24/2015	7/8/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321885	7/24/2015	7/9/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321886	7/24/2015	7/9/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321887	7/24/2015	7/9/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
<b>E - West</b>			<b>38</b>	
FO-319616	7/1/2015	7/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319617	7/1/2015			PM - Unspecified
FO-319618	7/1/2015			PM - Unspecified
FO-319628	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319629	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319630	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319634	7/1/2015	7/8/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319666	7/1/2015	7/29/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319694	7/1/2015	7/6/2015		PM - Sump Pump
FO-319695	7/1/2015	7/6/2015		PM - Sump Pump
FO-319696	7/1/2015	7/15/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319697	7/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-319800	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319801	7/1/2015			PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319818	7/1/2015	7/13/2015		PM - Trane Chillers: Operational Inspections Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-319848	7/1/2015	7/6/2015		Replace PRE-filters
FO-319849	7/1/2015	7/7/2015		Replace PRE-filters
FO-319850	7/1/2015	7/7/2015		Replace PRE-filters
FO-319851	7/1/2015	7/7/2015		Replace PRE-filters
FO-319852	7/1/2015	7/7/2015		Replace PRE-filters
FO-319853	7/1/2015	7/7/2015		Replace PRE-filters
FO-319854	7/1/2015	7/8/2015		Replace PRE-filters
FO-319855	7/1/2015	7/8/2015		Replace PRE-filters
FO-319856	7/1/2015	7/8/2015		Replace PRE-filters
FO-319857	7/1/2015	7/8/2015		Replace PRE-filters
FO-319858	7/1/2015	7/9/2015		Replace PRE-filters
FO-319859	7/1/2015	7/9/2015		Replace PRE-filters
FO-319860	7/1/2015	7/9/2015		Replace PRE-filters
FO-319861	7/1/2015	7/9/2015		Replace PRE-filters
FO-319862	7/1/2015	7/9/2015		Replace PRE-filters
FO-319863	7/1/2015	7/10/2015		Replace PRE-filters
FO-319864	7/1/2015	7/10/2015		Replace PRE-filters
FO-319865	7/1/2015	7/10/2015		Replace PRE-filters
FO-319866	7/1/2015	7/10/2015		Replace PRE-filters
FO-319867	7/1/2015	7/10/2015		Replace PRE-filters
FO-319787	7/14/2015			Generator Maintenance, Monthly
FO-319847	7/23/2015			Generator Maintenance, Monthly
FO-319619	7/24/2015	7/27/2015		PM - Sump Pump

WO	Recieved	Finished	Total	Request
<b>Trades</b>			<b>41</b>	
<b>Routine</b>			<b>41</b>	
<b>T - Electrician</b>			<b>36</b>	
FO-319752	7/3/2015			Generator Maintenance, Monthly
FO-320332	7/3/2015	7/2/2015		Generator Test Friday 7/3/2015 @ 2:15PM.
FO-320333	7/3/2015	7/7/2015		Generator Test Tuesday 7/7/2015 @ 7:15AM.
FO-320334	7/3/2015	7/2/2015		Generator Test Friday 7/3/2015 @ 2:15PM.
FO-320335	7/3/2015	7/2/2015		Generator Test Friday 7/3/2015 @ 2:15PM.
FO-320336	7/3/2015	7/2/2015		Generator Test Friday 7/3/2015 @ 2:15PM.
FO-320745	7/8/2015	7/8/2015		Generator Test Wednesday 7/8/2015 @9:15AM.
FO-320737	7/9/2015	7/9/2015		Generator Test Thursday 7/9/2015 @ 7:15AM.
FO-320738	7/9/2015	7/9/2015		Generator Test Thursday 7/9/2015 @ 7:15AM.
FO-320742	7/9/2015	7/9/2015		Generator Test Thursday 7/9/2015 @ 7:15AM.
FO-320739	7/10/2015	7/14/2015		Generator Test Tuesday 7/14/2015 @ 7:15AM.
FO-320740	7/10/2015	7/14/2015		Generator Test Tuesday 7/14/2015 @ 7:15AM.
FO-320743	7/10/2015	7/10/2015		Generator Test Friday 7/10/2015 @ 7:15AM.
FO-320741	7/14/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 1PM.
FO-320744	7/14/2015	7/14/2015		Generator Test Tuesday 7/14/2015 @ 12:15.
FO-320846	7/15/2015	7/15/2015		Generator Test Wednesday 7/15/2015 @ 10AM.
FO-320858	7/15/2015	7/22/2015		Generator Test Wednesday 7/15/2015 @ 1PM.
FO-320860	7/15/2015	7/15/2015		Generator Test Wednesday 7/15/2015 @ 7:15AM.
FO-320845	7/16/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 9:30AM.
FO-320861	7/16/2015	7/16/2015		Generator Test Thursday 7/16/2015 @ 7:15AM.
FO-320862	7/16/2015	7/16/2015		Generator Test Thursday 7/16/2015 @ 7:15AM.
FO-320844	7/21/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 7:15AM
FO-320855	7/21/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 8:15AM.
FO-320856	7/21/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 8:15AM.
FO-320859	7/21/2015	7/21/2015		Generator Test Tuesday 7/21/2015 @ 9:15AM.
FO-320847	7/22/2015	7/22/2015		Generator Test Wednesday 7/22/2015 @ 7:15AM.
FO-320857	7/22/2015	7/22/2015		Generator Test Wednesday 7/22/2015 @ 7:15AM.
FO-320863	7/23/2015	7/23/2015		Generator Test Thursday 7/23/2015 @ 7:15AM.
FO-320864	7/23/2015	7/23/2015		Generator Test Thursday 7/23/2015 @ 1PM.
FO-320865	7/23/2015	7/23/2015		Generator Test Thursday 7/23/2015 @ 1PM.
FO-320848	7/24/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @7:15AM.
FO-320850	7/28/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @ 10AM.
FO-320851	7/28/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @ 8AM.
FO-320852	7/28/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @ 8AM.
FO-320853	7/28/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @ 8AM.
FO-320854	7/28/2015	7/28/2015		Generator Test Tuesday 7/28/2015 @ 8AM.
<b>T - Plumber</b>			<b>5</b>	
FO-318345	7/1/2015	7/10/2015		PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/7-1-15 ,,,,,,,,,,
FO-318346	7/1/2015	7/1/2015		*CANCELLED JWT
				PM - Main Drain with Copper Sulfate
FO-318347	7/1/2015	7/28/2015		PM - Waterless Urinals ,,,,,,,,,, MM/7-22-15 ,,,,,,,,,,
FO-318348	7/1/2015	7/7/2015		PM - Waterless Urinals ,,,,,,,,,, MP/7-1-15 ,,,,,,,,,,
FO-318349	7/1/2015	7/7/2015		PM - Waterless Urinals ,,,,,,,,,, MP/7-1-15 ,,,,,,,,,,

---

**Total: 2284**