

# **\*DRAFT\* Facilities Operations PM DUE DATE Analysis from 3/1/2014 through 3/31/2014**

Request Finish Complete Due KPI WND								Total per Trade	
Engineering								224 of 473 47%	
E - Auxiliary								14 of 25 56%	
FO-275311	2/24/2014	2/28/2014	3/1/2014	1	False	PM - Emergency Shower/Eyewash Station	992-ES-001*	Checked unit's operation.	
FO-273199	2/1/2014	3/5/2014	3/3/2014	-2	False	PM - Air Handling Unit	134-AHU-001	Checked operation, belts, filters, bearings and dampers.	
FO-273205	2/1/2014	2/27/2014	3/3/2014	4	False	PM - Monthly Fire Alarm/Fire Protection System Test	507-FP-001	Checked fire pump and jockey pump operation when I filled the sprinkler system on the 2nd floor.	
FO-273206	2/1/2014	2/28/2014	3/3/2014	3	False	PM - Monthly Fire Alarm/Fire Protection System Test	992-FP-001	Tested fire pump and jockey pump operation. Tested fire alarm system.	
FO-273216	2/1/2014	2/28/2014	3/3/2014	3	False	PM - Monthly Fire Alarm/Fire Protection System Test	136-FAP-001	Building alarm was checked and flow switch was tested.	
FO-275901	3/4/2014	3/5/2014	3/5/2014	0	False	Generator Maintenance, Monthly	501-GEN-001	Checked status of unit. Missed electricians for test.	
FO-275300	2/20/2014	3/5/2014	3/6/2014	1	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	034-RAF-005	Checked operation of unit, lubed motor and bearings, checked belts.	
FO-276534	3/5/2014	3/12/2014	3/6/2014	-6	False	Generator Maintenance, Monthly	507-GEN-001	Checked fluid levels, batteries and assisted with test. Gregory Ray assisted in test.	
FO-275910	3/3/2014	3/7/2014	3/8/2014	1	False	PM - Emergency Shower/Eyewash Station	992-ES-001*	Checked units operation.	
FO-277243	3/12/2014	3/11/2014	3/12/2014	1	False	Generator Maintenance, Monthly	536-GEN-001	Test was conducted.	
FO-275904	3/1/2014	3/26/2014	3/15/2014	-11	False	PM - Fan Coil/HV/AC Unit	127-MAU-005	Checked unit. West burner not working and the vendor providing service is still working on the problem.	
FO-275906	3/1/2014	3/20/2014	3/15/2014	-5	False	PB - B&G Series 100 Pump	115-DHWP-007	Lubed pump and motor, checked operation.	
FO-275907	3/1/2014	3/20/2014	3/15/2014	-5	False	PB - B&G Series 100 Pump	115-DHWP-006	lubed pump and motor, checked operation.	
FO-275908	3/1/2014	3/20/2014	3/15/2014	-5	False	PB - B&G Series 100 Pump	115-DWB-003	lubed pump and motor, checked operation.	
FO-275909	3/1/2014	3/20/2014	3/15/2014	-5	False	PB - B&G Series 100 Pump	115-DWB-004	Lubed pump and motor, checked operation.	
FO-276536	3/10/2014	3/14/2014	3/15/2014	1	False	PM - Emergency Shower/Eyewash Station	992-ES-001*	Tested units operation and cleaned area.	
FO-277232	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Maintenance, Monthly	104-GEN-001	Elevators at Ghafari did not respond to power switching over from utility to generator. It has done this frequently in the past. The fire alarm to the building went off when the power went from utility to generator. This has happened before. Desk staff called Public Safety and also requested that the elevator service technicians come out and check the elevators. No problem running the generator itself. There is a puddle of fluid under the generator. I am unable to find the source of the leak.	
FO-277234	3/18/2014	3/18/2014	3/19/2014	1	False	Generator Maintenance, Monthly	127-GEN-001	Checked unit and assisted with test.	
FO-277236	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Maintenance, Monthly	127-GEN-002	No problems.	
FO-277238	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Maintenance, Monthly	127-GEN-003	No problems.	
FO-277240	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Maintenance, Monthly	127-GEN-004	No problems.	
FO-275902	3/1/2014	3/18/2014	3/22/2014	4	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	127-EXF-002	Checked belts, filters and units operation.	
FO-275903	3/1/2014	3/18/2014	3/22/2014	4	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	127-EXF-001	Checked, cleaned and returned to service.	

Request Finish Complete Due KPI WND								Total per Trade	
FO-277246	3/17/2014	3/21/2014	3/22/2014	1	False	PM - Emergency Shower/Eyewash Station	992-ES-001*	Tested unit operation.	
FO-278110	3/24/2014	3/27/2014	3/29/2014	2	False	PM - Emergency Shower/Eyewash Station	992-ES-001*	Tested units operation.	
25		25		-1.4	0				
E - Command Center								0 of 1	0%
FO-275297	2/23/2014		3/9/2014		False	PM - Air Compressor, Reciprocating 5-40 H.P.	082-AIR-001		
1		0		0					
E - MedPharm								10 of 68	15%
FO-275333	2/28/2014	2/28/2014	3/1/2014	1	False	Generator Maintenance, Monthly	611-GEN-001	Electricians performed emergency generator test	
FO-274533	2/16/2014	3/6/2014	3/2/2014	-4	False	PM - Domestic Water Heater, Electric	620-DHW-001	Done. checked valves, blowdown	
FO-275269	2/21/2014	3/4/2014	3/7/2014	3	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-001		
FO-275270	2/21/2014	3/6/2014	3/7/2014	1	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-002		
FO-275271	2/21/2014	3/4/2014	3/7/2014	3	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-003		
FO-275272	2/21/2014	3/11/2014	3/7/2014	-4	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-004		
FO-275273	2/21/2014	3/12/2014	3/7/2014	-5	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-005		
FO-275274	2/21/2014	3/12/2014	3/7/2014	-5	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-006		
FO-275275	2/21/2014	3/24/2014	3/7/2014	-17	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-007		
FO-275276	2/21/2014	3/6/2014	3/7/2014	1	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-008		
FO-275277	2/21/2014	3/14/2014	3/7/2014	-7	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-009		
FO-275278	2/21/2014	3/17/2014	3/7/2014	-10	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-010		
FO-276493	3/7/2014		3/7/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-021		
FO-276494	3/7/2014		3/7/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-022		
FO-276495	3/7/2014	3/24/2014	3/7/2014	-17	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-023		
FO-276496	3/7/2014		3/7/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-024		
FO-276497	3/7/2014		3/7/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-025		
FO-275267	2/22/2014		3/8/2014		False	PM - Heat Exchanger and Economizer	629-HEX-001		
FO-275268	2/22/2014		3/8/2014		False	PM - Heat Exchanger and Economizer	629-HEX-002		
FO-275279	2/23/2014	3/6/2014	3/9/2014	3	False	PM - Domestic Water Heater, Electric	620-DHW-002	Done, blowdown unit,	
FO-275335	2/28/2014	2/28/2014	3/12/2014	12	False	Generator Maintenance, Monthly	629-GEN-001	ok	
FO-276498	3/11/2014	3/31/2014	3/12/2014	-19	False	Generator Maintenance, Monthly	609-GEN-001	Checked fluids belts heaters and battery	
FO-271479	1/12/2014		3/13/2014		False	PM - Centrifugal Pump, over 1 H.P.	629-DWBP-001		
FO-271480	1/12/2014		3/13/2014		False	PM - Centrifugal Pump, over 1 H.P.	629-DWBP-002		
FO-271486	1/12/2014		3/13/2014		False	PM - Centrifugal Pump, over 1 H.P.	629-GFP-001		
FO-271487	1/12/2014		3/13/2014		False	PM - Centrifugal Pump, over 1 H.P.	629-GFP-002		
FO-271488	1/12/2014		3/13/2014		False	PM - Centrifugal Pump, over 1 H.P.	629-LCP-001		

Request	Finish	Complete	Due	KPI	WND		Total per Trade
FO-275871	2/28/2014	3/18/2014	3/14/2014	-4	False	PM - Reverse Osmosis Water Softener System	603-ROS-001 softner tank still leaking(old work order) using one pump/good
FO-275879	2/28/2014	3/24/2014	3/14/2014	-10	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-011
FO-275880	2/28/2014	3/28/2014	3/14/2014	-14	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-012
FO-275881	2/28/2014		3/14/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-016
FO-275882	2/28/2014		3/14/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-017
FO-275883	2/28/2014		3/14/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-019
FO-275884	2/28/2014		3/14/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-020
FO-277145	3/14/2014		3/14/2014		False	Generator Maintenance, Monthly	608-GEN-001
FO-275874	3/1/2014		3/15/2014		False	PM - Reverse Osmosis Water Softener System	629-ROS-001
FO-275876	3/1/2014	3/4/2014	3/15/2014	11	False	PM - Domestic Water Heater, Steam	612-HWH-001
FO-275877	3/1/2014	3/5/2014	3/15/2014	10	False	PM - Domestic Water Heater, Steam	612-HWH-002
FO-275878	3/1/2014	3/4/2014	3/15/2014	11	False	PM - Domestic Water Heater, Steam	612-HWH-003
FO-277116	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-045
FO-277117	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-046
FO-277118	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-047
FO-277119	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-048
FO-277120	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-049
FO-277121	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-050
FO-277122	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-051
FO-277123	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-052
FO-277124	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-053
FO-277125	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-054
FO-277126	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-055
FO-277127	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-056
FO-277128	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-057
FO-277129	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-058
FO-277130	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-059
FO-277131	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-060
FO-277132	3/1/2014		3/15/2014		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	612-EXF-061
FO-275885	3/4/2014		3/18/2014		False	PM - Water Softener	629-WSS-001
FO-276488	3/8/2014		3/22/2014		False	PM - Unspecified	603-SRS-001*
FO-277760	3/21/2014		3/22/2014		False	Generator Maintenance, Monthly	612-GEN-001
FO-277762	3/21/2014		3/22/2014		False	Generator Maintenance, Monthly	612-GEN-002
FO-276489	3/9/2014		3/23/2014		False	PM - Fan Coil/HV/AC Unit	611-HVU-001**
FO-276490	3/9/2014		3/23/2014		False	PM - Fan Coil/HV/AC Unit	611-HVU-004**

Request Finish Complete Due KPI WND							Total per Trade	
FO-277115	3/14/2014		3/28/2014	False	PM - Centrifugal Pump, over 1 H.P.	612-BFP-001		
FO-277754	3/28/2014		3/29/2014	False	Generator Maintenance, Monthly	611-GEN-001		
FO-277141	3/16/2014		3/30/2014	False	PM - Centrifugal Pump, over 1 H.P.	612-BFP-002		
FO-277142	3/16/2014		3/30/2014	False	PM - Centrifugal Pump, over 1 H.P.	612-BFP-003		
FO-277143	3/16/2014		3/30/2014	False	PM - Centrifugal Pump, over 1 H.P.	612-SRG-001		
FO-277144	3/16/2014		3/30/2014	False	PM - Centrifugal Pump, over 1 H.P.	612-SRG-002		
68		22		-2.7	0			
E - Midnight							0 of 1	0%
FO-273217	2/1/2014		3/3/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	612-FP-001		
1		0		0				
E - North							20 of 37	54%
FO-274535	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	027-HEX-001		
FO-274536	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	027-HEX-002		
FO-274537	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	027-HEX-003		
FO-274538	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	027-HEX-004		
FO-274539	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	036-HEX-001		
FO-274540	2/15/2014		3/1/2014	False	PM - Heat Exchanger and Economizer	036-HEX-002		
FO-275293	2/24/2014	3/7/2014	3/1/2014	-6	False PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	130-AHU-001		
FO-273177	2/1/2014	2/19/2014	3/3/2014	12	False PM - Sump Pump	027-SP-001		
FO-273178	2/1/2014	2/20/2014	3/3/2014	11	False PM - Sump Pump	027-SP-002		
FO-273179	2/1/2014	2/20/2014	3/3/2014	11	False PM - Sump Pump	027-SP-003		
FO-273180	2/1/2014	2/20/2014	3/3/2014	11	False PM - Sump Pump	036-SP-001		
FO-273181	2/1/2014	2/20/2014	3/3/2014	11	False PM - Sump Pump	036-SP-002		
FO-273182	2/1/2014	2/19/2014	3/3/2014	12	False PM - Sump Pump	027-SP-004		
FO-273176	2/4/2014	1/27/2014	3/19/2014	3/6/2014	38	False PM - Water Booster Pump	049-DWBP-001	This booster pump is for suppling the cooling tower when in service, and is off for the winter. The pumps are depowered until prepping the tower in the late Spring.
FO-275284	2/21/2014	2/21/2014	3/7/2014	14	False PM - Unspecified	050-RHC-001		
FO-275285	2/21/2014	2/21/2014	3/7/2014	14	False PM - Unspecified	050-RHC-002		
FO-275286	2/21/2014	3/26/2014	3/7/2014	-19	False PM - Harmsco Side Stream Filter	048-SSF-001	Cleaned filters and added closed-loop chemicals.	
FO-275287	2/21/2014	3/26/2014	3/7/2014	-19	False PM - Harmsco Side Stream Filter	048-SSF-002	Cleaned filters and added closed-loop chemicals.	
FO-275288	2/21/2014	3/27/2014	3/7/2014	-20	False PM - Harmsco Side Stream Filter	046-SSF-001	Replaced all filters and removed to dumpster. Added closed-loop chemicals to system.	
FO-275289	2/21/2014	3/28/2014	3/7/2014	-21	False PM - Harmsco Side Stream Filter	046-SSF-003	Pulled and washed filters, then reinstalled.	

Request	Finish	Complete	Due	KPI	WND		Total per Trade
FO-275291	2/21/2014	3/28/2014	3/7/2014	-21	False	PM - Harmsco Side Stream Filter	046-SSF-002 Removed filters, washed-down filters, and added closed-loop chemicals.
FO-275282	2/23/2014	3/7/2014	3/9/2014	2	False	PM - Centrifugal Pump, over 1 H.P.	130-HWP-001
FO-275283	2/23/2014	3/7/2014	3/9/2014	2	False	PM - Centrifugal Pump, over 1 H.P.	130-HWP-002
FO-275887	2/28/2014	2/24/2014	3/14/2014	18	False	PM - Unspecified	050-RHC-003
FO-275888	2/28/2014	2/24/2014	3/14/2014	18	False	PM - Unspecified	050-RHC-004
FO-276504	3/10/2014	3/14/2014	3/15/2014	1	False	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	130-AHU-001
FO-276502	3/6/2014		3/20/2014		False	PM - Harmsco Side Stream Filter	026-SSF-001
FO-276503	3/6/2014		3/20/2014		False	PM - Harmsco Side Stream Filter	036-SSF-001
FO-277758	3/19/2014	3/26/2014	3/20/2014	-6	False	Generator Maintenance, Monthly	130-GEN-001
FO-276499	3/7/2014	3/5/2014	3/21/2014	16	False	PM - Unspecified	050-RHC-005
FO-276500	3/7/2014	3/5/2014	3/21/2014	16	False	PM - Unspecified	050-RHC-006
FO-277767	3/21/2014	3/25/2014	3/21/2014	-4	False	Generator Maintenance, Monthly	048-GEN-001 This generator has not been turned-over to me. Also, I have no access key or information on this generator.
FO-277153	3/14/2014	3/6/2014	3/28/2014	22	False	PM - Unspecified	050-RHC-007
FO-277154	3/14/2014	3/6/2014	3/28/2014	22	False	PM - Unspecified	050-RHC-008
FO-277156	3/14/2014	3/12/2014	3/28/2014	16	False	PM - Centrifugal Pump, over 1 H.P.	140-DWBP-001
FO-277157	3/14/2014	3/12/2014	3/28/2014	16	False	PM - Centrifugal Pump, over 1 H.P.	140-DWBP-002
FO-278093	3/24/2014		3/29/2014		False	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	130-AHU-001

37

28

6.0

0

## E - Northeast

15 of 23 65%

FO-274541	2/15/2014	2/27/2014	3/1/2014	2	False	PM - Fan Coil/HV/AC Unit	195-ACU-001
FO-274542	2/15/2014	2/27/2014	3/1/2014	2	False	PM - Fan Coil/HV/AC Unit	195-ACU-002
FO-274543	2/15/2014	2/27/2014	3/1/2014	2	False	PM - Fan Coil/HV/AC Unit	195-ACU-003
FO-274544	2/15/2014	3/26/2014	3/1/2014	-25	True	PM - Domestic Water Heater, Steam	067-DHW-001 This unit is OOS. Condensate from several sources feed tank. the steam is isolated. the HEX has no insulation. None of the pumps are in service...one is not piped the other is missing a motor. The tank marked DHW-001 is crossed out on the unit.
FO-274545	2/15/2014	2/27/2014	3/1/2014	2	False	PM - Domestic Water Heater, Electric	141-DHW-001
FO-275893	2/28/2014	2/24/2014	3/2/2014	6	False	PM - Domestic Water Heater, Electric	509-DHW-001
FO-275294	2/21/2014	2/21/2014	3/7/2014	14	False	PM - Centrifugal Pump, over 1 H.P.	062-DWBP-001
FO-275295	2/21/2014	2/17/2014	3/7/2014	18	False	PM - Domestic Water Heater, Gas	193-DHW-001
FO-276515	3/6/2014	3/3/2014	3/7/2014	4	False	Generator Maintenance, Monthly	193-GEN-001
FO-276517	3/6/2014	3/3/2014	3/7/2014	4	False	Generator Maintenance, Monthly	193-GEN-002
FO-276518	3/6/2014	3/3/2014	3/7/2014	4	False	Generator Maintenance, Monthly	193-GEN-003

Request	Finish	Complete	Due	KPI	WND		Total per Trade
FO-276519	3/6/2014	3/3/2014	3/7/2014	4	False	Generator Maintenance, Monthly	193-GEN-004
FO-276516	3/8/2014		3/9/2014		False	Generator Maintenance, Monthly	060-GEN-001 (Towable)
FO-276514	3/11/2014		3/12/2014		False	Generator Maintenance, Monthly	203-GEN-001
FO-275891	2/28/2014	2/28/2014	3/14/2014	14	False	PM - Centrifugal Pump, over 1 H.P.	062-DWBP-002
FO-276507	3/7/2014		3/21/2014		False	PM - Fan Coil/HV/AC Unit	060-ACU-001
FO-276508	3/7/2014		3/21/2014		False	PM - Fan Coil/HV/AC Unit	060-ACU-002
FO-276509	3/7/2014		3/21/2014		False	PM - Fan Coil/HV/AC Unit	060-ACU-003
FO-276510	3/7/2014	3/11/2014	3/21/2014	10	False	PM - Domestic Water Heater, Gas	510-DHW-001 checked for leaks, pump operation and temperature of water
FO-276511	3/7/2014	3/11/2014	3/21/2014	10	False	PM - Domestic Water Heater, Gas	510-DHW-002 checked unit
FO-277751	3/25/2014		3/26/2014		False	Generator Maintenance, Monthly	066-GEN-001
FO-277766	3/27/2014		3/27/2014		False	Generator Maintenance, Monthly	527-GEN-001
FO-275892	2/28/2014	3/26/2014	3/30/2014	4	True	PM - Vacuum Pump	065-VPS-001 this piece of equipment is not in use.

23

16

4.7 2

### E - Preventative Maintenance

136 of 251 54%

FO-269522	2/1/2014	2/26/2014		3/1/2014	3	False	Replace PRE-filters	629-EXF-011A
FO-269526	2/1/2014	2/26/2014		3/1/2014	3	False	Replace PRE-filters	629-EXF-011B
FO-273222	2/15/2014		2/25/2014	3/1/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	155-RAF-003
FO-273223	2/15/2014		2/25/2014	3/1/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	155-RAF-004
FO-272710	2/9/2014		2/5/2014	3/2/2014		True	PM - Air Handling Unit	016-AHU-001
FO-272711	2/9/2014		2/5/2014	3/2/2014		True	PM - Air Handling Unit	016-AHU-002
FO-269506	2/1/2014	2/14/2014		3/3/2014	17	False	PM - Air Handling Unit (ANNUAL)	603-AHU-010
FO-269507	2/1/2014	2/7/2014		3/3/2014	24	False	PM - Air Handling Unit (ANNUAL)	603-AHU-009
FO-269508	2/1/2014	2/11/2014		3/3/2014	20	False	PM - Air Handling Unit (ANNUAL)	603-AHU-008
FO-269509	2/1/2014	2/4/2014	3/19/2014	3/3/2014	27	False	PM - Air Handling Unit (ANNUAL)	603-AHU-007
FO-269510	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	PM - Air Handling Unit (ANNUAL)	603-AHU-006
FO-269511	2/1/2014	2/6/2014	3/19/2014	3/3/2014	25	False	PM - Air Handling Unit (ANNUAL)	603-AHU-005
FO-269512	2/1/2014	2/13/2014		3/3/2014	18	False	PM - Air Handling Unit (ANNUAL)	603-AHU-004
FO-269513	2/1/2014	2/13/2014		3/3/2014	18	False	PM - Air Handling Unit (ANNUAL)	603-AHU-003
FO-269514	2/1/2014	2/14/2014		3/3/2014	17	False	PM - Air Handling Unit (ANNUAL)	603-AHU-002
FO-269515	2/1/2014	2/21/2014		3/3/2014	10	False	PM - Air Handling Unit (ANNUAL)	611-AHU-007**
FO-269516	2/1/2014	2/21/2014		3/3/2014	10	False	PM - Air Handling Unit (ANNUAL)	611-AHU-006
FO-269517	2/1/2014	2/6/2014		3/3/2014	25	False	PM - Air Handling Unit (ANNUAL)	611-AHU-005
FO-269518	2/1/2014	2/20/2014		3/3/2014	11	False	PM - Air Handling Unit (ANNUAL)	611-AHU-004

Request Finish Complete Due KPI WND								Total per Trade
FO-269519	2/1/2014	2/17/2014		3/3/2014	14	False	PM - Air Handling Unit (ANNUAL)	611-AHU-003
FO-269520	2/1/2014	2/20/2014		3/3/2014	11	False	PM - Air Handling Unit (ANNUAL)	611-AHU-002
FO-269521	2/1/2014	2/14/2014		3/3/2014	17	False	PM - Air Handling Unit (ANNUAL)	611-AHU-001
FO-269523	2/1/2014	2/26/2014		3/3/2014	5	False	PM - Air Handling Unit (ANNUAL)	629-AHU-003
FO-269524	2/1/2014	2/25/2014		3/3/2014	6	False	PM - Air Handling Unit (ANNUAL)	629-AHU-002
FO-269525	2/1/2014	2/22/2014		3/3/2014	9	False	PM - Air Handling Unit (ANNUAL)	629-AHU-001
FO-269527	2/1/2014	2/14/2014		3/3/2014	17	False	PM - Air Handling Unit (ANNUAL)	603-AHU-001
FO-269707	2/1/2014	2/28/2014		3/3/2014	3	False	PM - Monthly Fire Alarm/Fire Protection System Test	005-FAP-001
FO-269882	2/1/2014	2/3/2014	3/19/2014	3/3/2014	28	False	Replace PRE-filters	090-AHU-548
FO-269883	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	Replace PRE-filters	090-AHU-547
FO-269884	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	Replace PRE-filters	090-AHU-546
FO-269885	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	Replace PRE-filters	090-AHU-545
FO-269886	2/1/2014	2/6/2014		3/3/2014	25	False	Replace PRE-filters	090-AHU-544
FO-269887	2/1/2014	2/4/2014	3/19/2014	3/3/2014	27	False	Replace PRE-filters	090-AHU-543
FO-269888	2/1/2014	2/3/2014	3/19/2014	3/3/2014	28	False	Replace PRE-filters	090-AHU-542
FO-269889	2/1/2014	2/4/2014	3/19/2014	3/3/2014	27	False	Replace PRE-filters	090-AHU-541
FO-269890	2/1/2014	2/12/2014		3/3/2014	19	False	Replace PRE-filters	090-AHU-003
FO-269891	2/1/2014	2/18/2014		3/3/2014	13	False	Replace PRE-filters	090-AHU-002
FO-269892	2/1/2014	2/18/2014		3/3/2014	13	False	Replace PRE-filters	090-AHU-001
FO-269893	2/1/2014	2/12/2014		3/3/2014	19	False	Replace PRE-filters	090-HVU-004
FO-269894	2/1/2014	2/19/2014		3/3/2014	12	False	Replace PRE-filters	090-HVU-003
FO-269895	2/1/2014	2/11/2014		3/3/2014	20	False	Replace PRE-filters	090-HVU-002
FO-269896	2/1/2014	2/11/2014		3/3/2014	20	False	Replace PRE-filters	090-HVU-001
FO-270003	2/1/2014	2/12/2014		3/3/2014	19	False	Replace PRE-filters	049-AHU-005
FO-270004	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	Replace PRE-filters	049-AHU-004
FO-270005	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False	Replace PRE-filters	049-AHU-003
FO-270006	2/1/2014		2/5/2014	3/3/2014		True	Replace PRE-filters	049-AHU-002
								Incorrectly issued. Forgot to add season start and season end dates.
								Prefilters and bags are changed in February, Prefiltersonly are scheduled for May, August, & November.
FO-270007	2/1/2014		2/5/2014	3/3/2014		False	Replace PRE-filters	049-AHU-001
								Incorrectly issued. Forgot to add season start and season end dates.
								Prefilters and bags are changed in February, Prefiltersonly are scheduled for May, August, & November.
FO-270008	2/1/2014	2/15/2014		3/3/2014	16	False	Replace PRE-filters	046-SAF-003
FO-270151	2/1/2014		2/5/2014	3/3/2014		True	PM - Monthly Fire Alarm/Fire Protection System Test	062-FP-001

Request Finish Complete Due KPI WND							Total per Trade
FO-270861	2/1/2014		2/5/2014	3/3/2014	True	PM - Air Handling Unit (ANNUAL)	062-AHU-004
FO-270862	2/1/2014		2/5/2014	3/3/2014	True	PM - Air Handling Unit (ANNUAL)	062-AHU-003
FO-270863	2/1/2014		2/5/2014	3/3/2014	True	PM - Air Handling Unit (ANNUAL)	062-AHU-002
FO-270864	2/1/2014		2/5/2014	3/3/2014	True	PM - Air Handling Unit (ANNUAL)	062-AHU-001
FO-270865	2/1/2014	2/15/2014		3/3/2014	16	False PM - Air Handling Unit (ANNUAL)	046-AHU-002
FO-270866	2/1/2014	2/12/2014		3/3/2014	19	False PM - Air Handling Unit (ANNUAL)	046-AHU-001
FO-271925	2/1/2014	2/21/2014		3/3/2014	10	False PM - Monthly Fire Alarm/Fire Protection System Test	046-FAP-001
FO-271926	2/1/2014			3/3/2014		False PM - Monthly Fire Alarm/Fire Protection System Test	048-FAP-001
FO-271927	2/1/2014			3/3/2014		False PM - Monthly Fire Alarm/Fire Protection System Test	049-FAP-001
FO-271929	2/1/2014		3/1/2014	3/3/2014		True PM - Monthly Fire Alarm/Fire Protection System Test	134-FAP-001
FO-271930	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	156-FAP-001
FO-271931	2/1/2014	2/6/2014		3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	499-FAP-001
FO-271932	2/1/2014	2/6/2014		3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	620-FAP-001
FO-271933	2/1/2014	2/6/2014		3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	036-FP-001
FO-271934	2/1/2014	2/19/2014		3/3/2014	12	False PM - Monthly Fire Alarm/Fire Protection System Test	025-FP-001
FO-271935	2/1/2014	2/28/2014		3/3/2014	3	False PM - Monthly Fire Alarm/Fire Protection System Test	007-FP-001
FO-271936	2/1/2014	2/26/2014		3/3/2014	5	False PM - Monthly Fire Alarm/Fire Protection System Test	001-FP-001
FO-271937	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	040-FAP-001
FO-271938	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	038-FAP-001
FO-271939	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False PM - Monthly Fire Alarm/Fire Protection System Test	028-FAP-001
FO-271940	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False PM - Monthly Fire Alarm/Fire Protection System Test	026-FAP-001
FO-271941	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False PM - Monthly Fire Alarm/Fire Protection System Test	022-FAP-001
FO-271942	2/1/2014	2/6/2014	3/19/2014	3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	017-FAP-001
FO-271943	2/1/2014	2/14/2014		3/3/2014	17	False PM - Monthly Fire Alarm/Fire Protection System Test	016-FAP-001
FO-271944	2/1/2014	2/28/2014		3/3/2014	3	False PM - Monthly Fire Alarm/Fire Protection System Test	003-FAP-001
FO-271945	2/1/2014	2/28/2014		3/3/2014	3	False PM - Monthly Fire Alarm/Fire Protection System Test	006-FP-001
FO-271946	2/1/2014	2/21/2014		3/3/2014	10	False PM - Monthly Fire Alarm/Fire Protection System Test	050-FAP-001
FO-271947	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	043-FAP-001
FO-271948	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	042-FAP-001
FO-271949	2/1/2014	2/13/2014		3/3/2014	18	False PM - Monthly Fire Alarm/Fire Protection System Test	065-FP-001
FO-271950	2/1/2014	2/18/2014		3/3/2014	13	False PM - Monthly Fire Alarm/Fire Protection System Test	068-FAP-001
FO-271951	2/1/2014	2/13/2014		3/3/2014	18	False PM - Monthly Fire Alarm/Fire Protection System Test	067-FP-001
FO-271952	2/1/2014	2/28/2014		3/3/2014	3	False PM - Monthly Fire Alarm/Fire Protection System Test	089-FP-001
FO-271953	2/1/2014	2/6/2014		3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	082-FP-001
FO-271954	2/1/2014	2/13/2014		3/3/2014	18	False PM - Monthly Fire Alarm/Fire Protection System Test	080-FAP-001



Request Finish Complete Due KPI WND							Total per Trade
FO-271955	2/1/2014	2/27/2014		3/3/2014	4	False PM - Monthly Fire Alarm/Fire Protection System Test	090-FP-541
FO-271956	2/1/2014	2/27/2014		3/3/2014	4	False PM - Monthly Fire Alarm/Fire Protection System Test	090-FP-001
FO-271957	2/1/2014	2/26/2014		3/3/2014	5	False PM - Monthly Fire Alarm/Fire Protection System Test	096-FP-001
FO-271958	2/1/2014	2/19/2014		3/3/2014	12	False PM - Monthly Fire Alarm/Fire Protection System Test	155-FP-001
FO-271959	2/1/2014	2/12/2014		3/3/2014	19	False PM - Monthly Fire Alarm/Fire Protection System Test	150-FAP-001
FO-271960	2/1/2014	2/27/2014		3/3/2014	4	False PM - Monthly Fire Alarm/Fire Protection System Test	167-FAP-001
FO-271961	2/1/2014	2/27/2014		3/3/2014	4	False PM - Monthly Fire Alarm/Fire Protection System Test	166-FP-001
FO-271962	2/1/2014	2/13/2014		3/3/2014	18	False PM - Monthly Fire Alarm/Fire Protection System Test	140-FAP-001
FO-271963	2/1/2014	2/21/2014		3/3/2014	10	False PM - Monthly Fire Alarm/Fire Protection System Test	130-FP-001
FO-271964	2/1/2014	2/13/2014		3/3/2014	18	False PM - Monthly Fire Alarm/Fire Protection System Test	193-FAP-001
FO-271965	2/1/2014	2/6/2014		3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	189-FP-001
FO-271966	2/1/2014	2/6/2014	3/19/2014	3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	510-FAP-001
FO-271967	2/1/2014	2/6/2014	3/19/2014	3/3/2014	25	False PM - Monthly Fire Alarm/Fire Protection System Test	509-FAP-001
FO-271968	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False PM - Monthly Fire Alarm/Fire Protection System Test	504-FAP-001
FO-271969	2/1/2014	2/7/2014		3/3/2014	24	False PM - Monthly Fire Alarm/Fire Protection System Test	629-FP-001
FO-271970	2/1/2014	2/5/2014	3/19/2014	3/3/2014	26	False PM - Monthly Fire Alarm/Fire Protection System Test	611-FP-001
FO-271971	2/1/2014	2/7/2014		3/3/2014	24	False PM - Monthly Fire Alarm/Fire Protection System Test	609-FP-001
FO-271972	2/1/2014	2/18/2014		3/3/2014	13	False PM - Monthly Fire Alarm/Fire Protection System Test	603-FP-001
FO-271974	2/1/2014	2/27/2014		3/3/2014	4	False PM - Monthly Fire Alarm/Fire Protection System Test	074-FAP-001
FO-277244	2/1/2014			3/3/2014		False HEPA Filter Replacement at Applebaum Pharmacy Building	603-AHU-010
FO-277247	2/1/2014			3/3/2014		False HEPA Filter Replacement at Applebaum Pharmacy Building	603-EXF-005
FO-277248	2/1/2014			3/3/2014		False HEPA Filter Replacement at Applebaum Pharmacy Building	603-AHU-009
FO-272712	2/11/2014	2/5/2014		3/4/2014		True PM - Air Handling Unit	082-AHU-001
FO-272739	2/11/2014	1/14/2014		3/4/2014	49	False PM - Air Handling Unit	082-AHU-002
FO-273224	2/18/2014	2/25/2014		3/4/2014	7	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.3
FO-273225	2/18/2014	2/25/2014		3/4/2014	7	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.12
FO-273226	2/18/2014	2/25/2014		3/4/2014	7	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.13
FO-273227	2/18/2014	2/25/2014		3/4/2014	7	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.4
FO-273228	2/18/2014	2/25/2014		3/4/2014	7	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.5
FO-273229	2/18/2014	2/26/2014		3/4/2014	6	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.6
FO-273230	2/18/2014	2/26/2014		3/4/2014	6	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.7
FO-273231	2/18/2014	2/26/2014		3/4/2014	6	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.8
FO-273232	2/18/2014	2/26/2014		3/4/2014	6	False PM - Fan Coil/HV/AC Unit	001-FCU-2147.9

Request Finish Complete Due KPI WND								Total per Trade
FO-273233	2/18/2014	2/26/2014	3/4/2014	6	False	PM - Fan Coil/HV/AC Unit	001-FCU-2147.10	
FO-273234	2/18/2014	2/26/2014	3/4/2014	6	False	PM - Fan Coil/HV/AC Unit	001-FCU-2147.11	
FO-273235	2/18/2014	2/26/2014	3/4/2014	6	False	PM - Fan Coil/HV/AC Unit	001-FCU-2383-2	
FO-273236	2/18/2014	2/25/2014	3/4/2014	7	False	PM - Fan Coil/HV/AC Unit	001-FCU-2388	
FO-273237	2/18/2014	2/25/2014	3/4/2014	7	False	PM - Fan Coil/HV/AC Unit	001-FCU-2390	
FO-272839	2/13/2014	2/14/2014	3/6/2014		True	PM - Air Handling Unit, HV Type	074-AHU-003	
FO-273386	2/20/2014	2/25/2014	3/6/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-005	
FO-273387	2/20/2014	2/25/2014	3/6/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-006	
FO-273384	2/21/2014	2/22/2014	3/7/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	096-EXF-020	
FO-273947	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-005	
FO-273963	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-006	
FO-273964	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-007	
FO-273965	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-008	
FO-273966	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-009	
FO-273967	2/23/2014	2/25/2014	3/9/2014		True	PM - Unit/Space Heater	603-UNH-010	
FO-273238	2/17/2014	2/25/2014	3/10/2014		True	PM - Air Handling Unit	510-AHU-001	
FO-273239	2/17/2014	2/25/2014	3/10/2014		True	PM - Air Handling Unit	510-AHU-002	
FO-273951	2/25/2014	2/28/2014	3/11/2014	11	False	PM - Fan Coil/HV/AC Unit	001-FCU-2152	
FO-273952	2/25/2014	2/28/2014	3/11/2014	11	False	PM - Fan Coil/HV/AC Unit	001-FCU-2153-1	
FO-273953	2/25/2014	2/28/2014	3/11/2014	11	False	PM - Fan Coil/HV/AC Unit	001-FCU-2153-2	
FO-273954	2/25/2014	2/26/2014	3/11/2014	13	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.1B	
FO-273955	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.10	
FO-273956	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.11	
FO-273957	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.12	
FO-273958	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.14	
FO-273959	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.15	
FO-273960	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.17	
FO-273961	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.1A	
FO-273962	2/25/2014	2/27/2014	3/11/2014	12	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.2	

Request Finish Complete Due KPI WND							Total per Trade
FO-270877	2/10/2014		2/5/2014	3/12/2014	True	PM - Air Handling Unit	140-AHU-003
FO-270878	2/10/2014		2/5/2014	3/12/2014	True	PM - Air Handling Unit	140-AHU-004
FO-272736	2/10/2014		2/11/2014	3/12/2014	True	PM - Air Handling Unit, HV Type	130-HVU-002
FO-272737	2/10/2014		2/11/2014	3/12/2014	True	PM - Air Handling Unit, HV Type	130-HVU-001
FO-269704	2/27/2014		12/12/2013	3/13/2014	True	PM - Air Handling Unit, HV Type	005-AHU-004
FO-269705	2/27/2014		12/12/2013	3/13/2014	True	PM - Air Handling Unit, HV Type	005-AHU-005
FO-269706	2/27/2014		12/12/2013	3/13/2014	True	PM - Air Handling Unit, HV Type	005-AHU-006
FO-273388	2/20/2014		2/21/2014	3/13/2014	True	PM - Air Handling Unit, HV Type	074-AHU-004
FO-274007	2/27/2014		2/27/2014	3/13/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-007
FO-274008	2/27/2014		2/27/2014	3/13/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-008
FO-275458	3/13/2014		2/27/2014	3/13/2014	True	HEPA Filter Replacement at Applebaum Pharmacy Building	603-AHU-009
FO-274000	2/28/2014	4/1/2014		3/14/2014	-18	False PM - Fan Coil/HV/AC Unit	193-FCU-001
FO-274001	2/28/2014	1/29/2014		3/14/2014	44	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Finished 1/30/2014LT	155-AHU-002
FO-274002	2/28/2014		2/27/2014	3/14/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	155-AHU-003
FO-269839	3/1/2014	3/22/2014		3/15/2014	-7	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-001
FO-269840	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-001A
FO-269841	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-001B
FO-269842	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-002A
FO-269843	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-002B
FO-269844	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-003A1
FO-269845	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-003A2
FO-269846	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-003B2
FO-269847	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-003B1
FO-269848	3/1/2014	3/22/2014		3/15/2014	-7	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-005A
FO-269849	3/1/2014	3/22/2014		3/15/2014	-7	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-005B
FO-269850	3/1/2014	3/22/2014		3/15/2014	-7	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-006A
FO-269851	3/1/2014	3/22/2014		3/15/2014	-7	False PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-006B
FO-269852	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-010A
FO-269853	3/1/2014			3/15/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	609-EXF-010B
FO-273946	2/22/2014		2/25/2014	3/15/2014	True	PM - Air Handling Unit	022-AHU-001
FO-274628	3/1/2014			3/15/2014	False	PM - Air Handling Unit, HV Type	067-AHU-100
FO-274588	3/2/2014		2/27/2014	3/16/2014	True	PM - Fan Coil/HV/AC Unit	022-HVU-001
FO-274589	3/2/2014		4/1/2014	3/16/2014	False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	022-RAF-001
FO-274591	3/2/2014		2/27/2014	3/16/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	603-EXF-004-A-P
FO-274679	3/2/2014		2/27/2014	3/16/2014	True	PM - Fan Coil/HV/AC Unit	022-HVU-002

Request Finish Complete Due KPI WND								Total per Trade
FO-274592	3/3/2014		2/27/2014	3/17/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	603-EXF-004-B-P
FO-274614	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.9B
FO-274615	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.9A
FO-274616	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-215518A
FO-274617	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-215518B
FO-274618	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.3
FO-274619	3/4/2014	3/1/2014		3/18/2014	17	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.4
FO-274620	3/4/2014	3/19/2014		3/18/2014	-1	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.5B
FO-274621	3/4/2014	3/15/2014		3/18/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.5A
FO-274622	3/4/2014	3/15/2014		3/18/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.6
FO-274623	3/4/2014	3/15/2014		3/18/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-2155.7
FO-274003	2/27/2014		2/27/2014	3/20/2014		True	PM - Air Handling Unit	026-AHU-003
FO-274831	3/6/2014		2/7/2014	3/20/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-009
FO-274832	3/6/2014		2/7/2014	3/20/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	080-RAF-010
FO-274004	2/28/2014		2/27/2014	3/21/2014		True	PM - Air Handling Unit	155-AHU-001
FO-274005	2/28/2014		2/27/2014	3/21/2014		True	PM - Air Handling Unit	150-AHU-001
FO-274006	2/28/2014	1/30/2014		3/21/2014	50	False	PM - Air Handling Unit	150-AHU-002
FO-274827	3/7/2014		2/7/2014	3/21/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	082-RAF-001
FO-274828	3/7/2014		2/7/2014	3/21/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	082-RAF-002
FO-273385	2/20/2014			3/22/2014		False	PM - Fan Coil/HV/AC Unit	001-FCU-4349
FO-274626	3/1/2014	3/26/2014		3/22/2014	-4	False	PM - Air Handling Unit	140-AHU-002
FO-274627	3/1/2014	3/28/2014		3/22/2014	-6	False	PM - Air Handling Unit	140-AHU-001
FO-274590	3/4/2014		2/27/2014	3/25/2014		True	PM - Air Handling Unit	026-AHU-005
FO-274624	3/4/2014		2/27/2014	3/25/2014		True	PM - Air Handling Unit	026-AHU-004
FO-274625	3/4/2014		2/27/2014	3/25/2014		True	PM - Air Handling Unit	026-AHU-006
FO-274632	3/4/2014		2/27/2014	3/25/2014		True	PM - Air Handling Unit	091-AHU-002
FO-275314	3/11/2014	3/22/2014		3/25/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-3108.1
FO-275315	3/11/2014		4/1/2014	3/25/2014		False	PM - Fan Coil/HV/AC Unit	001-FCU-3109
FO-275316	3/11/2014	3/22/2014		3/25/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-3118
FO-275317	3/11/2014	3/22/2014		3/25/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-3132
FO-275318	3/11/2014	3/22/2014		3/25/2014	3	False	PM - Fan Coil/HV/AC Unit	001-FCU-3141.1
FO-275319	3/11/2014	3/11/2014		3/25/2014	14	False	PM - Fan Coil/HV/AC Unit	001-FCU-3141.5

Request Finish Complete Due KPI WND								Total per Trade
FO-275320	3/11/2014	3/25/2014	3/25/2014	0	False	PM - Fan Coil/HV/AC Unit		001-FCU-3201
FO-275321	3/11/2014	3/25/2014	3/25/2014	0	False	PM - Fan Coil/HV/AC Unit		001-FCU-3213
FO-275322	3/11/2014	3/25/2014	3/25/2014	0	False	PM - Fan Coil/HV/AC Unit		001-FCU-3315
FO-275323	3/11/2014	3/25/2014	3/25/2014	0	False	PM - Fan Coil/HV/AC Unit		001-FCU-3317
FO-275324	3/11/2014	3/26/2014	3/25/2014	-1	False	PM - Fan Coil/HV/AC Unit		001-FCU-3332
FO-275325	3/11/2014	3/26/2014	3/25/2014	-1	False	PM - Fan Coil/HV/AC Unit		001-FCU-3343
FO-275312	3/12/2014	2/27/2014	3/26/2014		True	PM - Unit/Space Heater		141-UNH-001
FO-275313	3/12/2014	2/27/2014	3/26/2014		True	PM - Unit/Space Heater		141-UNH-002
FO-274829	3/6/2014	2/7/2014	3/27/2014		True	PM - Air Handling Unit		016-AHU-004
FO-274830	3/6/2014	2/7/2014	3/27/2014		True	PM - Air Handling Unit		016-AHU-005
FO-275456	3/13/2014	2/27/2014	3/27/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		080-RAF-011
FO-275457	3/13/2014	2/27/2014	3/27/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		080-RAF-012
FO-275454	3/14/2014	2/27/2014	3/28/2014		True	PM - Unit/Space Heater		155-UNH-001
FO-275455	3/14/2014	2/27/2014	3/28/2014		True	PM - Unit/Space Heater		155-UNH-002
FO-276554	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-001
FO-276555	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-002
FO-276556	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-003
FO-276557	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-004
FO-276558	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-005
FO-276559	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-FCU-006
FO-276560	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-HVU-001
FO-276561	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-HVU-002
FO-276562	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-HVU-003
FO-276563	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-HVU-004
FO-276564	3/24/2014	2/27/2014	3/29/2014		True	PM - Fan Coil/HV/AC Unit		016-HVU-005
FO-275923	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-001
FO-275924	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-EF1B
FO-275925	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-002OA
FO-275926	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-003OA
FO-275927	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-004OA
FO-275928	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-006-1
FO-275929	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-006-2
FO-275930	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-007
FO-275931	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-012-1
FO-275932	3/16/2014	2/27/2014	3/30/2014		True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		001-EXF-012-2

Request Finish Complete Due KPI WND							Total per Trade	
FO-275933	3/16/2014		2/27/2014	3/30/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	001-EXF-013	
FO-275934	3/16/2014		2/27/2014	3/30/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	001-EXF-016B	
FO-275935	3/16/2014		2/27/2014	3/30/2014	True	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	001-EXF-019A	
251		147		13.3		83		
E - South							21 of 39	54%
FO-274551	2/15/2014	2/5/2014		3/1/2014	24	False	PM - Domestic Water Heater, Electric	090-DHW-002
FO-274552	2/15/2014	2/5/2014		3/1/2014	24	False	PM - Centrifugal Pump, over 1 H.P.	090-DWBP-001
FO-274583	2/15/2014	2/5/2014		3/1/2014	24	False	PM - Domestic Water Heater, Electric	090-DHW-003
FO-275898	3/1/2014	3/5/2014		3/1/2014	-4	False	PM - Bi Annual Inspection of Glycol	089-AHU-003
FO-275899	3/1/2014	3/5/2014		3/1/2014	-4	False	PM - Bi Annual Inspection of Glycol	089-AHU-004
FO-274546	2/16/2014	2/17/2014		3/2/2014	13	False	PM - Deaerator Tank	089-DAT-001
FO-274547	2/16/2014	2/17/2014		3/2/2014	13	False	PM - Domestic Water Heater, Gas	089-BSG-HW1
FO-274554	2/16/2014	2/17/2014		3/2/2014	13	False	PM - Vacuum Pump	089-VP-001**
FO-274555	2/16/2014	2/17/2014		3/2/2014	13	False	PM - Vacuum Pump	089-VP-002**
FO-274581	2/12/2014			3/2/2014		False	Replace Chemistry PreFilters (AHU-1A/2A) North End	007-AHU-001
FO-273207	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-541A
FO-273208	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-541B
FO-273209	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-542
FO-273210	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-543
FO-273211	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-544
FO-273212	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-545
FO-273213	2/4/2014	2/3/2014	3/19/2014	3/6/2014	31	False	PM - Water Booster Pump	090-ECP-546
FO-273214	2/4/2014	2/6/2014		3/6/2014	28	False	PM - Water Booster Pump	090-ERP-542
FO-273931	2/8/2014	2/19/2014		3/10/2014	19	False	PM - Monthly AHU Inspection Clean Room Unit 1	090-ACU-CR1
FO-276527	3/11/2014	3/18/2014		3/12/2014	-6	False	Generator Maintenance, Monthly	090-GEN-001
FO-277228	3/12/2014	3/13/2014		3/12/2014	-1	False	Generator Maintenance, Monthly	089-GEN-001
FO-275912	3/4/2014	3/6/2014		3/18/2014	12	False	PM - Water Softener	090-WSS-001
FO-277747	3/20/2014	3/28/2014		3/21/2014	-7	False	Generator Maintenance, Monthly	007-GEN-001
FO-277749	3/20/2014	3/28/2014		3/21/2014	-7	False	Generator Maintenance, Monthly	007-GEN-002
FO-277764	3/20/2014	3/13/2014		3/21/2014	8	False	Generator Maintenance, Monthly	090-GEN-002
FO-276522	3/8/2014	3/7/2014		3/22/2014	15	False	Monthly AHU Inspection Clean Room Unit 2	090-ACU-CR2
FO-278108	3/25/2014			3/25/2014		False	PM - Water/Air Cooled Condenser	008-ACU-001
FO-278109	3/25/2014			3/25/2014		False	PM - Water/Air Cooled Condenser	008-ACU-002
FO-277769	3/27/2014	3/28/2014		3/27/2014	-1	False	Generator Maintenance, Monthly	006-GEN-001
FO-277249	3/15/2014	3/10/2014		3/29/2014	19	False	PM - Centrifugal Pump, over 1 H.P.	090-ERP-541

Request	Finish	Complete	Due	KPI	WND	Total per Trade	
FO-277250	3/15/2014	3/10/2014	3/29/2014	19	False	PM - Centrifugal Pump, over 1 H.P.	090-ERP-542
FO-277742	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-007
FO-277743	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-006
FO-277744	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-005
FO-277745	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-004
FO-277746	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-003
FO-277770	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-002
FO-277771	3/15/2014		3/29/2014		False	Replace PRE-filters	007-AHU-001
FO-277245	3/15/2014		3/30/2014		False	Replace Chemistry Exhaust Air Filters (FUME HOODS) North End	007-AHU-001

39

28

15.4 0

## E - Southeast

6 of 21 29%

FO-275905	3/1/2014	3/31/2014	3/1/2014	-30	False	PM - Water/Air Cooled Condenser	637-ACU-005	completed
FO-273189	2/1/2014		3/3/2014		False	PM - Air Intake Dampers (Old Main)	001-AHU-001MU	
FO-273190	2/1/2014		3/3/2014		False	PM - Air Intake Dampers (Old Main)	001-AHU-002MU	
FO-273191	2/1/2014		3/3/2014		False	PM - Air Intake Dampers (Old Main)	001-AHU-003MU	
FO-273926	2/6/2014	1/21/2014	3/8/2014	46	False	PM - Heat Pumps (5057 Woodward)	071-HWP-206	
FO-273927	2/6/2014	1/21/2014	3/8/2014	46	False	PM - Heat Pumps (5057 Woodward)	071-HWP-207	
FO-273928	2/6/2014	1/21/2014	3/8/2014	46	False	PM - Heat Pumps (5057 Woodward)	071-HWP-208	
FO-273929	2/6/2014	1/21/2014	3/8/2014	46	False	PM - Heat Pumps (5057 Woodward)	071-HWP-209	
FO-275298	2/22/2014	2/24/2014	3/8/2014	12	False	PM - Heat Exchanger and Economizer	189-HEX-001	Heat exchanger is out of service
FO-275299	2/22/2014	2/24/2014	3/8/2014	12	False	PM - Heat Exchanger and Economizer	499-HEX-006	inspected heat exchanger and operation
FO-276530	3/11/2014	3/31/2014	3/12/2014	-19	False	Generator Maintenance, Monthly	637-GEN-001	Checked fluids and belts
FO-276532	3/11/2014	3/31/2014	3/12/2014	-19	False	Generator Maintenance, Monthly	637-GEN-002	checked fluids and belts
FO-274548	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-018A	
FO-274549	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-019A	
FO-274550	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-020A	
FO-274557	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-018B	
FO-274558	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-019B	
FO-274559	2/14/2014		3/16/2014		False	PM - Sump Pump	001-SP-020B	
FO-272700	1/24/2014		3/25/2014		False	PM - Water Booster Pump	001-DWBP-001	
FO-272701	1/24/2014		3/25/2014		False	PM - Water Booster Pump	001-DWBP-002	
FO-277209	3/12/2014		3/26/2014		False	PM - Domestic Water Heater, Electric	188-DHW-001	

Request Finish Complete Due KPI WND										Total per Trade	
21		9		15.6		0					
E - West										2 of 7	29%
FO-274556	2/15/2014	2/25/2014	3/1/2014	4	False	PM - Domestic Water Heater, Electric			003-DHW-001		
FO-274560	2/15/2014	2/25/2014	3/1/2014	4	False	PM - Domestic Water Heater, Electric			003-DHW-002		
FO-274563	2/15/2014	3/5/2014	3/1/2014	-4	False	PM - Domestic Water Heater, Electric			166-DHW-001		
FO-274564	2/15/2014	3/5/2014	3/1/2014	-4	False	PM - Domestic Water Heater, Electric			166-DHW-002		
FO-275913	3/4/2014		3/5/2014		False	Generator Maintenance, Monthly			195-GEN-001 SPARE from TechTwn		
FO-272703	1/22/2014		3/23/2014		False	PM - Centrifugal Pump, over 1 H.P.			155-HWP-001		
FO-272704	1/22/2014		3/23/2014		False	PM - Centrifugal Pump, over 1 H.P.			155-HWP-002		
7		4		0.0		0					

<b>Trades</b>										<b>15 of 37</b>	<b>41%</b>
<b>T - Electrician</b>										<b>13 of 35</b>	<b>37%</b>
FO-275332	2/28/2014		3/1/2014		False	Generator Test			611-GEN-001		
FO-275334	2/28/2014		3/1/2014		False	Generator Test			629-GEN-001		
FO-275900	3/4/2014		3/5/2014		False	Generator Test			501-GEN-001		
FO-276533	3/5/2014		3/6/2014		False	Generator Test			507-GEN-001		
FO-276538	3/8/2014	3/13/2014	3/9/2014	-4	False	Generator Test, Wednesday 3/12/2014 @ 9:15 AM. Finished 3/14/2014LT			060-GEN-001 (Towable)		
FO-276528	3/11/2014	3/18/2014	3/11/2014	-7	False	Generator Test, Tuesday 3/18/2014 @ 9:30 AM.			090-GEN-001		
FO-276537	3/10/2014	3/11/2014	3/11/2014	0	False	Generator Test, Tuesday 3/11/2014 @ 7:15 AM. Finished 3/12/2014LT			195-GEN-001 SPARE from TechTwn		
FO-276526	3/11/2014	3/18/2014	3/12/2014	-6	False	Generator Test, Tuesday 3/18/2014 @ 7:15 AM.			609-GEN-001		
FO-276529	3/11/2014	3/18/2014	3/12/2014	-6	False	Generator Test, Tuesday 3/18/2014 @ 8:15 AM.			637-GEN-001		
FO-276531	3/11/2014	3/18/2014	3/12/2014	-6	False	Generator Test, Tuesday 3/18/2014 @ 8:15 AM.			637-GEN-002		
FO-276535	3/11/2014	3/18/2014	3/12/2014	-6	False	Generator Test, Tuesday 3/18/2014 @ 9:15 AM.			203-GEN-001		
FO-277241	3/12/2014	3/19/2014	3/12/2014	-7	False	Generator Test, Wednesday 3/19/2014 @ 7:15 AM. Finished 3/21/2014LT			536-GEN-001		
FO-277229	3/12/2014	3/19/2014	3/13/2014	-6	False	Generator Test, Wednesday 3/19/2014 @ 10AM. Finished 3/21/2014LT			089-GEN-001		
FO-277251	3/13/2014		3/13/2014		False	Generator Test, Friday 3/14/2014 @ 7:15 AM.			048-GEN-001		
FO-277242	3/14/2014	3/7/2014	3/14/2014	7	False	Generator Test, Friday 3/7/2014 @ 7:15 AM. Finished 3/11/2014LT			608-GEN-001		
FO-277230	3/14/2014	3/7/2014	3/15/2014	8	False	Generator Test, Friday 3/7/2014 @ 2:15 PM. Finished 3/11/2014LT			193-GEN-001		



Request	Finish	Complete	Due	KPI	WND		Total per Trade
FO-277252	3/14/2014	3/7/2014	3/15/2014	8	False	Generator Test, Friday 3/7/2014 @ 2:15 PM. Finished 3/11/2014LT	193-GEN-002
FO-277253	3/14/2014	3/7/2014	3/15/2014	8	False	Generator Test, Friday 3/7/2014 @ 2:15 PM. Finished 3/11/2014LT	193-GEN-003
FO-277254	3/14/2014	3/7/2014	3/15/2014	8	False	Generator Test, Friday 3/7/2014 @ 2:15 PM. Finished 3/11/2014LT	193-GEN-004
FO-277231	3/18/2014	3/25/2014	3/18/2014	-7	False	Generator Test, Tuesday 3/25/2014 @ 10AM. Finished 3/27/2014LT	104-GEN-001
FO-277233	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Test, Tuesday 3/25/2014 @ 8AM. Finished 3/27/2014LT	127-GEN-001
FO-277235	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Test, Tuesday 3/25/2014 @ 8AM. Finished 3/27/2014LT	127-GEN-002
FO-277237	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Test, Tuesday 3/25/2014 @ 8AM. Finished 3/27/2014LT	127-GEN-003
FO-277239	3/18/2014	3/25/2014	3/19/2014	-6	False	Generator Test, Tuesday 3/25/2014 @ 8AM. Finished 3/27/2014LT	127-GEN-004
FO-277752	3/19/2014	3/26/2014	3/20/2014	-6	False	Generator Test, Wednesday 3/26/2014 @ 7:15 AM.Finished 3/27/2014LT	066-GEN-001
FO-277757	3/19/2014	3/26/2014	3/20/2014	-6	False	Generator Test, Wednesday 3/26/2014 @ 7:15 AM.Finished 3/27/2014LT	130-GEN-001
FO-277748	3/20/2014	3/13/2014	3/21/2014	8	False	Generator Test, Thursday 3/13/2014 @ 7:15 AM. Finished 3/14/2014LT	007-GEN-001
FO-277750	3/20/2014	3/13/2014	3/21/2014	8	False	Generator Test, Thursday 3/13/2014 @ 7:15. Finished 3/14/2014LT	007-GEN-002
FO-277763	3/20/2014	3/13/2014	3/21/2014	8	False	Generator Test, Thursday 3/13/2014 @7:15 AM. Finished 3/14/2014LT	090-GEN-002
FO-277759	3/21/2014	3/24/2014	3/22/2014	-2	False	Generator Test, Friday 3/14/2014 @ 7:15 AM.Finished 3/27/2014LT	612-GEN-001
FO-277761	3/21/2014	3/24/2014	3/22/2014	-2	False	Generator Test, Friday 3/14/2014 @ 7:15 AM.Finished 3/27/2014LT	612-GEN-002
FO-277765	3/27/2014	3/20/2014	3/27/2014	7	False	Generator Test Thursday 3/20/14 @ 7:15 AM. Finished 3/21/2014LT	527-GEN-001
FO-277768	3/27/2014	3/20/2014	3/27/2014	7	False	Generator Test Thursday, 3/20/14 @ 7:15 AM. Finished 3/21/2014LT	006-GEN-001
FO-277753	3/28/2014	3/28/2014	3/29/2014	1	False	Generator Test Finished 3/31/2014LT	611-GEN-001
FO-277755	3/28/2014	3/28/2014	3/29/2014	1	False	Generator Test Finished 3/31/2014LT	629-GEN-001
<b>35</b>		<b>30</b>		<b>-0.5</b>	<b>0</b>		
<b>T - Plumber</b>							<b>2 of 2      100%</b>
FO-276104	2/19/2014	2/28/2014	3/3/2014	3	False	PM - Sump Pump suction line needs replaced, lock on breaker LT 37 ,,,,,,,,,, RJC/RB 2-21-14 ,,,,,,,,,, DUE ASAP Finished 3/3/2014LT	027-SP-001

Request Finish Complete Due KPI WND										Total per Trade	
FO-276107	2/19/2014	2/28/2014	3/3/2014	3	False	PM - Sump Pump pump suction line needs a more ridgid coupling,temporary rubber coupling in use now ,,,,,,,,,, RJC/RB 2-21-14 ,,,,,,,,,, DUE ASAP Finished 3/3/2014LT				027-SP-004	
2		2	3.0		0						
Report Total: 510		311	8.6		85	239 of 510 47%					