

# DRAFT Facilities Operations PM Analysis from 6/1/2014 through 6/30/2014

Requested Finished Open WND										% Finished	
Engineering			552	424	128	22					77%
E - Auxiliary			30	9	21	0					30%
FO-284793	Finished	034-AIR-001	6/1/2014	6/26/2014		False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.			
Checked oil, filter and dryer. Cleaned area.											
FO-284794	Finished	034-AIR-002	6/1/2014	6/26/2014		False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.			
Checked oil, filter and dryer. Cleaned area.											
FO-284796	Created By PM Schedule	134-AHU-001	6/1/2014			False		PM - Air Handling Unit			
FO-284797	Created By PM Schedule	134-AHU-002	6/1/2014			False		PM - Air Handling Unit			
FO-284798	Created By PM Schedule	127-MAU-005	6/1/2014			False		PM - Fan Coil/HV/AC Unit			
FO-284799	Created By PM Schedule	501-ACU-001	6/1/2014			False		PM - Water/Air Cooled Condenser			
FO-284800	Created By PM Schedule	992-ES-001*	6/2/2014			False		PM - Emergency Shower/Eyewash Station			
FO-284804	Created By PM Schedule	134-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-284805	Created By PM Schedule	127-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-284806	Created By PM Schedule	115-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-284807	Created By PM Schedule	104-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-284808	Created By PM Schedule	507-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-285227	Created By PM Schedule	501-GEN-001	6/10/2014			False		Generator Maintenance, Monthly			
FO-285229	Created By PM Schedule	992-ES-001*	6/9/2014			False		PM - Emergency Shower/Eyewash Station			
FO-285552	Finished	104-GEN-001	6/24/2014	6/24/2014		False	0.75	Generator Maintenance, Monthly			
The generator has a leak.											
FO-285554	Finished	127-GEN-001	6/24/2014	6/24/2014		False	0.75	Generator Maintenance, Monthly			
Noticed no issues.											
FO-285556	Finished	127-GEN-002	6/24/2014	6/24/2014		False	0.10	Generator Maintenance, Monthly			
Noticed no issues.											
FO-285558	Finished	127-GEN-003	6/24/2014	6/24/2014		False	0.10	Generator Maintenance, Monthly			
Noticed no issues.											
FO-285560	Finished	127-GEN-004	6/24/2014	6/24/2014		False	0.10	Generator Maintenance, Monthly			
Noticed no issues.											
FO-285572	Created By PM Schedule	507-GEN-001	6/11/2014			False		Generator Maintenance, Monthly			
FO-285578	Created By PM Schedule	536-GEN-001	6/11/2014			False		Generator Maintenance, Monthly			
FO-285925	Created By PM Schedule	992-ES-001*	6/16/2014			False		PM - Emergency Shower/Eyewash Station			
FO-285930	Created By PM Schedule	134-ACU-001	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers			
FO-285947	Created By PM Schedule	507-ACU-001	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers			
FO-286708	Created By PM Schedule	025-UNH-001	6/22/2014			False		PM - Unit/Space Heater			
FO-286709	Created By PM Schedule	025-UNH-002	6/22/2014			False		PM - Unit/Space Heater			
FO-286745	Finished	034-AHU-001	6/19/2014	6/30/2014		False	2.00	PM - Air Handling Unit			
Changed pre-filters, checked belts and alignment, lubed motor and bearings.											
FO-286746	Finished	034-AHU-002	6/19/2014	6/30/2014		False	0.50	PM - Air Handling Unit			
AHU is out of service and will be renovated along with the North half of the building.											
FO-286747	Created By PM Schedule	034-AHU-003	6/19/2014			False		PM - Air Handling Unit			
FO-286748	Created By PM Schedule	992-ES-001*	6/23/2014			False		PM - Emergency Shower/Eyewash Station			

<b>E - Command Center</b>			<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>			<b>100%</b>
FO-285928	Finished	080-BSG-002	6/13/2014	6/14/2014		False		Boiler Rear Refractory Inspection - 48" Boiler	
FO-285929	Finished	080-BSG-001	6/13/2014	6/14/2014		False		Boiler Rear Refractory Inspection - 48" Boiler	
<b>E - Director</b>			<b>1</b>	<b>0</b>	<b>1</b>	<b>1</b>			<b>0%</b>
FO-284801	Completed	026-ACU-004	6/1/2014			True		PM - Carrier Chillers: Start Up Services for Centrifugal Chillers	
<b>E - MedPharm</b>			<b>32</b>	<b>7</b>	<b>25</b>	<b>0</b>			<b>22%</b>
FO-284754	Finished	609-ECO-001	6/3/2014	6/24/2014		False		PM - Heat Exchanger and Economizer	
FO-284755	Created By PM Schedule	511-AIR-001C**	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284756	Created By PM Schedule	629-AIR-001	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284757	Finished	629-ROS-001	6/1/2014	6/1/2014		False	1.00	PM - Reverse Osmosis Water Softener System	
worked with Siemens water...both booster pumps leaking. Have reported this issue several times									
FO-284758	Created By PM Schedule	612-AIR-001	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284759	Created By PM Schedule	612-AIR-002	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284760	Created By PM Schedule	612-AIR-003	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284762	Created By PM Schedule	611-AIR-001	6/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-284763	Created By PM Schedule	612-FP-001	6/1/2014			False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-285173	Created By PM Schedule	603-PCW-001	6/8/2014			False		PM - Centrifugal Pump, over 1 H.P.	
FO-285174	Created By PM Schedule	603-PCW-002	6/9/2014			False		PM - Centrifugal Pump, over 1 H.P.	
FO-285175	Created By PM Schedule	603-SP-001*	6/8/2014			False		PM - Sump Pump	
FO-285176	Created By PM Schedule	603-SP-002*	6/8/2014			False		PM - Sump Pump	
FO-285177	Created By PM Schedule	611-HVU-001**	6/9/2014			False		PM - Fan Coil/HV/AC Unit	
FO-285178	Created By PM Schedule	611-HVU-004**	6/9/2014			False		PM - Fan Coil/HV/AC Unit	
FO-285179	Created By PM Schedule	603-CRP-001	6/6/2014			False		PM - Condensate Return Pump	
FO-285180	Created By PM Schedule	603-CRP-002	6/6/2014			False		PM - Condensate Return Pump	
FO-285181	Finished	608-GEN-001	6/6/2014	6/20/2014		False	4.00	Generator Maintenance, Monthly Jonathan Keys-PM COMPLETED. FOUND LOW NATURAL GAS PRESSURE CAUSING ISSSUE WITH UNIT. DTE CAME OUT INSPECTED MAIN REGULATOR. ONLY 1LB BEING SUPPLIED. REGULATOR REPAIRED BY DTE	
FO-285182	Finished	629-WSS-001	6/4/2014	6/4/2014		False		PM - Water Softener	
heads replaced and repiped									
FO-285548	Created By PM Schedule	611-GEN-001	6/27/2014			False		Generator Maintenance, Monthly	
FO-285550	Created By PM Schedule	629-GEN-001	6/27/2014			False		Generator Maintenance, Monthly	
FO-285568	Finished	612-GEN-001	6/13/2014	6/13/2014		False		Generator Maintenance, Monthly	
FO-285570	Finished	612-GEN-002	6/13/2014	6/13/2014		False		Generator Maintenance, Monthly	
FO-285581	Finished	609-GEN-001	6/17/2014	6/24/2014		False		Generator Maintenance, Monthly	
checked battery and fluids									
FO-285940	Created By PM Schedule	612-ACU-002	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285941	Created By PM Schedule	612-ACU-001	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285942	Created By PM Schedule	611-ACU-002**	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285943	Created By PM Schedule	611-ACU-001**	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285944	Created By PM Schedule	608-ACU-001	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285945	Created By PM Schedule	603-ACU-002	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285946	Created By PM Schedule	603-ACU-001	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	
FO-285950	Created By PM Schedule	608-ACU-002	6/15/2014			False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers	

E - North

19

16

3

0

84%

# Requested Finished Open WND

% Finished

FO-284766	Finished	140-AIR-001	6/1/2014	6/6/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-284767	Finished	140-AIR-002	6/1/2014	6/6/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-284768	Finished	050-AIR-001	6/1/2014	6/23/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-284769	Finished	050-AIR-002	6/1/2014	6/23/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P. Carl Smith-changed oil
FO-284770	Finished	130-AIR-001	6/1/2014	6/9/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-284771	Finished	062-AIR-001	6/1/2014	6/3/2014	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-284772	Finished	130-AHU-001	6/2/2014	6/9/2014	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-285566	Finished	130-GEN-001	6/25/2014	6/25/2014	False		Generator Maintenance, Monthly
FO-285583	Finished	048-GEN-001	6/13/2014	6/10/2014	False	1.50	Generator Maintenance, Monthly This generator has not been turned-over to me and I do not have the access key, but contractor arrived and I assisted him with preventive maintenance on the gas motor and he did a four hour load test.
FO-285885	Finished	049-DWBP-002	6/13/2014	6/26/2014	False	0.50	PM - Water Booster Pump
FO-285886	Finished	043-AHU-INT	6/15/2014	6/17/2014	False	2.00	PM - Outside/Fresh Air Intake Screens Cleared fresh air grills of debris.
FO-285887	Finished	049-HWP-001	6/11/2014	6/26/2014	False	0.50	PM - Water Booster Pump
FO-285888	Finished	130-AHU-001	6/16/2014	6/20/2014	False	2.00	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units] Carl Smith-grease bearing
FO-285951	Finished	026-ACU-004	6/15/2014	6/2/2014	False	1.00	PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers Dean Schweinsberg-unit was checked by Tech quote to sent to AD
FO-286703	Created By PM Schedule	048-DHW-001	6/20/2014		False		PM - Domestic Water Heater, Steam
FO-286704	Created By PM Schedule	048-HEX-003	6/20/2014		False		PM - Heat Exchanger and Economizer
FO-286705	Created By PM Schedule	048-EW-001	6/18/2014		False		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-286706	Finished	048-DWBP-001	6/20/2014	6/27/2014	False	0.50	PM - Water Booster Pump No problems to note.
FO-286707	Finished	048-DWBP-002	6/20/2014	6/27/2014	False	0.50	PM - Water Booster Pump No problems to note.
<b>E - Northeast</b>			<b>18</b>	<b>16</b>	<b>2</b>	<b>0</b>	<b>89%</b>
FO-285183	Finished	193-GEN-001	6/6/2014	6/6/2014	False	0.50	Generator Maintenance, Monthly
FO-285184	Finished	193-GEN-002	6/6/2014	6/6/2014	False	0.50	Generator Maintenance, Monthly
FO-285185	Finished	193-GEN-003	6/6/2014	6/6/2014	False	0.50	Generator Maintenance, Monthly
FO-285186	Finished	193-GEN-004	6/6/2014	6/6/2014	False	1.00	Generator Maintenance, Monthly
FO-285545	Finished	066-GEN-001	6/25/2014	5/9/2014	False	1.00	Generator Maintenance, Monthly Mark Bobick-completed
FO-285574	Finished	203-GEN-001	6/17/2014	6/17/2014	False	0.50	Generator Maintenance, Monthly
FO-285580	Finished	527-GEN-001	6/19/2014	6/19/2014	False	1.50	Generator Maintenance, Monthly Worked with elect. checked oil, belts, lovers coolant etc.
FO-285889	Created By PM Schedule	195-UNH-001	6/13/2014		False		PM - Unit/Space Heater
FO-285890	Created By PM Schedule	062-DHW-006	6/12/2014		False		PM - Domestic Water Heater, Gas
FO-285891	Finished	062-DHW-005	6/12/2014	6/12/2014	False	0.50	PM - Domestic Water Heater, Gas
FO-285892	Finished	062-DHW-004	6/12/2014	6/12/2014	False	0.50	PM - Domestic Water Heater, Gas
FO-285893	Finished	062-DHW-003	6/12/2014	6/12/2014	False	0.50	PM - Domestic Water Heater, Gas
FO-285894	Completed	062-DHW-002	6/12/2014	6/12/2014	False	1.00	PM - Domestic Water Heater, Gas
FO-285895	Finished	062-DHW-001	6/12/2014	6/12/2014	False	0.50	PM - Domestic Water Heater, Gas

**Requested Finished Open WND**

**% Finished**

FO-285949	Finished	067-ACU-109	6/15/2014	5/28/2014	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Mark Bobick-completed unit has low charge on one circuit. York will repair.
FO-285949	Finished	067-ACU-109	6/15/2014	5/28/2014	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Mark Bobick-completed unit has low charge on one circuit. York will repair.
FO-285949	Finished	067-ACU-109	6/15/2014	5/28/2014	False	1.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Mark Bobick-completed. low charge on one circuit. PO created for repair.
FO-285955	Finished	065-ACU-001	6/15/2014	5/16/2014	False	1.00	PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers Mark Bobick-completed. two condenser fans replaced.
<b>E - Preventative Maintenance</b>		<b>288</b>	<b>265</b>	<b>23</b>	<b>19</b>	<b>92%</b>	
FO-277452	Finished	005-AHU-002	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Thomas Townsel-Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-277452	Finished	005-AHU-002	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Timothy Bowman-vChecked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-277452	Finished	005-AHU-002	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Morris Mims-Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-277453	Finished	005-AHU-001	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Thomas Townsel-Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-277453	Finished	005-AHU-001	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Timothy Bowman-Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-277453	Finished	005-AHU-001	6/1/2014	6/20/2014	False	9.00	Replace PRE-filters Morris Mims-Checked supply and return fan operation,changed air filters,lubed motor and fan bearings. Adjusted belts.
FO-283384	Finished	005-EXF-013	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283385	Finished	005-EXF-014	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283386	Finished	050-RAF-001	6/1/2014	6/11/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283387	Finished	31-FCU-003ANT	6/4/2014	7/1/2014	False	0.50	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Lubricated motor. Changed filter. Replaced cover, test ran and returned to service.
FO-283388	Finished	01-FCU-003LOB	6/4/2014	6/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. Removed covers. Inspected coil, valves, and piping. Cleaned interior. Changed filters. Replaced covers and returned to service. Disposed of old filters.
FO-283389	Finished	001-FCU-3121	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-283390	Finished	001-FCU-3129	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-283391	Finished	301-FCU-3133-1	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-283392	Finished	301-FCU-3133-2	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.

**Requested Finished Open WND**

**% Finished**

FO-283393	Finished	001-FCU-3133-3	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-283394	Finished	001-FCU-3133-4	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-283395	Finished	001-FCU-3133-5	6/4/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-283396	Finished	001-FCU-3134-1	6/4/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-283397	Finished	001-FCU-3134-2	6/4/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-283398	Finished	001-FCU-3134-3	6/4/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-283399	Finished	001-FCU-3134-4	6/4/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-283400	Finished	039-EXF-001	6/1/2014	6/28/2014	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt- tension wear and alignment. Lubricate fan and motor bearings. Check fan operation (This fan is mislabeled it is actually a return air fan for the auditorium.) Cleaning fan housing. Cleaning fan room.
FO-283401	Finished	039-EXF-004	6/1/2014	6/12/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Lubricated fan and motor bearings. Inspected belt. Cleaned area. Test ran and returned to service.
FO-283402	Finished	039-EXF-005	6/1/2014	6/28/2014	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Check belt- tension wear and alignment. Lubricate fan and motor bearings. Check fan operation. Cleaning fan housing (unit is almost rusted through and needs to be painted.) Cleaning fan room.
FO-283403	Finished	040-EXF-002	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283404	Finished	040-EXF-003	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283405	Finished	040-EXF-005	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283406	Finished	040-EXF-006	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283407	Finished	040-EXF-007	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283408	Finished	040-EXF-008	6/1/2014	6/11/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283409	Finished	040-EXF-009	6/1/2014	6/11/2014	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.

Requested Finished Open WND

% Finished

FO-283410	Finished	040-EXF-010	6/1/2014	6/11/2014	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Roman Wojtowicz-Shut down fan. Checked motor and fan. Checked belt. Added oil to fan bearings. Lubricated motor. Lubricated and exercised dampers. Replaced cover. Test ran and returned to service.
FO-283411	Finished	040-EXF-011	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt Adjusted belt- tension and alignmentLubricate fan and motor bearingsCheck fan operation Cleaning fan room
FO-283412	Finished	040-EXF-012	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt Adjusted belt- tension and alignmentLubricate fan and motor bearingsCheck fan operation Cleaning fan room
FO-283413	Finished	042-EXF-001	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt Adjusted belt- tension and alignmentLubricate fan and motor bearingsCheck fan operation Cleaning fan room
FO-283414	Finished	043-EXF-001	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Edward Nisnevich-Grease bearings, checked belt and found belt is broken(AP46), informed AD to order new belt.
FO-283415	Finished	043-EXF-002	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Edward Nisnevich-Greased bearings, checked belt tension and wear, cleaned up area around exhaust fan.
FO-283416	Finished	043-EXF-003	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Edward Nisnevich-Greased bearings, checked belt tension and wear, verified manual and automatic fan operation.
FO-283417	Finished	043-EXF-004	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Edward Nisnevich-Grease bearings, checked belts tension and wear, verified manual and automatic fan operation.
FO-283417	Finished	043-EXF-004	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Edward Nisnevich-Grease bearings, checked belts tension and wear, verified manual and automatic fan operation.
FO-283418	Finished	043-EXF-005	6/1/2014	6/28/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt- tension wear and alignmentLubricated bearingsCheck fan operation.
FO-283419	Finished	005-EXF-003	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing.
FO-283420	Finished	005-EXF-005	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283421	Finished	005-EXF-006	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283422	Finished	005-EXF-007	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283423	Finished	005-EXF-009	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283424	Finished	005-EXF-016	6/1/2014	6/19/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,lubed fan and motor bearings. Adjusted belts.
FO-283425	Finished	005-EXF-017	6/1/2014	6/19/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,lubed fan and motor bearings. Adjusted beltsChecked fan operation,lubed fan and motor bearings. Adjusted beltsChecked fan operation,lubed fan and motor bearings. Adjusted belts
FO-283426	Finished	005-EXF-018	6/1/2014	6/19/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,lubed fan and motor bearings. Adjusted belts
FO-283427	Finished	005-EXF-022	6/1/2014	6/19/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,lubed fan and motor bearings. Adjusted belts
FO-283428	Finished	005-EXF-023	6/1/2014	6/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.

**Requested Finished Open WND**

**% Finished**

FO-283429	Finished	005-EXF-034	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283430	Finished	005-EXF-037	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283431	Finished	005-EXF-038	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-, lubed fan and mChecked bearings.fan operationotor adjusted belts.
FO-283432	Finished	005-EXF-039	6/1/2014	6/27/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-Checked fan operation, Lubed fan and motor bearings. Adjusted belts.
FO-283433	Finished	005-EXF-040	6/1/2014	6/27/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-Checked fan opera bearings. Adjusted beltstion, lubed fan and motor.
FO-283434	Finished	005-EXF-041	6/1/2014	6/27/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-Checked fan opera bearings. Adjusted beltstion, lubed fan and motor.
FO-283435	Finished	005-EXF-042	6/1/2014	6/27/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-Checked fan opera bearings. Adjusted beltstion, lubed fan and motor.
FO-283436	Finished	005-EXF-043	6/1/2014	6/27/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Morris Mims-Checked fan opera bearings. Adjusted beltstion, lubed fan and motor.
FO-283437	Finished	006-EXF-001	6/1/2014	6/3/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, changed filters, lubed dampers,motor and bearings. Inspected belts.
FO-283438	Finished	006-EXF-002	6/1/2014	6/5/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed bearings and adjusted belts.
FO-283439	Finished	006-EXF-003	6/1/2014	6/5/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed bearings and adjusted belts
FO-283440	Finished	006-EXF-004	6/1/2014	6/5/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed bearings and adjusted belts
FO-283441	Finished	065-EXF-001A	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283442	Finished	065-EXF-001B	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283443	Finished	065-EXF-001C	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283444	Finished	065-EXF-002	6/1/2014	6/14/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283445	Finished	065-EXF-003	6/1/2014	6/14/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-283446	Finished	067-EXF-001	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsCheck operation
FO-283447	Finished	067-EXF-002	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsCheck fan operation.Fans need to be painted
FO-283448	Finished	067-EXF-003	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Check belt- tension wear and alignmentLubricate fan and motor bearingsCheck fan operation units are rusted and need to be painted.
FO-283449	Finished	067-EXF-004	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsCheck fan operation. unit is rusted and needs to be painted.
FO-283450	Finished	008-EXF-001	6/1/2014	6/28/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings . Adjusted belts.
FO-283451	Finished	008-EXF-002	6/1/2014	6/24/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings, adjusted belts.

**Requested Finished Open WND**

**% Finished**

FO-283452	Finished	005-EXF-030	6/1/2014	6/24/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings, adjusted belts.
FO-283453	Finished	005-EXF-031	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283454	Finished	005-EXF-032	6/1/2014	6/24/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings, adjusted belts.
FO-283455	Finished	005-EXF-033	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283456	Finished	005-EXF-035	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283457	Finished	005-EXF-036	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts
FO-283458	Finished	065-RAF-001	6/1/2014	6/21/2014	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Check belt- tension wear and alignment Lubricate fan and motor bearings Lubricate dampers and damper motor points Cleaning fan housing
FO-283459	Finished	005-EXF-004	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283460	Finished	005-EXF-008	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283461	Finished	005-EXF-015	6/1/2014	6/18/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,adjusted beltsand lubed motor and fan bearing
FO-283462	Finished	005-EXF-020	6/1/2014	6/19/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation,lubed fan and motor bearings. Adjusted belts
FO-283463	Finished	005-EXF-025	6/1/2014	6/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.
FO-283464	Finished	005-EXF-026	6/1/2014	6/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.Checked fan operation, lubed fan and motor bearings. Adjusted belts.
FO-283465	Finished	005-EXF-027	6/1/2014	6/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.
FO-283466	Finished	005-EXF-028	6/1/2014	6/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.
FO-283467	Finished	005-EXF-029	6/1/2014	6/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings. Adjusted belts.
FO-283468	Finished	046-FAP-001	6/1/2014	6/26/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested fire panel called PS reset panel and tested pull station.
FO-283469	Finished	048-FAP-001	6/1/2014	6/20/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested fire panel and station, called PS , reset , back in service.
FO-283470	Finished	049-FAP-001	6/1/2014	6/26/2014	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught- Tested fire panel called PS ,tested pull station. back in service.
FO-283471	Finished	156-FAP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D



FO-283472	Finished	499-FAP-001	6/1/2014	6/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283473	Finished	620-FAP-001	6/1/2014	6/13/2014	False	0.65	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the fire pump and the panel called PS ,reset system ,back in service.
FO-283474	Finished	036-FP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283475	Finished	025-FP-001	6/1/2014	6/17/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pressure tested jockey pump and main fire pump.Pulled pull station.Reset the fire alarm panel.Reset O.K at public safety.Copied reading on PM report and report back to Ms Carol D.
FO-283476	Finished	007-FP-001	6/1/2014	7/1/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test Morris Mims-Conducted monthly fire system test.
FO-283477	Finished	001-FP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283478	Finished	005-FAP-001	6/1/2014	7/1/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test Morris Mims-Conducted monthly fire system test.
FO-283479	Finished	040-FAP-001	6/1/2014	6/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283480	Finished	038-FAP-001	6/1/2014	6/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283481	Finished	028-FAP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283482	Finished	026-FAP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283483	Finished	022-FAP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283484	Finished	017-FAP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the fire panel ,called PS reset and back in service.

Requested Finished Open WND

% Finished

FO-283485	Finished	016-FAP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283486	Finished	003-FAP-001	6/1/2014	7/1/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-283487	Finished	006-FP-001	6/1/2014	7/1/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test Morris Mims-Conducted monthly fire system test.
FO-283488	Finished	050-FAP-001	6/1/2014	6/20/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested station and panel called PS reset, back in service.
FO-283489	Finished	043-FAP-001	6/1/2014	6/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283490	Finished	042-FAP-001	6/1/2014	6/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283491	Finished	062-FP-001	6/1/2014	6/12/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the fire pump and jockey pump greased the bearings ,called PS ,reset system back on line.
FO-283492	Finished	065-FP-001	6/1/2014	6/12/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the fire pump and jockey pump ,greased bearings Called PS ,reset , system back in service.
FO-283493	Finished	068-FAP-001	6/1/2014	6/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-performed monthly fire alarm testPulled pull station on third and second floorsReset system alarm panelConfirm with public safety that the fire signal was received and reset
FO-283494	Finished	067-FP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the fire pump and the jockey pump, called PS reset system ,back in service.
FO-283495	Finished	089-FP-001	6/1/2014	7/1/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test Morris Mims-Conducted monthly fire system test.
FO-283496	Finished	082-FP-001	6/1/2014	6/19/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Copied readings on fire alarm report. Pulled pull station. Reset O.k at public Safety. Reset main fire alarm panel. Report on fire alarm test given back to Ms Carol D.
FO-283497	Finished	080-FAP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283498	Finished	090-FP-001	6/1/2014	6/28/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test Timothy Bowman-ran fire alarm test

FO-283499	Finished	155-FP-001	6/1/2014	6/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283500	Finished	150-FAP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283501	Finished	167-FAP-001	6/1/2014	6/28/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Timothy Bowman-ran fire alarm test.
FO-283502	Finished	166-FP-001	6/1/2014	6/28/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Timothy Bowman-ran fire alarm test.
FO-283503	Finished	140-FAP-001	6/1/2014	6/26/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-283504	Finished	130-FP-001	6/1/2014	6/12/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested fire pump and jockey pump ,greased bearings call PS reset the system , back in service.
FO-283505	Finished	193-FAP-001	6/1/2014	6/20/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-tested panel and station called PS reset system ,back in service.
FO-283506	Finished	189-FP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-283507	Finished	510-FAP-001	6/1/2014	6/13/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-tested the panel called PS system back in service.
FO-283508	Finished	509-FAP-001	6/1/2014	6/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-tested fire system called PS put back in service.
FO-283509	Finished	504-FAP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test.Pulled pull station.Reset O.K at Public Safety.Copied readings and completed PM report.Report given back to Ms. Carol D
FO-283510	Finished	629-FP-001	6/1/2014	6/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-perform monthly fire alarm test.Pull pull stations in bsmt. Lowered system pressure to activate jockey pump and main fire pump.Call public safety to confirm signal was received and system was reset
FO-283511	Finished	611-FP-001	6/1/2014	6/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-perform monthly fire alarm test.Pull pull stations on 2nd floor.Lowered system pressure to active fire pump.Check with public safety to confirm receiving signal and system reset
FO-283512	Finished	609-FP-001	6/1/2014	6/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-performed monthly fire alarm test.Pull pull stations on 2nd floor.Lower system pressure to active jockey pump.Continue to lower pressure to activate main fire pump.Contac public safety to confirm that the fire alarm signal was received and system reset
FO-283513	Finished	603-FP-001	6/1/2014	6/18/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-perform monthly fire alarm test.Call public safety.Pull pull station on bsmt. level.Lower system pressure to activate jockey pump.Continue to lower system pressure to activate mainfire pump.Test inspector test valve.Confirm with public safety that fire alarm system signal was received by and reset

FO-283514	Finished	608-FP-001	6/1/2014	6/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Derrick Allen-perform monthly fire alarm test, pull pull stations on 2nd floor, lowered system pressure to activate jockey and main fire pump, call public safety to confirm fire signal was received and system reset
FO-283515	Finished	603-AHU-010	6/1/2014	6/25/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #10 pharmacy bldg. #603 lubricate fan and motor bearings, lubricate linkages and dampers, change dirty filters, dispose of dirty filters, clean up around fan housing
FO-283516	Finished	603-AHU-009	6/1/2014	6/25/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #9 pharmacy bldg. #603 lubricate fan and motor bearings, lubricate linkages and dampers, change dirty filters, dispose of dirty filters, clean up around fan housing
FO-283517	Finished	603-AHU-008	6/1/2014	6/24/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #8 pharmacy bldg. #603 lubricate motor and fan bearings, lubricate linkages and dampers, change dirty filters, dispose of dirty filters, clean up around fan housing
FO-283518	Finished	603-AHU-007	6/1/2014	6/24/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #7 pharmacy bldg. #603 lubricate motor and fan bearings, lubricate dampers and linkages, change dirty filters, dispose of dirty filters, clean up around fan housing
FO-283519	Finished	603-AHU-006	6/1/2014	6/21/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #6 pharmacy bldg. #603 lubricate motor and fan bearings, lubricate linkages and dampers, change dirty filters, dispose of dirty filters, clean up around fan housing
FO-283520	Finished	074-FAP-001	6/1/2014	6/6/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Frank Vaught-Tested the panel called PS reset and back in service.
FO-283521	Completed	005-AHU-006	6/1/2014		True		Replace PRE-filters
FO-283522	Completed	005-AHU-005	6/1/2014		True		Replace PRE-filters
FO-283523	Completed	005-AHU-004	6/1/2014		True		Replace PRE-filters
FO-283524	Finished	005-AHU-003	6/1/2014	6/24/2014	False	1.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed motor and fan bearings. Adjusted belts.
FO-283525	Finished	089-AHU-006	6/1/2014	6/12/2014	False	2.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed motor and bearings. Inspected belts.
FO-283526	Finished	089-AHU-005	6/1/2014	6/12/2014	False	2.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed motor and bearings. Inspected belts.
FO-283527	Finished	089-AHU-004	6/1/2014	6/28/2014	False	1.50	Replace PRE-filters Timothy Bowman-Checked fan operation, changed filters, lubed fan and motor bearings. Inspected belts.
FO-283528	Finished	089-AHU-003	6/1/2014	6/11/2014	False	2.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts.
FO-283529	Finished	089-AHU-002	6/1/2014	6/11/2014	False	4.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts. Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts. Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts.
FO-283529	Finished	089-AHU-002	6/1/2014	6/11/2014	False	4.00	Replace PRE-filters Timothy Bowman-vChecked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts. Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts.
FO-283530	Finished	089-AHU-001	6/1/2014	6/11/2014	False	2.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed fan and motor bearings. adjusted belts.
FO-283531	Finished	008-AHU-005	6/1/2014	6/7/2014	False	1.50	Replace PRE-filters Timothy Bowman-Checked fan operation, changed filters, lubed and inspected belts.
FO-283532	Finished	008-AHU-004	6/1/2014	6/10/2014	False	1.50	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed motor and fan bearing. Inspected belts.

**Requested Finished Open WND**

**% Finished**

FO-283533	Finished	008-AHU-003	6/1/2014	6/7/2014	False	1.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed filters, lubed and inspected belts.
FO-283534	Finished	008-AHU-002	6/1/2014	6/7/2014	False	1.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed filters, lubed and inspected belts.
FO-283535	Finished	008-AHU-001	6/1/2014	6/10/2014	False	1.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed air filters, lubed motor and fan bearing. Inspected belts.
FO-283536	Completed	006-AHU-006	6/1/2014		True		Replace PRE-filters
FO-283537	Finished	006-AHU-005	6/1/2014	6/4/2014	False	2.00	Replace PRE-filters Timothy Bowman-Checked fan operation, changed filters, lubed dampers, motor and fan bearings. Inspected belts.
FO-283538	Completed	006-AHU-004	6/1/2014		True		Replace PRE-filters
FO-283539	Completed	006-AHU-003	6/1/2014		True		Replace PRE-filters
FO-283540	Completed	006-AHU-002	6/1/2014		True		Replace PRE-filters
FO-283541	Completed	006-AHU-001	6/1/2014		True		Replace PRE-filters

FO-283542	Finished	008-EXF-005	6/1/2014	6/28/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
							Timothy Bowman-Checked fan operation, lubed fan and motor bearings . Adjusted belts. 
							
							
							
							Spell Check  LaborTechnicianLabor Adjustment  
							
							
							
							
							
							Saving...Loading...  Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check  LaborTechnicianLabor Adjustment 
							
							 Saving...Loading...  Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check  LaborTechnicianLabor Adjustment   Saving...Loading... 
							
							
							
							
							Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check 
							
							
							
							LaborTechnicianLabor Adjustment  
							
							
							
							
							
							Saving...Loading...  Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check  LaborTechnicianLabor Adjustment 
							
							 Saving...Loading...  Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check  LaborTechnicianLabor Adjustment   Saving...Loading... 
							
							
							
							
							Checked fan operation, lubed fan and motor bearings . Adjusted belts.  Spell Check 
							
							
							
							LaborTechnicianLabor Adjustment  
							
							
							
							
							
							

								Saving...Loading...Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check TechnicianLabor Adjustment
								Saving...Loading...Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check TechnicianLabor Adjustment
								Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check
								LaborTechnicianLabor Adjustment
								Saving...Loading...Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check TechnicianLabor Adjustment
								Saving...Loading...Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check TechnicianLabor Adjustment
								Saving...Loading...Checked fan operation, lubed fan and motor barings,adjusted belts.
FO-283543	Finished	008-EXF-004	6/1/2014	6/28/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings . Adjusted belts. Spell Check TechnicianLabor Adjustment	
								Spell Check TechnicianLabor Adjustment
								Saving...Loading...Checked fan operation, lubed fan and motor bearings, adjusted belts.
FO-283544	Finished	008-EXF-003	6/1/2014	6/24/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Timothy Bowman-Checked fan operation, lubed fan and motor bearings, adjusted belts.	
FO-283545	Finished	140-AHU-004	6/1/2014	6/10/2014	False	3.00	Replace PRE-filters Michael Fitzgerald-checked belt tension wear and alignmentChanged filtersLubricate fan and motor bearingsLubricate dampers and damper motor pointsCleaning fan housing Cleaning fan room.	
FO-283546	Finished	140-AHU-003	6/1/2014	6/10/2014	False	3.00	Replace PRE-filters Michael Fitzgerald-checked belt tension wear and alignmentChanged filtersLubricate fan and motor bearingsLubricate dampers and damper motor pointsCleaning fan housing Cleaning fan room.	

FO-283547	Finished	140-AHU-002	6/1/2014	6/3/2014	False	4.00	Replace PRE-filters Michael Fitzgerald-checked belt tension wear and alignment. Change pre filters. Lubricate fan and motor bearings. Lubricate dampers and damper motor points. Cleaning fan housing. Cleaning fan room. Heating coil is very dirty and needs to be cleaned. will inform supervisor.
FO-283548	Finished	140-AHU-001	6/1/2014	6/3/2014	False	4.00	Replace PRE-filters Michael Fitzgerald-Check belt- tension wear and alignment
FO-283548	Finished	140-AHU-001	6/1/2014	6/3/2014	False	4.00	Replace PRE-filters Michael Fitzgerald-checked belt tension wear and alignment. Change pre filters. Lubricate fan and motor bearings. Lubricate dampers and damper motor points. Cleaning fan housing. Cleaning fan room. Heating coil is very dirty and needs to be cleaned. will inform supervisor.
FO-283549	Finished	189-AHU-002	6/1/2014	6/12/2014	False	2.00	Replace PRE-filters Edward Nisnevich-Checked prefilters-OK, can be changed 3 times a year,checked belts, greased bearings, lubricated dampers.
FO-283550	Finished	189-AHU-001	6/1/2014	6/12/2014	False	3.00	Replace PRE-filters Edward Nisnevich- Changed prefilters,greased supply and return fan bearings,checked belts,lubricated dampers, verified damper operation, disposed dirty filters.
FO-283551	Finished	042-SAF-013	6/1/2014	6/12/2014	False	3.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened doors. Cleaned interior. Lubricated fan and motor bearings. Inspected belt. Changed filters 20x20x4 (10). Inspected coil, valves, and piping. Lubricated and exercised dampers. Closed up unit. Test ran and returned to service. Disposed of old filters.
FO-283552	Finished	042-SAF-012	6/1/2014	6/12/2014	False	3.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened doors. Cleaned interior. Lubricated fan and motor bearings. Inspected belt. Changed filters 20x20x4 (10). Inspected coil, valves, and piping. Lubricated and exercised dampers. Closed up unit. Test ran and returned to service. Disposed of old filters.
FO-283553	Finished	042-SAF-001	6/1/2014	6/28/2014	False	2.00	Replace PRE-filters Michael Fitzgerald-Checked belt tension wear and alignment. Lubricated fan and motor bearings. Checked filters. did not change. fan has low run hours. Cleaning fan housing. Cleaning fan room.
FO-283554	Finished	042-AHU-001	6/1/2014	6/10/2014	False	1.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Checked condition of coil, valves, and piping. Changed filters 20x25x1 (2). Cleaned interior. Closed up doors, test ran, and returned to service.
FO-283555	Created By PM Schedule	040-SAF-004	6/1/2014		False		Replace PRE-filters
FO-283556	Finished	040-SAF-003	6/1/2014	6/21/2014	False	1.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x25x2 (3). Lubricated fan bearings. Motor sealed. Checked and lubricated dampers. Cleaned interior. Closed up and returned to service. Disposed of old filters and cleaned area .
FO-283557	Finished	040-SAF-002	6/1/2014	6/21/2014	False	1.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x25x2 (6). Lubricated fan bearings. Motor sealed. Checked and lubricated dampers. Cleaned interior. Closed up and returned to service. Disposed of old filters and cleaned area.
FO-283558	Finished	039-SAF-009	6/1/2014	6/10/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Checked condition of coil, valves, and piping. Changed filters. Lubricated and exercised dampers. Lubricated fan and motor bearings. Cleaned interior. Closed up doors, test ran, and returned to service.
FO-283559	Finished	039-SAF-008	6/1/2014	6/10/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Checked condition of coil, valves, and piping. Changed filters. Lubricated and exercised dampers. Lubricated fan and motor bearings. Cleaned interior. Closed up doors, test ran, and returned to service.



FO-283560	Finished	039-SAF-007	6/1/2014	6/10/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Checked condition of coil, valves, and piping. Changed filters. Lubricated and exercised dampers. Lubricated fan and motor bearings. Cleaned interior. Closed up doors, test ran, and returned to service.
FO-283561	Finished	039-SAF-006	6/1/2014	6/21/2014	False	1.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x25x (3). Lubricated motor and fan bearings. Checked and lubricated dampers. Cleaned interior. Closed up and returned to service. Disposed of old filters and returned to service.
FO-283562	Finished	039-SAF-005	6/1/2014	6/12/2014	False	1.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened doors. Cleaned interior. Lubricated fan and motor bearings. Inspected belt. Changed filters 20x25x2 (2). Inspected coil, valves, and piping. Lubricated and exercised dampers. Closed up unit. Test ran and returned to service.
FO-283563	Finished	039-SAF-004	6/1/2014	6/19/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x25x2 (3). Lubricated and exercised dampers. Lubricated fan and motor bearings. Checked condition of belts. Cleaned interior. Closed up unit and returned to service. Cleaned area and disposed of old filters.
FO-283564	Finished	039-SAF-003	6/1/2014	6/19/2014	False	3.50	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x20x4 (10). Lubricated and exercised dampers. Lubricated fan and motor bearings. Checked condition of belts. Cleaned interior. Closed up unit and returned to service. Cleaned area and disposed of old filters.
FO-283564	Finished	039-SAF-003	6/1/2014	6/19/2014	False	3.50	Replace PRE-filters Michael Fitzgerald-Lubricated fan and motor bearings on return air fan for unit #3. Checked belt- tension wear and alignment
FO-283565	Finished	039-SAF-002	6/1/2014	6/21/2014	False	3.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x20x4 (10). Lubricated fan bearings. Motor sealed. Checked and lubricated dampers. Cleaned interior. Closed up and returned to service. Disposed of old filters and returned to service.
FO-283566	Finished	039-SAF-001	6/1/2014	6/19/2014	False	3.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x20x4 (10). Lubricated and exercised dampers. Lubricated fan and motor bearings. Checked condition of belts. Cleaned interior. Closed up unit and returned to service. Cleaned area and disposed of old filters.
FO-283567	Finished	038-SAF-004	6/1/2014	6/25/2014	False	1.00	Replace PRE-filters Michael Fitzgerald-checked belt- tension wear and alignmentLubricate fan and motor bearingsChange filters
FO-283568	Finished	038-SAF-003	6/1/2014	6/25/2014	False	1.00	Replace PRE-filters Michael Fitzgerald-checked belt- tension wear and alignmentLubricate fan and motor bearingsChange filters
FO-283569	Finished	038-SAF-002	6/1/2014	6/25/2014	False	1.00	Replace PRE-filters Michael Fitzgerald-check belt tension wear and alignmentWe are missing the oil can for the fan bearings. I will order a new one and a gallon of 30w oil. Lubricate motor bearingsChange filters
FO-283570	Finished	038-SAF-001	6/1/2014	6/21/2014	False	3.50	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Checked condition of coil, valves, and piping. Changed filters 20x20x4 (20). Lubricated fan bearings. Motor sealed. Checked and lubricated dampers. Cleaned interior. Closed up and returned to service. Disposed of old filters and returned to service.
FO-283570	Finished	038-SAF-001	6/1/2014	6/21/2014	False	3.50	Replace PRE-filters Michael Fitzgerald-As directed checked unit over and complete PM.
FO-283571	Finished	189-HVU-001	6/1/2014	7/1/2014	False	1.00	Replace PRE-filters Michael Fitzgerald-Check belt- tension wear and alignmentChange filtersLubricate fan and motor bearings
FO-283572	Finished	189-HVU-002	6/1/2014	6/12/2014	False	1.00	Replace PRE-filters Edward Nisnevich-Checked prefilters-OK.greased bearings, checked belts,lubricated dampers.

FO-283573	Finished	043-HVU-001	6/1/2014	6/23/2014	False	1.00	Replace PRE-filters Thomas Townsel-Change filters, checked belts, lubricated bearing and dampers, placed unit back in services, and checked for proper operation.
FO-283574	Finished	043-AHU-003	6/1/2014	6/23/2014	False	2.00	Replace PRE-filters Thomas Townsel-Changed filters, lubricated bearings and dampers, checked belts, placed unit back in service and checked for proper operation.
FO-283575	Finished	043-AHU-002	6/1/2014	6/23/2014	False	2.00	Replace PRE-filters Thomas Townsel-Changed filters, lubricated bearings and dampers, checked belts, placed unit back in service and checked for proper operation.
FO-283576	Finished	043-AHU-001	6/1/2014	6/23/2014	False	1.00	Replace PRE-filters Thomas Townsel-Changed filters, lubricated bearings and dampers, checked belts, placed unit back in service and checked for proper operation.
FO-283577	Finished	067-AHU-400.1	6/1/2014	6/12/2014	False	1.00	Replace PRE-filters Thomas Townsel-Changed filter, checked belts and shiv. Placed unit back in service.
FO-283578	Finished	067-AHU-400.2	6/1/2014	6/12/2014	False	1.00	Replace PRE-filters Thomas Townsel-Changed filter, checked belts and shiv. Placed unit back in service.
FO-283579	Finished	067-AHU-405.2	6/1/2014	6/12/2014	False	1.00	Replace PRE-filters Thomas Townsel-Changed filter, checked belts and shiv. Placed unit back in service.
FO-283580	Finished	096-FP-001	6/1/2014	6/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test Kumash Shah-Performed fire alarm test. Pressure tested Jockey pump and Main fire pump. Pulled pull station. Copied reading on fire alarm report issued by supervisor. Reset O.K at public safety. Report given back to Supervisor.
FO-284131	Finished	050-AHU-001	6/1/2014	6/6/2014	False	3.00	Replace PRE-filters Thomas Townsel-Changed pre filters. Lubricated bearings and dampers. Checked belts. Placed unit back in service.
FO-284132	Finished	065-AHU-001	6/1/2014	6/14/2014	False	6.00	Replace PRE-filters Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsChange filtersClean fan housing
FO-284133	Finished	067-AHU-003	6/1/2014	6/17/2014	False	3.00	Replace PRE-filters Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsLubricate dampers and damper motor pointsChange filtersCleaning fan housingCleaning fan room
FO-284134	Finished	067-AHU-001	6/1/2014	6/17/2014	False	3.00	Replace PRE-filters Michael Fitzgerald-check belt- tension wear and alignmentLubricate fan and motor bearingsLubricate dampers and damper motor pointsChange filtersCleaning fan housingCleaning fan room
FO-284159	Completed	608-UNH-001	6/7/2014		True		PM - Unit/Space Heater
FO-284160	Completed	608-UNH-002	6/7/2014		True		PM - Unit/Space Heater
FO-284161	Completed	608-UNH-003	6/7/2014		True		PM - Unit/Space Heater
FO-284162	Finished	001-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284163	Finished	001-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284164	Finished	001-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284165	Finished	001-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.

Requested Finished Open WND

% Finished

FO-284166	Finished	01-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284167	Finished	01-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284168	Finished	01-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284169	Finished	01-FCU-3141-1	6/11/2014	6/25/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter, cleaned under unit, checked for operation, placed back in service.
FO-284170	Finished	01-FCU-3141-1	6/11/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284171	Finished	01-FCU-3141-1	6/11/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284172	Finished	01-FCU-3141-1	6/11/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284173	Finished	001-FCU-3141-2	6/11/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284174	Finished	603-EXF-005	6/7/2014	6/25/2014	False	1.00	Animal Lab Filter Changes for Applelebaum Derrick Allen-pm ex-fan #5 pharmacy bldg. #603 Remove belt and motor guard Lubricate fan and motor bearings Inspect belt and sheaves for wear Put guard back on Return ex-fan back to service
FO-284289	Finished	609-AHU-005	6/1/2014	6/12/2014	False	2.50	Replace PRE-filters Derrick Allen-pm ahu #5 mott bldg. #609 Change dirty filters Dispose of dirty filters Lubricate fan and motor bearings Lubricate linkages and dampers
FO-284290	Finished	609-AHU-004	6/1/2014	6/12/2014	False	2.50	Replace PRE-filters Derrick Allen-pm ex-fan #4 mott bldg. #609 Lubricate motor and fan bearings Lubricate linkages and dampers Change dirty filters Dispose of dirty filters
FO-284291	Finished	609-AHU-003B	6/1/2014	6/20/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #3b mott bldg. # 609 Lubricate fan and motor bearings Lubricate dampers and linkages Change dirty filters Dispose of dirty filters Clean up around ahu housing
FO-284292	Finished	609-AHU-003A	6/1/2014	6/20/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #3a mott. bldg. #609 Lubricate fan and motor bearings Lubricate linkages and dampers Change dirty filters Dispose of dirty filters Clean up around fan housing
FO-284293	Finished	609-AHU-002	6/1/2014	6/18/2014	False	6.00	Replace PRE-filters Derrick Allen-pm ahu #1 mott bldg. # 609 Remove dirty filters Box up and dispose of dirty filters Lubricate fan and motor bearings Lubricate dampers and linkages Clean up around fan housing
FO-284293	Finished	609-AHU-002	6/1/2014	6/18/2014	False	6.00	Replace PRE-filters Derrick Allen-pm ahu #2 mott bldg. #609 Lubricate fan and motor bearings Lubricate linkages and dampers Inspect belts and sheaves for wear Replace dirty filters Dispose of dirty filters Clean up around fan housing
FO-284294	Finished	609-AHU-001	6/1/2014	6/21/2014	False	3.00	Replace PRE-filters Derrick Allen-pm ahu #1 mott bldg. #609 Lubricate fan and motor bearings Lubricate linkages and dampers Change dirty filters Dispose of dirty filters Clean up around fan housing
FO-284295	Finished	006-AHU-004	6/1/2014	6/4/2014	False	2.00	PM - Air Handling Unit (ANNUAL) Timothy Bowman-Checked fan operation, changed filters, lubed dampers, motor and fan bearings. Inspected belts.
FO-284296	Finished	006-AHU-003	6/1/2014	6/3/2014	False	2.00	PM - Air Handling Unit (ANNUAL) Timothy Bowman-Checked fan operation, changed filters, lubed dampers, motor and bearings. Inspected belts.

FO-284297	Finished	006-AHU-002	6/1/2014	6/3/2014	False	2.00	PM - Air Handling Unit (ANNUAL) Timothy Bowman-Checked fan operation, changed filters, lubed dampers,motor and bearings. Inspected belts.
FO-284298	Finished	006-AHU-001	6/1/2014	6/3/2014	False	2.00	PM - Air Handling Unit (PREFILTERS) Timothy Bowman-Checked fan operation, changed air filters, lubed motor and fan bearings, inspected belts.
FO-284809	Finished	01-FCU-002HCF	6/18/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.
FO-284810	Finished	01-FCU-003HCF	6/18/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.
FO-284811	Finished	01-FCU-004HCF	6/18/2014	6/24/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. Removed covers. Inspected coil, valves, and piping. Cleaned interior. Checked belt. Changed filters. Replaced covers and returned to service. Disposed of old filters
FO-284812	Finished	01-FCU-005HCF	6/18/2014	6/24/2014	False	1.50	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. Removed covers. Inspected coil, valves, and piping. Cleaned interior. Changed belt (B-55). Changed filters. Replaced covers and returned to service. Disposed of old filters.
FO-284813	Finished	01-FCU-006HCF	6/18/2014	6/24/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. Removed covers. Inspected coil, valves, and piping. Cleaned interior. Checked belt. Changed filters. Replaced covers and returned to service. Disposed of old filters
FO-284814	Finished	01-FCU-007HCF	6/18/2014	6/29/2014	False	1.00	PM - Fan Coil/HV/AC Unit Kumash Shah-Checked HCFC. Checked coils. Checked pre filter and replaced pre filter. Cleaned the area near the coil. Checked the belts and belt tension. Checked and cleaned the area near the unit. Disposed dirty filter. Unit back in service.
FO-284815	Finished	01-FCU-008HCF	6/18/2014	6/29/2014	False	1.00	PM - Fan Coil/HV/AC Unit Kumash Shah-Checked coils. Checked pre filter and replaced pre filter. Cleaned the area near the coil. Checked the belts and belt tension. NEED BELT L-410H Qty (1) Checked and cleaned the area near the unit. Disposed dirty filter. Unit back in service.
FO-284816	Finished	001-FCU-3141-3	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284817	Finished	001-FCU-3141-4	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284818	Finished	001-FCU-3141-5	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284819	Finished	001-FCU-3141-6	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284820	Finished	001-FCU-3141-7	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284821	Finished	001-FCU-3141-8	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284822	Finished	001-FCU-3141-9	6/18/2014	6/26/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filters and checked operation. Placed unit back in service.
FO-284944	Completed	195-UNH-002	6/20/2014		True		PM - Unit/Space Heater
FO-284945	Completed	062-UNH-001	6/20/2014		True		PM - Unit/Space Heater
FO-284946	Completed	080-UNH-201	6/19/2014		True		PM - Unit/Space Heater
FO-284947	Completed	080-UNH-253	6/19/2014		True		PM - Unit/Space Heater
FO-285240	Finished	01-FCU-009HCF	6/25/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.

**Requested Finished Open WND**

**% Finished**

FO-285241	Finished	01-FCU-010HCF	6/25/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.
FO-285242	Finished	01-FCU-011HCF	6/25/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.
FO-285243	Finished	01-FCU-012HCF	6/25/2014	6/27/2014	False	1.00	PM - Fan Coil/HV/AC Unit Thomas Townsel-Checked unit, changed filters, checked belts and placed unit back in service.
FO-285244	Finished	01-FCU-013HCF	6/25/2014	6/24/2014	False	1.50	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. Removed covers. Inspected coil, valves, and piping. Cleaned interior. Changed belt (4L430). Changed filters. Replaced covers and returned to service. Disposed of old filters.
FO-285245	Finished	001-FCU-3202	6/25/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-285246	Finished	001-FCU-3203	6/25/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-285247	Finished	001-FCU-3204	6/25/2014	6/27/2014	False	0.50	PM - Fan Coil/HV/AC Unit Thomas Townsel-Changed filter and checked unit for proper operation.
FO-285248	Finished	001-FCU-3207-1	6/25/2014	7/1/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Changed belt. Changed filters. Replaced cover, test ran and returned to service.
FO-285249	Created By PM Schedule	001-FCU-3207.2	6/25/2014		False		PM - Fan Coil/HV/AC Unit
FO-285250	Finished	001-FCU-3125	6/25/2014	7/1/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Changed belt. Changed filters. Replaced cover, test ran and returned to service.
FO-285251	Finished	001-FCU-3125.1	6/25/2014	7/1/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Changed belt. Changed filters. Replaced cover, test ran and returned to service.
FO-285252	Finished	001-FCU-3125.2	6/25/2014	7/1/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Changed belt. Changed filters. Replaced cover, test ran and returned to service.
FO-285253	Finished	001-FCU-3125.3	6/25/2014	7/1/2014	False	1.00	PM - Fan Coil/HV/AC Unit Roman Wojtowicz-Shut down unit. removed cover. Checked coil, valves, and piping. Cleaned interior. Changed belt. Changed filters. Replaced cover, test ran and returned to service.
FO-285254	Created By PM Schedule	001-FCU-3207.3	6/25/2014		False		PM - Fan Coil/HV/AC Unit
FO-285390	Completed	195-UNH-003	6/27/2014		True		PM - Unit/Space Heater
FO-285391	Completed	062-UNH-002	6/27/2014		True		PM - Unit/Space Heater
FO-285392	Completed	080-UNH-269	6/26/2014		True		PM - Unit/Space Heater
FO-285393	Completed	080-UNH-274	6/26/2014		True		PM - Unit/Space Heater
FO-287551	Created	067-EXF-010	6/18/2014		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-287552	Finished	067-EXF-005	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt- tension wear and alignment. Lubricate fan and motor bearings. Check fan operation. Cleaning fan area.
FO-287553	Finished	067-EXF-006	6/1/2014	6/17/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan Michael Fitzgerald-Checked belt- tension wear and alignment. Lubricate fan and motor bearings. Check fan operation. Cleaning fan area.
FO-288012	Finished	001-AHU-004O	6/1/2014	6/29/2014	False	2.00	Replace PRE-filters Kumash Shah-Checked OAHU-4 at R223. Shut down the unit. Lubricated motor and blower bearings. Replaced pre filters. Boxed dirty filters. Checked the belts and belt tension. Checked the cooling and heating coil. Cleaned the area near coils. Lubricated inlet dampers. Disposed dirty filters. Unit back in service.

**Requested Finished Open WND**

**% Finished**

FO-288013	Finished	001-AHU-003O	6/1/2014	6/29/2014	False	2.00	Replace PRE-filters Kumash Shah-Checked OAHU-3 at R223. Shut down the unit. Lubricated motor and blower bearings. Replaced pre filters. Boxed dirty filters. Checked the belts and belt tension. Checked the cooling and heating coil. Cleaned the area near coils. Lubricated inlet dampers. Disposed dirty filters. Unit back in service. Checked the return fan. Lubricated motor and blower bearings. Cleaned the area near return fan.
FO-288014	Finished	001-AHU-003ML	6/1/2014	6/27/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Lubricated fan and motor bearings. Changed filters 24x24x2 (3) 24x12x2 (3). Checked belt. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Cleaned area. Disposed of old filters.
FO-288015	Finished	001-AHU-002O	6/1/2014	6/27/2014	False	2.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Lubricated fan and motor bearings. Inspected filters. Checked belt. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Cleaned area
FO-288016	Finished	001-AHU-002ML	6/1/2014	6/29/2014	False	2.00	Replace PRE-filters Kumash Shah-Checked MUAHU-2 at attic A. Shut down the unit. Lubricated motor and blower bearings. Replaced pre filters. Boxed dirty filters. Checked the belts and belt tension. Checked the cooling and heating coil. Cleaned the area near coils. Lubricated inlet dampers. Disposed dirty filters. Unit back in service.
FO-288017	Finished	001-AHU-002	6/1/2014	6/28/2014	False	2.00	Replace PRE-filters Kumash Shah-Checked the supply fan intake. Checked the intake area. Checked the belts and tension. Lubricated the bearings on motor and fan side. Lubricated dampers. (supply, return and exhaust) Checked the pre filters. Replaced pre filters. Inspected the heating coil and chilled water coil. Cleaned the area around the coil form inside the fan. Cleaned the area around the fan. Boxed and dispose off dirty filters.
FO-288018	Finished	001-AHU-001O	6/1/2014	6/28/2014	False	2.50	Replace PRE-filters Kumash Shah-Checked the supply fan intake. Checked the intake area. Checked the belts and tension. Lubricated the bearings on motor and fan side. Lubricated dampers. (supply, return and exhaust) Checked the pre filters. Replaced pre filters. Inspected the heating coil and chilled water coil. Cleaned the area around the coil form inside the fan. Cleaned the area around the fan. Boxed and dispose off dirty filters.
FO-288019	Finished	001-AHU-001ML	6/1/2014	6/27/2014	False	3.00	Replace PRE-filters Roman Wojtowicz-Shut down unit. Opened access doors. Lubricated fan and motor bearings. Changed filters 24x24x2 (10) 24x12x2 (5). Checked belt. Lubricated and exercised dampers. Cleaned interior. Closed up doors and returned to service. Cleaned area. Disposed of old filters.
FO-288020	Finished	001-AHU-001	6/1/2014	6/28/2014	False	2.50	Replace PRE-filters Kumash Shah-Checked the supply fan intake. Checked the intake area. Checked the belts and tension. Lubricated the bearings on motor and fan side. Lubricated dampers. (supply, return and exhaust) Checked the pre filters. Replaced pre filters. Inspected the heating coil and chilled water coil. Cleaned the area around the coil form inside the fan. Cleaned the area around the fan. Boxed and dispose off dirty filters.

**E - South**

**51**

**45**

**6**

**0**

**88%**

FO-284773	Finished	022-AIR-001	6/1/2014	6/19/2014	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P. Checked operation of the unit, checked oil and filter they were good, didn't change oil it was changed on 2-16-14. checked operation of air dryer. blew down it's trap. cleaned air compressor and air dryer.
FO-284792	Finished	028-AIR-001	6/1/2014	6/12/2014	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P. Checked operation of the unit. Checked oil level, didn't changed oil, it was changed on 2-6-14. Checked air filters, they were clean. Checked air cooler operation, cleaned it's condenser coils, drained oil and moisture separator. cleaned the unit.
FO-285217	Finished	096-SP-001	6/6/2014	6/6/2014	False	1.00	PM - Sump Pump Darnell Smiley-Checked electrical cord and connections ok check pump operation lube bearings packing ok no leaks.
FO-285218	Finished	096-DWBP-001	6/6/2014	6/6/2014	False	1.00	PM - Water Booster Pump Darnell Smiley-Checked pump operation ok. Check for noise vibration ok alignment ok lube pump and motor cleaned around area and cleaned equipment.

**Requested Finished Open WND**

**% Finished**

FO-285219	Finished	096-DWBP-002	6/6/2014	6/6/2014	False	1.00	PM - Water Booster Pump Darnell Smiley-Checked pump operation ok,check for noise and vibration,alignment good,lube pump and motor.Also cleaned pump area and equipment.#2 PUMP SEALS ARE LEAKING ON THIS BOOSTER PUMP.
FO-285220	Finished	096-DWBP-003	6/6/2014	6/6/2014	False	0.50	PM - Clayton Valves for Booster Pumps (UGL) Darnell Smiley-I was informed that the plummers are doing the Pm on this booster clayton vavles.
FO-285221	Finished	096-SP-001	6/6/2014	6/6/2014	False	1.00	PM - Sump Pump Darnell Smiley-Checked electrical cord and connections check pump operation ok lube bearings check packing ok no leaks.
FO-285222	Finished	096-DWBP-003	6/6/2014	6/6/2014	False	0.50	PM - Clayton Valves for Booster Pumps (UGL) Darnell Smiley-I was informed that the plummers are doing the pm on these booster clayton vavles.
FO-285223	Finished	090-ACU-CR2	6/8/2014	6/12/2014	False	1.00	Monthly AHU Inspection Clean Room Unit 2 Robert McPherson-check belt and tighten, change air filters.
FO-285224	Finished	090-ACU-CR1	6/8/2014	6/12/2014	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1 Robert McPherson-checked belt and tighten, change air filters, check ops.
FO-285233	Finished	005-EW-001	6/4/2014	6/4/2014	False	0.10	PM - Emergency Shower/Eyewash Station - Annual Flow Test Dennis Paul-There are no eyewash/shower stations at Science Hall
FO-285234	Finished	090-WSS-001	6/4/2014	6/5/2014	False	1.00	PM - Water Softener Robert McPherson-Check ops all normal, salt level and water level good tested hardness of water and it is 0.
FO-285537	Finished	007-GEN-001	6/12/2014	6/12/2014	False	0.75	Generator Maintenance, Monthly John Covert-Sisung-Checked oil level - OK Fuel level - 3/4 tank Battery Level - OK Radiator - 1/2 sight glass
FO-285539	Finished	007-GEN-002	6/12/2014	6/12/2014	False	0.75	Generator Maintenance, Monthly John Covert-Sisung-Checked oil level - OK Fuel level - 3/4 tank Battery Level - OK Radiator level - In sight glass
FO-285541	Finished	090-GEN-001	6/17/2014	6/17/2014	False	1.00	Generator Maintenance, Monthly Robert McPherson-Check all fluid level, belts.
FO-285543	Finished	089-GEN-001	6/18/2014	6/18/2014	False	1.00	Generator Maintenance, Monthly Darnell Smiley-Completed test check oil ok check gas level 3/4 full called mark and reported gas level check belts ok check batterys water level full ok check antifreeze ok.NOTE THIS UNIT SMOKES A LOT ON START UP.
FO-285577	Finished	090-GEN-002	6/12/2014	6/12/2014	False	1.00	Generator Maintenance, Monthly Robert McPherson-check all fluid levels, belts.
FO-285585	Finished	006-GEN-001	6/19/2014	6/20/2014	False	1.00	Generator Maintenance, Monthly Dennis Paul-Completed the PM, generator has 66.4 hours on it.
FO-285588	Finished	089-GEN-002	6/18/2014	6/18/2014	False	1.00	Generator Maintenance, Monthly Darnell Smiley-performed test check oil ok check belts ok check anti-freeze level ok and battery level full on both sides.ran generator ok.NOTICE THAT LOTS OF BLACK SMOKE COMES OUT ON START UP WITH THIS GENERATOR.
FO-285902	Finished	096-CFP-003	6/13/2014	6/17/2014	False	1.00	PM - Chemical Feed/Metering Pump/Controller Darnell Smiley-Check pump operation check for leaks and noise and vibration cleaned area increased stroke and flush lines clean strainers blow off ok called Eldon water to let them know that the center pump is leaking.
FO-285903	Finished	089-HWP-003	6/15/2014	6/16/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. Darnell Smiley-Checked coupling aligment strainers. lube both motor and pump bearings check for noise and vibration.Check condition on pump and motor and cleaned around area.

**Requested Finished Open WND**

**% Finished**

FO-285904	Finished	089-HWP-003S	6/15/2014	6/16/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. Darnell Smiley-Check condition of pump running ok coupling alignment ok lube both pump and motor check for noise and vibration.cleaned around area.
FO-285923	Finished	089-CRP-001	6/15/2014	6/16/2014	False	0.50	PM - Centrifugal Pump, over 1 H.P. Darnell Smiley-Check condition of pump ok.Check for noise and vibration .pump is in operation and running fine.
FO-285924	Finished	089-CRP-002	6/15/2014	6/16/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. Darnell Smiley-Check condition of pump ok .this pump is on line.Coupling alignment ok.lube both pump and motor.check for noise and vibration.
FO-285926	Finished	090-DWBP-003	6/15/2014	6/16/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. Robert McPherson-Grease motor bearings, check ops, normal.
FO-285927	Finished	090-DWBP-004	6/15/2014	6/16/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. Robert McPherson-Greased motor bearings, check ops, all normal.
FO-285931	Finished	090-ACU-403	6/15/2014	6/24/2014	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Robert McPherson-Johnson Controls has completed this PM.
FO-285932	Finished	090-ACU-402	6/15/2014	6/24/2014	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Robert McPherson-Johnson Controls has completed this PM.
FO-285933	Finished	090-ACU-401	6/15/2014	6/24/2014	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Robert McPherson-Johnson Controls has completed this PM.
FO-285934	Finished	022-ACU-001	6/15/2014	6/23/2014	False	1.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers Checked operation of the unit, checked PRV for proper steam pressure, ran the purge pump for 6.0 hours( every week), checked cond. and chilled water pumps operation, cleaned strainers on cond. water pumps # 1&2.
FO-285935	Finished	007-ACU-002	6/15/2014	6/26/2014	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers John Covert-Sisung-Provide access. Contractor reports work is complete and a written report will be turned in to FP&M. Work completed earlier this month.
FO-285936	Finished	007-ACU-001	6/15/2014	6/26/2014	False	0.50	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers John Covert-Sisung-Provide access. Contractor reports work is complete and a written report will be turned in to FP&M. Work completed earlier this month.
FO-285954	Finished	096-ACU-001	6/15/2014	6/17/2014	False	6.00	PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers Darnell Smiley-Check chiller for leaks check chiller for noise and vibration check oil level normal and check refrigerant level normal chiller in operation and running logs in place.
FO-286749	Finished	007-AHU-007	6/14/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286750	Finished	007-AHU-006	6/14/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286751	Finished	007-AHU-005	6/14/2014	6/14/2014	False	4.00	Replace PRE-filters
FO-286752	Finished	007-AHU-004	6/14/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286753	Finished	007-AHU-003	6/14/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286754	Finished	007-EXF-002	6/21/2014	6/14/2014	False	4.00	Replace PRE-filters
FO-286755	Finished	007-EXF-001	6/21/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286756	Finished	007-AHU-002	6/14/2014	6/14/2014	False	2.00	Replace PRE-filters
FO-286757	Finished	007-AHU-001	6/14/2014	6/14/2014	False	4.00	Replace PRE-filters
FO-287046	Created By PM Schedule	090-EXF-555A	6/28/2014		False	0.00	PM Replace Exhaust Air Filters
FO-287047	Created By PM Schedule	090-EXF-555B	6/28/2014		False		PM Replace Exhaust Air Filters
FO-287048	Created By PM Schedule	090-EXF-556A	6/28/2014		False		PM Replace Exhaust Air Filters
FO-287049	Created By PM Schedule	090-EXF-556B	6/28/2014		False		PM Replace Exhaust Air Filters
FO-287050	Created By PM Schedule	090-EXF-5410A	6/28/2014		False		PM Replace Exhaust Air Filters
FO-287051	Created By PM Schedule	090-EXF-5410B	6/28/2014		False		PM Replace Exhaust Air Filters



FO-287347	Finished	096-DHW-001	6/27/2014	6/30/2014	False	1.00	PM - Domestic Water Heater, Electric Darnell Smiley-Check unit for leaks check function of unit ok lift relief valve clean around area piping good unit running ok.
FO-287348	Finished	096-DHW-003	6/27/2014	6/30/2014	False	1.00	PM - Domestic Water Heater, Electric Darnell Smiley-check unit function ok check around unit for leaks lift relief valve hot and cold supply ok unit in good condition.
FO-287349	Finished	096-DHW-004	6/27/2014	6/30/2014	False	1.00	PM - Domestic Water Heater, Electric Darnell Smiley-Check around unit for leaks lift relief valve check piping and check function of unit ok
<b>E - Southeast</b>			<b>97</b>	<b>59</b>	<b>38</b>	<b>2</b>	<b>61%</b>
FO-284802	Completed	609-ACU-002	6/1/2014		True		PM - Carrier Chillers: Start Up Services for Centrifugal Chillers
FO-284803	Completed	609-ACU-001	6/1/2014		True		PM - Carrier Chillers: Start Up Services for Centrifugal Chillers
FO-285187	Created By PM Schedule	001-CRP-001	6/6/2014		False		PM - Condensate Return Pump
FO-285188	Created By PM Schedule	001-CRP-002	6/6/2014		False		PM - Condensate Return Pump
FO-285189	Created By PM Schedule	001-CRP-003	6/6/2014		False		PM - Condensate Return Pump
FO-285190	Created By PM Schedule	001-CRP-004	6/6/2014		False		PM - Condensate Return Pump
FO-285194	Finished	070-CRS-001*	6/5/2014	6/30/2014	False	1.00	PM - Condensate Return Pump William Willard-Completed the pm per the tasking sheet pm.
FO-285195	Finished	070-CRS-002*	6/5/2014	6/30/2014	False	1.00	PM - Condensate Return Pump William Willard-Finished the pm per the pm tasking sheet.
FO-285196	Finished	071-CRP-001	6/6/2014	6/10/2014	False	2.00	PM - Centrifugal Pump, over 1 H.P. William Willard-Completed the pm per the pm tasking sheet.
FO-285197	Finished	071-HWP-003	6/6/2014	6/9/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-285198	Finished	071-HWP-004	6/6/2014	6/9/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. William Willard-Finished the pm on the closed loop pumps per the tasking pm sheet
FO-285199	Finished	071-HWP-002	6/6/2014	6/9/2014	False	1.00	PM - Centrifugal Pump, over 1 H.P. William Willard-Completed the pm on the hot water circulating pump per the tasking sheet pm.
FO-285200	Finished	071-ACU-003	6/6/2014	6/10/2014	False	1.00	PM - Fan Coil/HV/AC Unit William Willard-Finished the pm on the a/c unit per the pm tasking sheet.
FO-285201	Finished	071-ACU-006	6/6/2014	6/10/2014	False	1.00	PM - Fan Coil/HV/AC Unit William Willard-Completed the pm on the coils of the a/c unit per the tasking pm sheet.
FO-285202	Finished	071-HWP-009	6/5/2014	6/9/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking pm sheet.
FO-285203	Finished	071-HWP-010	6/5/2014	6/9/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the pm tasking sheet.
FO-285204	Finished	071-HWP-011	6/5/2014	6/9/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the pm tasking sheet.
FO-285205	Finished	071-HWP-012	6/5/2014	6/9/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking pm sheet.
FO-285206	Finished	071-HWP-013	6/5/2014	6/9/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the pm tasking sheet
FO-285207	Finished	071-HWP-014	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking sheet pm.
FO-285208	Finished	071-HWP-015	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking pm sheet.

**Requested Finished Open WND**

**% Finished**

FO-285209	Finished	071-HWP-016	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the pm tasking sheet.
FO-285210	Finished	071-HWP-017	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking sheet pm.
FO-285211	Finished	071-HWP-018	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the tasking pm sheet.
FO-285212	Finished	071-HWP-019	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the pm tasking sheet
FO-285213	Finished	071-HWP-020	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the pm tasking sheet
FO-285214	Finished	071-HWP-021	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking sheet pm.
FO-285215	Finished	071-HWP-022	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm per the tasking pm sheet.
FO-285216	Finished	071-HWP-023	6/5/2014	6/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the pm tasking sheet
FO-285230	Created By PM Schedule	001-EW-001	6/4/2014		False		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-285231	Created By PM Schedule	001-EW-002	6/4/2014		False		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-285232	Created By PM Schedule	001-EW-003	6/4/2014		False		PM - Emergency Shower/Eyewash Station - Annual Flow Test
FO-285562	Finished	637-GEN-001	6/17/2014	6/23/2014	False		Generator Maintenance, Monthly checked fluids belts and battery
FO-285564	Finished	637-GEN-002	6/17/2014	6/23/2014	False		Generator Maintenance, Monthly checked fluids belts and battery
FO-285896	Finished	071-HWP-005	6/12/2014	6/23/2014	False	2.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm per the tasking sheet pm.
FO-285897	Finished	071-HWP-006	6/12/2014	6/12/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the pm tasking sheet.
FO-285898	Finished	071-HWP-007	6/12/2014	6/12/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the heat pump pm per the tasking pm sheet.
FO-285899	Finished	071-HWP-008	6/12/2014	6/12/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the tasking sheet pm.
FO-285900	Finished	071-HWP-215	6/12/2014	6/12/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the pm tasking sheet.
FO-285901	Finished	071-HWP-216	6/12/2014	6/12/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the pm tasking sheet.
FO-285913	Created By PM Schedule	499-CFP-001	6/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-285914	Created By PM Schedule	499-CFP-002	6/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-285915	Created By PM Schedule	499-CFP-003	6/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-285916	Created By PM Schedule	499-CFP-004	6/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-285917	Finished	071-HWP-222	6/11/2014	6/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking sheet pm.
FO-285918	Finished	071-HWP-223	6/11/2014	6/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the pm tasking sheet.
FO-285919	Finished	071-HWP-224	6/11/2014	6/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking pm sheet.

**Requested Finished Open WND**

**% Finished**

FO-285920	Finished	071-HWP-225	6/11/2014	6/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking sheet pm.
FO-285921	Finished	071-HWP-226	6/11/2014	6/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the pm tasking sheet.
FO-285922	Finished	071-HWP-227	6/11/2014	6/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking pm sheet.
FO-285937	Created By PM Schedule	001-ACU-003	6/15/2014		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-285938	Created By PM Schedule	001-ACU-002	6/15/2014		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-285939	Created By PM Schedule	001-ACU-001	6/15/2014		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-285948	Created By PM Schedule	189-ACU-003	6/15/2014		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-285952	Created By PM Schedule	609-ACU-002	6/15/2014		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-285953	Created By PM Schedule	609-ACU-001	6/15/2014		False		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-286710	Finished	071-HWP-187	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the pm tasking sheet.
FO-286711	Finished	071-HWP-188	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the tasking sheet pm.
FO-286712	Finished	071-HWP-189	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking sheet pm.
FO-286713	Finished	071-HWP-190	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per thepm tasking sheet.
FO-286714	Finished	071-HWP-191	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per he tasking pm sheet.
FO-286715	Finished	071-HWP-192	6/19/2014	6/23/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the pm tasking sheet.
FO-286716	Finished	071-HWP-193	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the tasking pm sheet.
FO-286717	Finished	071-HWP-194	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the heat pump pm per the pm Tasking sheet.
FO-286718	Finished	071-HWP-195	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished he heat pump pm per the tasking sheet pm.
FO-286719	Finished	071-HWP-196	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the tasking sheet pm.
FO-286720	Finished	071-HWP-197	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the heat pump pm per the tasking pm sheet.
FO-286721	Finished	071-HWP-198	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the heat pump pm per the tasking pm sheet.
FO-286722	Finished	071-HWP-199	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the tasking sheet pm.
FO-286723	Finished	071-HWP-200	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the pm tasking sheet.
FO-286724	Finished	071-HWP-201	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the heat pump pm per the pm tasking sheet.
FO-286725	Finished	071-HWP-202	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the heat pump pm per the tasking pm sheet.

**Requested Finished Open WND**

**% Finished**

FO-286726	Finished	071-HWP-203	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the tasking sheet pm.
FO-286727	Finished	071-HWP-204	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Finished the pm on the heat pump per the pm tasking sheet.
FO-286728	Finished	071-HWP-205	6/19/2014	6/24/2014	False	1.00	PM - Heat Pumps (5057 Woodward) William Willard-Completed the pm on the heat pump per the pm tasking sheet.
FO-286729	Created By PM Schedule	016-CRP-001	6/20/2014		False		PM - Condensate Return Pump
FO-286730	Finished	016-CRP-002	6/20/2014	6/24/2014	False	1.00	PM - Condensate Return Pump Checked operation of the unit, checked for any leaks, checked for any extra noise and vibration. Cleaned the unit. Also checked operation of the float level control.
FO-286731	Created By PM Schedule	001-AHU-001	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286732	Created By PM Schedule	001-AHU-001O	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286733	Created By PM Schedule	001-AHU-002	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286734	Created By PM Schedule	001-AHU-002O	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286735	Created By PM Schedule	001-AHU-003O	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286736	Created By PM Schedule	001-AHU-004O	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286737	Created By PM Schedule	001-AHU-001	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286738	Created By PM Schedule	001-AHU-001O	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286739	Created By PM Schedule	001-AHU-002	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286740	Created By PM Schedule	001-AHU-002O	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286741	Created By PM Schedule	001-AHU-003O	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286742	Created By PM Schedule	001-AHU-004O	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-286743	Created By PM Schedule	001-AHU-PRIM	6/20/2014		False		PM - Outside/Fresh Air Intake Screens
FO-286744	Created By PM Schedule	001-AHU-PRIM	6/20/2014		False		PM - Air Intake Dampers (Old Main)
FO-287345	Finished	071-EXF-001	6/27/2014	6/30/2014	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan William Willard-Completed the pm on exhaust fan #9 per the pm tasking sheet. The two A-60 belts need to be replaced. Asked supervisor for the same.
FO-287346	Finished	071-EXF-002	6/27/2014	6/30/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan William Willard-Finished the pm per the tasking pm sheet.
FO-287350	Created By PM Schedule	016-SP-003	6/27/2014		False		PM - Sump Pump
FO-287351	Created By PM Schedule	016-SP-004	6/27/2014		False		PM - Sump Pump
FO-287352	Created By PM Schedule	023-SP-001	6/27/2014		False		PM - Sump Pump
FO-287353	Created By PM Schedule	023-SP-002	6/27/2014		False		PM - Sump Pump
<b>E - West</b>			<b>14</b>	<b>5</b>	<b>9</b>	<b>0</b>	<b>36%</b>
FO-284795	Created By PM Schedule	080-AIR-003	6/1/2014		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-285191	Created By PM Schedule	155-DWBP-001	6/6/2014		False		PM - Centrifugal Pump, over 1 H.P.
FO-285192	Created By PM Schedule	155-DWBP-002	6/6/2014		False		PM - Centrifugal Pump, over 1 H.P.
FO-285193	Finished	167-DHW-001	6/8/2014	6/18/2014	False	2.00	PM - Domestic Water Heater, Gas
FO-285236	Created By PM Schedule	001 SPARE from	6/10/2014		False		Generator Maintenance, Monthly
FO-285587	Created By PM Schedule	169-GEN-001	6/26/2014		False		Generator Maintenance, Monthly
FO-285905	Finished	169-AHU-001	6/15/2014	6/23/2014	False	1.50	PM - Water/Air Cooled Condenser
FO-285906	Finished	169-AHU-002	6/15/2014	6/23/2014	False	1.50	PM - Water/Air Cooled Condenser
FO-285907	Finished	169-AHU-003	6/15/2014	6/24/2014	False	1.50	PM - Water/Air Cooled Condenser
FO-285908	Created By PM Schedule	169-AHU-004	6/15/2014		False		PM - Water/Air Cooled Condenser

## Requested Finished Open WND

% Finished

FO-285909	Finished	169-AHU-005	6/15/2014	6/25/2014	False	3.50	PM - Water/Air Cooled Condenser Jim Darga-There are (4) units for this one FO all completed
FO-285910	Created By PM Schedule	169-AHU-006	6/15/2014		False		PM - Water/Air Cooled Condenser
FO-285911	Created By PM Schedule	169-AHU-007	6/15/2014		False		PM - Water/Air Cooled Condenser
FO-285912	Created By PM Schedule	169-AHU-008	6/15/2014		False		PM - Water/Air Cooled Condenser

<b>Trades</b>	<b>34</b>	<b>33</b>	<b>1</b>	<b>0</b>	<b>97%</b>
---------------	-----------	-----------	----------	----------	------------

<b>T - Electrician</b>	<b>34</b>	<b>33</b>	<b>1</b>	<b>0</b>	<b>97%</b>
------------------------	-----------	-----------	----------	----------	------------

FO-285225	Finished	193-GEN-001	6/6/2014	6/5/2014	False	1.00	Generator Test Finished 6/9/2014LT
FO-285226	Finished	501-GEN-001	6/10/2014	6/10/2014	False	4.00	Generator Test Finished 6/11/2014LT
FO-285228	Finished	608-GEN-001	6/6/2014	6/5/2014	False	4.00	Generator Test Finished 6/9/2014LT
FO-285235	Finished	001 SPARE from	6/10/2014	6/10/2014	False	4.00	Generator Test Finished 6/11/2014LT
FO-285237	Finished	193-GEN-002	6/6/2014	6/5/2014	False	1.00	Generator Test Finished 6/9/2014LT
FO-285238	Created By PM Schedule	193-GEN-003	6/6/2014		False	1.00	Generator Test
FO-285239	Finished	193-GEN-004	6/6/2014	6/5/2014	False	1.00	Generator Test Finished 6/9/2014LT
FO-285536	Finished	609-GEN-001	6/17/2014	6/17/2014	False	6.00	Generator Test Finished 6/17/2014
FO-285538	Finished	007-GEN-001	6/12/2014	6/12/2014	False	2.00	Generator Test Finished 6/13/2014LT
FO-285540	Finished	007-GEN-002	6/12/2014	6/12/2014	False	2.00	Generator Test Finished 6/13/2014LT
FO-285542	Finished	090-GEN-001	6/17/2014	6/18/2014	False	4.00	Generator Test Finished 6/19/2014LT
FO-285544	Finished	089-GEN-001	6/18/2014	6/18/2014	False	4.00	Generator Test Finished 6/19/2014LT
FO-285546	Finished	066-GEN-001	6/25/2014	6/25/2014	False		Generator Test Finished 6/26/2014LT
FO-285547	Finished	611-GEN-001	6/27/2014	6/27/2014	False		Generator Test
FO-285549	Finished	629-GEN-001	6/27/2014	6/27/2014	False		Generator Test
FO-285551	Finished	104-GEN-001	6/24/2014	6/24/2014	False	4.00	Generator Test Finished 6/25/2014LT
FO-285553	Finished	127-GEN-001	6/24/2014	6/24/2014	False	1.00	Generator Test Finished 6/25/2014LT
FO-285555	Finished	127-GEN-002	6/24/2014	6/24/2014	False	1.00	Generator Test Finished 6/25/2014LT
FO-285557	Finished	127-GEN-003	6/24/2014	6/24/2014	False	1.00	Generator Test Finished 6/25/2014LT
FO-285559	Finished	127-GEN-004	6/24/2014	6/24/2014	False	1.00	Generator Test Finished 6/25/2014LT
FO-285561	Finished	637-GEN-001	6/17/2014	6/17/2014	False	2.00	Generator Test Finished 6/17/2014
FO-285563	Finished	637-GEN-002	6/17/2014	6/17/2014	False	2.00	Generator Test Finished 6/17/2014
FO-285565	Finished	130-GEN-001	6/25/2014	6/25/2014	False		Generator Test Finished 6/26/2014LT
FO-285567	Finished	612-GEN-001	6/13/2014	6/13/2014	False	2.00	Generator Test Finished 6/16/2014LT
FO-285569	Finished	612-GEN-002	6/13/2014	6/13/2014	False	1.00	Generator Test Finished 6/16/2014LT
FO-285571	Finished	507-GEN-001	6/11/2014	6/11/2014	False	4.00	Generator Test Finished 6/12/2014LT
FO-285573	Finished	203-GEN-001	6/17/2014	6/17/2014	False	4.00	Generator Test Finished 6/17/2014
FO-285575	Finished	536-GEN-001	6/18/2014	6/18/2014	False	4.00	Generator Test Finished 6/19/2014LT
FO-285576	Finished	090-GEN-002	6/12/2014	6/12/2014	False	4.00	Generator Test Finished 6/13/2014LT
FO-285579	Finished	527-GEN-001	6/19/2014	6/19/2014	False	4.00	Generator Test Finished 6/20/2014LT
FO-285582	Finished	048-GEN-001	6/13/2014	6/13/2014	False	4.00	Generator Test Finished 6/16/2014LT
FO-285584	Finished	006-GEN-001	6/19/2014	6/19/2014	False	4.00	Generator Test Finished 6/20/2014LT
FO-285586	Finished	169-GEN-001	6/26/2014	6/26/2014	False	4.00	Generator Test Finished 6/27/2014LT
FO-285589	Finished	089-GEN-002	6/18/2014	6/18/2014	False	1.00	Generator Test Finished 6/19/2014LT

<b>Report Total</b>	<b>586</b>	<b>457</b>	<b>129</b>	<b>22</b>	<b>78%</b>
---------------------	------------	------------	------------	-----------	------------