

DRAFT Facilities Operations PM Analysis from 4/1/16 through 4/30/16

| Requested Finished Open WND | | | | | | | | | | % Finished | |
|--|------------------------|----------------|-----------|-----------|----|-------|------|---|--|------------|-----|
| Engineering | | 709 | | 475 | 82 | ### | | | | | 67% |
| E - Auxiliary | | 32 | | 25 | 7 | 0 | | | | | 78% |
| FO-342764 | Finished | 034-AHU-001 | 4/1/2016 | 4/26/2016 | | False | 1.50 | PM - Air Handling Unit | | | |
| Lubed motor and bearings, checked belts and changed pre-filters. | | | | | | | | | | | |
| FO-342765 | Finished | 034-AHU-002 | 4/1/2016 | 4/25/2016 | | False | 2.00 | PM - Air Handling Unit | | | |
| Lubed motor and bearings, checked belts and changed pre-filters. | | | | | | | | | | | |
| FO-342766 | Finished | 034-AHU-003 | 4/1/2016 | 4/20/2016 | | False | 0.25 | PM - Air Handling Unit | | | |
| Unit has been removed and will be replaced due to renovations. | | | | | | | | | | | |
| FO-342767 | Finished | 034-AHU-004 | 4/1/2016 | 4/26/2016 | | False | 1.00 | PM - Air Handling Unit | | | |
| Lubed motor and bearings, checked belts and changed filters. | | | | | | | | | | | |
| FO-342768 | Finished | 034-AHU-005 | 4/1/2016 | 4/20/2016 | | False | 0.25 | PM - Air Handling Unit | | | |
| Unit has been removed and will be replaced due to renovations. | | | | | | | | | | | |
| FO-342779 | Finished | 501-GEN-001 | 4/12/2016 | 4/12/2016 | | False | | Generator Maintenance, Monthly | | | |
| FO-342781 | Created By PM Schedule | 104-MUA-001 | 4/1/2016 | | | False | | PM - Air Handling Unit | | | |
| FO-342782 | Created By PM Schedule | 104-MUA-002 | 4/1/2016 | | | False | | PM - Air Handling Unit | | | |
| FO-342783 | Created By PM Schedule | 115-MUA-001 | 4/1/2016 | | | False | | PM - Air Handling Unit | | | |
| FO-342784 | Created By PM Schedule | 115-MUA-002 | 4/1/2016 | | | False | | PM - Air Handling Unit | | | |
| FO-342785 | Created By PM Schedule | 115-MUA-003 | 4/1/2016 | | | False | | PM - Air Handling Unit | | | |
| FO-342786 | Finished | 992-ES-001* | 4/4/2016 | 5/8/2015 | | False | | PM - Emergency Shower/Eyewash Station | | | |
| FO-342787 | Created By PM Schedule | 127-GCP-001 | 4/1/2016 | | | False | | PM - Centrifugal Pump, over 1 H.P. | | | |
| FO-342788 | Created By PM Schedule | 127-GCP-002 | 4/1/2016 | | | False | | PM - Centrifugal Pump, over 1 H.P. | | | |
| FO-342799 | Finished | 001 SPARE from | 4/12/2016 | 5/6/2016 | | False | | Generator Maintenance, Monthly | | | |
| FO-342804 | Finished | 134-FP-001 | 4/1/2016 | 4/3/2016 | | False | 0.25 | PM - Monthly Fire Alarm/Fire Protection System Test | | | |
| Took fire panel out of operation, opened sprinkler drain line to allow jockey and main fire pumps to stop, and restored fire panel to normal operation. | | | | | | | | | | | |
| FO-342805 | Finished | 127-FP-001 | 4/1/2016 | 5/2/2016 | | False | | PM - Monthly Fire Alarm/Fire Protection System Test | | | |
| FO-342806 | Finished | 115-FP-001 | 4/1/2016 | 4/29/2016 | | False | | PM - Monthly Fire Alarm/Fire Protection System Test | | | |
| FO-342807 | Finished | 104-FP-001 | 4/1/2016 | 4/29/2016 | | False | | PM - Monthly Fire Alarm/Fire Protection System Test | | | |
| FO-342808 | Finished | 507-FP-001 | 4/1/2016 | 4/29/2016 | | False | | PM - Monthly Fire Alarm/Fire Protection System Test | | | |
| FO-343387 | Finished | 507-GEN-001 | 4/13/2016 | 4/13/2016 | | False | 1.00 | Generator Maintenance, Monthly | | | |
| Secured elevators to ground level. Oil was changed out by electricians. Conducted test. Test was satisfactory. | | | | | | | | | | | |
| FO-343388 | Finished | 992-ES-001* | 4/11/2016 | 4/15/2016 | | False | | PM - Emergency Shower/Eyewash Station | | | |
| FO-343389 | Finished | 034-GEN-001 | 4/7/2016 | 4/7/2016 | | False | 0.50 | Generator Maintenance, Monthly | | | |
| Checked systems after monthly test. | | | | | | | | | | | |
| FO-343390 | Finished | 003-GEN-001 | 4/6/2016 | 4/6/2016 | | False | | Generator Maintenance, Monthly | | | |
| FO-343817 | Completed | 104-GEN-001 | 4/26/2016 | 4/26/2016 | | False | 1.00 | Generator Maintenance, Monthly | | | |
| Monthly test with WSU electricians Martin and Jeff. Shut down elevators at Ghafari during test. Ghafari fire alarm went off as building went from generator to utility power, 3rd floor flow switch. Reset panel and checked 3rd floor flow. Saw no problem. | | | | | | | | | | | |
| FO-343818 | Completed | 127-GEN-001 | 4/26/2016 | 4/26/2016 | | False | 0.25 | Generator Maintenance, Monthly | | | |
| Monthly test with WSU electricians Jeff and Martin. Saw no issues. | | | | | | | | | | | |

Requested Finished Open WND

% Finished

| | | | | | | | | |
|--|---|--------------|-----------|-----------|-----------|----------|--|------------|
| FO-343819 | Completed | 127-GEN-002 | 4/26/2016 | 4/26/2016 | False | 0.25 | Generator Maintenance, Monthly | |
| Monthly test with WSU electricians Martin and Jeff. Noticed no issues. | | | | | | | | |
| FO-343820 | Completed | 127-GEN-003 | 4/26/2016 | 4/26/2016 | False | 0.25 | Generator Maintenance, Monthly | |
| Monthly test with WSU electricians Jeff and Martin. Saw no issues. | | | | | | | | |
| FO-343821 | Completed | 127-GEN-004 | 4/26/2016 | 4/26/2016 | False | 0.25 | Generator Maintenance, Monthly | |
| Monthly test with WSU electricians Martin and Jeff. Noticed no issues. | | | | | | | | |
| FO-343823 | Finished | 536-GEN-001 | 4/20/2016 | 4/25/2016 | False | | Generator Maintenance, Monthly | |
| FO-343824 | Finished | 992-ES-001* | 4/18/2016 | 4/22/2016 | False | | PM - Emergency Shower/Eyewash Station | |
| FO-344606 | Finished | 992-ES-001* | 4/25/2016 | 4/29/2016 | False | | PM - Emergency Shower/Eyewash Station | |
| E - MedPharm | | | 53 | 8 | 43 | 2 | | 15% |
| FO-342479 | Finished inspected | 609-DHW-001 | 4/1/2016 | 4/4/2016 | False | | PM - Domestic Water Heater, Steam | |
| FO-342480 | Finished inspected | 609-DHW-002 | 4/1/2016 | 4/4/2016 | False | | PM - Domestic Water Heater, Steam | |
| FO-342481 | Finished inspected and lub | 609-SP-001 | 4/1/2016 | 4/4/2016 | False | | PM - Sump Pump | |
| FO-342482 | Finished inspected and lub | 609-SP-002 | 4/1/2016 | 4/4/2016 | False | | PM - Sump Pump | |
| FO-342483 | Finished checked pumps gauges cleaned unit | 603-DHW-001 | 4/1/2016 | 4/5/2016 | False | 1.00 | PM - Domestic Water Heater, Steam | |
| FO-342484 | Finished adjusted new steam regulator checked pumps | 603-DHW-002 | 4/1/2016 | 4/4/2016 | False | 1.00 | PM - Domestic Water Heater, Steam | |
| FO-342485 | Completed | 629-DWBP-001 | 4/1/2016 | | True | | PM - Centrifugal Pump, over 1 H.P. | |
| FO-342486 | Completed | 629-DWBP-002 | 4/1/2016 | | True | | PM - Centrifugal Pump, over 1 H.P. | |
| FO-342487 | Created By PM Schedule | 612-EXF-062 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342488 | Created By PM Schedule | 612-EXF-063 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342489 | Created By PM Schedule | 612-EXF-064 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342490 | Created By PM Schedule | 612-EXF-065 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342491 | Created By PM Schedule | 612-EXF-066 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342492 | Created By PM Schedule | 612-EXF-067 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342493 | Created By PM Schedule | 612-EXF-068 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342494 | Created By PM Schedule | 612-EXF-069 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342495 | Created By PM Schedule | 612-EXF-070 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342496 | Created By PM Schedule | 612-EXF-071 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342497 | Created By PM Schedule | 612-EXF-072 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342498 | Created By PM Schedule | 612-EXF-073 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342499 | Created By PM Schedule | 612-EXF-074 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342500 | Created By PM Schedule | 612-EXF-075 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342501 | Created By PM Schedule | 612-EXF-076 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342502 | Created By PM Schedule | 612-EXF-077 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342503 | Created By PM Schedule | 612-EXF-078 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342504 | Created By PM Schedule | 612-EXF-079 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |
| FO-342505 | Created By PM Schedule | 612-EXF-080 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan | |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|------------------------|--------------|-----------|-----------|-------|------|--|
| FO-342506 | Created By PM Schedule | 612-EXF-081 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342507 | Created By PM Schedule | 612-EXF-082 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342508 | Created By PM Schedule | 612-EXF-083 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342509 | Created By PM Schedule | 612-EXF-084 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342510 | Created By PM Schedule | 612-EXF-085 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342511 | Created By PM Schedule | 612-EXF-086 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342512 | Created By PM Schedule | 612-EXF-087 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342513 | Created By PM Schedule | 612-EXF-088 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342514 | Created By PM Schedule | 612-EXF-090 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342515 | Created By PM Schedule | 612-EXF-091 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342516 | Created By PM Schedule | 612-EXF-093 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342517 | Created By PM Schedule | 612-EXF-094 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342518 | Created By PM Schedule | 612-EXF-095 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342519 | Created By PM Schedule | 612-EXF-096 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342520 | Created By PM Schedule | 612-EXF-098 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342521 | Created By PM Schedule | 612-EXF-6345 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342522 | Created By PM Schedule | 612-EXF-8319 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-342523 | Created By PM Schedule | 612-WSS-001 | 4/1/2016 | | False | | PM - Water Softener |
| FO-342524 | Finished | 603-DHW-003 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Domestic Water Heater, Steam cleaned/checked pumps |
| FO-342525 | Created By PM Schedule | 612-GEN-001 | 4/12/2016 | | False | | Generator Maintenance, Monthly |
| FO-342526 | Created By PM Schedule | 612-GEN-002 | 4/12/2016 | | False | | Generator Maintenance, Monthly |
| FO-342527 | Created By PM Schedule | 608-GEN-001 | 4/5/2016 | | False | | Generator Maintenance, Monthly |
| FO-342528 | Created By PM Schedule | 603-GEN-001 | 4/5/2016 | | False | | Generator Maintenance, Monthly |
| FO-343356 | Finished | 609-GEN-001 | 4/19/2016 | 4/20/2016 | False | | Generator Maintenance, Monthly checked fluids |
| FO-343800 | Created By PM Schedule | 611-GEN-001 | 4/26/2016 | | False | | Generator Maintenance, Monthly |
| FO-343801 | Created By PM Schedule | 629-GEN-001 | 4/26/2016 | | False | | Generator Maintenance, Monthly |

E - North

49

46

3

0

94%

| | | | | | | | |
|-----------|----------|-------------|----------|-----------|-------|------|---|
| FO-342529 | Finished | 026-CFP-001 | 4/1/2016 | 4/28/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342530 | Finished | 026-SP-001 | 4/1/2016 | 3/29/2016 | False | 0.50 | PM - Sump Pump |
| FO-342531 | Finished | 026-SP-002 | 4/1/2016 | 3/29/2016 | False | 0.50 | PM - Sump Pump |
| FO-342532 | Finished | 050-SP-001 | 4/1/2016 | 4/4/2016 | False | 2.00 | PM - Sump Pump |
| FO-342533 | Finished | 050-SP-002 | 4/1/2016 | 4/6/2016 | False | 2.00 | PM - Sump Pump |
| FO-342534 | Finished | 049-CFP-002 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342535 | Finished | 049-CFP-003 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342536 | Finished | 049-CFP-004 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342537 | Finished | 038-SP-001 | 4/1/2016 | 4/28/2016 | False | 0.50 | PM - Sump Pump |

Checked pump for problems, lubed shaft.

| | | | | | | | |
|-----------|----------|------------|----------|-----------|-------|------|----------------|
| FO-342538 | Finished | 038-SP-002 | 4/1/2016 | 4/28/2016 | False | 0.50 | PM - Sump Pump |
|-----------|----------|------------|----------|-----------|-------|------|----------------|

Checked pump for problems lubed shaft.

| | | | | | | | |
|-----------|----------|------------|----------|----------|-------|------|----------------|
| FO-342539 | Finished | 039-SP-001 | 4/1/2016 | 5/2/2016 | False | 0.75 | PM - Sump Pump |
|-----------|----------|------------|----------|----------|-------|------|----------------|

Greased pump and motor bearings, checked unit operation.

Requested Finished Open WND

% Finished

| | | | | | | | |
|---|------------------------|---------------|-----------|-----------|-------|------|--|
| FO-342540 | Finished | 039-SP-002 | 4/1/2016 | 5/2/2016 | False | 0.50 | PM - Sump Pump |
| Pump and motor both new sealed bearings. Checked unit operation for problems. | | | | | | | |
| FO-342541 | Finished | 039-SP-003 | 4/1/2016 | 5/2/2016 | False | 0.75 | PM - Sump Pump |
| Greased pump and motor bearings. Checked unit operation. | | | | | | | |
| FO-342542 | Finished | 039-SP-004 | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Sump Pump |
| Greased pump and motor bearings, checked unit operation. | | | | | | | |
| FO-342543 | Finished | 039-SP-005 | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Sump Pump |
| Greased pump and motor bearings, checked unit operation. | | | | | | | |
| FO-342544 | Finished | 039-SP-006 | 4/1/2016 | 5/2/2016 | False | 0.75 | PM - Sump Pump |
| Greased pump and motor bearings, checked unit operation. | | | | | | | |
| FO-342545 | Finished | 042-SP-001 | 4/1/2016 | 5/11/2016 | False | 1.00 | PM - Sump Pump |
| Greased pump bearings, tightened loose coupling on shaft, checked for proper operation. | | | | | | | |
| FO-342546 | Finished | 042-SP-002 | 4/1/2016 | 5/11/2016 | False | 1.00 | PM - Sump Pump |
| Greased bearings, checked pump operation. | | | | | | | |
| FO-342547 | Finished | 043-SP-001 | 4/1/2016 | 4/29/2016 | False | 0.50 | PM - Sump Pump |
| Tested pump operation in hand and auto, float switch operation. | | | | | | | |
| FO-342548 | Finished | 043-SP-002 | 4/1/2016 | 4/29/2016 | False | 0.50 | PM - Sump Pump |
| Tested pump operation in hand and auto, float switch seems ok. put back in normal op. | | | | | | | |
| FO-342549 | Finished | 026-CFP-002 | 4/1/2016 | 4/28/2016 | False | | PM - Chemical Feed/Metering Pump/Controller |
| FO-342550 | Finished | 026-CFP-003 | 4/1/2016 | 4/28/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342551 | Finished | 026-CFP-004 | 4/1/2016 | 4/28/2016 | False | | PM - Chemical Feed/Metering Pump/Controller |
| FO-342552 | Finished | 033-HVU-001 | 4/3/2016 | 5/31/2016 | False | 0.50 | PM - Forced Air Furnace (Jacob House) - Summer |
| FO-342553 | Created By PM Schedule | 033-HVU-002 | 4/3/2016 | | False | | PM - Forced Air Furnace (Jacob House) - Summer |
| FO-342554 | Created By PM Schedule | 033-HVU-003 | 4/3/2016 | | False | | PM - Forced Air Furnace (Jacob House) - Summer |
| FO-342555 | Finished | 25-ROOF-Z2A3* | 4/1/2016 | 4/5/2016 | False | 0.75 | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342556 | Finished | 26-ROOF-Z2A3' | 4/1/2016 | 3/30/2016 | False | 1.00 | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342557 | Finished | 27-ROOF-Z2A3' | 4/1/2016 | 4/1/2016 | False | 0.75 | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342558 | Finished | 036-ROOF-Z2A3 | 4/1/2016 | 4/11/2016 | False | 0.75 | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342559 | Finished | 38-ROOF-Z2A3' | 4/1/2016 | 5/2/2016 | False | 0.50 | PM - Roof Sumps - Zone 2, Area 3 |
| Checked and cleared roof sump of debris. | | | | | | | |
| FO-342560 | Finished | 39-ROOF-Z2A3' | 4/1/2016 | 5/2/2016 | False | 0.50 | PM - Roof Sumps - Zone 2, Area 3 |
| Checked and cleared roof sumps of debris. | | | | | | | |
| FO-342561 | Finished | 40-ROOF-Z2A3' | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Roof Sumps - Zone 2, Area 3 |
| Checked roof sumps for debris, cleared if needed. | | | | | | | |
| FO-342562 | Finished | 42-ROOF-Z2A3' | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Roof Sumps - Zone 2, Area 3 |
| Cleared roof sumps of debris. | | | | | | | |
| FO-342563 | Finished | 43-ROOF-Z2A3' | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Roof Sumps - Zone 2, Area 3 |
| Checked roof sumps for debris cleared if needed. | | | | | | | |
| FO-342564 | Finished | 130-DHW-001 | 4/1/2016 | 4/6/2016 | False | 2.00 | PM - Domestic Water Heater, Electric |
| FO-342565 | Finished | 046-COT-001 | 4/1/2016 | 4/20/2016 | False | 2.15 | PM - Cooling Tower Start-up |
| FO-342566 | Finished | 048-GEN-001 | 4/12/2016 | 4/5/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-342567 | Finished | 026-ACU-014 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342568 | Finished | 026-ACU-013 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342569 | Finished | 026-ACU-012 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |

Requested Finished Open WND

% Finished

| | | | | | | | |
|---|------------------------|-------------|-----------|-----------|----------|----------|---------------------------------------|
| FO-342570 | Finished | 026-ACU-011 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342571 | Finished | 026-ACU-010 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342572 | Finished | 026-ACU-009 | 4/1/2016 | 4/29/2016 | False | | Replace PRE-filters |
| FO-342573 | Finished | 026-ACU-008 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342574 | Finished | 026-ACU-007 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-342575 | Finished | 026-ACU-006 | 4/1/2016 | 4/29/2016 | False | 0.50 | Replace PRE-filters |
| FO-343802 | Created By PM Schedule | 043-AHU-INT | 4/15/2016 | | False | | PM - Outside/Fresh Air Intake Screens |
| FO-344480 | Finished | 130-GEN-001 | 4/27/2016 | 4/27/2016 | False | 1.00 | Generator Maintenance, Monthly |
| E - Northeast | | | 69 | 65 | 4 | 0 | 94% |
| FO-341677 | Finished | 505-AHU-001 | 4/1/2016 | 4/5/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change | | | | | | | |
| FO-341678 | Finished | 505-AHU-002 | 4/1/2016 | 4/5/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change out | | | | | | | |
| FO-341679 | Finished | 505-AHU-003 | 4/1/2016 | 4/5/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change out | | | | | | | |
| FO-341680 | Finished | 505-AHU-004 | 4/1/2016 | 4/5/2016 | False | 1.00 | Replace PRE-filters |
| changed filter 20 X 25 X 1 | | | | | | | |
| FO-341681 | Finished | 505-AHU-005 | 4/1/2016 | 4/6/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change | | | | | | | |
| FO-341682 | Finished | 505-AHU-006 | 4/1/2016 | 4/6/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change | | | | | | | |
| FO-341683 | Finished | 505-AHU-007 | 4/1/2016 | 4/6/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filter not available to change | | | | | | | |
| FO-341684 | Finished | 505-AHU-008 | 4/1/2016 | 4/6/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filters not available to change | | | | | | | |
| FO-341685 | Finished | 505-AHU-009 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation, filters not available for replacement | | | | | | | |
| FO-341686 | Finished | 505-AHU-010 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filters not available for replacement | | | | | | | |
| FO-341691 | Finished | 505-AHU-011 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filters not available for replacement | | | | | | | |
| FO-341692 | Finished | 505-AHU-012 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| checked unit operation filters not available for replacement | | | | | | | |
| FO-342576 | Created By PM Schedule | 062-ACU-001 | 4/1/2016 | | False | | PM - Water/Air Cooled Condenser |
| FO-342577 | Created By PM Schedule | 062-ACU-002 | 4/1/2016 | | False | | PM - Water/Air Cooled Condenser |
| FO-342578 | Finished | 060-ACU-007 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342579 | Finished | 060-ACU-008 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342580 | Finished | 060-ACU-009 | 4/1/2016 | 5/11/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342581 | Finished | 060-ACU-010 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342582 | Finished | 060-ACU-011 | 4/1/2016 | 5/11/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342583 | Finished | 060-ACU-012 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342584 | Finished | 060-ACU-014 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342585 | Finished | 060-ACU-015 | 4/1/2016 | 5/10/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342586 | Finished | 060-ACU-016 | 4/1/2016 | 5/9/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |

Requested Finished Open WND

% Finished

| | | | | | | | |
|--|------------------------|-------------|-----------|-----------|-------|------|--|
| FO-342587 | Finished | 060-ACU-017 | 4/1/2016 | 5/3/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342588 | Finished | 060-ACU-018 | 4/1/2016 | 5/16/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342589 | Finished | 060-ACU-019 | 4/1/2016 | 5/16/2016 | False | 2.00 | PM - Fan Coil/HV/AC Unit |
| FO-342590 | Finished | 065-ACU-001 | 4/1/2016 | 5/27/2016 | False | 2.00 | PM - Water/Air Cooled Condenser |
| FO-342591 | Created By PM Schedule | 065-ACU-002 | 4/1/2016 | | False | | PM - Water/Air Cooled Condenser |
| FO-342592 | Finished | 065-ACU-003 | 4/1/2016 | 5/27/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342593 | Finished | 065-ACU-005 | 4/1/2016 | 5/26/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342594 | Finished | 065-ACU-007 | 4/1/2016 | 5/27/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342595 | Finished | 065-ACU-008 | 4/1/2016 | 5/27/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342596 | Created By PM Schedule | 065-ACU-009 | 4/1/2016 | | False | | PM - Water/Air Cooled Condenser |
| FO-342597 | Finished | 065-ACU-010 | 4/1/2016 | 5/24/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342598 | Finished | 066-ACU-001 | 4/1/2016 | 5/16/2016 | False | 2.00 | PM - Water/Air Cooled Condenser |
| FO-342599 | Finished | 066-ACU-002 | 4/1/2016 | 5/17/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342600 | Finished | 066-ACU-003 | 4/1/2016 | 5/16/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342601 | Finished | 067-ACU-001 | 4/1/2016 | 5/17/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-342602 | Finished | 067-ACU-002 | 4/1/2016 | 5/13/2016 | False | 4.00 | PM - Water/Air Cooled Condenser |
| FO-342603 | Finished | 510-ACU-001 | 4/1/2016 | 4/19/2016 | False | 4.00 | PM - Water/Air Cooled Condenser |
| washed condenser | | | | | | | |
| FO-342604 | Finished | 065-AIR-001 | 4/1/2016 | 5/2/2016 | False | 2.00 | PM - Air Compressor, Reciprocating 5-40 H.P. |
| FO-342605 | Finished | 067-AIR-001 | 4/1/2016 | 4/29/2016 | False | 1.50 | PM - Air Compressor, Reciprocating 5-40 H.P. |
| FO-342606 | Finished | 509-ACU-001 | 4/1/2016 | 4/15/2016 | False | 2.00 | PM - Water/Air Cooled Condenser |
| Condenser is of the plate type and cannot be cleaned, it must be replaced it becomes fouled However I cleaned the fine mesh strainer on the inlet to the condenser. | | | | | | | |
| FO-342607 | Finished | 509-ACU-002 | 4/1/2016 | 4/15/2016 | False | 2.00 | PM - Water/Air Cooled Condenser |
| The condenser is of the plate type and cannot be cleaned it must be replaced when fouled. I have cleaned the fine mesh screen on the strainer of the inlet water. The compressors are not of the reciprocating type and are scroll type. The P. M. task needs to be revised to reflect that. | | | | | | | |
| FO-342608 | Finished | 193-CFP-003 | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342609 | Finished | 193-CFP-004 | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342610 | Finished | 062-FCU-003 | 4/1/2016 | 5/18/2016 | False | 1.00 | PM - Fan Coil/HV/AC Unit |
| FO-342611 | Finished | 062-FCU-002 | 4/1/2016 | 5/4/2016 | False | | PM - Fan Coil/HV/AC Unit |
| FO-342612 | Finished | 062-FCU-001 | 4/1/2016 | 5/3/2016 | False | 1.00 | PM - Fan Coil/HV/AC Unit |
| FO-342613 | Finished | 062-FCU-004 | 4/1/2016 | 5/2/2016 | False | 1.00 | PM - Fan Coil/HV/AC Unit |
| FO-343357 | Finished | 203-GEN-001 | 4/19/2016 | 4/19/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343358 | Finished | 193-GEN-001 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343359 | Finished | 193-GEN-002 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343360 | Finished | 193-GEN-003 | 4/1/2016 | 4/8/2016 | False | | Generator Maintenance, Monthly |
| FO-343361 | Finished | 193-GEN-004 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343362 | Finished | 209-GEN-001 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343363 | Finished | 209-GEN-003 | 4/7/2016 | 4/7/2016 | False | 0.10 | Generator Maintenance, Monthly |
| FO-343364 | Finished | 209-GEN-004 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343365 | Finished | 209-GEN-002 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343366 | Finished | 211-GEN-001 | 4/1/2016 | 4/5/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343367 | Finished | 211-GEN-002 | 4/1/2016 | 4/5/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343368 | Finished | 209-EXF-031 | 4/1/2016 | 4/17/2016 | False | 2.00 | Replace PRE-filters |

Requested Finished Open WND

% Finished

| | | | | | | | |
|--|-----------|--------------|------------|-----------|----------|------|--|
| FO-343369 | Finished | 209-EXF-032 | 4/1/2016 | 4/24/2016 | False | 2.00 | Replace PRE-filters |
| FO-343370 | Finished | 209-EXF-033 | 4/1/2016 | 5/1/2016 | False | 2.00 | Replace PRE-filters |
| FO-344479 | Finished | 066-GEN-001 | 4/27/2016 | 4/27/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-344481 | Finished | 527-GEN-001 | 4/21/2016 | 4/20/2016 | False | 2.00 | Generator Maintenance, Monthly |
| Checked oil level coolant level louver operation battery cables heater | | | | | | | |
| FO-344484 | Finished | 060-GEN-001A | 4/28/2016 | 4/28/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-344485 | Finished | 060-GEN-001B | 4/28/2016 | 4/29/2016 | False | 2.00 | Generator Maintenance, Monthly |
| FO-344599 | Completed | 064-DHW-001 | 4/24/2016 | 5/3/2016 | False | 1.00 | PM - Domestic Water Heater, Gas |
| E - Preventative Maintenance | | 271 | 252 | 18 | 1 | | |
| FO-340905 | Finished | 130-EXF-001 | 4/1/2016 | 3/22/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340906 | Finished | 130-EXF-002 | 4/1/2016 | 3/22/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340907 | Finished | 130-EXF-003 | 4/1/2016 | 3/22/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340908 | Finished | 130-EXF-004 | 4/1/2016 | 3/22/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340909 | Finished | 090-EXF-001A | 4/1/2016 | 4/14/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340910 | Finished | 090-EXF-002A | 4/1/2016 | 4/14/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340911 | Finished | 090-EXF-003A | 4/1/2016 | 4/16/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340912 | Finished | 090-EXF-004A | 4/1/2016 | 4/16/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340913 | Finished | 090-EXF-005A | 4/1/2016 | 4/2/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340914 | Finished | 090-EXF-006A | 4/1/2016 | 4/20/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340915 | Finished | 090-EXF-007A | 4/1/2016 | 4/20/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340916 | Finished | 090-EXF-008A | 4/1/2016 | 4/20/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340917 | Finished | 090-EXF-009A | 4/1/2016 | 4/21/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340918 | Finished | 090-EXF-010A | 4/1/2016 | 4/21/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340919 | Finished | 090-EXF-011A | 4/1/2016 | 4/21/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340920 | Finished | 193-FCU-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Fan Coil/HV/AC Unit |
| FO-340921 | Finished | 090-EXF-005 | 4/1/2016 | 4/19/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340922 | Finished | 155-EXF-001 | 4/1/2016 | 3/31/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340923 | Finished | 155-EXF-002 | 4/1/2016 | 3/31/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340924 | Finished | 090-EXF-001 | 4/1/2016 | 4/14/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340925 | Finished | 090-EXF-002 | 4/1/2016 | 4/14/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340926 | Finished | 090-EXF-002E | 4/1/2016 | 4/15/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340927 | Finished | 090-EXF-002W | 4/1/2016 | 4/15/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340928 | Finished | 090-EXF-004 | 4/1/2016 | 4/16/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340929 | Finished | 090-EXF-006 | 4/1/2016 | 4/19/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340930 | Finished | 090-EXF-007 | 4/1/2016 | 4/20/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340931 | Finished | 090-EXF-021 | 4/1/2016 | 4/21/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340932 | Finished | 090-EXF-022 | 4/1/2016 | 4/21/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340933 | Finished | 090-EXF-024 | 4/1/2016 | 4/5/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340934 | Finished | 090-EXF-025 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340935 | Finished | 090-EXF-026 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340936 | Finished | 090-EXF-027 | 4/1/2016 | 4/8/2016 | False | 1.25 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340937 | Finished | 090-EXF-028 | 4/1/2016 | 4/2/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340938 | Finished | 090-EXF-029 | 4/1/2016 | 4/2/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340939 | Finished | 090-EXF-030 | 4/1/2016 | 4/2/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |

93%

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|------------------------|--------------|----------|-----------|-------|------|--|
| FO-340940 | Finished | 090-EXF-031 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340941 | Finished | 090-EXF-032 | 4/1/2016 | 4/5/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340942 | Finished | 090-EXF-033 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340943 | Finished | 090-EXF-034 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340944 | Finished | 090-EXF-035 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340945 | Finished | 090-EXF-036 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340946 | Finished | 090-EXF-037 | 4/1/2016 | 4/4/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340947 | Finished | 090-EXF-038 | 4/1/2016 | 4/5/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340948 | Finished | 090-EXF-040 | 4/1/2016 | 4/5/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340949 | Finished | 090-EXF-052 | 4/1/2016 | 4/19/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340950 | Finished | 090-EXF-053 | 4/1/2016 | 4/19/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340951 | Finished | 090-EXF-135 | 4/1/2016 | 4/5/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340952 | Finished | 090-EXF-EB | 4/1/2016 | 4/27/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340953 | Finished | 090-EXF-WB | 4/1/2016 | 4/27/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340954 | Finished | 090-SAF-EB | 4/1/2016 | 4/26/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340955 | Finished | 090-SAF-WB | 4/1/2016 | 4/26/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340956 | Finished | 612-EXF-013 | 4/1/2016 | 4/20/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340957 | Finished | 612-EXF-014 | 4/1/2016 | 4/26/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340958 | Created By PM Schedule | 612-EXF-015 | 4/1/2016 | | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340959 | Finished | 612-EXF-026 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340960 | Finished | 612-EXF-027 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340961 | Finished | 612-EXF-028 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340962 | Finished | 612-EXF-029 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340963 | Finished | 612-EXF-030 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340964 | Finished | 612-EXF-031 | 4/1/2016 | 4/12/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340965 | Finished | 612-EXF-032 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340966 | Finished | 612-EXF-033 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340967 | Finished | 612-EXF-034 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340968 | Finished | 612-EXF-037 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340969 | Finished | 612-EXF-038 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340970 | Finished | 612-EXF-039 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340971 | Finished | 612-EXF-041 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340972 | Finished | 612-EXF-042 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340973 | Finished | 612-EXF-043 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340974 | Finished | 612-EXF-044 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340975 | Finished | 612-EXF-089 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340976 | Finished | 096-SAF-0600 | 4/1/2016 | 4/2/2016 | False | 1.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340977 | Finished | 096-SAF-SFA | 4/1/2016 | 4/2/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-340985 | Finished | 603-ACU-005* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340986 | Finished | 603-ACU-002* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340987 | Finished | 603-ACU-004* | 4/1/2016 | 4/19/2016 | False | 2.00 | Replace PRE-filters |
| FO-340988 | Finished | 603-ACU-006* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340989 | Finished | 603-ACU-007* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340990 | Finished | 603-ACU-008* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|----------|--------------|----------|-----------|-------|------|---|
| FO-340991 | Finished | 603-ACU-010* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340992 | Finished | 603-ACU-011* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340993 | Finished | 603-ACU-012* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340994 | Finished | 603-ACU-013* | 4/1/2016 | 4/20/2016 | False | 2.00 | Replace PRE-filters |
| FO-340995 | Finished | 603-ACU-014* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340996 | Finished | 603-ACU-015* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340997 | Finished | 603-ACU-016* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340998 | Finished | 603-ACU-003* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-340999 | Finished | 603-ACU-001* | 4/1/2016 | 4/19/2016 | False | 2.00 | Replace PRE-filters |
| FO-341000 | Finished | 603-ACU-009* | 4/1/2016 | 4/26/2016 | False | 1.00 | Replace PRE-filters |
| FO-341001 | Finished | 090-EXF-003 | 4/1/2016 | 4/15/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341002 | Finished | 090-EXF-041 | 4/1/2016 | 4/15/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341003 | Finished | 090-EXF-042 | 4/1/2016 | 4/13/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341004 | Finished | 090-EXF-044 | 4/1/2016 | 4/12/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341005 | Finished | 090-EXF-045 | 4/1/2016 | 4/14/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341006 | Finished | 090-EXF-046 | 4/1/2016 | 4/15/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341007 | Finished | 090-EXF-048 | 4/1/2016 | 4/15/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341008 | Finished | 090-EXF-049 | 4/1/2016 | 4/16/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341009 | Finished | 090-EXF-B01 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341010 | Finished | 090-EXF-B02 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341011 | Finished | 090-EXF-B04 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341012 | Finished | 090-EXF-B05 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341013 | Finished | 090-EXF-B06 | 4/1/2016 | 4/20/2016 | False | 0.75 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341014 | Finished | 090-EXF-B07 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341015 | Finished | 090-EXF-B08 | 4/1/2016 | 4/6/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341016 | Finished | 090-EXF-B09 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341017 | Finished | 090-EXF-B10 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341018 | Finished | 090-EXF-B11 | 4/1/2016 | 4/7/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341019 | Finished | 090-EXF-B12 | 4/1/2016 | 4/21/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341020 | Finished | 046-FAP-001 | 4/1/2016 | 4/23/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341021 | Finished | 048-FAP-001 | 4/1/2016 | 4/14/2016 | False | 0.35 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341022 | Finished | 049-FAP-001 | 4/1/2016 | 4/23/2016 | False | 0.35 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341023 | Finished | 156-FAP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341024 | Finished | 499-FAP-001 | 4/1/2016 | 4/12/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341025 | Finished | 620-FAP-001 | 4/1/2016 | 4/19/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341026 | Finished | 036-FP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341027 | Finished | 025-FP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341028 | Finished | 007-FP-001 | 4/1/2016 | 4/30/2016 | False | 0.75 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341029 | Finished | 001-FP-001 | 4/1/2016 | 4/14/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341030 | Finished | 005-FAP-001 | 4/1/2016 | 4/30/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341031 | Finished | 040-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341032 | Finished | 038-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341033 | Finished | 028-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341034 | Finished | 026-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|----------|-------------|----------|-----------|-------|------|---|
| FO-341035 | Finished | 022-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341036 | Finished | 017-FAP-001 | 4/1/2016 | 4/8/2016 | False | 0.40 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341037 | Finished | 016-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341038 | Finished | 003-FAP-001 | 4/1/2016 | 4/30/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341039 | Finished | 006-FP-001 | 4/1/2016 | 4/30/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341040 | Finished | 050-FAP-001 | 4/1/2016 | 4/14/2016 | False | 0.40 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341041 | Finished | 043-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341042 | Finished | 042-FAP-001 | 4/1/2016 | 4/8/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341043 | Finished | 062-FP-001 | 4/1/2016 | 4/8/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341044 | Finished | 065-FP-001 | 4/1/2016 | 4/13/2016 | False | 0.35 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341045 | Finished | 068-FAP-001 | 4/1/2016 | 4/13/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341046 | Finished | 067-FP-001 | 4/1/2016 | 4/13/2016 | False | 0.35 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341047 | Finished | 089-FP-001 | 4/1/2016 | 4/30/2016 | False | 0.75 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341048 | Finished | 082-FP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341049 | Finished | 080-FAP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341050 | Finished | 090-FP-001 | 4/1/2016 | 4/27/2016 | False | 0.75 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341051 | Finished | 155-FP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341052 | Finished | 150-FAP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341053 | Finished | 167-FAP-001 | 4/1/2016 | 4/27/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341054 | Finished | 166-FP-001 | 4/1/2016 | 4/27/2016 | False | 0.75 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341055 | Finished | 140-FAP-001 | 4/1/2016 | 4/9/2016 | False | 0.35 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341056 | Finished | 130-FP-001 | 4/1/2016 | 4/8/2016 | False | 0.48 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341057 | Finished | 193-FAP-001 | 4/1/2016 | 4/19/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341058 | Finished | 189-FP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341059 | Finished | 510-FAP-001 | 4/1/2016 | 4/7/2016 | False | 0.25 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341060 | Finished | 509-FAP-001 | 4/1/2016 | 4/7/2016 | False | 0.45 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341061 | Finished | 504-FAP-001 | 4/1/2016 | 4/7/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341062 | Finished | 629-FP-001 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341063 | Finished | 612-FP-001 | 4/1/2016 | 4/28/2016 | False | 2.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341064 | Finished | 611-FP-001 | 4/1/2016 | 4/20/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341065 | Finished | 609-FP-001 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341066 | Finished | 603-FP-001 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341067 | Finished | 608-FP-001 | 4/1/2016 | 4/26/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341068 | Finished | 612-AHU-014 | 4/1/2016 | 4/7/2016 | False | 4.00 | Replace PRE-filters |
| FO-341069 | Finished | 612-AHU-013 | 4/1/2016 | 4/15/2016 | False | 4.00 | Replace PRE-filters |
| FO-341070 | Finished | 612-AHU-012 | 4/1/2016 | 4/5/2016 | False | 3.00 | Replace PRE-filters |
| FO-341071 | Finished | 612-AHU-011 | 4/1/2016 | 4/6/2016 | False | 6.00 | Replace PRE-filters |
| FO-341072 | Finished | 612-AHU-010 | 4/1/2016 | 4/6/2016 | False | 6.00 | Replace PRE-filters |
| FO-341073 | Finished | 612-AHU-009 | 4/1/2016 | 4/5/2016 | False | 6.00 | Replace PRE-filters |
| FO-341074 | Finished | 612-AHU-008 | 4/1/2016 | 4/12/2016 | False | 3.00 | Replace PRE-filters |
| FO-341075 | Finished | 612-AHU-007 | 4/1/2016 | 4/5/2016 | False | 6.00 | Replace PRE-filters |
| FO-341076 | Finished | 612-AHU-003 | 4/1/2016 | 4/7/2016 | False | 3.00 | Replace PRE-filters |
| FO-341077 | Finished | 612-AHU-002 | 4/1/2016 | 4/12/2016 | False | 1.50 | Replace PRE-filters |
| FO-341078 | Finished | 612-AHU-001 | 4/1/2016 | 4/11/2016 | False | 3.00 | Replace PRE-filters |

Requested Finished Open WND

% Finished

| | | | | | | | |
|---|-----------|-------------|----------|-----------|-------|------|---|
| FO-341079 | Finished | 074-FAP-001 | 4/1/2016 | 4/16/2016 | False | 0.30 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341080 | Finished | 166-HVU-001 | 4/1/2016 | 4/5/2016 | False | 0.75 | Replace PRE-filters |
| FO-341081 | Finished | 166-AHU-002 | 4/1/2016 | 4/11/2016 | False | 1.75 | Replace PRE-filters |
| FO-341082 | Finished | 166-AHU-001 | 4/1/2016 | 4/11/2016 | False | 1.75 | Replace PRE-filters |
| FO-341083 | Finished | 169-AHU-008 | 4/1/2016 | 4/20/2016 | False | 0.25 | Replace PRE-filters |
| FO-341084 | Finished | 169-AHU-007 | 4/1/2016 | 4/26/2016 | False | 0.50 | Replace PRE-filters |
| FO-341085 | Finished | 169-AHU-004 | 4/1/2016 | 4/19/2016 | False | 1.00 | Replace PRE-filters |
| FO-341086 | Finished | 169-AHU-003 | 4/1/2016 | 4/19/2016 | False | 1.00 | Replace PRE-filters |
| FO-341087 | Finished | 169-AHU-002 | 4/1/2016 | 4/19/2016 | False | 1.00 | Replace PRE-filters |
| FO-341088 | Finished | 169-AHU-001 | 4/1/2016 | 4/19/2016 | False | 1.00 | Replace PRE-filters |
| FO-341089 | Finished | 003-AHU-008 | 4/1/2016 | 4/27/2016 | False | 1.00 | Replace PRE-filters |
| FO-341090 | Finished | 003-AHU-007 | 4/1/2016 | 4/28/2016 | False | 2.00 | Replace PRE-filters |
| FO-341091 | Finished | 003-AHU-006 | 4/1/2016 | 4/27/2016 | False | 1.50 | Replace PRE-filters |
| FO-341092 | Finished | 003-AHU-005 | 4/1/2016 | 4/27/2016 | False | 1.50 | Replace PRE-filters |
| FO-341093 | Finished | 003-AHU-004 | 4/1/2016 | 4/21/2016 | False | 1.50 | Replace PRE-filters |
| FO-341094 | Finished | 003-AHU-003 | 4/1/2016 | 4/21/2016 | False | 1.50 | Replace PRE-filters |
| FO-341095 | Finished | 003-AHU-002 | 4/1/2016 | 4/28/2016 | False | 1.00 | Replace PRE-filters |
| FO-341096 | Finished | 003-AHU-001 | 4/1/2016 | 4/22/2016 | False | 2.00 | Replace PRE-filters |
| FO-341097 | Finished | 130-HVU-002 | 4/1/2016 | 5/5/2016 | False | 2.50 | Replace PRE-filters |
| FO-341098 | Finished | 130-HVU-001 | 4/1/2016 | 5/5/2016 | False | 2.50 | Replace PRE-filters |
| FO-341099 | Finished | 193-AHU-004 | 4/1/2016 | 3/29/2016 | False | 2.00 | Replace PRE-filters |
| FO-341100 | Finished | 193-AHU-003 | 4/1/2016 | 4/8/2016 | False | 3.50 | Replace PRE-filters |
| FO-341101 | Finished | 193-AHU-002 | 4/1/2016 | 4/5/2016 | False | 4.00 | Replace PRE-filters |
| FO-341102 | Finished | 193-AHU-001 | 4/1/2016 | 3/26/2016 | False | 1.50 | Replace PRE-filters |
| FO-341103 | Finished | 096-SAF-001 | 4/1/2016 | 4/26/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341104 | Finished | 096-RAF-010 | 4/1/2016 | 4/23/2016 | False | 2.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341105 | Finished | 096-RAF-00B | 4/1/2016 | 4/27/2016 | False | 5.50 | PM - Air Handling Unit (ANNUAL) |
| FO-341106 | Finished | 096-RAF-009 | 4/1/2016 | 4/26/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341107 | Finished | 096-RAF-008 | 4/1/2016 | 4/23/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341108 | Finished | 096-RAF-007 | 4/1/2016 | 4/22/2016 | False | 2.50 | PM - Air Handling Unit (ANNUAL) |
| FO-341109 | Finished | 096-RAF-006 | 4/1/2016 | 4/22/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341110 | Finished | 096-RAF-005 | 4/1/2016 | 4/21/2016 | False | 2.25 | PM - Air Handling Unit (ANNUAL) |
| FO-341111 | Finished | 096-RAF-004 | 4/1/2016 | 4/20/2016 | False | 4.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341112 | Finished | 096-RAF-003 | 4/1/2016 | 4/19/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341113 | Finished | 096-RAF-002 | 4/1/2016 | 4/19/2016 | False | 3.00 | PM - Air Handling Unit (ANNUAL) |
| FO-341114 | Cancelled | 096-SAF-B1 | 4/1/2016 | | False | | PM - Air Handling Unit (ANNUAL) |
| Unit does not exist - Equipment marked inactive and PM removed. | | | | | | | |
| FO-341115 | Finished | 096-SAF-FC1 | 4/1/2016 | 4/15/2016 | False | 1.00 | Replace PRE-filters |
| FO-341116 | Finished | 096-SAF-00E | 4/1/2016 | 4/27/2016 | False | 2.50 | Replace PRE-filters |
| FO-341117 | Finished | 155-AHU-005 | 4/1/2016 | 4/14/2016 | False | 1.50 | Replace PRE-filters |
| FO-341118 | Finished | 155-AHU-004 | 4/1/2016 | 4/15/2016 | False | 3.00 | Replace PRE-filters |
| FO-341119 | Finished | 155-AHU-003 | 4/1/2016 | 4/15/2016 | False | 3.00 | Replace PRE-filters |
| FO-341120 | Finished | 155-AHU-002 | 4/1/2016 | 4/15/2016 | False | 3.00 | Replace PRE-filters |
| FO-341121 | Finished | 155-AHU-001 | 4/1/2016 | 4/14/2016 | False | 2.00 | Replace PRE-filters |

Requested Finished Open WND

% Finished

| | | | | | | | |
|----------------|------------------------|--------------|----------|-----------|-------|------|---|
| FO-341122 | Finished | 150-AHU-003 | 4/1/2016 | 4/12/2016 | False | 2.25 | PM - Air Handling Unit (ANNUAL) |
| FO-341123 | Finished | 150-AHU-002 | 4/1/2016 | 4/12/2016 | False | 2.75 | PM - Air Handling Unit (ANNUAL) |
| FO-341124 | Finished | 150-AHU-001 | 4/1/2016 | 4/12/2016 | False | 2.25 | PM - Air Handling Unit (ANNUAL) |
| FO-341125 | Finished | 078-ACU-003 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| FO-341126 | Finished | 078-ACU-002B | 4/1/2016 | 4/7/2016 | False | 1.25 | Replace PRE-filters |
| FO-341127 | Finished | 078-ACU-002A | 4/1/2016 | 4/7/2016 | False | 1.25 | Replace PRE-filters |
| FO-341128 | Finished | 078-ACU-001 | 4/1/2016 | 4/7/2016 | False | 1.75 | Replace PRE-filters |
| FO-341129 | Finished | 091-AHU-002 | 4/1/2016 | 4/5/2016 | False | 2.50 | Replace PRE-filters |
| FO-341130 | Finished | 091-AHU-001 | 4/1/2016 | 4/5/2016 | False | 1.50 | Replace PRE-filters |
| FO-341131 | Finished | 499-AHU-007 | 4/1/2016 | 4/8/2016 | False | 2.50 | Replace PRE-filters |
| FO-341132 | Finished | 499-AHU-005 | 4/1/2016 | 4/9/2016 | False | 2.50 | Replace PRE-filters |
| FO-341133 | Finished | 499-AHU-004 | 4/1/2016 | 4/9/2016 | False | 3.00 | Replace PRE-filters |
| FO-341134 | Finished | 156-SAF-001 | 4/1/2016 | 4/6/2016 | False | 2.00 | Replace PRE-filters |
| FO-341155 | Finished | 499-AHU-006 | 4/1/2016 | 4/8/2016 | False | 0.25 | PM - Air Handling Unit (ANNUAL) |
| FO-341156 | Finished | 155-EXF-005 | 4/1/2016 | 4/1/2016 | False | 1.25 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341157 | Finished | 155-EXF-004 | 4/1/2016 | 3/31/2016 | False | 1.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341158 | Finished | 155-EXF-003 | 4/1/2016 | 3/31/2016 | False | 1.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341159 | Completed | 511-BFAH-001 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341160 | Completed | 511-AHU-206 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341161 | Completed | 511-AHU-205 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341162 | Completed | 511-AHU-204 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341163 | Completed | 511-AHU-203 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341164 | Completed | 511-AHU-202 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341165 | Completed | 511-AHU-201 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341166 | Completed | 511-AHU-007 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341167 | Completed | 511-AHU-006 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341168 | Completed | 511-AHU-005 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341169 | Completed | 511-AHU-004 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341170 | Completed | 511-AHU-003 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341171 | Completed | 511-AHU-002 | 4/1/2016 | | False | | Replace PRE-filters |
| FO-341172 | Completed | 511-AHU-001 | 4/1/2016 | 4/1/2016 | False | 1.00 | Replace PRE-filters |
| unit abandoned | | | | | | | |
| FO-341173 | Finished | 510-AHU-002 | 4/1/2016 | 4/9/2016 | False | 2.50 | Replace PRE-filters & Bags |
| FO-341174 | Finished | 510-AHU-001 | 4/1/2016 | 4/9/2016 | False | 3.00 | Change Pre-Filters & Bags |
| FO-341175 | Finished | 509-AHU-005 | 4/1/2016 | 4/22/2016 | False | 0.20 | Replace PRE-filters |
| FO-341176 | Finished | 509-AHU-004 | 4/1/2016 | 4/15/2016 | False | 3.00 | Replace PRE-filters |
| FO-341177 | Finished | 509-AHU-003 | 4/1/2016 | 4/12/2016 | False | 2.00 | Replace PRE-filters |
| FO-341178 | Finished | 509-AHU-002 | 4/1/2016 | 4/12/2016 | False | 2.00 | Replace PRE-filters |
| FO-341179 | Finished | 509-AHU-001 | 4/1/2016 | 4/16/2016 | False | 3.00 | Replace PRE-filters |
| FO-341180 | Finished | 612-HVU-001 | 4/1/2016 | 4/12/2016 | False | 2.00 | Replace PRE-filters |
| FO-341181 | Finished | 096-FP-001 | 4/1/2016 | 4/14/2016 | False | 1.00 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341189 | Created By PM Schedule | 130-SAF-003 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341190 | Created By PM Schedule | 130-SAF-002 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341191 | Created By PM Schedule | 130-SAF-001 | 4/1/2016 | | False | | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |

Requested Finished Open WND

% Finished

| | | | | | | | |
|--|-----------|---------------|-----------|-----------|----------|----------|---|
| FO-341192 | Finished | 130-EXF-006 | 4/1/2016 | 4/22/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341193 | Finished | 130-EXF-005 | 4/1/2016 | 4/22/2016 | False | 0.50 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341194 | Finished | 612-EXF-092 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Fan, Centrifugal: Supply/Return/Exhaust Fan |
| FO-341195 | Finished | 169-FAP-001 | 4/1/2016 | 4/27/2016 | False | 0.50 | PM - Monthly Fire Alarm/Fire Protection System Test |
| FO-341196 | Finished | 499-AHU-008 | 4/1/2016 | 4/8/2016 | False | 1.50 | Replace PRE-filters |
| FO-341197 | Finished | 169-AHU-005 | 4/1/2016 | 4/7/2016 | False | 1.00 | Replace PRE-filters |
| FO-341198 | Finished | 169-AHU-006 | 4/1/2016 | 4/20/2016 | False | 1.00 | Replace PRE-filters |
| FO-341199 | Finished | 099-AHU-001 | 4/1/2016 | 4/6/2016 | False | 1.50 | Replace PRE-filters |
| FO-341521 | Finished | 167-AHU-002 | 4/1/2016 | 4/13/2016 | False | 1.75 | Replace PRE-filters |
| FO-341531 | Finished | 167-AHU-001 | 4/1/2016 | 4/12/2016 | False | 1.75 | Replace PRE-filters |
| FO-341574 | Finished | 603-AHU-009 | 4/1/2016 | 4/19/2016 | False | 6.00 | Replace PRE-filters |
| FO-341575 | Finished | 603-AHU-008 | 4/1/2016 | 4/13/2016 | False | 4.00 | Replace PRE-filters |
| FO-341576 | Finished | 603-AHU-007 | 4/1/2016 | 4/14/2016 | False | 4.00 | Replace PRE-filters |
| FO-341577 | Completed | 603-AHU-006 | 4/1/2016 | | True | | Replace PRE-filters |
| FO-341620 | Finished | 090-EXF-555A | 4/1/2016 | 4/26/2016 | False | 1.00 | PM Replace Exhaust Air Filters |
| FO-341621 | Finished | 090-EXF-555B | 4/1/2016 | 4/26/2016 | False | 1.00 | PM Replace Exhaust Air Filters |
| FO-341622 | Finished | 090-EXF-556A | 4/1/2016 | 4/26/2016 | False | 1.00 | PM Replace Exhaust Air Filters |
| FO-341623 | Finished | 090-EXF-556B | 4/1/2016 | 4/26/2016 | False | 1.00 | PM Replace Exhaust Air Filters |
| E - South | | | 27 | 27 | 0 | 0 | 100% |
| FO-342642 | Finished | 006-SUP-001 | 4/1/2016 | 4/6/2016 | False | 0.10 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342643 | Finished | 006-SUP-002 | 4/1/2016 | 4/6/2016 | False | 0.10 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342644 | Finished | 006-SUP-003 | 4/1/2016 | 4/6/2016 | False | 0.10 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342645 | Finished | 006-SUP-004 | 4/1/2016 | 4/6/2016 | False | 0.10 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342646 | Finished | 006-SUP-005 | 4/1/2016 | 4/6/2016 | False | 0.10 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342647 | Finished | 006-SUP-006 | 4/1/2016 | 4/6/2016 | False | 0.20 | PM - Centrifugal Pump, over 1 H.P. |
| FO-342760 | Finished | 96-ROOF-Z2A3' | 4/1/2016 | 4/12/2016 | False | 1.00 | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342789 | Finished | 090-CFP-541 | 4/1/2016 | 4/12/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342790 | Finished | 090-CFP-542 | 4/1/2016 | 4/12/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342791 | Finished | 090-CFP-543 | 4/1/2016 | 4/12/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342792 | Finished | 090-CTL-001 | 4/1/2016 | 4/12/2016 | False | 0.50 | PM - Chemical Feed/Metering Pump/Controller |
| FO-342793 | Finished | 090-SSF-541 | 4/1/2016 | 4/13/2016 | False | 1.00 | PM - Harmsco Side Stream Filter |
| FO-342794 | Finished | 090-ACU-541B | 4/2/2016 | 4/4/2016 | False | 0.10 | PM INSPECT AND CLEAN COIL |
| FO-342795 | Finished | 090-ACU-542B | 4/2/2016 | 4/26/2016 | False | 1.00 | PM INSPECT AND CLEAN COIL |
| FO-342796 | Finished | 090-ACU-543B | 4/2/2016 | 4/20/2016 | False | 1.00 | PM INSPECT AND CLEAN COIL |
| FO-343372 | Finished | 090-ACU-CR2 | 4/8/2016 | 4/5/2016 | False | 0.50 | Monthly AHU Inspection Clean Room Unit 2 |
| FO-343373 | Finished | 090-ACU-CR2 | 4/8/2016 | 4/5/2016 | False | 0.10 | PM - Annual Inspection of Air Handling Unit |
| FO-343374 | Finished | 090-ACU-CR1 | 4/8/2016 | 4/5/2016 | False | 1.00 | PM - Monthly AHU Inspection Clean Room Unit 1 |
| FO-343384 | Finished | 090-GEN-001 | 4/19/2016 | 4/19/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343391 | Finished | 005-GEN-001 | 4/6/2016 | 4/6/2016 | False | 0.80 | Generator Maintenance, Monthly |
| FO-343803 | Finished | 005-ACU-002 | 4/15/2016 | 4/29/2016 | False | 0.50 | PM - Water/Air Cooled Condenser |
| FO-343814 | Finished | 007-GEN-001 | 4/14/2016 | 4/14/2016 | False | 0.50 | Generator Maintenance, Monthly |
| Checked the fuel, oil, coolant, and battery levels. Check the general operation. All was okay. | | | | | | | |
| FO-343815 | Finished | 007-GEN-002 | 4/14/2016 | 4/14/2016 | False | 0.50 | Generator Maintenance, Monthly |
| Checked the fuel, oil, coolant, and battery levels. Check the general operation. All was okay. | | | | | | | |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|----------|-------------|-----------|-----------|-------|------|--------------------------------|
| FO-343816 | Finished | 089-GEN-001 | 4/20/2016 | 4/21/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343822 | Finished | 090-GEN-002 | 4/14/2016 | 4/14/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-343833 | Finished | 090-GEN-003 | 4/14/2016 | 4/14/2016 | False | 1.00 | Generator Maintenance, Monthly |
| FO-344482 | Finished | 006-GEN-001 | 4/21/2016 | 4/21/2016 | False | 0.80 | Generator Maintenance, Monthly |

E - Southeast

173

17

7

###

10%

| | | | | | | | |
|-----------|-----------|----------------|----------|--|------|--|---------------------------------|
| FO-340982 | Completed | 001-FCU-4418 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-340983 | Completed | 001-FCU-4117 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-340984 | Completed | 001-FCU-4130.2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342614 | Completed | 001-FCU-2323 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342615 | Completed | 001-FCU-2325 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342616 | Completed | 001-FCU-2326 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342617 | Completed | 001-FCU-2327 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342618 | Completed | 001-FCU-2329 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342619 | Completed | 001-FCU-2330 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342620 | Completed | 001-FCU-2332 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342621 | Completed | 001-FCU-2334-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342622 | Completed | 001-FCU-2334-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342623 | Completed | 001-FCU-2339-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342624 | Completed | 001-FCU-2339-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342625 | Completed | 001-FCU-2341 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342626 | Completed | 001-FCU-2343-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342627 | Completed | 001-FCU-2343-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342628 | Completed | 001-FCU-2345-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342629 | Completed | 001-FCU-2345-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342630 | Completed | 001-FCU-2347-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342631 | Completed | 001-FCU-2347-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342632 | Completed | 001-FCU-2354 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342633 | Completed | 001-FCU-2356 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342634 | Completed | 001-FCU-2359-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342635 | Completed | 001-FCU-2359-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342636 | Completed | 001-FCU-2360 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342637 | Completed | 001-FCU-2362 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342638 | Completed | 001-FCU-2365-1 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342639 | Completed | 001-FCU-2365-2 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342640 | Completed | 001-FCU-2366 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342641 | Completed | 001-FCU-2372 | 4/1/2016 | | True | | PM - Fan Coil/HV/AC Unit |
| FO-342648 | Completed | 071-AHU-001 | 4/1/2016 | | True | | PM - Air Handling Unit |
| FO-342649 | Completed | 071-AHU-002 | 4/1/2016 | | True | | PM - Air Handling Unit |
| FO-342650 | Completed | 071-HWP-099 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |
| FO-342651 | Completed | 071-HWP-100 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |
| FO-342652 | Completed | 071-HWP-101 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |
| FO-342653 | Completed | 071-HWP-102 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |
| FO-342654 | Completed | 071-HWP-103 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |
| FO-342655 | Completed | 071-HWP-104 | 4/1/2016 | | True | | PM - Heat Pumps (5057 Woodward) |

[illegible]

Requested Finished Open WND

% Finished

| | | | | | |
|-----------|-----------|--------------|----------|------|---------------------------------|
| FO-342700 | Completed | 071-HWP-149 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342701 | Completed | 071-HWP-150 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342702 | Completed | 071-HWP-151 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342703 | Completed | 071-HWP-152 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342704 | Completed | 071-HWP-153 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342705 | Completed | 071-HWP-154 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342706 | Completed | 071-HWP-155 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342707 | Completed | 071-HWP-156 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342708 | Completed | 071-HWP-157 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342709 | Completed | 071-HWP-158 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342710 | Completed | 071-HWP-159 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342711 | Completed | 071-HWP-160 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342712 | Completed | 071-HWP-161 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342713 | Completed | 071-HWP-162 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342714 | Completed | 071-HWP-163 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342715 | Completed | 071-HWP-164 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342716 | Completed | 071-HWP-165 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342717 | Completed | 071-HWP-166 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342718 | Completed | 071-HWP-167 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342719 | Completed | 071-HWP-168 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342720 | Completed | 071-HWP-169 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342721 | Completed | 071-HWP-170 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342722 | Completed | 071-HWP-171 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342723 | Completed | 071-HWP-172 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342724 | Completed | 071-HWP-173 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342725 | Completed | 071-HWP-174 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342726 | Completed | 071-HWP-175 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342727 | Completed | 071-HWP-176 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342728 | Completed | 071-HWP-177 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342729 | Completed | 071-HWP-178 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342730 | Completed | 071-HWP-179 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342731 | Completed | 071-HWP-180 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342732 | Completed | 071-HWP-181 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342733 | Completed | 071-HWP-182 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342734 | Completed | 071-HWP-183 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342735 | Completed | 071-HWP-184 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342736 | Completed | 071-HWP-185 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342737 | Completed | 071-HWP-186 | 4/1/2016 | True | PM - Heat Pumps (5057 Woodward) |
| FO-342738 | Completed | 001-FCU-4113 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |
| FO-342739 | Completed | 001-FCU-4115 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |
| FO-342740 | Completed | 001-FCU-4116 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |
| FO-342741 | Completed | 001-FCU-4119 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |
| FO-342742 | Completed | 001-FCU-4131 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |
| FO-342743 | Completed | 001-FCU-4135 | 4/1/2016 | True | PM - Fan Coil/HV/AC Unit |

Requested Finished Open WND

% Finished

| | | | | | | |
|--|------------------------|---------------|-----------|-----------|-------|---|
| FO-342744 | Completed | 001-FCU-4136 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342745 | Completed | 001-FCU-4137 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342746 | Completed | 001-FCU-4138 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342747 | Completed | 001-FCU-4139 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342748 | Completed | 001-FCU-4402 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342749 | Completed | 001-FCU-4404 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342750 | Completed | 001-FCU-4406 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342751 | Completed | 001-FCU-4411 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342752 | Completed | 001-FCU-4413 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342753 | Completed | 001-FCU-4416 | 4/1/2016 | True | | PM - Fan Coil/HV/AC Unit |
| FO-342754 | Completed | 001-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342755 | Finished | 116-ROOF-Z2A3 | 4/1/2016 | 4/19/2016 | False | 1.00 PM - Roof Sumps - Zone 2, Area 3 |
| Checked and cleaned all roof sumps. | | | | | | |
| FO-342756 | Finished | 122-ROOF-Z2A3 | 4/1/2016 | 4/8/2016 | False | 0.50 PM - Roof Sumps - Zone 2, Area 3 |
| Checked and cleaned all roof sumps. | | | | | | |
| FO-342757 | Finished | 123-ROOF-Z2A3 | 4/1/2016 | 4/8/2016 | False | 0.50 PM - Roof Sumps - Zone 2, Area 3 |
| Checked all roof sumps were clean. | | | | | | |
| FO-342758 | Completed | 170-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342759 | Completed | 171-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342761 | Completed | 189-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342762 | Completed | 199-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342763 | Completed | 504-ROOF-Z2A3 | 4/1/2016 | True | | PM - Roof Sumps - Zone 2, Area 3 |
| FO-342769 | Finished | 017-DHW-001 | 4/1/2016 | 4/8/2016 | False | 1.00 PM - Domestic Water Heater, Electric |
| Checked operation of the unit, checked the relief valve, checked for any leaks, checked operation of heating elements. Drained the sediments from the bottom of the tank. Cleaned the equipment. | | | | | | |
| FO-342770 | Completed | 074-DHW-001 | 4/3/2016 | True | | PM - Domestic Water Heater, Gas |
| FO-342773 | Created By PM Schedule | 504-GFF-001 | 4/1/2016 | False | | Gas Fired Furnace |
| FO-342774 | Completed | 001-SSF-001 | 4/1/2016 | True | | PM - Harmsco Side Stream Filter |
| FO-342775 | Completed | 001-SSF-002 | 4/1/2016 | True | | PM - Harmsco Side Stream Filter |
| FO-342800 | Created By PM Schedule | 504-GFF-003 | 4/1/2016 | False | | Gas Fired Furnace |
| FO-342801 | Created By PM Schedule | 504-GFF-002 | 4/1/2016 | False | | Gas Fired Furnace |
| FO-342802 | Created By PM Schedule | 504-GFF-004 | 4/1/2016 | False | | Gas Fired Furnace |
| FO-342803 | Created By PM Schedule | 082-ACU-003 | 4/1/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343371 | Completed | 071-HWP-001 | 4/10/2016 | True | | PM - Heat Pumps (5057 Woodward) |
| FO-343375 | Finished | 001-AHU-001 | 4/10/2016 | 4/15/2016 | False | 0.50 PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | |
| FO-343376 | Finished | 101-AHU-001ML | 4/10/2016 | 4/18/2016 | False | 0.50 PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | |
| FO-343377 | Finished | 001-AHU-001O | 4/10/2016 | 4/14/2016 | False | 0.50 PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | |
| FO-343378 | Finished | 001-AHU-002 | 4/10/2016 | 4/15/2016 | False | 0.50 PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | |
| FO-343379 | Finished | 101-AHU-002ML | 4/10/2016 | 4/18/2016 | False | 0.50 PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | |

Requested Finished Open WND

% Finished

| | | | | | | | |
|----------------------------|------------------------|---------------|-----------|-----------|-------|------|---|
| FO-343380 | Finished | 001-AHU-002O | 4/10/2016 | 4/14/2016 | False | 0.50 | PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | | |
| FO-343381 | Finished | 001-AHU-003ML | 4/10/2016 | 4/18/2016 | False | 0.50 | PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | | |
| FO-343382 | Finished | 001-AHU-003O | 4/10/2016 | 4/13/2016 | False | 0.50 | PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | | |
| FO-343383 | Finished | 001-AHU-004O | 4/10/2016 | 4/13/2016 | False | 0.50 | PM - Chilled Water Coils - Refill (Old Main) |
| PURGE AIR & REFILL SYSTEM. | | | | | | | |
| FO-343385 | Created By PM Schedule | 637-GEN-001 | 4/19/2016 | | False | | Generator Maintenance, Monthly |
| FO-343386 | Created By PM Schedule | 637-GEN-002 | 4/19/2016 | | False | | Generator Maintenance, Monthly |
| FO-344600 | Finished | 001-AHU-001O | 4/24/2016 | 5/4/2016 | False | 0.25 | PM - Steam Valves to PreHeat Coils - Close (Old Main) |
| ISOLATE STEAM VALVES | | | | | | | |
| FO-344601 | Finished | 001-AHU-002O | 4/24/2016 | 5/4/2016 | False | 0.25 | PM - Steam Valves to PreHeat Coils - Close (Old Main) |
| ISOLATE STEAM VALVE | | | | | | | |
| FO-344602 | Finished | 001-AHU-003O | 4/24/2016 | 5/4/2016 | False | 0.25 | PM - Steam Valves to PreHeat Coils - Close (Old Main) |
| ISOLATE STEAM VALVES | | | | | | | |
| FO-344603 | Finished | 001-AHU-004O | 4/24/2016 | 5/4/2016 | False | 0.25 | PM - Steam Valves to PreHeat Coils - Close (Old Main) |
| ISOLATE STEAM VALVES. | | | | | | | |
| FO-344604 | Completed | 071-HUM-001 | 4/23/2016 | | True | | PM - Humidifier |
| FO-344605 | Completed | 504-DHW-001 | 4/22/2016 | | True | | PM - Domestic Water Heater, Gas |

| | | | | | | | |
|-----------------|--|--|-----------|-----------|----------|----------|-------------|
| E - West | | | 35 | 35 | 0 | 0 | 100% |
|-----------------|--|--|-----------|-----------|----------|----------|-------------|

| | | | | | | | |
|-------------------|----------|-------------|----------|-----------|-------|------|---------------------------------|
| FO-341135 | Finished | 080-SAF-02A | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341136 | Finished | 080-SAF-01A | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s on unit | | | | | | | |
| FO-341137 | Finished | 080-SAF-018 | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341138 | Finished | 080-SAF-017 | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341139 | Finished | 080-SAF-016 | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341140 | Finished | 080-SAF-015 | 4/1/2016 | 4/25/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341141 | Finished | 080-SAF-014 | 4/1/2016 | 4/26/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341142 | Finished | 080-SAF-013 | 4/1/2016 | 4/26/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341143 | Finished | 080-SAF-012 | 4/1/2016 | 4/26/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341144 | Finished | 080-SAF-011 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341145 | Finished | 080-SAF-010 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-------------------|----------|-------------|-----------|-----------|-------|------|--------------------------------------|
| FO-341146 | Finished | 080-SAF-009 | 4/1/2016 | 4/27/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341147 | Finished | 080-SAF-008 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341148 | Finished | 080-SAF-007 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341149 | Finished | 080-SAF-006 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341150 | Finished | 080-SAF-005 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341151 | Finished | 080-SAF-004 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341152 | Finished | 080-SAF-003 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341153 | Finished | 080-SAF-002 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-341154 | Finished | 080-SAF-001 | 4/1/2016 | 4/28/2016 | False | 1.00 | PM - Air Handling Unit (ANNUAL) |
| PM,s done on unit | | | | | | | |
| FO-342771 | Finished | 156-DHW-001 | 4/1/2016 | 5/4/2016 | False | 1.00 | PM - Domestic Water Heater, Electric |
| did PM on tank | | | | | | | |
| FO-342772 | Finished | 156-DHW-002 | 4/1/2016 | 5/4/2016 | False | 0.75 | PM - Domestic Water Heater, Electric |
| didPM on tank | | | | | | | |
| FO-343804 | Finished | 166-ACU-001 | 4/15/2016 | 5/6/2016 | False | | PM - Clean MEB AC unit Condenser |
| FO-343805 | Finished | 166-ACU-002 | 4/15/2016 | 5/6/2016 | False | | PM - Clean MEB AC unit Condenser |
| FO-343806 | Finished | 169-AHU-001 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343807 | Finished | 169-AHU-002 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343808 | Finished | 169-AHU-003 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343809 | Finished | 169-AHU-004 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343810 | Finished | 169-AHU-007 | 4/15/2016 | 4/20/2016 | False | 1.00 | PM - Water/Air Cooled Condenser |
| FO-343811 | Finished | 169-AHU-008 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343812 | Finished | 166-ACU-001 | 4/15/2016 | 5/6/2016 | False | | PM - Clean MEB AC unit Condenser |
| FO-343813 | Finished | 166-ACU-002 | 4/15/2016 | 5/6/2016 | False | | PM - Clean MEB AC unit Condenser |
| FO-343825 | Finished | 169-AHU-005 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-343826 | Finished | 169-AHU-006 | 4/15/2016 | 5/6/2016 | False | | PM - Water/Air Cooled Condenser |
| FO-344483 | Finished | 169-GEN-001 | 4/28/2016 | 5/6/2016 | False | | Generator Maintenance, Monthly |

| | | | | | | | |
|----------------------------|------------------------|-------------|-----------|-----------|----------|------|--|
| Trades | | 142 | 98 | 38 | 6 | | 69% |
| T - Electrician | | 77 | 64 | 7 | 6 | | 83% |
| FO-342776 | Finished | 612-GEN-001 | 4/5/2016 | 4/12/2016 | False | 4.00 | Generator Test, Tuesday 4/12/2016 @ 7:15 AM. |
| ***FAULT ALARM FLASHING*** | | | | | | | |
| FO-342777 | Finished | 612-GEN-002 | 4/5/2016 | 4/12/2016 | False | 2.00 | Generator Test, Tuesday 4/12/2016 @ 7:15 AM. |
| FO-342778 | Finished | 501-GEN-001 | 4/5/2016 | 4/12/2016 | False | 4.00 | Generator Test, Tuesday 4/12/2016 @ 1PM. |
| FO-342780 | Created By PM Schedule | 608-GEN-001 | 4/5/2016 | | False | | Generator Test |
| FO-342797 | Finished | 048-GEN-001 | 4/5/2016 | 4/12/2016 | False | 4.00 | Generator Test, Tuesday 4/12/2016 @ 7:15AM. |

Requested Finished Open WND

% Finished

| | | | | | | | |
|--|-----------|----------------|-----------|-----------|-------|------|--|
| FO-342798 | Finished | 001 SPARE from | 4/5/2016 | 4/12/2016 | False | 8.00 | Generator Test, Tuesday 4/12/2016 @ 1PM. |
| FO-342809 | Finished | 603-GEN-001 | 4/5/2016 | 3/29/2016 | False | | Generator Test, postponed until Generator is tested, and passed. |
| Electricians could not perform test, generator is still breing corrected by contractor | | | | | | | |
| FO-342810 | Completed | 051-SP-001 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342811 | Finished | 051-SP-001 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-342813 | Completed | 051-SP-002 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342814 | Finished | 051-SP-002 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-342816 | Completed | 051-SP-003 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342817 | Finished | 051-SP-003 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-342819 | Completed | 051-SP-004 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342820 | Finished | 051-SP-004 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-342822 | Completed | 051-SP-005 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342823 | Finished | 051-SP-005 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-342825 | Completed | 051-SP-006 | 4/1/2016 | | True | | PM - Sump Pump |
| FO-342826 | Finished | 051-SP-006 | 4/4/2016 | 4/4/2016 | False | 0.25 | PM - Sump Pump |
| FO-343315 | Finished | 609-GEN-001 | 4/19/2016 | 4/19/2016 | False | 4.00 | Generator Test |
| FO-343316 | Finished | 007-GEN-001 | 4/14/2016 | 4/14/2016 | False | 2.00 | Generator Test |
| FO-343317 | Finished | 007-GEN-002 | 4/14/2016 | 4/14/2016 | False | 2.00 | Generator Test |
| FO-343318 | Finished | 090-GEN-001 | 4/19/2016 | 4/19/2016 | False | 4.00 | Generator Test |
| FO-343319 | Finished | 089-GEN-001 | 4/20/2016 | 4/20/2016 | False | 4.00 | Generator Test |
| FO-343320 | Finished | 066-GEN-001 | 4/27/2016 | 4/27/2016 | False | 4.00 | Generator Test Wednesday 4/27/2016 @ 7:15 AM. |
| FO-343321 | Finished | 611-GEN-001 | 4/26/2016 | 4/26/2016 | False | 4.00 | Generator Test Tuesday 4/26/2016 @ 7:15 AM. |
| FO-343322 | Finished | 193-GEN-001 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Test, Friday 4/1/2016 @ 2:15 PM. |
| FO-343323 | Finished | 104-GEN-001 | 4/26/2016 | 4/26/2016 | False | 4.00 | Generator Test Tuesday 4/26/2016 @ 10AM. |
| FO-343324 | Finished | 127-GEN-001 | 4/26/2016 | 4/26/2016 | False | 1.00 | Generator Test Tuesday 4/26/2016 @ 8AM. |
| FO-343325 | Finished | 127-GEN-002 | 4/26/2016 | 4/26/2016 | False | 1.00 | Generator Test Tuesday 4/26/2016 @ 8AM. |
| FO-343326 | Finished | 127-GEN-003 | 4/26/2016 | 4/26/2016 | False | 1.00 | Generator Test Tuesday 4/26/2016 @ 8AM. |
| FO-343327 | Finished | 127-GEN-004 | 4/26/2016 | 4/26/2016 | False | 1.00 | Generator Test Tuesday 4/26/2016 @ 8AM. |
| FO-343328 | Finished | 637-GEN-001 | 4/19/2016 | 4/19/2016 | False | 2.00 | Generator Test |
| FO-343329 | Finished | 637-GEN-002 | 4/19/2016 | 4/19/2016 | False | 2.00 | Generator Test |
| FO-343330 | Finished | 130-GEN-001 | 4/27/2016 | 4/27/2016 | False | 4.00 | Generator Test Wednesday 4/27/2016 @ 7:15 AM. |
| FO-343331 | Finished | 507-GEN-001 | 4/13/2016 | 4/13/2016 | False | 4.00 | Generator Test |
| FO-343332 | Finished | 203-GEN-001 | 4/19/2016 | 4/19/2016 | False | 4.00 | Generator Test |
| FO-343333 | Finished | 536-GEN-001 | 4/20/2016 | 4/20/2016 | False | 4.00 | Generator Test |
| FO-343334 | Finished | 608-GEN-001 | 4/1/2016 | 4/6/2016 | False | 4.00 | Generator Test, Tuesday 4/5/2016 @ 7:15 AM. |
| FO-343335 | Finished | 090-GEN-002 | 4/14/2016 | 4/14/2016 | False | 2.00 | Generator Test |
| FO-343336 | Finished | 527-GEN-001 | 4/21/2016 | 4/19/2016 | False | 4.00 | Generator Test |
| FO-343337 | Finished | 006-GEN-001 | 4/21/2016 | 4/21/2016 | False | 4.00 | Generator Test |
| FO-343338 | Finished | 193-GEN-002 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Test, Friday 4/1/2016 @ 2:15 PM. |
| FO-343339 | Finished | 193-GEN-003 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Test, Friday 4/1/2016 @ 2:15 PM. |
| Gen went into fault SD stop alarm after [10th shell.?] Reset fault @ Gen. Gen in normal & auto | | | | | | | |
| FO-343340 | Finished | 193-GEN-004 | 4/1/2016 | 4/1/2016 | False | 1.00 | Generator Test, Friday 4/1/2016 @ 2:15 PM. |
| FO-343341 | Finished | 169-GEN-001 | 4/28/2016 | 4/28/2016 | False | 4.00 | Generator Test Thursday 4/28/2016 @ 7:15. |
| On screen (alarm) sevice schedule a inspect air filter | | | | | | | |

Requested Finished Open WND

% Finished

| | | | | | | | |
|------------------------|------------------------|--------------|-----------|-----------|-----------|----------|--|
| FO-343342 | Finished | 060-GEN-001A | 4/28/2016 | 4/28/2016 | False | 2.00 | Generator Test Thursday 4/28/2016 @ 1PM. |
| FO-343343 | Finished | 060-GEN-001B | 4/28/2016 | 4/28/2016 | False | 2.00 | Generator Test Thursday 4/28/2016 @ 1PM. |
| FO-343344 | Finished | 034-GEN-001 | 4/7/2016 | 4/7/2016 | False | 4.00 | Generator Test, Thursday 4/7/2016 @ 7:30 AM. |
| Ran Gen test last week | | | | | | | |
| FO-343345 | Finished | 003-GEN-001 | 4/6/2016 | 4/6/2016 | False | 4.00 | Generator Test, Wednesday 4/6/2016 @ 7:30 AM. |
| FO-343346 | Finished | 005-GEN-001 | 4/6/2016 | 4/6/2016 | False | 4.00 | Generator Test, Wednesday 4/6/2016 @ 7:30 AM. |
| FO-343347 | Finished | 090-GEN-003 | 4/14/2016 | 4/14/2016 | False | 2.00 | Generator Test |
| FO-343348 | Finished | 209-GEN-002 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Test, Thursday 4/7/2016 @ 7:30 AM. |
| FO-343349 | Finished | 209-GEN-001 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Test, Thursday 4/7/2016 @ 7:30 AM. |
| FO-343350 | Finished | 209-GEN-003 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Test, Thursday 4/7/2016 @ 7:30 AM. |
| FO-343351 | Finished | 209-GEN-004 | 4/7/2016 | 4/7/2016 | False | 1.00 | Generator Test, Thursday 4/7/2016 @ 7:30 AM. |
| NOT IN AUTO/DO NOT RUN | | | | | | | |
| FO-343352 | Finished | 211-GEN-001 | 4/1/2016 | 4/1/2016 | False | 2.00 | Generator Test, Friday 4/1/2016 @ 7:15 AM. |
| FO-343353 | Finished | 211-GEN-002 | 4/8/2016 | 4/1/2016 | False | 2.00 | Generator Test, Friday 4/1/2016 @ 7:15 AM. |
| FO-343354 | Finished | 629-GEN-001 | 4/26/2016 | 4/26/2016 | False | 4.00 | Generator Test Tuesday 4/26/2016 @ 2PM. |
| FO-343392 | Finished | 051-SP-001 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343393 | Finished | 051-SP-002 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343394 | Finished | 051-SP-003 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343395 | Finished | 051-SP-004 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343396 | Finished | 051-SP-005 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343397 | Finished | 051-SP-006 | 4/11/2016 | 4/19/2016 | False | 0.25 | PM - Sump Pump |
| FO-343827 | Finished | 051-SP-001 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-343828 | Finished | 051-SP-002 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-343829 | Finished | 051-SP-003 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-343830 | Finished | 051-SP-004 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-343831 | Finished | 051-SP-005 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-343832 | Finished | 051-SP-006 | 4/18/2016 | 4/22/2016 | False | 0.25 | PM - Sump Pump |
| FO-344607 | Created By PM Schedule | 051-SP-001 | 4/25/2016 | | False | | PM - Sump Pump |
| FO-344608 | Created By PM Schedule | 051-SP-002 | 4/25/2016 | | False | | PM - Sump Pump |
| FO-344609 | Created By PM Schedule | 051-SP-003 | 4/25/2016 | | False | | PM - Sump Pump |
| FO-344610 | Created By PM Schedule | 051-SP-004 | 4/25/2016 | | False | | PM - Sump Pump |
| FO-344611 | Created By PM Schedule | 051-SP-005 | 4/25/2016 | | False | | PM - Sump Pump |
| FO-344612 | Created By PM Schedule | 051-SP-006 | 4/25/2016 | | False | | PM - Sump Pump |
| T - Plumber | | | 64 | 34 | 30 | 0 | 53% |
| FO-341364 | Finished | 042 | 4/1/2016 | 4/22/2016 | False | 2.00 | PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/4-4-16 ,,,,,,,,,, |
| FO-341365 | Finished | 527 | 4/1/2016 | 4/7/2016 | False | 11.00 | PM - Main Drain with Copper Sulfate / Snake drain ,,,,,,,,,, GS/4-4-16 ,,,,,,,,,, |
| FO-341366 | Hold for Funds | 608 | 4/1/2016 | | False | | **HFF PER DK \$211.26 |
| | | | | | | | PM - Waterless Urinals ,,,,,,,,,, MM/4-4-16 ,,,,,,,,,, |
| FO-341367 | Created By PM Schedule | 049 | 4/1/2016 | | False | | PM - Waterless Urinals ,,,,,,,,,, TT/4-4-16 ,,,,,,,,,, |
| FO-341368 | Created By PM Schedule | 090 | 4/1/2016 | | False | 1.00 | PM - Waterless Urinals ,,,,,,,,,, TT/4-4-16 ,,,,,,,,,, |
| FO-342962 | Finished | 608-RPZ-001 | 4/1/2016 | 4/4/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-4-16 ,,,,,,,,,, |
| FO-342963 | Finished | 608-RPZ-002 | 4/1/2016 | 4/4/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-4-16 ,,,,,,,,,, |

Requested Finished Open WND

% Finished

| | | | | | | | |
|-----------|------------------------|-------------|----------|-----------|-------|------|--|
| FO-342964 | Finished | 603-RPZ-002 | 4/1/2016 | 4/5/2016 | False | 4.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342965 | Finished | 603-RPZ-003 | 4/1/2016 | 4/5/2016 | False | | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342966 | Finished | 603-RPZ-004 | 4/1/2016 | 4/5/2016 | False | 2.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342967 | Created By PM Schedule | 603-RPZ-001 | 4/1/2016 | | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342968 | Finished | 603-RPZ-005 | 4/1/2016 | 4/6/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342969 | Finished | 603-RPZ-006 | 4/1/2016 | 4/25/2016 | False | 3.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342970 | Finished | 603-RPZ-007 | 4/1/2016 | 4/22/2016 | False | 2.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342971 | Finished | 603-RPZ-008 | 4/1/2016 | 4/19/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342972 | Finished | 603-RPZ-009 | 4/1/2016 | 4/19/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/ 4-5-16 ,,,,,,,,, |
| FO-342973 | Finished | 603-RPZ-010 | 4/1/2016 | 4/19/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342974 | Finished | 603-RPZ-011 | 4/1/2016 | 4/18/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342975 | Finished | 603-RPZ-012 | 4/1/2016 | 4/19/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342976 | Finished | 603-RPZ-013 | 4/1/2016 | 4/18/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342977 | Finished | 603-RPZ-014 | 4/1/2016 | 4/18/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342978 | Finished | 603-RPZ-015 | 4/1/2016 | 4/18/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342979 | Finished | 603-RPZ-016 | 4/1/2016 | 4/14/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342980 | Finished | 603-RPZ-017 | 4/1/2016 | 4/14/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342981 | Finished | 603-RPZ-018 | 4/1/2016 | 4/14/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342982 | Finished | 603-RPZ-019 | 4/1/2016 | 4/14/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342983 | Finished | 603-RPZ-020 | 4/1/2016 | 4/7/2016 | False | 1.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342984 | Finished | 603-RPZ-021 | 4/1/2016 | 4/7/2016 | False | 1.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342985 | Finished | 603-RPZ-022 | 4/1/2016 | 4/7/2016 | False | 1.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342986 | Finished | 603-RPZ-023 | 4/1/2016 | 4/7/2016 | False | 1.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342987 | Finished | 603-RPZ-024 | 4/1/2016 | 4/18/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |

Requested Finished Open WND

% Finished

| | | | | | | | |
|---------------------|------------------------|-------------|------------|------------|------------|------------|---|
| FO-342988 | Finished | 603-RPZ-025 | 4/1/2016 | 4/6/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342989 | Finished | 603-RPZ-026 | 4/1/2016 | 4/7/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342990 | Finished | 603-RPZ-027 | 4/1/2016 | 4/7/2016 | False | 1.50 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342991 | Finished | 603-RPZ-028 | 4/1/2016 | 4/7/2016 | False | 1.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-342992 | Finished | 603-RPZ-029 | 4/1/2016 | 4/6/2016 | False | 2.00 | 2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/4-5-16 ,,,,,,,,, |
| FO-344437 | Finished | 608-RPZ-003 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344438 | Finished | 603-RPZ-030 | 4/1/2016 | 4/13/2016 | False | 2.00 | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344439 | Created By PM Schedule | 127-RPZ-003 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344440 | Created By PM Schedule | 127-RPZ-004 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344441 | Created By PM Schedule | 127-RPZ-005 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344442 | Created By PM Schedule | 127-RPZ-006 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344443 | Created By PM Schedule | 127-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344444 | Created By PM Schedule | 127-RPZ-002 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344445 | Created By PM Schedule | 136-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344446 | Created By PM Schedule | 134-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344447 | Created By PM Schedule | 134-PVB-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Pressure Vacuum Breaker |
| FO-344448 | Created By PM Schedule | 104-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344449 | Created By PM Schedule | 104-RPZ-002 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344450 | Created By PM Schedule | 104-RPZ-003 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344451 | Created By PM Schedule | 104-RPZ-004 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344452 | Created By PM Schedule | 115-RPZ-003 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344453 | Created By PM Schedule | 115-RPZ-004 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344454 | Created By PM Schedule | 115-RPZ-002 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344455 | Created By PM Schedule | 115-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344456 | Created By PM Schedule | 115-RPZ-005 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344457 | Created By PM Schedule | 115-RPZ-006 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344458 | Created By PM Schedule | 115-RPZ-007 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344465 | Created By PM Schedule | 507-RPZ-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344466 | Created By PM Schedule | 507-RPZ-002 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344467 | Created By PM Schedule | 507-RPZ-003 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| FO-344468 | Created By PM Schedule | 507-PVB-001 | 4/1/2016 | | False | | PM - Preventative Maintenance - Pressure Vacuum Breaker |
| FO-344469 | Created By PM Schedule | 507-PVB-002 | 4/1/2016 | | False | | PM - Preventative Maintenance - Pressure Vacuum Breaker |
| FO-346006 | Created By PM Schedule | 608-RPZ-004 | 4/1/2016 | | False | | PM - Preventative Maintenance - Backflow Preventer Testing |
| T - Roofing | | | 1 | 0 | 1 | 0 | 0% |
| FO-348612 | Created By PM Schedule | 007 | 4/1/2016 | | False | | Check Roof-Chemistry North Substation (Flat-Roof) |
| Report Total | | | 851 | 573 | 120 | 158 | 67% |