

Facilities Operations Maint. "Work Not Done" Report 10/1/2014 through 10/31/2014

			Total per Trade		Emergency 1 day		High 3 <= days		Medium <=14 days		Low <=30 days		Routine
Trades			4 of 8	50%	0 of 1	0%	1 of 2	50%	1 of 1	100%	2 of 4	50%	0
T - Electrician			1 of 2	50%	0 of 1	0%	0 of 0	#Num!	1 of 1	100%	0 of 0	#Num!	0
1	FO-296401	Maint. Work Order	9/25/2014	10/7/2014	12	Emergency	WALL OUTLET IS SPARKING. (FOUNDRY BUILDING) NORTHEAST CORNER OF BUILDING.						
							This work order is being closed out and another work order will be issued when approved. 10-7-2014 SRP						
3	FO-299337	Maint. Work Order	10/21/2014	10/23/2014	2	Medium	please fix light (media production light) located on the left side wall/ceiling. It is not working and we do need this light for filming during the NIH-funded BEST program every Tuesday evening.						
							Completed 10-23-2014						
T - Plumber			3 of 6	50%	0 of 0	#Num!	1 of 2	50%	0 of 0	#Num!	2 of 4	50%	0
2	FO-297061	Maint. Work Order	10/3/2014	10/17/2014	14	High	RM 283 WATER LEAKING FROM UNDER SINK ,,,,,,,,,, GS/ 10-3-14 ,,,,,,,,,						
2	FO-299426	Maint. Work Order	10/22/2014	10/23/2014	1	High	Plumbers - Replace Circulating Pump on Hot Water System. Building has no Hot Water. Located in half Basement off of Machine Shop. Contact Lee Burkel 734-417-6192. Priority is High,,,,,,,,, GS/10-23-14 ,,,,,,,,,						
4	FO-294618	Maint. Work Order	9/5/2014	10/22/2014	47	Low	Replace failed RPZ for boiler feed water in basement mechanical room ,,,,,,,,,, DB/9-5-14 ,,,,,,,,,						
4	FO-296246	Maint. Work Order	9/23/2014	10/29/2014	36	Low	Hot Water in all areas of Library Dean's Office, Suite 1600, is not consistent. There will be hot water and then it goes away. This affects Ladies' Room, Men's Room, Dean's Office Kitchen.(SUITE 3100 NOT 1600 PER MARILY WEISS) ,,,,,,,,,, GS/9-26-14 ,,,,,,,,,						
4	FO-298182	Maint. Work Order	10/14/2014	10/30/2014	16	Low	P.M. urinal gaskets in basement mens room, Replace urinal fill valves ,,,,,,,,,, GS/ 10-14-14 ,,,,,,,,,						
4	FO-299593	Maint. Work Order	10/24/2014	10/28/2014	4	Low	Plumbers: Please disconnect water softener water supply remove softener off deteriorating steal grate and set softener on exiting cement slab reconnect water supply piping. ,,,,,,,,,, GS/10-24-14 ,,,,,,,,,						
Total:			4 of 8	50%	0 of 1	0%	1 of 2	50%	1 of 1	100%	2 of 4	50%	0