

DRAFT Facilities Operations PM Analysis from 12/1/14 through 12/31/14

		Requested		Finished	Open	WND			% Finished
Engineering		415	369	36	10				89%
E - Auxiliary		22	22	-1	1				100%
FO-301988	Finished	034-AIR-001	12/1/2014	12/10/2014		False	0.25	PM - Air Compressor, Reciprocating 5-40 H.P.	
Blew down compressor (moisture); checked oil; checked all connection									
FO-301989	Finished	034-AIR-002	12/1/2014	12/10/2014		False	0.25	PM - Air Compressor, Reciprocating 5-40 H.P.	
Blew down compressor (moisture); checked oil; checked all connections.									
FO-301999	Finished	127-MAU-005	12/1/2014	2/27/2015		True		PM - Fan Coil/HV/AC Unit	
FO-302000	Finished	992-ES-001*	12/1/2014	12/8/2014		False		PM - Emergency Shower/Eyewash Station	
FO-302021	Completed	134-FP-001	12/1/2014	12/2/2014		False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test	
drained sprinkler line to activate fire pump...fire pump started without issue									
FO-302022	Finished	127-FP-001	12/1/2014	12/24/2014		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-302023	Finished	115-FP-001	12/1/2014	12/24/2014		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-302024	Finished	104-FP-001	12/1/2014	12/24/2014		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-302025	Finished	507-FP-001	12/1/2014	12/24/2014		False		PM - Monthly Fire Alarm/Fire Protection System Test	
FO-302885	Finished	104-GEN-001	12/23/2014	12/24/2014		False		Generator Maintenance, Monthly	
FO-302887	Finished	127-GEN-001	12/23/2014	12/24/2014		False		Generator Maintenance, Monthly	
FO-302889	Finished	127-GEN-002	12/23/2014	12/24/2014		False		Generator Maintenance, Monthly	
FO-302891	Finished	127-GEN-003	12/23/2014	12/24/2014		False		Generator Maintenance, Monthly	
FO-302893	Finished	127-GEN-004	12/23/2014	12/24/2014		False		Generator Maintenance, Monthly	
FO-302905	Finished	501-GEN-001	12/9/2014	12/10/2014		False		Generator Maintenance, Monthly	
FO-302907	Finished	507-GEN-001	12/10/2014	12/10/2014		False		Generator Maintenance, Monthly	
FO-302915	Finished	536-GEN-001	12/17/2014	12/17/2014		False		Generator Maintenance, Monthly	
FO-302937	Finished	992-ES-001*	12/8/2014	12/12/2014		False		PM - Emergency Shower/Eyewash Station	
FO-303191	Finished	992-ES-001*	12/15/2014	12/19/2014		False		PM - Emergency Shower/Eyewash Station	
FO-303821	Finished	992-ES-001*	12/22/2014	12/24/2014		False		PM - Emergency Shower/Eyewash Station	
FO-303822	Finished	127-MAU-005	12/22/2014	12/23/2014		False		Housing Fog Treatment	
FO-304446	Finished	992-ES-001*	12/29/2014	1/2/2015		False		PM - Emergency Shower/Eyewash Station	
E - MedPharm		23	10	13	0				43%
FO-301861	Completed	603-HEX-001	12/1/2014	12/4/2014		False	1.00	PM - Heat Exchanger and Economizer	
checked t.d.s. level gauges/ done									
FO-301862	Completed	603-HEX-002	12/1/2014	12/4/2014		False	1.50	PM - Heat Exchanger and Economizer	
checked T.D.S. REPLACED STEAM GAUGE Cleaned strainer									
FO-301863	Finished	603-HEX-003*	12/1/2014	1/22/2015		False	1.00	PM - Heat Exchanger and Economizer	
Done. Cleaned, ran chem test									
FO-301865	Finished	609-ECO-001	12/1/2014	12/15/2014		False		PM - Heat Exchanger and Economizer	
finished									
FO-301866	Created By PM Schedule	611-AIR-001C**	12/1/2014			False		PM - Air Compressor, Reciprocating 5-40 H.P.	
FO-301867	Created By PM Schedule	611-HVU-001**	12/1/2014			False		PM - Fan Coil/HV/AC Unit	
FO-301868	Created By PM Schedule	611-HVU-004**	12/1/2014			False		PM - Fan Coil/HV/AC Unit	

Requested Finished Open WND

% Finished

FO-301869	Created By PM Schedule	629-AIR-001	12/1/2014		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301870	Created By PM Schedule	629-ROS-001	12/1/2014		False		PM - Reverse Osmosis Water Softener System
FO-301871	Finished	612-AIR-001	12/1/2014	12/5/2014	False	4.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301872	Finished	612-AIR-002	12/1/2014	12/12/2014	False	4.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301873	Finished	612-AIR-003	12/1/2014	12/19/2014	False	4.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301874	Finished	603-HEX-004*	12/1/2014	1/22/2015	False	1.00	PM - Heat Exchanger and Economizer
Done, checked control valves ran chem test							
FO-301875	Created By PM Schedule	611-AIR-001	12/1/2014		False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301876	Created By PM Schedule	629-WSS-001	12/1/2014		False		PM - Water Softener
FO-301877	Created By PM Schedule	629-ACU-002	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301878	Created By PM Schedule	629-ACU-001	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301879	Created By PM Schedule	612-ACU-003	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302880	Finished	611-GEN-001	12/26/2014	1/28/2015	False	0.10	Generator Maintenance, Monthly
Electricians did generator test							
FO-302882	Created By PM Schedule	629-GEN-001	12/26/2014		False		Generator Maintenance, Monthly
FO-302918	Finished	609-GEN-001	12/16/2014	1/21/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-303812	Created By PM Schedule	612-ACU-001	12/23/2014		False		PM - Absorption Unit
FO-303813	Created By PM Schedule	612-ACU-002	12/23/2014		False		PM - Absorption Unit
E - North			41	41	0	0	100%
FO-300972	Completed	130-AHU-004	12/1/2014	11/24/2014	False	2.00	Replace PRE-filters
FO-300973	Completed	130-AHU-003	12/1/2014	11/25/2014	False	2.00	Replace PRE-filters
FO-300974	Completed	130-AHU-002	12/1/2014	11/26/2014	False	2.00	Replace PRE-filters
FO-300975	Finished	130-AHU-001	12/1/2014	12/8/2014	False	1.50	Replace PRE-filters
FO-301880	Finished	140-AIR-001	12/1/2014	12/10/2014	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301881	Finished	140-AIR-002	12/1/2014	12/10/2014	False	0.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301882	Finished	050-AIR-001	12/1/2014	12/11/2014	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301883	Finished	050-AIR-002	12/1/2014	12/11/2014	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301884	Completed	048-HEX-001	12/1/2014	11/20/2014	False	0.75	PM - Heat Exchanger and Economizer
FO-301885	Completed	048-HEX-002	12/1/2014	11/20/2014	False	0.75	PM - Heat Exchanger and Economizer
FO-301886	Completed	027-HEX-001	12/1/2014	11/25/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301887	Completed	027-HEX-002	12/1/2014	11/21/2014	False	0.25	PM - Heat Exchanger and Economizer
FO-301888	Completed	027-HEX-003	12/1/2014	11/21/2014	False	0.25	PM - Heat Exchanger and Economizer
FO-301889	Completed	027-HEX-004	12/1/2014	11/25/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301890	Completed	036-HEX-001	12/1/2014	11/18/2014	False	0.25	PM - Heat Exchanger and Economizer
FO-301891	Completed	036-HEX-002	12/1/2014	11/18/2014	False	0.25	PM - Heat Exchanger and Economizer
FO-301892	Completed	048-DHW-001	12/1/2014	11/24/2014	False	6.50	PM - Domestic Water Heater, Steam
FO-301893	Finished	130-AIR-001	12/1/2014	12/16/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301894	Completed	046-HEX-001	12/1/2014	11/20/2014	False	0.65	PM - Heat Exchanger and Economizer
FO-301895	Completed	046-HEX-002	12/1/2014	11/20/2014	False	0.65	PM - Heat Exchanger and Economizer
FO-301896	Completed	046-HEX-003	12/1/2014	11/26/2014	False	0.75	PM - Heat Exchanger and Economizer

Requested Finished Open WND

% Finished

FO-301897	Completed	046-HEX-004	12/1/2014	11/26/2014	False	0.65	PM - Heat Exchanger and Economizer
FO-301898	Completed	046-HEX-005	12/1/2014	11/26/2014	False	0.65	PM - Heat Exchanger and Economizer
FO-301899	Finished	048-HEX-003	12/1/2014	12/5/2014	False	0.65	PM - Heat Exchanger and Economizer
FO-301901	Completed	026-HEX-002	12/1/2014	11/25/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301902	Finished	140-ACU-002	12/1/2014	12/19/2014	False	0.50	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301903	Finished	140-ACU-001	12/1/2014	12/19/2014	False	3.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301904	Finished	050-ACU-001	12/1/2014	12/22/2014	False	3.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301905	Completed	049-ACU-001	12/1/2014	11/26/2014	False	0.75	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301906	Completed	048-ACU-001	12/1/2014	11/25/2014	False	1.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301907	Finished	046-ACU-001	12/1/2014	12/5/2014	False	1.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301908	Finished	039-ACU-002	12/1/2014	12/9/2014	False	8.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Chiller service performed by Trane.							
FO-301909	Finished	039-ACU-001	12/1/2014	12/9/2014	False	8.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Routine PM performed by Trane units laid up for winter storage.							
FO-301910	Finished	026-ACU-003	12/1/2014	12/22/2014	False	0.50	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301911	Finished	026-ACU-002	12/1/2014	12/22/2014	False	0.50	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301912	Finished	026-ACU-001	12/1/2014	12/22/2014	False	0.50	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301913	Finished	043-ACU-001	12/1/2014	12/5/2014	False	2.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Unit checked for problems and operation. Water valve adjusted.							
FO-302899	Finished	130-GEN-001	12/24/2014	12/24/2014	False	1.00	Generator Maintenance, Monthly
FO-302920	Finished	048-GEN-001	12/12/2014	12/11/2014	False	0.65	Generator Maintenance, Monthly
FO-303190	Finished	130-AHU-001	12/10/2014	1/9/2015	False	0.50	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-304445	Finished	130-AHU-001	12/24/2014	1/23/2015	False	0.50	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
E - Northeast			14	14	0	0	100%
FO-301900	Finished	062-AIR-001	12/1/2014	1/13/2015	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-301915	Finished	193-HEX-001	12/1/2014	12/8/2014	False	2.00	PM - Heat Exchanger and Economizer
FO-301916	Finished	193-HEX-002	12/1/2014	12/8/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301917	Finished	193-ACU-001	12/1/2014	12/9/2014	False	2.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301918	Completed	062-ACU-002	12/1/2014	12/4/2014	False	2.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301919	Completed	062-ACU-001	12/1/2014	12/4/2014	False	2.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-301920	Finished	065-ACU-001	12/1/2014	12/5/2014	False	0.50	PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled) Chillers
FO-302877	Finished	066-GEN-001	12/24/2014	11/26/2014	False	1.00	Generator Maintenance, Monthly
FO-302909	Finished	203-GEN-001	12/16/2014	12/9/2014	False	1.00	Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-302917	Finished	527-GEN-001	12/18/2014	12/18/2014	False	1.50	Generator Maintenance, Monthly
Test ran gen. checked all fluid levels and louvers. reset ahu #1 & #3							
FO-302921	Finished	193-GEN-001	12/5/2014	12/8/2014	False		Generator Maintenance, Monthly
FO-302927	Finished	193-GEN-002	12/5/2014	12/8/2014	False	0.50	Generator Maintenance, Monthly
FO-302929	Finished	193-GEN-003	12/5/2014	12/17/2014	False	0.50	Generator Maintenance, Monthly
FO-302931	Finished	193-GEN-004	12/5/2014	12/4/2014	False	0.50	Generator Maintenance, Monthly
E - Preventative Maintenance			199	175	16	8	88%
FO-300481	Completed	050-RAF-001	12/1/2014		False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-300482	Finished	001-FCU-1321.2	12/1/2014	12/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300483	Finished	001-FCU-1321.3	12/1/2014	12/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300484	Finished	001-FCU-1321.4	12/1/2014	12/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300485	Finished	001-FCU-1321.5	12/1/2014	12/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300486	Finished	001-FCU-1321.6	12/1/2014	12/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300487	Finished	001-FCU-1321.7	12/1/2014	12/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300488	Finished	001-FCU-1321.8	12/1/2014	12/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300489	Completed	001-FCU-1324	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300490	Completed	001-FCU-1328	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300491	Completed	001-FCU-1332	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300492	Completed	001-FCU-1336-1	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300493	Completed	001-FCU-1336-2	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300494	Completed	001-FCU-1343-1	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300495	Completed	001-FCU-1343-2	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300496	Completed	001-FCU-1343-3	12/1/2014	12/3/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300497	Finished	001-FCU-1343-4	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300498	Finished	001-FCU-1343-5	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300499	Finished	001-FCU-1345-1	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300500	Finished	001-FCU-1345-2	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300501	Finished	001-FCU-1345-3	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300502	Finished	001-FCU-1345-4	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300503	Finished	001-FCU-1345-5	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300504	Finished	001-FCU-1353-1	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300505	Finished	001-FCU-1353-2	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300506	Finished	001-FCU-1354	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300507	Finished	001-FCU-1201	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300508	Finished	001-FCU-1209	12/1/2014	12/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-300509	Finished	001-FCU-1316	12/1/2014	12/20/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-300510	Finished	001-FCU-1318	12/1/2014	12/20/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-300511	Finished	001-FCU-1320	12/1/2014	12/20/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-300512	Finished	001-FCU-1321	12/1/2014	12/24/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-300513	Finished	001-FCU-1321.1	12/1/2014	12/24/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-300514	Finished	046-FAP-001	12/1/2014	12/22/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300515	Finished	048-FAP-001	12/1/2014	12/12/2014	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300516	Finished	049-FAP-001	12/1/2014	12/22/2014	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300517	Completed	156-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-300518	Finished	499-FAP-001	12/1/2014	12/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300519	Finished	620-FAP-001	12/1/2014	12/12/2014	False	0.39	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300520	Completed	036-FP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300521	Finished	025-FP-001	12/1/2014	12/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300522	Finished	007-FP-001	12/1/2014	12/19/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300523	Finished	001-FP-001	12/1/2014	12/12/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300524	Finished	005-FAP-001	12/1/2014	12/19/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300525	Completed	040-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300526	Completed	038-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300527	Completed	028-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300528	Completed	026-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300529	Completed	022-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300530	Completed	017-FAP-001	12/1/2014	12/3/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300531	Completed	016-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300532	Finished	003-FAP-001	12/1/2014	12/19/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300533	Finished	006-FP-001	12/1/2014	12/19/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300534	Finished	050-FAP-001	12/1/2014	12/5/2014	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300535	Completed	043-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300536	Completed	042-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300537	Finished	062-FP-001	12/1/2014	12/11/2014	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300538	Finished	065-FP-001	12/1/2014	12/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300539	Completed	068-FAP-001	12/1/2014	12/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300540	Finished	067-FP-001	12/1/2014	12/11/2014	False	0.44	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300541	Finished	089-FP-001	12/1/2014	12/19/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300542	Completed	082-FP-001	12/1/2014	12/3/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300543	Completed	080-FAP-001	12/1/2014	12/3/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300544	Finished	090-FP-001	12/1/2014	12/20/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300545	Finished	155-FP-001	12/1/2014	12/8/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300546	Completed	150-FAP-001	12/1/2014	12/2/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300547	Finished	167-FAP-001	12/1/2014	12/20/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300548	Finished	166-FP-001	12/1/2014	12/20/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300549	Finished	140-FAP-001	12/1/2014	12/5/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300550	Finished	130-FP-001	12/1/2014	12/5/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300551	Finished	193-FAP-001	12/1/2014	12/11/2014	False	0.34	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300552	Finished	189-FP-001	12/1/2014	12/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300553	Completed	510-FAP-001	12/1/2014	12/3/2014	False	0.55	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300554	Completed	509-FAP-001	12/1/2014	12/3/2014	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300555	Completed	504-FAP-001	12/1/2014	12/3/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300556	Completed	629-FP-001	12/1/2014	12/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300557	Finished	612-FP-001	12/1/2014	12/5/2014	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300558	Completed	611-FP-001	12/1/2014	12/4/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300559	Completed	609-FP-001	12/1/2014	12/4/2014	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300560	Finished	603-FP-001	12/1/2014	12/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300561	Completed	608-FP-001	12/1/2014	12/4/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-300562	Finished	603-AHU-010	12/1/2014	12/9/2014	False	2.00	Replace PRE-filters
FO-300563	Finished	603-AHU-009	12/1/2014	12/9/2014	False	2.00	Replace PRE-filters
FO-300564	Finished	603-AHU-008	12/1/2014	12/8/2014	False	2.00	Replace PRE-filters
FO-300565	Finished	603-AHU-007	12/1/2014	12/8/2014	False	2.00	Replace PRE-filters
FO-300566	Finished	603-AHU-006	12/1/2014	12/5/2014	False	2.00	Replace PRE-filters
FO-300567	Finished	637-AHU-004	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300568	Finished	637-AHU-003	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300569	Finished	637-AHU-002	12/1/2014	12/12/2014	False	2.00	Replace PRE-filters
FO-300570	Finished	637-AHU-001A	12/1/2014	12/12/2014	False	2.00	Replace PRE-filters
FO-300571	Finished	637-AHU-001	12/1/2014	12/12/2014	False	2.00	Replace PRE-filters
FO-300572	Finished	074-FAP-001	12/1/2014	12/12/2014	False	0.40	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300573	Finished	005-AHU-006	12/1/2014	12/19/2014	False	1.00	Replace PRE-filters
FO-300574	Finished	005-AHU-005	12/1/2014	12/19/2014	False	1.00	Replace PRE-filters
FO-300575	Finished	005-AHU-004	12/1/2014	12/19/2014	False	1.00	Replace PRE-filters
FO-300576	Finished	005-AHU-003	12/1/2014	12/20/2014	False	0.50	Replace PRE-filters
FO-300577	Finished	005-AHU-002	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters
FO-300578	Finished	005-AHU-001	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters
FO-300579	Finished	089-AHU-006	12/1/2014	12/17/2014	False	1.50	Replace PRE-filters
FO-300580	Finished	089-AHU-005	12/1/2014	12/17/2014	False	2.00	Replace PRE-filters
FO-300581	Finished	089-AHU-004	12/1/2014	12/17/2014	False	1.00	Replace PRE-filters
FO-300582	Finished	089-AHU-003	12/1/2014	12/12/2014	False	1.50	Replace PRE-filters
FO-300583	Finished	089-AHU-002	12/1/2014	12/12/2014	False	1.50	Replace PRE-filters
FO-300584	Finished	089-AHU-001	12/1/2014	12/12/2014	False	1.50	Replace PRE-filters
FO-300585	Completed	008-AHU-005	12/1/2014	12/4/2014	False	1.00	Replace PRE-filters
FO-300586	Completed	008-AHU-004	12/1/2014	12/4/2014	False	3.00	Replace PRE-filters
FO-300587	Completed	008-AHU-003	12/1/2014	12/5/2014	False	4.00	Replace PRE-filters
FO-300588	Completed	008-AHU-002	12/1/2014	12/2/2014	False	1.00	Replace PRE-filters
FO-300589	Completed	008-AHU-001	12/1/2014	12/2/2014	False	1.00	Replace PRE-filters
FO-300590	Finished	006-AHU-005	12/1/2014	12/9/2014	False	1.00	Replace PRE-filters
FO-300591	Finished	006-AHU-004	12/1/2014	12/9/2014	False	1.00	PM - Air Handling Unit (ANNUAL)
FO-300592	Finished	006-AHU-003	12/1/2014	12/9/2014	False	1.00	PM - Air Handling Unit (ANNUAL)
FO-300593	Finished	006-AHU-002	12/1/2014	12/6/2014	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-300594	Finished	006-AHU-001	12/1/2014	12/6/2014	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-300595	Completed	090-AHU-548	12/1/2014		False		Replace PRE-filters
FO-300596	Completed	090-AHU-547	12/1/2014		False		Replace PRE-filters
FO-300597	Completed	090-AHU-546	12/1/2014		False		Replace PRE-filters
FO-300598	Completed	090-AHU-545	12/1/2014		False		Replace PRE-filters
FO-300599	Completed	090-AHU-544	12/1/2014		False		Replace PRE-filters
FO-300600	Completed	090-AHU-543	12/1/2014		False		Replace PRE-filters
FO-300601	Completed	090-AHU-542	12/1/2014		False		Replace PRE-filters
FO-300602	Completed	090-AHU-541	12/1/2014		False		Replace PRE-filters
FO-300603	Completed	090-AHU-003	12/1/2014		False		Replace PRE-filters
FO-300604	Completed	090-AHU-002	12/1/2014		False		Replace PRE-filters
FO-300605	Completed	090-AHU-001	12/1/2014		False		Replace PRE-filters

Requested Finished Open WND

% Finished

FO-300606	Completed	090-HVU-004	12/1/2014		False		Replace PRE-filters
FO-300607	Completed	090-HVU-003	12/1/2014		False		Replace PRE-filters
FO-300608	Completed	090-HVU-002	12/1/2014		False		Replace PRE-filters
FO-300609	Completed	090-HVU-001	12/1/2014		False		Replace PRE-filters
FO-300610	Finished	130-HVU-002	12/1/2014	12/11/2014	False	2.50	Replace PRE-filters
FO-300611	Finished	130-HVU-001	12/1/2014	12/11/2014	False	2.50	Replace PRE-filters
FO-300612	Completed	140-AHU-004	12/1/2014	12/2/2014	False	3.00	Replace PRE-filters
FO-300613	Completed	140-AHU-003	12/1/2014	12/2/2014	False	3.00	Replace PRE-filters
FO-300614	Completed	140-AHU-002	12/1/2014	12/3/2014	False	4.00	Replace PRE-filters
FO-300615	Completed	140-AHU-001	12/1/2014	12/3/2014	False	3.00	Replace PRE-filters
FO-300616	Completed	189-AHU-002	12/1/2014	12/2/2014	False	3.00	Replace PRE-filters
FO-300617	Completed	189-AHU-001	12/1/2014	12/2/2014	False	2.00	Replace PRE-filters
FO-300618	Finished	042-SAF-013	12/1/2014	12/12/2014	False	3.00	Replace PRE-filters
FO-300619	Finished	042-SAF-012	12/1/2014	12/12/2014	False	3.00	Replace PRE-filters
FO-300620	Completed	042-SAF-001	12/1/2014		True		Replace PRE-filters
FO-300621	Completed	042-AHU-001	12/1/2014		True		Replace PRE-filters
FO-300622	Completed	040-SAF-004	12/1/2014		True		Replace PRE-filters
FO-300623	Completed	040-SAF-003	12/1/2014		True		Replace PRE-filters
FO-300624	Completed	040-SAF-002	12/1/2014		True		Replace PRE-filters
FO-300625	Finished	039-SAF-009	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300626	Finished	039-SAF-008	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300627	Finished	039-SAF-007	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300628	Finished	039-SAF-006	12/1/2014	12/15/2014	False	2.00	Replace PRE-filters
FO-300629	Finished	039-SAF-005	12/1/2014	12/20/2014	False	2.00	Replace PRE-filters
FO-300630	Finished	039-SAF-004	12/1/2014	12/20/2014	False	2.00	Replace PRE-filters
FO-300631	Finished	039-SAF-003	12/1/2014	12/20/2014	False	2.00	Replace PRE-filters
FO-300632	Finished	039-SAF-002	12/1/2014	12/18/2014	False	3.00	Replace PRE-filters
FO-300633	Finished	039-SAF-001	12/1/2014	12/18/2014	False	3.00	Replace PRE-filters
FO-300634	Finished	038-SAF-004	12/1/2014	12/23/2014	False	2.00	Replace PRE-filters
FO-300635	Finished	038-SAF-003	12/1/2014	12/23/2014	False	2.00	Replace PRE-filters
FO-300636	Finished	038-SAF-002	12/1/2014	12/23/2014	False	2.00	Replace PRE-filters
FO-300637	Finished	038-SAF-001	12/1/2014	12/23/2014	False	2.00	Replace PRE-filters
FO-300638	Finished	189-HVU-001	12/1/2014	12/16/2014	False	1.00	Replace PRE-filters
FO-300639	Completed	189-HVU-002	12/1/2014	12/2/2014	False	1.00	Replace PRE-filters
FO-300640	Finished	043-HVU-001	12/1/2014	12/11/2014	False	1.50	Replace PRE-filters
FO-300641	Finished	043-AHU-003	12/1/2014	12/11/2014	False	1.50	Replace PRE-filters
FO-300642	Finished	043-AHU-002	12/1/2014	12/11/2014	False	2.00	Replace PRE-filters
FO-300643	Finished	043-AHU-001	12/1/2014	12/11/2014	False	2.00	Replace PRE-filters
FO-300644	Cancelled	067-AHU-400.1	12/1/2014		True		Replace PRE-filters
FO-300645	Cancelled	067-AHU-400.2	12/1/2014		True		Replace PRE-filters
FO-300646	Cancelled	067-AHU-405.2	12/1/2014		True		Replace PRE-filters
FO-300647	Finished	510-AHU-002	12/1/2014	12/9/2014	False	3.00	Replace PRE-filters
FO-300648	Finished	510-AHU-001	12/1/2014	12/9/2014	False	4.00	Replace PRE-filters
FO-300649	Finished	509-AHU-005	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-300650	Finished	509-AHU-004	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters
FO-300651	Finished	509-AHU-003	12/1/2014	12/10/2014	False	3.00	Replace PRE-filters
FO-300652	Finished	509-AHU-002	12/1/2014	12/10/2014	False	3.00	Replace PRE-filters
FO-300653	Finished	509-AHU-001	12/1/2014	12/9/2014	False	3.00	Replace PRE-filters
FO-300654	Finished	096-FP-001	12/1/2014	12/16/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300655	Finished	050-AHU-001	12/1/2014	12/6/2014	False	4.00	Replace PRE-filters
FO-300656	Finished	065-AHU-001	12/1/2014	12/6/2014	False	7.00	Replace PRE-filters
FO-300657	Finished	067-AHU-003	12/1/2014	12/6/2014	False	2.00	Replace PRE-filters
FO-300658	Finished	067-AHU-001	12/1/2014	12/6/2014	False	2.00	Replace PRE-filters
FO-300659	Finished	609-AHU-005	12/1/2014	12/11/2014	False	2.00	Replace PRE-filters
FO-300660	Finished	609-AHU-004	12/1/2014	12/10/2014	False	2.00	Replace PRE-filters
FO-300661	Finished	609-AHU-003B	12/1/2014	12/9/2014	False	2.00	Replace PRE-filters
FO-300662	Finished	609-AHU-003A	12/1/2014	12/9/2014	False	2.00	Replace PRE-filters
FO-300663	Finished	609-AHU-002	12/1/2014	12/10/2014	False	2.00	Replace PRE-filters
FO-300664	Finished	609-AHU-001	12/1/2014	12/10/2014	False	2.00	Replace PRE-filters
FO-300665	Finished	001-AHU-004O	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters
FO-300666	Finished	001-AHU-003O	12/1/2014	12/13/2014	False	3.00	Replace PRE-filters
FO-300667	Finished	001-AHU-003ML	12/1/2014	12/6/2014	False	2.50	Replace PRE-filters
FO-300668	Finished	001-AHU-002O	12/1/2014	12/13/2014	False	2.00	Replace PRE-filters
FO-300669	Finished	001-AHU-002ML	12/1/2014	12/6/2014	False	3.00	Replace PRE-filters
FO-300670	Finished	001-AHU-002	12/1/2014	12/10/2014	False	3.00	Replace PRE-filters
FO-300671	Finished	001-AHU-001O	12/1/2014	12/9/2014	False	3.00	Replace PRE-filters
FO-300672	Finished	001-AHU-001ML	12/1/2014	12/9/2014	False	3.00	Replace PRE-filters
FO-300673	Finished	001-AHU-001	12/1/2014	12/10/2014	False	4.00	Replace PRE-filters
FO-300674	Finished	169-FAP-001	12/1/2014	12/23/2014	False	0.25	PM - Monthly Fire Alarm/Fire Protection System Test
FO-300675	Finished	608-AHU-004	12/1/2014	12/17/2014	False	2.00	Replace PRE-filters
FO-300676	Finished	608-AHU-003	12/1/2014	12/17/2014	False	2.00	Replace PRE-filters
FO-300677	Finished	608-AHU-002	12/1/2014	12/16/2014	False	2.00	Replace PRE-filters
FO-300678	Finished	608-AHU-001	12/1/2014	12/16/2014	False	2.00	Replace PRE-filters
FO-301175	Finished	603-EXF-005	12/7/2014	12/5/2014	False	2.00	Animal Lab Filter Changes for Applelebaum
E - South			38	38	-1	1	
FO-301176	Finished	007-AHU-007	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301177	Finished	007-AHU-006	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301178	Finished	007-AHU-005	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301179	Finished	007-AHU-004	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301180	Finished	007-AHU-003	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301181	Finished	007-AHU-002	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301182	Finished	007-AHU-001	12/13/2014	12/13/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-301183	Finished	007-EXF-002	12/13/2014	12/13/2014	False	2.00	Replace PRE-filters
FO-301184	Finished	007-EXF-001	12/13/2014	12/13/2014	False	2.00	Replace PRE-filters
FO-301921	Completed	022-AIR-001	12/1/2014	11/20/2014	True		PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit. changed compressor oil, oil filter and air intake filter. checked for any unusual noise and vibration. Cleaned air dryer condenser coil, and drained water and oil separator. blew down the air tank. Cleaned the equipment.							

Requested Finished Open WND

% Finished

FO-301926	Completed	090-HEX-001	12/1/2014	11/19/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301927	Completed	090-HEX-003	12/1/2014	11/19/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301928	Completed	090-HEX-004	12/1/2014	11/19/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-301970	Finished	096-DHW-001	12/1/2014	12/31/2014	False	1.00	PM - Domestic Water Heater, Electric
FO-301971	Finished	096-DHW-003	12/1/2014	12/10/2014	False	1.00	PM - Domestic Water Heater, Electric
FO-301972	Finished	096-DHW-004	12/1/2014	12/10/2014	False	1.00	PM - Domestic Water Heater, Electric
FO-301977	Completed	028-AIR-001	12/1/2014	11/21/2014	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.

Checked operation of the unit, Changed compressor oil, checked air intake filters they were clean. Checked operation of air dryer. Cleaned condenser coils, checked and drained oil and water trap. Blew down the tank. Cleaned the equipment.

FO-302001	Completed	090-HEX-547	12/1/2014	11/19/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-302002	Completed	090-HEX-548	12/1/2014	11/19/2014	False	0.50	PM - Heat Exchanger and Economizer
FO-302003	Completed	090-HEX-542	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302004	Completed	090-HEX-543	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302005	Completed	090-HEX-544	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302006	Completed	090-HEX-546	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302007	Completed	090-HEX-545	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302008	Completed	090-HEX-541	12/1/2014	11/20/2014	False	0.10	PM - Heat Exchanger and Economizer
FO-302009	Completed	090-WSS-001	12/1/2014	11/20/2014	False	1.00	PM - Water Softener
FO-302015	Finished	089-ACU-001	12/1/2014	12/17/2014	False	3.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302016	Finished	016-ACU-004	12/1/2014	12/30/2014	False	1.00	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302017	Finished	006-ACU-001	12/1/2014	12/24/2014	False	0.10	PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302020	Finished	096-ACU-001	12/1/2014	12/17/2014	False	5.00	PM - McQuay Chillers: Annual Comprehensive Inspections for Centrifugal & Screw (Air cooled) Chillers
FO-302869	Finished	007-GEN-001	12/11/2014	12/11/2014	False	1.00	Generator Maintenance, Monthly
FO-302871	Finished	007-GEN-002	12/11/2014	12/11/2014	False	1.00	Generator Maintenance, Monthly
FO-302873	Finished	090-GEN-001	12/16/2014	12/16/2014	False	1.00	Generator Maintenance, Monthly
FO-302875	Finished	089-GEN-001	12/17/2014	12/17/2014	False	1.00	Generator Maintenance, Monthly
FO-302914	Finished	090-GEN-002	12/11/2014	12/11/2014	False	1.00	Generator Maintenance, Monthly
FO-302925	Finished	006-GEN-001	12/18/2014	12/19/2014	False	1.00	Generator Maintenance, Monthly
FO-302935	Finished	090-ACU-CR2	12/8/2014	12/8/2014	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-302936	Finished	090-ACU-CR1	12/8/2014	12/8/2014	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1

E - Southeast 70 61 9 0 87%

FO-301922	Finished	001-HEX-001SW	12/1/2014	12/17/2014	False	0.15	PM - Heat Exchanger and Economizer
CHECK OPERATION OF UNIT & CLEAN AREA.							
FO-301923	Finished	001-HEX-001WV	12/1/2014	12/17/2014	False	0.25	PM - Heat Exchanger and Economizer
CHECK OPERATION & CLEAN AREA.							
FO-301924	Finished	001-HEX-002SW	12/1/2014	12/17/2014	False	0.15	PM - Heat Exchanger and Economizer
CHECK OPERATION OF UNIT & CLEAN AREA.							
FO-301925	Finished	001-HEX-002WV	12/1/2014	12/17/2014	False	0.25	PM - Heat Exchanger and Economizer
CHECK OPERATION & CLEAN AREA.							
FO-301930	Completed	071-HWP-005	12/1/2014	11/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301931	Completed	071-HWP-006	12/1/2014	11/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward)

Requested Finished Open WND

% Finished

FO-301932	Completed	071-HWP-007	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301933	Completed	071-HWP-008	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301934	Completed	071-HWP-009	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301935	Completed	071-HWP-010	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301936	Completed	071-HWP-011	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301937	Completed	071-HWP-012	12/1/2014	11/3/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301938	Completed	071-HWP-013	12/1/2014	11/4/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301939	Completed	071-HWP-014	12/1/2014	11/4/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301940	Completed	071-HWP-015	12/1/2014	11/4/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301941	Completed	071-HWP-016	12/1/2014	11/4/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301942	Completed	071-HWP-017	12/1/2014	11/4/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301943	Completed	071-HWP-018	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301944	Completed	071-HWP-019	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301945	Completed	071-HWP-020	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301946	Completed	071-HWP-021	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301947	Completed	071-HWP-022	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301948	Completed	071-HWP-023	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301949	Completed	071-HWP-187	12/1/2014	11/5/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301950	Completed	071-HWP-188	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301951	Completed	071-HWP-189	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301952	Completed	071-HWP-190	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301953	Completed	071-HWP-191	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301954	Completed	071-HWP-192	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301955	Completed	071-HWP-193	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301956	Completed	071-HWP-194	12/1/2014	11/6/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301957	Completed	071-HWP-195	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301958	Completed	071-HWP-196	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301959	Completed	071-HWP-197	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301960	Completed	071-HWP-198	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301961	Completed	071-HWP-199	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301962	Completed	071-HWP-200	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301963	Completed	071-HWP-201	12/1/2014	11/11/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301964	Completed	071-HWP-202	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301965	Completed	071-HWP-203	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301966	Completed	071-HWP-204	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301967	Completed	071-HWP-205	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301968	Completed	071-HWP-215	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301969	Completed	071-HWP-216	12/1/2014	11/7/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301973	Created By PM Schedule	016-SP-003	12/1/2014		False		PM - Sump Pump
FO-301974	Created By PM Schedule	016-SP-004	12/1/2014		False		PM - Sump Pump
FO-301975	Created By PM Schedule	023-SP-001	12/1/2014		False		PM - Sump Pump
FO-301976	Created By PM Schedule	023-SP-002	12/1/2014		False		PM - Sump Pump
FO-301978	Created By PM Schedule	189-HEX-001	12/1/2014		False		PM - Heat Exchanger and Economizer

Requested Finished Open WND

% Finished

FO-301991	Finished	001-SSF-001	12/1/2014	12/18/2014	False	0.50	PM - Harmsco Side Stream Filter
CLEAN FILTERS							
FO-301992	Finished	001-SSF-002	12/1/2014	12/18/2014	False	0.50	PM - Harmsco Side Stream Filter
CLEAN FILTERS.							
FO-301993	Completed	071-HWP-222	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301994	Completed	071-HWP-223	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301995	Completed	071-HWP-224	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301996	Completed	071-HWP-225	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301997	Completed	071-HWP-226	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-301998	Completed	071-HWP-227	12/1/2014	11/10/2014	False	1.00	PM - Heat Pumps (5057 Woodward)
FO-302010	Created By PM Schedule	637-ACU-003	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302011	Created By PM Schedule	637-ACU-002	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302012	Created By PM Schedule	499-ACU-001	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302019	Created By PM Schedule	082-ACU-003	12/1/2014		False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302895	Finished	637-GEN-001	12/16/2014	1/21/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-302897	Finished	637-GEN-002	12/16/2014	1/21/2015	False		Generator Maintenance, Monthly
Checked fluids and battery							
FO-303814	Finished	001-AHU-001	12/20/2014	2/2/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK & LUBE DAMPERS.							
FO-303815	Finished	001-AHU-001O	12/20/2014	2/4/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK OPERATION & LUBE.							
FO-303816	Finished	001-AHU-002	12/20/2014	2/2/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK & LUBE DAMPERS.							
FO-303817	Finished	001-AHU-002O	12/20/2014	2/5/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK OPERATION & LUBE.							
FO-303818	Finished	001-AHU-003O	12/20/2014	2/2/2015	False	0.50	PM - Air Intake Dampers (Old Main)
check & lube dampers							
FO-303819	Finished	001-AHU-004O	12/20/2014	2/2/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK & LUBE DAMPERS.							
FO-303820	Finished	001-AHU-PRIM	12/20/2014	2/5/2015	False	0.50	PM - Air Intake Dampers (Old Main)
CHECK OPERATION & LUBE.							
E - West			8	8	0	0	100%
FO-301929	Finished	155-HEX-001	12/1/2014	1/15/2015	False		PM - Heat Exchanger and Economizer
FO-301990	Finished	080-AIR-003	12/1/2014	1/15/2015	False		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-302013	Finished	155-ACU-002	12/1/2014	12/24/2014	False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302014	Finished	155-ACU-001	12/1/2014	12/24/2014	False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-302018	Finished	003-ACU-001	12/1/2014	12/17/2014	False		PM - Trane Chillers: Comprehensive Annual PM Service for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
Trane Tech was out to service Chiller. JD							

Requested Finished Open WND

% Finished

FO-302923	Finished	001 SPARE from	12/9/2014	12/10/2014	False	Generator Maintenance, Monthly
FO-302933	Finished	169-GEN-001	12/25/2014	12/24/2014	False	Generator Maintenance, Monthly
FO-302934	Finished	167-DHW-001	12/8/2014	12/22/2014	False	PM - Domestic Water Heater, Gas

Trades			41	39	2	0		95%
T - Electrician			36	34	2	0		94%
FO-302868	Finished	609-GEN-001	12/16/2014	12/16/2014	False	4.00	Generator Test	
FO-302870	Finished	007-GEN-001	12/11/2014	12/11/2014	False	2.00	Generator Test	
FO-302872	Finished	007-GEN-002	12/11/2014	12/11/2014	False	2.00	Generator Test	
FO-302874	Finished	090-GEN-001	12/16/2014	12/16/2014	False	4.00	Generator Test	
FO-302876	Finished	089-GEN-001	12/17/2014	12/17/2014	False	4.00	Generator Test	
FO-302878	Finished	066-GEN-001	12/24/2014	12/24/2014	False	4.00	Generator Test	
FO-302879	Finished	611-GEN-001	12/26/2014	12/26/2014	False	4.00	Generator Test	
FO-302881	Finished	629-GEN-001	12/26/2014	12/26/2014	False	4.00	Generator Test	
FO-302883	Finished	193-GEN-001	12/12/2014	12/5/2014	False	1.00	Generator Test 12/05/2014 @2:15PM.	
FO-302884	Finished	104-GEN-001	12/23/2014	12/23/2014	False	4.00	Generator Test	
FO-302886	Finished	127-GEN-001	12/23/2014	12/23/2014	False	1.00	Generator Test	
FO-302888	Finished	127-GEN-002	12/23/2014	12/23/2014	False	1.00	Generator Test	
FO-302890	Finished	127-GEN-003	12/23/2014	12/23/2014	False	1.00	Generator Test	
FO-302892	Finished	127-GEN-004	12/23/2014	12/23/2014	False	1.00	Generator Test	
FO-302894	Finished	637-GEN-001	12/16/2014	12/16/2014	False	2.00	Generator Test	
FO-302896	Finished	637-GEN-002	12/16/2014	12/16/2014	False	2.00	Generator Test	
FO-302898	Finished	130-GEN-001	12/24/2014	12/24/2014	False	4.00	Generator Test	
FO-302900	Finished	612-GEN-001	12/12/2014	12/12/2014	False	2.00	Generator Test	
FO-302901	Created By PM Schedule	612-GEN-001	12/12/2014		False		Generator Maintenance, Monthly	
FO-302902	Finished	612-GEN-002	12/12/2014	12/12/2014	False	2.00	Generator Test	
FO-302903	Created By PM Schedule	612-GEN-002	12/12/2014		False		Generator Maintenance, Monthly	
FO-302904	Finished	501-GEN-001	12/9/2014	12/9/2014	False	4.00	Generator Test	
FO-302906	Finished	507-GEN-001	12/10/2014	12/10/2014	False	4.00	Generator Test	
FO-302908	Finished	203-GEN-001	12/16/2014	12/16/2014	False	4.00	Generator Test	
FO-302910	Finished	536-GEN-001	12/17/2014	12/17/2014	False	4.00	Generator Test	
FO-302911	Finished	608-GEN-001	12/5/2014	12/5/2014	False	6.00	Generator Test	
FO-302912	Finished	608-GEN-001	12/5/2014	12/5/2014	False		Generator Maintenance, Monthly	
FO-302913	Finished	090-GEN-002	12/11/2014	12/11/2014	False	4.00	Generator Test	
FO-302916	Finished	527-GEN-001	12/18/2014	12/18/2014	False	4.00	Generator Test	
FO-302919	Finished	048-GEN-001	12/12/2014	12/12/2014	False	4.00	Generator Test	
FO-302922	Finished	001 SPARE from	12/9/2014	12/9/2014	False	4.00	Generator Test	
FO-302924	Finished	006-GEN-001	12/18/2014	12/18/2014	False	4.00	Generator Test	
FO-302926	Finished	193-GEN-002	12/12/2014	12/5/2014	False	1.00	Generator Test 12/05/2014 @2:15PM.	
FO-302928	Finished	193-GEN-003	12/12/2014	12/5/2014	False	1.00	Generator Test 12/05/2014 @2:15PM.	
FO-302930	Finished	193-GEN-004	12/12/2014	12/5/2014	False	0.50	Generator Test 12/05/2014 @2:15PM.	
FO-302932	Finished	169-GEN-001	12/25/2014	12/24/2014	False	4.00	Generator Test	
T - Plumber			5	5	0	0		100%
FO-301735	Finished	042	12/1/2014	12/16/2014	False	1.50	PM - Main Drain with Copper Sulfate ,,,,,,,,,, MP/12-2-14 ,,,,,,,,,,	

Requested Finished Open WND

% Finished

FO-301736	Finished	527	12/1/2014	12/15/2014	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, MM/12-2-14 ,,,,,,,,,
FO-301737	Finished	608	12/1/2014	12/5/2014	False	5.00	PM - Waterless Urinals ,,,,,,,,,, MM/12-2-14 ,,,,,,,,,
FO-301738	Finished	049	12/1/2014	12/16/2014	False	1.50	PM - Waterless Urinals ,,,,,,,,,, MP/12-2-14 ,,,,,,,,,
FO-301739	Finished	090	12/1/2014	12/9/2014	False	2.00	PM - Waterless Urinals ,,,,,,,,,, MP/12-2-14 ,,,,,,,,,
Report Total			456	408	38	10	89%