

Facilities Operations Work Orders Received 10/1/15 through 10/31/15

WO	Receieved	Finished	Total	Request
Maint. Work Order			2036	
Custodial			257	
High			5	
C-Repair			2	
FO-331066	10/27/2015	10/27/2015		A REQUEST FOR SUPPLIES FOR (4), DIAL PROFESSIONAL FOAMING HAND SOAP DISPENSERS. THE SUPERVISORS TRANSFER DISPENSERS FROM THE CUSTOD. STOCKROOM TO (SCB)
FO-331073	10/27/2015	10/27/2015		EQUIPMENT TRANSFER: PICK UP (2), TWO FLOOR MACHINES AND TRANSFER THEY FROM (SCOTT, HALL) TO (MCGREGOR) FOR PROJECT WORK.
C-Sector 02			1	
FO-331141	10/28/2015			ADDING CUSTODIAL 10/28/15 FOR CLEAN UP AFTER FLR DRAIN HAD BEEN CLEANED OUT 10/27/15 NEED CLEANING/SANITIZE (**) PO REQ DK 7/31 ADDING PLUMBERS R/R RM 040 NEED TO REPAIR CLNG DRAIN LINE THATS IS LKNG FROM CEILING ,,,,,,,,,,,,,,,,,,,, MM/6-29-15 ,,,,,,,,,,
C-Sector 08			1	
FO-328568	10/1/2015	10/4/2015		CLEAN/MOP 1ST FLOOR MEN AND WOMEN RESTROOMS (NEAR LUNCHROOM). (PLUMBERS WORKED ON TOILET IN THE WOMEN'S RESTROOM)
Pest Controller			1	
FO-329157	10/7/2015	10/8/2015	10/8/2015	R/R PRESS BOX HAS AN ABUNDANCER OF GNATS/FLIES NEED EXTERMINATING BERFORE 10/10/15 THERE'S A FOOTBALL GAME SCHEDULED
Medium			10	
C-Repair			2	
FO-330559	10/20/2015	10/29/2015		4TH FL WOMENS RM PAPER TOWEL DISPENSER BROKEN
FO-330597	10/20/2015	10/29/2015		3rd floor ladies r/r - paper towel dispenser does not work
Pest Controller			8	
FO-328777	10/5/2015	10/6/2015	10/6/2015	RM 4226 PLEASE SET MICE TRAPS
FO-329820	10/16/2015	10/19/2015	10/19/2015	RM 184 & 186 PLEASE SPRAY OR SET TRAPS FOR SMALL INSECTS BITING STAFF
FO-329964	10/19/2015	10/21/2015	10/21/2015	RM 7908 & ENTIRE 7TH FL, HALLWAYS, AND STAIRWELLS PLEASE SPRAY OR SET ROACH TRAPS
FO-329966	10/19/2015	10/21/2015	10/21/2015	8TH FL PLEASE SPRAY OR SET TRAPS FOR COCK ROACHES
FO-330800	10/22/2015	10/26/2015	10/26/2015	Cockroaches reported in various rooms throughout Purdy/Kresge Library: 1st floor Purdy Unisex restroom 1st floor Purdy Men's staff restroom 2nd floor Purdy Men's restroom Room 240 in stair #1) 2nd Floor Kresge Men's restroom Thank you.
FO-330833	10/23/2015	10/23/2015	10/23/2015	EXTERIOR ENTRANCE DOOR PLEASE REMOVE DEAD BIRD
FO-330912	10/26/2015	10/29/2015	10/29/2015	1ST FL NEAR VENDING MACHINE PLEASE SPRAY OR SET TRAPS FOR COCKROACHES
FO-331041	10/27/2015	10/27/2015	10/27/2015	Remove dead rat on the south side of the front entrance.
Low			242	
C-Director			2	
FO-329028	10/6/2015			2015 Admissions Fall Open House on Sat. October 17, 2015. This is a university wide recruitment effort. Service to provide in the following areas pre-cleaning, event date cleaning, trash removal, keep restroom clean, replenish tissue, soap etc., area gro
FO-330848	10/23/2015			Stock Issue Request: 1 small padlock with key.
C-Lighting			81	
FO-328585	10/1/2015	10/2/2015		Some light bulbs in the Records office file room 318.2 are burned out. One fixture is totally out and the other is half lit.

WO	Recieved	Finished	Total	Request
FO-328631	10/2/2015	10/6/2015		Lighting crew replace ceiling lights in #1 (east) stairwell between 2nd and 3rd floor.
FO-328673	10/3/2015	10/7/2015		Please replace burned out light bulbs in ladies room. There are at least 9 affected bulbs. The theatre will have audiences beginning October 9th.
FO-328674	10/3/2015	10/6/2015		Please replace all burned out scone light bulbs in the inner and outer lobby and main auditorium. There are at least 42, 60 watt medium base candelabra bulbs burned out. The Theatre will have audiences beginning October 9th. Please check stairwells to ba
FO-328744	10/5/2015	10/6/2015		Please fix light in coffee/storage room across from my desk. Flickered and went out 10/5/15. Call Sandy 7-0762 if any add'l info needed. Thanks
FO-328745	10/5/2015	10/7/2015		Ceiling lighting fixtures need relamping.
FO-328755	10/5/2015	10/6/2015		LIGHT OUT IN SERVICE ELEVATOR. PLEASE REPLACE.
FO-328994	10/5/2015	10/7/2015		Please replace light bulbs in this service room and service room 227 located on the way to the balcony. Thanks.
FO-328996	10/5/2015	10/7/2015		The ceiling light in the south east stairwell from the inner lobby to the balcony is burned out please replace. We have audiences beginning October 9th. Thanks
FO-329075	10/6/2015			Please replace the lights that are out. This is a theatre classroom and rehearsal space please contact Dana Gamarra 313-595-7794 for best time to perform work.
FO-329076	10/6/2015			Please replace the lights that are out. This is a theatre classroom and rehearsal space please contact Dana Gamarra 313-595-7794 for best time to perform work.
FO-329098	10/7/2015	10/7/2015		Trade: CUSTODIAL Priority: Medium Half the lights are out in the EDC elevator, please replace burnt out bulbs.
FO-329097	10/7/2015	10/7/2015		Re-lamp fixture in hall outside room 132, Central Storage area.
FO-329102	10/7/2015	10/8/2015		6th fl - Room 6100.1 (R/R) 1 LO & 1 LO outside of this room as well.
FO-329104	10/7/2015	10/7/2015		President's Place: 2 LO - living room 1 LO - hallway
FO-329147	10/7/2015	10/7/2015		Re-lamp fixture in room 114.
FO-329154	10/7/2015	10/8/2015		INSIDE STE 6304 IN HALLWAY OUTSIDE OF RM 6304.6 LITE NEEDS REPLACING
FO-329203	10/8/2015	10/12/2015		Re-lamp staircase from 1st floor to mezzanine level. Entrance is next to room 184.
FO-329226	10/8/2015	10/8/2015		Room 443 - 2 LO
FO-329281	10/9/2015	10/13/2015		1 blown light bulb in classroom
FO-329282	10/9/2015	10/13/2015		Classrooms 307 and 308 have blown light bulbs
FO-329284	10/9/2015	10/14/2015		Light out in hallway 3rd floor, directly in front of Room 312 Also light out in Lobby area by elevator, light that shines down directly over glass banister
FO-329285	10/9/2015	10/13/2015		Light out on first floor directly in front of room 147 (right before you enter into the cafeteria in Scott Hall)
FO-329299	10/9/2015	10/12/2015		LIGHTS ARE OUT IN BASEMENT STAIRWELL LEADING TO THE 1ST FLOOR.
FO-329365	10/12/2015	10/12/2015		Please replace the burned out light bulb over the northwest entrance to the lobby at the top of the handicapped ramp. We are now having evening performances. Thanks
FO-329475	10/13/2015	10/15/2015		Lande room 254 - I have 4 overhead lights (in two glass panels) that sometimes go on and off by themselves. Can we have a lighting tech and/or an electrician come over to assess it? I have a feeling it's electrical, especially since we've had other electr
FO-329487	10/13/2015	10/14/2015		Suite 318 has 2 blown out light bulbs as soon as you walk in the suite
FO-329502	10/13/2015	10/19/2015		Light fixture room 0205 at Elliman has a cover falling off. Needs to be put on properly.
FO-329508	10/13/2015	10/13/2015		Room 5502 (Cold Room) - Long fluorescent lights out.
FO-329519	10/13/2015	10/15/2015		5th floor - Room 586 - 1 LO
FO-329547	10/13/2015	10/13/2015		LIGHTS OUT IN 1ST FLOOR LEFT STAIRWELL.
FO-329562	10/13/2015	10/15/2015		First floor men's room, light is out.
FO-329662	10/14/2015	10/15/2015		please replace ceiling light out-staff area-near office room# 395. thank you
FO-329748	10/15/2015	10/16/2015		Please replace the burned out lights in room 1106.
FO-329762	10/15/2015	10/16/2015		Please fix lights. Both bulbs in one bank are out.
FO-329784	10/16/2015	10/16/2015		The exterior lights in the main entrance to the building are burned out. Could they be replaced?

WO	Recieved	Finished	Total	Request
FO-329810	10/16/2015	10/16/2015		Three over head lights need replacing.
FO-329811	10/16/2015	10/16/2015		Three over head light bulbs need replacing.
FO-329813	10/16/2015	10/16/2015		stairwell #1 between 3rd and 4th floor please change light.
FO-329814	10/16/2015	10/16/2015		the north end card entry area (ground floor) entry light is out. It's in the area before you get to General Lecture Room 21
FO-329837	10/16/2015	10/19/2015		replace out light in hall outside of room 365. thank you
FO-329838	10/16/2015	10/19/2015		please replace florescent light outside of room 375. thank you
FO-329827	10/16/2015	10/16/2015		Light is out in my office.
FO-329840	10/16/2015	10/19/2015		please replace florescent light inside and outside of room 370. thank you
FO-329841	10/16/2015	10/19/2015		1 or two fluorescent bulbs burned out in rear of room
FO-329872	10/19/2015	10/19/2015		UNISEX RESTROOM 6TH FLOOR NEAR PUBLIC ELEVATOR LIGHT OUT. PLEASE REPLACE.
FO-329873	10/19/2015	10/20/2015		REPLACE LIGHT IN NORTHWEST CORRIDOR ON 6TH FLOOR NEAR OFFICE 6303.
FO-329881	10/19/2015	10/19/2015		EMERGENCY LITE CREW R/R FRONT MAIN ENTRANCE VESTIBULE LITE COVER IS HANGING NEEDS SECURING
FO-329887	10/19/2015	10/20/2015		CLEAN LIGHT COVERS IN ELEVATORS.
FO-329907	10/19/2015	10/20/2015		A light needs to be replaced in room 3212. Thank you.
FO-329909	10/19/2015	10/20/2015		There is a light out outside of the 3100 suite in the hallway closest to Anthony Wayne Drive. The light is located right outside of 3101. Please call Dories Ferris with any questions at 7-3834. Thank you.
FO-329921	10/19/2015	10/20/2015		Light over 300.12 is burned out and needs to be replaced.
FO-329948	10/19/2015	10/20/2015		Light crew: please replace burn out light bulbs in stair #1 at 1st floor level. Priority: med.
FO-330523	10/20/2015	10/19/2015		Room 441 - 6 LO
FO-330532	10/20/2015	10/19/2015		Room 431 - 2 LO
FO-330537	10/20/2015	10/29/2015		Room 2361 - Est 1 fixture out.
FO-330558	10/20/2015	10/21/2015		Two overhead lights out in Paul Beavers Office in Dean's Suite, Room 3111, just reported.
FO-330607	10/20/2015	10/21/2015		There are many lights burned out in the first floor ladies bathroom. Could they be replaced?
FO-330630	10/21/2015			Some lights are out - they are flashing. Please replace. Thank you - Dawn C.
FO-330648	10/21/2015	10/21/2015		Light bulb out in office #13202.6, Thank you.
FO-330650	10/21/2015	10/21/2015		Lights totally out in work area #13202 (outside of office #13202.7) very dark! Thank you.
FO-330666	10/21/2015	10/21/2015		Light bulb needs to be replaced in the lobby of the East door entrance. Thank you.
FO-330688	10/21/2015	10/29/2015		Some light sets are out. Please replace. Thank you. Dawn C.
FO-330689	10/21/2015	10/23/2015		PLEASE REPLACE FLOOD LIGHTS IN AUDITORIUM ON 1ST FLOOR.
FO-330732	10/22/2015	10/29/2015		St. 206 has 3 blown light bulbs listed below: -2 lights bulbs blown in patient cooridor by exam rooms 13 and 16 -1 light bulb blown in the mens bathroom in the skills center
FO-330741	10/22/2015	10/28/2015		1st. Floor hallway, adjacent to room 1102. Relamp ceiling lightfixture.
FO-330740	10/22/2015	10/29/2015		Light bulb is blown out in hallway on second floor, right in front of doors 229 and 230
FO-330775	10/22/2015	10/22/2015		Lights (2) out in observation area of the Early Childhood center. Please see Jamie for specific location
FO-330784	10/22/2015			Relamp recessed light fixture in cafeteria ust south of the check out area.
FO-330839	10/23/2015	10/23/2015		Re-lamp fixture in 1st floor Women's - new restroom.
FO-331020	10/27/2015	10/29/2015		rm#1310.1 lights out
FO-331094	10/27/2015	10/28/2015		Light is out in hallway outside of office #13201.2 (near reception area). Thank you!

WO	Recieved	Finished	Total	Request
FO-331159	10/28/2015	10/28/2015		LIGHT CREW -PLEASE REPLACE BURNED OUT BULB IN 5TH FLOOR STAIRWAY OUTSIDE OF BOILER ROOM 601 5TH FLOOR NW CORNER OF BLDG PRIORITY HIGH
FO-331238	10/28/2015	10/29/2015		fluorescent light in bathroom is burned out.
FO-331280	10/28/2015	10/29/2015		Repair 2 burnt out lights in hallway outside elevators on 3rd floor of Scott Hall. Contact Sheryl MacGillis at 7-1446 if you have questions.
FO-331290	10/28/2015	10/29/2015		The display case across from our office has burnt out lights that needs to be replaced.
FO-331320	10/29/2015	10/29/2015		2ND FLOOR JANITOR CLOSET ON WEST END OF BUILDING NEED LIGHT BULBS CHANGED. NO NUMBER ON DOOR?
FO-331431	10/30/2015			Relamp Light fixture at 1st Floor Stairway A Relamp light fixture at 1st Floor Stairway C.I
FO-331433	10/30/2015			Women's Locker Room relamp two light fixtures that are out.
FO-331439	10/30/2015			Outside Room 114 two lights are out please relamp.
FO-331476	10/30/2015			Relam light fixture in room 2361 Conjoint teaching office.
C-Materials			7	
FO-328552	10/1/2015	10/2/2015		2 gray recycling bins need to be picked up and replaced. Contact Sandy Yarrington if assistance is needed.
FO-329035	10/6/2015	10/13/2015		Basement; Room 1360 - Recycling bin drop off.
FO-329039	10/6/2015	10/13/2015		2nd fl; room 2361 - Recycling bin pick up and return.
FO-329399	10/12/2015	10/14/2015		NEW EQUIPMENT TRANSFER: ADVANCE, AUTO SCRUBBER (SC500 X20D / EceFlex) From: (FPM / STOCKROOM), Building To: Custod. / Stockroom for label (WSU). Approved By : (Geneva, Guice)
FO-331103	10/28/2015			EQUIPMENT TRANSFER: (ADVANCE / AUTO, SCRUBBER / ADPHIAN AXP / SER.#-100000479) From: Main Office Stockroom To: Scott, Hall (Basement Area)
FO-331324	10/29/2015			EQUIPMENT TRANSFER: AUTO, SCRUBBER (ADVANCE/CONV.) IN THE BASEMENT CLOSET NEXT TO MEN'S RESTROOM. NEEDS SERVICE REPAIRS. From: (Art) BLD To: Main Office Stockroom
FO-331428	10/30/2015			EQUIPMENT TRANSFER: AUTO, SCRUBBER (ADVANCE/ADHANCER)IN THE MEN'S LOCKROOM AREA CLOSET. NEEDS SERVICE REPAIRS. From: (MATTHAEI) To: Main Office Stockroom
C-Relief			1	
FO-331022	10/27/2015	10/30/2015		Need to install Hand Sanitizer unit and hand Sanitizer lotion next to room 13 in basement
C-Repair			49	
FO-328463	10/1/2015	10/22/2015		ADVANCE VACUUM SERIAL NO. 1659803, NEEDS A NEW CORD. PLEASE REPLACE. VACUUM IN STOCK ROOM 021.
FO-328478	10/1/2015	10/19/2015		AUTO-SCRUBBER 070906130 NOT WATER COMING OUT.PLEASE REPAIR. MACHINE IN BASEMENT CLOSET ON WEST SIDE OF BUILDING.
FO-328480	10/1/2015	10/2/2015		2nd floor Men's restroom backside soap dispenser off the wall need new 1.Also men's front restroom paper towel dispenser off the wall needs new 1
FO-328534	10/1/2015	10/5/2015		5th floor Men's restroom paper towel dispenser off the wall needs new 1.
FO-328648	10/2/2015	10/1/2015		A REQUEST FOR SERVICE ON A BROKEN ROLL TOWEL DISPENSER ON THE SECOND FLOOR BY THE ELEVATOR.
FO-328713	10/5/2015	10/27/2015		ADVAC12 VACUUM CLEANER 1615890 BROKEN BAG CLIP AT BOTTOM AND NEED BRUSHES. PLEASE REPAIR/REPLACE. VACUUM VERY OLD.
FO-328757	10/5/2015	10/6/2015		NEW EQUIPMENT:VACUUM CLEANER UP RIGHT W/DUSTCUP. Sanitaire/SC887/SER.#-1508001606 PART OF (FO-326275)
FO-328761	10/5/2015	10/6/2015		3RD FLOOR WOMEN'S RESTROOM SOAP DISPENSER CRACKED. PLEASE REPAIR/REPLACE. LOCATED NEAR ELEVATORS.

WO	Recieved	Finished	Total	Request
FO-329159	10/7/2015	10/8/2015		BASEMENT WOMEN'S RESTROOM SOAP DISPENSER BROKEN. PLEASE REPAIR OR REPLACE.
FO-329175	10/8/2015	10/26/2015		By the back dock under the stairs their is a rubber maid cart that needs some front wheels on it could you take a look at it. thx
FO-329211	10/8/2015	10/8/2015		4th FI W R/R - fix soap dispenser.
FO-329319	10/9/2015	10/22/2015		NEED TO PLACE A PARTS ORDER FOR (FO320733), ADVANCE/POWER WASHER MACHINE. From: Allied-Eagle Supply Co. Approved/Authorized By: (Geneva Guice)
FO-329377	10/12/2015	10/6/2015		Need a service check or repairs on a hand sanitizer dispenser in the lobby area.
FO-329391	10/12/2015	10/16/2015		NEW EQUIPMENT: AUTO, SCRUBBER NEED TO LABEL (W.S.U.) FOR NEW BUILDING (Tech. One). ADVANCE: SC500 X20D EcoFlex Ser. # -3510151108015 From: (Allied-Eagle supply Co. / PO693931), FO-321611, WORK ORDER #-809150 / WSU4075 Approved/Authorized By: (Geneva
FO-329407	10/12/2015	10/14/2015		A SERVICE CHECK ON THE (NOBLES / SCOUT 28') FLOOR SWEEPER IS NEEDED, PART OF (FO326379).
FO-329415	10/12/2015	10/28/2015		NEW EQUIPMENT: SANITAIRE UP RIGHT VACUUM CLEANER FOR SECTOR # 7 (NETTIE, M.) REPLACING THE VACUUM CLEANER FROM (FO326659) APPROVED/AUTHORIZED BY: GENEVA, GUIE SANTAIRE M#- SC887 SER.# -1415002880
FO-329437	10/13/2015	10/23/2015		Convertamatic X24DC-C Serial:1983773. Located in basement closet near Hancock entrance. scrubber is scratching the floor/removing finish when it is run.
FO-329566	10/13/2015	10/19/2015		The Vacuum at Mattheai needs new beater bar brushes, I will provide a new belt.
FO-329568	10/13/2015	10/14/2015		Men's restroom on the 4th floor closes to the elevator, the paper towel dispenser is broken.
FO-329569	10/13/2015	10/14/2015		Men's restroom on the south side of the building. The paper towel dispenser is broken.
FO-329573	10/14/2015	10/15/2015		Brushes for Sanitaire Vacuum, Serial #0825003440, Model SC689. Brushes broken on one side of beater bar.
FO-329575	10/14/2015	10/23/2015		Located in room 015. Vacuum cleaner handle lock is broken, vacuum won't lock into place while in the upright position.
FO-329576	10/14/2015	10/15/2015		Located in custodial room 403. Vacuum cleaner handle lock is broken, vacuum won't lock into place while in the upright position.
FO-329577	10/14/2015			Auto scrubber located on lower level in custodial closet in Art wing. Auto Scrubber is releasing minimum water and streaking the floor.
FO-329665	10/15/2015	10/15/2015		vacuum runs very loud, and needs new cord. Model:sc887 Serial:1234007570
FO-329721	10/15/2015	10/20/2015		Paper towel dispenser in the mens room is not working properly. Needs to be replaced.
FO-329804	10/16/2015	10/29/2015		WOMEN'S RESTROOM 1ST FLOOR NEAR MAIN ENTRANCE PAPER TOWEL DISPENSER BROKEN.PLEASE REPAIR.
FO-329805	10/16/2015			MEN'S RESTROOM #440 NEEDS ANOTHER SOAP DISPENSER INSTALLED.
FO-329829	10/16/2015	10/16/2015		NEED SOME TO PLACE A PARTS ORDER FOR VACUUMS CLEANER SERVICE REPAIRS PARTS. From: Allied-Eagle Supply Co. Approved/Authorized By: (Geneva, Guice)
FO-329943	10/19/2015	10/23/2015		13TH FLOOR WOMEN'S RESTROOM THE SOAP DISPENSER HANDLE IS CRACKED. PLEASE REPAIR/REPLACE.
FO-330495	10/20/2015	10/29/2015		Roll towel dispenser is broken (towel isn't dispensing) 1st floor men restroom.
FO-330496	10/20/2015	10/29/2015		Roll towel dispenser is broken (doesn't stay closed) 2nd floor men restroom. THE REQUESTER IS SECTOR # 6 SUPERVISOR
FO-330503	10/20/2015	10/20/2015		A REQUEST BY CUSTOD. WORKER (R. LLODY) VACUUM CLEANER NOT PICKING UP RIGHT NEED SERVICE CHECK.
FO-330514	10/20/2015			Please repair Sanitre vacuum. Vacuum is making load noise from the engine, it also can you replace the beattle bar also rplace the plug to 3 prong plug
FO-330516	10/20/2015			Please repair Santire vacuum no beattle bar, also making rattling in engine. repair handle. model# SC882 S#0822000543
FO-330519	10/20/2015	10/30/2015		Please repair Sanitaire vacuum . Engine is making a grinding noise from the engine. replace cord and plug. also replace brushes on beattle bar model# SC 689 S# 0825003522

WO	Recieved	Finished	Total	Request
FO-330592	10/20/2015	10/29/2015		1st floor ladies r/r - please fix paper towel dispenser is broken
FO-330710	10/22/2015	10/29/2015		1st and 2nd floor Men's restroom both paper towel dispensers are broken
FO-330713	10/22/2015			The autoscrubber works great, but it hard to maneuer and leaves a track in the floor. I think one of the wheels is not moving or rusted out. could check on this sir.Thx.
FO-330950	10/26/2015			SANITAIRE VACCUUM MODEL#SC687, SERIAL#0543002550 THE CORD IS SPARKLING FIRE. PLEASE REPLACE CORD. VACUUM IN SOCK ROOM #021.
FO-331043	10/27/2015			The carpet juan is not working correctly need a part.
FO-331079	10/27/2015			The roll towel dispenser in the 1st floor men's room of State Hall (on the Deroy side) is broken
FO-331081	10/27/2015			Both backpack vacuums in the Fitness Center are broken. The black one will not turn on at all and the grey one is loud and will not pick up anything at all.
FO-331130	10/28/2015	10/29/2015		3rd floor unisex restroom paper towel dispenser off the wall needs new 1.
FO-331151	10/28/2015			Vacuum located custodial closet 216 is releasing large amounts of dust during usage.
FO-331152	10/28/2015			Vacuum located in custodial closet 3285 is not collecting dirt.
FO-331156	10/28/2015	10/29/2015		Paper towel dispenser is broken (missing inner springs) located in men's restroom, 3rd floor. Sector # 6 Supervisor is the requester.
FO-331160	10/28/2015	10/30/2015		Vacuum belt caught in the motor. It's located on the 4th floor room in 453.1 (it's stored inside the inner room 453). REQUESTER IS SECTOR # 6 SUPERVISOR
FO-331377	10/29/2015			The auto scrubber in has a lot of corrosion on the squeegee and around the battery.
C-Sector 01			17	
FO-328998	10/5/2015	10/27/2015		Please clean the floors in this service room as well as 227 just off from the Bonstelle Room. Thanks
FO-328999	10/5/2015	10/27/2015		While vacuuming the the inner lobby, please vacuum the box office room. Also please clean the exit door in the south east corner of the lobby. Thanks task is complete
FO-329061	10/6/2015			We are requesting to have the hallways of the Basement, 1st Floor, Mezzanine, 2nd Floor, and 3rd Floor of the Prentis Building to be cleaned and waxed. Must be completed before Oct.30,2015.
FO-329062	10/6/2015			We are requesting for the stairs on the north and south side of the Prentis Building to be cleaned and waxed including the landings on each floor that is connected to the stairs. Must be completed before Oct.30,2015.
FO-329064	10/6/2015			Requesting to have the Basement, 1st Floor, 2nd Floor, and 3rd Floor Bathrooms in the Prentis Building to be scrubbed thoroughly and waxed. Must complete by Oct. 30,2015.
FO-329359	10/12/2015	10/19/2015		There is no soap in the dispenser in the lower level men's restroom. Task is complete
FO-329360	10/12/2015	10/27/2015		Please wash the glass doors at the Woodward entrance, and clean the stair wells at the same entrances. We are now having audiences on the weekends. Thanks. task is complete
FO-329484	10/13/2015			2 cases of dial soap.
FO-329488	10/13/2015			2 cases of dial soap.
FO-329489	10/13/2015			2 cases of dial soap.
FO-329490	10/13/2015			2 cases of dial soap.
FO-329491	10/13/2015			2 cases of dial soap.
FO-329720	10/15/2015	10/27/2015		Following up on FO-327087 from 9/16 . We will be having a open house in the first floor labs of Life Science next week. We requested that the hallway needs to be mopped and waxed and it has not been done. Also, please make sure the restroom are thoro
FO-330854	10/23/2015			2 cases of dial soap.
FO-331251	10/28/2015			Please shampoo office numbers 5137 and 5152 on the 5th floor of 259 Mack Ave. Please contact Chemika Buffington @ 577-1845 or Theresa Hill @ 577-0556 prior to starting service request so that the occupants may find another location to work for t
FO-331311	10/29/2015	10/28/2015		3 cases of dial soap. task is complete
FO-331312	10/29/2015	10/28/2015		6 cases of tissue. Task is complete

WO	Recieved	Finished	Total	Request
C-Sector 02			13	
FO-329278	10/9/2015	10/12/2015		Could someone from Facilities please come to clean the windows and the glass leading into office suite 313
FO-329476	10/13/2015	10/20/2015		6 cases of dial soap.
FO-329477	10/13/2015	10/20/2015		6 cases of dial soap.
FO-329478	10/13/2015	10/20/2015		4 cases of dial soap.
FO-329479	10/13/2015	10/20/2015		4 cases of dial soap.
FO-329480	10/13/2015	10/20/2015		60 & 95 W. Hancock - 2 cases of dial soap.
FO-329618	10/14/2015	10/26/2015		Student Affairs Suite 1600 - need carpet shampooed (including offices within the suite) no later than 11/4/15 for their annual Apple Days community event on 11/11/15.
FO-329619	10/14/2015	10/26/2015		Suite 1600 (Student Affairs) - the kitchen area floor needs to be cleaned and waxed no later than 11/4/15 for the department's annual Apple Days event 11/11/15.
FO-329655	10/14/2015			Please strip, scrub and wax floor of room 7327.
FO-330749	10/22/2015			Strip, scrub, and wax floors of lab area on the East side of the building (CMMG) Coordinate with David Wissbrun 313.577.07120; E-mail dy8703@wayne.edu) Geeneva Guice aware of this work
FO-331434	10/30/2015			Rm. 1130.4 (kitchen area) there seems to be a smelly odor emitting. Op. Mgr. is requesting for custodial services to clean sink & investigate it a bit.
FO-331438	10/30/2015			In the Learning Resource Center (LRC) the study rooms (322, 324, 325, 326, 351, 353, 354, 355). need to be cleaned prior to the 11/3 & 11/4 interviews (dust, empty trash, clean window cells and any glass windows).
FO-331450	10/30/2015			Men's restroom on 5th floor is out of hand towels; also, faculty person reports water fountain is dirty and needs cleaning.
C-Sector 03			11	
FO-329105	10/7/2015	10/8/2015		1 Box dial hand sanitizer.
FO-329649	10/14/2015	10/14/2015		1 case of dial soap.
FO-329650	10/14/2015	10/14/2015		1 case of dial soap.
FO-329651	10/14/2015	10/14/2015		1 case of dial soap.
FO-329652	10/14/2015	10/14/2015		1 case of dial soap.
FO-329653	10/14/2015	10/14/2015		1 case of dial soap.
FO-329654	10/14/2015	10/14/2015		1 case of dial soap.
FO-329656	10/14/2015	10/14/2015		1 case of dial soap.
FO-329657	10/14/2015	10/14/2015		1 case of dial soap.
FO-331285	10/28/2015	10/28/2015		The 3rd floor bathroom in Kresge needs to be cleaned. Thanks.
FO-331286	10/28/2015	10/29/2015		The 3rd floor bathroom in Kresge needs to be cleaned. Thanks.
C-Sector 04			8	
FO-329106	10/7/2015	10/13/2015		1 case of dial soap.
FO-329107	10/7/2015	10/13/2015		2 cases of dial soap.
FO-329108	10/7/2015	10/13/2015		1 case of dial soap.
FO-329481	10/13/2015	10/13/2015		2 cases of dial soap.
FO-329482	10/13/2015	10/13/2015		2 cases of dial soap.
FO-329483	10/13/2015	10/13/2015		2 cases of dial soap.
FO-330755	10/22/2015	10/22/2015		Both fume hoods in this room have low face velocity.
FO-331258	10/28/2015			Please shampoo the following offices at 5057 Woodward Ave - Offices 2103 and office 6304.6... Please schedule this service after 5:00pm. Notify Robert Wright @ 577-9670 or Theresa Hill @ 577-0556 once date is scheduled so that the floor areas wi

WO	Recieved	Finished	Total	Request
C-Sector 05			2	
FO-330568	10/20/2015	10/26/2015		10 cases of dial soap to sector 5 office.
FO-330675	10/21/2015	10/29/2015		It appears that room 3157 has not been cleaned in weeks. This room needs to be cleaned. Thank you.
C-Sector 06			4	
FO-330858	10/23/2015	10/27/2015		6 cases of small bags.
FO-331021	10/27/2015	10/27/2015		6 cases of dial soap.
FO-331277	10/28/2015			8 cases of dial soap.
FO-331278	10/28/2015			4 boxes of white rags.
C-Sector 07			3	
FO-328594	10/1/2015	10/2/2015		Who ever is responsible for cleaning this classroom has not done so in quite a while. The garbage can looks like it has not been emptied for around 2 weeks. Please have someone empty it. Thanks.
FO-329312	10/9/2015			Purdy Library 1st Floor Room 122, Office Suite of HR Region B. Staff in area have requested that their carpeting be shampooed. Thank you.
FO-330810	10/22/2015	10/23/2015		It has been reported that trash has not been picked up on the third floor of Kresge Library for two weeks. Please have assigned custodian notified.
C-Sector 08			10	
FO-329109	10/7/2015	10/8/2015		3 cases of gojo soap.
FO-329110	10/7/2015	10/8/2015		5 cases of dial soap.
FO-329112	10/7/2015	10/8/2015		2 cases of dial soap
FO-329350	10/12/2015			Wayne State Police - Dispatch Center - need a canister vacuum cleaner for the Dispatch room.
FO-329630	10/14/2015			Clean tile floor in the hallway leading to the new Volleyball team room...Please see Bob Ostrowski on specs. Please rush.Thank You. Bob Ostrowski
FO-330564	10/20/2015			4 cases of dial soap.
FO-330565	10/20/2015			4 cases of dial soap.
FO-330566	10/20/2015			4 cases of dial soap.
FO-330855	10/23/2015			1 case of dial soap.
FO-330857	10/23/2015			1 case dial soap.
C-Sector 09			16	
FO-329114	10/7/2015	10/8/2015		2 cases of dial soap.
FO-329118	10/7/2015	10/8/2015		1 case of dial soap.
FO-329120	10/7/2015	10/8/2015		1 case of dial soap.
FO-329122	10/7/2015	10/8/2015		1 case of dial soap.
FO-329123	10/7/2015	10/8/2015		1 case of dial soap.
FO-329124	10/7/2015	10/8/2015		1 case of dial soap.
FO-329126	10/7/2015	10/8/2015		1 case of dial soap.
FO-329127	10/7/2015	10/8/2015		2 cases of dial soap.
FO-329128	10/7/2015	10/8/2015		1 case of dial soap.
FO-329129	10/7/2015	10/8/2015		1 case of dial soap.
FO-329774	10/15/2015			please clean floors in labs 253 and 255. thank you
FO-331259	10/28/2015	10/28/2015		2 boxes of dial soap.
FO-331268	10/28/2015	10/28/2015		2 boxes of dial soap.
FO-331269	10/28/2015	10/28/2015		2 boxes of dial soap.
FO-331272	10/28/2015	10/28/2015		2 boxes of dial soap.
FO-331275	10/28/2015	10/28/2015		2 boxes of dial soap.

WO	Recieved	Finished	Total	Request
Pest Controller			18	
FO-328498	10/1/2015	10/1/2015	10/1/2015	PEST CONTROL- please investigate/resolve concern. Twice recently in the early morning I have seen "large mice" along the parking blocks on the North East side of the lot and going under the cement walkway in front of the stairs to the basement. Please add
FO-328527	10/1/2015	10/1/2015	10/1/2015	Exterminate rats at Alumni House
FO-328608	10/2/2015	10/14/2015	10/14/2015	EXTERMINATION FOR ROACHES AND BUGS. 1ST FLOOR KITCHEN, BREAK ROOM AND NEAR CIRCULATION DESK.
FO-328718	10/5/2015	10/5/2015	10/5/2015	EXTERMINATION FOR MICE IN ROOMS 6400.2, 6400.3 & 6400.4.
FO-329018	10/6/2015	10/6/2015	10/6/2015	In Office 1158 mouse droppings were found on the desk. Can someone please set some traps in this office. Thank you.
FO-329100	10/7/2015	10/8/2015	10/8/2015	Flies in the press box.
FO-329420	10/12/2015	10/21/2015	10/21/2015	EXTERMINATION FOR ANTS. WOMEN'S BASKETBALL LOCKER ROOM. ROOM 175.
FO-329534	10/13/2015	10/15/2015	10/15/2015	Live Flies in the football press box again....Need pest control prior to this Saturday's (10-17-15) home football game. Please rush. Contact - Bob Ostrowski
FO-329615	10/14/2015	10/14/2015	10/14/2015	Rat hole in front of main entrance.
FO-329617	10/14/2015	10/14/2015	10/14/2015	Rat hole in front of main entrance.
FO-329709	10/15/2015	10/21/2015	10/21/2015	EXTERMINATION FOR BUGS. 1ST FLOOR WOMEN'S RESTROOM IN ATRIUM.
FO-329890	10/19/2015	10/19/2015	10/19/2015	There is a black squirrel in lab 2524 that needs to be removed. Thank you.
FO-329977	10/19/2015	10/21/2015	10/21/2015	R/R 14TH FLR HALLWAY APPR NEAR RM 14001.5 A RAT/LARGE MOUSE WAS SEEN PLS LAY MORE STICKY TRAPS REPLACED OLD
FO-330840	10/23/2015	10/23/2015	10/23/2015	PLEASE REMOVE SQUIRREL IN REAR OF WELCOME CENTER. IT'S IN THE PARKING AREA.
FO-331153	10/28/2015	10/29/2015	10/29/2015	PEST CONTROL PLEASE REPLACE PEST GLUE TRAPS IN MECH ROOMS 1& 5,TRAPS FULL PRIORITY MED
FO-331244	10/28/2015	10/29/2015	10/29/2015	Please treat rooms B & C for ants.
FO-331339	10/29/2015	10/29/2015	10/29/2015	OFFICE SUITE #9306 NEEDS GLUE TRAPS PLACED IN ALL AREAS. THERE 3 SUITES INSIDE.
FO-331453	10/30/2015			R/R RM 3105 HAS A MOUSE TRAPPED ON THE STICKY TRAP WOULD LIKE IT DISPOSED OF & NEW TRAPS LAYED
Engineering			776	
Emergency			19	
E - Command Center			4	
FO-328698	10/5/2015	10/6/2015		REPAIR MAIN LINE FOR CONTROL AIR COMPRESSOR.
FO-330824	10/23/2015	10/26/2015		R/R RM 1077/MECH RM BOILER #1 WILL NOT START BELIEVE ITS AN ELECTRICAL ISSUE
FO-330826	10/23/2015	10/26/2015		R/R RM 1077/MECH RM BOILER #2 WILL NOT START BELIEVE ITS AN ELECTRICAL ISSUE
FO-331310	10/29/2015	10/29/2015		AIR HANDLER UNIT #3 SUPPLY FAN WILL NOT RUN. MECHANICAL ROOM 6TH FLOOR.
E - MedPharm			4	
FO-330528	10/20/2015	10/20/2015		RM 040 HAS WATER POURING IN THRU CLNG
FO-330849	10/23/2015	10/23/2015		OUTSIDE SW CORNER SMALL ELECTRICAL FIRE NEAR LAMP POST
FO-331039	10/27/2015	10/27/2015		RAF #2 IS IN ALARM
FO-331454	10/30/2015			RM 1348/KITCHEN EXH HOOD OVER FRYER STOPPED WORKING
E - North			1	
FO-329033	10/6/2015	10/6/2015		FAP FIRE ALARM ACTIVE
E - Northeast			1	
FO-329579	10/14/2015	10/14/2015		SMOKE DETECTOR CAUSING FIRE TROUBLE ALARM. CONTACT ENGINEER FOR DETAILS.
E - Preventative Maintenance			3	
FO-329073	10/6/2015	10/7/2015		3RD FL NORTH SIDE FLOOD GOING INTO STAIRWELL POSSIBLY COMING FROM MECH CLOSET

WO	Recieved	Finished	Total	Request
FO-329424	10/12/2015	10/13/2015		2ND FLR NORTHEND HAS A GAS SMELL
FO-329429	10/12/2015	10/12/2015		FAP FIRE ALARM ACTIVE
E - South			2	
FO-328700	10/5/2015	10/7/2015		DOOR ALARM. STAFF ENTRANCE ON THE NORTH SIDE OF BUILDING. NEAR CIRCULATION DESK. FIRE ALARM PANEL SHOWING BAD BATTERY FOR CIRCUIT 31.
FO-331034	10/27/2015	10/27/2015		FAP FIRE ALARM IS ACTIVE
E - Southeast			1	
FO-330685	10/21/2015	10/21/2015		FAP ACTIVE FIRE ALARM
E - West			3	
FO-329012	10/6/2015	10/6/2015		EMERGENCY ELEC R/R BLDG FAP FIRE TROUBLE ALARM ACTIVE UNABLE TO RESET
FO-329059	10/6/2015	10/6/2015		BLDG HAD A POWER BUMP
FO-330651	10/21/2015	10/22/2015		BLDG HAD A BROWN OUT PARTIAL LITES CAME BACK ON ??? ON OTHER ELECTRICAL POWER
High			434	
E - Auxiliary			48	
H-55083	10/3/2015	10/6/2015	10/12/2015	Ashley Hepp 10/12/2015 11:10 - The heat and AC is not working and the room is freezing cold. The weather is starting to get colder and this needs to be looked at ASAP. authenticated user: Alexandra D'Abreu-Hines - fp0908 requester ip address: 141.217.
H-55124	10/5/2015			Our central air conditioning is set to the lowest temperature allowed, and the air is blowing out lukewarm. We think the filter may need to be changed, because we get very hot at night and prefer our apartment cold.authenticated user: Cailey Stiteler - f
H-55133	10/5/2015			The cold water tap in the sink is not getting closed properly (again) and when hot water tap is turned on, it makes weird loud noise.authenticated user: Niranjan Jadhav - fr9238requester ip address: 141.217.205.82
H-55150	10/6/2015	10/7/2015	10/9/2015	Ashley Hepp 10/09/2015 14:27 - Three power ports do not work, including the one connected to the refrigerator. I am in a huge trouble. Please respond me as soon as possible. It is highly appreciated. authenticated user: Madusha Lakshani Watuthanthrige
FO-329086	10/7/2015	10/8/2015		FIRE ALARM. 5TH FLOOR.
FO-329139	10/7/2015	10/7/2015		FIRE TROUBLE ALARM
FO-329146	10/7/2015	10/8/2015		FAP FIRE TROUBLE ALARM ACTIVE
FO-329162	10/7/2015	10/7/2015		FAP FIRE TROUBLE ALARM ACTIVE
FO-329297	10/9/2015	10/9/2015		6TH FL TOO HOT
FO-329354	10/12/2015	10/12/2015		TOO WARM. BUILDING INCLUDING THE 4TH FLOOR.
FO-329368	10/12/2015	10/13/2015		7TH FL TOO HOT
FO-329409	10/12/2015	10/13/2015		APT 303 HOT WATER IN BATH TUB WON'T SHUT OFF
H-55254	10/12/2015			My kitchen fuse has blown and now my refrigerator and other appliances don't have power. Please restore power to my kitchen. (my living room area still has power so I'm guessing its only in my kitchen.authenticated user: - requester ip address: 141.2
H-55252	10/12/2015			there is electricity issue with entire bedroom and bathroom . they couldn't access to power for few areas of apartment authenticated user: Rahul Reddy Kandi - fs2308requester ip address: 141.217.23.210
H-55272	10/12/2015			BATHROOM WATER IS COMING FROM BASE OF TOILETauthenticated user: Joanna Berry - fa3511requester ip address: 141.217.23.194
H-55273	10/12/2015			SHOWER HEAD DRIPS CONSTANTLYauthenticated user: Joanna Berry - fa3511requester ip address: 141.217.23.194
FO-329470	10/13/2015	10/13/2015		TOO HOT. BUILDING INCLUDING 6TH, 2ND AND 1ST FLOORS.
H-55268	10/13/2015			Replace the faucet and connect the drain line after the new sink and top are installed. Installation will be Wednesday the 14th.
H-55298	10/13/2015			*****important*****1)water tap of kitchen not getting closed water is draining.Several times we have informed but always we face the same problem. authenticated user: Nirbhay Mehta - fs4551requester ip address: 141.217.232.222
FO-329623	10/14/2015	10/15/2015		FIRE TROUBLE ALARM.

WO	Recieved	Finished	Total	Request
FO-329690	10/15/2015	10/15/2015		FIRE TROUBLE ALARM
FO-329691	10/15/2015	10/15/2015		ALARM SOUNDING IN PARKING STRUCTURE #8. CONTACT TONYA AT 7-7974.
H-55323	10/15/2015			Garbage disposal is leaking causing sink to be clogged. Bruner may need to be called. authenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.210
FO-329714	10/15/2015	10/15/2015		GARBAGE DISPOSAL IS NOT WORKING. CAFETERIA.
FO-329739	10/15/2015	10/16/2015		FIRE TROUBLE ALARM
H-55353	10/15/2015			Toilet handle broke off because rusted. Went to flush the toilet and the lever arm part of the handle broke off from the base. Please fix as soon as possible because it is difficult to flush the toilet now. authenticated user: Matthew Schwartz - fb9919
H-55370	10/15/2015			Hey, I got a problem with the heater in my apartment. only the air conditioner is on and heater is not working, I greatly appreciate it if you address this problem, Thank you, authenticated user: Imaneh Fallahi - fc4641requester ip address: 35.16.227.13
FO-329794	10/16/2015	10/16/2015		ROOF DOOR ALARM 345 C
FO-329809	10/16/2015	10/19/2015		OCCUPANT MARTA RM 503 LOST POWER
H-55341	10/16/2015			Leaky ceiling. authenticated user: Kayla Dekoekkoek - fq8414 requester ip address: 141.217.23.187
FO-329857	10/16/2015	10/19/2015		FIRE ALARM.
H-55419	10/18/2015			The water leakage for the cold water tap in kitchen sink is still not resolved. It started around a month back and was repaired once. But even after that, it started to leak in a few days. Also, we are not able to close the tap properly as the tap is loos
H-55420	10/20/2015			The outlet that the vending machines and printer are hooked up to in the lobby of chatsworth is not working properly and sometimes makes sparking sounds. authenticated user: David Johnson - fn9187requester ip address: 141.217.23.216
FO-330561	10/20/2015	10/21/2015		ALARM SOUNDING IN EMERGENCY EQUIPMENT RM FOOR #107-E
H-55422	10/20/2015			Base of the toilet has lifted off the floor and it is leaking. authenticated user: Nicole Fry - eq0918requester ip address: 141.217.23.216
FO-330573	10/20/2015	10/21/2015		FAP FIRE TROUBLE ALARM
FO-330599	10/20/2015	10/21/2015		1ST FLR IS EXTREMELY HOT
FO-330600	10/20/2015	10/21/2015		2ND FLR IS EXTREMELY HOT
FO-330674	10/21/2015	10/22/2015		1ST FL CONVENIENCE STORE TOO HOT
FO-330745	10/22/2015	10/23/2015		6TH FL TOO HOT
FO-330836	10/23/2015	10/26/2015		RM 552 TOO COLD
FO-330897	10/26/2015	10/27/2015		FIRE ALARM.
FO-330966	10/26/2015	10/28/2015		FIRE TROUBLE ALARM
H-55534	10/26/2015			Please fix toilet (won't flush) Also, please fix blinds (won't move up/down as chain is no longer on track) &Please be mindful of the curtains! Thank you in advance authenticated user: - requester ip address: 35.16.103.211
H-55535	10/27/2015			Heater is not putting out heat in room. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.187
FO-331052	10/27/2015	10/29/2015		TABLE OUTLET SPARKS WERE EXTINGUISHED, WOULD LIKE ENG TO CHECK OUTLETS
FO-331110	10/28/2015	10/29/2015		POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331207	10/28/2015	10/28/2015		FIRE TROUBLE ALARM.
E - Command Center			27	
FO-328470	10/1/2015		10/5/2015	CONTROLS GROUP-NEED ASSITANCE GETTING #1BOILER TO START,BOILER WON'T START PRIORITY HIGH
FO-328607	10/2/2015	10/2/2015		Boiler #1 won't start. Please repair
FO-328610	10/2/2015	10/8/2015		Controls (High) Boiler BSG-002. Boiler #2 continues to go out on pilot flame failure. Check/replace pilot ignition rod. Tip appears to be broken.

WO	Recieved	Finished	Total	Request
FO-329099	10/7/2015	10/22/2015		Trade: Command Center Priority: High R/R ROOF AREA MUA #3 (near the elevator penthouse). Unit is discharging 140 deg. Flame is very large. Heat will not modulate. Please repair.
FO-329512	10/13/2015			Trade: Controls/Siemens Priority: High Engine lab 1543 is in huge negative pressure due to space CO alarm, can hardly open door to lab. No engines in this lab are running, CO sensor may be faulty or out of calibration.
FO-329520	10/13/2015	10/26/2015		Trade: Command Center Priority: High Pager is not receiving any RENO alarms. Pager is working properly otherwise. Please investigate and repair. 313-684-1706
FO-329678	10/15/2015	10/20/2015		Controls; High. Repair or replace sensor on No. 2 boiler as necessary.
FO-329679	10/15/2015	10/15/2015		Controls. High. Install Insight software on new computer at welcome center.
FO-329719	10/15/2015	10/16/2015		Controls -- Priority High Boiler will not reset
FO-329751	10/15/2015	10/16/2015		CONTROLS (HIGH) PLEASE MAKE A LIGHTING SCHEDULE TAB FOR MED COMMONS. O THE SEIMENS CONTROL
FO-329855	10/16/2015			BOILER KICKING OUT ON HIGH TEMP
FO-329885	10/19/2015			Controls. High; R/R RM 00505/MECH RM Boilers/circ pumps not starting although enabled by seimens.
FO-329916	10/19/2015			controls group, R/R RM 00104/MECH RM please repair the HONEYWELL controls for the entire bldg. system is locked up priority high
FO-329924	10/19/2015			It appears the freeze stat is bad
FO-329963	10/19/2015	10/29/2015		Trade: Command Center Priority: High R/R RM 00120 Please supply 2 DP transmitters for fume hoods in lab 120. Siemans Part # 590 - 780.
FO-329970	10/19/2015	10/21/2015		Controls- High Priority- R/R RM 3237/MECH RM Adjust humidity controls on fan #3 to provide DLAR with rH of 33-75% in animal quarters. Currently at 19% in most spaces.
FO-330505	10/20/2015	10/21/2015		trade siemens controls priority high R/R RM 6152/MECH RM please service humidification control valve has no air pressure to open the valve its at zero pounds and low humidity for animal quarters thank you
FO-330547	10/20/2015	10/21/2015		pls check repair ahu2 the cooling stage does not cycle off sub cooing the dat into the 40
FO-330625	10/21/2015	10/22/2015		Command Center, High; R/R RM 505/MECH RM Cabinets for heating system show cabinet error and AHUs intermittently show error.
FO-330667	10/21/2015	10/29/2015		control's-siemen stat not showing power, new forced air units blowing hot air out of control which is over heating the room. double coverage today Fab zone & lbio. I had to turn heating units off by switches in room. Three heating units are in this room i
FO-330719	10/22/2015	10/28/2015		Trade: Command Center Priority: High R/R RM 120 Fume hoods in lab 120 have been serviced. Please update the database for the following fume hoods 120-1 (27),2 (28), 4 (25), 10 (16), 11 (13), 12 (12), 15 (21) & 16 (22).
FO-330882	10/24/2015	10/26/2015		Repair Siemens control serving AHU-1 at Elliman. The fan controller is reporting "failed". Fan cannot be started.
FO-331047	10/27/2015	10/29/2015		BAS CONTROLS GROUP-R.HOSKING-R/R BLDG PLEASE INVESTIGATE SIEMENS INSIGHT FOR ST ANDREWS HALL, CAN'T SEE OPERATION OF BLDG PRORITY HIGH
FO-331179	10/28/2015			boilers & controls-Soleniod valve for D.A. tank is not operating properly with the float valve and is causing the D.A> tank to run out of water. high priority! pumps and boilers are shutting off due to low water condition. I have to use the by pass to kee
FO-331337	10/29/2015	10/29/2015		trade seimens controls priority high R/R RM 00150/MECH RM please service air handler unit B1 in basement area will not run in auto unit is running in hand right now in operator
FO-331376	10/29/2015			Control Engineer; High R/R RM 2218 Please look at the programming on the TEC for heat pump #2-15 that serves Suite 2218. The temperature in the Suite was sixty degrees. The heat pump was switched off.

WO	Recieved	Finished	Total	Request
FO-331430	10/30/2015			CONTROLS GROUP- R/R RM 604/MECH BLR RM PLEASE REPAIR OR MAKE ADJUSTMENTS TO #2 BOILER FEEDWATER REGULATOR, BOILER WATER LEVEL RUNNING HIGH CAUSING BOILER TO TRIP OUT PRIORITY HIGH
E - MedPharm			90	
FO-328476	10/1/2015			Humidity in room too high and too wide of a humidity swing.
FO-328491	10/1/2015	10/1/2015		TOO COLD. ROOM 5420.08.
FO-328504	10/1/2015	10/1/2015		TOO COLD. ROOMS 5364, 5370 & 5372.
FO-328633	10/2/2015	10/2/2015		Please adjust the temperature to 70F ASAP. Thanks.
FO-328630	10/2/2015	10/15/2015		RM 411 LOW HUMIDITY PLEASE FIX ASAP
FO-328634	10/2/2015	10/15/2015		RM 200.07 & 200.09 LOW HUMIDITY
FO-328636	10/2/2015	10/15/2015		RM 416 LOW TEMP
FO-328643	10/2/2015	10/15/2015		RM 415 LOW TEMP
FO-328721	10/5/2015	10/16/2015		RM 7263 TOO HOT
FO-328722	10/5/2015	10/15/2015		LOADING DOCK INTERIOR DOOR STANDING WATER FROM DOCK
FO-329002	10/6/2015			Humidity too high and wide swing in humidity
FO-329045	10/6/2015	10/14/2015		RM 0225 & 0522 AIR PRESSURE PROBLEM. AIR SHOULD BE NEGATIVE
FO-329084	10/7/2015	10/15/2015		LOW TEMP. ALARM. ROOM 4311.
FO-329115	10/7/2015	10/15/2015		RM 403 HIGH HUMIDITY
FO-329116	10/7/2015	10/7/2015		RM 4312 WALK IN COLD RM BOX IS IN ALARM
FO-329152	10/7/2015	10/15/2015		FIRE PANEL IN ATRIUM BUZZING
FO-329201	10/8/2015	10/8/2015		RM 0136 FREEZER #13 IS IN ALARM
FO-329230	10/8/2015			RM 472 HAS A HI TEMP
FO-329301	10/9/2015	10/9/2015		LOW TEMP. ROOM 0519.
FO-329349	10/12/2015	10/12/2015		CEILING LEAK IN WALK IN COOLER. ROOM 5502.
FO-329385	10/12/2015	10/13/2015		HIGH TEMP. ROOM 200.13.
FO-329404	10/12/2015	10/13/2015		LAB 5324 TOO HOT
FO-329406	10/12/2015	10/13/2015		HVAC SYSTEM IS MAKING A LOUD NOISE. BASEMENT MORGUE. CONTACT KRISTA FOR MORE DETAILS
FO-329461	10/13/2015	10/19/2015		HIGH TEMP. ROOM 200.13.
FO-329466	10/13/2015	10/14/2015		Rooms 05514 and 0515 in the basement of Elliman have too much exhaust air flow. The rooms are howling and it is not good for the critters. This has been called in before.
FO-329486	10/13/2015	10/19/2015		RM 3359 INDEPENDENT CHILLER NOT FUNCTIONING RM IS TOO HOT
FO-329497	10/13/2015	10/15/2015		The Temperatures are either too hot or too cold in these rooms in the basement of Elliman - Rooms 0209,0409,and 0412. Thermostat in one room already turned up to 80 but it is not responding.
FO-329594	10/14/2015	10/19/2015		RM 200.13 HIGH TEMP
FO-329598	10/14/2015	10/14/2015		RM 0225 NO WATER IN THE CAGEWASH
FO-329602	10/14/2015	10/14/2015		NO WATER IN RACK WASHERS. ROOM 0225.
FO-329608	10/14/2015			FIRE TROUBLE ALARM.
FO-329609	10/14/2015	10/19/2015		RM 5324 TOO HOT
FO-329624	10/14/2015	10/14/2015		NO STEAM IN DIRTY CAGE WASHER. BASEMENT ROOM 0225.
FO-329672	10/15/2015			temp too high
FO-329699	10/15/2015			RM 232 NEED SOMEONE TO UNLOCK DOOR
FO-329708	10/15/2015	10/15/2015		RM 0519 LOW TEMP & LOW HUMIDITY
FO-329712	10/15/2015	10/19/2015		GREEN LECTURE HALL TOO COLD
FO-329750	10/15/2015	10/22/2015		RM 1106 OTTER OFFICE, 1272,1276 TOO HOT
FO-329785	10/16/2015			Thermostat cover missing
FO-329779	10/16/2015			LIGHTS OUT IN LOBBY AND VESTIBULE.
FO-329780	10/16/2015			NO LIGHTS ON THE 2ND FLOOR INCLUDING ROOM 206.

WO	Recieved	Finished	Total	Request
FO-329796	10/16/2015			1ST FLOOR SECURITY GATE IS MAKING A BEEPING SOUND.
FO-329797	10/16/2015	10/22/2015		LOW TEMP. ROOM 200.01.
FO-329799	10/16/2015	10/16/2015		LOW TEMP. ROOMS 216.2 AND 219.
FO-329800	10/16/2015	10/16/2015		LOW HUMIDITY IN ROOMS 200 AND 203.
FO-329816	10/16/2015	10/16/2015		BSMNT LOW HUMIDITY
FO-329822	10/16/2015	10/22/2015		RM 4126 TOO COLD
FO-329836	10/16/2015	10/22/2015		LOW TEMP. ALARM. ROOM 200.08.
FO-329842	10/16/2015			BUILDING IS TOO COLD AND THERE IS A PERFORMANCE SCHEDULED FOR TOMORROW. PLEASE CALL FRED FLORKOWSKI.
FO-329882	10/19/2015	10/21/2015		LOW TEMP. IN ROOM 415.
FO-329888	10/19/2015	10/22/2015		HIGH TEMP. ROOM 200.13.
FO-329911	10/19/2015	10/19/2015		LOW HUMIDITY IN ALL BASEMENT ANIMAL ROOMS.
FO-329928	10/19/2015			The radiator valve in this room is seized and the knob has broken off. Right now this room is cold. In order to gain access please contact Fred Florkowski at 313-570-3556. This room contains sensitive lighting equipment for the theatre. Please repair.
FO-329936	10/19/2015	10/22/2015		RM 200.08/DLAR HAS A LOW TEMP
FO-329937	10/19/2015	10/22/2015		RM 413/DLAR HAS A LOW TEMP
FO-329940	10/19/2015	10/27/2015		RM 411/DLAR HAS A LOW TEMP
FO-329941	10/19/2015	10/27/2015		RM 416/DLAR HAS A LOW TEMP
FO-330553	10/20/2015	10/30/2015		TOO COOL - BLUE LECTURE HALL.
FO-330567	10/20/2015	10/20/2015		BSMT ENTIRE SMALL/LARGE ANINAL QUARTERS HAVE LOW HUMIDITY
FO-330652	10/21/2015	10/21/2015		RM 0229 TOO COLD
FO-330653	10/21/2015	10/21/2015		RM 0519 TOO COLD
FO-330665	10/21/2015	10/30/2015		ENTIRE STE 200/DLAR HAS LOW HUMIDITY
FO-330678	10/21/2015	10/21/2015		BLDG AHU #3 HAS A HI TEMP ALARM
FO-330751	10/22/2015	10/30/2015		RM 1200 TOO COLD, WOULD LIKE ENG TO COME ASAP MEETING IN JUST A FEW MIN
FO-330763	10/22/2015	10/30/2015		200.13 HIGH TEMP
FO-330768	10/22/2015			RM 414 TOO HOT
FO-330776	10/22/2015			1ST FL ALARM PANEL IN TROUBLE MAKING A BEEPING NOISE
FO-330813	10/23/2015			1ST FLR MAIN OFC UNISEX RR TOILET IS CON'T FLUSHING
FO-330815	10/23/2015	10/23/2015		GENERATOR TROUBLE ALARM
FO-330845	10/23/2015	10/23/2015		RM 2220 TOO HOT
FO-330850	10/23/2015			RM 1369.8 NEED BREAKER RESET
FO-330895	10/26/2015			REFRIGERATOR IS NOT WORKING. PLEASE CHECK WALL OUTLET. CAFETERIA
FO-330898	10/26/2015	10/26/2015		FF1 FAN ALARM.
FO-330900	10/26/2015			LOW TEMP. ROOMS 200.13 AND 415.
FO-330906	10/26/2015			RM 2602.1 TOO COLD
FO-330921	10/26/2015	10/27/2015		SF-2 FAN ALARM
FO-330945	10/26/2015			200.07 & 200.08 TEMP TOO LOW, TEMP IS 72 SHOULD BE 78
FO-331062	10/27/2015			LOW TEMP. ROOM 415.
FO-331063	10/27/2015			HIGH TEMP. ROOM 200.13.
FO-331080	10/27/2015	10/27/2015		RAF #2 IS IN ALARM AGAIN
FO-331133	10/28/2015			FIRE DOOR NEXT TO THE CAFE IS IN ALARM
FO-331149	10/28/2015	10/30/2015		Eyewash station water has low pressure, and is not flowing from one head.
FO-331169	10/28/2015			Room too cold. Set for 78 and ready 60
FO-331219	10/28/2015			FIRE TROUBLE ALARM
FO-331241	10/28/2015			RM 1102 IS TOO HOT
FO-331273	10/28/2015			LOW WATER PRESSURE. ALL RESTROOMS ON THE 3RD FLOOR.
FO-331329	10/29/2015			RM 4132 NO POWER

WO	Recieved	Finished	Total	Request
FO-331347	10/29/2015			HIGH TEMP. AND HIGH HUMIDITY. ROOM 410.
FO-331392	10/29/2015	10/29/2015		RM 3125 CEILING LEAK, PLEASE REMOVE WATER FILLED CEILING TILES
FO-331468	10/30/2015			LOW HUMIDITY. ROOM 7119.
E - North			68	
FO-328475	10/1/2015	10/1/2015		Purdy Library 2nd Floor Room 231 Received staff complaints regarding temperature: too cold! Please adjust. Thank you.
FO-328497	10/1/2015	10/1/2015		TOO COLD. 3RD FLOOR NORTH SIDE.
FO-328502	10/1/2015	10/1/2015		TOO COLD. ROOM 15. NEED AIR TURNED OFF.
FO-328532	10/1/2015	10/1/2015		EXHAUST FUMES ARE COMING THRU PIPE IN BASEMENT. ALSO EXHAUST FUMES ARE ON THE 1ST FLOOR. (FOUL SMELL)
FO-328689	10/5/2015	10/5/2015		TOO HOT. ROOMS 4043, 4045 & 4037.
FO-328692	10/5/2015	10/5/2015		TOO HOT. ROOM 4020.
FO-328699	10/5/2015	10/5/2015		BSMNT HOT KITCHEN AUDIO VISUAL BOX IS SPARKING
FO-328709	10/5/2015	10/5/2015		NORTH SIDE OF BLDG TOO HOT
FO-328723	10/5/2015	10/6/2015		TOO HOT. ROOM 1515.
FO-329021	10/6/2015	10/6/2015		ENTIRE BLDG IS TOO HOT
FO-329101	10/7/2015	10/7/2015		RM 2095 TOO HOT
FO-329158	10/7/2015	10/7/2015		KITCHEN BROWN WATER IS COMING OUT OF FAUCET BELIEVE PUMP IS OFF
FO-329202	10/8/2015	10/8/2015		RM 00140/AUD IS TOO COLD
FO-329236	10/8/2015	10/8/2015		BLDG TOO HOT
FO-329373	10/12/2015	10/12/2015		HOT AIR BLOWING. ROOM 2095.
FO-329587	10/14/2015	10/14/2015		TOO HOT. BUILDING (INCLUDING KITCHEN AND OFFICES)
FO-329606	10/14/2015	10/12/2015		HOT AIR BLOWING. ROOM 2095.
FO-329611	10/14/2015	10/14/2015		ELECTRICAL BURNING SMELL. HALLWAY OUTSIDE OF ROOM 105.
FO-329616	10/14/2015	10/14/2015		MECH RM 18 ALARMING
FO-329625	10/14/2015	10/14/2015		TOO HOT. ROOM 331.
FO-329643	10/14/2015	10/14/2015		BACKROOMS 34 & 36 TOO HOT
FO-329644	10/14/2015	10/14/2015		BLDG TOO HOT
FO-329688	10/15/2015			FIRE TROUBLE ALARM. ONGOING PROBLEM.
FO-329695	10/15/2015	10/15/2015		FIRE TROUBLE ALARM. ONGOING PROBLEM.
FO-329732	10/15/2015	10/15/2015		UNBEARABLE HOT AIR CONTINUES TO BLOW IN OFFICES.
FO-329736	10/15/2015	10/15/2015		TOO HOT. ROOM 4200.
FO-329737	10/15/2015	10/15/2015		RM 4020, 4043, & 4045 TOO HOT
FO-329832	10/16/2015	10/16/2015		RM 4259 TICKING SOUND FROM VENT
FO-329845	10/16/2015	10/16/2015		TOO COLD. ROOMS 423.3 AND 425.
FO-329884	10/19/2015	10/19/2015		TOO HOT. 4TH FLOOR INCLUDING ROOM 4020.
FO-329891	10/19/2015	10/19/2015		RM 421 IS TOO COLD
FO-329912	10/19/2015	10/19/2015		BSMT IS TOO COLD NO HEAT
FO-329915	10/19/2015	10/19/2015		2ND FLR IS TOO COLD NO HEAT
FO-329917	10/19/2015	10/19/2015		RM 351 RADIATOR LEAKING
FO-330554	10/20/2015	10/20/2015		TOO WARM. 3RD FLOOR.
FO-330628	10/21/2015	10/21/2015		High Priority Request: There is a water leak from the air conditioner's panel on the ceiling of the server room.
FO-330655	10/21/2015	10/21/2015		RM 189 TOO HOT
FO-330723	10/22/2015	10/22/2015		BLDG IS TOO HOT
FO-330747	10/22/2015	10/22/2015		RM 110/AUDITORIUM IS TOO HOT

WO	Recieved	Finished	Total	Request
FO-330928	10/26/2015	10/26/2015		The Partrich Auditorium, Atrium, and Jury Room are extremely hot. Please lower temperature ASAP, as there is an event in that area today.
FO-330951	10/26/2015	10/26/2015		SUMP PUMP ALARM.
FO-331012	10/27/2015	10/27/2015		CASS ENTRANCE AN ALARM (FAP) HAS A HI PITCH SOUND
FO-331042	10/27/2015	10/27/2015		RM 1120 PARTRIDGE AUDITORIUM, TOO COLD
FO-331072	10/27/2015	10/27/2015		TOO HOT. BUILDING. SEE JASON IN OFFICE. REFER TO WOS' FO-331221 (Main Ofc Hot 10/28/) FO-331222 (Rm-I Cold 10/28)
FO-331107	10/28/2015	10/28/2015		POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331111	10/28/2015	10/28/2015		FIRE PANEL IS BEEPING. 1ST FLOOR STAIRWELL - CASS SIDE.
FO-331154	10/28/2015	10/28/2015		RM 150 TOO HOT
FO-331155	10/28/2015			CEILING LEAK. ROOM 4228.
FO-331163	10/28/2015	10/28/2015		WITHIN RM 4236 CEILING LEAK, OUTSIDE RM 4228 LEAK
FO-331164	10/28/2015	10/28/2015		RM 2152 POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331170	10/28/2015	10/28/2015		FAP FIRE ALARM W/RESET
FO-331176	10/28/2015	10/28/2015		RM 4126 CEILING LEAK, C&IT RM 4116 AFRAID THAT THIS RM WILL GET LEAK ALSO
FO-331203	10/28/2015			CENTER ELEVATOR SUMP PUMP ALARM.
FO-331211	10/28/2015	10/28/2015		POWER FAILURE ALARM. ROOM 016.
FO-331214	10/28/2015	10/28/2015		LIGHTS BLINKING THROUGHOUT BUILDING.
FO-331221	10/28/2015	10/28/2015		MAIN OFFICE IS TOO HOT.
FO-331222	10/28/2015	10/28/2015		ROOM - I - IS TOO COLD.
FO-331228	10/28/2015			POWER BUMP APPR. 12:20
FO-331294	10/29/2015	10/29/2015		POOL MECHANICAL ROOM ALARM SOUNDING.
FO-331309	10/29/2015	10/29/2015		LOWER LEVEL AREAS HAVE A SEWAGE SMELL
FO-331321	10/29/2015	10/29/2015		TOO COLD. 3RD FLOOR
FO-331322	10/29/2015	10/29/2015		TOO COLD. BASEMENT
FO-331343	10/29/2015	10/29/2015		FIRE TROUBLE ALARM
FO-331441	10/30/2015			RM 4107 IS TOO COLD
FO-331442	10/30/2015	10/30/2015		RM 4116 TOO COLD
FO-331447	10/30/2015			CK BLDG WHERE BOATD OF GOVERNORS' ARE MTG IT IS TOO COLD NOW 10/30/15) TOO HOT. BUILDING. SEE JASON IN OFFICE. REFER TO WOS' FO-331221 (Main Ofc Hot 10/28/) FO-331222 (Rm-I Cold 10/28)
FO-331449	10/30/2015			RM 3198 IS TOO COLD
FO-331465	10/30/2015			NO HEAT IN ROOMS 1321 & 1317.
E - Northeast			33	
FO-328501	10/1/2015	10/14/2015		BLDG TOO COLD
FO-328620	10/2/2015	10/2/2015		TOO COLD. ROOM 313.
FO-328621	10/2/2015	10/2/2015		2ND FL NEAR MECH RM 2500 WIRE BURNING SMELL
FO-329027	10/6/2015	10/6/2015		INSIDE STE 1330 RM 1304 HAS PARTIAL POWER
FO-329026	10/6/2015	10/14/2015		BLDG TOO COLD
FO-329030	10/6/2015	10/6/2015		INSIDE STE 1330 RM 1306 HAS PARTIAL POWER
FO-329031	10/6/2015	10/6/2015		INSIDE STE 1330 RM 1308 HAS PARTIAL POWER
FO-329134	10/7/2015	10/7/2015		BLOWN FUSE. ROOM 3100.
FO-329294	10/9/2015	10/9/2015		BLDG TOO COLD
FO-329347	10/12/2015	10/12/2015		FIRE ALARM.
FO-329408	10/12/2015	10/29/2015		FIRE TROUBLE ALARM
FO-329492	10/13/2015	10/13/2015		BOUNCING FIRE TROUBLE ALARMS
FO-329629	10/14/2015	10/14/2015		Please send an engineer to fix the fuse that went out in Rm 240 Rands House.

WO	Recieved	Finished	Total	Request
FO-329715	10/15/2015	10/15/2015		TOO COLD. ROOM 2118.
FO-329718	10/15/2015	10/15/2015		1ST FL FUNNY SMELL POSSIBLY PAINT, SEE ODESSA
FO-329850	10/16/2015	10/16/2015		TOO HOT. ROOM 109.
FO-329893	10/19/2015	10/19/2015		BLDG TOO COLD
FO-329896	10/19/2015	10/19/2015		TOO COLD. ROOM 321.
FO-329902	10/19/2015	10/19/2015		RM 109 TOO HOT
FO-330518	10/20/2015	10/20/2015		TOO HOT. ROOM 113.
FO-330522	10/20/2015	10/20/2015		ENTIRE BLDG HAS COLD AIR BLOWING OUT OF VENTS TOO COLD
FO-330548	10/20/2015	10/29/2015		INSIDE STE 300 THE FOLLOWING RMS ARE HAVING HEAT PROBLEMS FANS ARE RUNNING HOWEVER NO HEAT RM 319, 321, 324, 326 & 328
FO-330761	10/22/2015			3RD FL BOILER ALARM SOUNDING
FO-330831	10/23/2015	10/23/2015		RM 313 IS TOO COLD
FO-330838	10/23/2015	10/23/2015		RM 0118 EXHAUST FAN NOT WORKING PLEASE SEE DEB ASHCRAFT
FO-330865	10/23/2015	10/23/2015		RM 109 ID TOO HOT
FO-330902	10/26/2015	10/26/2015		CONF RM 123 TOO HOT
FO-330917	10/26/2015	10/27/2015		WATER LEAK COMING UP THROUGH FLOOR. ROOM 125.
FO-330922	10/26/2015	10/26/2015		SOMEONE HIT THE BUILDING. PLEASE CHECK.
FO-331019	10/27/2015	10/27/2015		RM 313 IS TOO COLD
FO-331051	10/27/2015	10/29/2015		MDF/TECH RM, HUMIDIFIER ALARM SOUNDING
FO-331147	10/28/2015	10/29/2015		FIRE TROUBLE ALARM
FO-331150	10/28/2015	10/28/2015		TOO HOT. ROOM 109.
E - Preventative Maintenance			72	
FO-328565	10/1/2015	10/1/2015		LAB 60 TOO COLD TEMP SHOULD BE 72-73 F
FO-328587	10/1/2015		10/15/2015	MAIN LOBBY CEILING TILES DANGLING
FO-328592	10/1/2015	10/2/2015		RM 211 EXTREMELY HOT
FO-328654	10/2/2015	10/3/2015		RM 202.1 BLOWN FUSE
FO-328655	10/2/2015	10/3/2015		TOO WARM. ROOM 3043.
FO-328764	10/5/2015	10/5/2015		RM 105 TOO HOT
FO-328768	10/5/2015	10/5/2015		2ND FL AND 3RD FL HALLWAY HAVE MISSING LIGHT FIXTURES
FO-328774	10/5/2015	10/5/2015		RM 103 TOO HOT
FO-328776	10/5/2015	10/5/2015		EXTERIOR LIGHT POLE OFF THE MALL NEAR BLDG ENTRANCE, LIGHT POLE LOOKS LIKE IT HAS BEEN HIT. GLOBE LOOKS LOOSE
FO-328778	10/5/2015	10/5/2015		ENTIRE BLDG TOO HOT
FO-328787	10/5/2015	10/5/2015		6TH FL WOMENS RM 6013 TOILET OVERFLOWING
FO-329074	10/6/2015	10/7/2015		LOCKER IS STUCK CLOSED, NEED OPENED. (NO LOCK) MEN'S LOCKER ROOM 114. CONTACT CONROY.
FO-329166	10/7/2015	10/8/2015		STRUC # 4 PLEASE MEET NSA ON ROOF TO LET THEM IN
FO-329169	10/7/2015	10/8/2015		CONF RM M IS TOO HOT
FO-329171	10/7/2015	10/8/2015		KRESGE EXTERIOR DOOR NOT CLOSING PROPERLY
FO-329172	10/7/2015	10/7/2015		BLDG TOO HOT, TEMP IS RAISED DURING THE AFTERNOON SHIFT. WOULD LIKE TEMP TO BE LOWERED AND STAY AT A SET TEMP THROUGHOUT THE DAY SEE BRANDON CARTER
FO-329329	10/9/2015			please reattach metal boxes inner side of entry doors to 2nd flr suites-east end, north and south side. thank you
FO-329335	10/9/2015	10/10/2015		6275 & 6279 TOO HOT
FO-329338	10/9/2015	10/9/2015		1ST FL WOMENS RM TOILET PLUGGED
FO-329541	10/13/2015	10/13/2015		2602.1 TOO COLD
FO-329544	10/13/2015	10/13/2015		OUTLET NOT WORKING OUTLET FOR THE LARGE COPIER
FO-329549	10/13/2015	10/14/2015		1ST FL LEAK WITHIN MICHIGAN FIRST CREDIT UNION
FO-329555	10/13/2015	10/15/2015		PLEASE UNLOCK CLASSROOM 0134

WO	Recieved	Finished	Total	Request
FO-329559	10/13/2015	10/14/2015		Requesting to have an enginneer come adjust the tempeture in rm 300.1. It is very hot..
FO-329557	10/13/2015	10/15/2015		RM 3320 TOO COLD
FO-329658	10/14/2015	10/14/2015		BLDG TOO COLD
FO-329660	10/14/2015	10/14/2015		LAB 4176 TOO HOT
FO-329661	10/14/2015	10/15/2015		BACKROOMS 34 & 36 TOO HOT
FO-329663	10/14/2015	10/14/2015		RM 155 AUTOCLAVE NOT WORKING
FO-329766	10/15/2015	10/15/2015		TOO HOT. ROOM 2177.
FO-329771	10/15/2015			STRONG ELECTRICAL BURNING SMELL. SUBWAY RESTAURANT.
FO-329776	10/15/2015			Exhaust fan doesn't work properly. It is very noisy as if the bearing are destroyed.Please be informed that the mentioned room is an Engine test Lab1636Thank you
FO-329852	10/16/2015	10/20/2015		EMERGENCY LIGHTS TURNING ON RANDOMLY
FO-329856	10/16/2015	10/20/2015		Lower light on the front left side of the auditorium is flashing and making a loud noise.
FO-329858	10/16/2015	10/20/2015		In Office #224, employee hears the sound of water flowing inside wall of office.
FO-329862	10/16/2015	10/20/2015		RM 0319 HEATING UNIT MAKING A LOUD CLICKING NOISE
FO-329866	10/16/2015			APT 905 LEAKING INTO 8TH FL APT
FO-329867	10/16/2015			3RD FL HALLWAY ART BLDG
FO-329971	10/19/2015	10/20/2015		FAP FIRE TROUVBLE ALARM
FO-329972	10/19/2015	10/20/2015		BLDG TOO HOT
FO-329979	10/19/2015	10/19/2015		AHU#3 HIGH TEMP ALARM
FO-329983	10/19/2015	10/20/2015		RM 150 SMOKE SMELL, VISIBLE SMOKE WITHIN RM
FO-330563	10/20/2015		10/29/2015	6TH FL 670 TOO HOT
FO-330604	10/20/2015	10/21/2015		RM 150 TOO HOT
FO-330609	10/20/2015	10/20/2015		RM 189 TOO HOT
FO-330704	10/21/2015			WDET SMELLS SMOKE
FO-330706	10/21/2015	10/22/2015		RM 1111 CEILING LEAK
				SEE RESULTS
FO-330803	10/22/2015	10/22/2015		1ST FLR MENS RR (ONLY) THE ONLY STALL TOILET IS CON'T FLUSHING
FO-330805	10/22/2015	10/22/2015		INSIDE STE 110 DEAN'S OFC BATHROOM ONLY TOILET IS PLUGGED & OVERFLOWING
FO-330809	10/22/2015	10/23/2015		1ST FL WOMENS RM 2ND STALL TOILET CONTINUOUSLY FLUSHING
FO-330811	10/22/2015	10/26/2015		RM 6402.11 TOO HOT
FO-330874	10/23/2015			ROOF DOOR ALARM
FO-330975	10/26/2015	10/26/2015		5TH FL HALLWAY, EMERGENCY SHOWER IS LEAKING
FO-331093	10/27/2015	10/27/2015		STRONG GAS SMELL. 4TH FLOOR.
FO-331098	10/27/2015	10/27/2015		RM 134 DOOR LOCKED
FO-331101	10/27/2015	10/28/2015		RM 358 TOO COLD
FO-331257	10/28/2015	10/28/2015		RM 100 TOO HOT
FO-331261	10/28/2015	10/29/2015		5275 TOO HOT
FO-331262	10/28/2015	10/29/2015		TOO HOT. ROOM 5324.
FO-331264	10/28/2015	10/28/2015		A STRONG FOUL/SEWAGE SMELL BSMT LEVEL & 1ST FLR
FO-331266	10/28/2015	10/28/2015		BLDG IS TOO COLD
FO-331270	10/28/2015	10/28/2015		RM 14109.10 IS TOO HOT
FO-331276	10/28/2015	10/29/2015		RM 5463 TOO HOT
FO-331279	10/28/2015	10/29/2015		ENTIRE 8TH FLR LOW COLD WATER PRESSURE. (NOTE: FISH TKS ARE FED BY C.W.)
FO-331287	10/28/2015			Slight smell of natural gas around lab bench gas nozzle. Not enough to be a major issue but the researcher can smell it when he is working in front of it.
FO-331389	10/29/2015	10/29/2015		TOO WARM. SUB-BASEMENT.

WO	Recieved	Finished	Total	Request
FO-331399	10/29/2015			RM 134, PLEASE UNLOCK DOOR FOR MEDIA SERVICES
FO-331405	10/29/2015	10/29/2015		MAIN ENTRANCE DOOR NOT SECURING
FO-331410	10/29/2015			LAB 10 OIL LEAKING FROM HVAC SYSTEM
FO-331411	10/29/2015			LOBBY TOO COLD
FO-331472	10/30/2015			TOO HOT. ROOM 109.
FO-331473	10/30/2015			NO POWER IN WALL OUTLET. ROOM 489.
E - South			47	
FO-328512	10/1/2015	10/2/2015		Requesting engineer to adjust the temperature in room. It is too cold.
FO-328515	10/1/2015	10/1/2015		STE 2100 OUTLETS NOT WORKING, OUTLET SUPPORTING FAX AND MICROWAVE
FO-328526	10/1/2015	10/2/2015		TOO HOT. ROOM 324.
FO-328531	10/1/2015	10/5/2015		TOO HOT. LAB. 2177.
FO-328645	10/2/2015	10/5/2015		TOO HOT. ROOM 2177.
FO-328697	10/5/2015	10/5/2015		KEY WON'T OPEN DOOR. ROOM 416.1.
FO-328758	10/5/2015	10/5/2015		Emergency door in southeast corner of lab is chirping - battery needs to be replaced as soon as possible, as it disrupts students working in the lab.
FO-328737	10/5/2015	10/8/2015		The teaching lab is very hot and students are complaining that they cannot work in the room. Room 2039 also has the same complaints.
FO-329008	10/6/2015	10/7/2015		RM 1600 HAS AN ALARM SNDNG
FO-329009	10/6/2015	10/6/2015		RM 5178 IS TOO HOT
FO-329096	10/7/2015	10/7/2015		NO AIR CIRCULATION. ROOM 2142.
FO-329117	10/7/2015	10/14/2015		LAB 2177 TOO HOT
FO-329125	10/7/2015	10/7/2015		CIRCULATION DESK AREA 2 CUBICLES ARE W/OUT POWER PLS CK BREAKER
FO-329148	10/7/2015	10/19/2015		RM 2100 FRONT AREA NEAR RECEPTION DESK TOO COLD
FO-329200	10/8/2015	10/8/2015		ALARM PANEL IN RECEPTION AREA IN ALARM
FO-329220	10/8/2015	10/8/2015		Steam pipes are banging in office area.
FO-329300	10/9/2015	10/9/2015		Yifan Zhang has recently moved into this space temporarily. Since the space has been inactive for a long period of time, the air filters are very dirty. These need to be changed out ASAP due to the health issues related to the dirty filters.
FO-329379	10/12/2015	10/12/2015		RM 227 CK AIR PRESSURE W/IN RM CAUSING DOORS TO WHISTLE
FO-329383	10/12/2015	10/12/2015		BSMT RMS 242-247 HAS HI TEMPS
FO-329411	10/12/2015	10/12/2015		CALLED AGAIN SAYS HEAT IS APPROACHING 80degrees BSMT RMS 242-247 HAS HI TEMPS
FO-329417	10/12/2015	10/14/2015		RM 2177 IS TOO COLD
FO-329494	10/13/2015	10/14/2015		TOO HOT. ROOM 2177.
FO-329511	10/13/2015	10/14/2015		RM 4178 NO AIR, TOO HOT
FO-329530	10/13/2015	10/13/2015		CARBON MONOXIDE ALARM SOUNDING 888. ROOM 231.
FO-329614	10/14/2015	10/14/2015		RM 339 STRONG GAS SMELL
FO-329646	10/14/2015	10/14/2015		RM 1109 TOO HOT
FO-329728	10/15/2015	10/15/2015		Animal room temp is too cold without running space heater 24/7. Please raise temp to 72°F Please note this deficiency was noted on our recent inspection report.
FO-329729	10/15/2015	10/15/2015		Animal room is too hot. Please lower temp to 72°F.
FO-329734	10/15/2015	10/15/2015		South Stair Door open showing on silent alarm, couldn't reset with key. UGL Circulation Desk.
FO-329741	10/15/2015	10/16/2015		LAB 2177 TOO HOT
FO-329753	10/15/2015	10/16/2015		LAB 4178 TOO HOT
FO-329830	10/16/2015	10/27/2015		RM 1169 OUTLETS NOT WORKING
FO-329846	10/16/2015	10/19/2015		Two staff member in Dean's office reporting too much cold air coming out of overhead air vents, Etta and Karen. UGL Dean's office 3rd floor 3100.

WO	Recieved	Finished	Total	Request
FO-329951	10/19/2015	10/20/2015		ENTIRE 4TH FLR IS TOO COLD
FO-330668	10/21/2015	10/21/2015		LAB 10 TOO HOT
FO-330692	10/21/2015	10/22/2015		1ST FLR FAP IS SHOWING IN ERROR NOT NORMAL
FO-330792	10/22/2015	10/27/2015		RM 1169 OUTLETS NOT WORKING AGAIN
FO-330908	10/26/2015	10/26/2015		RM 113 TOO HOT, THERMOSTAT IS BROKEN
FO-330931	10/26/2015	10/27/2015		TOO HOT. ROOM 2177.
FO-331017	10/27/2015	10/27/2015		Requesting an engineer to come adjust the temperature in office 328.06 in the Prentis Building. The office is too hot.
FO-331071	10/27/2015	10/30/2015		RM 2177 IS TOO HOT
FO-331106	10/28/2015	10/28/2015		POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331108	10/28/2015	10/28/2015		POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331109	10/28/2015	10/28/2015		POWER OUTAGE. BUILDING. APPROX. 6:30 A.M.
FO-331192	10/28/2015	10/30/2015		LAB 4178 IS HAVING TEMPERATURE PROBLEMS WOULD LIKE RESOLVED PLS CALL/SEE DR. GREENBERG (75202) *SEE RESULTS*
FO-331205	10/28/2015	10/28/2015		FIRE TROUBLE ALARM.
FO-331220	10/28/2015	10/28/2015		WALL OUTLET IS NOT WORKING PROPERLY. OUTLET KEEPS BEEPING. ROOM 2159.1.
E - Southeast			30	
FO-328507	10/1/2015	10/1/2015		COLD AIR BLOWING VERY HARD. TOO COLD. ROOM 7908.
FO-328724	10/5/2015			SOUND OF RUNNING WATER IN CEILING IN ROOM 314.
FO-329042	10/6/2015	10/7/2015		RM 6307.6/CONF RM IS TOO COLD
FO-329238	10/8/2015	10/8/2015		CONFERENCE RM 6202 TOO COLD
FO-329292	10/9/2015	10/9/2015		PLEASE TURN HEAT OFF, ALSO LET AFTERNOON ENG KNOW NOT TO TURN HEAT ON
FO-329374	10/12/2015	10/12/2015		No air circulation again this morning (Mon. 10/12). Please reset HVAC system.
FO-329507	10/13/2015	10/13/2015		PLEASE UNLOCK CLASSROOM 0134
FO-329581	10/14/2015	10/14/2015		NEED DOOR UNLOCKED. ROOM 0134.
FO-329593	10/14/2015	10/14/2015		In the lobby (1st floor) there is a foul odor of sewage throughout.
FO-329725	10/15/2015	10/15/2015		DOOR IS LOCKED. ROOM 0134.
FO-329740	10/15/2015	10/15/2015		TOO COLD. BUILDING INCLUDING THE 2ND FLOOR.
FO-329744	10/15/2015	10/15/2015		BLDG TOO HOT
FO-329746	10/15/2015	10/15/2015		Low Humidity
FO-329795	10/16/2015	10/16/2015		14TH FL E. STAIRWELL DOOR ALARM
FO-329802	10/16/2015	10/30/2015		Controls -- Priority High Boiler has a bad relay Boiler will not start Controls engineer unable to troubleshoot Controls. Need special diagnostic equipment, Transferred to day shift AD for follow up.
FO-329894	10/19/2015			3RD FLR MENS RR (EITHER RM 305 OR 306) CLNG IS LKNG
FO-329904	10/19/2015	10/19/2015		2ND & 3RD FL TOO COLD
FO-329918	10/19/2015	10/19/2015		BLOWN FUSE. ROOM 105.
FO-329945	10/19/2015	10/19/2015		ENTIRE BLDG IS TOO COLD
FO-330541	10/20/2015	10/29/2015		Room needs to be negative pressure along with room 220.
FO-330545	10/20/2015	10/20/2015		RM 14110.2 STILL No air circulation SINCE 10/12/15 (please reset HVAC system.)
FO-330762	10/22/2015	10/22/2015		RM 105 IS EXTREMELY HOT
FO-330782	10/22/2015	10/22/2015		FAP ACTIVE FIRE TROUBLE ALARM
FO-330955	10/26/2015	10/27/2015		TOO HOT. ROOM 105.

WO	Recieved	Finished	Total	Request
FO-331067	10/27/2015	10/27/2015		RM 212 ACU IS STILL ON MAKING IT TOO COLD
FO-331318	10/29/2015	10/29/2015		TOO HOT. ROM 14109.1.
FO-331332	10/29/2015	10/29/2015		TOO COLD. ROOM 2218.
FO-331350	10/29/2015	10/29/2015		TOO COLD. ROOM 6305.3.
FO-331360	10/29/2015	10/29/2015		FREEZING COLD. ROOM 402.
FO-331429	10/30/2015	10/30/2015		WALL OUTLETS ARE NOT WORKING ON ONE SIDE OF OFFICE. ROOM 7908.
E - West			19	
FO-328618	10/2/2015	10/2/2015		FIRE TROUBLE ALARM.
FO-328714	10/5/2015	10/7/2015		General Lecture room 100 is always too cold. It is making it difficult for students (like myself) to come and pay attention to the lectures. It's not even winter yet and this room does not get warm. Thank you.
FO-329323	10/9/2015	10/9/2015		RM 185 CLNG LEAK IN FRONT OF PODIUM BELIEVE ITS COMING FROM LAB 285
FO-329648	10/14/2015	10/14/2015		RM 371 TOO HOT TEMP SHOULD BE 70
FO-329682	10/15/2015	10/16/2015		RM 1016 ELEC RM WITHIN, LOUD GRINDING NOISE COMING FROM RM
FO-329818	10/16/2015	10/16/2015		TOO COLD. ROOM 137.
FO-329931	10/19/2015	10/21/2015		Office is very cold; please check
FO-329933	10/19/2015	10/19/2015		Lab too cold
FO-329935	10/19/2015	10/19/2015		Lab too cold
FO-330529	10/20/2015	10/22/2015		2ND FL LUNCHROOM TOO HOT
FO-330544	10/20/2015	10/23/2015		RM 190 HAS A CLNG LEAK
FO-330560	10/20/2015	10/22/2015		TOO COLD. ROOMS 2100 AND 2108.
FO-330624	10/21/2015	10/21/2015		ENTIRE BLDG IS TOO HOT
FO-330639	10/21/2015	10/22/2015		RM 585 OUTLETS NOT WORKING
FO-331168	10/28/2015			WATER LEAK NEAR WINDOW - UNKNOWN WHERE IT IS COMING FROM. ROOM 1154
FO-331226	10/28/2015	10/28/2015		POWER BUMP APPR. 12:20
FO-331227	10/28/2015	10/29/2015		POWER BUMP APPR. 12:20
FO-331352	10/29/2015			RM 235 LEFT SIDE OF ROOM OUTLETS NOT WORKING
FO-331470	10/30/2015			POOL WATER LEVEL IS LOW. COMPETITION TONIGHT.
Medium			56	
E - Auxiliary			3	
H-55222	10/10/2015			The toilet is leaking.authenticated user: Xuecheng Yu - fl7209requester ip address: 35.16.73.204
H-55355	10/16/2015			there is an electrical problem in the bathroom. The lights flicker no matter what, i've tried changing the light bulb to two new ones but it still flickers.authenticated user: Rashd Alghamdi - fs0282requester ip address: 35.16.234.152
H-55357	10/17/2015			Lights are not working in half of the apartment. authenticated user: Keaira Stewart - fg9760requester ip address: 141.217.23.210
E - Command Center			40	
FO-328519	10/1/2015	10/2/2015		REFER-CREW PLEASE REPAIR FIRE DAMPER ROOM 107.2 MEDIUM PR ATT AUBREY WALLER
FO-326895	10/1/2015			A/C Shop; please replace heat pump 2-80. Compressor valves are bad. Existing unit is Mammoth: Model # G030HHA1 Recommended replacement unit: Carrier Model # 50PCH030ZCC6ACC1 (The configuration (Right return, left discharge) is in the Model Number) F
FO-328598	10/2/2015	10/7/2015		Trade: Command Center Priority: Medium Alarm (F005.02.ATC.ALM) will not reset. Please repair.
FO-328605	10/2/2015			Feedwater modulating valve is hunting as is fuel valve modulation control. Possible problem with level control sticking. See inspectors report.

WO	Recieved	Finished	Total	Request
FO-328637	10/2/2015	10/9/2015		BAS Section: please create links to S.O.O. on graphics pages for building mechanical equipment.
FO-328639	10/2/2015	10/2/2015		BAS Section: Please create S.O.O. links on graphics pages for building mechanical equipment.
FO-329138	10/7/2015			Control Engineer; Medium Please conduct a flue gas analysis on the two boilers at 5057 Woodward and the one boiler at 5035 Woodward.
FO-329142	10/7/2015	10/12/2015		BAS section: please troubleshoot EF4a/b start/proof issues. Exhaust fans are in alarm.
FO-329143	10/7/2015	10/14/2015		trade siemens controls please service staff office room 2142 has very little air flow in this office vav 9-7 vav9-8 vav9-9
FO-329244	10/8/2015	10/9/2015		Boiler will not start. Controls cabinet got wet.
FO-329246	10/8/2015	10/23/2015		Boiler smokes a little on low fire.
FO-329340	10/10/2015	10/15/2015		Restore Siemens panel to service at Reuther Library. There is no communication to the network.
FO-329468	10/12/2015	10/13/2015		Boiler not working - Fresh Air Dampers wont open.
FO-329358	10/12/2015	10/12/2015		Boiler Levelmaster not working
FO-329469	10/13/2015	10/15/2015		Trade: Controls/Siemens Priority: Medium UGL air handlers econ mode is off and the outside air temp is 55, I had to set the econ mode to on at Operator Priority on each fan. Please look into what temp econ mode is triggered and make sure it is operationa
FO-329505	10/13/2015	10/14/2015		COMMAND CTR, PLEASE ADD PROGRAMMING TO THE HEAT PUMP LOOP SO THAT THE COOLING TOWER PUMP WILL CYCLE OFF WHEN LOOP TEMP REACHES 70 DEGS. PRIORITY-MEDIUM
FO-329571	10/14/2015	10/14/2015		Trade: Controls Priority: Medium Chiller won't shut off when O.A temp in mid 40s. At night building gets to cold with chiller ON.
FO-329605	10/14/2015	10/15/2015		Boiler #1 trips on low fire.
FO-329647	10/14/2015	10/15/2015		Controls repair reheat for animal room AF-16.
FO-329667	10/15/2015	10/15/2015		Boiler not firing
FO-329908	10/19/2015			Controls BAS Med priority R/R RM 00027/MECH RM Heat exchanger over heating Valve 1 at 15 psi valve 2 at 0 psi. Set point 135 DT 227. Also please switch pump rotation so #1 is odd And #2 even
FO-329957	10/19/2015	10/21/2015		Perform Flue gas analysis on boiler #1.
FO-329958	10/19/2015	10/30/2015		Perform Flue gas analysis on boiler #2.
FO-330533	10/20/2015	10/27/2015		Calibrate spence valve to Siemens controls.
FO-330616	10/21/2015			COMMAND CTR, R/R RM 00495/NEW BLR RM PLEASE PERFORM A FLU GAS ANALYSIS ON #2 BOILER. PRIORITY-MEDIUM
FO-330631	10/21/2015	10/27/2015		Control Med Priority R/R RM 00055/MECH RM Replace diaphragm on 8-13# steam valve on #1 AHU
FO-330632	10/21/2015	10/27/2015		Controls Med Priority R/R RM 00055/MECH RM Replace Powers steam valve diaphragm on AHU #1. Valve is marked 8-13#
FO-330642	10/21/2015	10/28/2015		Controls group, R/R RM 00087.02/MECH RM adjust the combustion fuel/ air ratio on No. 1 boiler priority medium
FO-330643	10/21/2015			controls group, R/R RM 00187.01/MECH RM adjust the fuel/air ratio on the burner of # 2 boiler priority medium
FO-330656	10/21/2015			check ahu 2 for proper charge
FO-330830	10/23/2015	10/26/2015		trade siemens controls priority medium R/R RN 530/MECH RM please service heating hot water pump control panel pump will not run in auto mode only in hand position tec panel
FO-330903	10/26/2015			BAS section please repair/replace failed mixed air sensor on ahu #1
FO-330905	10/26/2015	10/30/2015		please readjust feedwater regulating valve on boiler #2 still leaking through (Aubrey)

WO	Recieved	Finished	Total	Request
FO-330910	10/26/2015			Controls Med. Priority Replace Hankison air dryer on building air compressor E end of mechanical rm.NOP. Model # HPR 15
FO-330947	10/26/2015	10/27/2015		COMMAND CTR, PLEASE CREATE AN OUTSIDE AIR COOLING ENABLE SETPOINT ON THE GRAPHICS FOR MECH COOLING. PRIORITY-MEDIUM
FO-331058	10/27/2015			Refrigeration / controls group, R/R ROOF repair the unit AHU #3 it does not heat priority medium
FO-331158	10/28/2015			Command Center, Medium; R/R RM 00322 Suspect bad heating control valve room 322. Repair or replace as necessary.
FO-331171	10/28/2015	10/29/2015		Command; Medium; R/R Room 321 stat in operator override, Why? Occupant not comfortable with assigned temp.
FO-331326	10/29/2015			REFER SHOP: R/R ROOF Please repair ACU #16 (elevator room AC Unit) on roof near cooling towers. MED.
FO-331378	10/29/2015			HONEYWELL: R/R Room 4210 Please repair/replace VAV for converted Freezer Room. MED.
E - MedPharm			4	
FO-328530	10/1/2015			Door will not open with key. This is a storage room so it is not an emergency.
FO-328712	10/5/2015	10/7/2015		LIGHT IS NOT COMING ON. PLEASE CHECK. ROOM 2352.
FO-329224	10/8/2015			The outlet number MS-038-2, MS-045-1 and MS-036-5 on the front desks of the auditorium don't work. If they could be fixed that would be fantastic!
FO-329493	10/13/2015	10/14/2015		air pressure too low to run machine used to sterilize instruments. Need it looked at asap. Instruments needed for surgeries
E - Northeast			1	
FO-328705	10/5/2015	10/29/2015		Please repair leaking control valve on unit heater, located above ceiling. Room 324.
E - Preventative Maintenance			6	
FO-328769	10/5/2015	10/5/2015		ENTIRE BLDG TOO HOT
FO-329853	10/16/2015	10/20/2015		Lower light on the front left side of the auditorium is flashing and making a loud noise.
FO-329978	10/19/2015	10/20/2015		Office is extremely cold
FO-331283	10/28/2015	10/29/2015		Emergency exit by the museum room 123, first floor- alarm is not sounding
FO-331407	10/29/2015			Building recirculating chill water system is too warm.
FO-331409	10/29/2015			Circuit of the projector in the ceiling is not working. Please send engineer to assess the issue. Please contact Richard Lerman at 7-1624 for further details.
E - West			2	
FO-329636	10/14/2015			Repair/replace broken knob on exhaust fan....This is the second request. Please check with T. Woods/Bob Ostrowski at the football Stadium.
FO-329932	10/19/2015	10/19/2015		Lab too cold; 66 degrees
Low			267	
E - Area 1 Engineer			2	
FO-329906	10/19/2015			All staff on east end of the third floor are cold, temps reading low 60s.
FO-330822	10/23/2015			Very chilly on the 3rd floor, East end of building. Feels like the air or maybe chillers are on. Very cool breeze.
E - Auxiliary			126	
H-55049	10/1/2015	10/1/2015	10/12/2015	Ashley Hepp 10/12/2015 10:57 - Electrical panel behind front desk will not stop going off. Showing that WSUPD has been called, they were not notified. Showing emergencies on the 5th and 9th floor--no emergencies happened. Engineer took a look and said t
H-55056	10/1/2015			Please change the ballasts in the hallway lights outside if 616 and 625.
H-55066	10/1/2015	10/2/2015	10/9/2015	Ashley Hepp 10/09/2015 14:21 - Engineering Check - DR 318 authenticated user: Charles Ringer - fz6340 requester ip address: 141.217.23.228

WO	Recieved	Finished	Total	Request
H-55071	10/1/2015			Hi, the air conditioning or heating in the first two rooms (near the entrance) do not work properly. The first room (closest to the entrance) receives majority of the cool air or in the winter the heat, and the second room receives very little. It has a
H-55062	10/1/2015	10/8/2015	10/9/2015	Ashley Hepp 10/09/2015 14:30 - Vacant Apartment, Mechanical Check - CT 509 authenticated user: Charles Ringer - fz6340 requester ip address: 141.217.23.228
H-55073	10/2/2015			The exhaust in the smaller washroom is not working.authenticated user: Mehnaz Hussain - fs4098requester ip address: 35.16.231.221
H-55070	10/2/2015			Kitchen faucet is loose.
H-55120	10/2/2015			the faucet in the kitchen leaking when you open it. It can not be totally turned off with no water dripping. Thank you. authenticated user: Xiaoyang Li - fp6057requester ip address: 146.9.242.142
H-55076	10/2/2015	10/2/2015	10/12/2015	Ashley Hepp 10/12/2015 11:00 - There is a leaky shower in Towers room 505 authenticated user: Xiantria Nichols - ez5268 requester ip address: 141.217.23.237
H-55108	10/2/2015			The garbage disposal isn't working and a nasty smell is coming out of the sink. Please come as soon as possible.authenticated user: Mossab Qatu - fk8100requester ip address: 35.16.230.221
H-55107	10/3/2015			Leaking toilet, lots of water.authenticated user: Sara Rashid - ez4253requester ip address: 35.16.70.2
H-55119	10/3/2015			hello, InSinkErator is not working in our kitcheni would like to request immediate assistance.authenticated user: Varun Kandukuri - fl9707requester ip address: 141.217.203.132
H-55090	10/3/2015			The room didn't come with a dresser with 3 drawers. Was wondering if I could get one.authenticated user: Julianne Meiu - fq5909requester ip address: 35.16.100.111
H-55115	10/3/2015	10/5/2015	10/12/2015	Ashley Hepp 10/12/2015 13:32 - Our toilet flush is not working properly authenticated user: Baldish Oberoi - fq4552 requester ip address: 35.16.71.127
H-55097	10/4/2015	10/5/2015	10/12/2015	Ashley Hepp 10/12/2015 11:04 - At 5:15pm, Towers Cafe Supervisor Jessica came to the Front Desk at Towers Residential Suites to let us know about the ventilation above the grill not working. RA on duty Sherell House called for engineers. Building Engine
H-55085	10/5/2015	10/8/2015	10/9/2015	Ashley Hepp 10/09/2015 14:30 - Lights in kitchen do not work. It takes them 20 mins to turn on after switching on the switch authenticated user: Nivedita Singh - fg4751 requester ip address: 141.217.233.247
H-55094	10/5/2015	10/6/2015	10/12/2015	Ashley Hepp 10/12/2015 11:11 - Leaking shower head. authenticated user: Beth Mcpherson - fw6020 requester ip address: 35.16.105.40
H-55106	10/5/2015			Disposal and drain leakingauthenticated user: Daniel Ferkovich - ev3614requester ip address: 141.217.221.195
H-55125	10/5/2015			The AC has broke down for the second time in a row. Please send someone to fix it and make sure it is okay. authenticated user: Mahmoud El-Ahdan - fz6031requester ip address: 35.16.96.128
H-55142	10/5/2015			Toilet in second bathroom never stops running after being flushedauthenticated user: Kaylin Braekevelt - ee9400requester ip address: 35.16.70.83
H-55137	10/5/2015			Electric switchboard problem.It is broken.Risky to deal with.authenticated user: Tejaskumar Patil - fq4478requester ip address: 141.217.220.232
H-55139	10/5/2015			Smoke detector is not workingauthenticated user: Tejaskumar Patil - fq4478requester ip address: 141.217.220.232
H-55141	10/5/2015			Bathroom flush tank has a crack.authenticated user: Tejaskumar Patil - fq4478requester ip address: 141.217.220.232
H-55129	10/5/2015	10/12/2015	10/12/2015	Shower was constantly running even when off, causing a small flood. Engineer shut off water, but issue is not resolved. authenticated user: Dijon Williams - fk3806 requester ip address: 35.16.108.79
H-55136	10/6/2015			Our garbage disposal is not working anymore and the water drains very slowly.authenticated user: Mukund Mohan - fh1768requester ip address: 35.16.78.211

WO	Recieved	Finished	Total	Request
H-55149	10/6/2015	10/6/2015	10/12/2015	Ashley Hepp 10/12/2015 11:08 - Towers suite 1024 green water is coming out of the faucet sink closet to the toilet.
H-55151	10/6/2015	10/7/2015	10/9/2015	Ashley Hepp 10/09/2015 14:24 - The Garbage disposal does not work. When turned on, it makes a quiet buzzing sound. It has been this way since yesterday (October 5th). Problem happened randomly. authenticated user: Vivien Okechukwu - fh2758 requester i
H-55169	10/6/2015			light and exhaust fan above the stove are not workingauthenticated user: Naveen Battina - ft5891requester ip address: 141.217.173.132
H-55165	10/6/2015	10/7/2015	10/9/2015	Ashley Hepp 10/09/2015 14:23 - i tried changing my sink faucet washer so i could put in a filter for the water, and now i cant get the washer head off the faucet to put the old one back on. it may need a wrench to get it off. authenticated user: Nadee
H-55153	10/6/2015			Garbage disposal is broken and leaking.
FO-329092	10/7/2015	10/7/2015		TOWERS CAFE KITCHEN GARBAGE DISPOSAL ISN'T WRKNG
H-55180	10/7/2015			thermostat and air/heat system stopped working authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.225
H-55179	10/7/2015			AC is broken. When ever thermostat is turned on it blows heat past 85 degrees authenticated user: Terrence Reese - fs5837requester ip address: 35.16.99.34
H-55206	10/7/2015			Need someone to come in and fix the in-sink erator in apartment 318 in University Tower. it appears to be blocked and whenever water goes into it it just fills up and eventually drains over a period of about a week. The in-sink erator has also stopped
H-55195	10/7/2015			Toilet tank takes a lot of time.to refill itself even when the knob is open. And the toilet clogs way too oftenauthenticated user: Ankita Ghosh - fp9957requester ip address: 172.56.11.42
H-55188	10/8/2015			TV isn't working anymore.Maybe the plug is faulty. This happened the day they pulled some cables out of the ground. Please report issue to Angelica if you are unable to resolve it.authenticated user: Lofti Kerzabi - fo8196requester ip address: 141.217.
H-55192	10/8/2015			Exhaust fan in the washroom is not working. Please fix it as soon as possible.authenticated user: Priyadarshan Karandikar - fx2192requester ip address: 141.217.221.241
H-55194	10/8/2015			Shower in the bathroom is not working properly. Please fix it asap.authenticated user: Priyadarshan Karandikar - fx2192requester ip address: 141.217.221.241
H-55208	10/8/2015			The stairwell A light ballast needs replacement.authenticated user: Briana Collins - ez6508requester ip address: 141.217.23.210
H-55201	10/8/2015			Bathroom sink has a constant drip.authenticated user: Abigail Landskroener - fk9925requester ip address: 141.217.23.243
H-55202	10/8/2015			In the hallway by this room, can light above bench seat bulbs been changed still not working. authenticated user: Abigail Landskroener - fk9925requester ip address: 141.217.23.243
H-55216	10/10/2015			My AC is not working from two weeks I submitted a complaint, my roommate submitted a complaint, but no cared to come and fix it. I request immediate maintenance. authenticated user: Mahmoud El-Ahdan - fz6031requester ip address: 35.16.100.163
H-55231	10/10/2015			in-sink erator not workingauthenticated user: Yijing Huang - fs8070requester ip address: 35.16.77.140
H-55229	10/11/2015			sockets in the second bed room not workingauthenticated user: Tulasi Priya Gudapati - ft7865requester ip address: 35.16.237.190
H-55220	10/11/2015			ENGINEERING--Please troubleshoot HVAC system in room 238. Backflushed h. pump, then replaced it twice on 10/11. Also replaced thermostat and checked programming. The compressor will not start at all. Wanted to take off thermostat and re-check wiring,
H-55266	10/12/2015			A water drinking glass has been gone inside the sink and has blocked the sink.We tried removing it out but it dint come out.authenticated user: Saurabh Chandorkar - fx3979requester ip address: 35.16.236.194
H-55264	10/12/2015			The sockets in the last corner room doesn't work properly.authenticated user: Shruthi Balajiga - fk1770requester ip address: 198.208.159.17
H-55267	10/12/2015			bathroom water is coming from the base of toilet authenticated user: - requester ip address: 141.217.23.194
H-55255	10/12/2015			Air conditioning is broken: we've had it set to 65 for a couple days and it hasn't cooled off (stuck at 78)... there is also a red light on the bottom that is onauthenticated user: Samantha Guerra - fv5692requester ip address: 35.16.108.61

WO	Recieved	Finished	Total	Request
H-55261	10/13/2015			There is a power failure in my apartment. This is the second time it happened in this month. I am in a huge inconvenience due to this. please do response at your earliest convenience. authenticated user: Madusha Lakshani Watuthanthrige Perera - fp1089re
H-55269	10/13/2015			Our Air Conditioning has not been working for about a week, and although it blows air it is not cold air, and would like to have it repaired authenticated user: Donovan Paige - fv5248 requester ip address: 35.16.100.198
H-55262	10/13/2015			Someone came to look at out kitchen light that doesnt work anymore and they said they would send an engineer to replace it - they came last tuesday and no one has come yet to replace it authenticated user: Ahila Manivannan - fj0752 requester ip address: 3
H-55260	10/13/2015			Hello,The sink's incinerator is not working.Thanks authenticated user: Rodrigo Lisboa Della Rovere - ft3036 requester ip address: 35.16.235.185
H-55293	10/13/2015			hi my previous work order is not yet done and you have submitted a work done mail to me. H-55135. you came and checked it out. the sink is leaking and the drainer is not changed yet. you said the engineer will come in 2 days time and get it done. but its
H-55302	10/13/2015			Pipes under sink are broken; flooding under the sink. Also, leaky faucet authenticated user: Hiba Jawadi - ef1433 requester ip address: 146.9.241.206
H-55290	10/14/2015			Air conditioning in room is not working. authenticated user: Dijon Williams - fk3806 requester ip address: 141.217.23.187
H-55321	10/14/2015			Shower leakage in bathroom#1 authenticated user: Krishnaraj Udayachalam - fl8319 requester ip address: 35.16.75.233
H-55300	10/14/2015			the tap in the kitchen leaks water. Two blinds of the shade in the living room is broken. authenticated user: Qing Ai - fx6090 requester ip address: 35.16.234.149
H-55320	10/14/2015			Rotten smell out of the AC vent when the AC is turned on in the room. This issue is in the room with the separate AC controller. Kindly attend to this asap. authenticated user: Anisha-Suresh Bhat - fs1622 requester ip address: 12.176.249.232
H-55314	10/14/2015			Our shower is making loud rattling noises when turned on. The water is usually extremely hot or extremely cold, there is no in between. authenticated user: Unavailable Unavailable - fo7193 requester ip address: 35.16.76.232
H-55318	10/14/2015			water does not stop flushing in the toilet. also water keeps dripping from the kitchen sink. authenticated user: Vedika Sandesh Jadkar - fx7755 requester ip address: 35.16.233.254
H-55317	10/14/2015			Waste disposal is not working. authenticated user: Ammaar Wattoo - fr2036 requester ip address: 141.217.220.206
H-55312	10/14/2015			Fix air in room. The unit itself works it's just always stuffy in the room. The filter or vent may need to be cleaned and changed. authenticated user: Thomas Wolf - fj0736 requester ip address: 35.16.103.60
H-55313	10/14/2015			AC not working well authenticated user: Marina Mikhail - fv2548 requester ip address: 141.217.230.173
H-55319	10/15/2015			1- The fan filter above the stove needs to be replaced. It is so dirty. 2- Electrical outlets next to the stove don't work. authenticated user: Lea Yazigi - eh2382 requester ip address: 35.16.235.169
H-55316	10/15/2015			Heater is not working authenticated user: Veena Bhavsar - fh9538 requester ip address: 141.217.220.226
H-55367	10/15/2015			Change of Air vent filter and new screw holes. Previously screwed into drywall, in which the holes dont stick. In addition, the filter is very dirty. authenticated user: Patrick Lai - fm3614 requester ip address: 141.217.221.144
H-55324	10/15/2015			HELP! The heat's not working in my room. It was at 58 degrees today when I woke up. Thank you! authenticated user: Jiwanjot Gill - ey8620 requester ip address: 141.217.230.141
H-55339	10/15/2015			Our thermostat is broken. There is a red light showing on the bottom. authenticated user: Nicholas Campbell - fl7564 requester ip address: 141.217.224.180
H-55369	10/15/2015			One of the plug sockets in the kitchen is broken. It is on the right of the stove which the toaster is plugged into. authenticated user: Saad Alshahrani - fp4858 requester ip address: 35.16.65.193
H-55334	10/15/2015			one light above board is out, replaced bulb and it's still not working. Maintenance authenticated user: Abigail Landskroener - fk9925 requester ip address: 141.217.23.227

WO	Recieved	Finished	Total	Request
H-55336	10/15/2015			Hot water pressure needs fixing in back room authenticated user: Dijon Williams - fk3806 requester ip address: 141.217.23.187
H-55337	10/15/2015			Behind bar, pipes are leaking. authenticated user: Dijon Williams - fk3806 requester ip address: 141.217.23.187
H-55354	10/16/2015			A fuse bust in the apartment. Only half of the apartment's lights are working. authenticated user: Danielle Henry - ew4467requester ip address: 35.16.66.160
H-55373	10/16/2015			In sinker is not working properly, it stopped sucking water and motor got jammed.authenticated user: Gayatri Praneeth Inakollu - fw6601requester ip address: 35.16.76.57
H-55374	10/17/2015			In sinknator not working. It's kind of urgent, water is not draining. Stinking...authenticated user: Akash Jadhav - ft0828requester ip address: 35.16.73.102
H-55375	10/17/2015			The heater is keep blowing hot air even though it is off. the apartment is hot and I can not sleep even with the windows open. authenticated user: Areeg Zuair - fe5804requester ip address: 35.16.70.252
H-55347	10/18/2015			Hot water is leaking from heater in the bedroomauthenticated user: Najeeb Arafat Mohammed - fr9153requester ip address: 141.217.23.216
H-55348	10/18/2015			please replace blown fuse in kitchen.authenticated user: Holly Cox - ez9047requester ip address: 141.217.233.19
H-55378	10/18/2015			Plug port at kitchen (right side of the sink) not working. authenticated user: Vignesh Muthukumar - fq6173requester ip address: 141.217.220.150
H-55380	10/18/2015			The garbage disposal is clogged.authenticated user: Anne Briand - es0317requester ip address: 35.16.79.182
H-55381	10/19/2015			We have a big issue in the bathroom .There is water leaking heavily from the ceiling and we are not able to use it please do fix it urgentlyauthenticated user: Jayanth Reddy Donthireddy - fs6740requester ip address: 166.170.24.145
H-55351	10/19/2015			Radiator in bathroom leaks black water onto the floor underneath the open/close knob. It is also incredibly hot and hisses very loudly, despite being turned all the way closed. Heat/noise isn't a problem, but the black sludge is. authenticated user: Chri
H-55383	10/19/2015			Greetings.The IN-SINK ERATOR (ISE DISPOSER) stopped working.Please have it fixed at the earliest.Thank you very much in advance.authenticated user: Srinivas Bondada - fr9008requester ip address: 35.16.77.160
H-55388	10/19/2015			There is some problem on shower head (in our bigger restroom). Either hot water or cold water come out, no warm water..authenticated user: Ying Li - fq7863requester ip address: 35.16.82.208
H-55407	10/19/2015			The radiators in my living room and bathroom cannot be turned off. The knob is not turning to the off position. This is making my apartment extremely warm and uncomfortable even with 3 fans on. I also cannot turn on the AC to help as it causes the power t
H-55403	10/19/2015			512-514 Lights above the door are outauthenticated user: Timothy Hiemstra - fw2596requester ip address: 141.217.23.203
H-55416	10/19/2015			The exhaust in the bathroom is not working, and we feel there is an odd odour emitting from the place, like that of something burnt. authenticated user: Adrian Fernando - fr1645requester ip address: 35.16.78.152
H-55397	10/19/2015			Smoke detector goes off for shower steam ONLY but for nothing else.authenticated user: Jasmine Kendrick - eu6470requester ip address: 141.217.23.210
H-55417	10/19/2015			cleaning of AC inlet and outlets required.authenticated user: Sriharsha Bandi - fs1353requester ip address: 35.16.65.70
H-55412	10/20/2015			the garbage disposal is brokenauthenticated user: Emily Maraskine - fh5687requester ip address: 35.16.74.113
H-55414	10/20/2015			Bathroom Flush Tank.authenticated user: Afzanuddin Syed - fx8793requester ip address: 35.16.65.181
H-55410	10/20/2015			Towers Cafe - garbage disposal not working.
H-55421	10/20/2015			Light fixture in kitchen is bad due to water damage and needs to be replaced.authenticated user: Manaswini Remidi - fs2524requester ip address: 141.217.23.210
H-55428	10/20/2015			The sink behind the bar is leaking. authenticated user: Marcus Beeler - fi1640 requester ip address: 141.217.23.187
H-55450	10/21/2015			The heat in our room isn't working. Every time we turn it on, cold air just blows out.authenticated user: Anna Bagnall - fo1173requester ip address: 35.16.103.92

WO	Recieved	Finished	Total	Request
H-55452	10/21/2015			Resident says that water is coming out of faucet in kitchen very slowly. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210
H-55439	10/21/2015			Towers 828 (Ahmad Baiyas fp5605). AC will not work 3 engineers have attempted to fix but no one is able to fix it. It is still unattended to. Resident has been without working unit for approximately 3 weeks.
H-55454	10/21/2015			Hot water in bathroom tub is not turning off. authenticated user: Tamika Davis - eq2532requester ip address: 141.217.23.210
H-55461	10/22/2015			Garbage disposal is backed up and under the sink is leaking water. authenticated user: Morgan Sawgle - fo9425requester ip address: 35.16.67.216
H-55479	10/23/2015			Hello wonderful staff! I need help with my heating and cooling system within my room, which is a concern to me especially since cold weather is approaching and the temperature fluctuates throughout the day. This is similar to the issue that happened at th
H-55478	10/23/2015			A/C doesn't work for the 5th time authenticated user: Dexter Wilson - fo0650requester ip address: 35.16.99.59
FO-330820	10/23/2015	10/28/2015		R/R 12TH FLR Cooling tower fan has blown a fuse. Procuring replacement fuses from stockroom.
H-55474	10/23/2015			Fire alarm panel indicated that smoke detector in 1201 is dirty. Please clear smoke detector and reset fire alarm system if needed. Thank you!authenticated user: Angelica Reyna - ag8310requester ip address: 141.217.23.215
H-55475	10/23/2015			MECHANICAL CHECK authenticated user: Rahul Reddy Kandi - fs2308requester ip address: 141.217.23.210
H-55483	10/23/2015			The air conditioning not is working. The temperature in my room is very very high! I can't sleep, I can't stay inside my room. Please, fix as soon as possible.authenticated user: Lais lara Martins - fs8516requester ip address: 35.16.99.239
FO-330866	10/23/2015			CAFETERIAS' KITCHEN CONVEYOR BELT IS BROKEN
H-55487	10/26/2015			The toilet flush does not work properly. The water stays very low in the seat and one has to run the flush twice or hold it for 10-15 seconds for proper flushing!authenticated user: Shreyans Kothari - fk2814requester ip address: 35.16.72.239
H-55515	10/26/2015			The heater and A/C are not working. Nothing happens when either one is turned on.authenticated user: Alexandra D'Abreu-Hines - fp0908requester ip address: 35.16.107.78
H-55520	10/26/2015			Resident's sink dispenser will not power on/workauthenticated user: Elijah Baker - fh0812requester ip address: 141.217.23.210
H-55526	10/26/2015			The shower in the far bathroom will not turn on. The water does not come out of the shower in the very last bathroom.authenticated user: Sara Ruhstorfer - fo3089requester ip address: 35.16.65.85
H-55536	10/27/2015			Air filter needs to be replaced in the the room. authenticated user: Amanda Funk - fi7020 requester ip address: 141.217.23.187
H-55550	10/27/2015			The exhaust fan in the first washroom(smaller washroom) is not working and when turned on it gives burnt smell all over. I have already complained this 3 weeks before and no action is taken. I really hope this would be fixed soon.authenticated user: Mehn
H-55576	10/27/2015			The Ceiling Light holder in the bed room is not working. Tried swapping the light bulb to another light source and it works fine. Tried a known good light bulb on this bulb holder - it does not work.. Please help by fixing this issue ASAP. Thanksauthent
H-55571	10/28/2015			The men's bathroom in the DeRoy lobby has a nonfunctional toilet.authenticated user: Peter Dolnicek - eo7549requester ip address: 141.217.23.210
H-55572	10/28/2015			Darlene White, of appt 611, has little to no water pressure in her bathroom sink and shower.authenticated user: Peter Dolnicek - eo7549requester ip address: 141.217.23.210
H-55573	10/28/2015			There is a leak in the ceiling that was raining through yesterday. It's by the window furthest to the wall right by the desk. There was a lot of water coming from the ceiling and on the window seal. It was dripping onto the outlet. I unplugged the outlet
H-55559	10/28/2015			Thermostat is broken and it does not display anything authenticated user: Hope-Zenobia Adams - fw6174requester ip address: 35.16.100.205
H-55567	10/28/2015			Heat is no longer working, needs attention.authenticated user: Christopher Ozog - fi3944requester ip address: 141.217.230.141
H-55574	10/29/2015			broken toilet. any time the toilet is flushed, water sprays from the tank. authenticated user: Jessica Weaver - fi2693requester ip address: 35.16.64.121
H-55561	10/29/2015			Change air filter in roomauthenticated user: Nicole Witzleben - fh2191requester ip address: 141.217.225.11

WO	Recieved	Finished	Total	Request
H-55578	10/29/2015			The knob of living room heater is broken. Therefore there is no heating at allauthenticated user: Zahabiya Husain - ec5075requester ip address: 141.217.232.76
H-55591	10/29/2015			Mechanical Checkauthenticated user: Najeeb Arafat Mohammed - fr9153requester ip address: 141.217.23.210
H-55590	10/29/2015			mechanical Checkauthenticated user: Najeeb Arafat Mohammed - fr9153requester ip address: 141.217.23.210
H-55598	10/29/2015			The air conditioning (cooling system) will not turn on in our room. The temperature is stuck at 74 degrees and will not come down. authenticated user: Rylee George - fw3470requester ip address: 35.16.101.110
H-55603	10/29/2015			The shower head detached and it needs to be tighten. authenticated user: Nicole Fry - eq0918 requester ip address: 141.217.23.187
E - Command Center			43	
FO-320527	10/1/2015			Please replace Heat Pump 2-139. Unit is down. Suggested replacement unit; Carrier, Model #50PCV030BCC6ACC1 480v 3ph. Right Return Top Discharge. (this unit is vertical)
FO-321271	10/1/2015			A/C Controls please troubleshoot Titus mixing box blowing continuous cold air.
FO-320557	10/1/2015			Please replace Loading dock heat Pump. Unit is down. Suggested replacement unit (Larger size; Carrier, Model #50PVC042RCCEACC1 208/230 3ph. Left Return Top Discharge. Also, Replacement unit will require sheet metal & piping rework.
FO-314191	10/1/2015	10/26/2015		Replace faulty thermostat serving the vestibule/lobby entrance heater, (Trane), located at Law Library near entrance door 053-23-E. The heater runs continuously regardless of the room temperature and only appears to shut off on aquastat.
FO-328613	10/2/2015	10/7/2015		To refrigeration shop. Please assist in correcting following problems with Music boiler controls. Blr. 1- Will not cycle on when called for has lead boiler. Blr. 2- Will not recognize remote signal from PI panel. Operates under local boiler controls. P
FO-328614	10/2/2015	10/2/2015		BAS section: please create S.O.O links on graphics pages for all major equipment in bldg. (ahu 1-3 and chiller/boiler plant).
FO-328662	10/4/2015	10/5/2015		Adjust operation schedule for air handlers at Education building to run fans the following hours: 6 am to 6 p.m. on Saturdays off on Sundays Also, change the schedule report to show the current day. As it is now, you can only see the following 7 da
FO-328726	10/5/2015			BAS Section: Adjust PPCL for unocc operation for all AHUs. Tune LOOP responses.
FO-328759	10/5/2015			BAS Section: Please investigate LTD and SMK point alarms and issue with clearing alarms on AHU.
FO-329023	10/6/2015	10/7/2015		trade siemens controls priority medium R/R RM 2529/STUDY RM please service vav box uv49 air flow is low in this area min air flow .
FO-329149	10/7/2015	10/13/2015		State Hall - Valve Diaphragms Siemens Part #599-01093 - Valve Diaphragm Qty: 5 Siemens Part #331-4511 - Valve Diaphragm Qty: 5 Honeywell Part #313745 - Valve Diaphragm Qty: 10
FO-329225	10/8/2015	10/8/2015		HONEYWELL R/R BLDG Engineer order Honeywell thermostat parts.
FO-329245	10/8/2015	10/12/2015		Trade: Controls Priority: Low R/R Lab 1540 is still in negative pressure, Jason from Siemens just replaced a fast acting damper control on supply box. The volume differential set point is 48cfm and the actual volume difference is 828cfm. The supply dam
FO-329256	10/8/2015	10/13/2015		Trade: Command Center Priority: Medium R/R RM 2027 Please supply one Honeywell thermostat: TP970A 2004. Parts are needed for FO 329737.

WO	Recieved	Finished	Total	Request
FO-329263	10/9/2015	10/15/2015		BAS Section: Please troubleshoot BLR room field panel: panel is intermittently losing communication.
FO-329314	10/9/2015	10/12/2015		A/C Controls, R/R PENTHOUSE Chillers need program changes. The lead chiller will run even if outside air temperature is below 50 degrees. The
FO-329316	10/9/2015	10/15/2015		A/C Controls, R/R 4TH FLR please trend humidity in DLAR. There are wide swings between the high and low humidity in the animal rooms (461, 463, 467, 468, 469, 470, 471, 472, 474).
FO-329317	10/9/2015	10/12/2015		A/C Controls, R/R PENTHOUSE please program main Insight homepage screen to show Air handlers down on freeze stat Spoke to Engineer: Found that problem is that home screen 'Fan' button does not flash when a unit trips on freeze stat. Engineer also in
FO-329318	10/9/2015	10/12/2015		A/C Controls, R/R RM 465 please troubleshoot Room 465 stat (LAN.10.CAV.1.17) shows 95 degrees on the graphics, but the actual temperature is 72 degrees on the stat in the room.
FO-329339	10/10/2015	10/12/2015		Please provide a link on Insight to the building operating schedule for Fitness Center.
FO-329357	10/12/2015	10/12/2015		Seimens BAS R/R Please set up my user account
FO-329376	10/12/2015			Trade: Controls/Siemens Priority: Low R/R PENTHOUSE The outside air temperature sensor is reading 67 and the actual temp is 62, could you install a new sensor.
FO-329378	10/12/2015	10/19/2015		BAS- R/R RM 150 COMMAND CTR Create a Air Handler overview graphic for Lande Building
FO-329418	10/12/2015	10/13/2015		Controls, R/R PENTHOUSE install lead/lag for exhaust fans EF-5A
FO-329419	10/12/2015	10/13/2015		Controls, R/R PENTHOUSE install lead/lag for exhaust fans EF-5B
FO-329450	10/13/2015	10/14/2015		Trade: Siemens Priority: Low On the chiller graphic it shows O.A. Cooling Enable set point but it does not show the point that it turns on to start the chiller. Please put this point on the graphic. Also what is the dead band to turn off this point.
FO-329452	10/13/2015	10/14/2015		Controls Please check Medical Commons and run a report for Seimens equipment to see if any equipment is on a schedule.
FO-329504	10/13/2015	10/14/2015		COMMAND CTR, PLEASE ADD CHILLER PROGRAMMING SO THAT A 2ND CHILLER DOES NOT START UNLESS ITS SEES 80 DEGS OUTSIDE AIR TEMP. PRIORITY-LOW
FO-329522	10/13/2015	10/29/2015		CONTROLS please replace and reconnect damaged pneumatic line to actuator for heating/cooling loop in this office. Thanks.
FO-329572	10/14/2015	10/15/2015		Trade: Controls/Siemens Priority: Low The econ mode set point is tied to the chilled water temp, right now the set point is 52, I would like this changed to 50, and would like this point to be displayed on the graphic and be adjustable by the operator.
FO-329685	10/15/2015			Refrigeration Tools: Part #67002 Mantooth Wireless digital refrigerant pressure gauge (Dual Hi-Lo Pressure Model) Qty: 1 \$360.00 Part # CST-P Oxy/Acetylene Welding Brazing Kit QTY: 1 \$264.80
FO-329733	10/15/2015	10/19/2015		In Siemens, for AHU-3, please change the display units from Ma to pct (%) for point E1A3V
FO-330582	10/20/2015			Controls, R/R PENTHOUSE adjust VFD start current to prevent overload on AH-1
FO-330581	10/20/2015			Controls, R/R PENTHOUSE adjust VFD start current to prevent overload on AHU #2

WO	Recieved	Finished	Total	Request
FO-330615	10/21/2015	10/22/2015		Trade: Command Center Priority: Low R/R RM 00018/MECH RM Please update graphics for the main page for Life Science. Buttons for "reheat system" and "animal rooms" require a double click. All other buttons require a single click. Update "reheat" and
FO-330623	10/21/2015			COMMAND CTR, R/R RM 00347/MECH RM PLEASE WRITE A PROGRAM THAT WOULD ENABLE THE ABSORBER TO RUN WITH THE SCREW CHILLERS OFF. PRIORITY-LOW
FO-330647	10/21/2015	10/28/2015		CONTROLS R/R RM 305/BLR RM please r/r Fuel Valve end switch that is malfunctioning on Boiler #1 at FP&M.
FO-330802	10/22/2015	10/23/2015		CONTROLS - R/R RM 00305/BLR RM please r/r level master boiler #1 at FP&M. No display and boiler did not shut down when ALWCO was tried. Boiler OOS.
FO-330867	10/23/2015	10/23/2015		BAS Section: R/R RM 1077.10 please troubleshoot boiler plant enable/short cycle issue. Also ahus 1 and 2 will not start.
FO-330868	10/23/2015	10/23/2015		BAS section: R/R BLDG please troubleshoot Engineer's DDC monitor: will not log onto Siemens Insight.
FO-331225	10/28/2015			Refr. Crew: R/R RM 00410/MECH RM On the fresh air dampers for Classrooms AHU, one linkage to a section of the dampers is bent and needs repair or replacement. High Priority
FO-331249	10/28/2015			BAS section: R/R RM 114.10 please purchase replacement legacy board for floater dell laptop, as well as 540-143 rj11/serial cable. Low priority
FO-331233	10/28/2015			The instrument panel needs to have the psi for boiler control adjusted (off by 10 psi).
E - MedPharm			16	
FO-328499	10/1/2015	10/1/2015		Please change dirty air filter in rooms 34 & 35 Lande. Contact Dr. Brusilow at 7-6659 for questions. Thank you.
FO-328647	10/2/2015	10/2/2015		PUBLIC SAFETY OFFICER NEED ACCESS INTO ENTRANCE OF BUILDING.
FO-329193	10/8/2015	10/12/2015		Thermostatic is broken on wall. Unable to adjust temperature . Needs to be replaced. This is a post operative recovery room that needs to have easy temperature adjustments.
FO-329269	10/9/2015			Engineeer- low priority- replace leaking seal on medical air compressor.
FO-329416	10/12/2015			DEHYDRO WTR TX FOR HOT WTR HE'S @ BACK DOOR 586-524-5783
FO-329543	10/13/2015			To Charles Redmond re: Fire system shut down,for 4th fl. isolate and drain sprinkler heads ,so that contractor can reposition new heads during renovation.Please contact risk management.
FO-329843	10/16/2015			MEET DTE AT BONSTELLE.
FO-330530	10/20/2015	10/27/2015		Low Humidity. Temp unstable running heater in room!
FO-330543	10/20/2015	10/30/2015		MORGUE DOOR PUSH BUTTON ISN'T WRKNG HAS NO POWER TO IT
FO-330730	10/22/2015			animal room getting too warm
FO-330727	10/22/2015			animal room getting too warm
FO-330961	10/26/2015			Fuel needed for generator. (Current level is 5/8).
FO-331188	10/28/2015			Ceiling tiles coming down in lab near fume hood because of vibrations in room. Find cause of vibration and repair ceiling tiles. Contact room occupant Dr. Paula Dore-Duffy (7-0354) for questions.
FO-331301	10/29/2015			low temp heater running in room!
FO-331370	10/29/2015			The outlet number MS-038-2, MS-045-1 and MS-036-5 on the front desks of the auditorium don't work.
FO-331418	10/30/2015			Temperatures in Rooms 0423, 0412 and 0414 at Scott Hall are too warm.
E - North			11	
FO-328730	10/5/2015	10/5/2015		Rooms 354 and 351 - Electrical outlets on the walls are not working.
FO-329446	10/12/2015	10/14/2015		Air filters for the building furnace was delivered. They are here in the stairway alcove on the basement level

WO	Recieved	Finished	Total	Request
FO-329641	10/14/2015	10/15/2015		change belts 3 BX 158
FO-329883	10/19/2015	10/19/2015		2nd request for 4037 FAB. Heat is blowing - currently office is on 89 degrees.
FO-329914	10/19/2015	10/19/2015		Strong electrical smell in faculty office 3269 and adjacent women's room. Please inspect ASAP.
FO-330660	10/21/2015	10/21/2015		Fountain Pump Pit Freeze Protection Grainger 3VU33 heater 2P547 Pump 11N179 Hose
FO-330827	10/23/2015	10/23/2015		RM 1550/GEN LECT HALL IS TOO HOT
FO-330957	10/26/2015	10/26/2015		Kresge Library, 1st Floor Room 106 - Library Science Office Suite Staff reported that the area is cold and ask to have the heat turned up. Thank you.
FO-331135	10/28/2015	10/28/2015		ONLY ELEV IS IN ALARM 1ST FLR DOORS OPEN
FO-331145	10/28/2015	10/28/2015		TOWER SUMP PUMP NEEDS CKNG
FO-331291	10/28/2015			4th floor public ladies restroom flooding.
E - Northeast			7	
FO-328612	10/2/2015	10/2/2015		The ventilation system in my office is very noisy. Please quiet it down!
FO-329017	10/6/2015			CLS instructor, Elam Ghonim RM. 403- cold air is blowing through the windows and walls. Windows covered and insulate walls please.
FO-329119	10/7/2015	10/7/2015		BLOWING HOT AIR - AGAIN!
FO-329313	10/9/2015	10/29/2015		Leak in "ceiling" in women's restroom every time it rains. Restroom near lunchroom on first floor. See Sandy for details.
FO-329523	10/13/2015			Please replace damaged pressure gage on steam line to HEX.
FO-330821	10/23/2015	10/29/2015		2ND FLR PRINT RM IS TOO HOT
FO-330892	10/26/2015			RECEIVED MESSAGE REGARDING GENERATOR.
E - Preventative Maintenance			32	
FO-329150	10/7/2015	10/13/2015		Filters for UPS System @ Mott 14x24x1 Qty: 12
FO-329151	10/7/2015	10/13/2015		Filters for Primary Electrical Rm 1208 16x20x2 Qty: 12
FO-329165	10/7/2015	10/8/2015		RM 126 IS TOO HOT
FO-329168	10/7/2015	10/8/2015		No air circulation since this morning. Please reset HVAC system.
FO-329170	10/7/2015	10/7/2015		A/C does NOT work. Thanks for checking and maintenance.
FO-329194	10/8/2015			DLAR Rms Filter Order 20x20x1 Qty:36
FO-329210	10/8/2015	10/27/2015		Filters Welcome Center Unit Heaters 45-1/2 x 8-3/4 x 1/2 Qty: 12
FO-329257	10/8/2015	10/8/2015		ENTIRE BLDG IS TOO HOT
FO-329334	10/9/2015	10/9/2015		Water leaking near entrance of 1st floor women's room. Outside of the door and inside of the restroom.
FO-329426	10/12/2015	10/12/2015		Building is very warm. Please cool down.
FO-329642	10/14/2015	10/20/2015		Belt Order: B-70 Qty: 2

WO	Recieved	Finished	Total	Request
FO-329772	10/15/2015			Ceiling tile in women's restroom appears wet and spongy with odd growth on it. Please check for leak and replace tile. This restroom is located on the lower level between rooms 0142 and 0148.
FO-329773	10/15/2015	10/15/2015		Rm. 2602.1 is too cold. T
FO-329781	10/16/2015	10/23/2015		Belt Order: Supply Fan BX93 Qty: 4 Return Fan A76 Qty: 4
FO-329782	10/16/2015	10/23/2015		Belt Order: Supply Fan B103 Qty: 4 Return Fan A76 Qty: 4
FO-329819	10/16/2015			Belt Order
FO-329903	10/19/2015	10/26/2015		Authorization Filter Clips HFFC-2304 \$2.01/ea Qty: 50 Supplier: AERO Filters Blanket Purchase Order #P0740775
FO-330804	10/22/2015			meet w/deliver guy @ eng bldg (Jason 248-755-9574)
FO-330806	10/22/2015	10/22/2015		RM 151/AUDITORIUM IS TOO HOT
FO-330873	10/23/2015	10/26/2015		There is a constant ticking sound coming from the heating unit. Please repair.
FO-331059	10/27/2015			AHU-1 Belt Order: B120 Qty: 10
FO-331060	10/27/2015			AHU-2 Belt Order: B-93 Qty: 4
FO-331061	10/27/2015			AHU-3 Belt Order: C-128 Qty: 5
FO-331064	10/27/2015			Ex Fan Belt Order: A42 Qty: 4
FO-331099	10/27/2015	10/27/2015		Requesting an engineer to come adjust the temperature in office 304 in the Prentis Building. The office is too hot.
FO-331100	10/27/2015	10/27/2015		Following a pipe burst over the weekend (addressed and fixed) the water in the bathroom across from room 2104 is running brown water. As I was told, this pipe also provides water the the water fountain in the main area.
FO-331355	10/29/2015			AHU-1 Belt Order: A-62 Qty: 2

WO	Recieved	Finished	Total	Request
FO-331356	10/29/2015			AHU-7 Belt Order: A-62 Qty: 2
FO-331357	10/29/2015			AHU-3 Belt Order: B-81 Qty: 2
FO-331388	10/29/2015	10/30/2015		In Rm. 2602.1 there is a bad odor emitting from the vent. Person assigned to the office says it smells like sewer/garbage.
FO-331390	10/29/2015			RM 431 A PROFESSOR FOR EVENING CLASSES SAYS RM IS TOO COLD (TUESDAY NITES)
FO-331474	10/30/2015	10/30/2015		There is no heat on the 2nd level. Vents on level 2 are blowing cold air. There are 2 thermostats in the building. One in office #115 the other in office # 202. Both are unlocked.
E - South			16	
FO-328593	10/1/2015	10/2/2015		The whole building is sweltering even on cold days. Temperature needs to be regulated.
FO-329060	10/6/2015	10/7/2015		The cold room in the hallway is way too cold. It is now freezing the items that are inside.
FO-329473	10/13/2015			Plaster on ceiling is loose. Found some on staircase this morning
FO-329848	10/16/2015			Staff on 3rd floor, East end of building are cold, requesting to have heat turned on.
FO-329913	10/19/2015	10/19/2015		The drain from the Cold Room above is leaking into Lab 251 over the entry door. Percy Broadnax looked into this issue before we moved Dr. Brownlee in and determined that the leak is coming from the edges of the drain above. The Cold Room is designat
FO-330535	10/20/2015	10/20/2015		Hood is lab 1320 is not working. There is no air flow and also water flooding on the floor. They are doing testing and need this fixed asap. Can Rocky please look at it. If there are any questions please contact Haipeng at 7-3147. Thank you.
FO-330569	10/20/2015	10/22/2015		Room 247 and 245 have high temps
FO-330570	10/20/2015	10/22/2015		Room 247 and 245 have low humidity.
FO-330636	10/21/2015	10/28/2015		? BELIEVE ITS A DUMBWAITER OUT OF SVC
FO-330680	10/21/2015	10/21/2015		Water is not coming out of emergency eyewash.
FO-330753	10/22/2015	10/22/2015		Fume hood 's face velocity is too high (150 fpm)
FO-330864	10/23/2015	10/26/2015		Fume hoods are very noisy . Students are complaining about the sound....
FO-331015	10/27/2015			Requesting an engineer to come adjust the temperature in office 300.01 in the Prentis Building. The office is too hot.
FO-331193	10/28/2015			Greenhouse is leaking water into the 3rd floor
FO-331365	10/29/2015	10/30/2015		Cold air blowing out of overhead vents at circulation front desk.
FO-331414	10/30/2015	10/30/2015		Can someone take a look at the temperature controls for State Hall 216. There seems to be an ongoing problem that has not been addressed. Here is the email I received from the Political Science chair Dr. John Corvino. The work order form # that
E - Southeast			9	
FO-328993	10/5/2015	10/6/2015		Please turn on heat in building to 68 degrees. Thanks,
FO-329526	10/13/2015	10/22/2015		The Heater/AC unit in 3103 Old Main is continuously blowing hot air
FO-329942	10/19/2015	10/19/2015		RM 4100 IS TOO COLD
FO-329946	10/19/2015	10/20/2015		Faculty member reported, "This morning, when the fan in the ceiling started up, there was a loud clicking sound (about 2-3 times per second) that continued for as long as the fan was running, which is typically 10-15 minutes at a time."

WO	Recieved	Finished	Total	Request
FO-330542	10/20/2015	10/29/2015		Steam pours out of bottle washer and fills room with steam. Hard to see and floor slippery.
FO-330562	10/20/2015			R/R RM 00195/MECH-BLR RM REPAIR DISCHARGE PIPING ON EYE WASH STATION
FO-330765	10/22/2015	10/22/2015		PLS MEET UP W/OMAR ON 13TH FLR CELL #870-7910
FO-331185	10/28/2015	10/28/2015		in the dean's actual office, the ceiling has a leak, again, it needs to be checked TODAY please
FO-331248	10/28/2015	10/28/2015		RM 134 NEED DOOR UNLOCKED
E - West			5	
FO-328649	10/2/2015	10/2/2015		CHILLED WATER IS WARM. ROOM 170.
FO-329787	10/16/2015	10/29/2015		Electrical outlets in gym 109 do not always supply power...Please check all outlets in gym 109...Total of 3. See Bob Ostrowski on specifics...Thank You.
FO-330510	10/20/2015	10/22/2015		Repair broken door closure on north lobby doors by exit. Bob Ostrowski has specifics. Thank You.
FO-330635	10/21/2015	10/28/2015		The building is Hot, could you please send someone
FO-331177	10/27/2015			Outside electrical supply box located on the south side of the field (on the fence) inside the Football Stadium has no power.Please repair prior to the next home Football Game this Saturday 10-31-15. Please see Jim Campbell/Mike Flynn on specifics. Th
Grounds			5	
High			1	
G - Moving/Storage			1	
FO-329218	10/7/2015	10/8/2015		Rotate desk in office (room 1208). Approval and index to be charged to follow. Needs to be done this week. Dorothy Carter 10/08/2015 09:38 - Account index 168247 has been added to TMA Dorothy Carter 10/08/2015 09:34 - Account index 168247 is not in TM
Low			4	
G - Moving/Storage			1	
FO-328617	10/1/2015	10/7/2015		Remove existing furniture from rooms 207 and 312 and take to Property warehouse. Furniture needs to be removed on or before 10/10/15 to allow for cleaning and delivery of new furniture on 10/12/15. Approval and index to be charged to follow. Dorothy Ca
G - Physical Grounds			3	
FO-329048	10/5/2015	10/9/2015		Just Do It. Report to Tom Adams Field for Warren De La Salle vs. U of D Jesuit football game Oct. 9th from 6pm - 10pm. Set-up field markers and benches (6 on home sideline and 4 on visitors). Pull trash in spectators area and surrounding areas. Wayne S
FO-329430	10/12/2015	10/16/2015		Just Do It. Report to Tom Adams Field for Warren De La Salle vs. Detroit Catholic Central football game Oct. 16th from 6pm - 10pm. Set-up field markers and benches (6 on home sideline and 4 on visitors). Pull trash in spectators area and surrounding areas
FO-329865	10/16/2015	10/26/2015		Open House - Place trash cans and maintain areas around Community Arts, Fitness, Prentis, McGregor and Law
Trades			998	
Emergency			59	
T - Carpenter			20	
FO-329153	10/7/2015	10/7/2015		EMERGENCY CARP R/R RM 00159/BSMT STORAGE CLOSET UNABLE TO UNLOCK DOOR W/MASTER KEY (need access ASAP)
FO-329222	10/8/2015	10/8/2015		EMERGENCY CARP R/R RM 1520 HALLWAY DOOR BTWN SHIPPING REC/STUDENT LNGE NOTE SHIPPING REC SIDE DOOR LOCK YOU'RE UNABLE TO INSERT KEY ALL THE WAY
FO-329233	10/8/2015	10/8/2015		KEY STUCK IN CONFERENCE RM C DOOR LOCK
FO-329247	10/8/2015	10/8/2015		EMERGENCY CARP R/R RM 1530 DOOR LOCK IS SPINNING UNABLE TO UNLOCK DOOR NEED ACCESS ASAP
FO-329343	10/10/2015	10/10/2015		Secure parking lot gate at 1011 E. Ferry. The gate was damaged by vehicle strike and cannot be opened or closed. The gate is unsecure and open to pedestrian access. WSU Police Incident Report #W152830048

WO	Recieved	Finished	Total	Request
FO-329627	10/14/2015	10/14/2015		LOCKED KEYS INSIDE JANITOR'S CLOSET. PLEASE OPEN DOOR. 3RD FLOOR JANITOR'S CLOSET.
FO-329635	10/14/2015	10/14/2015		KEY BROKEN OFF IN DOOR LOCK. ROOM 226.
FO-329742	10/15/2015	10/15/2015		RM 1013 WON'T LOCK, RM NEEDS TO BE SECURED
FO-330614	10/21/2015	10/21/2015		R/R ENTRY Door #603-02S does not latch properly, needs to be checked and adjusted
FO-330627	10/21/2015	10/21/2015		R/R 2ND FLR please have carpenters repair door latch on door J scott hall, fire door near Jafar lecture hall, south west side of building. this door is on the 2nd floor. the door is marked J.
FO-330629	10/21/2015	10/22/2015		trade carpenters priority medium R/R ENTRY DOOR 096-017W please service back door entrance door will not close on its own have to pull it close behind you
FO-330721	10/22/2015	10/22/2015		trade carpenters priority medium R/R ENTRY DOOR 096-018W please service back door entrance door will not close on its own have to pull it close behind you
FO-330929	10/26/2015	10/26/2015		RM 1348 BACK DOOR KEY STUCK IN LOCK
FO-331029	10/27/2015	10/27/2015		01-071-N DOOR WILL NOT LOCK, SECURITY ISSUE
FO-331038	10/27/2015	10/27/2015		EMERGENCY CARP R/R RM 00055 UNABLE TO LOCK DOOR (SECURITY ISSUE)
FO-331046	10/27/2015	10/27/2015		**ADDING CARPENTERS: set up scaffold on wheels and remove ceiling grid as needed in lab 054. See Mike McAlinden for detail pg# 684-6898 (**) PO REQ DK 9/28 R/R RM 00054/MECH AREA Plumber repair water leak in ceiling. Same leak as last week. It raine
FO-331327	10/29/2015	10/28/2015		LOCKSMITH CALLED IN TO GAIN ACCESS TO A STRANDED INSTRUCTOR ROOM # 151.2
FO-331331	10/29/2015	10/29/2015		Please cut lock off of locker #93. Need completed ASAP. Please contact Beth Madigan for details. 577-6497
FO-331455	10/30/2015	10/30/2015		EMERGENCY CARP R/R RM 00172/JANITORS' CLOSET DOOR IS HANGING BY ITS HINGES
FO-331456	10/30/2015	10/30/2015		EMERGENCY CARP R/R RM 6307.6 DOOR LOCK CYLINDER IS SPINNING UNABLE TO LOCK DOOR NEED TO LOCK *SECURITY ISSUE*
T - Electrician			29	
FO-328495	10/1/2015	10/1/2015		Computer Lab A, 1st floor behind UGL circulation desk has a light fixture that is hanging from the ceiling and needs to be locked in place before it falls and injures someone.
FO-328623	10/2/2015	10/2/2015		HEAT & VENTILATION UNIT #1 WILL NOT RUN. SEE ENGINEER.
FO-328700	10/5/2015	10/7/2015		DOOR ALARM. STAFF ENTRANCE ON THE NORTH SIDE OF BUILDING. NEAR CIRCULATION DESK. FIRE ALARM PANEL SHOWING BAD BATTERY FOR CIRCUIT 31.
FO-329012	10/6/2015	10/6/2015		EMERGENCY ELEC R/R BLDG FAP FIRE TROUBLE ALARM ACTIVE UNABLE TO RESET
FO-329057	10/6/2015	10/7/2015		EMERGENCY ELEC R/R 1ST FLR JANITOR'S CLOSET UNDER MAIN STRWL LIGHT FIXTURE STARTED SPARKING WHEN TURNED ON (Note: Left off/door left open)
FO-329579	10/14/2015	10/14/2015		SMOKE DETECTOR CAUSING FIRE TROUBLE ALARM. CONTACT ENGINEER FOR DETAILS.
FO-329668	10/15/2015	10/15/2015		REPAIR OR REPLACE BOILER FEED PUMP BOILER #3
FO-329726	10/15/2015	10/17/2015		Take Cables to Football Field, hook them up to generator, allow Wolverine to run generator to take readings, then remove cables, and return them to shop.
FO-329727	10/15/2015	10/16/2015		Deliver Generator Cables to Football Field, and bring them back when Electricians disconnect them.
FO-329783	10/16/2015	10/16/2015		FIRE ALARM PANEL IN TROUBLE. ROOM 468. CONTACT ENGINEER FOR DETAILS.
FO-330513	10/20/2015	10/20/2015		EXIT SIGN IS SPARKING WITH BURNING SMELL. 3RD FLOOR HALLWAY OUTSIDE OF ROOM 3343.

WO	Recieved	Finished	Total	Request
FO-330659	10/21/2015			R/R BLDG HAD A BROWN OUT PARTIAL LITES CAME BACK ON ??? ON OTHER ELECTRICAL POWER
FO-330690	10/21/2015	10/22/2015		EMERGENCY ELEC R/R RM 00002/BSMT ELEC RM UNABLE TO SILENCE FAP ACTIVE FIRE ALARM BAD SENSOR
FO-330823	10/23/2015			Priority: High R/R BLDG Lights are out in the east stairway facing Warren on floors 1, 2 &3. Please repair.
FO-330828	10/23/2015	10/23/2015		Lights on the side of the Building along Antoinette keep tripping the breaker leaving the street really dark, and students use building all week, as well as the weekend.
FO-330842	10/23/2015	10/23/2015		4TH FL ATRIUM FIRE ALARMS NOT WORKING
FO-330886	10/26/2015	10/26/2015		**ADDING ELECTRICIAN: Check operation of float switch on sump pump in room 0316. See Don Bear for detail
				Repair sanitary sump pumps located in mechanical room 0316 at Law Library. Pumps tripped on overload and will not run.
FO-330890	10/26/2015			#2 AIR HANDLER UNIT WILL NOT START. ROOM 1296. SEE ENGINEER.
FO-330904	10/26/2015	10/26/2015		REPAIR MALFUNCTIONING VFD DRIVE FOR FAN #1. 3RD FLOOR MECHANICAL ROOM. CONTACT ENGINEER.
FO-331011	10/27/2015			**ADDING LABORER: Set up scaffold in lab 054 to access drain repair. See Mike McAlinden for location
				(**) PO REQ DK 9/28 R/R RM 00054/MECH AREA Plumber repair water leak in ceiling. Same leak as last week. It rained last night and water this morning
FO-331040	10/27/2015			6119 NO POWER
FO-331040	10/27/2015			6119 NO POWER
FO-331045	10/27/2015	10/28/2015		EMERGENCY ELEC R/R RM 00359 LIGHT BALLAST STARTED BURNING CAUSING FIRE ALARM TO BE ACTIVATED
FO-331142	10/28/2015	10/28/2015		fix light in pres. garage
FO-331215	10/28/2015	10/28/2015		NFAB CLEAN RM HAS NO POWER
FO-331252	10/28/2015	10/28/2015		AUTO FAIL ALARM. 1ST FLOOR CLOSET NEAR GUARDS DESK.
FO-331292	10/29/2015	10/29/2015		AIR HANDLER UNIT #3 SUPPLY FAN WILL NOT RUN. MECHANICAL ROOM 6TH FLOOR.
FO-331304	10/29/2015	10/29/2015		EMERGENCY ELEC R/R PENTHOUSE MECH RM HYDRONIC PUMP #16 HAS NO POWER PLS CK
FO-331359	10/29/2015	10/29/2015		SHIFFMAN LIBRARY FIRE ALARM SOUNDING
T - Pipefitter			1	
FO-329880	10/19/2015	10/19/2015		CEILING LEAK IN CONFERENCE ROOM #3. ,,,,,,,,,,,,,, ME/10-19-15 ,,,,,,,,,,,,,,
T - Plumber			8	
FO-328528	10/1/2015	10/1/2015		FLOOR DRAIN IS BACKED UP. ROOM 0247. RIGHT SIDE OF ROOM. ,,,,,,,,,,,,,, MM/10-1-15 ,,,,,,,,,,,,,,
FO-328629	10/2/2015	10/5/2015		FLUSH VALVE LEAKING WATER ON FLOOR. MEN'S RESTROOM. ROOM 4101. ,,,,,,,,,,,,,, MM/10-2-15 ,,,,,,,,,,,,,,
FO-328629	10/2/2015	10/5/2015		FLUSH VALVE LEAKING WATER ON FLOOR. MEN'S RESTROOM. ROOM 4101. ,,,,,,,,,,,,,, MM/10-2-15 ,,,,,,,,,,,,,,
FO-329414	10/6/2015	10/6/2015		Remove sink trap in lab 160. Student got Mercury in sink. Meet Richard from OEHS ,,,,,,,,,,,,,, GS/10-6-15 ,,,,,,,,,,,,,,
FO-329582	10/14/2015	10/14/2015		NO WATER IN BUILDING. ,,,,,,,,,,,,,, MM/10-14-15 ,,,,,,,,,,,,,,
FO-329664	10/15/2015	10/15/2015		Over at the stadium in the coaches shower the pipes needs to be snaked. Water is backing up and flowing into the kitchen. ,,,,,,,,,,,,,, MM/10-15-15 ,,,,,,,,,,,,,,
FO-330846	10/23/2015	10/27/2015		LAB 2025 PIPE LEAKING ,,,,,,,,,,,,,, *GS/EA/10-23-15 ,,,,,,,,,,,,,,
FO-331082	10/27/2015	10/27/2015		TOILET OVERFLOWING. MEN'S RESTROOM. ROOM 105 ,,,,,,,,,,,,,, DB/10-27-15 ,,,,,,,,,,,,,,
T - Roofing			1	
FO-331223	10/28/2015			ROOF LEAKS IN ROOMS 4001 AND 4339.
High			300	

WO	Recieved	Finished	Total	Request
T - Carpenter			64	
FO-328656	10/2/2015	10/5/2015		2ND FL STAIRWELL 2A, EXTERIOR DOOR HANDLE IS LOOSE
FO-328671	10/3/2015	10/5/2015		All exit doors on the south and north side on the main floor of the auditorium and lobby as well as the balcony do not operate properly. They either do not open via panic bar or will no lock. Please check and repair. The theatre will have audiences begin
FO-328677	10/4/2015	10/5/2015		Door #620-04W, center entrance at Woodward closes but does lock. It stays ajar. Please check and repair.
FO-328731	10/5/2015	10/6/2015		This is in the open cubicle area of offices 4640 and 4934. The window next to Lynda's cubicle shows signs of rain water leakage and needs to be checked for cold air leaks with the cold weather approaching.
FO-328773	10/5/2015	10/6/2015		STAIRWELL A INTERIOR 1ST FL DOOR, HANDLE IS LOOSE
FO-329016	10/6/2015	10/7/2015		Carpenters: please repair sliding entrance door # 016 01 E, it stops working after short period of time when it is reset. Priority: High.
FO-329024	10/6/2015	10/7/2015		HANDICAP LEFT DOOR DOES NOT OPEN WHEN BUTTON IS PRESSED. REQUESTOR STATED THERE IS NO DOOR NUMBER CONTACT LERONIA ROSS FOR FURTHER DETAILS 7-6181
FO-329040	10/6/2015	10/7/2015		trade carpenters priority medium in lab 5138 the door slams hard and its leaking fluid from the door closer thank you
FO-329065	10/6/2015	10/7/2015		Door 005-001E - The handicap door leading out to Cass Ave. sticks open. The motor that opens up the door runs non stop. Custodian turned the "switch" off to stop the motor.
FO-329080	10/6/2015	10/23/2015		ALL FOUR FLOORS OF WOMENS RESTROOMS NEED PRIVACY STRIPS INSTALLED IN STALLS. YOU ARE ABLE TO SEE IN STALLS
FO-329093	10/7/2015	10/8/2015		BOTH EXTERIOR AND INTERIOR RIGHT ENTRANCE DOORS ARE NOT CLOSING.
FO-329136	10/7/2015	10/8/2015		Carpenters please change locks "KEY&CORE" to cabinet in engineers office also to Tool cage door. priority high
FO-329141	10/7/2015	10/8/2015		Backstage door is not locking properly. This is an alarmed area.
FO-329145	10/7/2015	10/8/2015		In suite 2590, Rm. 2521's door will not catch or lock. Need repaired right away, as there are confidential files housed in that room.
FO-329215	10/8/2015	10/13/2015		**ADDING CARPENTER: Set up scaffold and Open ceiling in 2nd floor south stairwell to access plumbing repair. See notes below on asbestos and closing stairwell during repairs *also repair ceiling when repairs are complete. See Gerry (Plumber)
				Ceiling
FO-329228	10/8/2015	10/9/2015		Floor 2 north stair door has detached door closer. High Priority
FO-329237	10/8/2015	10/9/2015		2ND FL STAIRWELL A FAR RIGHT DOOR HINGE BROKEN DOOR WONT CLOSE
FO-329272	10/9/2015	10/12/2015		Hose holder fell off the wall. It needs to be rehung.
				Attn. Carpenter (little Ed)
FO-329321	10/9/2015			Carpenters: Please repair the handicap sliding door # 016 01 E, it stopped working again the day after it was fixed. priority: high.
FO-329366	10/12/2015	10/13/2015		BSMNT RM 0117 LOCK NOT WORKING, UNABLE TO GET INTO STORAGE RM
FO-329389	10/12/2015	10/14/2015		**ADDING CARPENTER: Provide an access door in brick to access drain on 3rd floor across from elevator. See Mike McAlinden or Gerry
				(**) PO REQ DK 10/1 HALLWAY 3RD FL NEAR ELEV WATER FOUNTAIN NOT WORKING ,,,,,,,,,, MM/7-14-15 ,,,,,,,,,,
FO-329447	10/12/2015	10/14/2015		door to north end faculty suites on first floor the lock is very loose about to come a part - please tighten.
FO-329451	10/13/2015	10/14/2015		Dirty side cage wash has door knob broken off.
FO-329595	10/14/2015	10/15/2015		RM 7370 DOOR HARD TO CLOSE
FO-329610	10/14/2015	10/14/2015		RM 300.8 KEY BROKEN OFF IN LOCK
FO-329612	10/14/2015	10/15/2015		1ST FL AT THE BACK ENTRANCE LOOSE FLOOR TILE
FO-329613	10/14/2015	10/16/2015		Exterior handicap button for door 28S doesn't open adjacent vestibule door when depressed. Sequencing issue?
FO-329620	10/14/2015	10/15/2015		DOOR WON'T LOCK WITH KEY. ROOM 521.

WO	Recieved	Finished	Total	Request
FO-329626	10/14/2015	10/15/2015		The back door of the Trainers room at the Football Stadium does not lock properly and is hard to open...Please see Bob Ostrowski for specs. Thank You Bob Ostrowski
FO-329676	10/15/2015	10/15/2015		DOOR # 130-07S DOES NOT CLOSE, SECURITY ISSUE
FO-329713	10/15/2015	10/16/2015		RM 5002 CEILING TILES FALLING
FO-329724	10/15/2015	10/16/2015		CARPENTERS REPAIR HANDLE OF DOUBLE DOORS IN HALLWY INFRONT OF ROOM 3313
FO-329747	10/15/2015			Room 3117, one of the windows will not close (near the South end of the room).
FO-329768	10/15/2015	10/23/2015		INSIDE HANDICAP DOOR BUTTON IS NOT WORKING. ROOM 1600.
FO-329860	10/16/2015	10/19/2015		The outside handle to Door #3 on the east side of Shapero Hall is missing.
FO-329920	10/19/2015	10/20/2015		CARPENTER (HIGH)MAKE AND INSTALL SHELF FOR CHEMICAL PUMP ROOM 100. SEE ENGINEERS FOR EXACT LOCATION.
FO-330502	10/20/2015	10/21/2015		**Reader door 5 & 6 on the west side of the building.** The panic bar needs servicing so that the door will properly close. Public Safety gets an alarm every night on the door. Ongoing problem for several weeks. Engineers have advised several
FO-330512	10/20/2015	10/21/2015		R/R Repair broken INTERIOR door closure on north lobby doors TO ENT DOOR #080-21N. Bob Ostrowski has specifics. Thank You.
FO-330524	10/20/2015	10/21/2015		HANDICAP DOOR WON'T CLOSE WHEN BUTTON IS PUSHED. DOOR #629-02-S.
FO-330539	10/20/2015	10/21/2015		R/R backdoor screen is loose - needs repaired 10/19/15 lps: Chng to Est for Main. Spoke w/Dorothy C says should go thru maintenance trades. Note: This is a Maintenance Bldg not Reimb. Chng back to IServ Use Index 170091. If over \$500 let me know an
FO-330557	10/20/2015	10/21/2015		DOOR HANDLE IS LOOSE. STAIRWELL J - 2ND FLOOR.
FO-330572	10/20/2015	10/21/2015		R/R BSMT MENS RR (ONLY)ENTRANCE DOOR LOCK IS LOCKED & CANNOT BE OPEN DOOR LOCK IS ALSO IS BROKEN UNABLE TO USE KEY
FO-330589	10/20/2015	10/21/2015		rooms 3326 and 3327 door latches are not engaging, making the rooms unlockable.
FO-330583	10/20/2015			STAIRS ARE CRACKED AND TILES IS COMING UP - WEST & EAST STAIRWELLS BETWEEN THE 2ND AND 3RD FLOORS.
FO-330606	10/20/2015	10/21/2015		0125 DOOR LATCH NOT WORKING PROPERLY, DIFFICULT TO OPEN FROM INSIDE RM
FO-330622	10/21/2015	10/22/2015		R/R POOL Repair/replace missing floor tile square in pool...Trip hazard. Please see Bob Ostrowski on specifics. Thank You. Bob Ostrowski
FO-330640	10/21/2015	10/27/2015		Replace stained/missing ceiling tiles in lab. New occupant will be moving in within the next week or two.
FO-330701	10/21/2015	10/22/2015		R/R RMS 3326 DOOR IN LOCKED POSITION HOWEVER NOT LOCKED
FO-330702	10/21/2015	10/22/2015		R/R RMS 3327 DOOR IN LOCKED POSITION HOWEVER NOT LOCKED
FO-330703	10/21/2015	10/22/2015		R/R RMS 3331 DOOR IN LOCKED POSITION HOWEVER NOT LOCKED
FO-330742	10/22/2015	10/22/2015		RM 256 KEY IS DIFFICULT TO ENGAGE IN LOCK
FO-330748	10/22/2015	10/27/2015		**ADDING LABORER: Erect scaffold and open ceiling to access chill water pipe repair in ballroom. See Marty (PIPEFITTER) for location **WORK IN PROGRESS JWT BSMNT BALLROOM WATER POURING IN ,,ME/10-21-15 ,,,
FO-330894	10/26/2015	10/26/2015		Doorknob sticking/difficult to open
FO-330924	10/26/2015	10/26/2015		STE 1200 ENTRY DOOR NOT LATCHING
FO-330948	10/26/2015	10/27/2015		Carpenters, please repair/replace loose door handle. (It is located 1st floor hallway, north end near exit doors. It is an interior door that separates the east & west hallway).
FO-330974	10/26/2015	10/27/2015		Inside Suite 206, there is an office with a loose door handle...Office 208 needs to have the door handle looked at
FO-330977	10/26/2015	10/28/2015		Three of the exterior windows have broken handles and they cannot be closed properly or locked.
FO-331032	10/27/2015	10/28/2015		R/R 1ST FLR EAST SIDE MENS RR HANDICAP STALL DOOR LATCH ISN'T LATCHING CLOSE

WO	Recieved	Finished	Total	Request
FO-331037	10/27/2015	10/29/2015		**ADDING CARPENTER: Set up scaffold to access piping repair in room 105.3. See Jim Hill for location
				Pipe fitters: please unplug or replace plugged up reheat lines for room 226.6, the reheat unit is in room 105.4.Priority: med. ,,,,,,,,,, JH/6-29-
FO-331053	10/27/2015			Trip hazard: carpet tear in hallway near room 3372
FO-331190	10/28/2015	10/29/2015		High Priority Request: R/R RM 311 Door locks are not functioning. KEYS AREN'T WRKNG/ Unable to gain access to the space with key or punch code.
FO-331289	10/28/2015			The door knob on the door is broken and will not let you open the door. The only way into the classroom is with the key not the door swipe.
FO-331440	10/30/2015			SCREW HAS COME OFF OF PLATE AROUND DOOR LOCK MAKING DOOR HARD TO CLOSE. BACK DOOR LEADING TO PARKING LOT.
FO-331466	10/30/2015			RUBBER MAT (STAIR THREAD) IS COMING UP FROM FLOOR. LANDING BETWEEN THE 1ST AND 2ND FLOORS.
T - Electrician			87	
FO-328464	10/1/2015	10/2/2015		pool equipment room in basement has bad machine room light switch
FO-328496	10/1/2015	10/1/2015		Repair lights in room 100, and in hallway. Fixtures have been tagged for a while.
FO-328514	10/1/2015			Laborer -- Priority HighPlease deliver 5 buckets of Oxykor S1100 to boiler room
FO-328541	10/1/2015			**ADDING ELECTRICIAN: Verify voltage and phase of domestic water recirc pump listed in below description. See Gerry if needed **Report finding to John Towle
				R/R BSMT/Mechincal room , basement area , Domestic hot water pump 2 blew a pump seal, now
FO-328597	10/2/2015			There is one of two lights that needs Electrician to fix (shortin light) that is in the vohm leading from the lobby into the theatre. This is a major entrance into the theatre and needs both lights working - safety issue. The President of the University
FO-328599	10/2/2015	10/2/2015		Time for Electricians to learn how to adjust the Timers at Elliman DLAR.
FO-328603	10/2/2015			**ADDING ELECTRICIAN: Verify voltage and singe or 3 phase. *Also check condition of backup pump. *Report findings to John Towle
				**ADDING PLUMBER: Check sump pump A" . Blows fuse when energized. Electrical operations have been checked and pump is dew
FO-328650	10/2/2015	10/6/2015		CLOCK IS HANGING OFF WALL. ROOM 1525.
FO-328653	10/2/2015	10/2/2015		Repair Exterior Lighting in rear of Presidents Apartment.
FO-328679	10/5/2015	10/5/2015		Trade: ElectricianPriority: HighAlarm is sounding from the generator panel in switch gear room. Please investigate.
FO-328703	10/5/2015			Electrician Please repair supply fan in pool area blowing fuses. also control fuse was fried. I pulled all fuses out.
FO-328704	10/5/2015			ELECTRICAL DEPT-PLEASE CHECK TRANSFORMER BOX IN MECH RM 5,BOX MAKING A LOUD NOISE DISTURBING CLASS ROOM PRIORITY HIGH
FO-328701	10/5/2015	10/6/2015		Check the oven in the Kitchen of the Presidents Apartment, and note Model#, Serial#, and other pertinent information. Completed 10-6-2015 SRP
FO-328747	10/5/2015			There are numerous emergency lights in the stairwells that are not working. Lights on front are blinking "red"
FO-329082	10/7/2015	10/7/2015		The ceiling light in the inner box office is not working. We checked the bulb and it is not burned out. Please check and repair. Thanks
FO-329095	10/7/2015			Electrician R/R RM 410/CAGEWASH RM Please replace blower motor in ceiling AC-unit,and controls.Priority-HIGH. Located in cage washer rm.
FO-329121	10/7/2015	10/8/2015		Electricians: R/R RM 495/MECH BLR RM Exhaust fan #2 (South) will not run in manual, only in auto. Please repair. High Priority.

WO	Recieved	Finished	Total	Request
FO-329144	10/7/2015	10/7/2015		ELECTRICIANS- please restore power to room 3100 at AAB on going problem w/ reoccurring power loss. Power out in VIP office. Please give HIGH PRIORITY.
FO-329190	10/8/2015	10/12/2015		Electrician R/R BLDG repair outside entrance lights at door 609-05-N
FO-329271	10/9/2015	10/9/2015		TELEPHONE INSIDE OF ELEVATOR KEEPS CALLING PUBLIC SAFETY. SCHINDLER ELEVATOR REFERENCE #50329322.
FO-329277	10/9/2015			**ADDING ELECTRICIAN: Please disconnect old condensate transfer pumps (One AT a Time). Re-hook up new transfer pumps located in mechanical room 10. See Ron Clark (**) PO REQ DK 10/1 material (**) PO REQ DK 7/30 pumps Replace condensate transfer pu
FO-329309	10/9/2015	10/9/2015		Trade: Electricians Priority: High R/R RM 00145 Reset alarm in switch gear room. Alarm at the generator has been reset.
FO-329328	10/9/2015			Electrician R/R PH/MECH RM please troubleshoot EF-4 THE VFD is fried a loud bang after closing breaker.Priority HIGH
FO-329329	10/9/2015			please reattach metal boxes inner side of entry doors to 2nd flr suites-east end, north and south side. thank you
FO-329344	10/11/2015			Many of the emergency lights in the hallways are on for no apparent reason. All power otherwise seems normal. Please check and correct.
FO-329345	10/11/2015			Wayne State Police - Dispatch Center - Ceiling light fixture ballast is going bad, need electrician.
FO-329370	10/12/2015	10/12/2015		GIRLS SOFTBALL LOCKER RM ELECTRICIANS PLEASE CHECK EMERGENCY LIGHTS ALSO CHANGE BATTERIES ON EXIT SIGNS
FO-329394	10/12/2015	10/12/2015		Electrician R/R PENTHOUSE blow the dust out of the VFD's for exhaust fans #4 - A & B. They are overheating.
FO-329412	10/12/2015	10/14/2015		ELECTRICIANS: Please replace caulking in junction boxes on COLD ROOM 5502. Condensation forming / leaking into light fixtures. MED.
FO-329413	10/12/2015	10/14/2015		R/R RM 112/AUDITORIUM THREE (3) LITES ARE BEEPING DIFFERENT AREAS IN CLNG
FO-329423	10/12/2015	10/14/2015		ELECTRICIANS - R/R 3RD FLR please resolve fire alarm trouble (3rd floor smoke detector 10). trouble would not reset. engineer checked 3rd floor an there's no indication of any problems.
FO-329449	10/13/2015	10/15/2015		ELECTRICIANS, #8 SECONDARY CHILLED WATER PUMP TRIPPED OUT ON OVERTEMPERATURE, WILL NOT RESET, PLEASE REPAIR. PRIORITY-HIGH
FO-329495	10/13/2015			Please have electricians repair lights in the gas reading room on the loading dock.high priority.
FO-329499	10/13/2015			We have 5 light fixtures that have burnt out bulbs in the 3517 common area. This area is extremely dark...
FO-329513	10/13/2015	10/14/2015		The second to last row of lights in room 1545 are out. There is a short in the switch.
FO-329514	10/13/2015			LABORER-"DENNIS",please deliver 20 bags of salt to Hudson- webber bldg. for Engineers. priority High
FO-329529	10/13/2015	10/14/2015		**ADDING ELECTRICIAN: Verify voltage and phase on domestic hot water recirculation pump in mechanical room 00124. See Gerry (Plumber) if needed. * Report findings to John Towle PLUMBERS please r/r hot water circ pump. Received complaint of no hot wa
FO-329556	10/13/2015			Dusk to dawn lights on exterior of building on Antoinette Street and the Southwest corner of the building are not on at night. Please check circuit, so that lights will be lit at night.
FO-329621	10/14/2015	10/15/2015		ELECTRICIANS: UPS Power system in alarm Lower level electrical room. HIGH
FO-329633	10/14/2015			LIGHT SWITCH IS HANGING (3-WAY SWITCH) SUB-BASEMENT ROOM 34.
FO-329634	10/14/2015			LIGHTS OUT IN 1ST FLOOR LEFT STAIRWELL. CASS ENTRANCE
FO-329638	10/14/2015	10/16/2015		R/R door bell.
FO-329659	10/14/2015	10/15/2015		1ST FL AREA NEAR CONF RM CLOCK IS 5 MIN SLOW

WO	Recieved	Finished	Total	Request
FO-329671	10/15/2015	10/27/2015		Get the 2 light fixtures out of the Stockroom, and install them on the wall in the Men's restroom on the first floor off the entrance of Anthony Wayne Drive.
FO-329697	10/15/2015	10/16/2015		To electricians. There is a fire trouble alarm indicating an overcurrent condition on one of the strobes in rm. 55 Art. Please repair or replace.
FO-329738	10/15/2015			Transport duct hoist from Pipe Shop to water meter room *NEED ON SITE FRIDAY 10-16-15 SEE JOHN TOWLE
FO-329778	10/16/2015	10/19/2015		Run Generator to test engine operation.
FO-329870	10/18/2015	10/22/2015		Restore power to the receptacles serving the IT equipment inside room 2230 at UGL.
FO-330540	10/19/2015			R/R need light on back porch replaced (light by back door) 10/19/15 lps: Chng to Est for Main. Spoke w/Dorothy C says should go thru maintenance trades. Note: This is a Maintenance Bldg not Reimb. Chng back to IServ Use Index 170091. If over \$500 I
FO-329961	10/19/2015	10/26/2015		Electrician R/R PH please replace 15hp motor on EF-4,model #AS93,suspect bad bearings.Priority-HIGH
FO-330538	10/20/2015			R/R Light in garage comes on after turning off - faulty switch? 10/19/15 lps: Chng to Est for Main. Spoke w/Dorothy C says should go thru maintenance trades. Note: This is a Maintenance Bldg not Reimb. Chng back to IServ Use Index 170091. If over \$
FO-330556	10/20/2015	10/21/2015		ENTIRE BLDG NEEDS CLOCKS RESET AFTER THE ELECTRICAL SHUTDOWN OVER THE WEEKEND
FO-330575	10/20/2015	10/21/2015		Electricians- High priority- R/R RM 00187.01/MECH RM Please disconnect and make safe motor connection for cage wash domestic water circulation pump. In mechanical room in basement behind surgery.
FO-330574	10/20/2015			Please have laborer move new Grundfos feed water pump from the stockroom to Bio-Science penthouse.
FO-330657	10/21/2015	10/23/2015		President's apartment has light out in landing. The landing was to narrow to place the 8 foot ladder on. The bulb is a 300w mogul base.
FO-330658	10/21/2015			Repair / re lamp blue light wall pack mounted east elevation adjacent to main entrance on Fourth Ave. Repair / re lamp other exterior lights indicated on plan.
FO-330661	10/21/2015			Room 3700 has two lights that are flickering and need to be replaced. They are located above the tables closest to the north wall. There are 4 EP's along wall... This is a training room...
FO-330694	10/21/2015	10/22/2015		R/R 1ST FLR FAP IS SHOWING IN ERROR NOT NORMAL
FO-330756	10/22/2015	10/24/2015		Replace the FACP on Saturday 10/24/2015 between the hours of 12PM, and 4PM.
FO-330757	10/22/2015			Change out the VFD on Supply Fan #4 with the new ABB purchased from Fife-Pearce Saturday 10/24/2015 so Ron from Fife Pearce can terminate the controls on Monday 10/26/2015.
FO-330764	10/22/2015	10/22/2015		Purdy Library, 2nd Floor North East Corner All lights out in north east corner. Checked light panel: all breakers are in the "ON" position. Please repair. Thank you.
FO-330771	10/22/2015			Repair / re lamp blue light located on the exterior south west corner of the Law Library Building. Intersection Gullen Mall & Gilmore Mall. See map.
FO-330825	10/23/2015	10/23/2015		Time to attend training on timers for lighting.
FO-330834	10/23/2015			Deliver motor to penthouse near SF#4
FO-330863	10/23/2015	10/26/2015		Electrician R/R RM 1369.08 troubleshoot circuit,no power at outlet, FO-330850,priority high
FO-330881	10/24/2015	10/27/2015		MONDAY, and TUESDAY 10/26 & 7/2015. Check all lights in rooms A, B, and C on the first floor, and rooms F, G, and H on the second floor to make sure all lights are working. Also check the restrooms, hallways, and Lobby.
FO-330887	10/25/2015			ELECTRICIANS/ PLEASE CHECK THE VFD ON EXHAUST FAN #9 FAN WONT START, (PRIORITY HIGH)
FO-330888	10/26/2015			Electrician; HighPlease replace the bad electric basin heaters in the two cells of the cooling tower; 071-COT-001.

WO	Recieved	Finished	Total	Request
FO-330893	10/26/2015	10/26/2015		Electrician; High Please replace the bad fuses in the #2 Boiler Control Panel. The fuses are for the force draft fan, a continued issue.
FO-330919	10/26/2015			Check operation of all 3 pits for proper operation of all the sump pumps.
FO-330953	10/26/2015	10/26/2015		Electricians to set back-up alarm in Presidents garage again, it seems someone tampered with it, and no one can reset it.
FO-331033	10/27/2015	10/29/2015		FIRE LANE BETWEEN SCOTT HALL AND LANDE, EXTERIOR LIGHT TIMER IS OFF, LIGHTS ARE NOT ON WHEN ITS DARK IN THE EARLY AM
FO-331076	10/27/2015			R/R BLDG Segment of electrical conduit beneath southwest porch is rusted away, exposing wiring.
FO-331165	10/28/2015	10/29/2015		RM 120 CLOCK NOT WORKING
FO-331186	10/28/2015			The switch in the men's locker room is not working and needs to be prepared. A GIRF needs to be generated.
FO-331187	10/28/2015			Laborer-Please remove all of piping and coils from the ERC removal at Science. The coils are located on a four wheel cart in the basement. The piping (nipples, unions and elbows) are in the penthouse (room 4038) next to the skinny stairs . All is t
FO-331254	10/28/2015	10/29/2015		R/R RM 7203 HAS A WALL OUTLET THAT HAS FALLEN OUT OF WALL SOCKET
FO-331295	10/29/2015	10/29/2015		Electrician R/R RM 00087.10/MECH RM repair fire pump control panel. It is in fault. Priority high.
FO-331302	10/29/2015	10/29/2015		fix lens in elevator
FO-331305	10/29/2015	10/29/2015		fix lens in elevator
FO-331323	10/29/2015	10/29/2015		trade electricans priority high R/R RM 6149/MECH RM please disconnect electrical circuit to boiler feed pump #1
FO-331325	10/29/2015	10/29/2015		trade electricans priority high R/R RM 6149/MECH RM please disconnect electrical circuit to # 3 steam boiler
FO-331369	10/29/2015			R/R RM 2268 ELECTRICAL WALL Receptacle at fron of raise platform, has a prong stuck in one of the blade inserts. The AV contractor is reworking the technology in the room. He will be back on site tomorrow, 10 30/15, it would be helful if someone could r
FO-331386	10/29/2015			repair blue light at N.W. corner of building blue lens in broken
FO-331393	10/29/2015	10/29/2015		work with bridgeway at generator
FO-331417	10/30/2015			LABORER (HIGH) DELIVER TO SCOTT HALL ROOM 100: NITROKLENZ 17010050 20 PAILS NEUTRAMINE 10 PAILS
FO-331451	10/30/2015			**ADDING LABORER: Transport piping material on a pallet in the stockroom to room 100 at Scott Hall. See Jim Hill for assistance Install all pumps for hydronic heating system located in mechanical room 100,,,,,,,,,,,,, JH/9-16-15 ,,,,,,,,,,, *Sc
T - Locksmith				6
FO-329188	10/7/2015	10/8/2015		New Key Lost / Stolen Key #: 110009 Key Holder ID: Theresa Y. Hill Qty: 6 action: Please duplicate 6 keys for the aminal room in the DLAR basement area of the IBio building. Contact Theresa Hill at 577-1417 or 577-0556 with any question
FO-329232	10/8/2015			Requesting 1- Key # XOE-33

WO	Recieved	Finished	Total	Request
FO-329243	10/8/2015	10/8/2015		New KeyDamagedKey #: key #61865, core #22AAD87Key Holder ID: Cindy HildrethQty: 1action: Cut 1 key for room 524.3Account #: 228400
FO-329265	10/8/2015	10/16/2015		New Key Damaged Key #: Core# 22AAE122, Key# 62158 Key Holder ID: Cindy Hildreth Qty: 2 action: Cut 2 keys Account #: 228400
FO-329460	10/13/2015	10/12/2015		Replace core room 608.2
FO-329603	10/14/2015			New KeyNew Space AssignmentKey #: 11VB-20, 11VB-23, 11VB-7Key Holder ID: Andy MurrellQty: 11VB-20 (2) 11VB-23 (4) 11VB-7 (2)action: Provide keys in quantities as listed above. Deliver Directly to Mark Gibbons.Account #: N/A
T - Painter			4	
FO-328487	10/1/2015	10/2/2015		Paint the Bollard a Brown color to match the Poles around the Mall.
FO-328626	10/2/2015	10/7/2015		Service request to remove "KKK" graffiti on the northwest side on the Prentis building. Police Report #W15-2750031 Dorothy Carter 10/02/2015 10:57 - Not Insurance - Maintenance work, create work order to track labor.
FO-331353	10/29/2015			PLASTERERS/PAINTERS- please repair damaged plaster and paint at main entrance of mort sci on ceiling (there was a leak and it is now not active). Open House at mort Sci is Nov. 5th. please repair ASAP before Open House. high priority.
FO-331480	10/30/2015			Purdy Library first floor men's restroom (near entrance/in stairwell area)--vandalism/graffiti in several stalls. Police report #W153020041
T - Pipefitter			35	
FO-328477	10/1/2015			FITTERS COMPLETE 4 INCH VENT LINE CONNECTION FROM CONDENSATE PIT TO OUTSIDE VENT LINE. LINE IS CURRENTLY CAPPED OFF CAUSIONG STEAM TO TRIP SMOKE DETECTOR. WE ARE CURRENTLY COOLING DOWN THE PIT WITH EXTRA CITY WATER TO PREVENT ALARMS. ,,,,,,,,,,,,,,,,,,,,,,
FO-328482	10/1/2015	10/12/2015		FITTERS (HIGH) REPLACE BAD STEAM REGULATING VALVE AND ACTUATOR FOR AHU 13. ,,,,,,,,,,,,,,,,,,,,,, JH/10-1-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-328646	10/2/2015	10/5/2015		CEILING LEAK. ROOM 416.,,,,,,,,,,,,,,,,,,,,,, ME/10-5-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-328678	10/5/2015	10/5/2015		**DUPLICATE WORK ORDER/REFER TO FO#328265 JWT high priority, please have pipefitters repair a leaking insulated pipe that is on the loading dock from the plumbers work shop to the custodian supply room. pipe is leaking between these areas.
FO-329043	10/6/2015	10/7/2015		Feedwater line to boilers 1 & 2 is leaking heavily. Impacts operation of boilers ,,,,,,,,,,,,,,,,,,,,,, ME/10-8-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-329103	10/7/2015	10/13/2015		CEILING LEAK. SEVERAL AREAS. ROOM 324. ,,,,,,,,,,,,,,,,,,,,,, ME/10-9-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-329367	10/12/2015	10/12/2015		**DUPLICATE / REFER TO FO#329103 JWT CEILING LEAK. (ONGOING PROBLEM) ROOM 324.
FO-329472	10/13/2015	10/14/2015		STEAMFITTERS-PLEASE REPAIR LEAK IN MAIN STEAM HEADER FLANGE BETWEEN #1 AND #2 BOILERS PRIORITY HIGH ,,,,,,,,,,,,,,,,,,,,,, CB/10-13-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-329498	10/13/2015	10/15/2015		For pipe fitters. Please replace air compressor #1's Dayton, automatic air tank blow down device with a functional one and install a hand bypass around this device for emergencies. This is a high priority.,,,,,,,,,,,,,,,,,,,,,, ME/10-13-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-329515	10/13/2015			In room 0410 there's a cooling unit in the ceiling that isn't in service, the Electricians need some pipes moved to get to the motor, and replace it ,,,,,,,,,,,,,,,,,,,,,, ME/10-13-15 ,,,,,,,,,,,,,,,,,,,,,,
FO-329632	10/14/2015	10/19/2015		Pipefitters-Please extend the condensate return vent (unit is in Art mechanical room) outside to at least 8ft above air intake for air handlers in room 47. EHOS is complaining that when the vapor vents outside it is being sucked into the fans.,,,,,,,,,,,,,,,,,,,,,,
FO-329743	10/15/2015	10/16/2015		Steam leak in machine shop room 37 in basement, leak in small room on south side. See Tom Mitchell for details. ,,,,,,,,,,,,,,,,,,,,,, EA/10-15-15 ,,,,,,,,,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-329812	10/16/2015			(**) PO REQ DK 10/20 Pipefitters to re pipe the feedwater header for the Skillman feed water pumps. We are having trouble getting water to the boilers. ,,,,,,,,,,,,,, JH/10-19-15 ,,,,,,,,,,,,,,
FO-329831	10/16/2015	10/26/2015		FITTER: MEET HONEYWELL IN RM 200.13 VALVE LEAKING ,,,,,,,,,,,,,, ME/10-19-15 ,,,,,,,,,,,,,
FO-329854	10/16/2015	10/19/2015		REPAIR OR REPLACE BOILER FEED PUMP Boiler #3 ,,,,,,,,,,,,,, RC/10-19-15 ,,,,,,,,,,,,,,
FO-329895	10/19/2015	10/19/2015		1ST FL MENS RM, CEILING LEAK ,,,,,,,,,,,,,, EA/10-19-15 ,,,,,,,,,,,,,,
FO-329897	10/19/2015	10/21/2015		**REFER TO FO#328108 3RD FL HALLWAY, CEILING LEAK ,,,,,,,,,,,,,, ME/10-19-15 ,,,,,,,,,,,,,,
FO-329923	10/19/2015	10/20/2015		To pipefitters. The second steam radiator inside the door of this office has started leaking steam and water. Please repair or replace.Very High priority ,,,,,,,,,,,,,, ME/10-19-15 ,,,,,,,,,,,,,
FO-329959	10/19/2015	10/20/2015		Pilot line from DA tank has pin hole leak on 3/4" line.,,,,,,,,,,,,,, JH/10-19-15 ,,,,,,,,,,,,,,
FO-330531	10/20/2015	10/21/2015		PIPEFITTERS please r/r leaking return line in room 124 at Mort Sci. Line by condensate return pumps is leaking BADLY. Please hose clamp until proper repairs can be made. High priority. Water seeping into other rooms. ,,,,,,,,,,,,,, ME/10-21-15 ,,,,,,,,,,,,,,
FO-330662	10/21/2015			(**) PO REQ DK **WORK IN PROGRESS JWT BSMNT BALLROOM WATER POURING IN ,,,,,,,,,,,,,, ME/10-21-15 ,,,,,,,,,,,,,,
FO-330746	10/22/2015	10/22/2015		DUPLICATE / REFER TO FO#330662 BSMNT BALLROOM WATER POURING IN ,,,,,,,,,,,,,, ME/10-21-15 ,,,,,,,,,,,,,,
FO-330780	10/22/2015			Fitter repair another high pressure steam leak at flange above #1 boiler ,,,,,,,,,,,,,, JH/10-23-15 ,,,,,,,,,,,,,
FO-330843	10/23/2015			Pipe dripping and ceiling tile outside of office is wet and warped.,,,,,,,,,,,,,, ME/10-23-15 ,,,,,,,,,,,,,,
FO-330847	10/23/2015			RM 257 CEILING LEAK ,,,,,,,,,,,,,, EA/10-23-15 ,,,,,,,,,,,,,,
FO-330914	10/26/2015	10/27/2015		**DUPLICATE/ REFER TO FO#320408 CEILING LEAK. ROOM 040.,,,,,,,,,,,,,, ME/10-26-15 ,,,,,,,,,,,,,,
FO-330925	10/26/2015			Trade: PipeFitters Priority: Med/High Please replace a leaking flange gasket on the main steam valve for #2 heat exchanger in the boiler room. I believe this repair will require a steam/boiler shut down. Hopefully this can be done when the shut down h
FO-331023	10/27/2015			Steamfitters please repair 1 1/2" condensate pipe leak ,between low pressure domestic & low pressure lab hot water heaters. priority High ,,,,,,,,,,,,,, EA/10-27-15 ,,,,,,,,,,,,,,
FO-331095	10/27/2015	10/28/2015		**ADDING PIPEFITTER: Check temps on domestic heat exchanger. See Gerry with findings ,,,,,,,,,,,,, JH/10-27-15 ,,,,,,,,,,,,,, P.M all bathrooms for BOG on Friday 10-30-15 ,,,,,,,,,,,,,, GS/10-27-15 ,,,,,,,,,,,,,,
FO-331138	10/28/2015			CEILING LEAK. ROOM 5625.,,,,,,,,,,,,,, JH/10-28-15 ,,,,,,,,,,,,,,
FO-331146	10/28/2015			CEILING LEAK. ROOM 205. ,,,,,,,,,,,,,, ME/10-28-15 ,,,,,,,,,,,,,,
FO-331189	10/28/2015			Outside room 3141 Elliman. Roof leak is getting worse. Please repair and replace ceiling tiles when ,,,,,,,,,,,,,, ME/10-28-15 ,,,,,,,,,,,,,, leak is fixed.
FO-331194	10/28/2015			CEILING LEAK. HALLWAY OUTSIDE OF ROOMS 4113 AND 4218. ,,,,,,,,,,,,,, JH/10-28-15 ,,,,,,,,,,,,,
FO-331243	10/28/2015	10/28/2015		1ST FL WOMEN'S RM LEAKING WATER FROM 2ND FL INTO HANDICAP STALL ,,,,,,,,,,,,, EA/10-28-15 ,,,,,,,,,,,,,,
FO-331341	10/29/2015			FITTERS (HIGH) STEAM CONDENSATE TANK IN ROOM 100 IS LEAKING. THE LEAK IS GETTING WORSE. CHECK AND REPAIR. THE LEAK IS AT THE BOTTOM OF THE TANK ,,,,,,,,,,,,, JH/10-29-15 ,,,,,,,,,,,,,,
T - Plumber				90
FO-328486	10/1/2015	10/2/2015		The men's bathroom in the Basement of Prentis is blocked up and is causing water to leak out on to the floor. ,,,,,,,,,,,,,, MM/10-1-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-328503	10/1/2015	10/1/2015		**DUPLICATE/ REFER TO FO#328516 JWT PLUGGED TOILET. 1ST STALL. 1ST FLOOR WOMEN'S RESTROOM NEAR LUNCHROOM.
FO-328516	10/1/2015	10/1/2015		WOMENS RM ACROSS FROM KITCHENETTE AREA BETWEEN BUSINESS SVC AND DESIGN SVC, 2ND TOILET PLUGGED 1ST STALL OUT OF ORDER SIGN GS/10-1-15
FO-328536	10/1/2015	10/7/2015		This for Dantos side 2nd floor Men's urinal on the right side full and flushing full of piss. GS/10-1-15
FO-328576	10/1/2015	10/1/2015		*DUPLICATE/ REFER TO FO#328516 JWT MENS RM NEXT TO MR. SEARS OFFICE IS HAVING PLUMBING ISSUES. DIRTY WATER ON FLOOR.
FO-328596	10/1/2015	10/5/2015		HIGH PRIORITY the ONLY urinal left in the men's restroom near the service desk is stopped up and filled to overflow. PLEASE HELP! thanks Michelle MM/10-2-15
FO-328600	10/2/2015	10/2/2015		PLUGGED SINK. 2ND FLOOR WOMEN'S RESTROOM. NEAR ROOM 2506. MM/10-2-15
FO-328695	10/5/2015	10/6/2015		TOILET WON'T FLUSH. 5TH FLOOR WOMEN'S RESTROOM. MM/10-5-15
FO-328702	10/5/2015	10/6/2015		PLUGGED TOILET. 12TH FLOOR MEN'S RESTROOM NEAR SERVICE ELEVATOR. MM/10-5-15
FO-328706	10/5/2015	10/5/2015		Please check the Men's and Women's restroom near the lunchroom on the first floor. Please check all toilets and sinks to see that they are in working order. Often, when one toilet is cleared, another quits working. And/or the sink backs up.
FO-328707	10/5/2015	10/8/2015		In 5th floor ladies restroom, the disability stall's toilet has a constant leak coming from the pipe near the wall. MM/10-5-15
FO-328727	10/5/2015	10/8/2015		please unplug toilet in 2nd stall from entrance-3rd floor ladies rest/room. thank you MM/10-5-15
FO-328733	10/5/2015			(**) PO REQ DK 10/29 Water coming in boiler room behind D.A. tank. from leak on plug from sump pump job and also a cast iron line leaking. See Tony Crawley if needed MM/10-5-15
FO-328735	10/5/2015	10/5/2015		MENS RM NEAR MR. SEARS OFFICE, SINK PLUGGED MM/10-5-15
FO-328775	10/5/2015	10/8/2015		1ST FL MENS RM 2ND STALL NOT FLUSHING MM/10-6-15
FO-329003	10/6/2015	10/20/2015		Room 351, Faculty office, the radiator is leaking all over the office. This is a reoccurring problem ME/10-6-15
FO-329013	10/6/2015	10/6/2015		GARBAGE DISPOSAL IS NOT WORKING AND SINK GETS PLUGGED. 1ST FLOOR LOUNGE. ROOM 128. (CANCEL WORK ORDER PER ALEX STEPHENS)
FO-329037	10/6/2015	10/9/2015		R/R RM 00301 ONLY SHOWER THE HANDLE HAS FALLEN OFF MM/10-8-15
FO-329041	10/6/2015	10/8/2015		R/R 1ST FLR NEAR RM 1339 WOMENS RR ONLY TOILET IS PLUGGED UP TT/10-8-15
FO-329131	10/7/2015	10/7/2015		RM 3337 SINKS HAVE NO WATER MM/10-7-15
FO-329137	10/7/2015	10/9/2015		RM 9115 SINK LEAKING MM/10-5-15
FO-329160	10/7/2015	10/8/2015		HOT KITCHEN SINKS HAVE BROWN WATER COMING FROM FAUCET TT/10-8-15
FO-329173	10/7/2015	10/8/2015		RM 156 SINK TRAP PLUGGED TT/10-8-15
FO-329174	10/7/2015	10/8/2015		1ST FL MENS RM STALL PLUGGED TT/10-8-15
FO-329191	10/8/2015	10/9/2015		**DUPLICATE / REFER TO FO#328733 JWT PLUMBERS: R/R STM RM Please replace leaking CAST IRON drain line in steam room. HIGH MM/10-8-15
FO-329207	10/8/2015	10/12/2015		4TH FL WOMENS RM WITHIN SUITES, SINKS ARE NOT DRAINING TT/10-12-15
FO-329216	10/8/2015	10/9/2015		RESTROOM 402 WATER LEAKING AROUND TOILET MM/10-8-15

WO	Recieved	Finished	Total	Request
FO-329286	10/9/2015	10/9/2015		4TH FL MENS RM BOTH TOILET SEATS ARE LOOSE ,,,,,, TT/10-9-15 ,,,,,,
FO-329287	10/9/2015	10/9/2015		4TH FL WOMENS RM HANDICAP STALL TOILET SEAT IS LOOSE ,,,,,, TT/10-9-15 ,,,,,, ,,,,,,,,
FO-329288	10/9/2015	10/9/2015		4TH FL WOMENS RM LEFT SINK NEEDS BATTERIES ,,,,,, TT/10-9-15 ,,,,,,
FO-329431	10/12/2015	10/13/2015		1ST FL LADIES RM LEFT STALL TOILET IS PLUGGED ,,,,,, TT/10-13-15 ,,,,,,
FO-329531	10/13/2015	10/15/2015		Faucet is dripping at the sink on the east wall.,,,,,, MM/ 10-13-15 ,,,,,,
FO-329560	10/13/2015	10/14/2015		1ST FL UNISEX HANDICAP RESTROOM, TOILET NOT DRAINING PROPERLY WATER FILLS TO RIM AND SLOWLY DRAINS ,,,,,, TT/ 10-13-15 ,,,,,,
FO-329601	10/14/2015	10/14/2015		WATER FOUNTAIN IS PULLING AWAY FROM WALL. BASEMENT HALLWAY OUTSIDE OF ROOM 008.,,,,,, TT/10-14-15 ,,,,,,
FO-329622	10/14/2015	10/15/2015		PLUGGED TOILET. MEN'S RESTROOM. ROOM 1138.,,,,,, TT/10-15-15 ,,,,,,
FO-329631	10/14/2015	10/15/2015		Plumbers: Drinking fountain on second floor near the women's rest room is over spraying onto the wall. Please adjust. High Priority. ,,,,,, TT/10-15-15 ,,,,,,
FO-329645	10/14/2015			Purdy Library first floor men's restroom (near entrance/in stairwell area)--urinal flooding/overflowing (potential clog/back-up),,,,,, GS/10-14-15 ,,,,,,
FO-329716	10/15/2015	10/16/2015		There are dripping faucets in Rm 405 (on the front bench) and in Rm 403. ,,,,,, TT/10-15-15 ,,,,,,
FO-329767	10/15/2015	10/16/2015		PLUGGED TOILET. LADIES RESTROOM. ROOM 1234. ,,,,,, TT/10-16-15 ,,,,,,
FO-329798	10/16/2015	10/16/2015		RM 1348 FL DRAIN BACKED UP ,,,,,, GS/10-16-15 ,,,,,,
FO-329817	10/16/2015	10/16/2015		FLOOR DRAIN IS BACKED UP. ROOM 0247 ON THE RIGHT SIDE. ,,,,,, DB/10-16-15 ,,,,,, ,,,,,,,,
FO-329825	10/16/2015	10/19/2015		sink is clogged ,,,,,, TT/10-19-15 ,,,,,,
FO-329859	10/16/2015	10/19/2015		Please snake out only urinal in 1st floor Men's - old restroom. When flushed, water almost overflows the edge of urinal. ,,,,,, GS/10-19-15 ,,,,,,
FO-329874	10/17/2015	10/21/2015		The sink in the custodial closet located from the Hilberry Theatre 1st fllor lobby is clogged. Can a plumber unclog and snake the sink? Please see Michael in the box office for exact location. Thanks, ,,,,,, MM/10-21-15 ,,,,,,
FO-329919	10/19/2015	10/21/2015		BSMNT MENS RM 3RD STALL, TOILET SEAT IS FALLING OFF ,,,,,, TT/10-19-15 ,,,,,, ,,,,,,,,
FO-329925	10/19/2015	10/19/2015		One of the toilets in the lower level men's room will not shut off. Please check and repair. Thanks ,,,,,, GS/10-19-15 ,,,,,,
FO-329926	10/19/2015	10/20/2015		STE 1200, FAUCET WITH LOW WATER PRESSURE. WATER TRICKLES OUT ,,,,,, TT/10-19-15 ,,,,,,
FO-329944	10/19/2015	10/22/2015		R/R RM 416/DLAR SINK THAT HAS FAUCET MOUNTED IN WALL HAS A LEAK @ FAUCET ,,,,,, MM/10-19-15 ,,,,,,
FO-329967	10/19/2015	10/20/2015		URINAL CONTINUOUSLY FLUSHING. MEN'S RESTROOM. ROOM 1130.,,,,,, TT/10-20-15 ,,,,,,
FO-329976	10/19/2015			R/R RM 3338/MENS RR HANDICAP STALL SEEMS TO BE BACKING UP W/SEWAGE AGAIN (BAG OVER TOILET) Previous req- toilet clogged. When flushed all matters do not go down.,,,,,, MM/10-5-15 ,,,,,, ,,,,,,,,
FO-330504	10/20/2015	10/21/2015		PLUGGED TOILET. BASEMENT UNISEX RESTROOM.,,,,,, MM/10-21-15 ,,,,,,
FO-330517	10/20/2015	10/22/2015		1ST FL MENS RM 1ST STALL HANDLE LEAKS WHEN FLUSHED ,,,,,, TT/10-21-15 ,,,,,, ,,,,,,,,
FO-330579	10/20/2015	10/22/2015		9TH FL NEAR ELEV, WATER FOUNTAIN NOT WORKING ,,,,,, TT/10-21-15 ,,,,,,
FO-330603	10/20/2015			RM 4338 PIPE UNDER SINK IS BACK FEEDING ,,,,,, GS/10-23-15 ,,,,,,
FO-330603	10/20/2015			RM 4338 PIPE UNDER SINK IS BACK FEEDING ,,,,,, GS/10-23-15 ,,,,,,
FO-330608	10/20/2015	10/21/2015		LADIES RM 2377 3RD STALL NOT FLUSHING ,,,,,, MM/10-21-15 ,,,,,,
FO-330664	10/21/2015	10/28/2015		RM 2438 URINAL OVERFLOWING ,,,,,, MM/10-21-15 ,,,,,,
FO-330698	10/21/2015			Trade: Plumbers Priority: High Please restore water the the emergency eye wash and shower in room 133. Valves are open. ,,,,,, GS/10-22-15 ,,,,,,
FO-330709	10/21/2015	10/28/2015		2ND FL MENS RM TOILET NOT WORKING ,,,,,, MM/10-22-15 ,,,,,,

WO	Recieved	Finished	Total	Request
FO-330779	10/22/2015	10/23/2015		The janitor closet on the first floor by the freight elevator. It is right next to the Women's bathroom has the slop sink clogged. This has happened in the past. Thank you. TT/10-22-15
FO-330884	10/25/2015	10/27/2015		Repair sanitary sump pumps located in mechanical room 0316 at Law Library. Pumps tripped on overload and will not run..... DB/ 10-25-15
FO-330899	10/26/2015	10/27/2015		PLUGGED SINK. KITCHEN - ROOM 161. GS/10-26-15
FO-330934	10/26/2015			3RD FL WOMENS RM, FAUCET LEAKS IN OFF POSITION GS/10-26-15
FO-330946	10/26/2015	10/28/2015		MENS RM 1138, URINAL PLUGGED MM/10-26-15
FO-330949	10/26/2015	10/27/2015		TOILET CONTINUOUSLY FLUSHING. WOMEN'S RESTROOM. ROOM 110 TT/10-26-15
FO-331005	10/27/2015	10/28/2015		TOILET NOT FLUSHING. (YOU HAVE TO HOLD THE HANDLE DOWN) 1ST FLOOR MEN'S RESTROOM. TT/10-28-15
FO-331026	10/27/2015	10/27/2015		Men's restroom near DJK. Toilet in only stall is stopped up. DB/10-27-15
FO-331035	10/27/2015			RM 9232 ROTTEN SMELL FROM SINK MM/10-27-15
FO-331035	10/27/2015			RM 9232 ROTTEN SMELL FROM SINK MM/10-27-15
FO-331057	10/27/2015			HOT WATER TANK LEAKING AT TOP. 2ND FLOOR JANITOR'S CLOSET..... GS/10-27-15
FO-331134	10/28/2015			Plumb High Priority...Health and Safety Water coming in mechanical space behind engineers office. Please move sump pump in pipe pit area of Blr Rm. to under catch basin tray in mechanical rm. Install pump in 40 gal drum and pipe to near by storm water
FO-331140	10/28/2015			Leak coming from overhead glass in UGL atrium . Water leaking on carpet by UGL temp. display. First floor of UGL. GS/10-28-15
FO-331141	10/28/2015			ADDING CUSTODIAL 10/28/15 FOR CLEAN UP AFTER FLR DRAIN HAD BEEN CLEANED OUT 10/27/15 NEED CLEANING/SANITIZE (**) PO REQ DK 7/31 ADDING PLUMBERS R/R RM 040 NEED TO REPAIR CLNG DRAIN LINE THATS IS LKNG FROM CEILING MM/6-29-15
FO-331172	10/28/2015			CEILING LEAKS. ROOM 126 ALSO HALLWAYS OUTSIDE OF ROOM 111 (HALL OF FAME) AND 126. GS/10-28-15
FO-331217	10/28/2015	10/29/2015		ceiling leak MM/10-28-15
FO-331234	10/28/2015	10/28/2015		Duplicate / Refer to FO# 323337 Plumbers- High Priority- Replace hot water circulating pump for DHWH #1. Serving DLAR.
FO-331235	10/28/2015			Toilet fixture is loose from floor, and toilet seat is loose from the stool. TT/10-29-15
FO-331246	10/28/2015			CUSTODIAL CLOSET 216 SINK CLOGGED GS/10-29-15
FO-331255	10/28/2015			WATER FOUNTAINS HAVE BROWN WATER COMING OUT CONTACT 7-1645 TT/10-29-15
FO-331256	10/28/2015	10/30/2015		R/R BSMT MENS LOCKER RM 3 OUT OF 4 SHOWERS AREN'T WRKNG DB/10-29-15
FO-331300	10/29/2015	10/30/2015		R/R 1ST FLR COACHES' MENS LOCKER RM Please snake out floor drain in mens lockroom when the coach takes a shower the drain backs up and water runs into hall kitchen area..... MM/10-29-15
FO-331313	10/29/2015	10/30/2015		3RD FL LADIES RM NO WATER MM/10-29-15
FO-331351	10/29/2015	10/30/2015		R/R RM 1360/WOMENS RR 2ND STALL TOILET ISN'T FLUSHING MM/10-29-15
FO-331366	10/29/2015			R/R 1ST FLR MENS RR (ONLY ONE ON FLR) THE ONLY URINAL IS BAGGED TT/10-29-15
FO-331374	10/29/2015			R/R 1ST FLR Drinking Fountain adjacent to room 1209 is coming off the wall and needs to be addressed before someone runs into it and completely knocks it off the wall. MM/10-29-15

WO	Recieved	Finished	Total	Request
FO-331382	10/29/2015	10/30/2015		**POWERVAC JETT /VAC DRAINS 10/30/15 JWT EMERGENCY PLUM R/R BSMT HALLWAY NEAR CLASS/LAB RM 55 FLR DRAINS ARE BACKING UP GS/10-29-15
FO-331416	10/30/2015			URINALS CONTINUOUSLY RUNNING. BOTH MEN'S RESTROOM - 1ST FLOOR. TT/10-30-15
FO-331425	10/30/2015			Trade: Plumber Priority: High Repair leak in distilled water line in room 4021. DI shutdown will be required. DB/10-30-15
FO-331444	10/30/2015			TOILET IS PLUGGED. 1ST STALL. 1ST FLOOR LADIES RESTROOM NEAR LUNCH ROOM. TT/10-30-15
FO-331445	10/30/2015			1st floor Women - old restroom, handicap toilet, leaks at the bottom when someone is seated and the toilet is flushed. Please repair. TT/10-30-15
T - Roofing			14	
FO-331126	10/28/2015			R/R 4TH FLR HALLWAY NEAR MENS RR 4226 ROOF LEAKING
FO-331128	10/28/2015			R/R 3RD FLR "E" BLDG STRWL F ROOF LEAKING
FO-331129	10/28/2015			PLEASE REPAIR WATER COMING IN THROUGH ROOF AND WALL BEAMS. ROOM 3009.
FO-331139	10/28/2015			ACTIVE LEAK 2ND FL TRACK, BASKETBALL COURT AREA
FO-331144	10/28/2015			RM 330 ACTIVE CEILING LEAK
FO-331144	10/28/2015			RM 330 ACTIVE CEILING LEAK
FO-331173	10/28/2015			R/R WHARE HSE AREA WEST SIDE BY OVERHEAD DOOR FACING FREEWAY ROOF LEAK
FO-331240	10/28/2015			R/R RM 136 We have a roof leak on the south end of the building.
FO-331245	10/28/2015			R/R RM 4606 HAS A CLNG LEAK
FO-331250	10/28/2015			R/R RM 2155 in the dean's actual office, the ceiling has a leak, again, it needs to be checked TODAY please
FO-331253	10/28/2015			R/R 4TH FLR MUSIC/PHOTOGRAPHY DEPTS NEAR RM 4228 CLNG TILES HAVE FALLEN DUE TO ROOF LEAK
FO-331271	10/28/2015			R/R 1ST FLR MAIN ENTRANCE SOUTH LOBBY ROOF LEAK
FO-331274	10/28/2015			R/R RM 126 - 3 AREAS WHERE ROOF IS LKNG
FO-331335	10/29/2015			4TH FL NEAR ELEV ACTIVE CEILING LEAK, PLEASE UPDATE DONNA IN THE DEANS OFFICE
Medium			163	
T - Carpenter			28	
FO-328492	10/1/2015	10/1/2015		Left front entrance door not closing properly and can't secure area overnight.
FO-328513	10/1/2015	10/7/2015		Replace ceiling tiles in T7 magnet facility that were removed due to flooding from a leak that has been fixed. Contact Robin Roberts at rroberts@med.wayne.edu or 577-1747 for access to room. For safety reasons do NOT enter room without contact
FO-328595	10/1/2015	10/2/2015		On one of the doors leading to the alley, door#620-13-E the mechanism that holds this door open has broken. It was unattached so that this door could be locked. Please repair.
FO-328681	10/5/2015	10/5/2015		Purdy Library, 4th floor, Rooms 422, 423, 424 Doors to all three offices stick and are difficult to open and close. Please repair. Thank you.
FO-329140	10/7/2015	10/8/2015		Trade: Carpenter Priority: MediumThe west door into lab 1540 will not latch and lock without human assistance. This lab is in the EDC part of the building.
FO-329161	10/7/2015	10/8/2015		Carpenter install gas bottle safety rack for 4 tanks. See engineer.
FO-329227	10/8/2015	10/19/2015		Carpenter; MediumPlease insulate, for noise control, the bottom pan of A/C Unit that is exposed in the TV Studio. The unit is making intermittent noise that keeps them from recording.

WO	Recieved	Finished	Total	Request
FO-329253	10/8/2015	10/9/2015		Window off track in room 2145 due to high winds.
FO-329295	10/9/2015	10/12/2015		Carpenters --Priority Medium Please attach pneumatic tubing for handicap control for Theatre door # 1
FO-329296	10/9/2015	10/12/2015		Carpenters-- Priority mediumPlease replace ceiling tiles by room 122
FO-329342	10/10/2015	10/12/2015		Repair lock on the door to the Ticket Booth at Matthaei Stadium. Door #02302. Lock needs R/R. Reported by Bob Ostrowski and Erica Evans.
FO-329501	10/13/2015	10/15/2015		Room 0208 at Elliman has many missing ceiling tiles they need to be replaced.
FO-329525	10/13/2015	10/15/2015		CARPENTERS PLEASE REPLACE STAINED CEILING TILES OUTSIDE ROOM 201.1.....2nd Floor - Repair possible ceiling leak outside Room 201 that is causing damage to wall inside Room 201. EA/10-9-15
FO-329561	10/13/2015	10/14/2015		2nd floor women's rest room lock is sticking. Keys are not turning the lock.
FO-329570	10/14/2015	10/15/2015		Trade: CarpenterPriority: Medium Main door won't close. Need alignment.
FO-330520	10/20/2015	10/22/2015		STE 100 DOOR OFF THE STAIRS NOT LATCHING, ALSO INSIDE DOOR NEXT TO STE 100 NOT LATCHING...PLEASE SEE GERI WITHIN STE 100 FOR EXACT DETAILS
FO-330646	10/21/2015	10/22/2015		Trade: Carpenter Priority: Medium Squirrels are getting into building, please seal opening at base of column at entrance to EDC on Warren side of building. See Rocky for exact location.
FO-330707	10/21/2015	10/22/2015		In suite 2590, the lock on the door to Rm. 2521 needs repair. This was previously repaired under FO-329145, but it didn't last and needs repair again.
FO-330728	10/22/2015	10/22/2015		Carpenter R/R RM 00051.1/MECH RM please repair door in room 51.1 will not close medium pr
FO-330844	10/23/2015	10/28/2015		Remove and replace a ceiling tile with mold in room 1209 Elliman. Replace two missing ceiling tiles.
FO-330879	10/23/2015	10/26/2015		Women's bathroom, door sticks.
FO-330880	10/23/2015	10/26/2015		Men's restroom, door lock sticks.
FO-330954	10/26/2015	10/27/2015		Trade: Carpenter: Priority: mediumDoor to boiler room is not working, will not latch, please repair.
FO-331054	10/27/2015			Carpenter / locksmith, clean and lubricate panic bar on the East entry gate to the play ground located on E. ferry Bar sticks and leaves the area unsecured priority medium
FO-331104	10/27/2015			Trade: CarpenterPriority: MediumBehind elevator at student study area blind fell off. kindly re-install.
FO-331175	10/28/2015	10/29/2015		Trade: Carpenter Priority: MediumPlease replace leaking door closer on the door leading to the center stair well on the 3rd floor of the old lab wing, its the west door.
FO-331281	10/28/2015			Replace missing ceiling tile in server room. Contact David Wissbrun 7-0712 for questions.
FO-331461	10/30/2015			Locksmith Med. PriorityDoor is not closing and locking. sometimes it catches on strike plate.
T - Electrician			56	
FO-328687	10/5/2015			**ADDING ELECTRICIAN: Check operations on condensate pump #1 in room 32. Per Engineer contacts sticking causing pump to continually run. See Ron Clark Pipefitter: Repair condensate pump #1 at Alumni House/President's Apartment Mechanical Room 32.
FO-328711	10/5/2015	10/7/2015		Purdy Library 1st Floor Room 125.Clock over entrance to room 125 stopped working. Please repair.Thank you.
FO-328720	10/5/2015	10/9/2015		Electricians- med priority- Please repair malfunctioning cutoff on the MCC panel for exhaust fan 4b.
FO-328760	10/5/2015			**ADDING LABORER: Remove hot water heater and all plumbing debris from sump pump project from basement mechanical room. See Don Bear for assistance if needed (**) PO REQ DK 9/14 Sump pump backing up. Clear temporary and evaluate DB/
FO-328763	10/5/2015			**ADDING ELECTRICIAN: Please repair electrical switch knob on AH in room 120 at the Football Stadium. See Marty (Pipefitter) for detail Repair handle on AH in room 120 at the Football Stadium See Bob O for location ME/10-1-15

WO	Recieved	Finished	Total	Request
FO-328767	10/5/2015	10/5/2015		Evaluate and verify electrical on new submersible sewage pumps ASAP Disconnect existing sump pumps that Plumbers are ready to remove Rewire new pumps and check float switch operation **See Don Bear completed 9/30/15 po Wire pump back in for Plum
FO-329000	10/6/2015			Trade : ElectricianPriority: MediumPlease replace two light fixture at 2nd floor and 3rd floor hallway. This was taken down during heat pump replacement.Ladies working there are complaining being too dark.Please do needful ASAP.
FO-329004	10/6/2015	10/6/2015		Repair the 3 poles at the South end of Student Center.
FO-329052	10/6/2015	10/8/2015		Electricians: R/R RM 401/MENS RR please repair men's room domestic booster pump variable speed drive, it does not modulate and runs continuously causing the pump becomes very hot. Priority: med.
FO-329066	10/6/2015			Electricians- med priority- R/R RM 3218 please replace malfunctioning pressure switch on Quincy Air Compressor. Pleas rewire automatic blowdown so that the cord reaches the outlet.
FO-329135	10/7/2015			Laborer; MediumPlease have the laborer deliver three drums of open loop chemical to the basement machinery room.1) Lokor 2000 TM2) Aquaklean ODP3) Halochlor C
FO-329155	10/7/2015	10/8/2015		Electrician --priority medium R/R BSMT Electric Hotwater tank not heating water need to increase temp but can't find breaker
FO-329192	10/8/2015	10/15/2015		ELECTRICIANS: R/R STM RM Please adjust HIGH Level control float in SUMP (PER PLUMBERS). MED.
FO-329229	10/8/2015	10/12/2015		Electrician; Medium R/R RM 00195/MECH BLR RM Please troubleshoot the cause of blowing 480 volt line fuses for the force draft fan on the #1 Boiler, intermittently.
FO-329258	10/8/2015	10/12/2015		Trade: Electricians Priority: Medium R/R RM 360 Please investigate and repair numerous trouble alarms for the smoke duct detector serving the autoclave room on the third floor.
FO-329306	10/9/2015	10/12/2015		**ADDING ELECTRICIAN: Please verify voltage and phase on condensate pump#2 in fan room #1. **Report findings to John Towle Replace pitted #2 condensate transfer pump in #1 fan room,,,,,,,,,,,,,, RC/10-9-15
FO-329346	10/12/2015	10/13/2015		Meet Rob Muntz at the Generator, and assist him with adjustments to generator, and pick up any information you can.
FO-329351	10/12/2015			LABORER, PLEASE DELIVER 1) A 30 GAL DRUM OF LOKOR 2000M-P (#17010060). FO-327301 PRIORITY-MEDIUM
FO-329382	10/12/2015	10/19/2015		Electricians: R/R RM 00024.10/MECH BLR RM please repair or replace the light fixture next to receiver tank, the bulbs are good. Priority: med.
FO-329392	10/12/2015	10/12/2015		Trade: Electrician Priority: Medium R/R RM 1500 National Time Fire Panel is in a TROUBLE condition and will not reset. NAC panel 3rd floor battery.
FO-329393	10/12/2015	10/22/2015		**ADDING ELECTRICIAN: Relocate power sorce for 3rd floor drinking fountain. See Mike McAlindin for detail (**) PO REQ DK 10/1 HALLWAY 3RD FL NEAR ELEV WATER FOUNTAIN NOT WORKING ,,,,,,,,,,,,,, MM/7-14-15 ,,,,,,,,,,,,,,
FO-329395	10/12/2015			Pick up piping debris from water meter location in sled room. See Gerry if needed
FO-329410	10/12/2015			Electrician needed for lighting. This is a second request...

WO	Recieved	Finished	Total	Request
FO-329546	10/13/2015			<p>**ADDING ELECTRICIAN: Verify voltage and phase on pedestal condensate pump in sump. located in room 25. See Ron Clark</p> <p>**Provide findings to John Towle</p> <p>Repair #2 condensate return pump located in Mechanical Room 25 at Community Arts, (behind AHU-1. The</p>
FO-329558	10/13/2015			Exit signs in conference room 150.2 are out. Please re-lite these Exit signs.
FO-329584	10/14/2015			DENNIS: Please deliver SALT for COOLING TOWERS(appx. 25 bags) to finish the yearscooling needs. MED.
FO-329686	10/15/2015			Electricians, Medium, Replace bad 3 way light switch at chiller room exit door to stairwell.
FO-329765	10/15/2015	10/19/2015		<p>Room 212.1 2 LO - one in office and one in hallway outside of same room.</p> <p>Chandelier of first - 1 LO</p>
FO-329849	10/16/2015			trade electricans priority medium please service generator here at bio-science the top of the exauhst piping flap is open and rain may get into the generator
FO-329869	10/17/2015	10/24/2015		Repair trouble on fire alarm system at General Lectures.
FO-329901	10/19/2015			<p>Elect. Med Priority</p> <p>R/R RM 00027/MECH RM Repair or replace main disconnect on AHU #5. When you close disconnect with handle the knives do not engage the fuse block. One must take an unsafe position to close this disconnect using a 2X4.</p>
FO-329930	10/19/2015	10/20/2015		The clock in 302 is delayed and a SLIS faculty member requested that it be set to the current time. Thank you.
FO-329954	10/19/2015	10/21/2015		<p>trade electricans priority medium</p> <p>R/R ROOF please service exhaust fan unit #18 not working one has a broken switch the other bad conecction</p>
FO-329955	10/19/2015			<p>trade electricans priority medium</p> <p>R/R ROOF please service exhaust fan unit #25 not working one has a broken switch the other bad conecction</p>
FO-330621	10/21/2015			<p>Please transport urinals in stockroom to State Hall</p> <p>Also transport pump to Life Science</p> <p>**See Gerry (Plumber to assist and provide location)</p>
FO-330682	10/21/2015	10/22/2015		<p>ELECTRICIANS:</p> <p>R/R RM 1530 Please inspect/ repair SAFETY LIGHTS in Flammable Storage room 1530. MED.</p>
FO-330683	10/21/2015			<p>Transport duct hoist from Pipe Shop to Elliman.</p> <p>*See Jim Hill for location</p>
FO-330684	10/21/2015			<p>**ADDING ELECTRICIAN: Disconnect water cooler chiller/ re-connect new one.</p> <p>See Gerry (PLUMBER) for detail</p> <p>(**) PO REQ DK 9/28</p> <p>WATER FOUNTAIN IS LEAKING. 13TH FLOOR.,,,,,,,,,,,,,, MP/9-10-15 ,,,,,,,,,,</p>
FO-330750	10/22/2015			CHILLER RM HAS CIRCUIT BREAKER ISSUE PER AFTERNOON ENG SHAH
FO-330754	10/22/2015			<p>**ADDING LABORER; Transport lift to fish bowl for Pipefitters to repair heating unit in ceiling.</p> <p>**See Jim Hill for date needed</p> <p>Pipe fitters: please unplug or replace plugged up reheat lines for room 226.6, the reheat unit is in room 105.4.Priority:</p>
FO-330783	10/22/2015			<p>Electrician; Medium</p> <p>R/R RM 00005/MECH BLR RM Please repair the bad light fixtures located in the boiler room, very dark.</p>
FO-331025	10/27/2015	10/28/2015		<p>Electrician; Medium:</p> <p>R/R RM 322 Repair 4' fluorescent light fixture as needed.</p>
FO-331028	10/27/2015			<p>ELECTRICIANS:</p> <p>R/R LOADING AREA Please install new light switch (with indicator light) outside door of room 1530</p> <p>Flammable Storage Area. MED.</p>
FO-331105	10/27/2015	10/29/2015		<p>Trade: Electrician</p> <p>Priority: Medium</p> <p>Light fixture are making noise. (Indicating battery charging with red LED flickering) East side of the hallway. Very disturbing.</p>

WO	Recieved	Finished	Total	Request
FO-331162	10/28/2015	10/29/2016		Trade: Electrician Priority: Medium R/R BLDG Reset all time clocks in building, we had a power outage today and the clocks are all off by about 1 hour.
FO-331167	10/28/2015	10/29/2015		Trade: Electrician Priority: Medium R/R BSMT AREA Please install new light switch to replace broken switch in the old lab wing basement, located at the base of the east stairwell.
FO-331174	10/28/2015			Trade: Electrician Priority: Medium Some emergency lights did not work during the power outage today, 2 of them are in the landing stairway to boiler room and one is in the boiler room.
FO-331191	10/28/2015	10/28/2015		find FLA to SF #1
FO-331348	10/29/2015			ELECTRICIANS: R/R RM 4341 Please repair 2 light ballast in lab 4341. MED.
FO-331412	10/30/2015			set all building clocks for time change
FO-331415	10/30/2015			assist bridgeway gen. tech at 8:15
FO-331436	10/30/2015			Light crew: please replace burned out and missing light bulbs in middle stair where the vending machines are, there are 5 bulbs either missing or not working and the are is too dark. Priority: med. There are 3 electrical problem. They're 3 mercury bulb th
FO-331457	10/30/2015			Elect Med Priority R/R RM 00055/MECH RM Make necessary repairs or adjustment to PRV 1-4 (EXH FAN #1)
FO-331458	10/30/2015			Elect Med Priority R/R RM 00055/MECH RM Make necessary repairs or adjustment to PRV 1-4 (EXH FAN #2)
FO-331459	10/30/2015			Elect Med Priority R/R RM 00055/MECH RM Make necessary repairs or adjustment to PRV 1-4 (EXH FAN #3)
FO-331460	10/30/2015			Elect Med Priority R/R RM 00055/MECH RM Make necessary repairs or adjustment to PRV 1-4 (EXH FAN #4)
T - Painter			3	
FO-328779	10/5/2015	10/13/2015		Plaster on one area of the wall is buckling.
FO-329500	10/13/2015			Plasterer: please scrape loose ceiling plaster on 2nd floor in stairway area, plaster on the ceiling is falling off in few spots. Priority: med.
FO-330760	10/22/2015			**ADDING PAINTERS; Seal floor in penthouse. **SEE Mike McAlinden for location
				R/R RM 9320 please have plumbers repair drain line from ac-11 in penthouse. possible leak at connection from glass to metal. this water is leaking on lab counter top. the
T - Pipefitter			42	
FO-328483	10/1/2015	10/2/2015		Fitters, please repair leak in steam coil on AHU-1.,,,,,,,,,,,,,, EA/10-1-15 ,,,,,,,,,,,,,,
FO-328615	10/2/2015	10/5/2015		Pipe fitters: please replace heating valve for rm 34 VAV box. Valve body is in command center/DDC area. See Rich H or Dave J. ,,,,,,,,,,,,,, ME/10-5-15 ,,,,,,,,,,,,,,
FO-328624	10/2/2015	10/7/2015		Pipe fitters: please repair hot water supply and return lines to reheat units for the class room 10, lines are plugged up and we don't get any water flow through the coils. Priority : med ,,,,,,,,,,,,, EA/10-2-15 ,,,,,,,,,,,,,,
FO-328661	10/4/2015	10/5/2015		**REFER TO ELECTRICIAN WORK ORDER FO#328687 JWT Repair condensate pump #1 at Alumni House/President's Apartment Mechanical Room 32. The alternator switch contacts are staying closed, causing the pump to run continuously. ,,,,,,,,,,,,, RC/10-5-15 ,
FO-328683	10/5/2015	10/7/2015		PF med. Priority Please install valve on main steam header in boiler room to drain water and condensate. ,,,,,,,,,,,,, EA/10-5-15 ,,,,,,,,,,,,,,
FO-328684	10/5/2015	10/9/2015		PF med. Priority Please install valve on main steam header in fan room behind engineers office to drain water and condensate. ,,,,,,,,,,,,,, EA/10-5-15 ,,,,,,,,,,,,,,
FO-328729	10/5/2015	10/9/2015		Fitters please repair steam leak in coil on AHU-1. ,,,,,,,,,,,,,, ME/10-5-15 ,,,,,,,,,,,,,,
FO-329235	10/8/2015	10/9/2015		2nd Floor - Repair possible ceiling leak outside Room 201 that is causing damage to wall inside Room 201. ,,,,,,,,,,,,,, EA/10-9-15 ,,,,,,,,,,,,,,
FO-329266	10/9/2015	10/19/2015		Pipefitters to remove all OOS ERC coils located in mechanical room 4038. Old system possibly contains glycol EOHS should be involved. ,,,,,,,,,,,,,, EA/10-9-15 ,,,,,,,,,,,,,,
FO-329305	10/9/2015			(**) PO REQ DK Replace pitted #2 condensate transfer pump in #1 fan room.,,,,,,,,,,,,,, RC/10-9-15

WO	Recieved	Finished	Total	Request
FO-329538	10/13/2015	10/23/2015		trade pipefitters priority medium please replace cooling tower float valve cant get float to shut off water supply and cant make any adjustments due to rust ,,,,,,,,,, ME/ 10-13-15 ,,,,,,,,,
FO-329585	10/14/2015	10/20/2015		**REFER TO FO#320716 JWT Pipe fitters: please repair reheat coils for rooms 226.6 and 226.7, both lines to these units are plugged up and we get minimum heat from them. the reheat units for these rooms are in room 105.4. Priority: med. ,,,,,,,,,
FO-329586	10/14/2015			**PRIORITY LOWERED / WORK IN PROGRESS JWT #3 BOILER VALVE FLANGE LEAKING BETWEEN NON RETURN AND HEADER STOP VALVE. CONTACT ENGINEER.,,,,,,,,,, ME/10-14-15 ,,,,,,,,,
FO-329705	10/15/2015			FITTERS: Please repair leaking coil in Unit Heater (UNH 002)fo#325836 in Penthouse MED. ,,,,,,,,,, EA/10-15-15 ,,,,,,,,,
FO-329821	10/16/2015			Trade: Pipefitter Priority: Medium On H&V#10 the asbestos insulation on the steam piping has been damaged and we need to have an abatement done. This is located in the old lab wing basement. ,,,,,,,,,, CB/10-19-15 ,,,,,,,,,
FO-329826	10/16/2015			Trade:Pipefitter Priority: Medium In the animal quarters room 0245 the heating valve is not closing causing the room to over heat so I need a new heating valve installed on the unit above the ceiling.,,,,,,,,,, EA/10-19-15 ,,,,,,,,,
FO-329851	10/16/2015			To pipe fitters. Please replace the defective steam valve and operator on supply fan 1 for the auditorium.,,,,,,,,,, ME/10-19-15 ,,,,,,,,,
FO-329900	10/19/2015			PF Med Priority Drain line on vent stack in boiler Rm plugged. Please clear and provide means to drain and or clean line ,,,,,,,,,, EA/10-19-15 ,,,,,,,,,
FO-329905	10/19/2015	10/26/2015		Pipefitters; Medium: Valve leaking above ceiling men's restroom 3rd floor at access hatch ,,,,,,,,,, ME/10-19-15 ,,,,,,,,,
FO-329910	10/19/2015			(**) PO REQ DK 10/29 Trade: Pipe Fitters Priority: Medium Install fittings on the cooling coils so I can blow them out with air, on AHU#1,2,3. ,,,,,,,,,, JH/10-19-15 ,,,,,,,,,
FO-329952	10/19/2015	10/21/2015		Pipefitters- please replace air vent on water line for two season system on supply side that is dripping and corroded badly.,,,,,,,,,, ME/10-19-15 ,,,,,,,,,
FO-329953	10/19/2015	10/19/2015		**DUPLICATE/ REFER TO FO#329952 PIPEFITTERS- please replace air vent on water line for two season system on return side that is dripping and corroded badly.
FO-329968	10/19/2015	10/23/2015		Fitter repair steam leak at reducing station.,,,,,,,,,, JH/10-19-15 ,,,,,,,,,
FO-329969	10/19/2015			Trade: Pipefitters Priority: Medium Please repair steam leak in AHU #1 heating coil. ,,,,,,,,,, EA/10-20-15 ,,,,,,,,,
FO-330527	10/20/2015			(**) PO REQ DK 10/29 Pipefitters to replace heating hot water pumps #4 and 3 located in UGL basement. The #4 pump leaks and is OOS. The #3 pump is running but intermittently leaks. Both these existing pumps have had seals and bearings replace 3 times in
FO-330649	10/21/2015	10/22/2015		Fitter install condensate drain line on control air line to bedding dispenser. ,,,,,,,,,, JH/10-21-15 ,,,,,,,,,
FO-330720	10/22/2015			pipefitter R/R ROOF please repair cooling tower drain line medium pr.,,,,,,,,,, EA/10-22-15 ,,,,,,,,,
FO-330725	10/22/2015	10/26/2015		pipefitter R/R RM 00008/MECH RM please install air compressor fitting on Aahu 3 chill coils medium pr ,,,,,,,,,, EA/10-22-15 ,,,,,,,,,
FO-330726	10/22/2015	10/26/2015		pipefitter R/R RM 00008/MECH RM please install air compressor fitting on ahu 4 chill coils medium pr ,,,,,,,,,, EA/10-22-15 ,,,,,,,,,
FO-330875	10/23/2015	10/26/2015		Please inspect the second floor storage room on the south side of the hall. There are water stains on the ceiling and upper walls. Please contact Ian Studders, ew9618@wayne.edu or Derek Donnellon at ds1464@wayne.edu for a digital photo of the area of co
FO-330916	10/26/2015	10/27/2015		Pipe fitters: please repair or replace reheat control valve for room 300.10, the is leaking through and making the room too hot. the control valve is in room 200. Priority: med. ,,,,,,,,,, JH/10-26-15 ,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-330920	10/26/2015	10/27/2015		Pipefitters: Medium; Repair piping near expansion tank as needed. EA/10-26-15
FO-330936	10/26/2015	10/28/2015		To pipe fitters. Please replace defective chilled water drain valve on the bottom of chilled water line, on AHU-13. ME/10-26-15
FO-330959	10/26/2015	10/28/2015		Pipefitters- please install new supply and return lines from existing valves to hoses to new heat pump. EA/10-26-15
FO-330960	10/26/2015			Pipefitters- please install condensate drain line from new heat pump to condensate pump..... EA/10-26-15
FO-330967	10/26/2015	10/29/2015		PIPEFITTERS- pleaser/r condensate lines by HEX is room 124 that are dripping. to the left of the HEX and behind the HEX. thanks. EA/10-27-15
FO-331055	10/27/2015			Trade: Pipefitter Priority: Medium Replace leaking elbow on condensate vent pipe in old lab wing basement mechanical room 0332. EA/10-27-15
FO-331056	10/27/2015	10/29/2015		Fitters: Chiller supply water stop valve actuator is not working and needs to be repaired or replaced. Medium Priority. ME/10-27-15
FO-331065	10/27/2015	10/28/2015		r n r leaking control actuator on control valve to office JH/10-27-15
FO-331143	10/28/2015	10/30/2015		Pipe fitters: please repair or replace hot water reheat control valve for room 304, it is leaking through and making the room too hot. The reheat valve is in room 206. Priority: med. ME/10-29-15
FO-331209	10/28/2015	10/29/2015		**CANCELLED 10-29-15 JWT check gas regulator at emergency generator tech says diafram sticks at start up
FO-331315	10/29/2015	10/30/2015		fitters repair a leaking pipe nipple on a steam line in the mech. rm. priority medium JH/10-29-15
T - Plumber			34	
FO-328533	10/1/2015	10/7/2015		2nd floor women's restroom hand-cap stall won't flush. GS/10-1-15
FO-328686	10/5/2015	10/7/2015		Plumb. Med Priority repair leaking faucet mens lav. by rm.012. Basement near custodial office. TT/10-5-15
FO-328688	10/5/2015	10/7/2015		Plumb. Med Priority Please repair or replace bad sump pump in pit behind #2 boiler. this pump removes ground water from pipe pit prior to it seeping through the pipe sleeves and in to the fan room..... TT/10-5-15
FO-328719	10/5/2015	10/7/2015		plumb Med Priority Replace bad water flow adjusting valve on eye wash in boiler rm. Will not adjust TT/10-5-15
FO-328728	10/5/2015	10/12/2015		Plumbers please repair leaky faucet in lab 103. MM/10-5-15
FO-329132	10/7/2015	10/9/2015		Trade: Plumber Priority: Medium The chilled water back flow preventer is leaking water onto the floor, please repair. TT/10-8-15
FO-329133	10/7/2015			PLUMBERS- pleases r/r leaking pipe in basement at doorway from old cafeteria to stairwell. Area marked with rag. Must be supply leak. constant minor leak all summer even when steam was off. TT/10-12-15
FO-329214	10/8/2015	10/12/2015		Ceiling leak from cracked drain possible from roof sump located in 2nd floor south stairwell GS/10-8-15 **Ceiling is non-asbestos **catwalk to be closed during repairs. See Corey Blair for procedure from Bill Kemp Carpe
FO-329219	10/8/2015	10/10/2015		**REFER TO FO#325551 JWT ACROSS FROM RM 355, DRINKING FOUNTAIN NOT WORKING TT/10-8-15
FO-329509	10/13/2015	10/14/2015		TOILET SEAT IS LOOSE. 4TH FLOOR WOMEN'S RESTROOM. TT/10-13-15
FO-329563	10/13/2015	10/14/2015		Middle sink is draining very slowly..... TT/10-14-15
FO-329591	10/14/2015	10/21/2015		4th floor kitchen faucet is constantly dripping water MM/10-14-15
FO-329599	10/14/2015			Trade: Plumber Priority: Medium In engine lab 1330 a water shut off valve is leaking by in the closed position, please install new valve. The valve is located at floor level and the water line comes up from the basement. TT/10-14-15 ,,,

WO	Recieved	Finished	Total	Request
FO-329670	10/15/2015			The emergency shower in Rm 200.1 is dripping..... TT/10-15-15
FO-329833	10/16/2015	10/20/2015		please install a connection, valved in the supply line to outdoor fountain, to allow air compressor line to blow out line for freeze protection DB/10-19-15
FO-329871	10/18/2015	10/20/2015		Repair #1 sump pump serving President's Apartment chiller and McGregor receiving ramp outside sump and located in mechanical Room 32 at Alumni House. It will not pump water. #2 pump is currently working. DB/10-19-15
FO-329899	10/19/2015	10/22/2015		Trade: Plumber Priority: Medium Please repair small air leak in the lab air manifold for the south lab table at the west end in lab 470. Leak is marked. TT/10-19-15
FO-329939	10/19/2015	10/20/2015		R/R 1ST FLR MENS RR 3RD STALL HAS PAPER TOWEL PLUGGED IN TOILET TT/10-19-15
FO-329949	10/19/2015	10/21/2015		R/R 1ST FLR WOMENS RR NEXT TO JANITORS' CLOSET RM 1142 1ST STALL IS PLUGGED UP TT/10-19-15
FO-330555	10/20/2015	10/21/2015		R/R 1ST FLR (ONLY)MENS RR THE FIRST 2 SINKS FAUCETS AREN'T WRKNG SENSORS MAY NEED BATTERIES TT/10-21-15
FO-330580	10/20/2015	10/22/2015		Plumber repair long flush middle stall women rest room 2nd floor..... MM/10-21-15
FO-330596	10/20/2015	10/29/2015		3rd floor ladies r/r - please fix faucet GS/10-21-15
FO-330594	10/20/2015	10/28/2015		1st floor ladies toilet does not flush in 3rd stall to left as you enter the restroom. thank you GS/10-21-15
FO-330598	10/20/2015	10/29/2015		3rd floor ladies toilet in second stall not flushing. toilet is covered with plastic and sign on stall door. thank you GS/10-21-15
FO-330620	10/21/2015	10/21/2015		PLUMBER DEPT- R/R RM 00086/JANITORS' CLOSET PLEASE REPAIR LEAKING SINK SHUT OFF IN CUSTODIAN CLOSET ROOM 86,FAUCET WONT SHUT OFF ALL THE WAY CAUSING WATER IN HOSE TO FLOOD BASEMENT FLOOR PRIORITY MED TT/10-21-15
FO-330638	10/21/2015			Plumbers: please repair or replace the handicap urinal in men's room 209, it doesn't flush. priority: med. GS/10-21-15
FO-330758	10/22/2015	10/29/2015		3RD FL LADIES RM NEAR CMG AREA, 1ST STALL TOILET SEAT LOOSE MM/10-22-15
FO-330862	10/23/2015			Plumbers- med- Replace seals and bearing on domestic water booster pumps 1& 2 in basement of Elliman Research. DB/10-26-15
FO-330958	10/26/2015	10/27/2015		Plumbers- medium. Please repair toilet that won't flush properly (flush valve problem) in end stall of ladies restroom (No numbers on rooms) TT/10-26-15
FO-330956	10/26/2015	10/29/2015		URINAL COVERED WITH BAG. 3RD FLOOR MEN'S RESTROOM. MM/10-26-15
FO-331178	10/28/2015			Plumbers please repair toilet, left side, in 2nd floor women's restroom (toilet leaks when flushed) MM/10-29-15
FO-331180	10/28/2015			SINK NOT DRAINING. ROOM 470. NEAR FUME HOOD #3. TT/10-29-15
FO-331403	10/29/2015			First floor ladies bathroom one of the toilet seats is loose. TT/10-29-15
FO-331437	10/30/2015			Plumbers: please install a floor drain cover on the floor drain in the hallway in front of room 029. priority: med. TT/10-30-15
Low			458	
T - Carpenter			78	
FO-328537	10/1/2015			TEAM LEADER TIME (OCTOBER 2015)
FO-328570	10/1/2015	10/2/2015		CARPENTERS TO REMOVE THE SCAFFOLD & INSTALL MISSING CEILING TILE 1ST FLOOR LOBBY
FO-328625	10/2/2015	10/5/2015		Carpenters: please repair the door to office 126, it constantly vibrating and making noise. priority: low.
FO-328641	10/2/2015	10/2/2015		CARPENTERS TO PATCH THE 2ND FLOOR RAMP NEXT TO CARPENTERS SHOP ENTRANCE
FO-328644	10/2/2015	10/6/2015		On the Mack side, next to the 2nd floor elevator and under the AED box, there is wall tile damaged that needs repair.
FO-329015	10/2/2015	10/15/2015		At the 1st door of room 4545 (coming from the Mack side) there is damage to the corner guard on the wall that needs repair or to be replaced.

WO	Recieved	Finished	Total	Request
FO-328670	10/3/2015	10/6/2015		CARPENTERS - Please repair the door latch to Ladies restroom 310. Restroom is not accessible.
FO-328715	10/5/2015	10/6/2015		SHELVING IN 1ST FLOOR JANITOR CLOSET. 3 ROWS NEAR SINK OR THE NORTH BACK WALL.
FO-328717	10/5/2015	10/5/2015		CARPENTERS TO LUBRICATE FREEZER MOTOR LUNCH ROOM
FO-328742	10/5/2015			carpenters- low priority- build and install plywood shields to prevent pumps freezing during severe cold temperatures on deaerator and surge tank.
FO-328754	10/5/2015	10/7/2015		CARPENTERS, PLEASE REPLACE MISSING & WATER DAMAGED CEILING TILES.PRIORITY-LOW
FO-328997	10/5/2015	10/28/2015		Please replace badly stained ceiling tile in Women's restroom off of the main lobby. Thanks
FO-328988	10/6/2015			Repair and Replace Broken Spring And Adjusted Door as Needed
FO-329019	10/6/2015	10/9/2015		R/R RM 3103/LAB 1 or 2 window blinds are broken.
FO-329020	10/6/2015	10/9/2015		R/R RM 3106/LAB Few window blinds don't work.
FO-329022	10/6/2015	10/9/2015		R/R RM 3117/LAB Few window blinds need fixed.
FO-329054	10/6/2015	10/7/2015		R/R RM 00006/CLASS LAB The rubber edging on the step up to our editing suites is loose and needs securing. We've had several students trip and one who has twisted her ankle. This is in the 4130 Suite. Your timely attention to this matter is appreciat
FO-329111	10/7/2015	10/8/2015		Location: the south west exterior barrier-free access ramp to lower level. Three steel plate covers over the trench drain are uneven and unstable. Replace shims below plates and anchor plates to stabilize.
FO-329156	10/7/2015			R/R hole in wall/overhang where birds are entering the building. North/West corner.
FO-329198	10/8/2015			R/R RM 3210 The lock is not working correctly. The door will not close properly. Thank you.
FO-329298	10/9/2015	10/12/2015		Replace ceiling tiles in hall outside room 122. Tiles were damaged by a leak. See WO # FO-326480.
FO-329304	10/9/2015	10/12/2015		R/R SECOND FLOOR WINDOW OVER NORTH WEST DOOR. WHEN DONE HAVE PAINTERS PAINT TO MATCH.
FO-329308	10/9/2015	10/12/2015		R/R STOCK RM CABINET DOOR (Under Laminator) KEY IS BROKEN OFF IN DOOR LOCK (SEE LORETTA IF NECESSARY)
FO-329325	10/9/2015	10/12/2015		R/R ENTRY Door #082-11N needs new sweep to keep water out of building. Water runs down off the grass and under the door near the hinge area.
FO-329341	10/10/2015	10/12/2015		Repair door to handicapped accessible unisex lavatory located in the ground level hallway of Community Arts next to room 136. The door hits the sloped floor and cannot be opened fully. The hinges are also thrown.
FO-329353	10/12/2015	10/12/2015		Repair hole punched in drywall by door handle. 4th floor hallway entrance opposite elevators. Install backer board and door stop.
FO-329425	10/12/2015	10/13/2015		R/R RM 1043 TROUBLESHOOT I believe the battery needs to be change, key code will not work
FO-329455	10/12/2015	10/14/2015		Signage Correction Needed room 28 Missing Letter room 113 Crooked Sign room 131Crooked Sign 2 floor bathroom (South)Missing sign room 300-314Sign displaced 3rd Floor North - Evaluation Process SignTo Be Replaced room 357Crooked Sig
FO-329456	10/12/2015	10/15/2015		West entrance to building- Hanging sign over stairway to basement level needs to be removed - then patch holes and paint
FO-329448	10/12/2015	10/15/2015		3 North faculty suite and missing several ceiling tiles- please replace
FO-329457	10/12/2015	10/14/2015		All unisex bathrooms in the building have no coat/purse hooks anywhere in the room. Please place hooks in each bathroom (there is one on each floor)
FO-329441	10/13/2015	10/13/2015		CARPENTERS TO INSTALL STOP / YEILD SIGN @ END OF THE EXIT SIDE BEFORE SIDEWALK
FO-329442	10/13/2015	10/15/2015		CARPENTERS TO TAG ALL EXTERIOR DOORS
FO-329443	10/13/2015	10/13/2015		CARPENTERS TO TAG ALL EXTERIOR DOORS

WO	Recieved	Finished	Total	Request
FO-329444	10/13/2015	10/13/2015		CARPENTER TO REPAIR SAGGIN DOOR HANDLE CASS AVE MAIN ENTRANCE INSIDE VESTIBULE DOOR
FO-329445	10/13/2015	10/15/2015		CARPENTERS TO TAGG SOFTBALL & SHED EXTERIOR DOORS
FO-329465	10/13/2015	10/15/2015		Ceiling tiles in the basement of Elliman are missing by rooms 0406 and 0413 and a tile by room 0225 is moldy and has been called in many times and has not been replaced yet. Please replace the ceiling tiles.
FO-329474	10/13/2015	10/14/2015		The metal door that leads into the main office near room 107 is not closing on its own.
FO-329537	10/13/2015	10/14/2015		The entrance door lockset is apparently worn out, as most persons have to wiggle their keys to gain entrance to the 3rd floor suite. Can we have the lock mechanism replaced with identical key?
FO-329540	10/13/2015			Request for door stops
FO-329777	10/14/2015			Instructor reports that in 1109 Sci Hall classroom, the boards are not sliding. Her PHI 1050 class meets M W at 12:50p. Will the problem be resolved by next class session. Please let us know. Thanks
FO-329666	10/15/2015	10/20/2015		SOUTH SIDE ENTRANCE WEST WALL THE CAP IS LOOSE. CARPENTERS TO RE-ATTACH.
FO-329693	10/15/2015	10/15/2015		CARPENTERS, PLEASE REPAIR DEADBOLT LOCK ON DOUBLE DOORS.PRIORITY-LOW
FO-329723	10/15/2015	10/20/2015		CARPENTERSREPLACE BAD CEILING TILES OUTSIDE OF ROOMS 9115 AND 2206 OF SCOTTHALL
FO-329730	10/15/2015	10/28/2015		CARPENTER TO CHANGE OUT DEFECTIVE FREEZER MOTOR BREAKROOM CARPENTER SHOP
FO-329801	10/16/2015	10/20/2015		Wall near women's restroom, wall corner piece has come unglued and is laying on the floor near rest room.
FO-329808	10/16/2015	10/19/2015		1ST FLOOR MEN'S RESTROOM THE 3RD STALL THE DOOR IS LOCKED. PLEASE UNLOCK.
FO-329823	10/16/2015	10/16/2015		CARPENTERS TO REHANG BLINDS/ DRAPES THAT HAVE FALLEN. PRESIDENTS APARTMENT
FO-329934	10/19/2015	10/23/2015		Please have Carpenters pick up pallet racking from the IT department , 100 Antoinette. IT contact Alex Stephens , 577-2079. See Lynda Kinder/Larry Cook for details.
FO-329960	10/19/2015	10/21/2015		A drop ceiling tile is cracked and bowed. It is exposing the insulation. Please repair the ceiling tile.
FO-330511	10/20/2015			R/R PRESS BOX Please replace damaged ceiling tile caused from a leak on the 2nd floor of the pressbox - south side. Bob Ostrowski has specifics. Thank You.
FO-330587	10/20/2015	10/21/2015		CARPENTERS, DOUBLE DOORS BINDING, PLEASE REPAIR.PRIORITY-LOW
FO-330588	10/20/2015	10/28/2015		CARPENTERS, PLEASE REPLACE WATER STAINED CEILING TILES.PRIORITY-LOW
FO-330619	10/21/2015	10/22/2015		R/R RM 150 NEED AN END MOLDING FOR MY PARTION RE-ATTACHED SEE LORETTA
FO-330691	10/21/2015			TIM HERR: R/R RM 2534 Please install access door in room 2534 to access short roof above the FLAMMABLE STORAGE ROOM (safety) HIGH
FO-330735	10/22/2015	10/22/2015		R/R RM 150 NEED 2 DRAWER FILE CABINET (TAN) LEGS ADJUSTED/BALANCED
FO-330781	10/22/2015			CARPENTERS TO SET UP SCAFFOLD FOR RUSSELL BARLOW (PLASTER) DUE FRIDAY MORNING MAIN STAIR WELL BETWEEN 1ST & 2ND FLOOR
FO-330896	10/26/2015			Service to radiator complete, carpenter repairs to rework and fix radiator panel enclosure need to be completed. Director of Engineers office.
FO-330918	10/26/2015	10/26/2015		CARPENTERS TO HANG WALKWAY SIGNAGE ON THE SLIDING DOOR LEADING OUT
FO-330932	10/26/2015			CARPENTERS,PLEASE SECURE #3 FFC UNIT TO WALL.PRIORITY-LOW
FO-330933	10/26/2015			CARPENTERS, PLEASE REPAIR #2 WINDOW , WILL NOT OPEN OR CLOSE.PRIORITY-LOW
FO-330944	10/26/2015	10/26/2015		CARPENTER TO ROTATE LOCK ROOM #115 CYLINDER /UPSIDE DOWN
FO-330968	10/26/2015			WINDOW IS STUCK OPEN. ROOM 360.
FO-330973	10/26/2015	10/27/2015		CARPENTERS TO REPAIR LOOSE CORNER GUARD CONFERENCE ROOM " B "

WO	Recieved	Finished	Total	Request
FO-331121	10/28/2015	10/28/2015		CARPENTERS TO ATTEND RESPIRATOR FIT TEST
FO-331125	10/28/2015	10/28/2015		WORK ORDER TO COVER N95 MASK FOR FIT TEST.
FO-331181	10/28/2015	10/29/2015		CARPENTERS TO CEMENT DRAIN 1ST FLOOR BATHROOM ROOM 135.2. REPLACE CEILINGS TILES & TAKE DOWN SCAFFOLD
FO-331200	10/28/2015	10/29/2015		replace ceiling tiles outside room 6307.4
FO-331265	10/28/2015	10/28/2015		CARPENTERS TO INSTALL ACCESS PANEL N/W STAIRWELL BETWEEN 2ND & 1ST FLOOR
FO-331307	10/29/2015	10/29/2015		cut lens to size
FO-331361	10/29/2015			CARPENTRY please caulk around window in ladies restroom 1st floor at university services (down the hall from Larry Fodor). water penetrates into restroom whenever there is a good rain. Mortar outside looks OK, but please check for possible areas of penetr
FO-331395	10/29/2015			CARPENTERS, R/R BSMT HALLWAY PLEASE REPAIR DAMAGED FLOOR TILES IN HALLWAY NEAR ROOM 0384. PRIORITY-LOW
FO-331387	10/29/2015			CARPENTERS TO HANG BEAUTIFICATION PLAQUE
FO-331432	10/30/2015			CARPENTERS TO REPAIR BROKEN ROOM DARKING SHADE CONFERENCE ROOM #B OR #C
FO-331446	10/30/2015			Please repair - In 1st floor hall as you exit the south door of suite 1600 and right before the elevator, a piece of tile is missing. Op. Mgr. for EACPHS put the missing tile in the Bus. Office, Rm. 2602.
FO-331475	10/30/2015			Rackham, R/R Ball Room I am not the Building Coordinator for Rackham, one of my co-workers who frequents Rackham reported that the knob on the door to the ball room is hanging loose and makes it difficult to enter the area. Please repair. Thank yo
FO-331477	10/30/2015			R/R BSMT Audio/Visual room in Purdy basement with brown door knob is broken. The door to the room is brown. Location of room is next to Stairwell 8.
FO-331478	10/30/2015			R/R RM 3121 REPLACE DAMAGED Ceiling tiles THATS FALLEN DOWN In lab near fume hood OCCUpant Dr. Paula Dore-Duffy (7-0354) for questions.

T - Electrician

137

FO-328460	10/1/2015	10/2/2015		Time for Electricians Safety Meeting for month of October, 2015.
FO-328461	10/1/2015			Time for Laborer to clean the Trades shops, and do work throughout the University.
FO-328462	10/1/2015			Time to Repair/Rebuild clocks throughout University.
FO-328484	10/1/2015			The light fixture over the northwest lobby entrance door, at the top of the ramp is missing. Please repair. This light fixture would allow a safer entry to the theatre. Thanks
FO-328488	10/1/2015			Hallway in front of Range 72 has an electrical problem.
FO-328489	10/1/2015	10/9/2015		Hallway outside of Rooms 1371 and 1365 has electrical problems.
FO-328490	10/1/2015	10/7/2015		(Hallway in back of Range 323 has an electrical problem. (2nd floor)
FO-328500	10/1/2015			Room 119 has 4 electrical problems.
FO-328505	10/1/2015	10/28/2015		Cafeteria Serving area at Scott Hall. 5 of the 6 ceiling lights in the serving area of the cafeteria are out. This is the 3rd request/submission over the past 3 months. Please replace bulbs in ceiling lights. Lights are compact flourescent bulbs. We don
FO-328517	10/1/2015	10/2/2015		Repair light fixture outside of room 133.
FO-328539	10/1/2015			Time to enter time on TMA, and Payroll for the month of October.
FO-328542	10/1/2015	10/8/2015		Repair the bad clock located on the 2nd floor near Stair #1.
FO-328544	10/1/2015			Light out in stairway leading to basement near south entrance of building.
FO-328622	10/2/2015			Relamp Flickering light Fixture in MD Lab 2136. There is 1 electrical problem in room 2136.
FO-328632	10/2/2015			Electrician repair 2 receptacle in garage area. Not working.
FO-328675	10/3/2015			Please replace burned out light bulbs in the balcony chandeliers. Thank you.

WO	Recieved	Finished	Total	Request
FO-328676	10/3/2015			Please replace dimmer switch the white light circuit of the pin rail at the south wall. This was an old work order that was never completed. The faulty dimmer switch was removed, but never replaced. The electrical box is still open. The theatre needs t
FO-328682	10/5/2015	10/9/2015		Purdy Library 3rd Floor Lights out over stack ranges 54 - 60. Lamp replacement requested. Thank you.
FO-328710	10/5/2015			18 light fixtures need fluorescent tubes replaced - 17 long, 1 short
FO-328743	10/5/2015			In rooms 4374, 4370, and 4364 Ceiling lighting fixtures need relamping. Room 4374 has 2 electrical problems; Room 4370 has 1 electrical problem; and room 4364 has 2 electrical problems.
FO-328756	10/5/2015	10/30/2015		LIGHT OUT ON 4TH FLOOR EAST IN STAIRWELL NEAR DOOR. PLEASE REPLACE.
FO-328762	10/5/2015	10/8/2015		Repair bad clock in the basement near the elevators/African room.
FO-328770	10/5/2015			Replace 4 keyed light switches with standard light switches in the basement level lobby area, near the restrooms at Rackham. This will allow building personal to shut off lights when the building is unoccupied.
FO-328780	10/5/2015			Remove surface mounted 2' x 4' light fixture in south stairwell second floor landing. To try and determine source of water entering building.
FO-329005	10/6/2015			Hallway between the elevators and STAIR A has an electrical problem. (3rd floor)
FO-329011	10/6/2015			ELECTRICIANS TO REMOVE OUTLET & GREENFIELD WIRE ROOM # 3552 STAIRWELL
FO-329032	10/6/2015			Trade: Laborer Priority: High R/R RM 00000.62/MECH BLR RM Please supply the following chemicals. 1) 2 drums of Lokor 2000M-P - stock # 17010060 2) 2 drums of Halochlor C - stock # 17010100 3) 1 drum of Aquaklean ODP - stock # 17010106
FO-329025	10/6/2015			Repair Exterior Pole Lights, Wall-packs, and check the Timer for proper adjustments.
FO-329053	10/6/2015			**ADDING ELECTRICIAN: Disconnect electrical to each of the 8 heating recirculation pumps as needed per Jim Hill. As Jim gets each new pump installed please install new disconnects when hooking power back up. Charles Redman has new disconnects **Use this
FO-329058	10/6/2015			LIGHTS OUT IN STAIRWELL B MAIN ENTRANCE. PLEASE REPLACE. OLD MAIN. There is 1 electrical problem. The fixture caused the bulbs to spark.
FO-329197	10/8/2015			Trade: Electrician Priority: Low R/R RM 1526/Office the lights will not turn off, this room has a motion sensor but no wall switch, please repair.
FO-329195	10/8/2015			The women's restroom has an electrical problem. (2nd floor)
FO-329196	10/8/2015			Room 1535 has an electrical problem.
FO-329262	10/9/2015	10/9/2015		CEILING TILE BEING REPLACED BY CARPENTERS / ELECTRICIANS TO DISCONNECT LIGHTS @ SEVERAL LOCATIONS ROOMS # 5124,5116,5600,5625,5500,5421, HALLWAYS BY ROOMS # 5411,5450.1, 5463,5565,5545,5530,5520,5518.SEE ED STANCZAK FOR LOCATIONS
FO-329279	10/9/2015			light out rm.1128. There is 1 electrical problem.
FO-329280	10/9/2015	10/28/2015		Shiffman Library has a few electronic clocks that need to be reset. The clocks that need to be reset are in the following locations: Library atrium Library Suite on second floor Room 232 Shiffman Library rooms 112 and 125
FO-329290	10/9/2015			Batteries for Cordless Drills. Phil Oliver 18V, and Eugene Owens 16V
FO-329310	10/9/2015			LABORER -DENNIS- R/R RM 195/MECH RM Please deliver boiler chemicals and salt to Boiler room at 5425 Woodward. Thanks. 1) 6 oxykor 2) 2 nuetramine 3) 2 quest & 4) 12 bags of salt
FO-329332	10/9/2015			1 EP - 2nd - 3rd floor stairwell - west-east.
FO-329333	10/9/2015	10/23/2015		1 EP - Stairwell - Basement - East-West.

WO	Recieved	Finished	Total	Request
FO-329352	10/12/2015			LABORER, PLEASE DELIVER 1)16 BAGS OF SALT (#17010010-1) FO-327301. PRIORITY-LOW
FO-329361	10/12/2015	10/12/2015		Training for UPS at 8AM.
FO-329362	10/12/2015	10/12/2015		Training on the UPS at 9:30 AM.
FO-329363	10/12/2015			The hallway along side of room 130 has 2 electrical problems.
FO-329364	10/12/2015	10/12/2015		Training for UPS at 11AM.
FO-329369	10/12/2015			R/R RM 0100/MECH RM please have laborer deliver 1) 10-5 gallon pails of nitroklenz to room 100 scott hall.
FO-329390	10/12/2015	10/16/2015		Training for the Fountain pump across from Fitness, Friday @ 9:30 - 11:30 AM.
FO-329422	10/12/2015	10/14/2015		Electrician R/R PENTHOUSE repair EF4A VFD. It keeps cycling on and off.
FO-329438	10/13/2015			electricians to attend UPS Training @ 8AM.
FO-329439	10/13/2015	10/13/2015		Electricians to attend UPS Training @ 9:30 AM.
FO-329440	10/13/2015	10/13/2015		Electricians to attend UPS Training @ 11AM.
FO-329510	10/13/2015			Room 9201 - 1 LO .There is 1 electrical problem in room 9201.
FO-329518	10/13/2015			3rd floor - W R/R Light Flickering.
FO-329524	10/13/2015			Laborer, please return gondola from room 3125 to roof..... Se Gerry (PLUMBER) if needed
FO-329532	10/13/2015			The timer for the lights along the sidewalk in front of the Elliman building need to be reset. Lights are on during the middle of the day and off at 6 pm. Timer is located in Elliman and has been reset in the past by the building engineer. Remi
FO-329533	10/13/2015	10/16/2015		Check the timer for the lights located on the outside walls of the Mazurek Medical Education Commons. They were on at 11 am on both buildings. Contact Sheryl MacGillis 7-1446 if you have questions.
FO-329536	10/13/2015			Several lights are not functioning in the Legal Aid section of the first floor. Please have a bulb changer look at replacing the burnt-out tubes.
FO-329596	10/14/2015	10/22/2015		Trade: Electrician/Lighting Crew Priority: High Room 1550 Utility Fuel Hub has burnt out light bulbs please install new ones. This room is extremely dark...
FO-329639	10/14/2015			There is 1 electrical problem behind the cage in the Grounds dept.
FO-329683	10/15/2015	10/15/2015		Please repair clock in room #65.
FO-329696	10/15/2015			Complete repairs on the #1 generator found during PM maintenance.
FO-329706	10/15/2015			Deliver a pallet of Lamps to the Retro Lighting Crew.
FO-329707	10/15/2015			Deliver Lift to Maccabees for Electricians to change lights on Clock.
FO-329722	10/15/2015			Trade: Electrician Priority: LowLights in EDC office 1524 are staying on all the time. This office has a motion sensor.
FO-329749	10/15/2015			Please replace the burned out lights in lab 2212.
FO-329770	10/15/2015	10/15/2015		Time to attend training for Transfer Switch on Generator.
FO-329803	10/16/2015			light out. there is 1 electrical problem.
FO-329844	10/16/2015	10/19/2015		ELECTRICIANS TO FIND LOSE OF POWER TO ADA DOOR OPENER ROOM 1600 (SEE WILLIE TELLIS FOR LOCATION)
FO-329875	10/19/2015	10/21/2015		The passenger elevator has 2 electrical problems.
FO-329879	10/19/2015			Deliver 15 bags of salt to boiler room at Matthaei
FO-329962	10/19/2015			Electrician R/R PENTHOUSE repair VFD for AH-1
FO-329973	10/19/2015			Electricians- Med Priority- R/R RM 3237 Please deliver 1) 2 5gal units of Halochlor 2) 5 gal of Lokor. to penthouse.
FO-329974	10/19/2015			Electricians- med priority R/R RM 1195/MECH-BLR RM Please deliver 1) 1 barrel of Oxycor, 2) 1 Barrel of Quest, 3) 2 5 gal units of neutramine.

WO	Recieved	Finished	Total	Request
FO-329980	10/19/2015			Room 2323 has lights out. Please replace. There is 1 electrical problem.
FO-330534	10/20/2015	10/21/2015		CLOCKS ARE NOT WORKING. CONFERENCE ROOMS #1 AND #3. CHECK ALL CONFERENCE ROOMS.
FO-330584	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. AH-4
FO-330585	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. AH-5
FO-330586	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. AH-1
FO-330590	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. AH-2,
FO-330591	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. EF5-A
FO-330593	10/20/2015			Electrician, R/R PENTHOUSE blow dust out of 6 VFD's for fans in the penthouse. EF5-B
FO-330595	10/20/2015			1 EP - Outside 219 - The fixture has been relamped; bulbs are not working.
FO-330669	10/21/2015			Laborer, please remove old meter valve and piping in mech room, see Jerry for exact location **See Gerry (PLUMBER) if needed
FO-330672	10/21/2015			Laborer, please remove old pumps and piping in room 100, see Jim Hill if u have questions.
FO-330673	10/21/2015			Laborer, please remove piping and two old pumps from mech room 10 *See Jim or Ron if needed
FO-330687	10/21/2015			PLEASE REPLACE BURNED OUT LIGHTS ON THE 1ST FLOOR OF WELCOME CENTER.
FO-330729	10/22/2015	10/23/2015		Rang 113 has an electrical problem. (1st floor)
FO-330731	10/22/2015			The entrance light has an electrical problem.
FO-330733	10/22/2015			The ramp surrounding room 1120 has an electrical problem.
FO-330734	10/22/2015	10/28/2015		The elevator lights in the Damon Keith wing has 4 electrical problems.
FO-330737	10/22/2015	10/27/2015		The outside overhead bulbs between the Law Classroom and the Law Library have 13 lights out.
FO-330752	10/22/2015			Pick up motor from Electric Motor, and bring to shop.
FO-330832	10/23/2015			R/R RM 404/DLAR Light fixtures don't have end caps. We have end caps but need them installed.
FO-330837	10/23/2015			on the second floor as you get off the elevator, the light switch is tagged do not turn lights on and half of the floor is dark...Electrician needed for this.
FO-330856	10/23/2015			EXIT signs in the back entrance, the Ferry entrance and the back stairwell have 3 electrical problems. (1st floor)
FO-330859	10/23/2015			The EXIT sign outside of Donna's office has an electrical problem. (2nd floor)
FO-330860	10/23/2015			EXIT signs in the front and back stairwell have 2 electrical problems. (3rd floor)
FO-330870	10/23/2015			2 EPs - The two fixtures are tagged at the front of the auditorium - both located next to the exit sign in front of podium.
FO-330871	10/23/2015			3 EPs - The fixtures are (1) 422 second door entrance from the hallway. (2) fourth floor men's room. (3) First floor canister just before Anita Knight's office.
FO-330877	10/23/2015			Light is out in the lab. Interfering with research conducted in the lab. May be an electrical issue, please investigate and repair. The room has 1 electrical problem. The electrical problem is located on the last door on the left.
FO-330923	10/26/2015			Trade: LaborerPriority: Med/HighPlease supply one pallet of water softener salt.
FO-330939	10/26/2015			Replace burnt out bulb in indicator light next to door. Light is used to indicate if someone is using the darkroom. Contact Lynette Rae 7-1555 if you have any questions. It's an electrical problem.
FO-330938	10/26/2015			Room 102 has an electrical problem in the overhead light.
FO-330940	10/26/2015			Room 220 has an electrical problem in the overhead light.
FO-330941	10/26/2015	10/27/2015		Room 230 has an electrical problem.
FO-330969	10/26/2015			Electrician to repair / re lamp exterior light fixtures indicated on plan. Note wall wash lights located above main entrance doors washing clock tower.
FO-330970	10/26/2015			Electrician to repair / re lamp exterior light fixtures indicated on plan.
FO-330979	10/26/2015			Repair Exhaust Fan #8 control wiring so that it operates interlocked to Exhaust Fan #9, located in Mechanical Room 349.1, Art Building. Exhaust Fan #9 serves hoods in rooms 050 & 052. Exhaust Fan #8 serves the chemical sink hood exhaust in room 052.

WO	Recieved	Finished	Total	Request
FO-331004	10/27/2015	10/27/2015		Trade: Electrician Priority: Medium Metal hylide light fixture at rear exit door is flickering and won't stay "ON". located at right above card reader.
FO-331016	10/27/2015			Room 1130 has 3 electrical problems.
FO-331018	10/27/2015			Hallway along side of room 1420 has 1 electrical problem.
FO-331030	10/27/2015			Reference work order FO-329475. R/R RM 254 Lights are still flickering. Please tag and submit work order to electricians.
FO-331074	10/27/2015			Hall light across from the front stairwell has 1 electrical problem. (Basement)
FO-331075	10/27/2015			The Gym area has 2 electrical problems. (Basement)
FO-331078	10/27/2015	10/28/2015		ELECTRICIANS - R/R RM 106/MECH RM please meet w/ engineer and assess total load for generator at 5435 Woodward. Thanks.
FO-331083	10/27/2015			Please repair dusk to dawn exterior building light over entry/exit door on Antoinette street. Light does not come on at night.
FO-331097	10/27/2015			Please have Maintenance Laborer take extra wooden pallets from FP&M Stockroom to Holden Warehouse.
FO-331182	10/28/2015			The Gym area has 1 electrical problem. (Basement) Now there are a total 3 electrical problems.
FO-331183	10/28/2015			The kitchenette has 1 electrical problem. (Basement)
FO-331184	10/28/2015			The tunnel in the basement has 1 electrical problem. A GIRF will need to be generated.
FO-331224	10/28/2015			Electricians- Low priority- R/R RM 3237/MECH RM Install a 110v outlet on machinery pad for air compressor #1. To power automatic blowdown.
FO-331314	10/29/2015			Hallway across from Range 248 has 1 electrical problem. (2nd floor)
FO-331338	10/29/2015			R/R RM 404/DLAR All light covers are missing n room 0404 at Scott Hall. Inspection report said we needed covers. Replace covers.
FO-331345	10/29/2015			Electrician R/R 6FL MECH RM replace defective light switch for 6th floor mechanical room.
FO-331344	10/29/2015			The light switch on the first floor that controls the lights on the second floor is not functioning.
FO-331363	10/29/2015			ELECTRICIANS R/R 3RD FLR please r/r trouble at fire panel. smoke detector 3rd floor. fire panel indicating trouble and lit source indicates 3rd flr. smoke alarm.
FO-331354	10/29/2015			In suite 2290 (Occupation/Physical Therapy) above the reception desk, a lights are blinking and needs replacing with a new fluorescent bulb. There are 4 electrical problems.
FO-331383	10/29/2015			2 EPs - patient corridor - lights are blown out. Taped.
FO-331384	10/29/2015			1 EP - 3rd floor hallway - in front of elevators.
FO-331400	10/29/2015			Clock not working please building clock on west wall.
FO-331401	10/29/2015			Building clock in room not working please fix clock.
FO-331402	10/29/2015			Building clock on east wall not working please fix clock.
FO-331424	10/30/2015			R&R Light fixtures in South emergency stairwell. Access through room 325.
FO-331427	10/30/2015			Be sure that all Scott Hall Master Clocks are working and reset to eastern Standard time on Monday, November 2, 2015 (Eastern Daylight Savings Time Ends on Sunday, November 1, 2015 at 2:00 a.m.
FO-331443	10/30/2015			R/R RM 2220 Clock on the wall stopped working
FO-331462	10/30/2015			The men's locker room has an electrical problem. (Basement)
FO-331463	10/30/2015			Room to the right of the back stairwell has 2 electrical problems.(Basement)
T - Locksmith			89	
FO-328508	10/1/2015	10/7/2015		New KeyLost / StolenKey #: key 4005AFKey Holder ID: Cindy HildrethQty: 2 keys for mailboxaction: Cut 2 keys for 742 mailboxAccount #: 228400
FO-328509	10/1/2015	10/7/2015		New KeyLost / StolenKey #: key 4700AFKey Holder ID: Cindy HildrethQty: 1 key for mailboxaction: Cut 1 key for mailboxAccount #: 228400
FO-328510	10/1/2015	10/7/2015		New KeyLost / StolenKey #: key 4019AF Key Holder ID: Cindy HildrethQty: 1 key for mailboxaction: Cut 1 key for mailboxAccount #: 228400

WO	Recieved	Finished	Total	Request
FO-328511	10/1/2015	10/16/2015		CORE CHANGE Lost / Stolen Key #: core #22aaa96, key #62907 Key Holder ID: Cindy Hildreth Qty: 1 core and 2 keys action: 1 core and 2 keys for room 907.3 Account #: 228400
FO-328548	10/1/2015	10/12/2015		Core ChangeLost / StolenKey #: key #62317 no core number on faceKey Holder ID: Cindy HildrethQty: 1 core and 2 keysaction: 1 core and 2 keys for room 714.2Account #: 228400
FO-328550	10/1/2015	10/12/2015		Core ChangeLost / StolenKey #: key #62821, core 22aah11Key Holder ID: Cindy HildrethQty: 1 core and 2 keysaction: 1 core and 2 keys for room 910.2 ***temp core installed please return to front desk***Account #: 228400
FO-328551	10/1/2015	10/13/2015		Core ChangeLost / StolenKey #: core #22aa660, key #62612 Key Holder ID: Cindy HildrethQty: 2 keys and 1 coreaction: 1 core and 2 keys Account #: 228400
FO-328540	10/1/2015	10/13/2015		KEYS & CORES (OCTOBER 2015)
FO-328693	10/2/2015	10/19/2015		Core ChangeLost / StolenKey #: key 62874, core22aah106Key Holder ID: Cindy HildrethQty: 2 keys and 1 coreaction: 1 core and 2 keysAccount #: 228400
FO-328696	10/5/2015	10/7/2015		New KeyNew Space AssignmentKey #: 7681.19-.21Key Holder ID: Lynette RaeQty: 3action: Key is actually for multiple labs. Room 7277 is the lead labAccount #: 143511
FO-328765	10/5/2015	10/8/2015		New KeyNew Space AssignmentKey #: 12 BEST RE 5 Key Holder ID: Ewart JarrettQty: 2action: Need 2 door keys for OfficeRm# 250 per Mr. E. Jarrett ext 7-9717Account #: 300710
FO-329006	10/5/2015	10/15/2015		New KeyLost / StolenKey #: FR326, FR394, FR384, FR448, FR428, FR316, FR330, FR408, FR377, FR415Key Holder ID: Valeria CookQty: 2 for eachaction: Note: The Department is Center for Urban Studies.
FO-329007	10/6/2015	10/8/2015		New KeyLost / StolenKey #: 12V B31 - Rm 266 MatthaehiKey Holder ID: Bob OstrowskiQty: 2action: Please cut 2 keys for Matthaehi Office 266 for new athletic staff coach. Key # 29978Thank You
FO-329055	10/6/2015	10/7/2015		New KeyDamagedKey #: UTBKey Holder ID: Jeffrey BlockQty: 7action: Request for (7) keys for freight elevator.Account #: Special Events 168227
FO-329056	10/6/2015	10/7/2015		New KeyNew Staff MemberKey #: Core #12GEA9Key Holder ID: Cristie PagieQty: 1action: Student Disability ServicesAccount #: 146961
FO-329068	10/6/2015	10/6/2015		New KeyDamagedKey #: 83464-2Key Holder ID: Narendra GoelQty: 1action: The key to his office, Room 14109.2, broke and we do not have any spare keys for this office. Note that this room number is not on the Area list.
FO-329089	10/6/2015	10/8/2015		New KeyNew Space AssignmentKey #: 171XKey Holder ID: martha haywardQty: 2action: 2 keys please
FO-329090	10/6/2015	10/8/2015		New KeyNew Staff MemberKey #: 20711Key Holder ID: Lynnetta R SmithQty: 3action: need additional key to closet for part time faculty member
FO-329091	10/6/2015	10/8/2015		New KeyNew Staff MemberKey #: x3038Key Holder ID: Lynnetta R SmithQty: 3action: New staff member
FO-329087	10/7/2015	10/7/2015		R&R core to door 7902. Core is to be split to be opened by all 20H & 20J series keys.
FO-329183	10/7/2015	10/19/2015		New KeyNew Staff MemberKey #: BEST, 10GN11Key Holder ID: Xiuyuan LiangQty: 3action: We need 3 new keys, thank you very much!
FO-329184	10/7/2015	10/19/2015		New Key New Staff Member Key #: 12 VN1 Key Holder ID: Bob Ostrowski for the KHS Department Qty: 2 action: Please cut 2 additional keys for the Matthaehi Kitchen on the 2nd floor room 256. Please rush keys are needed by Noon on Thursday - 10-8-
FO-329185	10/7/2015	10/19/2015		New KeyLost / StolenKey #: FR436Key Holder ID: Leo T./Marilyn WeissQty: 2action: need to get a replacement key for library storage cabinet.

WO	Recieved	Finished	Total	Request
FO-329330	10/7/2015	10/13/2015		Core Change Lost / Stolen Key # on security series Key Holder ID: Theresa Y. Hill Qty: 6 KEYS action: Please make 6 keys for room 0013 which is the LN2 Freezers Room in the basement of IBio. Please contact Theresa Y. Hill at 577-1417 or
FO-329186	10/7/2015	10/20/2015		New KeyNew Space AssignmentKey #: 25286Key Holder ID: Mike Dobson & Jim KentQty: 2action: two Library IT staff who will be working on SLIS servers being installed.
FO-329187	10/7/2015	10/9/2015		New KeyLost / StolenKey #: 110404Key Holder ID: Theresa Y. HillQty: 4action: Please duplicate 4 keys for the key number listed above. This is for the an office in the IBio building. Please contact Theresa Hill at 577-0556 or 577-1417 if you r
FO-329264	10/8/2015	10/16/2015		New KeyNew Staff MemberKey #: 27283Key Holder ID: DeVaughn ElledgeQty: 1action: 4th IT room Key Needed. I Transposed numbers on request#273841. This is the correct key number.
FO-329454	10/12/2015	10/20/2015		New KeyNew Staff MemberKey #: core #4517AF Key Holder ID: Cindy HildrethQty: 2 keys for mailboxaction: Cut 2 keys for the mailbox. This was the mailbox for the CD.Account #: 228400
FO-329453	10/12/2015	10/20/2015		New KeyNew Staff MemberKey #: Key 96654Key Holder ID: Sheila A. JacksonQty: 1action: New Key for room 461 for new Research Assistant (for our data team)at Tolan Park Medical Building.
FO-329539	10/13/2015	10/20/2015		Core Change Lost / Stolen Key #: Core #AB22, Key #037050 Key Holder ID: Angelica Reyna Qty: 2 cores and 3 keys action: 2 cores and 3 keys. EMERGENCY CORE INSTALL PLEASE RETURN TO FRONT DESK Account #: 228156
FO-329551	10/13/2015	10/16/2015		New KeyNew Space AssignmentKey #: cORE #11VB25, 11VB20, 11VB7Key Holder ID: Andy MurrellQty: 6action: Please provide (6) Six keys to access rooms, 133,135 & 137. Mark Gibbons to pick-up and Deliver.Account #: N/A
FO-329600	10/13/2015	10/20/2015		New KeyLost / StolenKey #: Core #AA35, Key #036998Key Holder ID: Angelica ReynaQty: 2 cores and 4 keysaction: 2 cores and 4 keys (mailbox and door) EMERGENCY CORE INSTALLED PLEASE RETURN TO FRONT DESKAccount #: 228156
FO-329628	10/14/2015	10/22/2015		New KeyNew Staff MemberKey #: 64659Key Holder ID: Paul BishopQty: 3action: Key for new faculty member.
FO-329700	10/14/2015	10/21/2015		New KeyNew Staff MemberKey #: 110845Key Holder ID: Sarah BrownleeQty: 6action: I need 6 more keys to my lab, 251 Life Sciences, to give more students access. I'm not sure I picked the right 'Area' on this form.Account #: 125501
FO-329692	10/15/2015			Lockshop training for Jeff Hammell
FO-329698	10/15/2015			We need 9 Padlocks for the Generator, and Transfer switch at Physics with the 14 Key core.
FO-329701	10/15/2015	10/22/2015		New KeyNew Space AssignmentKey #: 25300Key Holder ID: Jonathan KeysQty: 1action: Communications room key. I am a building Engineer at Scott Hall. Supervisor Charles Redond
FO-329702	10/15/2015	10/22/2015		New KeyNew Space AssignmentKey #: 25300Key Holder ID: p.belcherQty: 1action: request for key to communications room on the 3rd floor
FO-329786	10/15/2015	10/22/2015		New KeyNew Staff MemberKey #: 21C-3 (Key Number 88405)Key Holder ID: James CampbellQty: 2action: We only have two keys for the Baseball Assistants' Office but we now have four total coaches who need access to this room.Account #: n/a
FO-329950	10/15/2015	10/21/2015		New KeyNew Staff MemberKey #: 27412Key Holder ID: Shane PerrineQty: 3action: To be picked up by the med school courier. FYI, I need 1 key for a new student in the lab and want to have 2 back-ups, 1 for me and 1 to keep with my colleague Dr. M
FO-329789	10/15/2015	10/22/2015		New KeyLost / StolenKey #: 18C11 Key Holder ID: Dr. Larry Matherly Qty: 7action: Please add Department of Oncology to form. Also,please send to SOM Sheryl MacGillis.

WO	Recieved	Finished	Total	Request
FO-329790	10/16/2015	10/16/2015		LOCKSMITH TO REPLACE CORE 14A-4 PRESSBOX 3 FLOOR ELECTRICAL CLOSET (MUST CNTACT BOB OSTROWSKI TO DISARM ALARM
FO-329835	10/16/2015	10/26/2015		New KeyLost / StolenKey #: 96317Key Holder ID: Elizabeth RoggenbuckQty: 2action: issue two keys #96317
FO-329876	10/16/2015	10/21/2015		New KeyNew Staff MemberKey #: 16192Key Holder ID: martha haywardQty: 2action: 2 new keys
FO-329877	10/16/2015	10/21/2015		New KeyNew Staff MemberKey #: 16166Key Holder ID: martha haywardQty: 2action: 2 new keys
FO-330497	10/19/2015	10/21/2015		New KeyNew Staff MemberKey #: 23602Key Holder ID: LockboxQty: 2action: 23602.4 thru 23602.8Account #: 135511
FO-330498	10/19/2015	10/23/2015		New KeyLost / StolenKey #: 23603Key Holder ID: LockboxQty: 1action: 23603.7 thru 23603.10Account #: 135511
FO-330499	10/19/2015	10/23/2015		New KeyLost / StolenKey #: 23608Key Holder ID: lockboxQty: 3action: 23608.5 thru23608.9Account #: 135511
FO-330500	10/19/2015	10/23/2015		New KeyNew Staff MemberKey #: 23215Key Holder ID: LockboxQty: 2action: 23215.4 thru23215.7Account #: 135511
FO-330501	10/19/2015	10/23/2015		New KeyLost / StolenKey #: 23634Key Holder ID: lockboxQty: 4action: 23634.5 thru23634.8Account #: 135511
FO-330506	10/19/2015	10/23/2015		New KeyNew Staff MemberKey #: 20322Key Holder ID: Margaret EasleyQty: 4action: Need more keys
FO-330507	10/20/2015			New KeyNew Staff MemberKey #: 7652 next available is .3 and .4Key Holder ID: Lynette RaeQty: 2action: Key is for inner office door marked as room 7378Account #: 133751
FO-330626	10/20/2015	10/26/2015		New KeyNew Staff MemberKey #: 36668Key Holder ID: AdminQty: 1action: Please provide the requested key. Thanks.
FO-330817	10/20/2015	10/26/2015		New KeyNew Staff MemberKey #: 19183--9Key Holder ID: Dr. Stanley TerleckyQty: 3action: Need duplicate keys in order to accommodate students and Dr.Terlecky, who need access to laboratory at different times.
FO-330571	10/20/2015	10/21/2015		Provide a padlock for file cabinet in the stockroom for Siemens
FO-330715	10/21/2015	10/26/2015		New KeyNew Staff MemberKey #: 36684Key Holder ID: Yajing ShuQty: 1action: We need a key for new staff member joined.
FO-330716	10/21/2015	10/27/2015		New KeyNew Space AssignmentKey #: 38737Key Holder ID: Dawn CochraneQty: 10action: The actual room number is 342.2, but this is not reflected on the drop-down menu or even the floor plans. We have had multiple renovations on the third floor to accom
FO-330717	10/21/2015	10/27/2015		New KeyNew Space AssignmentKey #: 13509Key Holder ID: Charlyce JacksonQty: 3action: Please process if possible. Keys that were ordered in August have been utilized. Thank you!Account #: 127211
FO-330786	10/22/2015	10/28/2015		New KeyNew Staff MemberKey #: 26333.11Key Holder ID: CUSTODIANQty: 2action: JANITOR CLOSET KEY ON 12TH FLOOR ON WOODWARD SIDE OF BUILDING NEAR STAIRWELL.
FO-330736	10/22/2015			R/R RM 150 NEED 2 KEYS MADE FOR 2 DRAWER FILE CABINET (TAN) ***SEE LORETTA FOR KEYS ALREADY MADE***
FO-330787	10/22/2015	10/27/2015		New KeyLost / StolenKey #: BauerKey Holder ID: Scott Payson and Alan SebastianQty: 2 eachaction: Bauer keys: 2 each of BP 670, BP 691, BP 606, BP 577 -- Keys to cabinets in room 115 (laboratory.)Spare key set for myself and Alan Sebastian
FO-330818	10/22/2015	10/26/2015		Core Change New Space Assignment Key #: 22aa118 (key code 61121) Key Holder ID: Cindy Hildreth Qty: 2 action: Request by Cindy Hildreth Account #: 228400
FO-330819	10/22/2015	10/26/2015		Core Change Lost / Stolen Key #: 22aa888 (key code 61348) Key Holder ID: Cindy Hildreth Qty: 2 action: Keys request by Cindy Hildreth Account #: 228400

WO	Recieved	Finished	Total	Request
FO-330788	10/22/2015	10/26/2015		New KeyLost / StolenKey #: 4372af (mail box key for #544Key Holder ID: Cindy HildrethQty: 2action: Requested by Cindy HildrethAccount #: 228400
FO-330789	10/22/2015	10/27/2015		New KeyLost / StolenKey #: 4869af (mail box number 404)Key Holder ID: Cindy HildrethQty: 2action: Requested by Cindy HildrethAccount #: 228400
FO-330790	10/22/2015	10/27/2015		New KeyLost / StolenKey #: 4752af (mail box 308)Key Holder ID: Cindy HildrethQty: 2action: Request by Cindy HildrethAccount #: 228400
FO-331007	10/23/2015			New KeyLost / StolenKey #: 17AC17Key Holder ID: Starbucks managementQty: 2action: Core number 17AC17 with key number 34214. Mike you were correct on the core number to this door. Had someone take the core out of the door and this number was stamp
FO-331008	10/23/2015			New KeyDamagedKey #: JC45Key Holder ID: Rob HessQty: 2action: This is a Janitor Closet. That was not an option for the 'Area' box.
FO-331009	10/26/2015			New Key Damaged Key #: Key 036961-6 Key Holder ID: Felipe Jimenez - Maintenance Tech Qty: 1 action: The maintenance tech for DeRoy has a master key that is worn out. Request 1 key duplicated. Account #: 228156
FO-331010	10/26/2015			New KeyDamagedKey #: core #4933AFKey Holder ID: Cindy HildrethQty: 1keyaction: Cut 1 mailbox key for mailbox 744Account #: 228400
FO-331127	10/27/2015			Core ChangeLost / StolenKey #: key# 101709 Key Holder ID: Sheila GoreeQty: 2cores and 3 keysaction: 1 mailbox core, 1 room core, 3 keysAccount #: 228300
FO-331120	10/27/2015			Core Change Lost / Stolen Key #: key # 101595 Key Holder ID: Sheila Goree Qty: 2 cores and 3 keys action: 1 mailbox core, 1 room core and 3 keys Account #: 228300
FO-331118	10/27/2015			Core Change Lost / Stolen Key #: key # 101649 Key Holder ID: Sheila Goree Qty: 2 cores and 3 keys action: 1 mailbox core, 1 room core, and 3 keys Account #: 228300
FO-331116	10/27/2015			Core Change Lost / Stolen Key #: Temp Cores Key Holder ID: Sheila Goree Qty: 10 action: Request 10 Temp Cores next in series. Account #: 228300
FO-331115	10/27/2015	10/28/2015		Core Change Lost / Stolen Key #: Core #AB29, Key #037057 Key Holder ID: Angelica Reyna Qty: 2 cores and 3 keys action: 1 room core, 1 mailbox core and 3 keys. ****EMER 8 core installed, must be returned to front desk after lock change* Account
FO-331085	10/27/2015			New KeyLost / StolenKey #: 31 BA1Key Holder ID: Theresa Y. Hill / Antonio E. YanceyQty: 5action: Please duplicate 5 keys for room #1022.1 in the IBio building. This key is for the room on the receiving dock.

WO	Recieved	Finished	Total	Request
FO-331114	10/27/2015			New KeyNew Staff MemberKey #: 31 BA1Key Holder ID: Theresa Y. Hill / Antonio E. YanceyQty: 5action: Please duplicate 5 keys for room 1005. This is for the storage room on the first floor of the IBio building.
FO-331088	10/27/2015			New Key Damaged Key #: it says fred's key shop on it Key Holder ID: Diablo Bowman Qty: 1 action: Custodian broke the key to this closet I need a replacement.
FO-331113	10/27/2015			New KeyNew Staff MemberKey #: 110009Key Holder ID: Theresa Y. Hill / Antonio E. YanceyQty: 5action: Please duplicate 5 keys for the Surgical Suite in the basement of IBio. Thank you.
FO-331299	10/28/2015			New KeyLost / StolenKey #: 8133Key Holder ID: Krista MitchellQty: 10action: Please provide 10 copies of key 8133 - for the Scott Hall Mail Room - room 1309.
FO-331298	10/28/2015			Core Change Lost / Stolen Key #: Temp Core Key Holder ID: Cindy Hildreth Qty: 5 action: 5 temp cores next in series Account #: 228400
FO-331296	10/28/2015			New KeyLost / StolenKey #: *Key Holder ID: Leo LiebermanQty: 2 copies of each keyaction: I have the blank mailbox keys that I need replicated. It's for two departments that have lost their keys to their mailboxes. I will drop off the blanks an
FO-331426	10/28/2015			New KeyLost / StolenKey #: 25392Key Holder ID: Nicholas Board, Gerry Tilson, Aliou Darboe, Anthony CarinciQty: 4action: Please make 4 keysAccount #: 227149
FO-331218	10/28/2015	10/28/2015		LOCKSMITH TO PROVIDE PADLOCK & CORE FOR THE SEIMENS STORAGE CABINET
FO-331422	10/28/2015			New KeyNew Staff MemberKey #: 27764Key Holder ID: Will LangfordQty: 1action: New key needed for new employeeAccount #: 113231
FO-331421	10/29/2015			New KeyNew Staff MemberKey #: 64807Key Holder ID: Paul BishopQty: 4action: Keys for faculty lounge that was recently re-cored.
FO-331420	10/29/2015			New KeyNew Space AssignmentKey #: 170002Key Holder ID: Kimberly ElmsQty: 2action: 2 additional copies of key# 170002; One to be assigned to James Barbret who will be the AVP for Finance and 1 to be assigned to Kimberly Elms for the Business
FO-331362	10/29/2015			New KeyNew Space AssignmentKey #: 12V & 170XKey Holder ID: Cory BlairQty: 2action: Need Bldg. Master & South Door Key
FO-331419	10/29/2015			New KeyNew Space AssignmentKey #: 11A1F22Key Holder ID: Leo T./Jum Kent/Mike DobsonQty: 3action: new workers sharing an IT office space.
T - Painter			32	
FO-328506	10/1/2015	10/13/2015		There is a nicked wall outside of room 2602 and a damaged wall by the elevator on the second floor that needs to be fixed. Estimates needed. Thanks!
FO-328524	10/1/2015	10/23/2015		HANDY MAN TIME (OCTOBER 2015)
FO-328547	10/1/2015	10/7/2015		PAINTERS PAINT / CLEAN WALL SECTION ADJACENT TO THE NEW BRONZE PLAQUE NORTH EAST WALL MAIN FLOOR
FO-328555	10/1/2015			CLEAN & PAINT OVER GRAFITTI CAMPUS WIDE, FOR THE MONTH OCT.
FO-328652	10/2/2015			Plaster Repair ceiling in corridor, Main floor.
FO-328771	10/5/2015	10/19/2015		Plaster Repair & Paint to finish, east wall near elevator in basement.
FO-328772	10/5/2015	10/16/2015		Plaster Repair & Paint to finish ceiling, outside conference room.
FO-329063	10/6/2015	10/19/2015		Paint the windows on the north side of the building and paint the two hollow metal doors.
FO-329072	10/6/2015			Paint all exterior hollow metal doors and overhead door.
FO-329094	10/7/2015	10/13/2015		PAINTERS TO PAINT WALL CORNER BUMPER GUARD & WALL ROOM # 4545
FO-329179	10/8/2015	10/19/2015		PAINTER TO PAINT LIFTED CONCRETE WALKWAY BETWEEN LOT #50 & LOT #40
FO-329181	10/8/2015	10/8/2015		PAINTERS TO REMOVE GRAFFITTI EAST BLACK CHAULK BOARD WALL TUNNEL AREA

WO	Recieved	Finished	Total	Request
FO-329302	10/9/2015	10/21/2015		PAINT NEW RAILING AROUND WINDOW COVE ON THE NORTH EAST CORNER AND PAINT THE HANDRAILS ON THE NORTH SIDDE. PRIME WITH TRIUMPH RUST CONVERTER AND PAINT.(SEE Tim Herr for location of missed railing)
FO-329303	10/9/2015	10/23/2015		PAINT GAS PIPE FROM MANIFOLD TO THE UNIT ON ROOF.SOUTH EAST CORNER OF THE BUILDING.
FO-329307	10/9/2015	10/12/2015		R/R RM 150 NEED 2 BOXES OF XEROX PAPER
FO-329458	10/13/2015	10/13/2015		SAFTEY TIME FOR THE MONTH OF OCT.
FO-329459	10/13/2015	10/15/2015		SAFTEY TIME FOR THE MONTH OF OCT.
FO-329473	10/13/2015			Plaster on ceiling is loose. Found some on staircase this morning
FO-329687	10/15/2015	10/16/2015		Scrape, Prime & Paint to finish all exterior handrail, North west side of Building.
FO-329689	10/15/2015	10/16/2015		Repaint, Exterior, Overhead Doors on North side of building.
FO-329764	10/15/2015			Repair, scrape, Prime an Paint to finish. Windows on the West side of building.
FO-329824	10/16/2015	10/21/2015		PAINTERS TO MUD & PAINT CEILING ON STAIRWELL WHERE SIGNAGE WAS REMOVED WEST END STAIRWELL
FO-329965	10/19/2015	10/21/2015		PAINTERS TO MUDD & PAINT ROOM # 352.00 ENTIRE WALL CARPENTERS WO#FO-327782
FO-330618	10/21/2015	10/26/2015		Plaster Repair, & Paint window sills, North east corner of 1st floor.
FO-330617	10/21/2015	10/23/2015		R/R RM 150 NEED A 2 DRAWER FILE CABINET MOVED FROM RM 138 (Old Svc Ctr/New Conf Rm) TO RM 150 SVC CTR AREA SEE LORETTA
FO-330633	10/21/2015	10/22/2015		R/R RM 00247/DLAR Inspection deficiency following needs correction: Hole in wall above and left to door open to corridor The holes should be sealed /repaired per inspection report.
FO-330634	10/21/2015	10/22/2015		R/R 002347/DLAR Inspection deficiency following needs correction: Hole in ceiling BY LITE FIXTURE. (NOTE: CEILING IS A PLASTER CLNG)The holes should be sealed /repaired per inspection report.
FO-330641	10/21/2015	10/30/2015		Tape/mud Repair ceiling, Prime an Paint to finish. 1st floor, By north west stairwell-RM. 1135
FO-330644	10/21/2015			Tape/Mud repair, Prime & Paint to finish, North wall, across from the elevators on 4th floor.
FO-330915	10/26/2015	10/29/2015		PAINTERS TO TOUCH UP WALLS & CEILINGS ECT.CONFREENCE ROOMS A,B & C ALSO ROOMS F,G & H ALSO RESTROOMS & ELEVATORS
FO-331077	10/27/2015			Purdy Library, 2nd Floor, across from Stair#1 Painted surface of pillar in Sorting Area is bubbled and cracked. Please repair. Thank you.
FO-331368	10/29/2015			Restrooms doors needs to be paint
T - Pipefitter			60	
FO-328473	10/1/2015	10/12/2015		FITTERS PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #2 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, JH/10-1-15 ,,,,,,,,,,,,,,
FO-328474	10/1/2015	10/1/2015		**REFER TO FO#328763 JWT Repair handle on AH in room 120 at the Football Stadium See Bob O for location ,,,,,,,,,,,,,, ME/10-1-15 ,,,,,,,,,,,,,,
FO-328481	10/1/2015	10/12/2015		Repair loose handrail on south side entrance stairs ,,,,,,,,,,,,,, JH/10-1-15 ,,,,,,,,,,,,,,
FO-328543	10/1/2015	10/1/2015		Safety meeting.....
FO-328545	10/1/2015	10/1/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....10-1-15
FO-328546	10/1/2015	10/1/2015		assist city of Detroit Water dept. in locating main shut off and access to building.....CB.....10-1-15
FO-328606	10/2/2015	10/2/2015		R/R shot feeded for HWH system ,,,,,,,,,,,,,, JH/10-2-15 ,,,,,,,,,,,,,,
FO-328619	10/2/2015	10/2/2015		Repair gasket leak on main steam ,,,,,,,,,,,,,, JH/10-2-15 ,,,,,,,,,,,,,,
FO-328672	10/3/2015			Due to continual water leak, please repair plaster, repaint and clean up fallen plaster in the hallway leading to the lower level mens room. If repair cannot be done before 10-9-2015 at least clean up the fallen plaster. Thank you
FO-328660	10/4/2015	10/4/2015		DUPLICATE / REFER TO FO#326625 JWT Repair #1 condensate return pump located in Mechanical Room 018 at Cohn. Pump is not running and is leaking at the seal. ,,,,,,,,,,,,,, RC/10-5-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-328663	10/4/2015			(**) PO REQ DK Repair #2 condensate return pump located in Mechanical Room 25 at Community Arts, (behind AHU-1. The large pit pump). The pump will not operate via the float control, and if placed on "Hand", it rattles. Bearings and pump are likely shot.
FO-328708	10/5/2015	10/8/2015		Pipefitter please r/r control valve for reheat to conference room. Room overheated badly. Manual valve before control valve is closed currently. Please see engineer (M. Kemp) for location. ,,,,,,,,,,,,,, ME/10-5-15 ,,,,,,,,,,,,,,
FO-329001	10/6/2015	10/9/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #1 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, ME/10-6-15 ,,,,,,,,,,,,,,
FO-329067	10/6/2015	10/6/2015		take contractor to several buildings to look at abatement jobs.....CB.....10-6-15
FO-329069	10/6/2015	10/6/2015		Meeting with Dave K about asbestos quotes.....CB.....10-6-15
FO-329070	10/6/2015	10/6/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....10-6-15
FO-329071	10/6/2015	10/6/2015		go with Tim H to investigate 2nd floor stairwell ceiling leak.....CB.....10-6-15
FO-329177	10/7/2015	10/7/2015		take coil contractor to 5 different buildings on campus to measure coils for quotes.....CB.....10-7-15
FO-329254	10/8/2015	10/8/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....10-8-15
FO-329255	10/8/2015	10/8/2015		go with Mark Bobick to look at some heat recovery coils in 3 different places that need to be removed.....CB.....10-8-15
FO-329268	10/9/2015			Pipefitters to remove both ERC coils inside ahu's 1 and 2. Located in penthouse. Old system possibly contains glycol EOHS should be involved.,,,,,,,,,,,,,, EA/10-9-15 ,,,,,,,,,,,,,,
FO-329371	10/12/2015	10/12/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #3 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, ME/10-12-15 ,,,,,,,,,,,,,,
FO-329375	10/12/2015			FITTERS, PLEASE REPLACE DAMAGED CONDENSATE DRIP PAN ON # 2 FFC UNIT. (ATTN: RON CLARK) PRIORITY-LOW ,,,,,,,,,,,,,, JH/10-12-15 ,,,,,,,,,,,,,,
FO-329462	10/13/2015			Reinsulate replaced chill water lines in ceiling of room 59 ,,,,,,,,,,,,,, ME/10-13-15 ,,,,,,,,,,,,,, *See Corey for detail
FO-329503	10/13/2015			Rom 0225 at Elliman has a rackwsher and some of the insulation around some of the pipes going to the it are coming off. Please replace or secure them. ,,,,,,,,,,,,,, CB/10-15-15 ,,,,,,,,,,,,,
FO-329548	10/13/2015	10/13/2015		processing time for paperwork, e-mails, phone calls, etc....CB....10-13-15
FO-329550	10/13/2015	10/13/2015		worked on 3 different impact reports for upcoming building shutdowns scheduled for this week.....CB.....10-13-15
FO-329640	10/14/2015			R/R heating coil in bathroom 149 ,,,,,,,,,,,,,, EA/10-14-15 ,,,,,,,,,,,,,,
FO-329681	10/15/2015	10/26/2015		FITTERS, PLEASE REPAIR STEAM LEAK ON CONDUCTIVITY BLOWDOWN LINE FOR #1 BOILER. PRIORITY-LOW ,,,,,,,,,,,,,, ME/10-15-15 ,,,,,,,,,,,,,,
FO-329759	10/15/2015	10/15/2015		processing time for up-coming asbestos work, e-mails-upcoming building shutdowns, phone calls, etc.....CB....10-15-15
FO-329791	10/16/2015	10/21/2015		PIPEFITTERS - please r/r float trap in SE corner of the carpentry shop (at FP&M), just outside of Doug Obrien's office in the corner. Trap is leaking by and causing excessive noise in Mark Allen's office down stairs. Thanks. ,,,,,,,,,,,,,, JH/10-19-15
FO-329792	10/16/2015	10/21/2015		PIPEFITTERS- please replace trap in Steven Pecic's office. Trap appears to be failed shut and not allowing radiator to warm. Wall covering radiator has been removed to expose radiator and trap. ,,,,,,,,,,,,,, JH/10-19-15 ,,,,,,,,,,,,,,
FO-329793	10/16/2015	10/21/2015		PIPEFITTERS- please replace trap in conference room next to Mark Allen's office. Trap appears to be failed shut and radiator is not heating. ,,,,,,,,,,,,,, JH/10-19-15 ,,,,,,,,,,,,,,
FO-330576	10/20/2015	10/20/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....10-20-15
FO-330577	10/20/2015	10/20/2015		post asbestos notifications for 6 abatement jobs this week< Wednesday and Thursday.....CB....10-20-15
FO-330578	10/20/2015	10/20/2015		Take Dave K to mech room 100 to evaluate the scope of abatement needed....CB....10-20-15
FO-330681	10/21/2015	10/30/2015		Assist Engineer with float on D.A. tank ,,,,,,,,,,,,,, JH/10-21-15 ,,,,,,,,,,,,,,
FO-330693	10/21/2015	10/21/2015		facilitate entry, set up, and supervise 2 abatement jobs.....CB....10-21-15
FO-330695	10/21/2015	10/21/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....10-21-15
FO-330696	10/21/2015	10/21/2015		facilitate entry, set up, and supervise abatement job in room 10...CB....10-21-15

WO	Recieved	Finished	Total	Request
FO-330697	10/21/2015	10/21/2015		put up notifications for Abatement job svheduled for 10-22-15....CB....10-21-15
FO-330794	10/22/2015	10/22/2015		processing time for paperwork, e-mails,phone calls, etc.....CB...10-22-15
FO-330797	10/22/2015	10/22/2015		get access, supervise and follow up abatement job....CB....10-22-15
FO-330799	10/22/2015	10/22/2015		access, supervise and follow up abatement job.....CB.....10-22-15
FO-330851	10/23/2015	10/26/2015		please repair or run new sight glass drain piping ,,,,,,,,,,,,,, JH/10-26-15 ,,,,,,,,,,,,,,
FO-330937	10/26/2015	10/27/2015		FITTERS, PLEASE REPLACE LEAKING HWH VALVE ON #3 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, JH/10-26-15 ,,,,,,,,,,,,,,
FO-331091	10/27/2015	10/28/2015		R/R RM 451-B hot pipes need to be rewrapped ,,,,,,,,,,,,,, CB/10-27-15 ,,,,,,,,,,,,,,
FO-331090	10/27/2015	10/28/2015		R/R RM 453 autoclave pipes need to be insulated ,,,,,,,,,,,,,, CB/10-27-15 ,,,,,,,,,,,,,,
FO-331084	10/27/2015	10/27/2015		processing time for paperwork, e-mails, phone calls, etc....CB
FO-331086	10/27/2015	10/27/2015		post all abatement notifications for several abatement jobs that are happening Thursday evening.....CB....10-27-15
FO-331087	10/27/2015	10/27/2015		meeting with Bob O over shutdown and abatement jobs.....CB....10-27-15
FO-331089	10/27/2015	10/27/2015		meeting with Dave K and Larry C over po approval's for abatement jobs....CB.....10-27-15
FO-331112	10/28/2015			FITTERS , R/R RM 1137 PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #2 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, ME/10-29-15 ,,,,,,,,,,,,,,
FO-331132	10/28/2015			check bfp strainers 1 and 2 ,,,,,,,,,,,,,, EA/10-29-15 ,,,,,,,,,,,,,,
FO-331237	10/28/2015			Install blow down lines for pump strainers on the DA tank. ,,,,,,,,,,,,,, JH/10-29-15 ,,,,,,,,,,,,,,
FO-331263	10/28/2015			FITTERS, PLEASE REPLACE LEAKING HWH VALVE ON #1 FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, ME/10-29-15 ,,,,,,,,,,,,,,
FO-331367	10/29/2015	10/29/2015		processing time for paperwork, e-mails, phone calls, etc....CB....10-29-15
FO-331371	10/29/2015	10/30/2015		verify access to building chk with coordinator, make sure abatment job is ready for this evening...CB....10-29-15
FO-331379	10/29/2015	10/30/2015		gain access supervise and follow up on 4 different abatement jobs in Mathaeii building....CB....10-29-15
FO-331381	10/29/2015	10/30/2015		gain access to loading dock, then building, then DLAR, to facilitate contractor for abatement job, supervise, and follow up...CB....10-29-15
T - Plumber			59	
FO-328458	10/1/2015	10/2/2015		On the rd floor in the Men's restroom the toilet second from the door handle on the sloan valve won't flush the toilet. ,,,,,,,,,,,,,, MM/10-1-15 ,,,,,,,,,,,,,,
FO-328459	10/1/2015	10/2/2015		In the Women's restroom sink nearest the door the sink drain is plugged on the rd floor. ,,,,,,,,,,,,,, MM/10-1-15 ,,,,,,,,,,,,,,
FO-328602	10/2/2015			Administrative Time for OCT 2015
FO-328659	10/3/2015	10/5/2015		In the 4th floor women's resroom, the sink closest to the door, the drain is plugged..... TT/10-5-15 ,,,,,,,,,,,,,,
FO-328669	10/5/2015	10/7/2015		Restroom #3338 toilet clogged. When flushed all matters do not go down..... MM/10-5-15 ,,,,,,,,,,,,,,
FO-328995	10/5/2015	10/7/2015		The water fountain in the balcony overshoots. Please check and repair. Thanks ,,,,,,,,,,,,,, MM/10-6-15 ,,,,,,,,,,,,,,
FO-329077	10/6/2015	10/8/2015		R/R On the 1st floor in the Dean's Office the workroom has a sink that faucet is dripping non-stop. You have to turn the faucet a certain way for the water to stop. Thank you..... TT/10-8-15 ,,,,,,,,,,,,,,
FO-329167	10/7/2015	10/16/2015		Evaluate and log protocol a winterization scheduled for Gullen Mall fountain ,,,,,,,,,,,,,, DB/10-7-15 ,,,,,,,,,,,,,,
FO-329199	10/8/2015	10/14/2015		please investigate leak on covered line in room 1001 ,,,,,,,,,,,,,, GS/10-8-15 ,,,,,,,,,,,,,,
FO-329355	10/12/2015	10/12/2015		The toilet seat in this handicapped restroom is broken. Please check and repair. ,,,,,,,,,,,,,, TT/10-12-15 ,,,,,,,,,,,,,,
				Thanks
FO-329380	10/12/2015	10/16/2015		R/R RM 229-LOCKER/RESTROOM Shower head is STILL leaking. Please repair(NOTE: PREVIOUS REPAIRS GS/9-17-15) ,,,,,,,,,,,,,, GS/10-12-15 ,,,,,,,,,,,,,,
FO-329381	10/12/2015	10/13/2015		R/R RM 229-LOCKER/RESTROOM ONLY TOILET FLUSH HANDLE IS VERY HARD TO MANUEVER ,,,,,,,,,,,,,, TT/10-12-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-329388	10/12/2015	10/13/2015		P.M. all bathrooms ,,,,,,,,,,,,,, MM/10-12-15 ,,,,,,,,,,,,,,
FO-329396	10/12/2015	10/13/2015		Replace wall seal for women's restroom toilet across from elevator ,,,,,,,,,,,,,, TT/10-12-15 ,,,,,,,,,,,,,
FO-329463	10/13/2015	10/29/2015		PLUMBERS- Please clear drain between boilers. Will not drain (drains VERY slowly). thanks,,,,,,,,,,,,, MM/10-14-15 ,,,,,,,,,,,,,,
FO-329485	10/13/2015	10/15/2015		3rd floor Ladies rest room - please fix sink- not working. thank you ,,,,,,,,,,,,,, MM/10-13-15 ,,,,,,,,,,,,,
FO-329567	10/13/2015	10/15/2015		Hot water knob in janitor closet on the first floor is stripped. ,,,,,,,,,,,,,, TT/10-14-15 ,,,,,,,,,,,,,,
FO-329583	10/14/2015			(**) PO REQ DK 10/29 PLUMBERS please replace P-trap over fire pump in room 116. There's a bad hole. Water dumped out of it this morning (custodian must have been cleaning)..... TT/10-14-15 ,,,,,,,,,,,,,
FO-329674	10/15/2015	10/19/2015		replace 3 leaking lab faucets in room 2003 ,,,,,,,,,,,,,, GS/10-15-15 ,,,,,,,,,,,,,,
FO-329675	10/15/2015	10/16/2015		Plumbers, please replace wall gasket and toilet seat for 1st floor stairwell bathroom first stall(right)..... GS/10-15-15 ,,,,,,,,,,,,,,
FO-329694	10/15/2015	10/21/2015		MEN'S RESTROOM 4TH FLOOR URINAL CLOGGED. PLEASE REPAIR. ,,,,,,,,,,,,,, TT/10- 15-15 ,,,,,,,,,,,,,,
FO-329807	10/16/2015	10/21/2015		1ST FLOOR MEN'S RESTROOM THE FIRST URINAL NOT FLUSHING. PLEASE REPAIR..... TT/ 10-19-15 ,,,,,,,,,,,,,,
FO-329815	10/16/2015			bathroom on the 1st floor south (men) last stall; toilet handle leaks when flushed. ,,,,,,,,,,,,,, TT/10-19-15 ,,,,,,,,,,,,,,
FO-329889	10/19/2015	10/21/2015		REPLACE TOILET SEAT IN 1ST STALL IN WOMEN'S RESTROOM ON 6TH FLOOR EASTSIDE, SEAT STAINED. ,,,,,,,,,,,,,, TT/10-19-15 ,,,,,,,,,,,,,,
FO-329922	10/19/2015			The drain from the room 353 above is leaking into Lab 251 over the entry door. Percy Broadnax looked into this issue before we moved Dr. Brownlee in and determined that the leak is coming from the edges of the drain above. Room 353 is designated as
FO-330508	10/20/2015	10/28/2015		MEN'S RESTROOM 3338 TOILET CLOGGED NOT FLUSHING ALL MATTER DOWN. ,,,,,,,,,,,,, GS/10-21-15 ,,,,,,,,,,,,,,
FO-330536	10/20/2015	10/28/2015		(**) PO REQ DK 10/29 Follow up to work order number "FO-326802" Still having problems with the urinals in the mens bathroom, appears to be a drainage problem. Faculty and Students are complaining about the smell. Talked to custodian, she said it ha
FO-330546	10/20/2015			R/R RM 130/MENS RR Check and repair as needed 2nd urinal from the end in the men's rest room on the first floor of Matthaei by the Hall of Fame. Bob Ostrowski has specifics. Thank You. ,,,,,,,,,,,,,, GS/10-21-15 ,,,,,,,,,,,,,,
FO-330670	10/21/2015			Plumbers , replace hose faucet and piping at front entrance ,,,,,,,,,,,,,, GS/10-21-15 ,,,,,,,,,,,,,,
FO-330671	10/21/2015			Plumbers, r&r all 8 delta faucets in lavatory that are leaking ,,,,,,,,,,,,,, GS/10-21-15 ,,,,,,,,,,,,,,
FO-330686	10/21/2015			(**) PO REQ DK 10/29 Plumbers need 2 sloan repair kits ,,,,,,,,,,,,,, DB/10-21-15 ,,,,,,,,,,,,,,
FO-330711	10/22/2015			In the 2nd floor Men's restroom one of the toilet sensors is not working. ,,,,,,,,,,,,,, GS/10-22- 15 ,,,,,,,,,,,,,,
FO-330712	10/22/2015	10/28/2015		A sensor in the Women'n and Men's restrooms on the 1st floor. That operate the sink is not working. ,,,,,,,,,,,,,, GS/10-22-15 ,,,,,,,,,,,,,,
FO-330718	10/22/2015			Trade: Plumber Priority: High (SEE RESULTS) R/R RM 2111 Please repair leak from the tub (Possibly from Strainer and marked) in this lab. When tub is in use it leaks in class room 0111. Students are very concern about this leak. GS ,,,,,,,,,,,,,
FO-330791	10/22/2015			R/R Room 300- toilet fixture is loose from the floor, and seat is loose from the fixture. ,,,,,,,,,,,,, GS/10-22-15 ,,,,,,,,,,,,,,
FO-330795	10/22/2015	10/26/2015		MEN'S RESTROOM 1120 HANDICAP TOILET WATER LEAKING FROM PIPE. PLEASE REPAIR..... TT/10-23-15 ,,,,,,,,,,,,,,
FO-330796	10/22/2015	10/26/2015		WOMEN'S RESTROOM 0130 BASEMENT THE 3RD STALL TOILET HANDLE BROKEN..... TT/10-23-15 ,,,,,,,,,,,,,,
FO-330798	10/22/2015	10/26/2015		WOMEN'S RESTROOM 1130 toilet handle broken in 3rd stall..... TT/10-23-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-330814	10/23/2015			Plumber R/R RM 00008/MENS RR repair toilet in basement men's room. long flush MM/10-23-15
FO-330913	10/26/2015	10/29/2015		Toilet in second floor unisex bathroom often runs on and gurgles after it is flushed. The tank often does not fill and the toilet will not flush without unless the lever is jiggled, held, etc. so the tank will fill. Please investigate and correct the pr
FO-331048	10/27/2015	10/29/2015		R/R 3RD FLR MENS RR 2ND URINAL ISN'T FLUSHING GS/10-27-15
FO-331068	10/27/2015			Plumbers, replace 2 leaking lav faucets in mens room next to room 1321 GS/10-27-15
FO-331069	10/27/2015			Plumbers...replace lav faucet in mens room 2138 GS/10-27-15
FO-331070	10/27/2015			Plumbers replace 1inch water pipe sloan valve for bathroom 2204 GS/10-27-15
FO-331092	10/27/2015	10/27/2015		P.M all bathrooms for BOG on Friday 10-30-15 GS/10-27-15
FO-331096	10/27/2015	10/30/2015		Project reopened 10-27-15 DB/10-27-15 **Valve on site / Material to be ordered after OCT 2015 Per David Kuffner. **Water shut down and drain needed to support project JWT 6-29-15 (**) PO REQ DK 6-2-15 (**) PO REQ D
FO-331102	10/27/2015	10/28/2015		On the 2nd floor Men's restroom #2301 the 1st urinal leaking from the wall and underneath..... MM/10-27-15
FO-331122	10/28/2015			plumbers please repair/replace leaking water heater in 2nd floor janitors closet 10-28-15
FO-331123	10/28/2015	10/28/2015		plumbers repair running toilet in men's second floor restroomGS/10-28-15
FO-331124	10/28/2015	10/29/2015		**DUPLICATE/ REFER TO FO#331123 plumbers R/R RM 2006/MENS RR repair running toilet in men's second floor restroom GS/10-28-15
FO-331199	10/28/2015			3inch domestic hot water pipe leaking in hallway near hot room.. DB/10-29-15
FO-331202	10/28/2015			Plumbers, r&r eyewash station in room 3028... GS/ 10-29-15
FO-331267	10/28/2015	10/28/2015		Plumber Interviews DB/10-28-15
FO-331330	10/29/2015			No cold water going to the sink. Need cold water. MM/10-29-15
FO-331364	10/29/2015			R/R RM 113/WOMENS RR (VENDING MACHINE HALLWAY) 2ND STALL TOILET IS LOOSE AGAIN SCREWS MAYBE STRIPPED TT/10-29-15
FO-331391	10/29/2015			R/R RM 322 The sink in the training room kitchen will not shut off, dripping continuously.. It has a Delta single-handle faucet TT/10-29-15
FO-331435	10/30/2015			Mens Restroom - Flush valve on men's urinals not working properly. MM/10-30-15
FO-331448	10/30/2015			R/R 1st floor ladies restroom's 2nd sink from entrance has no hot water MM/1-30-15
FO-331452	10/30/2015			please repair running urinal in men's restroom first floor GS/ 10-30-15
T - Roofing			3	
FO-329176	10/8/2015	10/8/2015		David's flashlight.
FO-330526	10/20/2015			Carpenters please shingle roof at Freer House with shingles located in the basement (attic stock). Shingles need to be pre drilled and attached with copper nails. Any other questions contact Steven Pecic. All roof electronics were repaired by vendor and
FO-331247	10/28/2015			Purdy Library, R/R 1st Floor, Teaching Commons Inside entrance to Teaching Commons: water leaking from ceiling - running down wall and ceiling tiles are wet. Outside entrance to Teaching Commons: ceiling tile hanging loose, looks like it will fall.
Routine			18	
T - Electrician			7	
FO-328557	10/1/2015			PS#1 ROUTINE CHECK 10/1 THRU 10/31/15

WO	Recieved	Finished	Total	Request
FO-328559	10/1/2015			PS#2 ROUTINE CHECK 10/1 THRU 10/31/15
FO-328560	10/1/2015			PS#3 ROUTINE CHECK 10/1 THRU 10/31/15
FO-328561	10/1/2015			PS#4 ROUTINE CHECK 10/1 THRU 10/31/15
FO-328562	10/1/2015			PS#5 ROUTINE CHECK 10/1 THRU 10/31/15
FO-328563	10/1/2015			PS#6 ROUTINE CHECK 10/1 THRU 10/31/15
FO-328566	10/1/2015			VARIOUS CAMPUS LOTS ROUTINE CHECK 10/1 THRU 10/31/15
T - Plumber			11	
FO-329204	10/8/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/10-8-15 ,,,,,,,,,,
FO-329205	10/8/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-8-15 ,,,,,,,,,,
FO-329206	10/8/2015	10/8/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-8-15 ,,,,,,,,,,
FO-329208	10/8/2015	10/9/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-8-15 ,,,,,,,,,,
FO-329209	10/8/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-8-15 ,,,,,,,,,,
FO-329397	10/12/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-12-15 ,,,,,,,,,, FINDINGS:
FO-329398	10/12/2015	10/13/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-12-15 ,,,,,,,,,, FINDINGS:
FO-329400	10/12/2015	10/13/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-12-15 ,,,,,,,,,, FINDINGS:
FO-329401	10/12/2015	10/12/2015		BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-12-15 ,,,,,,,,,, FINDINGS:
FO-329402	10/12/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/ 10-12-15 ,,,,,,,,,, FINDINGS:
FO-329403	10/12/2015			BFS/2015 Please Test, Inspect and Repair Water Backflow Devices in Building. Complete Testing, Record Data, and Install Valve Tag ,,,,,,,,,, DB/10-12-15 ,,,,,,,,,, FINDINGS:

Scheduled Maint. (PM)	790
Engineering	748
Routine	748
E - Auxiliary	46

FO-327596	10/1/2015	10/8/2015	PM - Air Handling Unit
FO-327597	10/1/2015	10/8/2015	PM - Air Handling Unit
FO-327598	10/1/2015		PM - Air Handling Unit
FO-327599	10/1/2015	10/14/2015	PM - Air Handling Unit
FO-327600	10/1/2015		PM - Air Handling Unit
FO-327601	10/1/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327603	10/1/2015		PM - Water Booster Pump

WO	Recieved	Finished	Total	Request
FO-327604	10/1/2015			PM - Water Booster Pump
FO-327618	10/1/2015			PM - Air Handling Unit
FO-327619	10/1/2015			PM - Air Handling Unit
FO-327620	10/1/2015			PM - Air Handling Unit
FO-327621	10/1/2015			PM - Air Handling Unit
FO-327622	10/1/2015			PM - Air Handling Unit
FO-327623	10/1/2015			PM - Air Handling Unit
FO-327624	10/1/2015			PM - Air Handling Unit
FO-327625	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327626	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327627	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327628	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327629	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327630	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327631	10/1/2015	10/29/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327632	10/1/2015	10/13/2015		PM - Water/Air Cooled Condenser
FO-327633	10/1/2015	10/29/2015		PM - Absorption Unit
FO-327634	10/1/2015	10/29/2015		PM - Absorption Unit
FO-327636	10/1/2015	10/29/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327637	10/1/2015	10/29/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327648	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-327649	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-327650	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-327651	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-327652	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-327635	10/5/2015	10/9/2015		PM - Emergency Shower/Eyewash Station
FO-324887	10/6/2015	10/7/2015		Generator Maintenance, Monthly
FO-328238	10/12/2015	10/16/2015		PM - Emergency Shower/Eyewash Station
FO-328224	10/13/2015	10/13/2015		Generator Maintenance, Monthly
FO-324891	10/14/2015	10/14/2015		Generator Maintenance, Monthly
FO-328808	10/19/2015	10/23/2015		PM - Emergency Shower/Eyewash Station
FO-328427	10/21/2015	10/21/2015		Generator Maintenance, Monthly
FO-329436	10/26/2015	10/29/2015		PM - Emergency Shower/Eyewash Station
FO-328401	10/27/2015	10/28/2015		Generator Maintenance, Monthly
FO-328411	10/27/2015	10/28/2015		Generator Maintenance, Monthly
FO-328413	10/27/2015	10/28/2015		Generator Maintenance, Monthly
FO-328415	10/27/2015	10/28/2015		Generator Maintenance, Monthly
FO-328417	10/27/2015	10/28/2015		Generator Maintenance, Monthly
FO-328419	10/27/2015	10/28/2015		Generator Maintenance, Monthly
E - MedPharm			39	
FO-325835	10/1/2015	10/27/2015		PM - Unit/Space Heater
FO-325836	10/1/2015	10/23/2015		PM - Unit/Space Heater
FO-325837	10/1/2015	10/22/2015		PM - Unit/Space Heater
FO-325838	10/1/2015	10/27/2015		PM - Unit/Space Heater
FO-325839	10/1/2015	10/22/2015		PM - Unit/Space Heater
FO-326061	10/1/2015			PM - Unit/Space Heater
FO-326062	10/1/2015			PM - Unit/Space Heater

WO	Recieved	Finished	Total	Request
FO-326063	10/1/2015			PM - Unit/Space Heater
FO-326064	10/1/2015			PM - Unit/Space Heater
FO-326065	10/1/2015			PM - Unit/Space Heater
FO-327358	10/1/2015	10/21/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327359	10/1/2015	10/21/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327360	10/1/2015	10/21/2015		PM - Domestic Water Heater, Steam
FO-327361	10/1/2015	10/21/2015		PM - Domestic Water Heater, Steam
FO-327362	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327363	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327364	10/1/2015	10/12/2015		PM - Domestic Water Heater, Steam
FO-327365	10/1/2015	10/12/2015		PM - Domestic Water Heater, Steam
FO-327366	10/1/2015			PM - Centrifugal Pump, over 1 H.P.
FO-327367	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327368	10/1/2015	10/30/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327369	10/1/2015	10/30/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327370	10/1/2015	10/8/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327371	10/1/2015	10/8/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327372	10/1/2015	10/7/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327373	10/1/2015	10/7/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327374	10/1/2015	10/12/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327375	10/1/2015	10/12/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327376	10/1/2015	10/5/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327377	10/1/2015	10/5/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327378	10/1/2015	10/5/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327379	10/1/2015	10/15/2015		PM - Water Softener
FO-327380	10/1/2015	10/12/2015		PM - Domestic Water Heater, Steam
FO-327381	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327382	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327383	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-328222	10/2/2015	10/2/2015		Generator Maintenance, Monthly
FO-328407	10/23/2015	10/23/2015		Generator Maintenance, Monthly
FO-328409	10/27/2015			Generator Maintenance, Monthly
E - North			58	
FO-327384	10/1/2015	10/27/2015		PM - Unit/Space Heater
FO-327385	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-327386	10/1/2015	10/15/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327387	10/1/2015	10/9/2015		PM - Chemical Feed/Metering Pump/Controller
FO-327388	10/1/2015	10/9/2015		PM - Sump Pump
FO-327389	10/1/2015	10/9/2015		PM - Sump Pump
FO-327390	10/1/2015	10/15/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327391	10/1/2015	10/12/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327392	10/1/2015	10/9/2015		PM - Chemical Feed/Metering Pump/Controller
FO-327393	10/1/2015	10/9/2015		PM - Chemical Feed/Metering Pump/Controller
FO-327394	10/1/2015	10/9/2015		PM - Chemical Feed/Metering Pump/Controller
FO-327395	10/1/2015	10/27/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327396	10/1/2015	10/27/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327397	10/1/2015	10/27/2015		PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-327398	10/1/2015	10/27/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327399	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327400	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327401	10/1/2015	10/20/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327402	10/1/2015	10/13/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327403	10/1/2015	10/27/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327404	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327405	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327406	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327407	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327408	10/1/2015	10/12/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327409	10/1/2015	10/14/2015		PM - Domestic Water Heater, Electric
FO-327410	10/1/2015			PM - Humidifier
FO-327411	10/1/2015			PM - Humidifier
FO-327412	10/1/2015			PM - Humidifier
FO-327413	10/1/2015			PM - Humidifier
FO-327414	10/1/2015			PM - Cooling Tower Lay-up - GE Betz
FO-327415	10/1/2015			PM - Cooling Tower Lay-up - GE Betz
FO-327416	10/1/2015			PM - Cooling Tower Lay-up - GE Betz
FO-327417	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327418	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327419	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327420	10/1/2015	10/26/2015		Replace PRE-filters
FO-327421	10/1/2015	10/26/2015		Replace PRE-filters
FO-327422	10/1/2015	10/26/2015		Replace PRE-filters
FO-327423	10/1/2015			Replace PRE-filters
FO-327424	10/1/2015			Replace PRE-filters
FO-327425	10/1/2015	10/26/2015		Replace PRE-filters
FO-327426	10/1/2015			Replace PRE-filters
FO-327427	10/1/2015	10/26/2015		Replace PRE-filters
FO-327428	10/1/2015			Replace PRE-filters
FO-328789	10/1/2015			PM - Condensate Return Pump
FO-328790	10/1/2015	10/28/2015		PM - Condensate Return Pump
FO-328791	10/1/2015	10/28/2015		PM - Condensate Return Pump
FO-328792	10/1/2015	10/28/2015		PM - Condensate Return Pump
FO-328793	10/1/2015	10/28/2015		PM - Condensate Return Pump
FO-328795	10/1/2015			PM - Condensate Return Pump
FO-328796	10/1/2015			PM - Condensate Return Pump
FO-328797	10/1/2015	10/28/2015		PM - Condensate Return Pump
FO-328798	10/1/2015			PM - Condensate Return Pump
FO-328799	10/1/2015			PM - Condensate Return Pump
FO-328794	10/15/2015	10/12/2015		PM - Outside/Fresh Air Intake Screens
FO-328430	10/16/2015			Generator Maintenance, Monthly
FO-328421	10/28/2015	10/28/2015		Generator Maintenance, Monthly
E - Northeast			56	
FO-326132	10/1/2015			Replace PRE-filters
FO-326133	10/1/2015			Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-326134	10/1/2015			Replace PRE-filters
FO-326135	10/1/2015			Replace PRE-filters
FO-326136	10/1/2015			Replace PRE-filters
FO-326137	10/1/2015			Replace PRE-filters
FO-326138	10/1/2015			Replace PRE-filters
FO-326139	10/1/2015			Replace PRE-filters
FO-326140	10/1/2015			Replace PRE-filters
FO-326141	10/1/2015			Replace PRE-filters
FO-326142	10/1/2015			Replace PRE-filters
FO-326143	10/1/2015			Replace PRE-filters
FO-326144	10/1/2015			Replace PRE-filters
FO-326145	10/1/2015			Replace PRE-filters
FO-327429	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327430	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327431	10/1/2015			PM - Unit/Space Heater
FO-327432	10/1/2015			PM - Unit/Space Heater
FO-327433	10/1/2015			PM - Unit/Space Heater
FO-327434	10/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-327435	10/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-327436	10/1/2015			PM - Unit/Space Heater
FO-327437	10/1/2015			PM - Unit/Space Heater
FO-327438	10/1/2015			PM - Unit/Space Heater
FO-327439	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-327440	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-327441	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-327442	10/1/2015			PM - Unit/Space Heater
FO-327443	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-327444	10/1/2015	10/27/2015		PM - Unit/Space Heater
FO-327445	10/1/2015	10/27/2015		PM - Unit/Space Heater
FO-327446	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-327447	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-327448	10/1/2015	10/26/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327449	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327450	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327451	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327452	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327453	10/1/2015	10/27/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327769	10/1/2015	10/27/2015		Replace PRE-filters
FO-327770	10/1/2015	10/27/2015		Replace PRE-filters
FO-327771	10/1/2015	10/27/2015		Replace PRE-filters
FO-327772	10/1/2015	10/27/2015		Replace PRE-filters
FO-328800	10/1/2015			PM - Condensate Return Pump
FO-328801	10/1/2015			PM - Condensate Return Pump
FO-328802	10/1/2015			PM - Condensate Return Pump
FO-328803	10/1/2015			PM - Condensate Return Pump
FO-324919	10/2/2015	10/2/2015		Generator Maintenance, Monthly
FO-324908	10/2/2015			Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-324925	10/2/2015	10/2/2015		Generator Maintenance, Monthly
FO-328429	10/15/2015	10/15/2015		Generator Maintenance, Monthly
FO-329432	10/21/2015	10/29/2015		PM - Centrifugal Pump, over 1 H.P.
FO-328436	10/22/2015			Generator Maintenance, Monthly
FO-328438	10/22/2015			Generator Maintenance, Monthly
FO-329433	10/24/2015			PM - Domestic Water Heater, Gas
FO-328404	10/28/2015	10/28/2015		Generator Maintenance, Monthly
E - Preventative Maintenance			317	
FO-325831	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325832	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325833	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325834	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325840	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325841	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325842	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325843	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325844	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325845	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325846	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325847	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325848	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325849	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325850	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325851	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325852	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325853	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325854	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325855	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325856	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325857	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325858	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325859	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-325860	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-325861	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-325862	10/1/2015	10/28/2015		PM - Unit/Space Heater
FO-325863	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325864	10/1/2015			PM - Unit/Space Heater
FO-325865	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325866	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325867	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325868	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325869	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325870	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325871	10/1/2015			PM - Unit/Space Heater
FO-325872	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325873	10/1/2015			PM - Unit/Space Heater
FO-325874	10/1/2015	10/29/2015		PM - Unit/Space Heater

WO	Recieved	Finished	Total	Request
FO-325875	10/1/2015			PM - Unit/Space Heater
FO-325876	10/1/2015			PM - Unit/Space Heater
FO-325877	10/1/2015			PM - Unit/Space Heater
FO-325878	10/1/2015			PM - Unit/Space Heater
FO-325879	10/1/2015			PM - Unit/Space Heater
FO-325880	10/1/2015			PM - Unit/Space Heater
FO-325881	10/1/2015			PM - Unit/Space Heater
FO-325882	10/1/2015			PM - Unit/Space Heater
FO-325883	10/1/2015			PM - Unit/Space Heater
FO-325884	10/1/2015			PM - Unit/Space Heater
FO-325885	10/1/2015			PM - Unit/Space Heater
FO-325886	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-325887	10/1/2015			PM - Unit/Space Heater
FO-325888	10/1/2015			PM - Unit/Space Heater
FO-325889	10/1/2015			PM - Unit/Space Heater
FO-325890	10/1/2015			PM - Unit/Space Heater
FO-325891	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325892	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325893	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325894	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325895	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325896	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325897	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325898	10/1/2015			PM - Unit/Space Heater
FO-325899	10/1/2015			PM - Unit/Space Heater
FO-325900	10/1/2015			PM - Unit/Space Heater
FO-325901	10/1/2015			PM - Unit/Space Heater
FO-325902	10/1/2015			PM - Unit/Space Heater
FO-325903	10/1/2015			PM - Unit/Space Heater
FO-325904	10/1/2015			PM - Unit/Space Heater
FO-325905	10/1/2015			PM - Unit/Space Heater
FO-325906	10/1/2015	10/30/2015		PM - Unit/Space Heater
FO-325907	10/1/2015	10/30/2015		PM - Unit/Space Heater
FO-325908	10/1/2015	10/30/2015		PM - Unit/Space Heater
FO-325909	10/1/2015			PM - Unit/Space Heater
FO-325910	10/1/2015			PM - Unit/Space Heater
FO-325911	10/1/2015			PM - Unit/Space Heater
FO-325912	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325913	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325914	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325915	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325916	10/1/2015	10/19/2015		PM - Unit/Space Heater
FO-325917	10/1/2015	10/20/2015		PM - Unit/Space Heater
FO-325918	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325919	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325920	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325921	10/1/2015	10/6/2015		PM - Unit/Space Heater

WO	Recieved	Finished	Total	Request
FO-325922	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325923	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325924	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325925	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325926	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325927	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325928	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325929	10/1/2015	10/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325930	10/1/2015	10/30/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325931	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325932	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325933	10/1/2015			PM - Unit/Space Heater
FO-325934	10/1/2015			PM - Unit/Space Heater
FO-325935	10/1/2015			PM - Unit/Space Heater
FO-325936	10/1/2015			PM - Unit/Space Heater
FO-325937	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325938	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325939	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325940	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325941	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325942	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325943	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325944	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325945	10/1/2015	10/13/2015		PM - Unit/Space Heater
FO-325946	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325947	10/1/2015	10/14/2015		PM - Unit/Space Heater
FO-325948	10/1/2015			PM - Unit/Space Heater
FO-325949	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325950	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325951	10/1/2015		10/1/2015	Maintain Fan Powered Boxes
FO-325952	10/1/2015		10/1/2015	Maintain Fan Powered Boxes
FO-325953	10/1/2015		10/1/2015	Maintain Fan Powered Boxes
FO-325954	10/1/2015		10/1/2015	Maintain Fan Powered Boxes
FO-325955	10/1/2015	10/20/2015		Replace PRE-filters
FO-325956	10/1/2015	10/20/2015		Replace PRE-filters
FO-325957	10/1/2015	10/20/2015		Replace PRE-filters
FO-325958	10/1/2015	10/20/2015		Replace PRE-filters
FO-325959	10/1/2015	10/20/2015		Replace PRE-filters
FO-325960	10/1/2015	10/29/2015		Replace PRE-filters
FO-325961	10/1/2015	10/29/2015		Replace PRE-filters
FO-325962	10/1/2015	10/29/2015		Replace PRE-filters
FO-325963	10/1/2015	10/29/2015		Replace PRE-filters
FO-325964	10/1/2015	10/29/2015		Replace PRE-filters
FO-325965	10/1/2015	10/29/2015		Replace PRE-filters
FO-325966	10/1/2015	10/29/2015		Replace PRE-filters
FO-325967	10/1/2015	10/29/2015		Replace PRE-filters
FO-325968	10/1/2015	10/20/2015		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-325969	10/1/2015	10/20/2015		Replace PRE-filters
FO-325970	10/1/2015	10/29/2015		Replace PRE-filters
FO-325971	10/1/2015	10/9/2015		PM - Unit/Space Heater
FO-325972	10/1/2015	10/9/2015		PM - Unit/Space Heater
FO-325973	10/1/2015	10/9/2015		PM - Unit/Space Heater
FO-325974	10/1/2015	10/30/2015		PM - Unit/Space Heater
FO-325975	10/1/2015	10/30/2015		PM - Unit/Space Heater
FO-325976	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325977	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325978	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325979	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325980	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325981	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325982	10/1/2015			PM - Unit/Space Heater
FO-325983	10/1/2015			PM - Unit/Space Heater
FO-325984	10/1/2015			PM - Unit/Space Heater
FO-325985	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325986	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325987	10/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325988	10/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325989	10/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-325990	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325991	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325992	10/1/2015	10/6/2015		PM - Unit/Space Heater
FO-325993	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325994	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-325995	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325996	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325997	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325998	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-325999	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-326000	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-326001	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-326002	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-326003	10/1/2015	10/7/2015		PM - Unit/Space Heater
FO-326004	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-326005	10/1/2015	10/8/2015		PM - Unit/Space Heater
FO-326006	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326007	10/1/2015	10/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326008	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326009	10/1/2015			PM - Unit/Space Heater
FO-326010	10/1/2015			PM - Unit/Space Heater
FO-326011	10/1/2015	10/13/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326012	10/1/2015	10/22/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326013	10/1/2015	10/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326014	10/1/2015	10/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326015	10/1/2015	10/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-326016	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326017	10/1/2015	10/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326018	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326019	10/1/2015	10/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326020	10/1/2015	10/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326021	10/1/2015	10/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326022	10/1/2015	10/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326023	10/1/2015	10/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326024	10/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-326025	10/1/2015	10/5/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326026	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326027	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326028	10/1/2015	10/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326029	10/1/2015	10/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326030	10/1/2015	10/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326031	10/1/2015	10/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326032	10/1/2015	10/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326033	10/1/2015	10/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326034	10/1/2015	10/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326035	10/1/2015	10/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326036	10/1/2015	10/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326037	10/1/2015	10/13/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326038	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326039	10/1/2015	10/13/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326040	10/1/2015	10/13/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326041	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326042	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326043	10/1/2015	10/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326044	10/1/2015			PM - Monthly Fire Alarm/Fire Protection System Test
FO-326045	10/1/2015	10/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326046	10/1/2015	10/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326047	10/1/2015	10/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326048	10/1/2015	10/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326049	10/1/2015	10/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326050	10/1/2015	10/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326051	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326052	10/1/2015	10/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326053	10/1/2015	10/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326054	10/1/2015	10/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326055	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326056	10/1/2015	10/21/2015		Replace PRE-filters
FO-326057	10/1/2015	10/26/2015		Replace PRE-filters
FO-326058	10/1/2015	10/26/2015		Replace PRE-filters
FO-326059	10/1/2015	10/21/2015		Replace PRE-filters
FO-326060	10/1/2015	10/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326066	10/1/2015	10/28/2015		PM - Air Handling Unit (ANNUAL)
FO-326067	10/1/2015	10/12/2015		PM - Air Handling Unit (ANNUAL)

WO	Recieved	Finished	Total	Request
FO-326068	10/1/2015	10/28/2015		PM - Air Handling Unit (ANNUAL)
FO-326069	10/1/2015	10/27/2015		PM - Air Handling Unit (ANNUAL)
FO-326070	10/1/2015	10/12/2015		PM - Air Handling Unit (ANNUAL)
FO-326071	10/1/2015	10/27/2015		PM - Air Handling Unit (ANNUAL)
FO-326072	10/1/2015	10/28/2015		PM - Air Handling Unit (ANNUAL)
FO-326073	10/1/2015	10/20/2015		Replace PRE-filters
FO-326074	10/1/2015	10/20/2015		Replace PRE-filters
FO-326075	10/1/2015	10/9/2015		Replace PRE-filters
FO-326076	10/1/2015	10/9/2015		Replace PRE-filters
FO-326077	10/1/2015	10/9/2015		Replace PRE-filters
FO-326078	10/1/2015	10/28/2015		Replace PRE-filters
FO-326079	10/1/2015	10/28/2015		Replace PRE-filters
FO-326080	10/1/2015	10/24/2015		Replace PRE-filters
FO-326081	10/1/2015	10/24/2015		Replace PRE-filters
FO-326082	10/1/2015	10/23/2015		Replace PRE-filters
FO-326083	10/1/2015	10/23/2015		Replace PRE-filters
FO-326084	10/1/2015	10/16/2015		PM - Unit/Space Heater
FO-326085	10/1/2015	10/15/2015		PM - Unit/Space Heater
FO-326086	10/1/2015	10/15/2015		PM - Unit/Space Heater
FO-326087	10/1/2015	10/27/2015		PM - Air Handling Unit (ANNUAL)
FO-326089	10/1/2015			Replace PRE-filters
FO-326090	10/1/2015			Replace PRE-filters
FO-326091	10/1/2015			Replace PRE-filters
FO-326092	10/1/2015	10/9/2015		Replace PRE-filters
FO-326093	10/1/2015	10/9/2015		Replace PRE-filters
FO-326094	10/1/2015			Replace PRE-filters
FO-326095	10/1/2015			Replace PRE-filters
FO-326096	10/1/2015			Replace PRE-filters
FO-326097	10/1/2015			Replace PRE-filters
FO-326098	10/1/2015			Replace PRE-filters
FO-326099	10/1/2015			Replace PRE-filters
FO-326100	10/1/2015			Replace PRE-filters
FO-326101	10/1/2015			Replace PRE-filters
FO-326102	10/1/2015	10/15/2015		Replace PRE-filters
FO-326103	10/1/2015	10/16/2015		Replace PRE-filters
FO-326104	10/1/2015	10/15/2015		Replace PRE-filters
FO-326105	10/1/2015	10/15/2015		Replace PRE-filters
FO-326106	10/1/2015	10/15/2015		Replace PRE-filters
FO-326107	10/1/2015	10/30/2015		Replace PRE-filters
FO-326108	10/1/2015	10/15/2015		Replace PRE-filters
FO-326109	10/1/2015	10/14/2015		Replace PRE-filters
FO-326110	10/1/2015	10/14/2015		Replace PRE-filters
FO-326111	10/1/2015	10/15/2015		Replace PRE-filters
FO-326112	10/1/2015	10/2/2015		Replace PRE-filters
FO-326113	10/1/2015	10/14/2015		Replace PRE-filters
FO-326114	10/1/2015	10/15/2015		Replace PRE-filters
FO-326115	10/1/2015	10/15/2015		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-326116	10/1/2015			Replace PRE-filters
FO-326117	10/1/2015			Replace PRE-filters
FO-326118	10/1/2015	10/27/2015		Replace PRE-filters
FO-326119	10/1/2015			Replace PRE-filters
FO-326120	10/1/2015			Replace PRE-filters
FO-326121	10/1/2015	10/27/2015		Replace PRE-filters
FO-326122	10/1/2015	10/27/2015		Replace PRE-filters
FO-326123	10/1/2015	10/27/2015		Replace PRE-filters
FO-326124	10/1/2015	10/27/2015		Replace PRE-filters
FO-326125	10/1/2015	10/21/2015		Replace PRE-filters
FO-326126	10/1/2015	10/21/2015		Replace PRE-filters
FO-326127	10/1/2015	10/24/2015		Replace PRE-filters
FO-326128	10/1/2015	10/23/2015		Replace PRE-filters
FO-326129	10/1/2015	10/24/2015		Replace PRE-filters
FO-326130	10/1/2015	10/27/2015		Replace PRE-filters
FO-326131	10/1/2015	10/23/2015		Replace PRE-filters
FO-326146	10/1/2015	10/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326154	10/1/2015			PM - Air Handling Unit, HV Type
FO-326155	10/1/2015			PM - Air Handling Unit, HV Type
FO-326156	10/1/2015	10/17/2015		Replace PRE-filters
FO-326157	10/1/2015	10/17/2015		Replace PRE-filters
FO-326158	10/1/2015	10/17/2015		Replace PRE-filters
FO-326159	10/1/2015	10/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-326160	10/1/2015	10/12/2015		PM - Unit/Space Heater
FO-326161	10/1/2015	10/27/2015		Replace PRE-filters
FO-326162	10/1/2015	10/27/2015		Replace PRE-filters
FO-326163	10/1/2015	10/27/2015		Replace PRE-filters
FO-321756	10/1/2015	10/13/2015		Replace PRE-filters
FO-321755	10/1/2015	10/5/2015		Replace PRE-filters
FO-321754	10/1/2015	10/12/2015		Replace PRE-filters
FO-321748	10/1/2015	10/12/2015		Replace PRE-filters
FO-321747	10/1/2015	10/7/2015		Replace PRE-filters
FO-321746	10/1/2015	10/6/2015		Replace PRE-filters
FO-321745	10/1/2015	10/2/2015		Replace PRE-filters
FO-321741	10/1/2015	10/13/2015		Replace PRE-filters
FO-321744	10/1/2015	10/28/2015		Replace PRE-filters
FO-321743	10/1/2015	10/31/2015		Replace PRE-filters
FO-321742	10/1/2015	10/30/2015		Replace PRE-filters
FO-321821	10/1/2015	10/5/2015		Replace PRE-filters
FO-327788	10/1/2015	10/30/2015		PM Replace Exhaust Air Filters
FO-327789	10/1/2015	10/30/2015		PM Replace Exhaust Air Filters
FO-327790	10/1/2015	10/30/2015		PM Replace Exhaust Air Filters
FO-327791	10/1/2015	10/30/2015		PM Replace Exhaust Air Filters
E - South			38	
FO-327454	10/1/2015	10/19/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327455	10/1/2015	10/26/2015		PM - Centrifugal Pump, over 1 H.P.
FO-327456	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons

WO	Recieved	Finished	Total	Request
FO-327457	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327458	10/1/2015	10/19/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327523	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327525	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327592	10/1/2015	10/28/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327609	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327638	10/1/2015	10/30/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327639	10/1/2015	10/13/2015		PM - Harmsco Side Stream Filter
FO-328809	10/1/2015	10/13/2015		PM - Chemical Feed/Metering Pump/Controller
FO-328810	10/1/2015	10/13/2015		PM - Chemical Feed/Metering Pump/Controller
FO-328811	10/1/2015	10/13/2015		PM - Chemical Feed/Metering Pump/Controller
FO-328812	10/1/2015	10/13/2015		PM - Chemical Feed/Metering Pump/Controller
FO-328813	10/1/2015	10/16/2015		PM - Condensate Return Pump
FO-328814	10/1/2015	10/16/2015		PM - Condensate Return Pump
FO-328815	10/1/2015	10/16/2015		PM - Condensate Return Pump
FO-328816	10/1/2015	10/16/2015		PM - Condensate Return Pump
FO-328817	10/1/2015	10/20/2015		PM - Condensate Return Pump
FO-328818	10/1/2015	10/20/2015		PM - Condensate Return Pump
FO-328819	10/1/2015	10/15/2015		PM - Condensate Return Pump
FO-328820	10/1/2015	10/15/2015		PM - Condensate Return Pump
FO-328821	10/1/2015	10/13/2015		PM - Condensate Return Pump
FO-327640	10/2/2015	10/13/2015		PM INSPECT AND CLEAN COIL
FO-327641	10/2/2015	10/13/2015		PM INSPECT AND CLEAN COIL
FO-327642	10/2/2015	10/15/2015		PM INSPECT AND CLEAN COIL
FO-324846	10/8/2015	10/9/2015		Generator Maintenance, Monthly
FO-324850	10/8/2015	10/9/2015		Generator Maintenance, Monthly
FO-324900	10/8/2015	10/15/2015		Generator Maintenance, Monthly
FO-328226	10/8/2015	10/6/2015		Monthly AHU Inspection Clean Room Unit 2
FO-328227	10/8/2015	10/6/2015		PM - Monthly AHU Inspection Clean Room Unit 1
FO-328239	10/8/2015	10/15/2015		PM - Domestic Water Heater, Gas
FO-328432	10/15/2015	10/16/2015		Generator Maintenance, Monthly
FO-328822	10/17/2015			PM INSPECT AND CLEAN COIL
FO-328823	10/17/2015			PM INSPECT AND CLEAN COIL
FO-328229	10/20/2015	10/20/2015		Generator Maintenance, Monthly
FO-328402	10/21/2015	10/22/2015		Generator Maintenance, Monthly
E - Southeast			165	
FO-327459	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327461	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327466	10/1/2015	10/1/2015		PM - Air Handling Unit
FO-327467	10/1/2015	10/1/2015		PM - Air Handling Unit
FO-327468	10/1/2015	10/24/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327469	10/1/2015	10/5/2015		PM - Unit/Space Heater
FO-327470	10/1/2015	10/5/2015		PM - Unit/Space Heater
FO-327471	10/1/2015	10/5/2015		PM - Unit/Space Heater
FO-327472	10/1/2015	10/6/2015		PM - Heat Pumps (5057 Woodward)
FO-327473	10/1/2015	10/6/2015		PM - Heat Pumps (5057 Woodward)
FO-327474	10/1/2015	10/6/2015		PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-327522	10/1/2015	10/21/2015		PM - Heat Pumps (5057 Woodward)
FO-327524	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327526	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327527	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327528	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327529	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327530	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327531	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327532	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327533	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327534	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327535	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327536	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327537	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327538	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327539	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327540	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327541	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327542	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327543	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327544	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327545	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327546	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327547	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327548	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327549	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327550	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327551	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327552	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327553	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327554	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327555	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327556	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327557	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327558	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327559	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327560	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327561	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327562	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327563	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327564	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327565	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327566	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327567	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327568	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327569	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327570	10/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-327571	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327572	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327573	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327574	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327575	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327576	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327577	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327578	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327579	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327580	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327581	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-327582	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327583	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327584	10/1/2015			PM - Fan Coil/HV/AC Unit
FO-327586	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327587	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327588	10/1/2015	10/26/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327589	10/1/2015	10/27/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327590	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327591	10/1/2015	10/6/2015		PM - Roof Sumps - Zone 2, Area 3
FO-327593	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327594	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327595	10/1/2015			PM - Roof Sumps - Zone 2, Area 3
FO-327605	10/1/2015	10/9/2015		PM - Domestic Water Heater, Electric
FO-327614	10/1/2015	10/29/2015		PM - Steam to Air Handling Unit - Open for Winter (Old Main)
FO-327615	10/1/2015	10/29/2015		PM - Steam to Air Handling Unit - Open for Winter (Old Main)
FO-327616	10/1/2015			PM - Unit/Space Heater
FO-327617	10/1/2015			Gas Fired Furnace
FO-327643	10/1/2015			Gas Fired Furnace
FO-327644	10/1/2015			Gas Fired Furnace
FO-327645	10/1/2015			Gas Fired Furnace
FO-327646	10/1/2015	10/21/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327647	10/1/2015			PM - Cooling Tower, 500 - 1000 Tons
FO-328804	10/1/2015			PM - Chemical Feed/Metering Pump/Controller
FO-328805	10/1/2015			PM - Chemical Feed/Metering Pump/Controller
FO-328806	10/1/2015			PM - Chemical Feed/Metering Pump/Controller
FO-328807	10/1/2015			PM - Chemical Feed/Metering Pump/Controller
FO-327673	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327674	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327675	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327676	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327682	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327677	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327678	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327680	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327679	10/1/2015			PM - Fan Motor Box (Old Main)
FO-327681	10/1/2015			PM - Fan Motor Box (Old Main)

WO	Recieved	Finished	Total	Request
FO-327610	10/2/2015	10/29/2015		PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-327611	10/2/2015	10/29/2015		PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-327612	10/2/2015	10/29/2015		PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-327613	10/2/2015	10/29/2015		PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-324922	10/2/2015	10/2/2015		Generator Maintenance, Monthly
FO-327606	10/3/2015	10/1/2015		PM - Domestic Water Heater, Gas
FO-327585	10/4/2015			PM - Cooling Tower Fan (Old Main)
FO-328225	10/10/2015	10/21/2015		PM - Heat Pumps (5057 Woodward)
FO-328223	10/20/2015	10/21/2015		Generator Maintenance, Monthly
FO-328233	10/20/2015	10/21/2015		Generator Maintenance, Monthly
FO-328235	10/20/2015	10/21/2015		Generator Maintenance, Monthly
FO-329435	10/22/2015	10/1/2015		PM - Domestic Water Heater, Gas
FO-329434	10/23/2015	10/23/2015		PM - Humidifier
E - West			29	
FO-327460	10/1/2015	10/28/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327463	10/1/2015	10/16/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327464	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-327465	10/1/2015	10/29/2015		PM - Unit/Space Heater
FO-327602	10/1/2015	10/15/2015		PM - Cooling Tower, 500 - 1000 Tons
FO-327607	10/1/2015	10/29/2015		PM - Domestic Water Heater, Electric
FO-327608	10/1/2015	10/29/2015		PM - Domestic Water Heater, Electric
FO-327653	10/1/2015	10/28/2015		Replace PRE-filters
FO-327654	10/1/2015	10/29/2015		Replace PRE-filters
FO-327655	10/1/2015	10/28/2015		Replace PRE-filters
FO-327656	10/1/2015	10/28/2015		Replace PRE-filters
FO-327657	10/1/2015	10/28/2015		Replace PRE-filters
FO-327658	10/1/2015	10/29/2015		Replace PRE-filters
FO-327659	10/1/2015	10/28/2015		Replace PRE-filters
FO-327660	10/1/2015	10/28/2015		Replace PRE-filters
FO-327661	10/1/2015	10/28/2015		Replace PRE-filters
FO-327662	10/1/2015	10/28/2015		Replace PRE-filters
FO-327663	10/1/2015	10/28/2015		Replace PRE-filters
FO-327664	10/1/2015	10/28/2015		Replace PRE-filters
FO-327665	10/1/2015	10/28/2015		Replace PRE-filters
FO-327666	10/1/2015	10/28/2015		Replace PRE-filters
FO-327667	10/1/2015	10/28/2015		Replace PRE-filters
FO-327668	10/1/2015	10/28/2015		Replace PRE-filters
FO-327669	10/1/2015	10/28/2015		Replace PRE-filters
FO-327670	10/1/2015	10/28/2015		Replace PRE-filters
FO-327671	10/1/2015	10/28/2015		Replace PRE-filters
FO-327672	10/1/2015	10/28/2015		Replace PRE-filters
FO-324912	10/13/2015	10/13/2015		Generator Maintenance, Monthly
FO-328434	10/22/2015	10/23/2015		Generator Maintenance, Monthly
Trades			42	
Routine			42	
T - Electrician			37	
FO-328231	10/2/2015	10/2/2015		Generator Test, Friday 10/2/2015 @ 2:15 PM.

WO	Recieved	Finished	Total	Request
FO-328241	10/2/2015	10/2/2015		Generator Test, Friday 1-/2/2015 @ 2:15 PM.
FO-328242	10/2/2015	10/2/2015		Generator Test, Friday 1-/2/2015 @ 2:15 PM.
FO-328243	10/2/2015	10/2/2015		Generator Test, Friday 10/2/2015 @ 2:15 PM.
FO-324848	10/8/2015	10/12/2015		Generator Test, Thursday 10/15/2015 @ 7:15 AM. Also fill the Batteries on the rack for the UPS.
FO-324852	10/8/2015	10/8/2015		Generator Test, Thursday 10/15/2015 @ 7:15 AM. Also fill Batteries on the rack for the UPS.
FO-324898	10/8/2015	10/8/2015		Generator Test, Thursday 10/15/2015 @ 7:15 AM.
FO-328237	10/9/2015			Generator Test, Tuesday 10/6/2015 @ 7:15 AM.
FO-328240	10/9/2015	10/9/2015		Generator Test, Friday 10/9/2015 @ 7:15 AM.
FO-328422	10/9/2015	10/13/2015		Generator Test, Tuesday 10/13/2015 @ 7:15AM.
FO-328423	10/9/2015			Generator Maintenance, Monthly
FO-328424	10/9/2015	10/13/2015		Generator Test, Tuesday 10/13/2015 @ 7:15 AM.
FO-328425	10/9/2015			Generator Maintenance, Monthly
FO-328228	10/13/2015	10/20/2015		Generator Test, Tuesday 10/20/2015 @7:15 AM.
FO-328232	10/13/2015	10/20/2015		Generator Test, Tuesday 10/20/2015 @ 8:15 AM.
FO-328234	10/13/2015	10/20/2015		Generator Test, Tuesday 10/20/2015 @ 8:15 AM.
FO-324910	10/13/2015	10/13/2015		Generator Test, Tuesday 10/13/2015 @ 1PM.
FO-324885	10/13/2015	10/20/2015		Generator Test, Tuesday 10/20/2015 @ 1PM.
FO-324889	10/14/2015	10/14/2015		Generator Test, Wednesday 10/14/2015 @ 1PM.
FO-328428	10/15/2015			Generator Test, Thursday 10/15/2015 @ 7:15 AM.
FO-328431	10/15/2015	10/15/2015		Generator Test, Thursday 10/15/2015 @ 7:15 AM.
FO-328230	10/20/2015	10/21/2015		Generator Test, Tuesday 10/20/2015 @ 9:30 AM.
FO-328236	10/20/2015	10/20/2015		Generator Test, Tuesday 10/20/2015 @ 9:30 AM.
FO-328403	10/21/2015	10/21/2015		Generator Test, Wednesday 10/21/2015 @ 10AM.
FO-328426	10/21/2015	10/21/2015		Generator Test, Wednesday 10/21/2015 @ 7:15 AM.
FO-328433	10/22/2015	10/22/2015		Generator Test, Thursday 10/22/2015 @ 7:15 AM.
FO-328435	10/22/2015	10/22/2015		Generator Test, Thursday 10/22/2015 @ 1PM.
FO-328437	10/22/2015	10/22/2015		Generator Test, Thursday 10/22/2015 @ 1PM.
FO-328406	10/23/2015	10/27/2015		Generator Test, Tuesday 10,27/2015 @ 7:15 AM.
FO-328408	10/27/2015	10/27/2015		Generator Test
FO-328410	10/27/2015	10/27/2015		Generator Test, Tuesday 10/27/2015 @ 10AM.
FO-328412	10/27/2015	10/27/2015		Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328414	10/27/2015	10/27/2015		Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328416	10/27/2015	10/27/2015		Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328418	10/27/2015	10/27/2015		Generator Test, Tuesday 10/27/2015 @ 8AM.
FO-328405	10/28/2015	10/28/2015		Generator Test
FO-328420	10/28/2015	10/28/2015		Generator Test, Wednesday 10/28/2015 @ 7:15 AM.
T - Plumber			5	
FO-326459	10/1/2015	10/9/2015		PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/10-1-15 ,,,,,,,,,
FO-326460	10/1/2015	10/1/2015		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-326461	10/1/2015	10/2/2015		**CANCELLED JWT PM - Waterless Urinals ,,,,,,,,,, MM/10-1-15 ,,,,,,,,,
FO-326462	10/1/2015	10/2/2015		*CANCELLED JWT PM - Waterless Urinals ,,,,,,,,,, MM/10-1-15 ,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-326463	10/1/2015	10/2/2015		CANCELLED JWT
				PM - Waterless Urinals ,,,,,,,,,,,,,, MM/10-1-15 ,,,,,,,,,,,,,,

Total: 2826