

Facilities Operations Work Orders Received 8/1/15 through 8/31/15

WO	Recieved	Finished	Total	Request
Maint. Work Order			1798	
Custodial			257	
High			3	
C-Sector 04			1	
FO-325635	8/28/2015	8/29/2015		NEED CLEAN UP 3RD FLOOR LADIES RESTROOM 1ST STALL.
Pest Controller			2	
FO-323486	8/3/2015	8/11/2015	8/11/2015	EXTERMINATION FOR BUGS. ROOM 235. (CEILING LIGHT GLOBE)
FO-324010	8/10/2015	8/10/2015	8/10/2015	PRESIDENTS HOUSE BUG BOX NEEDS CHANGING PLEASE CONTACT HENRIETTA FOR MORE DETAILS 7-4882
Medium			10	
C-Sector 08			1	
FO-325068	8/20/2015	8/30/2015		Carpet needs cleaning in Grounds Supervisors office room 111. Contact Carla Crawford with any questions. 577-4323
Pest Controller			9	
FO-323673	8/4/2015	8/26/2015	8/26/2015	RM 12002.3 & 1212.63 NEED TRAPS SET FOR MICE
FO-324395	8/14/2015	8/18/2015	8/18/2015	MENS RM 1ST FL BED BUGS CAPTURED PLEASE COME ASAP
FO-324498	8/17/2015			can you come spray/set traps mouse and droppings were found in office.
FO-324743	8/18/2015	8/27/2015	8/27/2015	RM 3309,3312, 3317 PLEASE SPRAY FOR BEE'S, DEAD BEE'S FOUND ON WINDOW SEALS
FO-324756	8/18/2015	8/27/2015	8/27/2015	RM 2315, 2321 PLEASE SPRAY FOR BEE'S
FO-325333	8/25/2015	8/26/2015	8/26/2015	PLEASE BRING GLUE TRAPS
FO-325478	8/26/2015			RM 2317 SET MICE TRAPS
FO-325534	8/27/2015			9TH FL STAFF DEAD MOUSE ON TRAP IN LOUNGE AND MOUSE SITED IN RESTROOM
FO-325539	8/27/2015	8/28/2015	8/28/2015	Suite 1600 - there are lots of gnats flying around. They would like about 10 hanging pest strips placed in the offices and reception area.
Low			244	
C-Director			2	
FO-325042	8/20/2015			20 packing boxes
FO-325043	8/20/2015			3 rolls of packing tape.
C-Lighting			82	
FO-323462	8/3/2015	8/4/2015		Overhead lights are out. Please replace. Also check electrical switch seems to be malfunctioning. Also check electrical switch seems to be malfunctioning.
FO-323573	8/4/2015	8/10/2015		The light directly in front off, right before you go into office 231 is blown out.
FO-323575	8/4/2015	8/10/2015		3 lights in the Main corridor of office 232 are blown out.
FO-323691	8/4/2015	8/5/2015		Room 113 - 5 LO
FO-323692	8/4/2015	8/5/2015		Room 115 - 2 LO
FO-323722	8/5/2015	8/28/2015		Lighting-Scott Hall cafeteria serving area. Four compact fluorescent lights are out in the ceiling.
FO-323730	8/5/2015	8/5/2015		Room 117 - 6 LO.
FO-323740	8/5/2015	8/10/2015		Women's Restroom "220.01" has a light out as soon as you walk in.
FO-323761	8/5/2015			Dr. Lai's basement lab #315 has 2 light bulb fixtures that are burnt out. Thank you. (2) cases of T 12 bulbs will be pulled from Stock room.
FO-323779	8/5/2015	8/6/2015		4th floor Ladies restroom, ceiling light keeps going out, may have a short somewhere.
FO-323788	8/5/2015	8/12/2015		Relam light fixtures with burned out tubes.
FO-323806	8/6/2015	8/6/2015		3rd floor, next to cubicle #341.30, ceiling light is consistently beeping every 3 seconds.
FO-323823	8/6/2015	8/10/2015		5th floor, room 5018 - all lights are out.
FO-323838	8/6/2015	8/11/2015		Lamp in stairwell "B" landing to the second floor is out.

WO	Recieved	Finished	Total	Request
FO-323840	8/6/2015	8/11/2015		2nd floor, room 216 - 2 LO
FO-323859	8/6/2015	8/7/2015		Room 160 - 1 LO
FO-323860	8/6/2015	8/7/2015		Room 118 - 12 LO
FO-323953	8/7/2015	8/10/2015		Please replace all light bulbs in trophy case. Bob Ostrowski has specifics. Thank You. Bob Ostrowski 8/7/15 lps: Spoke w/Geneva she'll let me know if to process req or not. She called back and gave the go ahead to process req
FO-323985	8/10/2015	8/10/2015		**8/11/15 1 EP - middle fixture 1/2 out** Public Safety -Dispatch Room 133 - Ceiling light fixture located towards the break room needs light bulb replacement - access point requires tall ladder / scaffolding.
FO-324020	8/10/2015	8/13/2015		Lights out on First (11) and Third Floor (25) of UGL, total of 36 to be replaced.
FO-324046	8/10/2015	8/12/2015		Replace light bulb in ceiling fixture.
FO-324096	8/11/2015	8/12/2015		Light Changers please replace burned out bulbs in 4th floor men's restroom
FO-324097	8/11/2015	8/12/2015		Light Changers please replace burned out bulbs in basement men's restroom
FO-324132	8/11/2015	8/12/2015		rm. 9277 & 9278 lights out.
FO-324130	8/11/2015	8/13/2015		football pressbox changing all lights that are burnt - out. This needs to be accomplished before the 1st scrimmage on Saturday, August 22nd. Please contact Bob Ostrowski on details/questions. Thank You. Bob Ostrowski
FO-324169	8/12/2015	8/17/2015		Relamp Lighjt Fixture in Men's Shower Area.
FO-324178	8/12/2015	8/12/2015		Mens bathroom has light out between first and second door upon entering
FO-324187	8/12/2015	8/12/2015		2 LO - President's Place
FO-324201	8/12/2015	8/12/2015		Light changers, please replace bulbs in hallway in front of room 58
FO-324199	8/12/2015	8/12/2015		Light changers, please replace multiple bulbs in hallway on 1st floor
FO-324202	8/12/2015	8/12/2015		Light changers, please replace multiple bulbs in hallway on 2nd floor
FO-324203	8/12/2015	8/12/2015		Light changers, please replace multiple bulbs in hallway on 3rd floor
FO-324204	8/12/2015	8/12/2015		Light changers, please replace multiple bulbs in hallway on 4th floor
FO-324223	8/12/2015	8/13/2015		Room - 123 - 10 LO
FO-324316	8/13/2015	8/13/2015		Light outside of office room 325.1, 3rd floor north needs bulb replaced.
FO-324377	8/14/2015			Re-lamp 4 light fixtures in room 150. They are beeping indicating they need new bulbs.
FO-324413	8/14/2015	8/28/2015		Room 103 - Fluorescent light attached to desk is out.
FO-324452	8/17/2015	8/18/2015		Trade: Lighting Crew Priority: Low Lab 2524 has many florescent lights that are not working, please replace with new bulbs as needed. This lab is in the EDC part of the building. (4) cases of T-8 bulbs will need to be pulled from stockroom to complete t
FO-324464	8/17/2015	8/18/2015		Stairwell C 4th fl 1 out 5th floor stairwell 1 out D 2nd floor 1 out rm 25 1 out NE Foyer round can lite out
FO-324759	8/18/2015	8/18/2015		In Rm. 1616 there are 2 bulbs out that need to be replaced.
FO-324758	8/18/2015	8/18/2015		Rm. 1620 3 bulbs are out and need replacing.
FO-324769	8/18/2015	8/19/2015		Third floor stairwell. The lights are blinking and are very dim. They will be out soon.Please replace.Thank you.Dawn C.
FO-324784	8/18/2015	8/25/2015		Relamp Light fixe tha lights Art work in min Lobby opposite the froont doors.
FO-324823	8/19/2015	8/20/2015		Room 127 - 18 LO
FO-324825	8/19/2015	8/21/2015		Room 125 - 14 LO
FO-324831	8/19/2015	8/19/2015		Light bulb is out in the small hallway located directly outside of room 212. (note 212 is within suite 247 2nd floor south)
FO-324935	8/19/2015	8/19/2015		Dim lightbulbs need to be changed, specifically in copy room.

WO	Recieved	Finished	Total	Request
FO-324937	8/19/2015	8/20/2015		Room 25 - 9 LO 1 case of T-8 bulbs will be picked up from stock room.
FO-324942	8/19/2015	8/24/2015		Room 2701 - 3 LO
FO-324946	8/19/2015	8/25/2015		One light bulb burned out in the fixture closest to the door in this animal room. Thank you, Susan
FO-324959	8/19/2015	8/20/2015		Office 225 - 2 fluorescent bulbs out.
FO-324974	8/19/2015	8/20/2015		rm 5136 - 4 lights out rm 5123- 4 lights out
FO-324998	8/19/2015	8/25/2015		Light is out inside suite 206. In front of Exam room #12
FO-325023	8/20/2015	8/20/2015		Light over small stall, Ladies Room 1134, is flickering again. Another person has reported that the room is darkened because of unstable light.
FO-325063	8/20/2015	8/14/2015		Room 128 - 12 LO
FO-325065	8/20/2015	8/21/2015		Room 129 - 12 LO
FO-325067	8/20/2015	8/21/2015		Room 131 - Entire room of lights are out.
FO-325069	8/20/2015	8/26/2015		LIGHT IS STROBBING. PLEASE REPLACE. ROOM 1272.
FO-325110	8/21/2015	8/21/2015		REPLACE BLOWN OUT LIGHTS. ROOM 422.
FO-325194	8/24/2015	8/25/2015		Football building lights out main hall - 4 players locker room - 3 room 130 - 1 reception area - 1 1 roll of adhesive tape for labeling 1 angle brush to clean lens. 1 case of T-8 bulbs will be needed for additional lights out....
FO-325195	8/24/2015	8/25/2015		Two tube lights out over desk of Tamiya Earley in UGL Dean's Office Suite, Room 1600.
FO-325215	8/24/2015	8/25/2015		Lights out in men's room: reported that 1/2 the lights are out. This is men's room nearest to freight elevator
FO-325216	8/24/2015	8/28/2015		Rm. 1352.1 (Cafe Area) 6 recessed can lights out
FO-325226	8/24/2015	8/25/2015		globe out 1133
FO-325227	8/24/2015	8/25/2015		3 Lights out in Suite 206, the Kado Clinical Skills Center
FO-325322	8/25/2015	8/26/2015		Light Changers, please change burned out bulbs in 2nd floor men's restroom. ROOM 210.
FO-325323	8/25/2015	8/26/2015		Room 135 - 10 LO
FO-325324	8/25/2015	8/26/2015		Room 137 - 4 LO
FO-325338	8/25/2015	8/26/2015		Mens room needs fluorescent lamps replaced.
FO-325340	8/25/2015	8/26/2015		Lamps in stairwell need to be replaced between 2nd and 3rd floor.
FO-325359	8/25/2015	8/26/2015		Room 1209 - Several lights burnt out. Please replace.
FO-325376	8/25/2015			Light bulbs on the "IN USE" sign outside of practice rooms need to be replaced on 4th floor in rooms: 4202; 4208; 4210; 4212; 4214; 4215; 4216; 4217; 4218; 4219; 4220; 4221; 4222; 4223; 4224; 4225; 4227; 4228; 4229; 4230; 4231; 4232; 4233. Light bulb
FO-325384	8/25/2015	8/27/2015		Kresge Library 1st Floor - Library Science Offices, Room 101 Dead cockroach in ceiling light over desk. Please remove. Thank you.
FO-325396	8/26/2015	8/26/2015		LIGHT OUT IN BASEMENT CORRIDOR ACROSS FROM MEN'S RESTROOM. PLEASE REPLACE.
FO-325410	8/26/2015	8/26/2015		R/R RM 4200 ENTRY WAY NEED LITE REPLACEMENT
FO-325417	8/26/2015	8/26/2015		Burned out bulbs: 385 equipment area - one burned out bulb
FO-325420	8/26/2015	8/27/2015		Burned out bulbs: 385 equipment area, 1 bulb 385 DW work area, 1 bulb 308, 1 out & one flickering/dim bulb 358, 1 out & one flickering/dim bulb
FO-325454	8/26/2015	8/27/2015		rm 179 2 lites out get key from 487

WO	Recieved	Finished	Total	Request
FO-325483	8/26/2015			There are also two lights out in this office.thanksMichelle
FO-325486	8/26/2015			Multiple light fixtures are out in chemistry teaching labs - 1- Room 10402- Room 10392- Room 10271- Room 10281- Room 20271- Room 2039
FO-325518	8/27/2015	8/27/2015		Lighting crew: please replace burned out lights on 4th floor hallway in front of room 419. Priority: med.
FO-325638	8/28/2015			Re-lamp fixtures in room 197. Note: Will need someone to give technician to the room.
C-Materials			11	
FO-323534	8/4/2015	8/5/2015		EQUIPMENT TRANSFER: FROM (FAB) FIRST FLOOR STAIRWAY AREA. AUTO SCRUBBER (ADVANCE/ADFINTY)FOR SERVICE REPAIRS PART OF (FO321536).
FO-323535	8/4/2015	8/4/2015		EQUIPMENT TRANSFER: AUTO, SCRUBBER (ADVANCE/ADPHIBIAN) From: (UGL) 3rd. FLOOR STOCKROOM CLOSET To: MAIN OFFICE STOCKROOM / FOR SERVICE REPAIRS PART OF (FO321246)
FO-323605	8/4/2015	8/5/2015		Room 458 - Gray recycling bin pick up and drop off.
FO-323852	8/6/2015	8/7/2015		Stock Issue: 1 back brace
FO-324135	8/11/2015			Room - 2155 - Pick up and replace recycling bin.
FO-324782	8/18/2015	8/20/2015		2 gray recycling bins to be delivered.
FO-324783	8/18/2015	8/20/2015		Room 1150 - Large recycling bin needs to be removed and replaced.
FO-324826	8/19/2015	8/28/2015		4HWCRC - pick up and return recycling bin.
FO-325096	8/21/2015			EQUIPMENT TRANSFER: NEW STAND UP (SCRUBBER and CARPET) MACHINE. From: (FPM/STOCKROOM) To: (CUSTOD. STOCKROOM) After/To: (I Bio.)
FO-325183	8/21/2015			Blue, Green & Jaffer Auditoriums located off the 2nd floor: Request for replacement of batteries & hand sanitizer.
FO-325373	8/25/2015	8/27/2015		Room 3100; Recycling bin drop off and pick up.
C-Repair			39	
FO-323485	8/3/2015	8/4/2015		2nd floor women restroom paper towel dispenser off the wall needs new 1.Also 4th floor Men restroom soap dispenser off wall needs new 1.
FO-323550	8/4/2015	8/4/2015		Broken Soap dispenser on the 4th. floor Men's Restroom.
FO-323696	8/5/2015	8/5/2015		Paper towel dispenser in Men's 1st floor bathroom is broken.
FO-323697	8/5/2015	8/5/2015		Men's restroom 1st floor the paper towel dispenser is broke needs new 1
FO-323698	8/5/2015	8/6/2015		Men's restroom 2nd floor paper towel off the wall needs a new 1.
FO-323793	8/6/2015	8/6/2015		Men restroom the paper towel dispenser off the wall needs new 1.
FO-323794	8/6/2015	8/11/2015		NEW EQUIPMENT: A REQUEST FOR A NEW VACUUM, CLEANER FOR (HECKLER, MANSION) LABEL AND MAGNET BAR INSTALL. FROM CUSTOD., MAIN OFFICE STOCKROOM Approved/Authorized By: (Geneva, Guice)
FO-323805	8/6/2015	8/6/2015		NEED TO PLACE A PARTS AND SUPPLIES ORDER FOR SERVICE REPAIRS IN (CUSTOD./STOCKROOM) ON VACUUMS CLEANER. From: (Allied-Eagle Supply Co./po693931) Approved/Authorized By: (Geneva, Guice)
FO-323835	8/6/2015	8/14/2015		Please repair paper towel dispenser in ladies rest room 7th floor Scott Hall
FO-323967	8/8/2015	8/11/2015		Storage rm. 158: Sanitaire Upright Vacuum Cleaner; Model #SC887; Ser. No. #1429008743: Vacuum will not start up (possibly a short in the switch). I will pick back up from main office stockroom area once it is fixed. Thanks CBJohns
FO-323968	8/8/2015	8/17/2015		Women 2nd floor Restroom #272: Request for three (3) Sanitary Napkin Boxes as the remaining five (5) other stalls have sanitary boxes present. Thanks CBJohns
FO-324088	8/11/2015	8/12/2015		The belt cannot be changed on the Sanitair vacuum in the fitness center because the clamp on the bottom of the vacuum has seized up and cannot be removed.
FO-324089	8/11/2015	8/12/2015		The soap dispenser in the basement men's room of the prentis building is broken.
FO-324159	8/12/2015	8/12/2015		NEW EQUIPMENT: A REQUEST FOR A VACUUM, CLEANER FOR (AAB), BUILDING 4th. FLOOR AREA. Approved/Authorized By: (Geneva, Guice)

WO	Recieved	Finished	Total	Request
FO-324284	8/13/2015	8/13/2015		The carpet machine handle have a leak.
FO-324294	8/13/2015	8/14/2015		Please repair soap dispenser in ladies restroom on 9th floor Scott Hall
FO-324411	8/14/2015	8/18/2015		please rehang toilet paper dispenser in men's restroom, its sitting on floor.
FO-324416	8/15/2015	8/17/2015		NEW EQUIPMENT: (ADVANCE/STAND-UP SCRUBBER) NEED TO BE LABEL/TAG FOR THE NEW BUILDING (I Bio). Approved/Authorized By: (G. Guice)
FO-324417	8/15/2015	8/15/2015		NEW EQUIPMENT:NEED TO BE LABEL/TAG FOR NEW BUILDING (I Bio). WINDSOR/CHARIOT 2 iVac 24 ATV STAND-UP CARPET MACHINE Approved/Authorized By: (G. Guice)
FO-324418	8/15/2015	8/15/2015		NEW EQUIPMENT:NEED TO BE LABEL FOR (GROUNDS/DEPT.) (John Deere/Gator) 625i SER.#-1M0625GSLM101784 Approved/Authorized By: (Geneva Guice)
FO-324706	8/18/2015	8/19/2015		Convertamatic Auto Scrubber; Model X26D-C; Ser. no. 1955712 (Location is in basement nearest the single dock area door): Panel display/lights are misconstrued as nothing seems to be working on the display mechanisms such as brushes going up or down; no va
FO-324755	8/18/2015	8/18/2015		R/R RM 113/WOMENS RR (VENDING MACHINE HALLWAY SIDE) PAPER TOWEL DISPENSER LEVER IS BROKEN
FO-324798	8/19/2015	8/21/2015		The control panel on the autoscrubber is broken. I was told that when using the machine the spring that controls the forward and backward motion of the control panel is broken.
FO-324827	8/19/2015	8/31/2015		please replace sanitary box in ladies restroom
FO-325001	8/19/2015			Nilfisk Advance; Model: Adphibian AXP; Ser. no. 1000000479: I came upon the condition of the squeegee (separated into various pieces) & it's missing the two small balancing wheels located on each end of the squeegee. Can you fix the squeegee for me? I dr
FO-325008	8/20/2015	8/21/2015		The vacuum is located in room 055 next to the old custodial office (room 057). Two of the prongs are broken off and needs to be replaced.
FO-325097	8/21/2015	8/21/2015		NEED A VACUUM, CLEANER (SANITAIRE/BRUSH, ROLLER) TO REPLACE THE MISSING ROLLER.
FO-325101	8/21/2015			NEED SOME SERVICE REPAIRS ON THE AUTO, SCRUBBER / ADPHIBIAN (SQUEEGEE, ASSEMBLY) MACHINE IS PLACE IN THE BASEMENT STAIRWAY.
FO-325104	8/21/2015			Need some service repairs on the auto, scrubber (Conv. X26D-C) machine control panel (Fault Indicator) light is on.
FO-325106	8/21/2015	8/21/2015		NEW BATTERIES (GEL), INSTALLATION IN THE AUTO, SCRUBBER (ADVANCE/CONVERTAMATIC X26DC) THIS MACHINE LOUCATION IS THE (OLD, WING) AREA OF BUILDING.
FO-325138	8/21/2015			NEED TO ORDER SOME AUTO, SCRUBBER SERVICE REPAIR PARTS FOR CUSTOD. STOCKROOM WORK REQUESTS. From: (Allied-Eagle Supply Co.) Approved/Authorized By: (Geneva Guice)
FO-325166	8/21/2015			Need to place a parts order for (FO320733) (AdVance/AllCleaner) machine. From: (Allied-Eagle Supply Co.) Approved/Authorized By: (Geneva Guice)
FO-325176	8/21/2015	8/21/2015		EQUIPMENT TRANSFER: TWO AUTO SCRUBBER (ADVANCE/CONV. X26DC), BACK IN BUILDINGS (ENGINEERING & FITNESS, CENTER)
FO-325182	8/21/2015	8/26/2015		Women Restroom #2377 (Last stall): Request for a new Sanitary holder box as the current one is broken. Thanks cbj
FO-325531	8/27/2015			1 Caulk Gun Silicone
FO-325550	8/27/2015			HAND SANITIZER NOT WORKING ON 1ST FLOOR, REPLACED BATTERIES BUT STILL NOT WORKING PROPERLY. PLEASE REPAIR.
FO-325625	8/28/2015	8/31/2015		MEN'S RESTROOM 3124 PAPER TOWEL DISPENSER BROKEN. PLEASE REPAIR.
FO-325627	8/28/2015	8/31/2015		MEN'S RESTROOM 0348 SOAP DISPENSER BROKEN. PLEASE REPAIR OR REPLACE.
FO-325628	8/28/2015	8/31/2015		WOMEN'S RESTROOM 1130 SOAP DISPENSER BROKEN. PLEASE REPAIR/REPLACE.
C-Sector 01			15	
FO-323612	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.
FO-323613	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.
FO-323614	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.

WO	Recieved	Finished	Total	Request
FO-323615	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.
FO-323617	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.
FO-323618	8/4/2015	8/7/2015		2 cases of dial soap. Task is complete.
FO-323620	8/4/2015	8/7/2015		1 case of dial soap. Task is complete.
FO-323621	8/4/2015	8/7/2015		1 case of dial soap. Task is complete.
FO-323622	8/4/2015	8/7/2015		2 cases of dial soap Task is complete.
FO-323624	8/4/2015	8/7/2015		4 cases of gojo. Task is complete.
FO-324267	8/12/2015			Several of the teaching labs and lecture halls need to be "deep" cleaned before the fall semester. Teaching labs :10021027102810391040 need strip and waxingI did not look at the lecture halls but now would be a good time for carpet and regular cl
FO-325247	8/24/2015			Wax and polish floors in the entire building.
FO-325248	8/24/2015			Requesting to have all bathrooms in building scrubbed and waxed.
FO-325597	8/28/2015			The women's restroom on first floor has needed service for the last several weeks Trash is overflowing.
FO-325598	8/28/2015			The stair carpet still needs to be cleaned. this is the third request for this work. previous requests 263409 & 268781. We will look to schedule this project asap.
C-Sector 02			20	
FO-323831	8/6/2015	8/5/2015		Please scrub and wax labs 7222,7130,7132 in Scott Hall
FO-323832	8/6/2015	8/6/2015		Please scrub and wax sewing room and costume room on 1st floor of 95 W. Hancock
FO-323833	8/6/2015	8/6/2015		Please clean all counter tops and scrub and wax the floors in room 004 in Mott Center
FO-323931	8/7/2015	8/7/2015		Please shampoo Deans 1st floor conference room 1130. Also the Deans Asst. Sue Christie suite 2623.
FO-324456	8/17/2015			Dean's Office/Administrative Offices Suite on 2nd floor to be shampooed. This includes 2600 conference room, hallway & all offices within the suite.
FO-324467	8/17/2015			2nd floor - Clean and wax hall floors.
FO-324471	8/17/2015			Pharm Sci. Suite 3610 and all offices within the suite we are requesting to have carpet shampooed.
FO-324473	8/17/2015			3rd floor - clean and wax hall floors
FO-324477	8/17/2015			LRC 0350's attached study rooms need carpet cleaned.
FO-324481	8/17/2015			Clean and wax hall floors on the research side.
FO-324750	8/18/2015			Suite 2590 and offices within the suite need carpet shampooed.
FO-324964	8/19/2015	8/25/2015		6 cases - dial soap.
FO-324965	8/19/2015	8/25/2015		4 cases - dial soap
FO-324966	8/19/2015	8/25/2015		4 cases - dial soap
FO-324967	8/19/2015	8/25/2015		4 cases - dial soap
FO-324968	8/19/2015	8/25/2015		60 & 95 W. Hancock - 4 cases - dial soap
FO-324991	8/19/2015	8/24/2015		Classroom 1341 - Please clean floor and tables. Orientation to be held Monday, 8/23 & Tuesday, 8/24.
FO-325136	8/21/2015	8/21/2015		Please scrub and wax 9245 of Scott Hall
FO-325481	8/26/2015			Rm. 1233 - The faculty that use the room would liked the floor cleaned and waxed before school starts. If not possible to have it cleaned and waxed before school starts, then they are asking for it to be at least mopped.
FO-325634	8/28/2015			Suite 313, has a big stain on the carpet and chair right next to the main receptionist. Can we please someone to clean the carper and chair.
C-Sector 03			2	
FO-324963	8/19/2015			Would like to request that the carpet in room 2262 FAB be cleaned. The following are dates that the office will not be in use this week and next week: 8/20, 8/21, 8/27, 8/28.
FO-325540	8/27/2015			Please check out the carpet- the classroom smells of mildew- will carpet cleaning work or does it need removal. If the carpet is viable please clean it.Thanks
C-Sector 04			4	
FO-323789	8/5/2015	8/6/2015		Cleaning of carpeted hallway at University daycare. Requested by Mrs. Frierson.

WO	Recieved	Finished	Total	Request
FO-325213	8/24/2015	8/27/2015		Spot clean large stains out of carpet in rooms 1328 and 1367.
FO-325489	8/26/2015	8/27/2015		Spot clean carpet in room 2365 Old Main.
FO-325574	8/27/2015	9/1/2015		Spot clean carpet in the computer lab on the 2nd floor of Old Main near student lounge. Alarmed area. Come to main office between 8:30am - 5:00pm room 1321 to gain access.
C-Sector 05			6	
FO-324039	8/10/2015	8/13/2015		I am requesting carpet cleaning in Room 345 Manoogian Hall before the beginning of the Fall 2015 semester start date. project_name: Carpet Cleaning in Room 345 Manoogian Hall contact: D. Hendricks contact_email: ab5825@waynel.edu contact_ph: (313) 577
FO-324150	8/12/2015	8/12/2015		We deep clean entrance carpet remove all winter salt.
FO-324460	8/17/2015	8/18/2015		Floor in room needs striping and waxing.
FO-324461	8/17/2015	8/18/2015		Floors need stripping and waxing.
FO-324753	8/18/2015	8/23/2015		Carpet Cleaning in Main Office and attached offices in suite; Room 137, 139, 141, 143, if possible. Carpet has not been cleaned since being installed 5 years ago.
FO-325280	8/24/2015			Request to have office carpet shampooed. It's been several years.
C-Sector 06			9	
FO-323802	8/5/2015	8/17/2015		basement hallway floor outside of rooms 41 & 43 - please clean rust stains from floor. thank you
FO-323803	8/5/2015	8/18/2015		basement hallway floor - clean wax build-up btween doors marked 30-31 & 40-49. thank you
FO-323842	8/6/2015	8/7/2015		There are about 10 boxes of trash can liners in the Judges Chamber Room 1119 that we need removed before 9/1/15 due to an event we have scheduled.
FO-323923	8/7/2015	8/31/2015		please vac and clean all carpet in rooms 112, 114, 114.6, 116, 179, hours of 7am-5pm, rooms are alarmed. Preferably btwn 8/25 & 9/1, (before classes begin). Please contact Mr. Kevin Carroll at 7-9935 to set this up. thank you
FO-324230	8/12/2015	8/18/2015		please have someone clean and dust Anna Millers new office (room 235.) thank you
FO-324360	8/13/2015			Request to have floors stripped, waxed in the IT area. Rooms are: server room 215, 212, hallway in the IT area including the back rooms 208-210. We would like this to be completed sometime in the next 2 weeks. Thank you.
FO-325005	8/20/2015	8/20/2015		Please scrub and wax all the corridors.
FO-325007	8/20/2015			Please scrub and wax all the corridors.
FO-325425	8/26/2015			Could we please get the carpet cleaned before 9/2/15? It is a large room. Also, there is a hole in the wall that needs to be patched up. What is the process for that?
C-Sector 07			15	
FO-323595	8/4/2015	8/5/2015		4 cases of dial soap.
FO-323597	8/4/2015	8/5/2015		2 cases of dial soap.
FO-323598	8/4/2015	8/5/2015		3 cases of dial soap.
FO-323599	8/4/2015	8/5/2015		*PURDY AND KRESGE* 3 cases of dial soap.
FO-323600	8/4/2015	8/5/2015		1 case of dial soap.
FO-323601	8/4/2015	8/5/2015		1 case of dial soap.
FO-323602	8/4/2015	8/5/2015		1 case of dial soap.
FO-323808	8/6/2015	8/28/2015		Purdy Library 1st Floor Room 138 Vacuum and carpet cleaning requested. Area is getting rather nasty. Thank you.

WO	Recieved	Finished	Total	Request
FO-324486	8/17/2015			Please shampoo carpet in the following offices: 6409.1 (this office belongs to the Vice President for Research), office 6407 (this is the VP's administrative assistant's office - the two offices are connected) and 6202 (Conference Room A) Please
FO-324489	8/17/2015	8/28/2015		I am the Manager of the Midtown TV Studio on the first floor of 5057 Woodward and we need to have the studio floor mopped and buffed before the beginning of classes. The best days for us would be either Monday, 8/24 or Tuesday, 8/25/15. We will move the
FO-324757	8/18/2015			R/R RM 4101 Clean CARPET/FLR @ 2 work stations of former employees 8/18/15 lps: Spoke w/Mark says the areas are cubicles would like entire desks & flrs cleaned. Also, spoke w/Geneva G she says their dept doesn't clean cubicles. I spoke w/Mark to let
FO-325071	8/20/2015			Shampoo practice room carpets from room 4202 through 4233. Please include hallways. Pianos do not have to be removed, please clean around pianos.
FO-325143	8/21/2015			Purdy Library R/R 3rd Floor - east end Request wash and wax of east end 3rd floor - several areas look rather bad due to recently removed shelves. Thank you.
FO-325415	8/26/2015	8/28/2015		Spot clean carpet in room 2383.
FO-325525	8/27/2015	8/28/2015		2 boxes of batteries - D Cell
C-Sector 08			2	
FO-324131	8/11/2015	8/22/2015		Clean football pressbox including windows inside and outside This needs to be accomplished before the 1st scrimmage on Saturday, August 22nd. Please contact Bob Ostrowski on details/questions. Thank You. Bob Ostrowski 8/11/15 lps: Spoke w/Geneva c
FO-325059	8/20/2015			Clean carpet in the cubicle area, entrance ramp, and open table areas of room 150/160.
C-Sector 09			5	
FO-324189	8/12/2015	8/12/2015		2 cases of dial soap.
FO-324191	8/12/2015	8/12/2015		2 cases of dial soap.
FO-324192	8/12/2015	8/12/2015		2 cases of dial soap.
FO-324196	8/12/2015	8/12/2015		2 cases of dial soap.
FO-324197	8/12/2015	8/12/2015		2 cases of dial soap.
C-Sector 10			2	
FO-324370	8/14/2015			Back brace - large
FO-324389	8/14/2015			20 boxes and 3 rolls of tape.
Pest Controller			30	
FO-323685	8/4/2015	8/10/2015	8/10/2015	EXTERMINATION FOR MICE. ROOM 3094.
FO-323994	8/10/2015	8/11/2015	8/11/2015	PEST CONTROL-PLEASE REPLACE PEST TRAPS IN MECH RMS 1 AND 5,PRIORITY MED
FO-324038	8/10/2015	8/13/2015	8/13/2015	R/R RM 241 NEED PEST CONTROL FOR EXTERMINATE FOR ROACHES
FO-324071	8/10/2015	8/14/2015	8/14/2015	R/R 10TH FLR UNISEX RR NEAR ELEVS' HAS A LARGE ROACH NEED EXTERMINATOR TO SPRAY & PUT DOWN TRAPS
FO-324093	8/11/2015	8/11/2015	8/11/2015	Office 1162 has a cockroach in it. They need to spray the office immediately. Thank you.
FO-324158	8/12/2015	8/16/2015	8/16/2015	Sited bed bugs in Grounds area. Treat all chairs and tables.
FO-324260	8/12/2015	8/13/2015	8/13/2015	Stock request: 5 cases of bee traps and 12 pro zaps
FO-324352	8/13/2015	8/14/2015		as was already reported (FO-323583), room 2315 (computer Lab B) has bees entering from an unknown location. The first request was marked as finished, but the bees continue to enter the room, rendering it unusable.
FO-324393	8/14/2015	8/21/2015	8/21/2015	EXTERMINATION FOR MICE. ROOM 5018.
FO-324493	8/17/2015	8/19/2015		EXTERMINATION FOR BED BUGS. 1ST FLOOR.

WO	Recieved	Finished	Total	Request
FO-324729	8/18/2015	8/21/2015	8/21/2015	Mouse droppings underneath kitchen sink, room #13100.3 in break room. Reported hearing mouse on 7/10/15, but, no one came! Thank you.
FO-324775	8/18/2015	8/21/2015	8/21/2015	R/R RM 2317 PLS EXTERMINATE SPRAY LAY STICKY TRAPS FOR ROACH PROBLEM
FO-324936	8/19/2015	8/27/2015	8/27/2015	EXTERMINATION FOR BEES. 1ST FLOOR ROOM 1676.
FO-324961	8/19/2015	8/24/2015	8/24/2015	Treat Matthei Grounds shed for bed bugs
FO-325093	8/20/2015	8/24/2015		rm 3638 need pest control identify a bug make sure not bed bug also for exterminating said bug
FO-325219	8/24/2015	8/25/2015	8/25/2015	Infestation of flies (alive and dead) on window in mail sorting device room.
FO-325221	8/24/2015	8/30/2015	8/30/2015	Our building is being overrun by crickets. We need an exterminator ASAP. The crickets are on the 1st and 4th floor.
FO-325276	8/24/2015			Would like to request 2 bee repellants to be used on 9/1/15 during our sno-cone event for Festifall
FO-325316	8/25/2015	8/26/2015	8/26/2015	BED BUGS IN CAR. CONTACT GARY AT PUBLIC SAFETY.
FO-325317	8/25/2015	8/25/2015	8/25/2015	EXTERMINATION FOR MICE. ROOM 25.
FO-325371	8/25/2015	8/26/2015	8/26/2015	PLEASE REMOVE DEAD MOUSE ON TRAP. ROOM 4100.
FO-325411	8/26/2015	8/26/2015	8/26/2015	EXTERMINATION FOR MICE. ROOMS 6407 AND 6409.1.
FO-325480	8/26/2015			can we have pest control (Mouse/mice) come and plug a hole outside of the Law School building. Admissions is having Orientation and while sitting outside they saw 2 mice run in a hole. I can show you better than I can describe where the hole is
FO-325494	8/27/2015			EXTERMINATION FOR ROACHES. MECHANICAL ROOM 32.
FO-325519	8/27/2015			Pest control: Please apply pest control for roaches in mechanical room 024. please see engineer for specific areas. Priority: med.
FO-325553	8/27/2015			WASPS AT TOP OF FRONT ENTRANCE DOOR. (OUTSIDE)
FO-325571	8/27/2015			EXTERMINATION FOR MICE. ROOM 6203.6. CONTACT DORIS DAVIS.
FO-325596	8/28/2015			EXTERMINATION FOR MICE. SUITE 2317.
FO-325604	8/28/2015			EXTERMINATION FOR MICE. ROOM 207.
FO-325612	8/28/2015			We are requesting that the entire building be treated on a weekend (date TBD) for Rodents, Roaches and other unknown pest. We have mice recently in the business service area in employees drawers and live droppings. Thanks, Bobby

Engineering

629

Emergency

20

E - Auxiliary

3

FO-323843	8/6/2015	8/6/2015		3RD FL FIRE ALARM
FO-323936	8/7/2015	8/7/2015		CAFE HAS A STRONG GAS SMELL
H-53682	8/12/2015			Toilet in constantly flushing and running. Has been running non stop since early July. authenticated user: Amari McGee - ev1977requester ip address: 141.217.23.187

E - Command Center

3

FO-323744	8/5/2015	8/5/2015		Boiler 1 is intermittently shutting off. Please troubleshoot and repair.
FO-324215	8/12/2015	8/13/2015		EMERGENCY CONTROLS R/R RM 495/NEW BLR RM BOILER #1 KEEPS TRIPPING OUT ON FLAME FAILURE
FO-324236	8/12/2015	8/13/2015		AIR LEAK. ROOM 4300. CONTACT ENGINEER FOR DETAILS.

E - MedPharm

4

FO-324951	8/19/2015	8/19/2015		HIGH TEMP. SHOULD BE 61. ROOM 423.
FO-325466	8/26/2015	8/27/2015		RM 5344 A MAJOR CLNG LEAK CAUSING CLNG TILES TO FALL WTR POURING IN
FO-325590	8/28/2015	8/31/2015		STRONG KEROSENE SMELL. ROOM 154.
FO-325591	8/28/2015	8/31/2015		STRONG KEROSENE/GAS SMELL. 4TH FLOOR.

E - North

4

WO	Recieved	Finished	Total	Request
FO-323717	8/5/2015	8/19/2015		RESET FIRE ALARM PANEL. (MULTI-TASK) Completed 8-19-2015 SRP
FO-323918	8/7/2015	8/7/2015		POWER BUMP BLDG APPR 9AM CHECK EQUIP
FO-323919	8/7/2015	8/7/2015		POWER BUMP AT LIFE SCI/ SCI HALL BLDG APPR 9AM CHECK EQUIP
FO-324014	8/10/2015	8/10/2015		CALLED SCHINDLER ELEV CO FOR NORTH ELEV ENTRAPMENT 1ST FLR REF #49461958
E - Northeast			1	
FO-325103	8/21/2015	8/21/2015		CALLED KONE FOR ENTRAPMENT FREIGHT ELEV ? FLR REF #9588977
E - Preventative Maintenance			3	
FO-323496	8/3/2015	8/3/2015		ALL THE POWER WENT OUT IN BUILDING.
FO-324353	8/13/2015	8/15/2015		FAP FIRE ALARM ACTIVE
FO-324992	8/19/2015	8/21/2015		Overhead receiving exterior door is not functioning. It is stopped partially open creating an emergency security issue as the room contains expensive equipment and is open to the back parking area.
E - South			2	
FO-323910	8/7/2015	8/7/2015		POWER BUMP BLDG APPR 9AM
FO-324042	8/10/2015	8/10/2015		3RD FLR JANITORS' CLOSET LOCKED EVERTHING INSIDE CLOSET NEED ACCESS ASAP
High			313	
E - Auxiliary			37	
H-53540	8/3/2015			ceiling is leaking near gold n greens side entrance over the light.
FO-323458	8/3/2015	8/3/2015		FIRE TROUBLE ALARM AND FIRE ALARM SOUNDING
H-53592	8/6/2015			Toilet tank leaks when flushed.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53593	8/6/2015			Toilet will not flush. Handle has come off. authenticated user: Tamica Dothard - as5605requester ip address: 35.16.226.82
H-53603	8/6/2015			Maintenance Room-There is no electricity in dinning room and kitchen.Resident has already reported it twice from past two week,but no one has visited still. authenticated user: Akshay Kenjale - fp6257requester ip address: 141.217.23.216
H-53641	8/7/2015			Shower back drain has backed up. A black mass surrounds the drain. The resident says there's no smell but it came about this morning. August 7, 2015.Please fix as soon as possible. (resident's request)authenticated user: Marc Johnson - ek1297requester i
H-53653	8/8/2015			our washing dish is stuck because the cutting machine was not workingit may have been an electrical or waste disposal unit problem.authenticated user: Hassan Alkhwaildi - ft8883requester ip address: 35.16.79.203
H-53654	8/9/2015			There is a leaking in kitchen sink motor.authenticated user: Ashish Raosaheb Patil - fq5142requester ip address: 35.16.77.15
FO-324028	8/10/2015	8/11/2015		TOWERS KITCHEN, GARBAGE DISPOSAL NOT WORKING
FO-324031	8/10/2015	8/10/2015		2ND FL BALLROOM TOO HOT, EVENT IN PROGRESS
FO-324044	8/10/2015	8/11/2015		RM 109 ACU ISN'T WRKNG
FO-324069	8/10/2015	8/10/2015		RM 109 ACU ISN'T WRKNG
H-53681	8/11/2015			A/C out of order. Needs attn. ASAPauthenticated user: Christopher Ozog - fi3944requester ip address: 141.217.23.191
H-53672	8/12/2015			There is leakage in kitchen's sink motor/pump. authenticated user: Tushar Dudhediya - fr4040requester ip address: 35.16.77.22
FO-324220	8/12/2015	8/12/2015		FAP FIRE TROUBLE ALARM ACTIVE
H-53690	8/13/2015			Kitchen sink is leaking for about a week now. Would appreciate it to be fixed. authenticated user: Vivien Okechukwu - fh2758requester ip address: 141.217.23.210
H-53701	8/13/2015			Toilet tank is leakingauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
FO-324508	8/17/2015	8/18/2015		POSSIBLE POWER BUMP. PLEASE CHECK EQUIPMENT.
H-53779	8/18/2015			Garbage disposal is not working properlyauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
H-53783	8/18/2015			leaking shower tapauthenticated user: Wei Du - ff4793requester ip address: 141.217.173.188
H-53786	8/19/2015			Air conditioning is broken and will not produce cool air. Could you please take a look at it? authenticated user: Anthony Kurcz - ez7811 requester ip address: 70.210.67.20
FO-324943	8/19/2015	8/20/2015		FIRE TROUBLE ALARM
H-53910	8/20/2015			Toilet will not stop running and now it will not flushThank youauthenticated user: Kimberly Daniels - fx3290requester ip address: 35.16.64.27
H-53914	8/21/2015			The garbage disposal is brokenauthenticated user: Isabell Groves - fb2096requester ip address: 141.217.23.210
H-53915	8/21/2015			Their is water starting to flood out on the kitchen floor. Might be due to broken garbage disposal.authenticated user: Isabell Groves - fb2096requester ip address: 141.217.23.210
H-53916	8/21/2015			The water from the shower in this unit gets really hot only and never gets coldauthenticated user: Isabell Groves - fb2096requester ip address: 141.217.23.210
FO-325145	8/21/2015	8/24/2015		WDET STUDIO AREA IS TOO HOT
FO-325153	8/21/2015	8/24/2015		FIRE TROUBLE ALARM.
FO-325170	8/21/2015	8/24/2015		FAP FIRE TROUBLE ALARM ACTIVE
H-53908	8/24/2015			I recently put in a request because the front of the toilet was leaking. Someone came by when I was out of town and fixed that problem. However, now the back of the toilet is leaking (at least I think) because now there's water constantly on the floor beh
H-53938	8/25/2015			Shower/tub faucet cold water is not working. The water comes out too hot it is impossible to use.authenticated user: Debora Mendes Coelho - fx5531requester ip address: 35.16.79.77
H-53950	8/25/2015			kitchen sink doesn't not have a drain pipe authenticated user: Manaswini Remidi - fs2524requester ip address: 141.217.23.216
H-53973	8/26/2015			Issues reported by resident immediately after move-in...-bathtub faucet is leaking-ac fan making loud noise-exhaust fan above stove is not workingauthenticated user: Psocrates Stansberry - cl5547requester ip address: 141.217.23.210
H-53974	8/26/2015			Sink in the kitchen is leaking from underneath.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53975	8/27/2015			Garbage disposal is not working.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-54034	8/28/2015			Toilet has issue with flushing, wont flush without opening the back of toilet. authenticated user: Samantha Mannino - ez5465requester ip address: 141.217.233.108
H-54114	8/28/2015			"Toilet flushes, but instead of refilling the bowl water gushes out from the top of the tank after flushing. Problem started when I moved in Tuesday night. I have been catching the water with towels." Urgent!authenticated user: Psocrates Stansberry - cl
E - Command Center			15	
FO-323700	8/5/2015	8/18/2015		Trade: Controls Priority: high 090-AHU-541 EDC AHU #1 is tripping on virtual high static on start up.
FO-323709	8/5/2015	8/10/2015		Trade: Controls Priority: High R/R RM 4505/MECH RM EDC York Chiller #2 is still shutting down for no apparent reason, the display screen on the chiller says remote shut down which means the Siemens system is shutting it down. It did it 2 times yesterday
FO-323765	8/5/2015			Trade: Command Center Priority: High R/R RM 000000.62/MECH-BLR RM Please check and adjust burner for boiler #2 which was returned to service after open, clean and close. Flame is very yellow at low fire. Boiler was heavily sooted up when taken down
FO-324090	8/11/2015	8/13/2015		COMMAND CTR, R/R RM 495/NEW BLR RM AIR/FUEL LINKAGE ON # 1 BOILER NEEDS ADJUSTMENT. (ATTN: AUBREY) PRIORITY-HIGH
FO-324125	8/11/2015	8/13/2015		A/C Controls R/R RM 463/DLAR please adjust airflow in room 463. Airflow is positive and needs to be negative (See work order FO-324085). Priority: high
FO-324126	8/11/2015	8/12/2015		A/C Controls R/R RM 468/DLAR please adjust airflow in room 468. Airflow is positive and needs to be negative (See work order FO-324086). Priority: high

WO	Recieved	Finished	Total	Request
FO-324127	8/11/2015	8/13/2015		A/C Controls R/R RM 472/DLAR please adjust airflow in room 472. Airflow is negative and needs to be positive (See work order FO-324087). Priority: high
FO-324346	8/13/2015			**ADDING CONTROLS GROUP : Please check gas valve and igniter on domestic hot water heater. burner will not light.Please let Pipe Shop know outcome. Trade: Plumber Priority: High 090-DHW-003 EDC domestic water heater, gas fired, will not fire. Also
FO-324436	8/17/2015	8/18/2015		#1 BOILER LINKAGE BINDING ON KAM. BOILER ROOM.
FO-324453	8/17/2015	8/18/2015		Refrigeration Crew, High, Please charge Sanyo Mini Split condensing unit at South side of Roof. R-22, 240v. 4.5A, unit takes care of 2nd floor South conference room, J. Davis
FO-324485	8/17/2015	8/19/2015		ROOF TOP UNIT #4 KEEPS TRIPPING OUT. (The air conditioning is blowing hot air instead of cold). (Multi-Task)
FO-325228	8/24/2015			Control Engineer; High R/R RM 10302 Please check the refrigerant pressures in the heat pump 2-61-071-HWP-109. The unit is not cooling.
FO-325388	8/25/2015			COMMAND CTR, DECOUPLING VALVE ON THE CHILLED WATER SYSTEM IS SHORT CIRCUITING, CHILLED WATER IS NOT BEING CIRCULATED OUT TO THE BUILDING ON LOW LOAD DAYS, PLEASE CORRECT. PRIORITY-HIGH
FO-325547	8/27/2015			Control Engineer;HighPlease repair heat pump #2-11 that serves Suite 2218. The unit will not heat the space.PLease check reversing valve operation. The heat pump is shut off.
FO-325593	8/28/2015			Please have controls remove water separator from above main control fuse panel. the water leaks into the panel causing the fuses and contact damage in the panel. please relocate to a area away from the main control panel. High priority.
E - MedPharm			80	
FO-323481	8/3/2015	8/12/2015		WATER IS HOT. ROOM 521.
FO-323559	8/4/2015	8/4/2015		TOO COLD. ROOM 2602.1.
FO-323571	8/4/2015	8/4/2015		5TH FL COOLER NOT COLD, NEAR RM 5502
FO-323577	8/4/2015	8/4/2015		RM 2532 TOO HOT
FO-323591	8/4/2015	8/4/2015		COLD ROOM IS VERY HOT. ROOM 4465.
FO-323596	8/4/2015			512 LOW TEMP
FO-323619	8/4/2015	8/12/2015		RM 6238 HIGH TEMP ALARM
FO-323680	8/4/2015	8/4/2015		POWER BUMP (POWER WENT OUT AND CAME BACK ON)
FO-323703	8/5/2015	8/12/2015		LOW STEAM PRESSURE ALARM. ROOM 100.
FO-323715	8/5/2015			RM 0512 LOW TEMP
FO-323817	8/6/2015	8/12/2015		RM 1352/KITCHEN HAS NO STEAM (SERVING LUNCH SOON)
FO-323836	8/6/2015			R/R RM 133/DLAR IT IS TOO HOT
FO-323847	8/6/2015	8/12/2015		RM 423 HAS NO HOT WATER
FO-323899	8/7/2015	8/7/2015		4TH FLR HALLWAY/DLAR AREA (471)A STRANGE BURNING SMELL
FO-323906	8/7/2015	8/7/2015		RM 468 HIGH HUMIDITY
FO-323937	8/7/2015			RM 0514 HAS AN AIR EXCHANGE PROBLEM
FO-323943	8/7/2015	8/12/2015		RM 6238 HIGH TEMP ALARM
FO-323999	8/10/2015	8/13/2015		Office 7339, adjacent to Lab 7327. Dr Berkowitz is complaining about the noise in his office from the HVAC system. Please have Building Engineer check out.
FO-324025	8/10/2015			RM 220 EXHAUST FAN NOT WORKING
FO-324032	8/10/2015			RM 525 & 0225 BOTH RM'S HAVE POSITIVE PRESSURE TO THE HALLWAY, PRESSURE SHOULD BE NEGATIVE TO HALLWAY
FO-324035	8/10/2015	8/13/2015		LOBBY NEAR GUARDS DESK ALARM PANEL TROUBLE LIGHT IS ON
FO-324085	8/11/2015	8/12/2015		Room needs to be under negative pressure
FO-324086	8/11/2015	8/12/2015		Room needs to be under negative pressure
FO-324087	8/11/2015	8/12/2015		Room needs to be under positive pressure

WO	Recieved	Finished	Total	Request
FO-324117	8/11/2015	8/11/2015		2ND FLR NO STEAM TO THE AUTOCLAVE
FO-324120	8/11/2015			FAN ALARM ON RETURN AIR FAN #1
FO-324128	8/11/2015	8/11/2015		RM 9374 HAS A LITE COVER HANGING OBSCURING WALKING
FO-324212	8/12/2015			RM 2602.1 TOO COLD
FO-324224	8/12/2015	8/13/2015		RM 1272 SEWER SMELL
FO-324250	8/12/2015	8/13/2015		RM 6130 (WALK IN COLD RM BOX) HAS A HI TEMP ALARM
FO-324278	8/13/2015	8/13/2015		TEMPERATURE ALARM. ROOM 4465.
FO-324300	8/13/2015	8/13/2015		RM 111 TOO COLD
FO-324313	8/13/2015			air supply from tower is not working properly. Is going on and off. In surgery at this time. need it looked at right away
FO-324330	8/13/2015	8/14/2015		RM 5215 TOO COLD
FO-324369	8/14/2015	8/14/2015		2602.1 TOO COLD
FO-324379	8/14/2015	8/17/2015		WATER CLOSET IS CONTINOUSLY RUNNING. MEN'S RESTROOM. ROOM 4101.
FO-324479	8/17/2015	8/18/2015		TOO HOT. MAGERIO CONFERENCE CENTER.
FO-324482	8/17/2015	8/18/2015		RM 115 BODY CHILLER NOT WORKING, BODY IS INSIDE
FO-324716	8/18/2015	8/19/2015		VERY HOT AND THERE IS A SMOKY SMELL IN THIS ROOM. ROOM 525.
FO-324717	8/18/2015	8/19/2015		7TH FL TOO HOT 7598,7271,7575,7577
FO-324722	8/18/2015	8/18/2015		FLOOD - WATER ON FLOOR. ROOM 328.
FO-324734	8/18/2015	8/20/2015		HIGH TEMP. ROOM 200.14.
FO-324742	8/18/2015	8/20/2015		9TH FL TOO HOT
FO-324746	8/18/2015	8/20/2015		RM 0525 TOO HOT
FO-324748	8/18/2015	8/20/2015		RM 9248 SMOLDERING SMELL
FO-324766	8/18/2015	8/20/2015		RM 0521, 0527, AGAIN 0525 TOO HOT PLEASE UPDATE OCCUPANT REGARDING TEMP
FO-324842	8/19/2015	8/19/2015		RM 5520 & 5530 TOO HOT
FO-324944	8/19/2015			Animal Room is positive pressure to the hallway, it needs to be negative pressure. Thank you, Susan
FO-324953	8/19/2015			2290 TOO COLD
FO-324954	8/19/2015			2290 TOO COLD
FO-324955	8/19/2015	8/19/2015		RM 5617 TOO HOT
FO-324984	8/19/2015	8/20/2015		RM 423 HIGH TEMP
FO-325035	8/20/2015	8/20/2015		5TH FLR JOHN R SIDE OF BLDG IS TOO HOT
FO-325121	8/21/2015	8/21/2015		CHECK SINK FAUCETS FOR PROBLEMS WITH WATER. LADIES RESTROOM. ROOM 2377.
FO-325129	8/21/2015	8/21/2015		BLDG FAP FIRE ALARM IS BUZZING/BEEPING LOUD
FO-325155	8/21/2015	8/21/2015		BLDG FAP FIRE ALARM IS BUZZING/BEEPING LOUDLY AGAIN
FO-325156	8/21/2015			RM 1128 IS TOO HOT
FO-325162	8/21/2015			RM 00359/STORAGE RM TO YOUR RIGHT AS YOU WALK IN CLNG PIPE IS LKNG
FO-325190	8/24/2015	8/24/2015		RM 423 TOO HOT
FO-325235	8/24/2015	8/24/2015		RM 0519 LOW TEMP
FO-325307	8/25/2015	8/25/2015		TOO WARM. ROOM 2105.
FO-325321	8/25/2015			INVESTIGATE LOUD KICKING SOUND 1ST FLOOR ROOMS 1367 AND 1369 AND SURROUNDING AREAS.
FO-325337	8/25/2015			RM 7119 HIGH TEMP
FO-325418	8/26/2015			TOO COLD. ROOM 321.
FO-325448	8/26/2015			HIGH TEMP. ALARM. ROOM 8337.
FO-325458	8/26/2015			RM 231 TOO COLD
FO-325467	8/26/2015	8/26/2015		Temperature is too high (75 degrees)
FO-325468	8/26/2015			BLUE LECT HALL IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-325529	8/27/2015			RM 200.01 LOW TEMP ALARM
FO-325532	8/27/2015	8/31/2015		RM 231 TOO COLD
FO-325554	8/27/2015	8/27/2015		TOO COLD. ROOMS 2290 AND 2226.
FO-325563	8/27/2015	8/28/2015		LOW TEMP. IT'S 71 DEGREES. ROOM 0247
FO-325564	8/27/2015	8/28/2015		LOW TEMP. IT'S 68 DEGREES. ROOMS 0231 AND 0239.
FO-325567	8/27/2015	8/28/2015		ALL ANIMAL ROOMS IN BASEMENT ARE TOO COLD.
FO-325580	8/28/2015	8/31/2015		LOW TEMP. ROOM 0231.
FO-325582	8/28/2015	8/31/2015		LOW TEMP. ROOMS 0519 AND 0513 THEY ARE BELOW 68 DEGREES.
FO-325588	8/28/2015	8/31/2015		High temperature - 86 degrees. This is an animal holding room and is high priority.
FO-325595	8/28/2015			WATER FILTER SUPPLY IS LEAKING. ROOM 521.
FO-325599	8/28/2015			TOO COLD. ROOMS 240 THRU 243 AND 301 THRU 308.
FO-325618	8/28/2015			BANGING NOISE IN ROOM 310.
E - North			47	
FO-323439	8/3/2015	8/3/2015		TOO COLD. 2ND FLOOR ROOMS 258 AND 250.
FO-323468	8/3/2015	8/3/2015		WITHIN 3094 LOUD RUMBLING NOISE CAN BE HEARD FROM ABOVE
FO-323478	8/3/2015	8/3/2015		TOO HOT. ROOM 2242. (DAMON KEITH BLDG.)
FO-323487	8/3/2015	8/3/2015		POSSIBLE CEILING LEAK. WATER ON FLOOR. 4TH FLOOR - 4WH.
FO-323557	8/4/2015	8/4/2015		TOO COLD. BUILDING EXCEPT THE OFFICE.
FO-323608	8/4/2015	8/4/2015		TOO WARM. BUILDING.
FO-323609	8/4/2015	8/5/2015		BURNING RUBBER SMELL AS YOU ENTER THE FRONT ENTRANCE MIDDLE DOOR.
FO-323669	8/4/2015	8/4/2015		LOUD NOISE COMING FROM CEILING. ROOM 3094.
FO-323676	8/4/2015	8/4/2015		POWER FAILURE ALARM. ROOM 016.
FO-323705	8/5/2015	8/5/2015		ENTIRE BLDG IS TOO COLD
FO-323741	8/5/2015	8/5/2015		BLDG TOO COLD
FO-323924	8/7/2015	8/17/2015		POWER BUMP AT REUTHER & PURDY APPR 9AM CHECK EQUIP
FO-323925	8/7/2015	8/7/2015		POWER BUMP AT COMM ARTS, ALUMNI HOUSE, MUSIC SHAVER APPR 9AM CHECK EQUIP
FO-323930	8/7/2015	8/7/2015		POWER BUM APPR 9AM CHECK EQUIP
FO-324000	8/10/2015	8/26/2015		FAP FIRE TROUBLE ALARM
FO-324009	8/10/2015	8/6/2015		RM 4236 HAS A LEAK IN CLNG (Hear wtr running)
FO-324040	8/10/2015	8/10/2015		4TH FLR BY ELEVS' @ CLNG A CONTINUOUS LEAK NOT FROM RAIN
FO-324110	8/11/2015	8/11/2015		NO AIR. BUILDING
FO-324293	8/13/2015	8/13/2015		RM 4129 BUZZING NOISE
FO-324317	8/13/2015	8/14/2015		Purdy Library 2nd Floor, Room 242 Door will not stay locked. Security concern: room contains expensive computer equipment. Please repair. (Multi-task) Thank you.
FO-324341	8/13/2015	8/13/2015		RM 146 UPPER PART OF DERROY WHERE AUDIO VISUAL EQUIP IS PLUGGD IN NO POWER
FO-324400	8/14/2015	8/14/2015		FIRE TROUBLE ALARM
FO-324455	8/17/2015	8/17/2015		RM 2228 TOO HOT
FO-324510	8/17/2015	8/17/2015		POSSIBLE POWER BUMP. PLEASE CHECK EQUIPMENT.
FO-324726	8/18/2015	8/18/2015		RM 4236 CEILING LEAK POSSIBLY DUE TO CONSTRUCTION
FO-324741	8/18/2015	8/18/2015		RM 4116 CEILING LEAK POSSIBLY DUE TO CONSTRUCTION
FO-324763	8/18/2015	8/18/2015		FIRE ALARM
FO-324765	8/18/2015	8/18/2015		RM 4092 TOO HOT
FO-325036	8/20/2015	8/20/2015		PORTABLE AIR CONDITIONER IS COMING APART. PRESIDENT'S OFFICE. ROOM 4200.

WO	Recieved	Finished	Total	Request
FO-325051	8/20/2015	8/20/2015		RM 3327/LOUNGE KITCHEN AREA HAS NO WATER RUNNING (GO THRU RM 3315 TO GET TO RM 3327)
FO-325117	8/21/2015	8/21/2015		FIRE ALARM SOUNDING. BASEMENT ROOMS 10.1 AND 10.7.
FO-325192	8/24/2015	8/24/2015		CEILING LEAK. ROOM 4032.
FO-325207	8/24/2015	8/24/2015		CARPET IS WET IN HALLWAY FRONT OF ROOM 3300. WATER IS COMING FROM UNDERNEATH DOOR OF ROOM NEXT TO ROOM 3300.
FO-325217	8/24/2015	8/24/2015		RM 00030/BSMT IS TOO HOT
FO-325220	8/24/2015	8/24/2015		RM 00050/BSMT IS TOO HOT
FO-325244	8/24/2015	8/24/2015		RM 250 IS EXTREMELY COLD
FO-325246	8/24/2015	8/24/2015		RM 258 IS EXTREMELY COLD
FO-325250	8/24/2015	8/24/2015		TOO HOT. ROOM 2325.
FO-325251	8/24/2015	8/24/2015		TOO COLD. ROOM 3291.
FO-325252	8/24/2015	8/24/2015		TOO WARM. 3RD FLOOR SOUTH SIDE OF BUILDING.
FO-325257	8/24/2015	8/25/2015		CEILING LEAK. ROOMS 4300 AND 4302.
FO-325264	8/24/2015	8/24/2015		TOO HOT. ROOM 241.
FO-325303	8/25/2015	8/25/2015		TOO COLD. BUILDING.
FO-325315	8/25/2015	8/25/2015		RM 3291 TOO COLD
FO-325469	8/26/2015	8/26/2015		Air conditioner is running constantly. Thermostat has message "please check". thank you.
FO-325530	8/27/2015	8/27/2015		TOO COLD. ROOM 425.
FO-325561	8/27/2015	8/27/2015		TOO COLD. BUILDING.
E - Northeast			12	
FO-323712	8/5/2015	8/7/2015		DESIGN SERVICE AREA FRANS OFFICE IS TOO HOT
FO-323819	8/6/2015	8/6/2015		Please turn air conditioning on
FO-323934	8/7/2015	8/7/2015		ENTIRE BLDG HAS A VERY BAD SMELL BELIEVE FANS ARE OFF
FO-324005	8/10/2015	8/10/2015		2ND FL CHIEFS CONF RM AND POSSIBLY KITCHEN OUTLETS NOT WORKING
FO-324295	8/13/2015	8/7/2015		AIR NOT FLOWING PROPERLY CAUSING FOUL SMELL THROUGHOUT BUILDING.
FO-324443	8/17/2015	8/18/2015		There is no air conditioning in the front end (East)end of the third floor.
FO-324444	8/17/2015	8/17/2015		TOO HOT. 2ND FLOOR MULTI-PURPOSE ROOM.
FO-324505	8/17/2015	8/17/2015		POSSIBLE POWER BUMP. PLEASE CHECK EQUIPMENT.
FO-324507	8/17/2015	8/17/2015		POSSIBLE POWER BUMP. PLEASE CHECK EQUIPMENT.
FO-324744	8/18/2015	8/18/2015		Water cooled AC unit on third floor is not cooling and display shows in Celsius instead of Fahrenheit.
FO-324934	8/19/2015	8/19/2015		RM 115 TOO HOT
FO-324988	8/19/2015			WINDOW AIR CONDITIONER IS LEAKING. STOCKROOM.
E - Preventative Maintenance			50	
FO-323495	8/3/2015	8/4/2015		14001.3 TOO HOT
FO-323497	8/3/2015	8/4/2015		RM 3421 HIGH TEMP ALARM
FO-323498	8/3/2015	8/5/2015		BLDG TOO COLD
FO-323499	8/3/2015	8/4/2015		GAS SMELL WEST SIDE OF BLDG STAIRWELL D
FO-323681	8/4/2015	8/5/2015		ALARM PANEL MAKING A LOUD BEEPING NOISE
FO-323682	8/4/2015	8/5/2015		GENERATOR/LOW FUEL ALARM
FO-323687	8/4/2015	8/5/2015		BLDG TOO HOT
FO-323688	8/4/2015	8/4/2015		Front cover and filter for AC unit were removed or fell off and are on the floor. Please reinstall and check that AC unit is working properly.
FO-323694	8/4/2015	8/4/2015		BACK DOOR NOT LATCHING
FO-323777	8/5/2015	8/5/2015		RM 2529 IS TOO HOT
FO-323780	8/5/2015	8/6/2015		RM 2105 HAS A SET OF DOUBLE DOORS THEY'RE UNABLE TO OPEN OTHER DOUBLE DOOR SO THE TANK CAN BE BROUGHT IN

WO	Recieved	Finished	Total	Request
FO-323782	8/5/2015	8/6/2015		RMS 9213/9223 CLNG IS LEAKING BELIEVE WATER COMING FROM PH MM/8-5-15
FO-323787	8/5/2015	8/6/2015		RM 1126 SHOWER NOT WORKING
FO-323960	8/7/2015	8/7/2015		RM 7119 HAS A LOW TEMP
FO-323966	8/7/2015	8/8/2015		FOOTBALL STADIUM RESTROOM TOILET IS PLUGGED
FO-324070	8/10/2015	8/11/2015		FIRE TROUBLE ALARM
FO-324074	8/10/2015	8/10/2015		APT 911 TOILET NOT FLUSHING
FO-324075	8/10/2015	8/11/2015		SOFTBALL STADIUM OFFICE TO THE LEFT, CEILING LEAK
FO-324076	8/10/2015	8/10/2015		RM 523 BURNING SMELL
FO-324268	8/12/2015	8/13/2015		The cooling system is making a very high pitched squealing sound which is very irritating. It started around 4pm. Please make it stop.
FO-324266	8/12/2015	8/13/2015		ROOF HATCH ALARM
FO-324415	8/14/2015	8/15/2015		LOBBY AREA, CEILING LEAK
FO-324513	8/17/2015	8/18/2015		TOO HOT. ROOM 9405.4.
FO-324514	8/17/2015	8/18/2015		NO AIR IN BUILDING DUE TO POWER SURGE.
FO-324515	8/17/2015	8/18/2015		TOO HOT. ROOM 202.
FO-324516	8/17/2015			ALARM WONT RESET FIRE ALARM SOUNDING. Completed 8-18-2015 SRP
FO-324518	8/17/2015	8/18/2015		RM WITHIN 3207 AC NOT WORKING
FO-324520	8/17/2015			RM 1353 & 1325 PIPE LEAKING WITHIN BOTH ROOMS
FO-324788	8/18/2015	8/19/2015		STE 200 BLOWN FUSE
FO-324795	8/18/2015	8/18/2015		RM 3249 TOO HOT, WOULD LIKE AIR TURNED ON
FO-324797	8/18/2015	8/19/2015		BSMNT 150 TOO HOT
FO-324993	8/19/2015	8/19/2015		RM 5102 TOO HOT
FO-324997	8/19/2015	8/20/2015		RM 1330 OCCUPANT HAS QUESTIONS REGARDING EXHAUST FL UNIT
FO-324999	8/19/2015	8/20/2015		Breaker is tripped for the oven that is in the fume hood. This is the second time this has happened this week. Researcher is in the middle of a experiment right now and needs it reset a.s.a.p
FO-325085	8/20/2015	8/21/2015		TOO COLD. ROOM 324.
FO-325174	8/21/2015			RM 4402 IS TOO WARM/STUFFY
FO-325179	8/21/2015	8/21/2015		VENT COVER IS HANGING OFF. HALLWAY OUTSIDE OF KITCHEN ROOM 1103.
FO-325273	8/24/2015	8/25/2015		RM 13100.1 WOMENS RR ONLY TOILET WON'T FLUSHING
FO-325278	8/24/2015	8/24/2015		RM 3261 UNABLE TO UNLOCK OUTER DOOR TO RM HOWEVER INNER DOOR ABLE TO UNLOCK (KEY IS IN RM 3315 OF LAW LIB)
FO-325279	8/24/2015	8/24/2015		INVESTIGATE LOUD KICKING SOUND 1ST FLOOR ROOMS 1367 AND 1369 AND SURROUNDING AREAS.
FO-325389	8/25/2015	8/25/2015		STE 100 TOILET OVERFLOWING
FO-325391	8/25/2015	8/29/2015		LOUD AUDIBLE VIBRATION THROUGHOUT BLDG
FO-325394	8/25/2015	8/26/2015		Our fume hood labeled EF-32 is does not turn on when we switch it on. It seems as though the switch is broken. Can we have this looked at? Thanks! Eric
FO-325477	8/26/2015	8/26/2015		RM 112 IS TOO COLD
FO-325570	8/27/2015			LAB 279 FUME HOOD 15 LEAKING
FO-325572	8/27/2015	8/28/2015		LIGHT POLE ON THE SIDE OF MCGREGOR HAS BEEN STRUCK, WIRES ARE EXPOSED REQUESTING ENG
FO-325629	8/28/2015	8/29/2015		TOO HOT. ROOMS 308 AND 318. ROOM 308 IS BLOWING HOT AIR OUT OF VENT.
FO-325630	8/28/2015	8/29/2015		FIRE TROUBLE ALARM. BASEMENT
FO-325636	8/28/2015	8/29/2015		TOO HOT. A/C NOT WORKING. PLEASE TURN A/C ON. (BUILDING)

WO	Recieved	Finished	Total	Request
FO-325637	8/28/2015			TOO COLD. ROOM 429.
E - South			31	
FO-323427	8/3/2015	8/3/2015		FIRE TROUBLE ALARM.
FO-323451	8/3/2015	8/3/2015		2ND FL BRIDGE ALARMING
FO-323482	8/3/2015	8/3/2015		TOO HOT. ROOM 403.
FO-323488	8/3/2015	8/3/2015		BLDG TOO HOT
FO-323551	8/4/2015	8/6/2015		PIPE LEAKING AT CAGE WASHER. ROOM 0239.
FO-323552	8/4/2015	8/6/2015		BROKEN LIGHT TIMER. ROOM 0245.
FO-323554	8/4/2015	8/6/2015		EYEWASH WATER IS HOT. ROOM 239.
FO-323555	8/4/2015	8/6/2015		WHOLE IN CEILING. ROOM 239. PLEASE INVESTIGATE.
FO-323631	8/4/2015	8/4/2015		FIRE TROUBLE ALARM
FO-323679	8/4/2015	8/4/2015		ALARM SOUNDING. 1ST FLOOR RECEPTION AREA.
FO-323723	8/5/2015	8/5/2015		WON DOOR IS BEEPING AND FIRE DOOR ALSO NEEDS TO BE ROLLED UP
FO-323735	8/5/2015	8/6/2015		TOO COLD. ROOMS 3100 AND 1100.
FO-323850	8/6/2015	8/6/2015		1ST FLR HALLWAY OUTSIDE RM 169 PANEL (FAP) IS BEEPING
FO-323912	8/7/2015	8/7/2015		POWER BUMP RFIRE TROUBLE ALARM
FO-323921	8/7/2015	8/7/2015		POWER BUMP AT APPR 9AM CHECK EQUIP
FO-323945	8/7/2015	8/7/2015		LAB 360 LIGHTS NOT WORKING AFTER POWER BUMP
FO-324368	8/14/2015	8/14/2015		TOO COLD. AUDITORIUM.
FO-324398	8/14/2015			RECEPTION AREA ALARM PANEL ALARMING
				Completed 8-17-2015 SRP
FO-324402	8/14/2015	8/17/2015		LAB 140 TOO COLD
FO-324822	8/19/2015	8/19/2015		TOO HOT. 4TH FLOOR.
FO-324977	8/19/2015	8/19/2015		Requesting an engineer to Rands House 100 to change air condition setting to high.
FO-325049	8/20/2015	8/20/2015		RM 1165 CK BREAKER FOR CLNG PROJECTOR OUTLET
FO-325189	8/24/2015	8/24/2015		ALARM PANEL OUTSIDE ENGINEER RM MAKING A LOUD VIBRATING NOISE
FO-325265	8/24/2015	8/25/2015		The steam pipes are banging very loudly in our office area. (AGAIN)
FO-325351	8/25/2015	8/25/2015		Room 1551 in the EDC. The exhaust fan is not working properly. Back pressure is building up and it is damaging the engine. We need Rocky to look at immediately. Please contact Kamal at 313-424-2562. Thank you.
FO-325369	8/25/2015	8/26/2015		VERY LOUD BANGING SOUND. ROOM 0034.
FO-325428	8/26/2015	8/26/2015		ALARM SOUNDING - 1ST FLOOR LOBBY.
FO-325441	8/26/2015	8/26/2015		FIRE TROUBLE ALARM AND FULL ALARM SOUNDING.
FO-325603	8/28/2015	8/31/2015		TOO COLD. ROOM 4159.
FO-325616	8/28/2015	8/31/2015		WALL OUTLETS ARE NOT WORKING. LAB. 3321.
FO-325619	8/28/2015	8/28/2015		TOO COLD. ROOM 243.
E - Southeast			29	
FO-323432	8/3/2015	8/4/2015		TOO HOT. ROOM 1137.
FO-323592	8/4/2015	8/4/2015		RM 43 FLOOR GETS WET WHEN IT RAINS NOT SURE IF IT IS A LEAK
FO-323713	8/5/2015	8/5/2015		RM 205 & 220 AIR PRESSURE IS OFF, PRESSURE SHOULD BE NEGATIVE
FO-323724	8/5/2015	8/12/2015		RM 2316 IS TOO COLD
FO-323911	8/7/2015			POWER BUMP
FO-323932	8/7/2015	8/12/2015		6TH FL NEXT TO RM 6304.7 RM TOO COLD FOR MORE DETAILS SEE LILLY IN RM 6203
FO-323984	8/10/2015	8/10/2015		RM 6100.30 GARBAGE DISPOSAL ISN'T WRKNG CK BREAKER
FO-324021	8/10/2015	8/10/2015		AF28 NO STEAM ON AUTOCLAVE
FO-324029	8/10/2015	8/10/2015		RM 5102 AIR NOT WORKING
FO-324431	8/17/2015			NO AIR IN BUILDING.

WO	Recieved	Finished	Total	Request
FO-324438	8/17/2015	8/17/2015		RM 4032 ANS 4100 AIR NOT WORKING
FO-324459	8/17/2015	8/17/2015		1ST FL LOBBY AND THEATRE NEED AIR TURNED ON
FO-324485	8/17/2015	8/19/2015		ROOF TOP UNIT #4 KEEPS TRIPPING OUT. (The air conditioning is blowing hot air instead of cold). (Multi-Task)
FO-324511	8/17/2015			POSSIBLE POWER BUMP. PLEASE CHECK EQUIPMENT.
FO-324735	8/18/2015	8/18/2015		PRENTIS 2ND FL NO STEAM
FO-324738	8/18/2015	8/18/2015		LOADING DOCK LIFT IS NOT WORKING.
FO-324762	8/18/2015	8/18/2015		TOO HOT. ROOM 202.
FO-324767	8/18/2015			RM 201.3 TOO HOT
FO-324839	8/19/2015	8/21/2015		BLOWN FUSE. 2ND FLOOR WOMEN AND CONFERENCE ROOMS.
FO-325044	8/20/2015			PLS TURN ACU BACK ON TOO HOT
FO-325108	8/21/2015	8/21/2015		FAP FIRE TROUBLE ACTIVE
FO-325128	8/21/2015	8/21/2015		RM 1372 HAS A CLNG PIPE LEAK BY WINDOW
FO-325224	8/24/2015	8/24/2015		RM 10302/CONF RM IS TOO HOT
FO-325225	8/24/2015	8/24/2015		RM 10302.10/LOUNGE IS TOO HOT
FO-325300	8/25/2015	8/25/2015		FIRE TROUBLE ALARM.
FO-325412	8/26/2015	8/26/2015		FAP FIRE TROUBLE ALARM ACTIVE
FO-325527	8/27/2015	8/27/2015		RM 14101.3 TOO HOT
FO-325528	8/27/2015	8/27/2015		RM 2218 TOO COLD
FO-325535	8/27/2015	8/27/2015		RM 2139 OUTLET NOT WORKING, OUTLET CONNECTED TO FRIDGE
E - West			12	
FO-323556	8/4/2015	8/5/2015		FIRE ALARM.
FO-323672	8/4/2015	8/5/2015		NATURAL GAS SMELL. WARREN ENTRANCE INSIDE AND OUTSIDE OF BUILDING.
FO-323674	8/4/2015	8/5/2015		FIRE TROUBLE ALARM.
FO-323922	8/7/2015	8/7/2015		POWER BUMP AT APPR 9AM CHECK EQUIP
FO-323928	8/7/2015	8/7/2015		POWER BUM APPR 9AM CHECK EQUIP
FO-324344	8/13/2015	8/13/2015		SOUTH WALL OUTLET IS NOT WORKING. ROOM 211.
FO-325033	8/20/2015	8/21/2015		RM 100/AUD THEY HAVE ORIENTATION & COMPLAINING ITS TOO COLD
FO-325056	8/20/2015	8/21/2015		TOO COLD. ROOM 324.
FO-325169	8/21/2015	8/24/2015		TOO COLD. BUILDING.
FO-325349	8/25/2015	8/31/2015		COACHES OFFICE NO AIR
FO-325426	8/26/2015	8/27/2015		RM 137 IS TOO COLD/FREEZING
FO-325427	8/26/2015	8/27/2015		3RD FLR IS TOO COLD/FREEZING
Medium			45	
E - Auxiliary			11	
H-53520	8/1/2015			kitchen sink is plugged up.Grinder is not working at all authenticated user: Durie Nam - fg8878requester ip address: 35.16.199.186
H-53521	8/3/2015			food disposal drain is bot working.authenticated user: Rahul Reddy Kandi - fs2308requester ip address: 141.217.23.210
H-53719	8/16/2015			The flush in the toilet bowl is too noisy. Once the flush is used, the noise persists and never stops. authenticated user: Vineeth Rakesh Mohan - ed3424requester ip address: 35.16.69.175
H-53785	8/18/2015			When I moved in August 16 my shower nozzle that turns the water on and off was broken and I put a work order in that day and got no response. It's still broken. authenticated user: Lorene Ivey - el6553 requester ip address: 35.16.101.7
H-53909	8/20/2015			Outlet across from window does not workauthenticated user: Kimberly Daniels - fx3290requester ip address: 35.16.64.27
H-53905	8/22/2015			Faucet in bathroom is dripping. authenticated user: Krishna Shah - cq3799requester ip address: 141.217.232.64

WO	Recieved	Finished	Total	Request
H-53907	8/24/2015			Using machines 4, 6, and 7 simultaneously in the laundry room causes the circuit breaker to trip and power is lost to those machines cause many problems for residents who don't know where the panel is. authenticated user: Krishna Shah - cq3799requester
H-53948	8/25/2015			Kitchen light flickers when turned on.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53985	8/27/2015			Power outlets are not working in room 1506authenticated user: Briana Collins - ez6508requester ip address: 141.217.23.214
H-54033	8/28/2015			Garbage Disposal is broken, creates very loud noise.authenticated user: Samantha Mannino - ez5465requester ip address: 141.217.233.108
H-54173	8/30/2015			Leaks from ceiling at two spots. It was sort of fixed yesterday but it started leaking again.authenticated user: Naman Chopra - fq7231requester ip address: 141.217.23.210
E - Command Center			22	
FO-323423	8/3/2015	8/6/2015		Perform flue gas analysis on Boiler "A"
FO-323453	8/3/2015	8/7/2015		Perform Flue -gas analysis on Boiler #1.
FO-323454	8/3/2015	8/7/2015		Perform Flue -gas analysis on Boiler #1.
FO-323455	8/3/2015	8/6/2015		Replace high limit pressure switch on RTU serving the compliance office. Work will require evacuating the refrigerant in the unit.
FO-323457	8/3/2015	8/4/2015		CHANGE BATTERIES IN SIEMENS FIELD PANELS 1,2, & 4 THEY SHOW 0% POWER LEFT
FO-323671	8/4/2015	8/11/2015		Trade: Controls Priority: Medium 090-BSG-001 Perform post combustion test on Boiler #1.
FO-323863	8/6/2015	8/18/2015		Trade: Command Center Priority: Medium R/R RM 270 Please make repairs to fume hood #6
FO-324420	8/16/2015			Repair control air compressor. The motor sheave has come loose and the keyway is stripped on the motor shaft at Hilberry. Discovered by W. Owens. Unit taken out of service.
FO-324421	8/16/2015	8/17/2015		Old Main Boiler #1 is out of service due to faulty burner cam linkage. Please restore to service.
FO-324422	8/16/2015	8/14/2015		Cohn Boiler #1 is tripping on flame failure regularly.
FO-324427	8/17/2015	8/17/2015		R/R site glass Boiler #1
FO-325003	8/20/2015			The end switch on high purge is not working on Boiler "A"
FO-325012	8/20/2015			Trade: command Center Priority: Medium R/R RM 280 Please PProvide "operator display panel" (ODP) for fume hood #3. (part no: 537720A010218120)
FO-325075	8/20/2015	8/20/2015		Trade: controls/siemens Priority: Medium R/R RM 3540 Lab occupants complaining too cold. I raised the room setpoint to 74 from 72 and did not get any movement on reheat valve.
FO-325078	8/20/2015	8/20/2015		Trade: controls/Siemens Priority: Medium R/R RM 3546 Occupants complaining lab is too cold. Graphic for this lab shows 74 degrees space temp. Yet when I raise the room set point to 76 the reheat valve does not move.
FO-325064	8/20/2015			The air drier on the main air compressor has failed and is not working properly
FO-325079	8/20/2015	8/20/2015	8/20/2015	Trade: controls/siemens Priority: Medium R/R RM 3540 Lab occupants complaining too cold. I raised the room setpoint to 74 from 72 and did not get any movement on reheat valve.
FO-325188	8/24/2015			BAS engineers:Please check settings for VAV boxes in Design Services area. When air dampers open 70-80%, VAVs are making excessive high pitched sound.Priority:medium
FO-325214	8/24/2015			Alter Siemens building schedule to active: M-F 7a-10p; Sa/Su 8a-6p
FO-325499	8/27/2015			Trade: Command CenterPriority: MediumPlease investigate and correct nuisance alarms on points "F005.02.ATC.ALM" & "F005.04.FAN.ALM".
FO-325503	8/27/2015			Trade: Command CenterPriority: MediumPlease check graphics on the exhaust fan page "F005.EF". There is an extra point box in the upper left corner that is not in use. This may have been an alarm point.
FO-325549	8/27/2015	8/28/2015		Controls, repair boiler #2 no start. Seems like a safety control is holding it out. Priority Med.
E - MedPharm			1	
FO-325522	8/27/2015	8/31/2015		RM 206 TOO COLD
E - North			2	

WO	Recieved	Finished	Total	Request
FO-323589	8/4/2015	8/17/2015		please repair chipped paint and hole in upper part of wall behind door-rm 219. contact Dale at 7-9880. thank you
FO-325460	8/26/2015	8/26/2015		RM 2074 TOO COLD
E - Preventative Maintenance			4	
FO-324412	8/14/2015	8/14/2015		Please check pin code pad on second door closest to 319/323 (women/men's restroom). It doesn't unlock.
FO-324793	8/18/2015	8/19/2015		TOILET SEAT IS LOOSE KEEPS MOVING. 1ST FLOOR WOMEN'S RESTROOM. ROOM 106.
FO-324995	8/19/2015	8/19/2015		In suite 2190 - the kitchen area's power is working on the left side only.
FO-325487	8/26/2015			Thermostat is making a loud noise
E - South			2	
FO-325013	8/20/2015	8/20/2015		RM 101/CLASS RM IS TOO HOT
FO-325360	8/25/2015	8/25/2015		Steam pipes are banging non stop!
E - Southeast			3	
FO-323431	8/3/2015	8/4/2015		RM 1137 TOO HOT
FO-323463	8/3/2015	8/4/2015		Air and fan is not working in faculty office.
FO-324933	8/19/2015	8/19/2015		I found that the cooler does not work well (i.e. the fans cannot open, so that the cool air cannot enter) during these days, and I feel very warm in my office. Could you please come to check it?
Low			251	
E - Auxiliary			162	
H-53533	8/1/2015			Air conditioner is not working properly. authenticated user: Arish Nag Perumalpillai Rajappan Pillai - fq9175requester ip address: 35.16.195.115
H-53526	8/2/2015			Air conditioning turns on but does not cool off room. Warm air comes out of vent.authenticated user: Jake Clor - ff6066requester ip address: 35.16.104.24
H-53518	8/2/2015			Hi! Conference guests in room 210, have notified me that their A/C has been down since Sunday, of last week. I need a maintenance worker to come repair it as soon as they can so our guests can have a comfortable stay. Thanks! authenticated user: Niyah Ri
H-53538	8/2/2015			The master bedroom gets very little air conditioning. Even with the thermostat set to max cooling, the room is still very warm.authenticated user: Krishna Modi - fs8082requester ip address: 35.16.72.89
H-53528	8/2/2015			Broken Air Conditioningauthenticated user: Michelle Talukder - ev6408requester ip address: 35.16.111.172
H-53530	8/2/2015			Exhaust in the kitchen making too much noiseauthenticated user: Vignesh Muthukumar - fq6173requester ip address: 141.217.221.165
H-53537	8/3/2015			The kitchen sink is clogged. authenticated user: Serena Liu - fr1983requester ip address: 35.16.68.219
H-53536	8/3/2015			shower head and piping not working correctlyauthenticated user: Adon Harris - fs8066requester ip address: 35.16.65.191
H-53551	8/3/2015			Toilet is clogged and it is a single bath apartment. *****PRIORITY*****authenticated user: Ankita Ghosh - fp9957requester ip address: 141.217.221.68
H-53552	8/3/2015			Garbage disposer beside the kitchen sink is leaking and not working. My roommate and I moved in on the weekend.authenticated user: Jay Gajiwala - ft0997requester ip address: 35.16.76.46
H-53553	8/3/2015			Please check the air vent. it blows air. but even on High and Cool it is not cool enough.authenticated user: Ankita Ghosh - fp9957requester ip address: 141.217.221.68
H-53554	8/4/2015			I lost my power yesterday. Could you help me to restore that, please?authenticated user: Lin Fan - fb9071requester ip address: 35.16.228.129
H-53557	8/4/2015			loud noise is coming from heating and cooling systemauthenticated user: Chester Fleming - fc0603requester ip address: 141.217.224.141
H-53561	8/4/2015			Bathroom light having issues. The bulbs were changed, but they still don't work.authenticated user: Thomas Wolf - fj0736requester ip address: 141.217.23.191
H-53564	8/4/2015			Entry light doesn't work properly. Bulbs have been replaced but still don't work.authenticated user: Thomas Wolf - fj0736requester ip address: 141.217.23.191
H-53571	8/4/2015			mechanical checkauthenticated user: Keontae Ware - fg9660requester ip address: 141.217.23.210

WO	Recieved	Finished	Total	Request
H-53563	8/5/2015			Kitchen Sink waste disposer is not working.authenticated user: Arjun Singh - fi8442requester ip address: 141.217.220.66
H-53566	8/5/2015			Shower only has hot water.
H-53572	8/5/2015			Mechanical checkauthenticated user: Nicole Fry - eq0918requester ip address: 141.217.23.210
H-53585	8/5/2015			Part of the garbage disposal came out.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53584	8/6/2015			Garbage Disposal in kitchen not workingauthenticated user: Minna Cheng - fk8161requester ip address: 35.16.73.145
H-53580	8/6/2015			Towers 642 A/C is not working.
H-53588	8/6/2015			engineering check to CD apt. Ghafari
H-53600	8/6/2015			ENTRY LIGHT BULB BEEN CHANGED BUT STILL IS NOT WORKING!authenticated user: Joanna Berry - fa3511requester ip address: 141.217.23.225
H-53590	8/6/2015			The outlet in the main building hallway near apt 404 is broken.authenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53595	8/6/2015			The garbage disposal is jammed/not working. The red switch at the bottom gets pushed out every time someone tries to use it.authenticated user: Zachary Meyer - fy3419requester ip address: 146.9.154.107
H-53602	8/6/2015			Light in bathroom is broke. Bulbs have been switched in and out of there with no sign of power.authenticated user: Christopher Ozog - fi3944requester ip address: 141.217.230.142
H-53651	8/7/2015			Toilet is continuously flushingauthenticated user: Gihan Basnayake - ft6366requester ip address: 208.54.40.175
H-53627	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53624	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53626	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53628	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53625	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53606	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53607	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53608	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53609	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53610	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53611	8/7/2015			Mechanical Checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53647	8/8/2015			Kitchen sink disposer not working.Urgent Action required.authenticated user: Akshay Jadhav - fk1699requester ip address: 35.16.231.111
H-53645	8/9/2015			If possible, please replace TWO 2-prong outlets in the main living room. Currently, an adapter is being used instead, but I would like it converted to a 3-prong outlet for safety. One outlet has an AC unit plugged in, the other outlet has a power strip pl
H-53655	8/10/2015			The thermostat is not working, it is running hot. authenticated user: Chiara Woods - eb8378 requester ip address: 141.217.23.187
FO-323988	8/10/2015	8/11/2015		TWRS CAFE GARBAGE DISPOSAL ISN'T WRKNG/CK BREAKER
H-53658	8/10/2015			The air conditioner is not blowing out cool air anymore. authenticated user: Keontae Ware - fg9660requester ip address: 141.217.23.191
H-53675	8/11/2015			1. Toilet flush handle is not working properly and therefore the toilet does not flush. authenticated user: Adam Hafeez - bb8788requester ip address: 150.198.17.3

WO	Recieved	Finished	Total	Request
H-53663	8/11/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53664	8/11/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53661	8/11/2015			Toilet makes whining noise when flushed.authenticated user: - requester ip address: 141.217.23.210
H-53677	8/11/2015			1. Flush on the toilet will not work properly. Not sure if the handle is loose.authenticated user: Adam Hafeez - bb8788requester ip address: 150.198.17.3
H-53679	8/11/2015			My bedroom is the second one from the door. The air-conditioner in my bedroom does not work well, and I feel the cooling effect is relatively worse compared with the dinning room. In winter, the warming effect works not so good. authenticated user: Juan
H-53676	8/12/2015			Our disposer in the kitchen sink is out of workauthenticated user: Yuchuan Guo - fy7643requester ip address: 141.217.220.223
H-53699	8/12/2015			Far bathroom has a leak on the bottom right side of the tank. Water leaks onto floor when flushed.authenticated user: Brian Chun - ft0995requester ip address: 35.16.68.119
H-53685	8/12/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53700	8/13/2015			Towers 242 (former CD suite) garbage needs to be repaired. Not running - appears to be no power.
H-53726	8/14/2015			The a/c is not blowing out cold air anymoreauthenticated user: Keontae Ware - fg9660requester ip address: 35.16.101.10
H-53706	8/14/2015			The toilet is constantly running water and has issues flushing. Please resolve as soon as possible, thanks. authenticated user: Chiara Woods - eb8378 requester ip address: 141.217.23.187
H-53724	8/15/2015			Hi, the flushing valve of the toilet in the second bathroom is leaking all the time. It makes lots of noise and waste water. Can you come to repair it? Thanks!authenticated user: Zhao Yang - et2481requester ip address: 141.217.220.95
H-53712	8/15/2015			Kitchen - Hood Fan in the kitchen is broken. It will not turn on or off. authenticated user: Maddison Smith - fx6230requester ip address: 35.16.68.1
H-53713	8/15/2015			Bathroom 1 - Fan is not working.authenticated user: Maddison Smith - fx6230requester ip address: 35.16.68.1
H-53710	8/16/2015			Our air intake needs a new filter and we have BLACK MOLD on the air registers. authenticated user: Mikayla Shell - fh9275requester ip address: 35.16.65.207
H-53716	8/16/2015			The first bathroom flush system not working properly. authenticated user: Anvesha Dogra - fk3620requester ip address: 35.16.64.83
H-53727	8/16/2015			Could someone fix the thermostat?authenticated user: Bianca Dean - fo1867requester ip address: 35.16.102.106
H-53708	8/16/2015			Shower head faucet is broken authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.187
H-53721	8/17/2015			Garbage disposal in kitchen sink is jammed: contents of sink cannot go down. Sounds like it is not grinding properly. authenticated user: Naijamah Allah - ej2633requester ip address: 141.217.23.210
H-53725	8/17/2015			The larger bathroom's shower head is broken. Only half the water goes up to the shower headauthenticated user: Christie Cheng - fk4577requester ip address: 35.16.226.36
H-53729	8/17/2015			The air conditioning unit in my room is not working. When it is set on cool, the air that comes out is hot. The system is not cooling the air. authenticated user: Philip Trela - eu7977requester ip address: 35.16.108.35
H-53723	8/17/2015			Bathroom flush tank not working wellauthenticated user: Rohan Bhawar - fq8019requester ip address: 35.16.224.197
H-53730	8/17/2015			The air conditioning in Room 403 does not get cool. The fan turns on, but the air coming out is warm.authenticated user: James Wojno - eu8192requester ip address: 141.217.225.41
H-53703	8/17/2015			Shower constant dripsauthenticated user: Dazsanique Davis - fp0309requester ip address: 141.217.23.191
H-53762	8/17/2015			Bathroom sink water will not turn off constant runningauthenticated user: Dazsanique Davis - fp0309requester ip address: 141.217.23.191
H-53743	8/17/2015			Plastic covering of power socket has fallen off (Left wall of the kitchen)authenticated user: Chinthaka Amarasinghe - dy2128requester ip address: 141.217.154.50

WO	Recieved	Finished	Total	Request
H-53731	8/17/2015			Air Conditioning unit is not working properly , the thermostat is not responding. authenticated user: Yousef Al-Hashem - ax6195requester ip address: 35.16.23.88
H-53732	8/17/2015			Towers 850 AC not working
H-53733	8/17/2015			Towers 803 AC not working.
H-53751	8/17/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53752	8/17/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53753	8/17/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53754	8/17/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53755	8/17/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-53745	8/17/2015			Electrical plug broken behind kitchen.
H-53768	8/17/2015			Fan in front bathroom doesn't workauthenticated user: Karrington Seals - fn9683requester ip address: 66.87.114.139
H-53764	8/17/2015			A/C is not working- constant at 79 degreesauthenticated user: Dexter Wilson - fo0650requester ip address: 70.194.38.194
H-53772	8/18/2015			The kitchen fan that's right above our stove is not working properly. Sometimes it will work ok but most times it won't even turn on. The motor sounds like its working but it's just the sound it doesn't actually suck any of the air out. Thank youauthenti
H-53766	8/18/2015			I am requesting help to have my air conditioning system in the room fixed, which does not go to a "cool" temperature regardless of the time allowed to run.authenticated user: Sabbir Ahmed - fo9519requester ip address: 141.217.23.186
H-53767	8/18/2015			I sincerely apologize for this second form , but my shower is also severely malfunctioning and I need help with it as soon as possible! The shower has a problem with the water pressure (to get "hot" water , it must be turned all the way to the left and th
H-53796	8/18/2015			kitchen insink erator not working.authenticated user: Sohrab Sukhu - fr4260requester ip address: 35.16.73.108
FO-324794	8/18/2015	8/19/2015		LOBBY AREA HAS A LARGE CLNG LEAK
H-53803	8/19/2015			Shower not working properly and water leaking from tap when shower is turned on.authenticated user: Sohrab Sukhu - fr4260requester ip address: 141.217.59.50
H-53811	8/19/2015			Hello, AC of our apartment is not working properly. Please make a visit to check it once, it seems it's not cooling the room.Thank you.authenticated user: Hanspal Singh Kahlon - fk8843requester ip address: 35.16.72.224
H-53798	8/19/2015			Please help with the removal of a spoon from the garbage disposal.
H-53809	8/20/2015			A/C not working againauthenticated user: Dexter Wilson - fo0650requester ip address: 35.16.101.251
H-53800	8/20/2015			There is leak coming from the right overhead light in the entrance of Atchison Hall. Can you please resolve this issue as soon as possible.authenticated user: Marc Johnson - ek1297requester ip address: 141.217.23.183
H-53913	8/20/2015			The p-trap is leaking. authenticated user: Amanda Funk - fi7020requester ip address: 141.217.23.210
H-53833	8/20/2015			The hot water in my shower is not working. authenticated user: Sherell House - fa9352requester ip address: 35.16.100.16
H-53834	8/20/2015			The air conditioner in my room, 427, does not work. authenticated user: Sherell House - fa9352requester ip address: 35.16.100.16
H-53827	8/20/2015			Far Bathroom, the knob for turning the shower/tub water on slips on whatever holds it in place, the water turns on and off and changes temperatures at random knob positions instead of where they should (i.e. off should be all the way to the right and hot
H-53836	8/21/2015			The shower head is leaky and needs to be fixed. Thank You. authenticated user: Alexandra D'Abreu-Hines - fp0908 requester ip address: 35.16.100.163
H-53835	8/21/2015			Change air filter in roomauthenticated user: Nicole Witzleben - fh2191requester ip address: 141.217.225.96
H-53918	8/21/2015			There is no cold water in the apartment. When I turn on the cold water it runs very warm.authenticated user: Kimberly Daniels - fx3290requester ip address: 35.16.64.27

WO	Recieved	Finished	Total	Request
H-53899	8/22/2015			Thermostat make a weird humming sound. Louder than normal. authenticated user: Monique Bailhe - ev2511 requester ip address: 35.16.106.219
H-53867	8/22/2015			The in-sink erator/garbage disposal does not work and the draining is very slow. authenticated user: Christian Oliver Avila - ez7149 requester ip address: 141.217.59.62
H-53853	8/22/2015			Air Conditioning is not working authenticated user: Hunter Hollister - fi6094 requester ip address: 35.16.103.29
H-53878	8/22/2015			Hello, Our bathroom flush tank is not working properly. Please fix the problem as soon as possible. Thank You,Rohan Bhawar authenticated user: Rohan Bhawar - fq8019 requester ip address: 35.16.74.8
H-53922	8/23/2015			Foyer light by front door flickers and sometimes doesn't turn on. authenticated user: Natalie Nogoy - fb8644 requester ip address: 35.16.226.202
H-53923	8/23/2015			problem with toilet flush it wont flush and run constantly authenticated user: Rahul Reddy Kandi - fs2308 requester ip address: 141.217.23.210
H-53886	8/23/2015			Far Bathroom - bath/shower does not work properly, very difficult to turn water on, and when the water does turn on it is very difficult to turn back off. Water turns on or off or changes temperature at random knob positions. authenticated user: Namun Sri
H-53849	8/23/2015			- bathroom fan is loud authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53864	8/23/2015			Electrical outlet covering is off (by the kitchen) authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53870	8/24/2015			In bedroom 3, light switch is loose and not completely connected to the wall authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53888	8/24/2015			The door to the unit has a loose door latch authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53868	8/24/2015			The air conditioner is broken. authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53869	8/24/2015			The toilet makes loud ongoing sound after being flushed authenticated user: Dreana Williams - fi2266 requester ip address: 141.217.59.50
H-53880	8/24/2015			The garbage disposer is not working. Please fix authenticated user: Aniruddha Paranjpe - ew2356 requester ip address: 141.217.220.240
H-53902	8/24/2015			Lounge 200's air and vent do not work authenticated user: Dijon Williams - fk3806 requester ip address: 35.16.96.239
H-53903	8/24/2015			Lounge 300 vent/air does not work, room is (excessively) hot authenticated user: Dijon Williams - fk3806 requester ip address: 35.16.96.239
H-53894	8/24/2015			Large vent in last bedroom does not work when AC is on. authenticated user: Tahsin Rahman - er5131 requester ip address: 166.176.251.168
H-53931	8/24/2015			Air conditioning is not working authenticated user: Aarti Sajnani - ez8543 requester ip address: 141.217.23.186
H-53936	8/24/2015			In the small bedroom, Electric plug point on the wall adjacent to the bathroom is not working authenticated user: Sonal Joshi - ec9262 requester ip address: 35.16.65.245
H-53940	8/25/2015			We recently moved into the apartment. we had a problem in restroom there is no knob in the tub and problem in the flush. so kindly do the needy. authenticated user: Gayatri Praneeth Inakollu - fw6601 requester ip address: 35.16.78.227
H-53943	8/25/2015			The socket plugs in my room under my desk do not work. authenticated user: Jordan Baker - fv2685 requester ip address: 35.16.71.189
H-53956	8/25/2015			The vent in the second bathroom on the right (the one with the tub) is not working very well. It's making a very weird loud noise. Also it will randomly stop working even though it is "turned on". authenticated user: Andreea Mitache - fh1512 requester ip address: 141.217.23.210
H-53953	8/25/2015			APARTMENT 1513: When The shower is on and the tab is pulled up on the faucet, the water still runs at the bottom. ALSOThe air conditioner fan is noisy when running. authenticated user: Dina Mhanna - ev5191 requester ip address: 141.217.23.210
H-53954	8/26/2015			The ceiling in the bedroom is leaking water. It just started at 10:00pm. Can someone come and fix it thank you for your help. authenticated user: Latina Lightbourn - fm7003 requester ip address: 35.16.73.189
H-53955	8/26/2015			Sink crusher has stopped working. Please can you fix it? Thank you. authenticated user: Ruta Jog - fj1102 requester ip address: 35.16.64.231

WO	Recieved	Finished	Total	Request
H-53962	8/26/2015			503 and 1125 have bad ballisters over the sink and need to be replacedauthenticated user: Chester Fleming - fc0603requester ip address: 141.217.23.186
H-54001	8/26/2015			The kitchen sink is leaking from the motor and the motor is not working properly. The bathroom sinks are draining very slowly too.authenticated user: Mesam Akhter - fs2968requester ip address: 12.228.232.226
H-53983	8/26/2015			Second bathroom flush broken,authenticated user: Sri Lakshmi Vengala - fo9759requester ip address: 141.217.59.50
H-53967	8/26/2015			Towers 943 - no thermostat in room
H-53971	8/26/2015			Broken hood fan and dead light over stoveauthenticated user: Christian Oliver Avila - ez7149requester ip address: 141.217.59.62
H-54152	8/27/2015			The room needs a vent change. authenticated user: Danielle Henry - ew4467requester ip address: 141.217.23.191
H-54153	8/27/2015			On and off switch on the thermostat is broken. authenticated user: Danielle Henry - ew4467requester ip address: 141.217.23.191
H-54018	8/27/2015			Urgent please!! cannot turn off the water properly in the bathroom sink. I cannot leave the house pls fix this problem. Thanks!authenticated user: Ayse Karaca - ek6995requester ip address: 35.16.69.170
H-54012	8/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-54013	8/27/2015			Mechanical checkauthenticated user: Ashley Fry - ej8471requester ip address: 141.217.23.210
H-54079	8/27/2015			Outlet in bathroom is bad. Air filter needs to be clean. authenticated user: Garrett Sears - fh9529 requester ip address: 141.217.23.218
H-54155	8/28/2015			Heating/Air Conditioning unit will switch into circulating hot air despite being set in air conditioning mode and above the threshold temperature set by the thermostat.authenticated user: Felix Shun - fz1066requester ip address: 35.16.231.215
H-54030	8/28/2015			Garbage disposal in the sink has stopped working.authenticated user: Joseph Dedvukaj - ez7227requester ip address: 35.16.71.27
H-54156	8/28/2015			Thermostat is broken. authenticated user: Grace Albers - el3882requester ip address: 141.217.224.213
H-54126	8/28/2015			This pertains to the sink by the toilet room. The metal ring inside of the sink is missing a piece.authenticated user: Dominique Witherspoon - ev6822requester ip address: 35.16.103.74
H-54124	8/28/2015			1018- Please check the thermostat because it seems not to be working. (Particularly the A/C) authenticated user: Kajun Lloyd - cq4472requester ip address: 35.16.99.155
H-54212	8/28/2015			Front small shower does not have hot waterauthenticated user: Kayla Balfour - ey3154requester ip address: 66.87.115.9
H-54219	8/28/2015			Toilet tank overflowing water when flushed. authenticated user: Atika Singh - ez6430requester ip address: 146.9.59.15
H-54230	8/28/2015			One of the outlets in the living room is cracked and it most likely needs to be replaced. I'm afraid to stick any plugs in it. Thank you. authenticated user: Joseph Clawson - fg9595requester ip address: 35.16.73.168
H-54236	8/28/2015			Bedroom 1 has no airflow through the ventauthenticated user: Christian Oliver Avila - ez7149requester ip address: 141.217.59.51
H-54237	8/28/2015			Bathroom 2 exhaust is blockedauthenticated user: Christian Oliver Avila - ez7149requester ip address: 141.217.59.51
H-54157	8/28/2015			Thermostat broken- please fix asapauthenticated user: Emily Borden - fi4178requester ip address: 35.16.228.254
H-54162	8/29/2015			The water takes long to go down the drain in the sink of the bathroom.authenticated user: Faith Basheer - fp3620requester ip address: 98.209.91.204
H-54215	8/29/2015			The sink in the kitchen is leaking. authenticated user: Dreana Williams - fi2266requester ip address: 141.217.59.50
H-54239	8/29/2015			Kitchen sink hot water. The hot water supply from kitchen sink is off. Please fix it as early as possible.authenticated user: Kaushik Innamuri - fr6209requester ip address: 141.217.221.248
H-54144	8/29/2015			Broken air conditioner. authenticated user: Kayla Dekoekkoek - fq8414 requester ip address: 141.217.23.218

WO	Recieved	Finished	Total	Request
H-54147	8/29/2015			when toilet is flushed, leaks from handle authenticated user: Rheana Allen - fh1699 requester ip address: 141.217.23.187
H-54136	8/29/2015			Toilet is leaking. Need urgent treatmentauthenticated user: Naman Chopra - fq7231 requester ip address: 141.217.23.210
H-54165	8/29/2015			sink leaks. authenticated user: Jasmynn Brown - fk4951 requester ip address: 141.217.23.242
H-54138	8/29/2015			needs a mechanical check authenticated user: Manaswini Remidi - fs2524 requester ip address: 141.217.23.210
H-54158	8/29/2015			The AC is still not working after several people have come to work on it.authenticated user: Bianca Dean - fo1867 requester ip address: 141.217.225.248
H-54160	8/30/2015			Vent needs to be changedauthenticated user: Rajveer Mand - fv7526 requester ip address: 35.16.102.38
H-54154	8/30/2015			Air conditioning is busted. Please send help. Dying from heatauthenticated user: Brianna Wetherington - fv2600 requester ip address: 35.16.226.176
H-54224	8/30/2015			The exhaust is not functioning properlyauthenticated user: Sai Teja Ghanta - fx2452 requester ip address: 172.56.10.27
H-54170	8/30/2015			thermostate is not working. Our room is 80 degrees right now since we move in.authenticated user: Fabricio Rubens Coimbra Vilarinho - fx6417 requester ip address: 141.217.224.189
H-54168	8/30/2015			ENGINEERING: Replace the fan capacitor/motor within the HVAC unit. Fan is not running.authenticated user: Prentis Gipson - bq7019 requester ip address: 141.217.23.197
H-54172	8/30/2015			Towers - front desk break room condensation leak from ceiling.
H-54183	8/30/2015			The air conditioning will not go below 70 degrees, is it possible to bring it lower to around 60?authenticated user: Blake Freund - fh3685 requester ip address: 141.217.225.237
E - Command Center			24	
FO-323436	8/3/2015	8/5/2015		REFRIG CREW please r/r "portable AC" serving 2nd floor lobby at beecher. tank fills with condensation and shuts off compressor. pump replaced last year. same unit worked on recently. unit works well if tank is drained.
FO-323590	8/4/2015	8/5/2015		COMMAND CENTER, TEC ADDRESS M3AF24 IS SHARING ANOTHER ADDRESS, PLEASE CORRECT. PRIORITY- LOW
FO-323593	8/4/2015	8/5/2015		COMMAND CENTER, PLEASE CHANGE TEC UNITS TO FAHRENHEIT. PRIORITY-LOW
FO-323781	8/5/2015	8/6/2015		R/R RM 00054/MECH RM Investigate why 5 tec's are not wired to the network and repair.
FO-323807	8/6/2015	8/10/2015		COMMAND CENTER, R/R 3RD FLR STRWL A-PLEASE REPLACE BAD RETURN AIR SENSER ON STAIRWELL FFC UNIT. (M3CF21) 3RD FLOOR STAIRWELL- A. PRIORITY-LOW
FO-323955	8/7/2015			Please load program in industrial cooler so that it can be operated in automatic. Currently the CT is being run manually.
FO-323965	8/7/2015			Please move thermostat from second floor to first floor in the space that the only occupant is located. Also set up program on all four RTU's so they are running when heating or cooling but fan is off when not calling for either.
FO-323970	8/8/2015	8/11/2015		Reprogram energy recovery system, (ERS) settings to cool incoming air when OAT is >77 degrees at Mott. Also provide description of operation/settings on screen. Any questions, contact Ed Nisnevich.
FO-324163	8/12/2015			A/C Controls, R/R PENTHOUSE please add graphics in Insight for exhaust fans 1-5.
FO-324164	8/12/2015		8/12/2015	A/C Controls, R/R PENTHOUSE EXF-002 please add graphics in Insight for exhaust fans 1-5.
FO-324165	8/12/2015		8/12/2015	A/C Controls, R/R PENTHOUSE EXF-003 please add graphics in Insight for exhaust fans 1-5.
FO-324166	8/12/2015		8/12/2015	A/C Controls, R/R PENTHOUSE EXF-004 please add graphics in Insight for exhaust fans 1-5.
FO-324167	8/12/2015		8/12/2015	A/C Controls, R/R PENTHOUSE EXF-005 please add graphics in Insight for exhaust fans 1-5.

WO	Recieved	Finished	Total	Request
FO-324217	8/12/2015	8/13/2015		BAS crew. Please trouble shoot chilled water valve controller for UV - 9 in room 403. it does not modulate. Priority: med 8/12/15 lps: Eq not avail in TMA Sys
FO-324259	8/12/2015			Controls. R/R 3RD FLR Make changes to floor plan on graphics to reflect changes.
FO-324408	8/14/2015	8/17/2015		CONTROLS- please replace broken conduit going to electrical box for ALWCO Boiler #2 5425 Woodward. (right now electrical is disconnected b/c probes are pulled for inspection.) if box is replaced please mark corners 1-4 so probes can be properly replaced.
FO-324474	8/17/2015	8/25/2015		BAS section: Please replace failed pxcm field panel, restore BLN, install VAEM license, and troubleshoot/correct building automation issues.
FO-324774	8/18/2015	8/31/2015		CONTROLS ATT LLOYD/TONY- R/R RM 324 please investigate cooling problem rm. 324. suspect problem with secondary refrigerant flow or isolation valve. No cooling in room.
FO-324810	8/19/2015	8/19/2015		BAS section: please set up trend collection/report for Mott mechanical on DDC. Data is for Mike Lenahan. Low priority.
FO-325231	8/24/2015	8/26/2015		COMMAND CTR, R/R RM 00347/MECH RM PLEASE MODIFY CHILLER REQUIRED PROGRAM, TWO CHILLERS ARE NOT NEEDED TO RUN AT LOW OUTSIDE AIR TEMPS. PRIORITY-LOW
FO-325461	8/26/2015			COMMAND CTR, R/R RM 00021/MECH RM AHU# 1 CANNOT ACHIEVE THEIR DISCHARGE AIR SETPOINTS OF 60 DEG ON LOW LOAD DAYS WITH THE CHILLER IN SERVICE. PLEASE CORRECT. PRIORITY-LOW.
FO-325463	8/26/2015			COMMAND CTR, R/R RM 00021/MECH RM AHU# 2 CANNOT ACHIEVE THEIR DISCHARGE AIR SETPOINTS OF 60 DEG ON LOW LOAD DAYS WITH THE CHILLER IN SERVICE. PLEASE CORRECT. PRIORITY-LOW.
FO-325609	8/28/2015	8/28/2015		Dryer for Lab air compressor leaking air.
FO-325624	8/28/2015			REFRIG CREW please replace missing knob on window ac room 109 at Beecher House. The knob is on a FEDDERS model #A3J12E2AG. part#OEM Part - Manufacturer #111404290023
E - MedPharm			13	
FO-323475	8/3/2015			Engineeer- low priority- replace leaking seal on medical air compressor.
FO-323758	8/5/2015	8/6/2015		Room is cold
FO-324228	8/12/2015	8/13/2015		Please change the air filter
FO-324229	8/12/2015	8/14/2015		Please change the air filter. and turn the temprature to ~72 F (22 C)
FO-324256	8/12/2015	8/12/2015		RM 205 SINK IS LKNG FROM UNDERNEATH THE ATTACHMENT FOR HOT WATER IS
FO-324470	8/17/2015	8/18/2015		filter in ceiling needs to be changed
FO-324715	8/18/2015	8/18/2015		Change air filters in animal rooms 411, 412, 413, 414, 415, 416, 417, 419, 423
FO-324807	8/18/2015			In suite 2190 - the kitchen area's power is working on the left side only.
FO-324941	8/19/2015	8/19/2015		Room whistles when door is closed
FO-324948	8/19/2015	8/19/2015		Thermostat is hanging off the wall with wires exposed. Needs to be replaced. Thank you, Susan
FO-325037	8/20/2015	8/21/2015		RM 0519 TEMP NEEDS RESETTNG SHOULD BE BTWN 74-82degrees
FO-325605	8/28/2015			FUME HOOD IS NOT RUNNING. ROOM 9304.
FO-325613	8/28/2015	8/31/2015		leaky hose in lab
E - North			8	
FO-323854	8/6/2015	8/6/2015		RM 3291 IS TOO COLD/COLD AIR BLOWING OUT CLNG VENT WOULD LIKE VENT TO BE SHUT OFF
FO-324180	8/12/2015	8/20/2015		RM 113/WOMENS RR 2ND STALL TOILET SEAT NEEDS TO BE TIGHTEN UP IS LOOSE
FO-324335	8/13/2015	8/13/2015		It's very cold in this suite. We are wearing sweaters, sweatshirts, and jackets. Could we please have the temperature adjusted? Thank you!
FO-324778	8/18/2015	8/21/2015		We would like to have the all the plastic sleeves removed from the Law School main doors, facing Palmer St.(Glass Breezeway) Please note that this includes removing the sticky glue too.

WO	Recieved	Finished	Total	Request
FO-324969	8/19/2015	8/19/2015		Purdy Library 4th Floor Handicap Restroom Air Handling/Ventilation problem in handicap restroom: warm, stuffy and humid. Please correct. Thank you.
FO-325165	8/21/2015	8/21/2015		Afternoon Engineer: R/R RM 3133/MECH RM Please replace drive belts on AHU-1. High priority.
FO-325238	8/24/2015	8/24/2015		Very cold in office. Please send someone to adjust temperature. Thank you.
FO-325474	8/26/2015	8/27/2015		Thermostat was broken. It was set to 75 but the temp was well above 95 degrees Fahrenheit; it was noticeably sweltering when I walked in. Noticed this yesterday when I was checking out the classrooms that I would be teaching in.
E - Northeast			8	
FO-323437	8/3/2015			Knob for turning AC unit on and off is missing. Please install a new knob.
FO-323448	8/3/2015	8/3/2015		Emergency exit door alarm keeps going off without being disturbed. Door exits into parking lot.
FO-323616	8/4/2015	8/4/2015		Please reduce the air conditioning on the 1st floor.
FO-323755	8/5/2015	8/19/2015		Room 330 Dr. Frade has a puddle of water on his rug in front of his door from Sunday's rain.
FO-324296	8/13/2015	8/17/2015		Loud vibration noise from AC unit in the room. Please investigate and make necessary repairs.
FO-325002	8/20/2015	8/20/2015		A/C is not cooling building. Many zone temperatures are 73 or above. Room 133 in dispatch is running well over 74 degrees if we leave our backup/emergency air conditioning running. (Should only be used if main is down) Dispatch Room needs to be abo
FO-325014	8/20/2015	8/20/2015		4TH FLR MENS RR BY ELEV CK PARTITION BTWN URINALS
FO-325034	8/20/2015	8/20/2015		ASSIST AT&T. MEET IN LOBBY.
E - Preventative Maintenance			17	
FO-323627	8/4/2015	8/7/2015		Belt Order: 4L320 QTY: 2 A43 QTY: 2 AX42 QTY: 8 3L230 QTY: 4 A40 QTY: 2
FO-323628	8/4/2015	8/7/2015		Belt Order: 4L200 QTY: 4
FO-323804	8/6/2015			Roll Filter Media for Life Science heat recovery coils. Blue/White Media 96"x90"x1 \$186/roll
FO-323898	8/7/2015			Filter Order - Boiler Combustion Air Unit Filters 20x24x2 Qty: 12 20x16x2 Qty: 4 12x24x2 Qty: 6
FO-323962	8/7/2015	8/7/2015		STUDENT ACCIDENTLY HIT THE EMERGENCY BUTTON ON ELEV #2 ALARM IS ACTIVE
FO-324519	8/17/2015	8/18/2015		Breaker is tripped for the oven that is in the fume hood.
FO-324790	8/18/2015	8/19/2015		RM 160 SOMEONE LOCKED DOOR FROM INSIDE CLASS RM NEED TO OPEN
FO-325082	8/20/2015	8/21/2015		heating/cooling unit is leaking
FO-325092	8/20/2015	8/20/2015		call DTE Kenny Miller 313-354-6058
FO-325271	8/24/2015	8/25/2015		Room 1551 in the EDC. The exhaust fan is not working properly. Back pressure is building up and it is damaging the engine. We need Rocky to look at immediately. Please contact Kamal at 313-424-2562. Thank you.
FO-325274	8/24/2015	8/25/2015		HVAC unit blowing only hot air. Please check for cooling.

WO	Recieved	Finished	Total	Request
FO-325275	8/24/2015	8/24/2015		Afternoon shift: A53 Qty: 3
FO-325283	8/24/2015	8/25/2015		Toilet in Women's restroom will not flush.
FO-325284	8/24/2015	8/24/2015		2nd floor Ladies restroom - someone has stuffed the 2nd stall's toilet full of tissue. I didn't want to flush it in case it would overflow.
FO-325336	8/25/2015			Filter Order - PRB RTU 20x24x2 Qty: 12
FO-325390	8/25/2015	8/29/2015		ASSIST AT&T WITH ACCESS TO TELECOMMUNICATION ROOM. 1ST FLOOR.
FO-325482	8/26/2015	8/26/2015		Please check for a leak because there are water spots on the ceiling. Michelle
E - South			12	
FO-323442	8/3/2015	8/3/2015		Need to have Rocky look at the Sr. Business Affairs Office it is very hot. Seems like ac not going to office. Her office is 1150. Thank you.
FO-324016	8/10/2015	8/10/2015		Building is under major positive pressure. Exterior doors will not close since inside air is blowing them open.
FO-324018	8/10/2015	8/10/2015		RM 1100 IS TOO COLD
FO-324019	8/10/2015	8/10/2015		RM 3100 IS TOO COLD
FO-324022	8/10/2015	8/10/2015		It's sweltering, our humidity reading is 73% can you please adjust the temperature in suite 3305.
FO-324107	8/11/2015			Purdy Library 2nd Floor North east corner - lights off, switches not working. Please repair. Thank you.
FO-324721	8/18/2015	8/18/2015		Air conditioner in kitchen not blowing out cold air
FO-324736	8/18/2015	8/18/2015		Breaker is tripped for the oven that is in the fume hood.
FO-325009	8/20/2015	8/20/2015		Overhead Light not coming on and power on right side of office not working.
FO-325245	8/24/2015	8/24/2015		The steam pipes are banging very loudly in our office area.
FO-325447	8/26/2015	8/31/2015		UGL Collaborative Study Room 2540: metal round disk that covers pipe opening in floor under one chair is off to the side of the room, needs repair or replacement.
FO-325621	8/28/2015	8/31/2015		The Fume hoods are alarming in 3540,3543,3546,and 3556 EDC. There is not enough airflow. The room temperatures are also higher than normal.
E - Southeast			2	
FO-324332	8/13/2015	8/13/2015		No air circulation in office. Please reset HVAC system.
FO-325437	8/26/2015	8/26/2015		N. MAIN ELEV CLOSES TO WOODWARD NEED ELEV #
E - West			5	
FO-324133	8/11/2015	8/21/2015		Ceiling leak @ Softball Building...1st office on the left...Please see Bob Ostrowski on specs. Thank You. Bob Ostrowski
FO-324157	8/12/2015	8/13/2015		Exhaust fan EF4 is not operational in Electrical room. Please repair. Clean protective screen around exhaust fan. Also clean intake louver at other end of electrical room. Temperature is vey hot in this room.
FO-324773	8/18/2015	8/21/2015		Acidic condensate is dripping from the ceiling. pH of the condensate is close to 1.0, very acidic.
FO-324787	8/18/2015	8/21/2015		RM 160 SOMEONE LOCKED DOOR FROM INSIDE CLASS RM NEED TO OPEN
FO-325335	8/25/2015	8/28/2015		Midnight-shift officers state that the building's air pressure keeps multiple doors ajar at night.
Grounds			11	
Medium			3	
G - Moving/Storage			1	
FO-324981	8/19/2015	8/22/2015		Per e-mail from Jeff Block dated 8-17-15, he is requesting that Grounds assist with the Baroudeur bike ride on Saturday, August 22, 2015. Delive 15 - 20 outdoor garbage cans to the front of the Undergraduate Library on Friday 8/21/15 morning. (Bring som

WO	Recieved	Finished	Total	Request
G - Physical Grounds			2	
FO-323418	8/1/2015	8/7/2015		<p>GROUNDS</p> <p>REPLACE MISSIING PAVER BRICKS AT MAIN ENTRANCE.</p> <p>TRIP HAZZARD HIGH PRIORITY</p>
FO-325124	8/20/2015	8/25/2015		Keast Commons. Sod needed in areas discussed with Carla Crawford on 8/20/15. I will be emailing her and Mark Allen a map that shows exact locations. Work to be completed on Monday, August 24 or Tuesday, August 25. Has to be complete by move in d
Low			8	
G - Moving/Storage			4	
FO-325282	8/5/2015	8/28/2015		Set-up 11 round tables with 80 chairs and a couple of long tables set up for the food (buffet style) for preceptor breakfast for Thursday, August 27. The event starts at 7:30 am so the setup will need to happen on Wednesday, August 26th. Myron Harper 08
FO-320569	8/6/2015	8/28/2015		The University is having all student copiers around campus replaced with a new fleet. We need grounds to move all old copiers from various locations around campus including off campus to Holden (property office). The deployment of the new fleet starts
FO-324063	8/10/2015	8/31/2015		Need two grounds employees to work on Saturday, August 29 from 7:00 a.m. until 4:00 p.m. and Sunday, August 30 from 9:00 a.m. until 5:00 p.m. Index to charge is 228101. Employees will report to Pat Erne on these days. Pat's cell number is 586-89
FO-325330	8/25/2015	8/31/2015		Just Do It. Per Carla Crawford, Assign the following grounds keepers for coverage of the 2015 Prep Kickoff Classic. Thursday, 8/27/15 (3 Grounds keepers from 3 pm - 9 pm); Friday, 8/28/15 (3 Grounds keepers from 3 pm - 9 pm); Saturday, 8/29/15 (6 Grounds
G - Physical Grounds			4	
FO-323757	8/5/2015	8/7/2015		<p>Grounds:</p> <p>R/R BLDG please cut and trim tree branches over hanging the roof of State Hall building on both north and south sides causing to constantly plugging up roof drains and damaging the roof. Priority: med.</p>
FO-323864	8/6/2015	8/7/2015		THIRD REQUEST. Previous requests are number 268108 and 267524. The recycling dumpster outside the building on the John C. Lodge service drive is sitting on the sidewalk and not on the grassy area where it used to be. Whoever empties the dumpster has been
FO-324286	8/13/2015	8/13/2015		The asphalt walkway has numerous potholes stretching from in front of the Multi Purpose Bldg / Tennis Courts and Baseball diamond
FO-324288	8/13/2015	8/13/2015		St Andrews Hall - driveway leading up to bldg from the John Lodge Service Drive has several potholes that need to be filled.
Trades			901	
Emergency			54	
T - Carpenter			14	
FO-323742	8/5/2015	8/6/2015		Carpenters please remove ceiling tiles and grid for pipe repair access, see Eric A.....CEILING PIPE LEAK. (HERMAN NELSON) ROOM 59.....EA.....8/3/15
FO-323834	8/6/2015	8/6/2015		EMERGENCY CARP R/R RM 133/DLAR INSIDE DOOR KNOB FELL OFF (UNABLE TO OPEN DOOR FROM WITHIN RM
FO-323858	8/6/2015	8/6/2015		EMERGENCY CARP R/R RM 1044 CODE WILL NOT LOCK DOOR
FO-324037	8/10/2015	8/12/2015		OPEN UP TO CARPENTERS PLUMBERS NEED WALL OPENED UP FOR ACCES TO PIPES..... Investigate a location for an isolation valve in city main, leading to basement.....MP....8-10-15....this has turned into an emergency, Rick Massa has bee
FO-324123	8/11/2015	8/11/2015		EMERGENCY CARP R/R INNER HANDICAP DOOR TO DOOR #603-10N IS RATTTLING WHEN OPENNING/CLOSING VERY LOUD AS IF SOMETHING MECHANICALLY IS BROKEN

WO	Recieved	Finished	Total	Request
FO-324124	8/11/2015	8/11/2015		R/R BSMT WOMENS RR (OFF OF ELEV) 2ND STALL DOOR IS HANGING BY THE BOTTOM HINGES ONLY FALLING INWARD *SAFETY ISSUE*
FO-324249	8/12/2015	8/12/2015		EMERGENCY CARP R/R 2ND FLR UNISEX RR (ONLY ONE ON FLR) INSIDE DOOR HANDLE WILL NOT OPEN DOOR FROM INSIDE PEOPLE ARE GETTING STUCK W/IN
FO-324432	8/17/2015	8/17/2015		KEY BROKEN OFF IN DOOR LOCK. ROOM 211.
FO-324433	8/17/2015	8/18/2015		NORTH GARAGE DOOR GOES DOWN THEN GOES BACK UP.
FO-324781	8/18/2015	8/18/2015		EMERGENCY CARP R/R RM 4017 CANNOT UNLOCK DOOR W/KEY
FO-324992	8/19/2015	8/21/2015		Overhead receiving exterior door is not functioning. It is stopped partially open creating an emergency security issue as the room contains expensive equipment and is open to the back parking area.
FO-325011	8/20/2015	8/20/2015		EMERGENCY CARP R/R BLDG ENT OUTER HANDICAP DOORS #060 01W ARE STANDING OPEN
FO-325168	8/21/2015	8/21/2015		EMERGENCY CARP R/R RM 2324/DLAR ANIMAL RM KEY BROKEN OFF IN DOOR LOCK CAN OPEN DOOR HOWEVER UNABLE TO LOCK WILL NEED TO LOCK UP
FO-325585	8/28/2015	8/28/2015		DOOR WILL NOT UNLOCK. ROOM 103.
T - Electrician			24	
FO-323422	8/3/2015	8/11/2015		COOLING TOWER FAN MOTOR WILL NOT RUN. OFFICE WING CHILLER.
FO-323424	8/3/2015	8/3/2015		FIRE ALARM SYSTEM AND PARTIAL SYSTEM DISABLED. PLEASE CHECK. Completed 8-3-2015 SRP
FO-323542	8/3/2015	8/3/2015		Please , check and or restore power to Building due to Eletrical outage if possible. This is for the Eletrical Department.
FO-323717	8/5/2015	8/19/2015		RESET FIRE ALARM PANEL. (MULTI-TASK) Completed 8-19-2015 SRP
FO-323913	8/7/2015	8/7/2015		EMERGENCY ELEC R/R BLDG POWER BUMP BLDG APPR 9AM ONLY 1/2 OF BLDG CAME BACK UP (SOUTH IS STILL DOWN)
FO-323914	8/7/2015	8/7/2015		EMERGENCY ELEC R/R BLDG POWER BUMP BLDG APPR 9AM ONLY 1/2 OF BLDG CAME BACK UP (SOUTH IS STILL DOWN) Completed 8-7-2015 SRP
FO-323944	8/7/2015	8/7/2015		Electrician R/R BSMT inspect and repair why generator did not start the last two power outages. Emergency.
FO-324007	8/10/2015	8/10/2015		EMERGENCY ELEC R/R RM 1131 FAP FIRE TROUBLE ALARM HAS A GROUND FAULT CARD 1
FO-324156	8/12/2015	8/12/2015		EXHAUST FAN #1 NOT RUNNING. PENTHOUSE.
FO-324173	8/12/2015	8/12/2015		#2(NORTH)ELEVATOR LIGHTS ARE OUT.
FO-324310	8/13/2015	8/14/2015		AHU# 5 FAILED START UP WON'T RESTART
FO-324491	8/17/2015	8/17/2015		LIGHT FIXTURE IS SMOKING. ROOM 5364.
FO-324751	8/18/2015			ADDING ELECTRICIAN: Please disconnect Electricity to water heater. HOT WATER TANK LEAKING. BASEMENT NEXT TO MECHANICAL ROOM. CONTACT ENGINEER.....GS.....8/18/15
FO-324989	8/19/2015	8/19/2015		Make safe damaged pole by grounds shed
FO-325159	8/21/2015	8/21/2015		Electrician R/R RM 1102 please troubleshoot main fire panel 1st. floor,trouble lite indicate,card 13,IDNET (250 pts.) IDNET extra device abnormal. 5th fl. nac 10 &11 trigger 2:sig 16 visual , open ckt trouble.FO-325129,it is buzzing/beeping.Priority High
FO-325185	8/24/2015			Cable failure needs immediate repair.

WO	Recieved	Finished	Total	Request
FO-325240	8/24/2015	8/24/2015		R/R RM 5111 WEST SIDE WALL PLUG IS VERY LOOSE CAUSING A SHOCK WHEN OCCUPANTS TRY TO USE IT
FO-325361	8/25/2015	8/28/2015		RM 4300 & 4032 PLEASE CHECK FIXTURES FOR WATER
FO-325435	8/26/2015			**ADDING LABORER: Transport gas welder to Stadium and return by end of shift. See Eric or Corey for assistance **This has to be done today ASAP
				Repair broken gate at football stadium at ticket booth ,,,,,,,,,,,,,,EA/8-26-15 ,,,,,,,,,,,,,,
FO-325552	8/27/2015	8/28/2015		PLEASE REPLACE THREADED BOLT THAT HOLDS MOTOR TOGETHER ON COOLING TOWER. 2ND FLOOR MECHANICAL ROOM. CONTACT ENGINEER FOR DETAILS.
FO-325560	8/27/2015	8/27/2015		SPARKS COMING FROM LIGHT FIXTURE IN ROOM 225.
FO-325576	8/28/2015			AIR COMPRESSOR BLEW ALL FUSES. PENT.
FO-325583	8/28/2015			REPLACE FUSE FOR MAIN AIR COMPRESSOR. MECHANICAL ROOM.
FO-325620	8/28/2015	8/28/2015		POWER OUT IN THE CONCESSION STAND.
T - Pipefitter			7	
FO-323704	8/5/2015	8/5/2015		EMERGENCY PIPE R/R RM 0425/MECH RM BFP #2 PIPE NIPPLE ON PUMP SPRUNG A LEAK ,,,,,,,,,,,,,, JH/8-5-15 ,,,,,,,,,,,,,,
FO-323897	8/7/2015	8/7/2015		EMERGENCY PIPE R/R RM 0604/MECH BLR RM BACKFLOW PREVENTER FAILED ON CITY MAKE-UP LINE.....DB.....8-7-15
FO-324829	8/19/2015	8/19/2015		BSMNT LAB AIR COMPRESSOR, AIRLINE LEAK.....CB.....8/19/15
FO-324958	8/19/2015	8/19/2015		CEILING LEAK. ROOM 0145.....EA.....8/19/15
FO-324980	8/19/2015	8/20/2015		FAN #1 CONDENSATE DRAIN PLUGGED WATER LEAKING.....ME.....8/19/15
FO-325218	8/24/2015			EMERGENCY ELEC R/R RM 00119/MECH RM EMERGENCY GENERATOR FUEL TRANSFER PUMP NEEDS REPLACING ITS NOT PUMPING. Electricians turned over to Pipefitter ,,,,,,,,,,,,,, JH/8-24-15 ,,,,,,,,,,,,,,
FO-325433	8/26/2015	8/26/2015		Repair broken gate at football stadium at ticket booth ,,,,,,,,,,,,,,EA/8-26-15 ,,,,,,,,,,,,,,
T - Plumber			9	
FO-323820	8/6/2015	8/6/2015		1ST FL LADIES RM ALL (4)SINKS ARE PLUGGED AND HAVE STANDING WATER IN SINKS.....DB/TT....8-5-15
FO-324188	8/12/2015	8/12/2015		FLOOD IN BASEMENT. UNKNOW WHERE WATER IS COMING AND IS GETTIN DEEPER FROM.....DB/TT.....8-12-15
FO-324231	8/12/2015	8/13/2015		MENS RM 154 URINAL CONTINUOUSLY FLUSHING AND OVERFLOWING....MM.....8-12-15
FO-324713	8/18/2015	8/18/2015		**DUPLICATE REFER TO FO#324713 HOT WATER TANK LEAKING. BASEMENT NEXT TO MECHANICAL ROOM. CONTACT ENGINEER.....GS.....8/18/15
FO-324818	8/19/2015	8/19/2015		SNAKE OUT DRAIN IN FRONT OF AIR HANDLER UNIT #3. PENTHOUSE. (CONTACT ENGINEER FOR MORE DETAILS).....MM....8/19/15
FO-324982	8/19/2015	8/20/2015		1ST FL WATER FOUNTAIN SHOOTING WATER.....GS.....8/19/15
FO-325061	8/20/2015			NO HOT WATER IN BUILDING.....MP.....8/20/15
FO-325083	8/20/2015	8/20/2015		Adding Pipefitters: Please check steam control valve to domestic hot water heat exchanger....CB....8/20/15 NO HOT WATER IN BUILDING.....MP.....8/20/15
FO-325470	8/26/2015	8/26/2015		EMERGENCY PLUM R/R RM 5344 NEED A 1/2" CLAMP FOR 1/2" COPPER LINE IN CLNG CAUSED A MAJOR CLNG LEAK CAUSING CLNG TILES TO FALL WTR POURING IN (WTR HAS BEEN SLIGHTLY ISOLATED) ,,,,,,,,,,,,,, GS/8-26-15 ,,,,,,,,,,,,,,
High			223	
T - Carpenter			63	

WO	Recieved	Finished	Total	Request
FO-323411	8/3/2015	8/5/2015		Adding Carpenter** Need wall access in basement hallway, south end of building. See Mike Pummill for location.....
				BSMNT SOUTH WOMENS RM (3) SINKS PLUGGED ,,,,,,,,,,,,,, MP/7-29-15 ,,,,,,,,,,,,,,
FO-323441	8/3/2015	8/3/2015		Tonya Jones 08/03/2015 12:57 - Extract broken key from desk drawer. action: Employee is locked out her broken desk drawer, needs a carpenter to come over and open drawer. ASAP!
FO-323456	8/3/2015	8/3/2015		Lock on door is hard to get key into and also to open. Key hard to get into lock and when it is finally in core is hard to turn.
FO-323543	8/4/2015	8/5/2015		Please repair door 2 south at the Elliman building , it will not secure when closed. This is for the carpenter Department.
FO-323611	8/4/2015	8/5/2015		please have ed the carpenter replace ceiling tile in 9105. the tile is dark brown and collapsing to the floor. high opriority.
FO-323733	8/5/2015	8/5/2015		WON DOOR IS BEEPING
FO-323780	8/5/2015	8/6/2015		RM 2105 HAS A SET OF DOUBLE DOORS THEY'RE UNABLE TO OPEN OTHER DOUBLE DOOR SO THE TANK CAN BE BROUGHT IN
FO-323809	8/6/2015	8/7/2015		EAST ENTRY DOORS NOT CLOSING PROPERLY
FO-323837	8/6/2015	8/7/2015		The hand rail outside of the Building is hanging off needs too repair it on the left side.
FO-323909	8/7/2015	8/7/2015		Secure exterior Panel Between 1st and 2nd flr South side of bld. near the east end
FO-323950	8/7/2015	8/10/2015		3RD FL STAIRWELL K DOOR HANDLE BROKEN OFF
FO-323957	8/7/2015	8/10/2015		RM 12001 DOOR LOCK DOESN'T LATCH
FO-324003	8/10/2015	8/11/2015		5TH FL DOOR HANDLE BROKEN, DOOR NEAREST FREIGHT ELEV
FO-324012	8/10/2015	8/11/2015		Carpenter R/R LOBBY INNER DOOR TO DOOR 608-03n,02n,& o1n please make nessasary adjustment to Lobby door interior doors are not closing properly when locked at 8:00 PM,students enter and door takes too long to close.(FO-323986)priority High ,608-03n,02n,
FO-324017	8/10/2015	8/28/2015		RECEIVING DOOR, KEY WON'T DISARM THE DOOR
FO-324066	8/10/2015	8/11/2015		RM 0235 DOOR LATCH BROKEN
FO-324098	8/11/2015	8/19/2015		Electricians need the wood replaced for the base of the light fixture to mount to. If needed Paul Prouty can show them the area it's needed at.
FO-324102	8/11/2015	8/12/2015		R/R RM 2119 UNABLE TO UNLOCK ENTRY DOOR LOCK
FO-324111	8/11/2015	8/13/2015		Electrician; Medium Please repair the Building Clock located outside the Woodward Entrance. The clock is not running. OPEN TO LABORER: Wednesday 8/12/2015 7AM: Build scaffold at Woodward Entrance so Electricians can repair clock, it may nee
FO-324122	8/11/2015	8/12/2015		MENS RM 1ST FL DOOR HANGING OFF HINGE TO STALL DOOR
FO-324155	8/12/2015	8/13/2015		Please repair brown box at the West entrance. Lock is not securing the box.
FO-324209	8/12/2015	8/13/2015		Rm. 162 - Something has broken off inside the lock on the door.
FO-324218	8/12/2015			RM 0210 CEILING TILES MISSING (3)
FO-324264	8/12/2015	8/28/2015		OPEN UP TO CARPENTERS..PLEASE REPAIR WALL IN HALLWAY THAT WAS OPENED UP FOR PLUMBERS.....BSMNT SOUTH WOMENS RM (3) SINKS PLUGGED ,,,,,,,,,,,,,, DB/7-29-15 ,,,,,,,,,,,,,,gave to Don and Troy on 8-11-15
FO-324269	8/12/2015			RM 3207 CEILING TILES NEED REPLACING ASAP, LEAK WAS FIXED MONTHS AGO
FO-324307	8/13/2015	8/13/2015		Remove sign post in median of Palmer between Anthony Wayne Drive and Cass Av.. See e-mail for pictures of location.
FO-324317	8/13/2015	8/14/2015		Purdy Library 2nd Floor, Room 242 Door will not stay locked. Security concern: room contains expensive computer equipment. Please repair. (Multi-task) Thank you.
FO-324338	8/13/2015	8/18/2015		Assemble large desk for Supervisor Carla Crawford

WO	Recieved	Finished	Total	Request
FO-324347	8/13/2015	8/14/2015		lock for door to 242 Purdy is hard to operate. occupant, Elliot Polak, has trouble using.
FO-324384	8/14/2015	8/17/2015		Please have electricians check exhaust fan motor in the trash pit area off the loading dock. fan is out of service OPEN TO CARPENTERS: Electricians need a scaffold built under the exhaust fan in the duct work going outside.
FO-324745	8/14/2015	8/18/2015		We need the large cabinet white board hung back up in the executive conference room of Bill Decatur, on the south west wall ASAP.T
FO-324454	8/17/2015	8/18/2015		FRONT LEFT ENTRANCE DOOR STICKS CAUSING THE DOOR TO GET STUCK OPEN
FO-324488	8/17/2015	8/18/2015		ELEV NEAR WOMENS RESTROOM, CEILING TILE WITHIN ELEV HAS FALLEN
FO-324502	8/17/2015	8/18/2015		Carpenters please repair leaking door closure in NE stairwell 1st floor near rm. 1215,priority high.
FO-324509	8/17/2015	8/18/2015		the exit door in the basement next to room 0133 is propped open and we are unable to close it. All basement exit doors should be locked without access to the basement.
FO-324796	8/18/2015	8/19/2015		R/R 2ND FLR STRWL "A" INSIDE DOOR HANDLE WILL NOT OPEN DOOR (person is able to go up/down to get out of Strwl)
FO-324808	8/18/2015	8/21/2015		door lock occasionally does not open with the key- seems that something inside the door lock is loose and gets in the way occasionally-
FO-324817	8/19/2015	8/20/2015		KEY STICKS IN DOOR LOCK. ROOM 5116.
FO-324945	8/19/2015	8/20/2015		Key lock to the animal room door is hard to turn, when locking the door. Thank you, Susan
FO-324947	8/19/2015	8/27/2015		Fire Extinguisher sitting on floor. Needs to be attached to the wall. Thank you, Susan
FO-324962	8/19/2015	8/20/2015		The handicap button to automatically open the door (18905N) for access into the building is not working from the outside along Cass Ave. Can the battery in the outside switch be changed? Please see Michael in the box office for exact location or more in
FO-324970	8/19/2015	8/20/2015		Purdy Library 4th Floor Room 438 Door difficult to open and close; sticks in frame. Please repair. Thank you.
FO-324972	8/19/2015	8/20/2015		Purdy Library 4th Floor Room 448 Door difficult to open and close: door sticks in frame. Please repair. Thank you.
FO-325022	8/20/2015	8/24/2015		505-Hecker Alumni House (not listed) Please install a wireless doorbell at the back door so it can be heard in Mrs. Wilson's Office on 2nd Floor Door bell is at location by back door on window sill
FO-325015	8/20/2015			CARP R/R 4TH FLR MENS RR BY ELEV PARTITION BTWN URINAL & TOILET STALL IS COMING LOOSE FROM WALL
FO-325031	8/20/2015	8/24/2015		CEILING TILES ARE WET AND SMELLY. OCCUPANT WANTS TILES REMOVED AND NEW TILES REPLACED AFTER LEAK IS REPAIRED. ROOM 4260.
FO-325053	8/20/2015	8/21/2015		HANDICAP DOOR #003-4N IS OPERATING ERRECTACLLY.
FO-325111	8/21/2015	8/24/2015		SOMETHING IS BROKEN OFF IN DOOR LOCK AT 100 ANTOINETTE. (KEY WON'T GO INTO DOOR LOCK)
FO-325131	8/21/2015			Adding Carpenters: Please Remove Wood Lattice in ceiling to access plumbing Located in basement next to room 10 See Gerry Simancas One of the Drinking water fountains is Out of Order since May 2015. Can this be fixed now? The asbestos removal from
FO-325152	8/21/2015	8/24/2015		In Office/Suite 313, the "back door" will not close all the way and latch when someone goes thru it. It's is located right next to the filing room 313.5. This is a secure area and the "back door" needs to be able to close and latch tightly at all times.
FO-325236	8/24/2015	8/25/2015		Remove scaffold ASAP in 1st floor mens bathroom so bathroom can be cleaned and reopened **Please try to remove Monday 8/24/15 if possible. **Let Don Bear know when scaffold has been broke down
FO-325302	8/25/2015	8/26/2015		KEY STICKS IN DOOR LOCKS. ROOMS 216 AND 216.2.
FO-325331	8/25/2015	8/26/2015		Keys are getting stuck in door lock of room 312.

WO	Recieved	Finished	Total	Request
FO-325344	8/25/2015	8/26/2015		DOOR # W155-16, DOOR WON'T CLOSE PROPERLY ALSO MAKES A LOUD SQUEAKING NOISE
FO-325363	8/25/2015			ADDING CARPENTERS, PLEASE REPLACE DAMAGED/STAINED CEILING TILES IN ROOMS 1316,1318,1320..THANKS.....RM 1316 ACTIVE CEILING LEAK ,,,,,,,,,,,,,, ME/8-24-15 ,,,,,,,,,,,,,,
FO-325381	8/25/2015	8/26/2015		The door jam in practice room 4225 is loose. This is a swipe card access room, but the door can be pushed open without swiping in.
FO-325432	8/26/2015	8/28/2015		The room number is actually 3551, but that wasn't on this list of room numbers. The door lock for 3551 is sticking again and the door will not completely shut and lock. It was repaired in the last year, but it needs to be fixed again.
FO-325444	8/26/2015	8/27/2015		Purdy Library 2nd Floor Room 238 Door sticking; difficult to open and close. Please repair. Thank you.
FO-325451	8/26/2015	8/27/2015		Trade: CarpentersPriority: HighPlease repair NE (3) basement stairwell door (near lab 50.1). Door will not open from inside the stairway to the hall.
FO-325473	8/26/2015	8/27/2015		R/R BLDG ENTRY Door 001-04E intermittently fails to lock. Concealed latch assys may be binding.
FO-325490	8/26/2015	8/27/2015		LAB 5324 INSIDE DOOR HANDLE LOOSE
FO-325543	8/27/2015	8/28/2015		Door does not close all the way automatically to 3North faculty suite. The door sits ajar.
FO-325633	8/28/2015			WEST WING 6TH FLOOR LEFT HANDLE DOOR IS MISSING A SCREW ON THE SILVER PLATE. CAUSING DOOR HARD TO CLOSE.
T - Electrician			55	
FO-323428	8/3/2015	8/3/2015		Reset Clocks in Building, clocks lost time due to Power Outage Sunday. Completed 8-3-2015 SRP
FO-323433	8/3/2015	8/3/2015		RM 329 LOW BATTERY ON ALARM Completed 8-3-2015 SRP
FO-323548	8/4/2015	8/5/2015		LABORER, PLEASE DELIVER A 30 GAL BARREL OF LOKOR 2000M-P (17010060) F0-297751. PRIORITY-HIGH
FO-323633	8/4/2015	8/5/2015		In receptionist area on 2nd floor, ceiling light is beeping every 3 seconds.
FO-323683	8/4/2015	8/5/2015		Please repair the dusk to dawn lights on the North side of the building, behind London Luggage bldg. Staffers coming in at midnight have said that they are out.
FO-323708	8/5/2015	8/6/2015		The light above the desk in 2410.1 is burned out on one side and flickering on the other. Please repair between the hours of 8:30am and 10:00pm. Thanks in advance, Andy
FO-323716	8/5/2015	8/6/2015		AHU will not run, power bump 8-4-15
FO-323791	8/5/2015	8/10/2015		**ADDING LABORER: Transport new hot water heater from Pipe Shop to basement of Bio-Engineering. Also remove old hot water heater and debris when Plumbers are complete See Mike Pummill for assistance if needed High, Please replace hot water tank in
FO-323904	8/7/2015	8/11/2015		ELECTRICIANS (HIGH) R/R RM 402 CONTROL PANEL FOR CHILLER #1 CONDENSER PUMPS 1 AND 2 ARE TO SMALL. THIS HAS BEEN CAUSING OPERATIONAL ISSUES WTH THE PUMPS. PLEASE INVESTIGATE AND REWIRE PANELS OR INSTALL LARGER CONTROL BOXES. SEE ENGINEER 8/7/15 lps: S
FO-323905	8/7/2015	8/11/2015		ELECTRICIANS (HIGH) R/R RM 402 CONTROL PANEL FOR CHILLER #1 CONDENSER PUMPS 1 AND 2 ARE TO SMALL. THIS HAS BEEN CAUSING OPERATIONAL ISSUES WTH THE PUMPS. PLEASE INVESTIGATE AND REWIRE PANELS OR INSTALL LARGER CONTROL BOXES. SEE ENGINEER 8/7/15 lps: S
FO-323954	8/7/2015	8/7/2015		Time to repair Heat Synch on Generator #1, which is preventing it from producing AC Current.

WO	Recieved	Finished	Total	Request
FO-323972	8/8/2015	8/7/2015		Dining Rm. light has went out, and need to be replaced in the Presidents Apartment.
FO-323980	8/9/2015	8/10/2015		ELECTRICIANS: R/R LOBBY AREA PLEASE CHECK TROUBLE ALARM ON FIRE ALARM SYSTEM, RM. 0327 NAC2 BATTERY FAULT, PRIORITY (HIGH)
FO-324011	8/10/2015	8/10/2015		The closet light in the President's Apartment has a light out in it. There is 1 electrical problem.
FO-324023	8/10/2015	8/10/2015		elect. replace GFI in conference room and kitchen priority high
FO-324083	8/11/2015			Fire alarm trouble.Trouble alarm cannot be cleared.
FO-324101	8/11/2015	8/12/2015		RM 32 CIRCUIT POPS WHEN COMPUTER IS PLUGGED IN SEE MIRABELA FOR FURTHER DETAILS 7-6268
FO-324105	8/11/2015	8/18/2015		R/R RM 00245 BROKEN LIGHT TIMER. Completed 8-18-2015 SRP
FO-324106	8/11/2015	8/11/2015		Purdy Library 2nd Floor North east corner - lights off, switches not working. Please repair. Thank you.
FO-324116	8/11/2015	8/11/2015		Repair the Heat Sync on Generator #2 at Scott Hall.
FO-324248	8/12/2015	8/13/2015		ELECTRICAL DEPT- R/R RM 603/MECH (ELEV RM) ACU-003/RTU PLEASE CHECK PANEL 2B-CIRCUIT BREAKER #4,ROOF TOP UNIT WONT RUN BECAUSE OF SUPECTED BAD 60 AMP BREAKER PRIORITY HIGH
FO-324251	8/12/2015	8/14/2015		Remove Light fixture to provide access to air leak in pneumatic line in ROOM 4300. CONTACT ENGINEER FOR DETAILS.
FO-324265	8/12/2015	8/18/2015		RM 1210 CLOCK NOT WORKING. Completed 8-18-2015 SRP
FO-324271	8/13/2015	8/13/2015		Please , check and or restore power to Building due to Eletrical outage if possible. 8/13/2015 WEDNESDAY: Electricians to come in at 4AM, and work with Utilities Instrumentation Technicians to correct problem with Primary Transfer Switch.
FO-324276	8/13/2015	8/17/2015		R/R RM 1102/OFC please have electricians check fire panel in lobby trouble light. nac-2 battery fault. Completed 8-17-2015 SRP
FO-324290	8/13/2015	8/13/2015		Please have Maintenance Laborer pick up two pallets of softener salt from the Boomer Company (1940 E. Forrest Ave. , Detroit , 48207). Deliver one pallet to Chemistry building , one to the FP&M Stockroom. See Larry Cook/Tim Herr for details.
FO-324333	8/13/2015	8/17/2015		Electricians: R/R RM 00316/MECH RM Sewage ejector pump #11 keeps tripping the power breaker. Please repair. High Priority. Completed 8-17-2015 SRP
FO-324362	8/14/2015	8/14/2015		Hook up Field Lights to generator, Run Generator for 30 minutes with lights on, and note lights not working so we can have them repaired.
FO-324363	8/14/2015	8/19/2015		Electricians: Please repair the fire panel alarm, "Ground fault third floor." Was able to silence the audible alarm. High Priority. Completed 8-19-2015 SRP
FO-324396	8/14/2015	8/17/2015		REQUESTING ELECTRICIANS TO MEET MIKE MACALINDEN IN ROOM 2245 ON MONDAY (8-17-15) AT 8:00 AM TO REMOVE A LIHGH T FIXTURE SO PLUMBER CAN GAIN ACCESS TO PIPE LEAK.....Leak coming from ceiling ,,,,,,,,,,,,,,,*MM/ME/7-29-15 ,,,,,,,,,,,,,,,
FO-324398	8/14/2015			RECEPTION AREA ALARM PANEL ALARMING Completed 8-17-2015 SRP
FO-324483	8/17/2015	8/19/2015		Electricians-please re-locate 460V disconnect for new heat pump installation. Additional material needed. Contact Andy or Gordie. High Priority.
FO-324490	8/17/2015			ELECTRICIANS- please replace blower in room 413 at 5425 woodward. Shaft is frozen. motor is FASCO NO.7164-0388. breaker for unit is far side of hall panel LP-T breaker #9. (off at breaker now.) Room has no AC w/o working blower.

WO	Recieved	Finished	Total	Request
FO-324501	8/17/2015			ELECTRICIANS : PLEASE REPLACE OR REPAIR MOTOR TO BOILER ROOM EXHAUST FAN #1 PRIORITY HIGH
FO-324516	8/17/2015			ALARM WONT RESET FIRE ALARM SOUNDING. Completed 8-18-2015 SRP
FO-324837	8/18/2015			Repair hole in concrete at the top of the steps to the back door.
FO-324843	8/19/2015	8/19/2015		Electrician; High Please repair/replace the motor for the low speed belt drive on the west cell of the cooling tower. 071-COT-001.
FO-324985	8/19/2015			Electrician replace phase monitor in VFD for supply fan 3A-1. It keeps tripping out shutting the fan off. Priority High.
FO-324986	8/19/2015	8/20/2015		ELECTRICIANS,PLEASE TROUBLESHOOT FREQ DRIVE ON # 7 CHILLED WATER PUMP, WILL NOT RUN.PRIORITY-HIGH.
FO-324987	8/19/2015	8/20/2015		LIGHT SWITCH IS BROKEN IN STORAGE AREA ROOM C. (BASEMENT) Completed 8-20-2015 SRP
FO-325006	8/20/2015			Trade: ElectricianPriority: HighPlease repair lights in mechanical room 22 and stairway to fan room #1. Circuit breaker #1 in panel "C" (newer panel near engineers office) will not reset.
FO-325019	8/20/2015	8/24/2015		Check receptacles on the outside of Fitness, and UGL to make sure they have power, and drop an extension cord from the overhang of UGL to be used Saturday 8/22/2015. Completed 8-24-2015 SRP
FO-325026	8/20/2015			Breaker keeps tripping on oven circuit. I contacted Eugene Owens and he said to have his shop get the work order to come and figure out why it keeps tripping. Old work orders FO324999 & FO324519
FO-325029	8/20/2015	8/21/2015		R/R INSIDE LOADING DOCK (appr. 12ft)This is the loading dock. Almost all the lights, except one, no longer work. When the only remaining one quits working, we will no longer be able to see. Please fix. Thank you - Dawn C.
FO-325112	8/21/2015	8/24/2015		LIGHT SWITCH IS BROKEN IN SQUASH COURT 18. (BASEMENT)
FO-325241	8/24/2015	8/24/2015		R/R RM 5111 EAST SIDE WALL PLUG ISN'T WRKING
FO-325259	8/24/2015	8/25/2015		LIGHTS ARE NOT COMING ON AFTER REPLACEMENT. OCCUPANT THINKS THERE MAY BE A PROBLEM WITH THE WIRE. ROOM 1806. SEE SHEREESE.
FO-325270	8/24/2015			Fill fuel day tank with Diesel Fuel for the generator.
FO-325378	8/25/2015	8/26/2015		**ADDING ELECTRICIAN; Please disconnect controller in boiler room for mixing tanks. **This needs to be disconnected 1st thing Wednesday 8-26-15 morning. See Jim Hill for location Remove 2 old mixing tanks from Boiler room. See Engineer Greg Ray for d
FO-325397	8/26/2015			ELECTRICIANSFUME HOOD #3 HAS BAD SWITCH TO START EXHAUST FAN.HIGH PRIORITY
FO-325429	8/26/2015			Repair receptacle in sump pump area going down ramp.
FO-325449	8/26/2015			Trade: Electricians Priority: High Fire alarm system will not reset. Trouble alarm from the second floor chemical storage.
FO-325514	8/27/2015			Electrician repair EF-1 on lower roof. Does not run. Priority high
FO-325611	8/28/2015			let PM technologies in generator at scott hall and karmonos.
FO-325640	8/29/2015			Trade: ElectricalPriority: HighFire panel malfunction.After pulling pull station, Annunciation or strobe won't work. Public safety did get the alarm.Strobe will work only when panel is reset.

T - Locksmith

5

WO	Recieved	Finished	Total	Request
FO-323884	8/6/2015	8/6/2015		New Key Lost / Stolen Key #: 109745 Key Holder ID: James Darga Qty: 1 action: Master key for Engineer Darga
FO-324140	8/11/2015	8/13/2015		Site 505-Hecker-Hartman House at 5510 Woodward Please change key pad access code at back door as code has been compromised. Recommend new code be address (5510) if possible? 8/11/15 lps: Chng to Est for Main
FO-324375	8/14/2015	8/14/2015		Key # MJX-52 for Plumbers. Need to access for repair scheduled for 4:00 am Tuesday. Approved by Ian Studders.
FO-325523	8/27/2015	8/28/2015		Please repair latch on Generator door facing the building, you may have to replace the key cylinder.
FO-325524	8/27/2015			Please repair/replace the key so Employees can gain access to fuel tank.
T - Painter			4	
FO-323829	8/6/2015	8/10/2015		PAINTERS (HIGH) R/R RM 9223 CEILING LEAK IN ROOM 9223 FROM 2 DRAINS IN THE PENTHOUSE. PLEASE SEAL FLOOR AND DRAINS FOR THE PENTHOUSE EYE WASH STATION AND CHEMICAL TESTING AREA DRAIN. SEE ENGINEERS
FO-324407	8/14/2015	8/20/2015		**ADDING PAINTER: Please seal floor drain 2ed floor men's room . See Don Bear for detail WATER CEILING LEAK OVER URINAL. 1ST FLOOR MEN'S RESTROOM. ROOM 108,,,,,,,,,,,,,,,,, DB/6-15-15 ,,,,,,,,,,,,,,,,,
FO-324809	8/19/2015	8/27/2015		ADDING PAINTER: Please seal Mechanical Room above room 310 entrance. Crack in floor is draining through. See Gerry Simancas for location or questions 3RD FL HALLWAY OUTSIDE 310 CEILING LEAK ,,,,,,,,,,,,,,,,, GS/8-5-15 ,,,,,,,,,,,,,,,,, **SEE JIM HILL FO
FO-325234	8/24/2015	8/26/2015		RM 251 WALL PLASTER CRUMBLING
T - Pipefitter			32	
FO-323549	8/4/2015	8/4/2015		CEILING LEAK. CONFERENCE ROOM 1339,,,,,,,,,,,,,,,,, JH/8-4-15 ,,,,,,,,,,,,,,,,,
FO-323584	8/4/2015	8/5/2015		RADIATOR LEAKING VERY BADLY. ROOM 2339,,,,,,,,,,,,,,,,, JH/8-5-15 ,,,,,,,,,,,,,,,,,
FO-323686	8/4/2015	8/6/2015		FITTERS PLEASE REPLACE REHEAT HOT WATER VALVE TO ROOM 512 PRIORITY (HIGH) RED TAG POWERS 656-0013 MOCEL28803, SPRING RANGE 10-15# ,,,,,,,,,,,,,,,,, ME/8-5-15 ,,,,,,,,,,,,,,,,,
FO-323767	8/5/2015	8/11/2015		Trade: Pipefitter Priority: High Please repair leaking make up line to the condensate surge tank,,,,,,,,,,,,,,,,, ME/8-6-15 ,,,,,,,,,,,,,,,,,
FO-323784	8/5/2015	8/6/2015		Fitter replace the head on the #2 water softener for the boilers. Priority high. Contact Peter Miller from Eldon Water at 734.679.6603 ,,,,,,,,,,,,,,,,, JH/ 8-5-15 ,,,,,,,,,,,,,,,,,
FO-323861	8/6/2015			MD 2136 INNER RM CEILING LEAK.....EA,,,,,,,,,8-7-15
FO-324006	8/10/2015	8/11/2015		STEAM FITTERS-PLEASE REPAIR/REPLACE FLOAT VALVE ON COOLING TOWER, FLOAT BAD CAUSING NO MAKE UP TO ENTER TOWER CUASING HI HEAD CONDITIONS TO TRANE UNIT PRIORITY HIGH.....ME/RC.....8-10-15
FO-324026	8/10/2015	8/10/2015		RM 4130 CEILING LEAK.....ME/RC....8-10-15
FO-324104	8/11/2015	8/13/2015		R/R RM 00239 REPAIR LEAK IN UNION AT CAGE WASHER.....ME/RC.....8-11-15
FO-324108	8/11/2015	8/13/2015		R/R RM 00239 MIXING VLV NEEDS REPLACING CAUSING EYEWASH WATER TOO HOT.....ME/RC....8-11-15
FO-324113	8/11/2015			1318 CEILING LEAK.....EA.....8-11-15
FO-324118	8/11/2015			please meet Rich Moon from Honeywell in Mcgregor mech/fan room so he can show you what valves need to be replaced on defective vav boxes.....contractor has parts.....ME/RC.....8-11-15
FO-324214	8/12/2015	8/13/2015		RM 0225 SHUT OFF TEE PIPE DRIPPING.....ME....8-12-15
FO-324254	8/12/2015			please assist Engineers by breaking unions on #3 boiler on front blow down see Smiley.....EA.....8-12-15

WO	Recieved	Finished	Total	Request
FO-324463	8/17/2015	8/17/2015		RM 325 BAD CEILING LEAK.....JH.....8/17/15
FO-324480	8/17/2015	8/18/2015		Pipefitters-please re-locate supply and return lines for new Heat Pump installation. Floor will need to be isolated and lines drained Contact Andy or Gordie for Details. High Priority. From FO 311899.....ME.....8/18/15
FO-324709	8/18/2015	8/20/2015		Trade: Pipefitter Priority: high Please provide drain pipe so that water due to condensation can be drained from the duct. Evaporator coil enclosed inside the duct. Unit shut down.....JH.....8/18/15
FO-324754	8/18/2015	8/19/2015		Fitter repair overflow trap on D.A. tank in boiler room.....JH.....8/18/15
FO-324768	8/18/2015	8/18/2015		**THIS IS BEING CONTRACTED OUT TO FARNELL CONTRACTOR PER OEHS DUE TO SULFERIC ACID JWT/CB/ME RM 019.3 PIPE LEAKING.....CB.....8/18/15
FO-324824	8/19/2015	8/20/2015		Rm. 4126 needs to be checked/repared for leakage in ceiling. There are stained tiles. Once leaks are checked the tiles should be replaced.....JH.....8/19/15
FO-324950	8/19/2015	8/19/2015		Replace 1" Drain Valve on surge tank in basement boiler room.....JH.....8/19/15
FO-325010	8/20/2015	8/20/2015		CEILING LEAK. CEILING TILES ARE FALLING. 1ST FLOOR FERRY ENTRANCE.....JH.....8/20/15
FO-325149	8/21/2015	8/24/2015		please have pipefitters install a p-trap on the chilled water drain line on ac-8 high priority.....JH....8/21/15
FO-325210	8/24/2015	8/24/2015		RM 1316 ACTIVE CEILING LEAK ,,,,,,,,,, ME/8-24-15 ,,,,,,,,,,
FO-325232	8/24/2015			FITTERS: PLEASE REPAIR #2 HEAT EXCHANGER TUBE BUNDLE APPEARS TO HAVE A LEAK, PRIORITY HIGH ,,,,,,,,,, ME/8-24-15 ,,,,,,,,,,
FO-325233	8/24/2015			FITTERS: PLEASE REPAIR #2 HEAT EXCHANGER TUBE BUNDLE APPEARS TO HAVE A LEAK, PRIORITY HIGH
FO-325308	8/25/2015	8/26/2015		**REFER TO PLUMBERS FO#325456 JWT CEILING LEAK. ROOM 2151. ,,,,,,,,,, EA/8-25-15 ,,,,,,,,,,
FO-325326	8/25/2015	8/27/2015		Please have pipe fitters replace 1 1/2 in. elbow near hv-2 blowing steam. high priority. ,,,,,,,,,, JH/8-26-15 ,,,,,,,,,,
FO-325419	8/26/2015	8/26/2015		**DUPLICATE WORK ORDER/REFER TO FO#325308 CEILING LEAK. ROOM 2151
FO-325431	8/26/2015	8/27/2015		fitters_please repair heat exchanger control in basement room#023 at the in of the ramp from the entrance doors to the fan room. the heat exchanger has the water temperature going over 200f causing the safety valve to open shooting steam across the floor.
FO-325459	8/26/2015			RM 5344 CEILING LEAK ,,,,,,,,,, ME/8-26-15 ,,,,,,,,,,
FO-325622	8/28/2015			please have pipefitters repair/replace union on steam riser in room 100 above electrical cage across from low pressure cold water tank. high high priority. ,,,,,,,,,, ME/8-31-15
T - Plumber			58	
FO-323440	8/3/2015	8/3/2015		TOILET OVERFLOWING. 4TH FLOOR MEN'S RESTROOM.....DB.....8/3/15
FO-323465	8/3/2015	8/4/2015		Sink is running, hot water will not turn completely off. Please fix. Thank you.....DB.....8/3/15
FO-323469	8/3/2015	8/4/2015		Water present on floor from leakage through wall, ceiling or floor. Thank you, Susan.....MM.....8/3/15
FO-323492	8/3/2015	8/11/2015		Plumber please troubleshoot control valve to body wash tables in prep room,temperture of cold water is too warm.(FO-323481) priority HIGH.....MM.....8/3/15
FO-323547	8/4/2015	8/7/2015		FAUCET LEAK. ROOM 026.1.,,,,,,,,,, MM/8-4-15 ,,,,,,,,,,
FO-323603	8/4/2015	8/4/2015		**DUPLICATE / REFER TO FO#316847 1ST FL UNISEX/HANDICAP RESTROOM OUT OF ORDER ,,,,,,,,,, MM/8-4-15 ,,,,,,,,,,
FO-323607	8/4/2015	8/7/2015		please have plumbers repair glass drain line from penthouse to the 9th floor 2 couplings are leaking and drain in penthouse is leaking. high priority. ,,,,,,,,,, MM/8-4-15 ,,,,,,,,,
FO-323707	8/5/2015	8/7/2015		LEAK UNDERNEATH SINK. BASEMENT MEN'S LOCKER ROOM. ,,,,,,,,,, MM/8-5-15 ,,,,,,,,,
FO-323714	8/5/2015			RM 216 SINK IS CRACKED ,,,,,,,,,, MM/8-5-15 ,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-323748	8/5/2015	8/10/2015		WATER FOUNTAIN IS NOT WORKING. HALLWAY OUTSIDE OF ROOM 170..... MM/8-5-15
FO-323749	8/5/2015	8/10/2015		WATER FAUCET IS SPRAYING WATER WHEN TURNED ON. 4TH FLOOR CUSTODIAL CLOSET..... MM/8-5-15
FO-323754	8/5/2015	8/18/2015		3RD FL HALLWAY OUTSIDE 310 CEILING LEAK GS/8-5-15 **SEE JIM HILL FOR DETAIL
FO-323782	8/5/2015	8/6/2015		RMS 9213/9223 CLNG IS LEAKING BELIEVE WATER COMING FROM PH MM/8-5-15
FO-323785	8/5/2015	8/10/2015		Inside of Suite 2100 UGL in the back Kitchen, the garbage disposal is not functioning. Please assist..... MM/8-5-15 thank you
FO-323786	8/5/2015			RM 9215 FAUCET WON'T TURN OFF MM/8-5-15
FO-323786	8/5/2015			RM 9215 FAUCET WON'T TURN OFF MM/8-5-15
FO-323792	8/6/2015	8/6/2015		There have been a bag over the Handicap toilet in women restroom for a month can w please have someone look at it.....MM.....8-6-15
FO-323810	8/6/2015			BSMNT SOUTH END UNISEX RESTROOM TOILET LEAKING AND ALSO STANDING WATER AROUND FL DRAIN.....MM...8-5-15
FO-323940	8/7/2015	8/10/2015		WOMENS RM 1216 TOILET CONTINUOUSLY FLUSHING.....MM.....8-7-15
FO-323998	8/10/2015	8/11/2015		MENS RM 4TH FL URINAL NOT DRAINING.....MM.....8-10-15
FO-324001	8/10/2015	8/13/2015		PLUM R/R RM 6100.30 GARBAGE DISPOSAL ISN'T WRKNG ENG CK BREAKER DRAIN NEEDS TO BE CLEARED OUT.....MM.....8-10-15
FO-324002	8/10/2015	8/11/2015		MENS RM 2438 TOILET CONTINUOUSLY FLUSHING.....MM.....8-10-15
FO-324008	8/10/2015			cb (**) PO REQ TH 8/10/15 Investigate a location for an isolation valve in city main, leading to basement Also replace all 3 meter valves, meter, and related pipingGS /8-10-15 **this has turned into an emergency, Rick Mass
FO-324067	8/10/2015			RM 0225 NO COLD WATER.....MM.....8-11-15
FO-324216	8/12/2015			RM 0225 COLD WATER FAUCET NOT WORKING.....MM....8-12-15
FO-324240	8/12/2015	8/13/2015		PIPE LEAK UNDERNEATH SINK. (WATER ON FLOOR) ROOM 0503.....MM....8-12-15
FO-324261	8/12/2015	8/13/2015		WATER IS BROWN. drinking fountain HALLWAY OUTSIDE OF ROOM 308..... DB/8- 13-15
FO-324292	8/13/2015			Trade: Plumber Priority: High 090-DHW-003 EDC domestic water heater, gas fired, will not fire. Also the small circulating pump attached to it is leaking. This unit is located in the basement mechanical room of EDC..... MP/8-13-15
FO-324364	8/14/2015	8/14/2015		PLUGGED TOILET. (OVERFLOWED) 5TH FLOOR WOMEN'S RESTROOM. DB/8-14-15
FO-324380	8/14/2015	8/14/2015		DUPLICATE/REFER TO FO#324387 TOILET CONTINUOUSLY FLUSHING. 2ND FLOOR MEN'S RESTROOM.....MP....8/17/15
FO-324385	8/14/2015	8/14/2015		RM 212 SINK PLUGGED MM/8-14-15
FO-324392	8/14/2015	8/14/2015		TOILET WON'T FLUSH. UNISEX RESTROOM. ROOM 5100..... DB/8-14-15
FO-324394	8/14/2015	8/14/2015		TOILET CONTINUOUSLY FLUSHING AND OTHER TOILETS HAVE LOW WATER PRESSURE AND WON'T FLUSH. LADIES RESTROOM. ROOM 2377..... MP/8-14- 15
FO-324401	8/14/2015	8/17/2015		PLUMBERS MENS URINAL IS CONTINUOUSLY RUNNING WATER. REPAIR/ REPLACE WATER ASSEMBLY.....MM.....8/17/15 FO#324379

WO	Recieved	Finished	Total	Request
FO-324404	8/14/2015			One of the Drinking water fountains is Out of Order since May 2015. Can this be fixed now? The asbestos removal from the Studio ceiling is completed. Also there is a gray pushcart that has been left in the custodial closet from when they were here
FO-324465	8/17/2015	8/18/2015		RM 6344 LEAK, PUDDLE OF WATER ON FLOOR.....MM.....8/18/15
FO-324740	8/18/2015	8/22/2015		TOILET IS NOT FLUSHING. MEN'S RESTROOM NEXT TO ROOM 1506.....MM...8/18/15
FO-324832	8/19/2015	8/19/2015		Within Suite 200 2nd floor south, in the women's bathroom. The toilet handle leaks water when flushed.....DB....8/19/15
FO-324938	8/19/2015	8/20/2015		TOILET NOT FLUSHING. 1ST FLOOR MEN'S RESTROOM.....GS.....8/19/15
FO-325000	8/19/2015	8/21/2015		RM 154 FAUCETS NOT WORKING LEFT SINK CONSTANTLY DRIPS, RIGHT SINK HARD TO TURN HOT WATER OFF.....MP....8/20/15
FO-325032	8/20/2015	8/21/2015		TOILET CONTINUOUSLY FLUSHING. WOMEN'S RESTROOM. ROOM 572.....DB....8/20/15
FO-325120	8/21/2015	8/21/2015		TOILET CONTINUOUSLY FLUSHING. LADIES RESTROOM. ROOM 2377.....MM...8/21/15
FO-325122	8/21/2015	8/21/2015		CLOGGED TOILET. 2ND FLOOR UNISEX RESTROOM.....MM.....8/21/15
FO-325130	8/21/2015	8/21/2015		PLUM R/R RM 113/WOMENS RR (ALONG VENDING MACHINE HALLWAY) 2ND STALL TOILET SEAT HINGES SEEMS TP HAVE BEEN STRIPPED. SEAT IS VERY LOOSE.....DB.....8/21/15
FO-325146	8/21/2015	8/25/2015		Plumber please repair 3rd sink faucet not working properly,FO-325121,priority high.....MM....8/21/15
FO-325167	8/21/2015			Plumbers: R/R RM 3133/MECH RM Please repair the sloop sink faucet (Chicago) backflow preventer. Leaks every time faucet is used. High Priority. ,,,,,,,,,,,,,, GS/8-24-15 ,,,,,,,,,,,,,,
FO-325201	8/24/2015			Replace spigot on the south side of stadium. Same faucet was leaking last fall water shut-off.,,,,,,,,,,,,,, GS/8-24-15 ,,,,,,,,,,,,,,
FO-325202	8/24/2015	8/24/2015		SINK FAUCET IS CONTINUOUSLY RUNNING. ROOM 2303. ,,,,,,,,,,,,,, MM/8-24-15 ,,,,,,,,,,,,,
FO-325253	8/24/2015	8/25/2015		WATER IS RUSTY 4TH FLOOR LADIES RESTROOM 4TH SINK.,,,,,,,,,,,,,, DB/8-24-15 ,,,,,,,,,,,,,
FO-325254	8/24/2015	8/25/2015		WATER IS RUSTY 4TH FLOOR WATER FOUNTAIN OUTSIDE OF THE LADIES RESTROOM. ,,,,,,,,,,,,,, DB/8-24-15 ,,,,,,,,,,,,,,
FO-325263	8/24/2015	8/27/2015		PLUMBERS: Please repair Eye Wash near room 4451 no flow. HIGH ,,,,,,,,,,,,,, MM/8-24-15 ,,,,,,,,,,,,,
FO-325382	8/25/2015			STE 100 TOILET OVERFLOWING ,,,,,,,,,,,,,, MM/8/25/15 ,,,,,,,,,,,,,,
FO-325442	8/26/2015			Purdy Library 2nd Floor Room 231 Sink is slow to drain. Please repair. Thank you. ,,,,,,,,,,,,,, GS/8-26-15 ,,,,,,,,,,,,,,
FO-325456	8/26/2015			trade plumbers priority high theirs a ceiling leak in this area right above sink spilling from up top inside the walls not able to get to this leak and isolate ,,,,,,,,,,,,,, MM/8-27-15 ,,,,,,,,,,,,,,
FO-325462	8/26/2015	8/27/2015		R/R 4TH FLR MENS RR ON THE SOUTH SIDE OF BLDG ONLY URINAL ISN'T FLUSHING ,,,,,,,,,,,,, MM/8-26-15 ,,,,,,,,,,,,,,
FO-325526	8/27/2015			Plumbers: Please repair drinking fountain on second floor that is stopped-up near the elevator. High Priority.,,,,,,,,,,,,,, MM/8-27-15 ,,,,,,,,,,,,,,
FO-325557	8/27/2015			Kresge Library 1st Floor Room 113 Handicap Restroom Unable to shut off water in sink; steady stream. Please repair. Thank you.,,,,,,,,,,,,,, GS/8-27-15 ,,,,,,,,,,,,,,
FO-325607	8/28/2015			FAUCET CONTINUOUSLY RUNNING. 3RD FLOOR MEN'S RESTROOM. RIGHT SINK. ,,,,,,,,,,,,, GS/8-31-15 ,,,,,,,,,,,,,,
T - Roofing			5	
FO-323750	8/5/2015	8/7/2015		Roof Leak again that is hampering research - Below is the email from our researcher - There are still multiple ceiling leaking in our life science room 422. Can you send someone to fix it (it has been several times, but the issue not yet resolved which
FO-324084	8/11/2015			Roof leak 2nd room from the left as you enter the building.Trade: RooferPriority: Medium

WO	Recieved	Finished	Total	Request
FO-324139	8/11/2015			WARRANTY/ROOFER R/R GIRLS' SOFTBALL FACILITY Ceiling leak @ Softball Building...1st office on the left...Please see Bob Ostrowski on specs. Thank You. Bob Ostrowski
FO-325076	8/20/2015			WATER LEAK. 4TH FLOOR WEST. STACK AREA.
FO-325076	8/20/2015			WATER LEAK. 4TH FLOOR WEST. STACK AREA.
T - Sheetmetal			1	
FO-323667	8/4/2015			D. Kuffner, Insulation - High Priority There is water dripping from the duct work above the ceiling in the following labs. 19.2 19.3 19.4 19.5. This duct work has been replaced recently and it is not insulated nor provisions made for condensate draina
Medium			126	
T - Carpenter			27	
FO-323558	8/4/2015	8/5/2015		door is screeching every time its opened.
FO-323583	8/4/2015	8/10/2015		Requiring caulking of base of UGL, southeast area across from Engineering Building, starting between pillars six & seven (one or two more continuing past) from corner nearest to resident hall.CAUTION: BEES SEEN ENTERING AND EXITING FROM AT LEAST ONE OF TH
FO-323745	8/5/2015	8/10/2015		please replace stained ceiling tiles in room 1351
FO-323768	8/5/2015			Carpenters: Please replace missing and loose ceiling tiles on 1st floor hallway between rooms 106 and 118. Priority: med.
FO-323769	8/5/2015			Carpenters: Please replace missing and loose ceiling tiles on 2nd floor hallway between rooms 201 and 208. Priority: med.
FO-323844	8/6/2015	8/7/2015		CARPENTRY- please repair wooden cabinet in boiler room that has been damaged and cannot be secured. located in boiler at 5425 Woodward on West wall.
FO-323845	8/6/2015			CARPENTRY please r/r hook in lavatory across from new ROTC area Back hall of 5425 Woodward. There is no hook to hang a coat. Shelf is also missing. please r/r.
FO-323866	8/6/2015	8/21/2015		the drywall corner bead missing on the wall outside of 2380
FO-323941	8/7/2015	8/10/2015		CARPENTER please repair (3) door locks to women stalls,rm. 3341. priority med.
FO-323981	8/10/2015	8/11/2015		R/R RM 107/WOMENS RR first stall door is locked from the inside , can you please open it? thanks Michelle
FO-323987	8/10/2015			CARPENTER (MED) R/R RM 401/MECH RM BUILD RAMP INTO ROOM 401. RAMP SHOULD BE DESIGNED SO CHEMICAL PAILS AND DRUMS CAN BE ROLLED INTO THE ROOM.
FO-324146	8/11/2015	8/24/2015		Please provide and install shelf for the new chemical pumps to be installed. Per Mark Allen.
FO-324371	8/14/2015	8/19/2015		Trade: Carpenter Priority: MediumPlease remove vent from wall above the door and close opening. This vent was installed a couple of years ago because we had to place a temporary spot cooler in this room. We removed the cooler so the opening needs to be c
FO-324378	8/14/2015	8/17/2015		CARPENTER PLEASE REPLACE DAMGER CEILING TILE LOCATION BASEMENT HALLWAY IN FRONT ROOM 41,43.51 MEDIUM PR
FO-324458	8/17/2015	8/18/2015		Rm. 4621 (office) needs missing ceiling tile replaced.
FO-324517	8/17/2015	8/18/2015		ENTRANCE DOOR WILL NOT CLOSE PROPERLY. 2ND FLOOR LADIES RESTROOM.
FO-324708	8/18/2015	8/19/2015		Trade: Carpenter Priority: Medium Please replace water damaged ceiling tiles.
FO-324978	8/19/2015	8/26/2015		CARPENTERS: Please replace multiple FLOOR TILES NEAR ROOM 3250. MED
FO-325004	8/20/2015			Carpenters-Please rebuild ceiling in area. Heat pump replacement complete. Medium Priority
FO-325066	8/20/2015	8/20/2015		Clean carpet in Grounds supervisors offices room 111. Contact Carla Crawford with any questions - 7-4323
FO-325260	8/24/2015	8/25/2015		LOCKSMITH: PLEASE REPAIR DOUBLE DOOR LOCK AT THE LOADING DOCK (DOOR DOESNT LOCK) PRIORITY MED, DOOR DOESNT HAVE A NUMBER
FO-325269	8/24/2015			CARPENTERS,PLEASE REPAIR GLASS MOULDING IN HALLWAY DOUBLE DOORS NEAR ROOM 3384.PRIORITY-MEDIUM
FO-325341	8/25/2015	8/27/2015		Repair broken cage gate top track located across from service area in Grounds department.
FO-325367	8/25/2015			Carpenters- Please build cover for exposed pipes next to new console heat pump unit, located in the deans conference room (202). From FO 314503Medium Priority

WO	Recieved	Finished	Total	Request
FO-325377	8/25/2015			CARPENTERS: Please repair broken floor tiles near room 3210 MED.
FO-325594	8/28/2015	8/28/2015		FRONT AND BACK DOORS ARE STICKING IN ROOM 310.
FO-325626	8/28/2015			DOOR SCRAPES FRAME. DOOR #039-02-S.
T - Electrician			35	
FO-323461	8/3/2015	8/5/2015		Also check electrical switch seems to be malfunctioning.
FO-323500	8/3/2015	8/5/2015		Time to attend training for the new Generator, at 8 AM to 10 AM.
FO-323501	8/3/2015	8/6/2015		Time for Safety meeting for the month of August, 2015 for the Electricians.
FO-323610	8/4/2015	8/4/2015		Purdy Library, 2nd Floor, across from Stair 1/Exit 1 Wall clock out of order. Please repair. Thank you. Completed 8-4-2015 SRP
FO-323706	8/5/2015			Laborer med. Priority Please deliver the following kegs of tower chem to pump station in basement mechanical rm1- 30 gal keg of Lokor 2000TM1- 30 gal keg of Aquaklene ODP1- 30 gal keg of Halochlor C please see engineer for location and assistance 810-5
FO-323743	8/5/2015			Electricians can you please remove light fixture,,,see Eric A for questions.....CEILING PIPE LEAK. (HERMAN NELSON) ROOM 59.....EA.....8/3/15 ASBESTOS IN AREA SEE CORY BEFORE REMOVING FIXTURE
FO-323756	8/5/2015			freeze stat appears to have failed. Unit will run if switch is made manually.
FO-323862	8/6/2015	8/7/2015		Trade: Electricians Priority: Medium R/R ATRIUM Please repair problem with the first floor fire dampers that are closed. AHU-6 graphic shows that the dampers are closed. Siemens looked at and found 3 dampers that are closed causing a whistlwhistling sou
FO-323876	8/6/2015	8/11/2015		ELECTRICIANS R/R ROOF/BLDG Replace blown flood light lamp at rooftop along north side of building. Medium Priority
FO-323956	8/7/2015	8/17/2015		Trade: Electricians Priority: Medium Follow up to FO 323945 R/R RM 360 Lights in lab 360 were off. Switches in lab did not restore lights. Switch in 360.1 (near cold room) operates the lights in 360. Switch in 360.1 should not prevent switches in
FO-324143	8/11/2015	8/28/2015		Repair fire trouble on Siemens fire panel at Skillman. Completed 8-28-2015 SRP
FO-324147	8/11/2015	8/20/2015		Electricians to install electrical outlet within 3 feet of the shelf that is constructed by the carpenters.Per Mark Allen.
FO-324186	8/12/2015	8/31/2015		Install 110V outlet within 3 feet of shelf (boiler room).
FO-324221	8/12/2015	8/12/2015		Electricians: R/R RM 403 please trouble shoot breaker for UV - 9, it does not shut off power to the unit. Breaker panel is in room 408. Priority: med. 8/12/15 lps: Eq not avail in TMA Sys
FO-324233	8/12/2015			Labore- Tower chemicals- med priority. Please deliver 2 barrels each of the following chemicals, Aquaclean, Lokor, Halochlor. and 2 boxes of Nithawk gloves large.
FO-324245	8/12/2015			Install solenoid valve wiring, conductivity wiring for automated blowdown control. For Eldon Water, per M. Allen.
FO-324246	8/12/2015			Install solenoid valve wiring, conductivity wiring for automated blowdown control. For Eldon Water, per M. Allen.
FO-324247	8/12/2015			Install solenoid valve wiring, conductivity wiring for automated blowdown control. For Eldon Water, per M. Allen.
FO-324457	8/17/2015			please have laborer deliver 1 pallet of salt to room 100 for water softner.
FO-324472	8/17/2015	8/18/2015		pls deliver keg of halocore to comp center asap
FO-324497	8/17/2015			Electricians: please trouble shoot and repair FCU-3 blower motor in mechanical room 408. It keeps blowing fuses. Priority: med.
FO-324718	8/18/2015			pls deliver 3 pails of nitrokanse and 1 bag of oil dry and one small pail of boiler refactory cement

WO	Recieved	Finished	Total	Request
FO-324932	8/19/2015	8/21/2015		Electrician; Medium Please check to see if repair/replacement is needed for the two basin heaters and the heat tape used on the cooling tower. 071-COT-001.
FO-325095	8/21/2015			Electrician; Medium Please repair the Building Clock located outside the Woodward Entrance. The clock is not running. Completed 8-14-2015 SRP Install lamps to illuminate clock
FO-325134	8/21/2015			Run a meter wire (1 pair, 18-22 AWG) from the boiler make up meter to the boiler chemical controller, per Peter Miller (Eldon Water).
FO-325163	8/21/2015			To electricians. R/R RM 00023/MECH RM The domestic hot water recirc. pump above door is not working. There is power coming into the switch, but no power going up to pump. This switch has built in overloads.
FO-325164	8/21/2015			Pick up poles off mall between Student Ctr., and UGL, and take them to roof area. 1 Blue Light, and 3 poles.
FO-325198	8/24/2015			Electricians to run a meter wire (1 pair, 18-22 AWG) at Chatsworth from the boiler make up meter to the boiler chemical controller
FO-325212	8/24/2015			Repair/reattach chain to turn light on and off in the closet off room 205.
FO-325357	8/25/2015			Electricians-Please remount light fixture in ceiling in office area. Heat pump Replacement complete. From FO 311900
FO-325358	8/25/2015			Electricians-Please remount light fixture in ceiling in hallway outside room 10507. Heat pump Replacement complete. From FO 311899
FO-325450	8/26/2015	8/27/2015		1ST AND 2ND FL CLASSROOMS ALL CLOCKS NEED TO BE SET WRONG TIMES OR NOT WORKING Completed 8-27-2015 SRP
FO-325578	8/28/2015			Trade: ElectricalPriority: Medium3rd floor Elevator Lobby Smoke detector dirty M2-9. code 3C01Trouble alarm cannot be cleared ON PANEL.
FO-325581	8/28/2015	8/31/2015		ELECTRICIAN PLEASE R/R CLOCK IN ROOM 469 NOT WORKING MAKE LOUD NOISE MEDIUM PR Completed 8-31-2015 SRP
FO-325641	8/29/2015			Trade : ElectricianPriority: MediumFire panel in trouble.NCC 1st Floor lobby. Trouble cannot be cleared.
T - Painter			2	
FO-323589	8/4/2015	8/17/2015		please repair chipped paint and hole in upper part of wall behind door-rm 219. contact Dale at 7-9880. thank you
FO-324109	8/11/2015	8/12/2015		R/R RM 00239 PATCH HOLE IN CEILING. (Note: no evidence of any type of leak)
T - Pipefitter			34	
FO-323464	8/3/2015	8/4/2015		STEAMFITTERS-PLEASE CLEAR CHILLED WATER COIL CONDENSTATE DRAIN INSIDE AHU,DRAIN PLUGGED WATER ALL OVER FLOOR IN MECH ROOM MED PRIORITY.....JH.....8/3/15
FO-323483	8/3/2015	8/19/2015		**LOWERED PRIORITY / WORK IN PROGRESS JWT CEILING PIPE LEAK. (HERMAN NELSON) ROOM 59.....EA.....8/3/15
FO-323737	8/5/2015	8/21/2015		Fitters, repair a pin hole leak in the blow down line on No. one boiler priority med ,,,,,,,,,,,,,, EA/8-5-15 ,,,,,,,,,,,,,,
FO-323738	8/5/2015	8/21/2015		Fitters repair a pin hole leak in the blow down line on No. two boiler priority medium ,,,,,,,,,,,,,, EA/ 8-5-15 ,,,,,,,,,,,,,,
FO-323762	8/5/2015	8/7/2015		FITTERS: Please repair leaking shutoff valve on SOUTH VAV UNIT. MED,,,,,,,,,,,,,,,,, JH/8-5-15 ,,,,,,,,,,,,,,,,,,
FO-323764	8/5/2015			Pipe fitters: please repair steam leak on both side of the main steam bypass valve for PRV station. Priority: med. ,,,,,,,,,,,,,,,,,, ME/8-6-15 ,,,,,,,,,,,,,,,,,,
FO-323938	8/7/2015			STEAMFITTERS-PLEASE REPAIR 3/4 INCH NIPPLE LEAK IN HOT WATER PERIMETER MAKE UP LINE BY AHU #4,PRIORITY MED FLOOR WET.....EA....8-7-15
FO-323939	8/7/2015	8/7/2015		Fitter (Ron/Jim) repair drain pipe leak at boiler sample station.....JH/RC....8-7-15

WO	Recieved	Finished	Total	Request
FO-324033	8/10/2015			STEAMFITTER RM 0225 PLEASE CHECK BEFORE FEDERAL INSPECTION PLEASE INSTALL PLASTIC COVER OVER FIBER GLASS INSTALLATION INSULATION COMING OFF STEAM PIPE ,,,,,,,,,, JH/8-10-15 ,,,,,,,,,
FO-324033	8/10/2015			STEAMFITTER RM 0225 PLEASE CHECK BEFORE FEDERAL INSPECTION PLEASE INSTALL PLASTIC COVER OVER FIBER GLASS INSTALLATION INSULATION COMING OFF STEAM PIPE ,,,,,,,,,, JH/8-10-15 ,,,,,,,,,
FO-324041	8/10/2015			Trade: Pipefitter Priority: Medium Please repair or replace the rear safety valve on #4 boiler. Steam is leaking through the rear safety valve.....ME.....8-11-15
FO-324148	8/11/2015	8/20/2015		Pipefitters to install make up meter for cooling tower. Per Mark Allen.....ME/RC....8-12-15
FO-324190	8/12/2015			Install New Controller on Tower System.....ME,....8-12-15
FO-324193	8/12/2015	8/17/2015		Install cooling tower controller.....ME/RC.....8-12-15
FO-324194	8/12/2015	8/21/2015		Install 5 Gal Potfeeder (In Stockroom) on the Hot Water Loop.....EA.....8-12-15
FO-324232	8/12/2015	8/21/2015		Pipefitters-please install new condensate drain line from new heat pump to existing drain. Please return temporary drain line to Andy or Gordie. Medium priority. From FO 320094.....EA.....8-12-15
FO-324237	8/12/2015			Install automated blowdown control piping. For Eldon Water, per M. Allen.....ME.....8-12-15
FO-324238	8/12/2015			Install automated blowdown control piping. For Eldon Water, per M. Allen.....RC...8-12-15
FO-324239	8/12/2015			Install automated blowdown control piping. For Eldon Water, per M. Allen.....RC....8-12-15
FO-324241	8/12/2015			Install amine injection point. For Eldon Water, per M. Allen.....RC....8-12-15
FO-324242	8/12/2015	8/13/2015		Install new controller on main tower. For Eldon Water, per M. Allen.....RC....8-12-15
FO-324243	8/12/2015			Install amine injection point. For Eldon Water, per M. Allen,,,,,,,,,,,,, RC/8-13-15 ,,,,,,,,,
FO-324244	8/12/2015	8/14/2015		Finish controller install. For Eldon Water, per M. Allen,,,,,,,,,,,,, RC/8-13-15 ,,,,,,,,,
FO-324258	8/12/2015	8/18/2015		Pipe fitters: please repair or replace leaking hot water reheat valve for room 300.4. the reheat unit is in room 202. priority: med. ,,,,,,,,,, JH/8-13-15 ,,,,,,,,,
FO-324442	8/17/2015			Fitters, Please modify the slug feeder/side stream separator piping so chemicals can be added to the hydronic boiler. Priority medium.....ME....8/19/15
FO-324737	8/18/2015	8/26/2015		Remove 2 old mixing tanks from Boiler room. See Engineer Greg Ray for details 248-410-0214 ,,,,,,,,,, RC/8-25-15 ,,,,,,,,,
FO-324749	8/18/2015			STAEMFITTERS-PLEASE UNPLUG CHILLED WATER COIL CONDENSTATE DRIP PAN DRAIN INSIDE AHU,DRAIN PLUGGED WATER ALL OVER FLOOR PRIORITY MED.....EA.....8/18/15
FO-324834	8/19/2015	8/24/2015		RE: HP#23 located in RM 202 Please assist with disconnecting pipe to unit. Unit has been isolated but cannot be removed due to hard piping to unit after the isolation valve. Please disconnect water supply to unit and provide a means for future isolat
FO-324983	8/19/2015	8/20/2015		Fitter replace top man hole gasket on D.A. tank in boiler room.....EA.....8/19/15
FO-325048	8/20/2015	8/26/2015		Pipefitters- R/R 10TH FLR Please extend length of supply and return lines for new heat pump (2-64). Please leave area in front of unit clear for cabinet access. Medium Priority from FO 311899 Contact Andy or Gordie if further assistance if needed.....ME
FO-325116	8/21/2015	8/31/2015		Trade: Pipefitter Priority: Medium Please repair leak in LP steam line on the west wall.....EA.....8/21/15
FO-325261	8/24/2015	8/25/2015		Trade: Pipefitters Priority: Medium Please restore control air to thermostats in the northwest stairs (near lab 040) in the basement and near the first floor emergency exit,,,,,,,,,,,,, JH/8-24-15 ,,,,,,,,,
FO-325439	8/26/2015	8/27/2015		trade pipefitter priority medium please check flange leak coming off chill water line up near office area mech rm,,,,,,,,,,,,, JH/8-26-15 ,,,,,,,,,
FO-325511	8/27/2015	8/28/2015		pls spot weld on more insulation fasteners on boiler 2 front door ,,,,,,,,,, JH/8-27-15 ,,,,,,,,,,,,,
T - Plumber			26	
FO-323444	8/3/2015			Plumbers: Please replace all cracked and leaking sewer line in mechanical room 15. Priority: med.....GS.....8/3/15
FO-323445	8/3/2015			Plumbers: please replace cracked and leaking slop sink drain line for the custodian closet, the broken drain line is inside the mechanical room15. Priority: med.....GS.....8/3/15

WO	Recieved	Finished	Total	Request
FO-323452	8/3/2015			The water fountain on the 3rd floor (at the junction of North and South Wing) is not working. Thank you.....MP....8/3/15
FO-323689	8/4/2015			2ND REQUEST Please repair ceiling leak on 4th floor at the front of the elevators in ceiling..REFER TO FO-322238 This is for the pluming Department.
FO-323720	8/5/2015	8/24/2015		PLUMBERS please r/r leaking drain line in kitchen at beecher house. Drain line from sink leaking at coupling where it goes through wall to main drain line.MM/8-5-15
FO-323841	8/6/2015	8/7/2015		PLUMBERS (MED) REPLACE LEAKING PVC LINE FROM PENTHOUSE CHEMICAL TESTING SINK AND ROUTE DIRECTLY INTO DRAIN.....MM....8-5-15 SEE ENGINEER
FO-324103	8/11/2015	8/20/2015		R/R RM 00162 1ST SINK HAS A LEAKY FAUCET (PLS CK BOTH SINKS).....MP.....8-11-15
FO-324160	8/12/2015	8/18/2015		Plumber; Medium Please repair the plugged toilet located on the first floor in the maintenance hallway.....MP.....8-12-15
FO-324168	8/12/2015	8/14/2015		R/R 1ST FLR MENS RR (ONLY ONE ON FLR) TALL URINAL LEAKS @ BOTTOM WHEN FLUSHEDMM/8-13-15
FO-324437	8/17/2015	8/19/2015		Plumber please repair urinal continuously running.(FO-324379),priority
FO-324446	8/17/2015	8/19/2015		Plumbers, please repair sink leaky faucet in PH next to AHU-1MM.....8/17/15
FO-324727	8/18/2015	8/19/2015		Plumbers, please repair toilet 1st stall in ladies restroom on 1st floor. Toilet will flush.....MM.....8/18/15
FO-324785	8/18/2015			Trade: Plumbers Priority: Medium Please snake out backing up floor drain near the Surge tank in the chiller/pump room in the sub-basement.....GS.....8/19/15
FO-324979	8/19/2015			1ST FL 2 DRINKING FOUNTAINS, PLEASE CHANGE FILTER'S.....GS.....8/20/15
FO-325158	8/21/2015	8/25/2015		R/R RM 2301/MENS RR 2 OUT OF 3 FAUCETS AREN'T WRKNG NO WTR FLOWMM/8-24-15
FO-325262	8/24/2015			PLUMBERS: Please repair Safety Shower near room 4431. Leaking under sink of eye wash. MED.MM/8-24-15
FO-325297	8/25/2015			Trade: PlumberPriority: MediumPlease repair Sloan valve. Toilet won't flush.
FO-325298	8/25/2015			Trade: PlumberPriority: MediumRepair Sloan valve. Toilet leaking water.
FO-325325	8/25/2015	8/26/2015		Plumbers please clear slow draining sink in 2nd floor men's restroomMM/8-25-15
FO-325370	8/25/2015	8/31/2015		R/R RM 001144/WOMENS RR BOTH NORTH/SOUTH SINKS ARE PLUGGED. 1ST FLOOR LADIES RESTROOM.....DB/8-26-15
FO-325383	8/25/2015	8/31/2015		trade plumbers priority medium please service 3rd floor mens bath room toilet will not flushDB/8-26-15
FO-325386	8/25/2015			FAUCET LEAK. ROOM 2115.MM/8-26-15
FO-325464	8/26/2015	8/27/2015		R/R BSMT (ONLY ONE) WOMENS RR 1ST SINK ISN'T DRAINING PLUGGING UP NEEDS TO BE SNAKEDMM/8-26-15
FO-325501	8/27/2015			PLUMBER PLEASE R/R SOLAN VALVE LADIES ROOM TOILET 3RD FLOOR MEDIUM PRMM/8-27-15
FO-325541	8/27/2015			PLUMBERS: Please repair Safety Eye Sationnear room 3341(north). MED
FO-325623	8/28/2015			Plumber; Medium Please repair/replace the supply water tail pipe on the toilet in the men rest room located on the mezzanine level. The water is shut off to the toilet.....MM/8-28-15
T - Roofing			2	
FO-323460	8/3/2015			ROOFERS- please repair roof leak (minor) in West Hall outside new ROTC renovation. Several drips in hall. Standing water on roof due to pitch.

WO	Recieved	Finished	Total	Request
FO-324779	8/18/2015			Trade: Roofer Priority: Medium to High R/R RM 414 Please stop the roof leak that has water running into the cold room (walk-in cooler) that is now being used by the Food & Nutrition department.
Low			489	
T - Carpenter			94	
FO-323449	8/3/2015	8/3/2015		REPAIR DOOR 089-04-E LATCH NOT LANDING IN THE STRIKE POCKET
FO-323474	8/3/2015			TEAM LEADER TIME (AUGUST 2015)
FO-323491	8/3/2015	8/4/2015		Purdy Library 1st Floor Office Suite 122 (Human Resources Region B) Door to Room 122 slams shut. Please adjust door closer. Thank you.
FO-323545	8/4/2015	8/5/2015		Locksmith, please repair/replace door lock. Door extremely hard to lock.
FO-323585	8/4/2015	8/5/2015		Between the 9th and 10th windows east of door 096 16 S the eave trough/headliner?? is sagging. Possible water damage? Rehang/replace?
FO-323604	8/4/2015	8/6/2015		File Cabinet that was previously fixed is stuck and will not open. Cannot get into employee filing cabinet.
FO-323684	8/4/2015	8/5/2015		Door 629-02S scrapes threshold.
FO-323702	8/5/2015	8/7/2015		Purdy Library R/R 2nd Floor Emergency Door to Stair 8, Exit 9 is unlocked and I was unable to lock. Safety concern. Please repair. Thank you.
FO-323725	8/5/2015	8/13/2015		On the Woodward side of the building - One of the squares in the outer glass block window is cracked/loose at the end of the building (closer to Palmer) and one of the engineers says it can be caulked.
FO-323731	8/5/2015			R/R ENTRY Door #082-11N needs new sweep to keep water out of building.
FO-323732	8/5/2015			R/R ENTRY Door #082-14N allows water on interior floor when it rains.
FO-323734	8/5/2015	8/6/2015		The lock on the east entrance door is very sticky; often not working
FO-323736	8/5/2015	8/6/2015		Door gasket hanging loose
FO-323746	8/5/2015	8/11/2015		Please replace stained ceiling tiles in room 1339
FO-323747	8/5/2015	8/6/2015		please replace/install cover plate/escusion around pipe in air plenum tunnel #15 at red brick wall, see Marty E.....
FO-323795	8/6/2015	8/6/2015		CARPENTER TO REPAIR LOCKSET INSIDE DOOR MENS BATHROOM 1ST FLOOR
FO-323797	8/6/2015	8/10/2015		CARPENTER TO REPLACE 2ND & 3RD STAIRWELL THRESHOLD
FO-325655	8/6/2015			R/R Wood on back porch is starting to denigrate. 8/6/15 lps: Wrkng on req\ 8/26/15 lps: Spoke w/Dave K okay to for processing to Carp
FO-323839	8/6/2015	8/7/2015		R/R ENTRY Door #603-14E is still intermittently failing to latch; causing alarms.
FO-323856	8/6/2015	8/7/2015		HANDICAP DOOR ON WARREN(NORTHSIDE) THE HANDICAP BUTTON NOT WORKING WHEN STUDENTS TRYING TO ENTER. PLEASE REPAIR.
FO-323900	8/7/2015	8/13/2015		See Service Request 265487 from 4-20-15. I received an email this morning saying the work was finished. It is not. I was just in 101 State Hall and the lights are still out. This is an old EP...forward to electricians OPEN TO CARPENTERS:
FO-323907	8/7/2015			RM 7204 HAS 2 CLNG TILES SITTING ON FLR NEED TO BE REMOVED OR REPLACED IN CLNG
FO-323915	8/7/2015	8/10/2015		Purdy Library R/R RM 428 Door sticks; difficult to open or close. Closed area with limited access. Contact Richard for access ad3702@wayne.edu or 7-6307 Thank you.

WO	Recieved	Finished	Total	Request
FO-323917	8/7/2015	8/10/2015		R/R RM 354 Adjust door closers on both front and back entrances to the office so doors close and latch every time. This is a secure area and doors need to latch to lock. Contact person in office is Ed Bogardus (313)448-9400.
FO-323982	8/10/2015	8/11/2015		R/R RM 102 the wooden swinging door at the west end of the service desk is sticking and damaging the border of the wall. Can it be sanded and/ or adjusted so that it opens and moves easily. thanks Michelle
FO-323986	8/10/2015	8/28/2015		the interior doors are not closing properly when locked at 8:00 pm , students enter and door takes too long to close. Can you check for efficient closing? thanks Michelle
FO-325222	8/10/2015	8/25/2015		Public Safety - R/R RM 133 Dispatch Room 133 - Window blind broken Myron Harper 08/10/2015 14:04 -Request for estimate sent to Maintenance Trades. 8/10/15 lps: Chng to Est for Main 8/13/15 lps:Spoke w/Blake to rec'd an Acct # 8/24/15 lps: Spoke w/
FO-324055	8/10/2015	8/11/2015		R/R BLDG ENTRANCE Door 603-14E intermittently won't latch after card swipe. (REFER TO WO FO-323839 R/R ENTRY Door #603-14E is still intermittently failing to latch; causing alarms.)
FO-324045	8/10/2015	8/25/2015		R/R RM 133 Dispatch's east entry door fails to secure. Door needs to be rebuilt per carpenters.
FO-324073	8/10/2015	8/10/2015		CARPENTER TO INSTALL THRESHOLD 3RD FLOOR STAIRWELL B
FO-324092	8/11/2015	8/13/2015		The tile in the janitors office room 207 is broken and needs repair.
FO-324094	8/11/2015	8/28/2015		BOOMMERS TO SUPPLY 24X24 ACCESS PANEL
FO-324095	8/11/2015	8/12/2015		CARPENTERS, PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY NEAR ROOM 0402. PRIORITY-LOW
FO-324112	8/11/2015	8/12/2015		CARPENTERS REPLACE BROOKEN TILE HALLWAY OUTSIDE ROOM #4346
FO-324114	8/11/2015	8/12/2015		CARPENTERS TO REPLACE IN HALL WAY NEXT TO ROOM# 4347
FO-324119	8/11/2015	8/12/2015		Door to UGL Ladies Room in Suite 1600, Academic Success, is squeaking.
FO-324129	8/11/2015	8/21/2015		please replace marble top to both urinal walls in room 109 see Jerry S if you have questions.....
FO-324142	8/11/2015	8/12/2015		R/R BLDG ENTRANCE Door #603-09N stays slightly ajar if used.
FO-324184	8/12/2015			Carpenters, please replace stained ceiling tiles in front of 1st floor elevator.
FO-324198	8/12/2015			Carpenters, please replace stained ceiling tiles in front of 3rd floor elevator.
FO-324234	8/12/2015	8/13/2015		Door 155-18W won't latch intermittently. Door doesn't close flush and may be scraping the threshold.
FO-324253	8/12/2015	8/13/2015		Carpenters: please mount the door stop, it is knocked off the wall. Priority: low.
FO-324262	8/12/2015	8/13/2015		CARPENTER TO REPLACE WATER DAMAGED CEILING TILES DAVE'S & TIM'S OFFICE
FO-324263	8/12/2015	8/12/2015		CARPENTERS TO REHANG CABINET DOOR PRESIDENTS APARTMENT
FO-324272	8/13/2015	8/14/2015		CARPENTER TO REPLACE 2 CEILING TILES LADIES ROOM NEAR THE ELEVATOR IN THE BASEMENT MUST BE COMPLETED BY 8/21/2015
FO-324324	8/13/2015	8/17/2015		In Handicap Restroom 1st floor off lobby there is a ceiling tile that needs replacement. There was a leak from above that has been fixed and the tile has black stains from water leak. Please see Michael in the box office if you have questions or need ex
FO-324339	8/13/2015			CARPENTERS, REPLACE WATER DAMAGED DRYWALL & REPAINT @ WINDOW COVE.PRIORITY-LOW
FO-324342	8/13/2015			R/R RM 150/SVC CTR I NEED MWRF FORMS CUT IN HALF
FO-324343	8/13/2015			R/R RM 150/SVC CTR I NEED 2 BOXES OF COPY PAPER
FO-324350	8/13/2015	8/13/2015		CARPENTER TO TAKE APART DESK FOR GROUNDS ROOM #109
FO-324448	8/17/2015			Please install shelf in IBio penthouse for boiler chemical feed. Per Mark Allen
FO-324450	8/17/2015	8/18/2015		Carpenters: please replace damaged ceiling tiles in men's room 109. Priority: low.

WO	Recieved	Finished	Total	Request
FO-324710	8/17/2015	8/24/2015		Need ramp and automatic door installed on West entry of building. Or, doorway opened in wall that is blocking the hallway to room 133 to enable handicap access to room before classes start.
FO-324720	8/18/2015			R/R RM 4116 REPLACE WATER DAMAGED CEILING TILES
FO-324739	8/18/2015	8/19/2015		R/R RM 3243/Office Kirsten Carlson's need lock checked key doesn't go in lock.
FO-324792	8/18/2015	8/18/2015		CARPENTER TO REPAIR DOOR CLOSER ROOM #4200
FO-324812	8/19/2015	8/20/2015		CARPENTERS TO MAKE ELDON WATER TREATMENT PUMP COUNTER TOPS
FO-324828	8/19/2015	8/21/2015		Please repair door knob next to room 2268 for stairwell.
FO-324971	8/19/2015	8/20/2015		Purdy Library 4th Floor Room 450 Door difficult to open and close: door sticks in frame. Please repair. Thank you.
FO-324990	8/19/2015	8/21/2015		Carpenter replace damaged ceiling tile in lab space. Leak was repaired.
FO-325027	8/20/2015	8/24/2015		R/R RM 125 there are several DAMAGED/MISSING ceiling tiles in need to be replaced. This area falls within the KHS department 8/20/15 lps: I spoke w/Carol will have to separate req into 2 due to the painting is a reimburseable req & the ceiling tiles wil
FO-325028	8/20/2015	8/24/2015		R/R RM 125.1 there are several DAMAGED/MISSING ceiling tiles in need to be replaced. This area falls within the KHS department 8/20/15 lps: I spoke w/Carol will have to separate req into 2 due to the painting is a reimburseable req & the ceiling tiles w
FO-325038	8/20/2015	8/21/2015		R/R RM 3501 Door cannot be opened. Key turns in lock, but handle does not move.
FO-325045	8/20/2015	8/21/2015		Adding Carpenters: Please replace ceiling tiles in room 0346. Ceiling leak - repair leak and need new tile.....ME....8/19/15
FO-325077	8/20/2015	8/21/2015		Please replace damaged ceiling tiles in Conference Room 3 and adjacent Print Room that were damaged by water leak. See Sandy or Alicia for location if you need help.
FO-325081	8/20/2015			R/R BLDG We would like to have the all the plastic sleeves removed from the Law School main doors, facing Palmer St.(Glass Breezeway) Please note that this includes removing the sticky glue too.
FO-325098	8/21/2015	8/21/2015		CARPENTERS TO REINSTALL CENTER DOOR MULLION FIRST FLOOR DOOUBLE LEADING TO THE OLD WING OF THE BUILDING
FO-325115	8/21/2015			Adding Carpenters. Please provide rolling scaffold and install plywood to support floor drains for plumbers. See Mike Pummill or Gerry Simancas for details. Please replace drain pipe connected to Floor drains in green house.....GS....8/21/15
FO-325118	8/21/2015	8/25/2015		Adding Carpenters: Please Replace ceiling tiles in room 4126 Rm. 4126 needs to be checked/repared for leakage in ceiling. There are stained tiles. Once leaks are checked the tiles should be replaced.....JH.....8/19/15
FO-325140	8/21/2015			Carpenter: Please replace ceiling tile that was removed from pipe leak. Room # 59
FO-325141	8/21/2015	8/25/2015		Purdy Library R/R 3rd Floor Room 335 (Custodial Closet) Door difficult to open. Please repair. Thank you.
FO-325142	8/21/2015	8/25/2015		Purdy Library R/R 4th Floor Room 439 (Custodial Closet): Door difficult to open. Please repair. Thank you.
FO-325144	8/21/2015	8/24/2015		Purdy Library R/R 4th Floor Room 428 Three additional entrance doors are difficult to open (sticking in frame). Please repair.The main door was repaired on Thursday, August 20th and is working just fine.Thank you.
FO-325184	8/24/2015	8/24/2015		CARPENTERS TO INSTALL SHELF FOR CHEMCALS FEED PUMPS
FO-325229	8/24/2015	8/25/2015		Bumper needs to be reattached to wall by room 223 door.
FO-325249	8/24/2015			CARPENTERS TO REPLACE ALL DAMAGED CEILING TILES & REPAIR GRID ALL ROOMS DAYCARE

WO	Recieved	Finished	Total	Request
FO-325318	8/25/2015	8/27/2015		door leading from building into the garage is not closing completely. It need to be adjusted.
FO-325328	8/25/2015	8/28/2015		Carpenter repair front door (609.02.S). Door is scraping on the bottom preventing door from closing all the way.
FO-325334	8/25/2015	8/27/2015		Door 155-22BN stays ajar intermittently; scraping threshold.
FO-325339	8/25/2015	8/26/2015		Lock on door needs to be fixed
FO-325364	8/25/2015			Carpenters-Please rebuild ceiling in office area. Heat pump Replacement complete. From FO 311900
FO-325366	8/25/2015			Carpenters-Please rebuild ceiling in hallway outside room 10507. Heat pump Replacement complete. From FO 311899
FO-325368	8/25/2015	8/26/2015		Door gasket needs to be repaired for rooms 2369 and 2308.
FO-325414	8/26/2015	8/27/2015		Gasket needs to be replaced on door frame in 1336.
FO-325446	8/26/2015	8/27/2015		UGL Collaborative Study Room 2545 door handle in need of repair.
FO-325479	8/26/2015	8/26/2015		CARPENTERS TO LOCKSET SOUTH GATE WEST SIDE TICKETS BOOTHS
FO-325492	8/27/2015			CARPENTERS TO REMOVE GLASS NORTH END TO ACCOMIDATE THE ELECTRICIANS
FO-325495	8/27/2015			ADDING CARPENTERS, PLEASE REPLACE MISSING CEILING TILES IN ROOM 013.....(**) PO REQ DK 7/14 **LEAK STOPED / COIL TO BE ORDERED JWT RM 13 CEILING LEAK, LEAKING ON EQUIPMENT JH/6-24-15
FO-325509	8/27/2015			Doors 01E thru 04E need back-check adjustment on door closers
FO-325545	8/27/2015			CARPENTERS,PLEASE REPLACE WATER DAMAGED CEILING TILES IN HALLWAY AT THE FREIGHT ELEVATOR IN THE E-SUBBSMT.PRIORITY-LOW
FO-325575	8/28/2015	8/28/2015		CARPENTERS TO REPAIR BEDROOM CLOSET DOOR PRESIDENTS APARTMENT
FO-325579	8/28/2015			ADDING CARPENTERS REPLACE CEILING TILES IN BASEMENT NEAR WOMENS RESTROOM.....Ceiling by women's locker room has water dripping. ME/8-24-15
FO-325592	8/28/2015	8/28/2015		COPY MACHINE CARPENTER SHOP TOSHIBA STUDIO 230 REPLACEMENT INK TONER CARTAGE
FO-325631	8/28/2015	8/28/2015		# 505 HECKER HOUSE ASSEMBLE TREADMILL MRS WILSON
T - Electrician			148	
FO-323420	8/3/2015			Old Main - Cass Avenue entrance - lollipop lights along the sidewalk leading up the entry doors are not working.
FO-323410	8/3/2015			Time for Laborer to clean shops for the Trades.
FO-323412	8/3/2015	8/31/2015		Time for Electricians to repair clocks throughout campus. Completed 8-31-2015 SRP
FO-323413	8/3/2015	8/3/2015		Deliver a pallet of lamps to the Retro-Lighting Crew, at Physics.
FO-323415	8/3/2015			Team Leader Administrative Time.
FO-323426	8/3/2015	8/6/2015		The Lights switch just past the passenger elevator needs to be repaired or replaced. (1st floor)
FO-323434	8/3/2015	7/31/2015		Please troubleshoot and restore power at Chemistry.
FO-323447	8/3/2015	8/3/2015		Light fixture is hanging in the student lounge.
FO-323450	8/3/2015	8/6/2015		pls deliver 1 keg of lokor to the comp center asap
FO-323476	8/3/2015			Adding Electrician: Please connect new sump pump and float switch. See Don Bear Install new sump pump rm 179 that has been received from FO#298137 DB/7-28-15
FO-323477	8/3/2015	8/3/2015		Assist Generator Mechanic in accessing generators.
FO-323560	8/4/2015			Broken Light cover
FO-323562	8/4/2015	8/10/2015		Due to the power outage, the following light fixtures have seven electrical problems: The hallway along side of rooms 1215, 1264, 1321, 1324, 1501, and 1505.
FO-323570	8/4/2015			Due to the power outage, 2 mercury bulbs have electrical problems: Wall lights across from room 1600.

WO	Recieved	Finished	Total	Request
FO-323572	8/4/2015	8/11/2015		Room 1306 has an electrical problem.
FO-323574	8/4/2015	8/11/2015		Due to the power outage, the light over the lockers across from 364 has an electrical problem. (Basement)
FO-323576	8/4/2015	8/17/2015		Due to the power outage, the mercury bulb has between STAIR A and the elevators has an electrical problem. (2nd floor)
FO-323578	8/4/2015			Due to the power outage, the mercury bulb between STAIR A and the elevators has an electrical problem. (5th floor)
FO-323587	8/4/2015			Due to the power outage, the following areas have 2 electrical problem: Hallway along side of rooms 3341 and 3363.
FO-323625	8/4/2015	8/6/2015		EXIT sign outside of room 022 has an electrical problem.
FO-323626	8/4/2015	8/6/2015		EXIT sign out outside of rooms 250 and 253 have 2 electrical problems.
FO-323668	8/4/2015	8/5/2015		ELECTRICIANS (FIRE DOOR) FIRE DOOR OUTSIDE OF ROOM 2305 AT SCOTTHALL WILL NOT LOCK IN PLACE. REPAIR Completed 8-5-2015 SRP
FO-323690	8/4/2015			Room 317 - 1 EP *The room is alarmed - please see building coordinator.*
FO-323699	8/5/2015	8/10/2015		Gilmour Mall - Three light poles burned out along Gilmour Mall between the Presidents Apt and the Cohn Bldg
FO-323719	8/5/2015			The men's restroom has 1 electrical problem. (8th floor)
FO-323721	8/5/2015	8/7/2015		To laborer. R/R RM 425/MECH BLR RM Please remove three old chemical tanks from Music boiler room.
FO-323726	8/5/2015	8/7/2015		2 EPS - Room 309 and 310 - the fixtures are locked. One fixture in each room clearly tagged.
FO-323727	8/5/2015	8/6/2015		2 EP - Room 112 - Whole fixtures are out. They are tagged clearly.
FO-323739	8/5/2015	8/6/2015		Light over the stairwell between the 1st and 2nd floor. The stairwell faces Palmer. Completed 8-6-2015 SRP
FO-323811	8/6/2015	8/10/2015		The hallway just past the elevator has an electrical problem. (2nd floor)
FO-323812	8/6/2015	8/10/2015		Hallway outside of Range 129 has an electrical problem. (1st floor)
FO-323822	8/6/2015	8/11/2015		ELECTRICIANS TO DISCONNECT ADA OPERATOR FOR BRUCE LANGLEY EAST EXIT VESTIBULE DOOR (SEE BRUCE) Completed 8-11-2015 SRP
FO-323857	8/6/2015			3rd fl, reading room, will need a ladder, 1 LO.
FO-323901	8/7/2015			LABORER (HIGH) R/R PH PLEASE DELIVER TO SCOTTHALL 1) NITROKLENZ 17010050 30 PAILS 2) HALOCHLOR 17010100 10 PAILS 3) AQUAKLEEN 17010106 10 AILS 4) LOKOR 17010060 30 PAILS 5) SALT 17010010 1 PALLET 8/7/15 lps: Spoke w/Orlandis says
FO-323902	8/7/2015	8/7/2015		LABORER (HIGH) R/R RM 402 DELIVER TO MEDICAL COMMONS 1) 2 PAILS HALOCHLOR 17010100 2) 2 PAILS NITROKLENZ 17010050 3) 2 PAILS AQUAKLEEN 17010106 4) 5 PAILS LOKOR 17010060 5 PAILS FO#297744 8/7/15 lps: Spoke w/Orlandis okay for delivery for Monda
FO-323908	8/7/2015			2 wall lights between the custodial closet and the stairwell have 2 electrical problems. (Basement)
FO-323929	8/7/2015	8/10/2015		Delivery 20 bags of softener salt to MEB. See Engineer Jeff Davis 248-797-0099.
FO-323916	8/7/2015			Light fixtures with burned out tubes in rm. 5364 and light fixtures with burned out tubes in room 5370. There are 2 electrical problems in room 5364. There is 1 electrical problem in room 5370.
FO-323933	8/7/2015	8/7/2015		ADDING LABORER....PLEASE TAKE WELDER TO ST ANDREWS CHURCH SEE ERIC FOR DETAILS.....please repair loose railing on the southside stairs.....EA....8-5-15

WO	Recieved	Finished	Total	Request
FO-323947	8/7/2015			Room 125 - 1 1/2 EPs 1) Upon entering the room - directly overhead. 1/2) Fixture tagged middle of the room.
FO-323969	8/8/2015	8/8/2015		Need PM Technologies to repair Radiator on Generator #2, the Radiator is seeping Coolant, and all the bolts has to be tightened up all the way around the Radiator.
FO-323971	8/8/2015	8/8/2015		Need to have PM Technologies repair the Crankcase Breather hose, and correct a Diesel Leak.
FO-323983	8/10/2015	8/10/2015		Laborer; Medium R/R R 00195/MECH-BLR RM Please have the laborer bring over 1) two drums open water loop chemicals. 2) One drum of Halochlor C 3) One drum of Lokor 2000 TM
FO-324138	8/11/2015	8/28/2015		Take Van to Dealership, drop off keys, and have them programmed. Completed 8-28-2015 SRP
FO-324144	8/11/2015	8/31/2015		Room 5018 - EP - 4 Fixtures out - half of room is out. Lights have been replaced.
FO-324145	8/11/2015			OSR - 232 - 1 EP - Outside room 232 in hallway taped.
FO-324152	8/12/2015			please chk hand dryers inop in both 102 and 104 bathrooms.....thx
FO-324162	8/12/2015			Electricians, R/R RM, 00017/WOMENS RR please replace light in basement ladies restroom, electrical problem.
FO-324200	8/12/2015			R/R BSMT HALLWAY OUTSIDE OF RMS 11 & 54 REPLACE TAGGED LITES/EP
FO-324205	8/12/2015			R/R 3RD FLR HALLWAY OUTSIDE OF RMS 313, 327, 329, 3RD FLR OUTSIDE OF PASS ELEV & NEAR #2 STRWL/RM 375 REPLACE TAGGED LITES/EP
FO-324206	8/12/2015			R/R 3RD FLR MECH RM REPLACE TAGGED LITES/EP
FO-324207	8/12/2015			R/R RM 357 REPLACE TAGGED LITES/EP
FO-324208	8/12/2015			R/R RM 460 REPLACE TAGGED LITES/EP
FO-324213	8/12/2015			R/R 4TH FLR OUTSIDE OF SVC. ELEV. REPLACE TAGGED LITES/EP
FO-324222	8/12/2015			R/R 2ND FLR HALLWAY OUTSIDE OF RM 208 Exit sign in hallway outside of room is blinking.
FO-324225	8/12/2015			Repair or Replace light fixture in room 9374. It's in Dr. Wael Sakr's office. The light cover will not go back up into fixture.
FO-324226	8/12/2015			Labore- Tower chemicals- med priority. R/R RM 3237/MECH RM Please deliver 2 barrels each of the following chemicals, 1) 2 BARRELS Aquaclean, 2) 2 BARRELS Lokor, 3) 2 BARRELS Halochlor. and 4) 2 boxes of Nithawk gloves large.
FO-324257	8/12/2015	8/18/2015		ELECTRICAL DEPT- R/R RM 603/MECH RM PLEASE HAVE LABORER DELIVER 1) KEG OF HALOCHLOR C TO MECH ROOM 603 PRIORITY MED
FO-324280	8/13/2015			R/R OUTSIDE Several light posts along Gullen Mall in front of the Linsell House are burned out.
FO-324281	8/13/2015	8/20/2015		Matthaei R/R OUTSIDE - Several exterior lights on the north side of the bldg are burned out.
FO-324287	8/13/2015	8/24/2015		Chemistry Bldg - rooftop lights on the north edge of the bldg are burned out
FO-324289	8/13/2015			Undergraduate Library - R/R OUTSIDE Several exterior lights underneath the overhang around the bldg are burned out
FO-324285	8/13/2015			McGregor - R/R OUTSIDE the two light poles in the lawn between the McGregor Conference Center and the Alumni House are burned out.
FO-324386	8/13/2015			Parking Lot 11 - Blue light phone light in the middle of the parking lot is burned out. Tonya Jones 08/14/2015 11:39 - Per Eugene, this is reg maint 8/13/15 lps: Chng to Est for Main
FO-324298	8/13/2015			Range 139 has an electrical problem.

WO	Recieved	Finished	Total	Request
FO-324301	8/13/2015			Hallway outside of range 173 has an electrical problem.
FO-324303	8/13/2015			The entrance light has an electrical problem.
FO-324304	8/13/2015			Overhead light across from the elevator has an electrical problem. (1st floor)
FO-324305	8/13/2015			Light over the Einstein Brothers food cart. (1st floor)
FO-324306	8/13/2015			Hallway outside room 1111.
FO-324309	8/13/2015			Ramp surrounding room 1120 has 2 electrical problems.
FO-324320	8/13/2015	8/18/2015		Within Suite 200, ladies bathroom, light bulb out over the sink. Needs to be replaced. As soon as I replaced the bulb, there was a loud buzzing noise coming from the fixture.
FO-324355	8/13/2015			inquire into replacing the lights of Shiffman library, specifically the lights which illuminate the letters on the outside of the building, check Photo-cell/Timer.
FO-324365	8/14/2015	8/18/2015		Third Floor Clock on mid-point pillar facing UGL Bernath Seminar Room is in need of repair. Completed 8-18-2015 SRP
FO-324388	8/14/2015			Office 1117 has a set of fluorescent lights that are off. Can contact Yinlun Huang at 7-3771 for replacement. Thank you. There is 1 EP directly over the Professor's desk.
FO-324390	8/14/2015			Student Affairs, suite 1600-3 fixtures in the hallway of the suite were impacted by the power shut down and all of the bulbs in the 7 ceiling lights are out. There are 2 electrical problems.
FO-324428	8/17/2015			The globe light in the Speech and Language Center has an electrical problem. (1st floor)
FO-324429	8/17/2015			EXIT sign in the stairwell landing facing Woodward Ave. has an electrical problem. (1st floor)
FO-324430	8/17/2015			EXIT sign facing the parking structure near the stairwell that went upstairs to DAPCEP. (1st floor)
FO-324441	8/17/2015			Hallway along side of rooms 1264,1324,1501 and 1505 have electrical problems.
FO-324449	8/17/2015			Please install plug for chemical feed systems Per Mark Allen
FO-324468	8/17/2015			remove device for carpenter to change tile. call pat 734/624/7465
FO-324469	8/17/2015			Repair lens cover that has fallen down and replace bad lamp in Presidents Apartment.
FO-324484	8/17/2015			Room 4545 - There are lights that need to be replaced. Thanks! There are 2 electrical problems.
FO-324492	8/17/2015	8/17/2015		open locks to generators for PM
FO-324494	8/17/2015			The women's restroom has an electrical problem. (1st floor)
FO-324504	8/17/2015			Repair motor starter serving AHU-2 Art Building. The fan is located in mechanical room in the basement of the Art Building. Starter will not reset. NOTE: A new motor was installed recently and the heaters were too small. This may not have been corrected.
FO-324506	8/17/2015			Repair fire trouble, McGregor Simplex panel showing "Lobby Area Smoke Detector" trouble.
FO-324725	8/18/2015			1 EP in the press box just as you go up the stairs to second floor.
FO-324728	8/18/2015			Hallway outside of the guard's desk. (1st floor)
FO-324731	8/18/2015			Hallway between the elevators and STAIR A has an electrical problem. (4th floor)
FO-324760	8/18/2015			Student Affairs (suite 1600) has 6 lights out in the hallway of the suite. See FO-324390
FO-324772	8/18/2015			1 EP -Room 1209 - in the intern office.
FO-324776	8/18/2015			1 EP - The fixture is out at the second door to the room; next to exit sign.
FO-324777	8/18/2015			1 EP - StairwellD (basement) - the fixture is the only wall light there is tagged.
FO-324780	8/18/2015			2 EPs - 351 & 325, both of these fixtures are located in hallway above these room numbers. Tagged clearly.
FO-324814	8/19/2015			Please have laborer deliver 2 5-gallon pails of Oxycor and 2 5-gallon pails of Neutrmine to Music boiler room.
FO-324830	8/19/2015			Light flickering in room 117 Cohn. There is 1 electrical problem.
FO-324975	8/19/2015			scaffold to be built in room #1515 #1535 #1545 #1550 see phil and steve
FO-325017	8/20/2015			Hallway between the tables and Range 173 has an electrical problem.
FO-325018	8/20/2015			Hallway outside of Range 19 has an electrical problem. (Basement)

WO	Recieved	Finished	Total	Request
FO-325020	8/20/2015	8/21/2015		Room 1545 has 2 electrical problems. Completed 8-21-2015 SRP
FO-325040	8/20/2015			Maintenance Request. R/R OUTSIDE Request WSU Electricians to repair sidewalk lighting around Athletics Campus. 9 pole lights (FBE-8, FBE-2, BB-5, BB-3, TBS-6, TBS-2, MW-12, MW-10, MW-3); 1 Missing Pole (MW-11); 1 bad pole base (MW-8); two parking light
FO-325054	8/20/2015			Room 131 - 1EP - The fixture is to your right hand side of the door entrance. It will be above you.
FO-325087	8/20/2015			Time for PM Technologies to repair radiator cap on Generator.
FO-325100	8/21/2015			Please have Maintenance Laborer take wooden pallets to Holden Warehouse.
FO-325119	8/21/2015			Trade: Laborer Priority: High R/R RM 00000.62/MECH-BLR RM Please deliver 1) one pallet of salt to the Chemistry sub-basement.
FO-325154	8/21/2015			WSU Electricians to install automated ball valve wiring, conductivity wiring for the automated blowdown control. Per Mark Allen.
FO-325161	8/21/2015			1 EP - Exit 4, first floor: The fixture is on the long hall leading to science hall, first floor.
FO-325171	8/21/2015			Room 135 - 1EP - Room 135: The fixture is overhead of the entrance to the room. It needs bulbs and cover as well.
FO-325172	8/21/2015			Room 1330 - 1EP
FO-325193	8/24/2015			Lights out on second and third floors of UGL: parts of 24 fixtures on second floor and parts of 10 fixtures on third floor (these are tube lights with three tubes each in one fixture).
FO-325200	8/24/2015			Light Timer for room 0229 is fried. Cannot reset it. Please replace ASAP.
FO-325205	8/24/2015			Electrician; SIEMENS High R/R E. WOODWARD LOBBY/SECURITY DESK Please repair/replace the NCC Monitor Panel located at the Security Desk. The unit is down and does not respond. The unit has been down for six months, this is another work request for the
FO-325204	8/24/2015			Electrician; High R/R RM 15100.10/MECH RM Please Repair/replace the Duct sensor for the exhaust fan #2 ceiling. The device is a trouble alarm on the Siemens Firefinder System. 8/24/15 lps: Spoke w/Bill W says this is Siemens Fire Sprinkler Sys Com
FO-325208	8/24/2015	8/25/2015		Electrician; SIEMENS High R/R RM 15000 Please repair/replace the smoke device. The device is a trouble alarm on the Siemens Firefinder System. 8/24/15 lps: Spoke w/Bill W says this is Siemens Fire Sprinkler Sys Completed 8-25-2015 SRP
FO-325209	8/24/2015	8/26/2015		Electrician; SIEMENS High R/R RM 15022 Please repair/replace the smoke device. The smoke device is located in the Pipe Chase Closet. The device is a trouble alarm on the Siemens Firefinder System. 8/24/15 lps: Spoke w/Bill W says this is Siemens Fir
FO-325203	8/24/2015			Laborer, Please deliver a pallet of softener salt to the basement via the freight elevator. Please bring pallet jack.
FO-325211	8/24/2015			Please have Laborer deliver 1) 1 pallet of nitroclenze to the penthouse at scotthall thankyou
FO-325272	8/24/2015			Take truck to Goodyear to have tire fixed.
FO-325296	8/25/2015			Tools needed for the Electric shop.
FO-325301	8/25/2015			Electrician, Low, Please replace lamp to exterior light fixture on West side of building, the South fixture, Thank you. Jeffrey L. Davis
FO-325304	8/25/2015			Outside light along side of the Knapp bldg. It's a mercury bulb.
FO-325305	8/25/2015			Hallway light near room 065.

WO	Recieved	Finished	Total	Request
FO-325306	8/25/2015			Room 200 has an electrical problem. Also, I noticed that 1 of the fixtures is partially detached from the ceiling. Room 200 is in back of the Hoobler lounge.
FO-325312	8/25/2015			HWHP-2 located in the basement pump room next to the elevator at UGL will not run. Please restore to service.
FO-325329	8/25/2015			Room 241 - 4 LO. There is 1 electrical problem in room 241.
FO-325374	8/25/2015			Handy man: Please remove old chemical tanks from boiler room.
FO-325402	8/26/2015			Room 2333 has an electrical problem.
FO-325405	8/26/2015			EXIT signs outside of rooms 9263,9374 and STAIR A. (9th floor)
FO-325452	8/26/2015			Wall light next to room 258 has an electrical problem. A GIRF will need to be created.
FO-325453	8/26/2015			2 mercury lights over the basketball courts has 2 electrical problems. A lift may be needed. A GIRF will need to be created.
FO-325457	8/26/2015			3 long tubes out in 5530 animal lab call Serena 71631 between 7 am-3 pm. 1 electrical problem.
FO-325472	8/26/2015			Lights out under the cabinets. Ask for Sue. There are 5 electrical problems.
FO-325488	8/26/2015			MD Lab 2333, Relamp flickering ceiling light at back of lab, near the inner lab. There is 1 electrical problem.
FO-325506	8/27/2015			LIGHTS BLOWN OUT. ROOM 8402.23. There is 1 electrical problem.
FO-325510	8/27/2015			Go to Ford Dealership, and pick up new key for truck. They also have a tire that was repaired, pick it up too.
FO-325515	8/27/2015			Doorbell at front entrance is sticking. At times can hear it in the kitchen and not in the front, at times doesn't ring at all
FO-325513	8/27/2015			There is 1 EP outside mens room on 4th floor There is 1 Ep outside mens room of 3rd floor There is 1 EP outside room 361 2 doors from mens room..
FO-325517	8/27/2015			LIGHTS OUT IN FUME HOOD. ROOM 7223.
FO-325520	8/27/2015			The lounge area has 1 electrical problem.
FO-325521	8/27/2015			Both entrances in the men's and women's restroom have electrical problems. Both restrooms are across from room 1120.
FO-325533	8/27/2015			Please have delivered to rm. 25, three 5 gallon Aquaklean, three 5 gallon Lokor, and three 5 gallon pails of Halochlor.
FO-325546	8/27/2015			3 North lights - only half of the hallway lights working- is there a short we've had this problem corrected twice this year. Electrical problem
FO-325548	8/27/2015			Lighting Crew; Medium Please replace the burned out lights in the boiler room area.
FO-325556	8/27/2015			Room 225 - sparks coming out of light sockets.
FO-325608	8/28/2015			Please replace batteries in "Exit" signs and emergency lighting units outside room 313. Per William Kemp of Risk Management.
FO-325610	8/28/2015	8/31/2015		Please fix the time on the clock in Room 316 State Hall. Completed 8-31-2015 SRP
T - Laborer			1	
FO-324960	8/19/2015			LABORER: Please have Laborer transport material form stock room to State Hall. See Gerry Simancas
T - Locksmith			126	
FO-323425	8/3/2015	8/12/2015		33-Keys for Hecker Mansion
FO-323480	8/3/2015	8/10/2015		New KeyNew Staff MemberKey #: 7AA 17.2Key Holder ID: Debra C. MazurQty: 5action: need 5 keys for new faculty, chair & PTF.Account #: 126401
FO-323484	8/3/2015			Need a key for carts locked up.
FO-323536	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 73928Key Holder ID: Terrie PickeringQty: 2action: 2 duplicate keys for room 151Account #: 126780
FO-323537	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 15697Key Holder ID: Terrie PickeringQty: 2action: 2 duplicate keys for room 323Account #: 126780
FO-323538	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 15729Key Holder ID: Terrie PickeringQty: 2action: 2 duplicate keys for room 331Account #: 126780

WO	Recieved	Finished	Total	Request
FO-323539	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 15730Key Holder ID: Terrie PickeringQty: 2action: 2 duplicate keys for room 334Account #: 126780
FO-323540	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 15734Key Holder ID: Terrie PickeringQty: 3action: 3 duplicate keys for room 348Account #: 126780
FO-323541	8/3/2015	8/19/2015		New KeyNew Staff MemberKey #: 28025Key Holder ID: Terrie PickeringQty: 3action: 3 duplicate keys for room 433Account #: 126780
FO-323718	8/5/2015	8/13/2015		Core Change Lost / Stolen Key #: Core, AA14, Key 036977 Key Holder ID: Angelica Reyna Qty: 1 new core, 3 new keys action: Replace core and make 3 new keys. Emergency core is in place please return emergency core back to the front desk, EMER11.
FO-323766	8/5/2015	8/18/2015		New KeyNew Space AssignmentKey #: 41145Key Holder ID: P. SealsQty: 10action: Requesting keys for:10 keys - #41145, Rm. 12212.110 Keys - #41144, Hall Corridor
FO-323801	8/5/2015	8/14/2015		Core Change and KeysLost / StolenKey #: 16EG27Key Holder ID: Eric JohnsonQty: 1 core and 4 keysaction: Core is the incorrect series for the 3rd floor at UT. Please supply 1 core and 4 keys.Account #: 228184Reference Work Order FO-323216
FO-323796	8/5/2015	8/14/2015		New Key and New CoreLost / StolenKey #: 62154 Key Holder ID: Cindy HildrethQty: 1 core and 4 keysaction: 1 new core and 4 new keysAccount #: 228400
FO-323798	8/5/2015	8/13/2015		New Key and New Core Lost / Stolen Key #: 4322AF Key Holder ID: Cindy Hildreth Qty: 1 mailbox core and 4 new keys action: 1 mailbox core and 4 new keys Account #: 228400
FO-323825	8/6/2015	8/14/2015		New KeyNew Staff MemberKey #: 38978/9FC13Key Holder ID: Delores CowenQty: 2action: additional keysAccount #: 126611
FO-323851	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 10A7/3Key Holder ID: Sarah HamzaQty: 1action: 1 key for room 1374.1 Scott Hall. Approved by Sayf Fathy.
FO-323853	8/6/2015			New KeyDamagedKey #: #89842-2Key Holder ID: Brenca ContractorsQty: 1action: Existing Brown Box key is not working.Please call if you have any questions. 577-0478.
FO-323867	8/6/2015	8/14/2015		New KeyNew Space AssignmentKey #: B LG1.52Key Holder ID: Nick DeNardisQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my know
FO-323868	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11E LG1.51Key Holder ID: Catherine SiladiQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowle
FO-323869	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11 LG1.7Key Holder ID: Christa MowryQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323870	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG6Key Holder ID: Christopher WilliamsQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowled
FO-323871	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG6Key Holder ID: Amy RobergeQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323872	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG16Key Holder ID: Alexander BienkowskiQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowle
FO-323873	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG8Key Holder ID: Kristin CopenhaverQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge
FO-323874	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG6Key Holder ID: Julie HasseQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.

WO	Recieved	Finished	Total	Request
FO-323875	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG3Key Holder ID: Mike BrinichQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323877	8/6/2015	8/18/2015		New KeyLost / StolenKey #: 11LG3Key Holder ID: Arthur LionasQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323878	8/6/2015	8/18/2015		New KeyLost / StolenKey #: 11LG9Key Holder ID: Rasheda WilliamsQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323879	8/6/2015	8/18/2015		New KeyLost / StolenKey #: 11LG10Key Holder ID: Shawn WrightQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323880	8/6/2015	8/18/2015		New KeyLost / StolenKey #: 11LG5Key Holder ID: Thomas ReynoldsQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323882	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG4Key Holder ID: Matt LockwoodQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323883	8/6/2015	8/14/2015		New KeyLost / StolenKey #: 11LG2XKey Holder ID: Michael WrightQty: 1action: New key for office so that employee can be sure to lock it when not in it. Do not have any previous keys that might have been issued for this office to my knowledge.
FO-323885	8/6/2015	8/17/2015		New KeyNew Staff MemberKey #: 71036-1Key Holder ID: Eric GreeneQty: 1action: Opens the C&IT Desktech office in FAB, 4311.Account #: 153736
FO-323886	8/6/2015	8/18/2015		New KeyNew Staff MemberKey #: 66302-3Key Holder ID: Eric GreeneQty: 1action: Opens closet that student assistants and supplies are stationed.Account #: 153736
FO-324149	8/6/2015	8/19/2015		Core Change Lost / Stolen Key #: 9ZCB16X Key Holder ID: Dean of Students/Student Affairs Suite Qty: 5 action: Administration is concerned that a recently terminated employee will attempt to gain access to the Dean of Students/Student Affairs Offi
FO-323887	8/6/2015	8/18/2015		New KeyNew Staff MemberKey #: 2547-4Key Holder ID: Eric GreeneQty: 1action: Opens server room that C&IT DeskTech personal services.Account #: 153736
FO-323935	8/7/2015	8/14/2015		New KeyNew Space AssignmentKey #: 13509Key Holder ID: Steven Johnson/Sector 5Qty: 2action: I need two keys, one for the sector supervisor and another for the custodian.
FO-323978	8/7/2015	8/14/2015		New KeyNew Space AssignmentKey #: 113X, 138X & X3171Key Holder ID: Kumash ShahQty: 1 eachaction: Please issue the following keys to Engineer K. Shah due to difficulty accessing buildings after hours:X3171 - Alumni Hse Front Door113X - McGregor F
FO-323979	8/7/2015	8/14/2015		New KeyLost / StolenKey #: 63167Key Holder ID: Cindy HildrethQty: 1 keyaction: One key made for room 1121.5 AKey is not lost. Housing never ordered the correct number of keysAccount #: 228400
FO-324030	8/10/2015	8/13/2015		New KeyNew Space AssignmentKey #: Best Log FixKey Holder ID: 13187Qty: 1action:
FO-324047	8/10/2015	8/12/2015		Core ChangeLost / StolenKey #: core 17AAA52, key 33854Key Holder ID: Donnella JohnsonQty: 1 mailbox core, 1 door core, and 3 keysaction: new core for room door and new core for mailbox. 3 keysAccount #: 228300
FO-324049	8/10/2015	8/13/2015		Core Change and KeyLost / StolenKey #: core 17AAB7, key 33874Key Holder ID: Donnella JohnsonQty: 1 mailbox core, 1 room core, and 3 keysaction: 1 mailbox core, 1 room core and 3 keysAccount #: 228300
FO-324050	8/10/2015	8/13/2015		New KeyNew Space AssignmentKey #: 10GS12Key Holder ID: James Lightbody 7-1505Qty: 2action: Need keys ASAP. Leave for med school courier pick up.
FO-324051	8/10/2015	8/13/2015		New KeyNew Space AssignmentKey #: 10GJ2Key Holder ID: Drs. Vinogradov & JohnsonQty: 2action: Keys to be picked up by med school courier.
FO-324052	8/10/2015	8/12/2015		Core Change and KeyLost / StolenKey #: core17AAB13, key 33880Key Holder ID: Donnella JohnsonQty: 1 mailbox core, 1 room core and 3 keysaction: 1 mailbox core, 1 room core and 3 keysAccount #: 228200

WO	Recieved	Finished	Total	Request
FO-324054	8/10/2015	8/12/2015		Core ChangeLost / StolenKey #: core 17AAC28, key 33960Key Holder ID: Donnellla JohnsonQty: 1 mailbox core, 1 room core and 3 keysaction: 1 mailbox core, 1 room core and 3 keysAccount #: 228200
FO-324057	8/10/2015	8/12/2015		Core ChangeLost / StolenKey #: core 17AAA63, key 34027Key Holder ID: Donnellla JohnsonQty: 1 mailbox core, 1 room core, 3 keys action: 1 mailbox core, 1 room core and 3 keys. Temp core is installed door please return to front desk. Account
FO-324058	8/10/2015	8/12/2015		Core ChangeLost / StolenKey #: core 17AAD6, key 34003Key Holder ID: Donnellla JohnsonQty: 1 mailbox core, 1 room core, and 3 keysaction: 1 mailbox core, 1 room core and 3 keysAccount #: 228200
FO-324059	8/10/2015	8/13/2015		Core ChangeLost / StolenKey #: core17AAE64, key 34126Key Holder ID: Donnellla JohnsonQty: 1 mailbox core, 1 room core, and 3 keysaction: 1 mailbox core, 1 room core and 3 keysAccount #: 228200
FO-324060	8/10/2015	8/19/2015		New KeyDamagedKey #: key code 33813Key Holder ID: Donnellla JohnsonQty: 1action: 1 key madeAccount #: 228200
FO-324061	8/10/2015	8/19/2015		New KeyDamagedKey #: key code 33991Key Holder ID: Donnellla JohnsonQty: 1action: 1 key madeAccount #: 228200
FO-324062	8/10/2015	8/19/2015		New KeyDamagedKey #: key code 33955Key Holder ID: Donnellla JohnsonQty: 1action: 1 key madeAccount #: 228200
FO-324064	8/10/2015	8/19/2015		New KeyDamagedKey #: key code 34018Key Holder ID: Donnellla JohnsonQty: 1action: 1 key madeAccount #: 228200
FO-324065	8/10/2015	8/19/2015		New KeyDamagedKey #: key code 34118Key Holder ID: Donnellla JohnsonQty: 1action: 1 key madeAccount #: 228200
FO-324496	8/11/2015	8/19/2015		Core ChangeNew Staff MemberKey #: XOE(next available) (3) 25296Key Holder ID: Maureen KempQty: 4 action: I need four cores requested. Two for padlocks engineer key (engineer has padlocks). Two for cabinet core. One engineer, one xoe core key
FO-324151	8/11/2015	8/13/2015		New KeyNew Staff MemberKey #: W-71Key Holder ID: Karen WilsonQty: 1action: Please call when ready to pick up.
FO-324210	8/12/2015	8/13/2015		ReplacementLost / StolenKey #: Key # 109726 - B311 & 14A4Key Holder ID: Bob OQty: 2 keys eachaction: 2 keys for New Volleyball team room - key # 109726 2 keys for Boiler Room - key # 14A4 2 Keys - Outside Athletic Fields B311Account #: N/C
FO-324273	8/12/2015	8/20/2015		New KeyLost / StolenKey #: unknownKey Holder ID: Andrew Kulek, Sharon PepeQty: 2action: Requesting two new keys, one for Andrew Kulek and a spare for Sharon Pepe. Thank you.
FO-324326	8/13/2015	8/25/2015		New KeyLost / StolenKey #: 64533Key Holder ID: LaKisha C. BurnsQty: 4action: Replace Keys for incoming resident scholars, student assistants and IT personnel
FO-324327	8/13/2015	8/20/2015		New KeyLost / StolenKey #: 2083Key Holder ID: LaKisha C. BurnsQty: 2action: Replace Office Key
FO-324328	8/13/2015	8/20/2015		New KeyLost / StolenKey #: 2098Key Holder ID: LaKisha C. BurnsQty: 2action: Replace lost key
FO-324367	8/13/2015	8/20/2015		Core ChangeNew Space AssignmentKey #: 63565Key Holder ID: Jacqueline PattersonQty: 1 action: Would like core to 7902 to be changed to the same core as 7910 which the key # to 7910 is 63534 Account #: 126731
FO-324476	8/17/2015			New KeyNew Space AssignmentKey #: AssortedKey Holder ID: Tia FinneyQty: 115action: Pls. see email with spreadsheet attachment for 9th Floor.Account #: 125361

WO	Recieved	Finished	Total	Request
FO-324475	8/17/2015			New KeyLost / StolenKey #: AssortedKey Holder ID: Tia FinneyQty: 119action: Pls. see email with spreadsheet attachment for 10th Floor.Account #: 125361
FO-324723	8/17/2015	8/19/2015		New KeyLost / StolenKey #: 10AD2-25Key Holder ID: Lynette RaeQty: 2action: Key is for Room 7134 the new faculty member's office located within lab room 7130Account #: 143511
FO-324707	8/17/2015	8/20/2015		New Key New Space Assignment Key #: 7168 Key Holder ID: Business Office Qty: 6 action: 9Z- classroom access. Additional copies needed by Business Office to lend to grant access to classrooms. (Apologies if the 2103 area is incorrect)
FO-324712	8/18/2015			Lock shop training for Jeff Hammell
FO-324714	8/18/2015			KEYS & CORES (AUGUST 2015)
FO-324730	8/18/2015	8/26/2015		New KeyNew Space AssignmentKey #: 7712Key Holder ID: Robin RobertsQty: 2action: Two keys for room 7123 (Tissue Culture Room).Account #: N/A
FO-324732	8/18/2015	8/26/2015		New KeyNew Staff MemberKey #: 41658Key Holder ID: Dr. Jena SteinleQty: 2action: Two keys for room 9312 (office).Account #: N/A
FO-324733	8/18/2015	8/26/2015		New KeyNew Staff MemberKey #: 41642Key Holder ID: Dr. Jena SteinleQty: 2action: Two keys for 9320 Scott Hall (laboratory).Account #: N/A
FO-324770	8/18/2015	8/27/2015		New KeyNew Staff MemberKey #: 16166Key Holder ID: MarthaQty: 2action: extra keys
FO-324771	8/18/2015	8/26/2015		New KeyNew Staff MemberKey #: 28035Key Holder ID: Terrie PickeringQty: 4action: 4 Keys for room 431 Manoogian#28035Account #: 126780
FO-324786	8/18/2015	8/19/2015		ReplacementDamagedKey #: GG133Key Holder ID: Andrea Sankar/ Debra MazurQty: 2action: 2 Keys for file cabinet number GG133 brand of cabinet HONAccount #: 127571
FO-324799	8/18/2015	8/25/2015		New KeyNew Staff MemberKey #: 78211Key Holder ID: Carolyn DaytonQty: 3action: cut three keys to room 238 knapp building office-thanks you --carol Talbott 664.2630Account #: 157573
FO-324800	8/18/2015	8/25/2015		New KeyNew Staff MemberKey #: 65011Key Holder ID: jessica damoixeauxQty: 5action: please cut 5 keys to room 52 basement of knapp building.questions call 664.2630Account #: 157575
FO-324801	8/18/2015	8/25/2015		New KeyNew Staff MemberKey #: 78111Key Holder ID: noa ofenQty: 5action: thank youAccount #: 157573
FO-324802	8/18/2015	8/27/2015		New KeyLost / StolenKey #: 20681Key Holder ID: Lynnetta R SmithQty: 3action: Faculty member lost the key off campus
FO-324803	8/18/2015	8/27/2015		New Key Lost / Stolen Key #: 20726 Key Holder ID: Lynnetta R Smith Qty: 3 action: Additional keys needed
FO-324804	8/18/2015	8/27/2015		New KeyLost / StolenKey #: 64578Key Holder ID: Lynnetta R SmithQty: 2action: Additional keys needed
FO-324805	8/18/2015			New KeyNew Staff MemberKey #: 20678Key Holder ID: Lynnetta R SmithQty: 3action: need additional keys
FO-324811	8/18/2015			New KeyNew Staff MemberKey #: 20679Key Holder ID: Lynnetta R SmithQty: 5action: Additional keys needed
FO-324815	8/18/2015	8/27/2015		New KeyLost / StolenKey #: 20692Key Holder ID: Lynnetta R SmithQty: 3action: new faculty member
FO-324816	8/18/2015	8/27/2015		New KeyLost / StolenKey #: 20701Key Holder ID: Lynnetta R SmithQty: 3action: new faculty member
FO-324819	8/18/2015	8/25/2015		New KeyLost / StolenKey #: 13509Key Holder ID: Charlyce JacksonQty: 2action: Dept. of Communication orchestrates this room and needs to be able to allow guests to access room without giving them the sub master.Account #: 127211
FO-324820	8/18/2015	8/25/2015		New KeyLost / StolenKey #: 61532Key Holder ID: Charlyce JacksonQty: 4action: New Faculty coming in.Account #: 127211

WO	Recieved	Finished	Total	Request
FO-324821	8/18/2015	8/26/2015		New KeyLost / StolenKey #: 66219Key Holder ID: Charlyce JacksonQty: 5action: New GTA's starting in fall semester.Account #: 127211
FO-324835	8/19/2015	8/27/2015		New KeyNew Staff MemberKey #: 18684Key Holder ID: Mallory SmithQty: 5action: Master key for Art Building
FO-324841	8/19/2015	8/25/2015		New KeyNew Space AssignmentKey #: 28522/ 9ZAA13Key Holder ID: Student UseQty: 3action: This key is issued to editors of the Journal of Law in Society for their secure office space.
FO-324949	8/19/2015			New KeyLost / StolenKey #: B200,11724,11742Key Holder ID: Mohammad AvanakiQty: 5action: I would like to ask you to please prepare keys for 1. entering the life science building [key mark: B200]2. Entering room # 363 (life science building)[key
FO-324973	8/19/2015	8/25/2015		New KeyLost / StolenKey #: 33240Key Holder ID: Sonya ScottQty: 4action: Key is for Rm. 2323 and there are no more keys on hand.
FO-325062	8/19/2015			New KeyNew Staff MemberKey #: TC 10Key Holder ID: Mallory SmithQty: 2action: Key to Room 12 (Clay storage) in basement
FO-325186	8/20/2015			New KeyLost / StolenKey #: FR420, 101E, SL188, SL166Key Holder ID: Valeria CookQty: FR420 (6), 101E (2), SL188 (2), SL166 (2)action: Note: Department is Center for Urban Studies
FO-325187	8/20/2015	8/27/2015		New Key Lost / Stolen Key #: MM101 Key Holder ID: Camisha Muhamed Qty: 1 action: The Circ Desk staff have lost there key to the dumb waiter. it is a Dover elevator
FO-325196	8/21/2015			Core ChangeLost / StolenKey #: Core #AC34, Key #037127Key Holder ID: Angelica ReynaQty: 2 cores and 3 keysaction: 1 mailbox core, 1 room core, and 3 keys. Emergency core 6 is currently installed, please return to front deskAccount #: 228156
FO-325310	8/24/2015			New KeyNew Staff MemberKey #: 10AJ15Key Holder ID: Mary Simmons, Deborah Strahan, Matt GarinQty: 3action: For some reason they want to use keys instead of the CM lock. Keys to be picked up by med school courier.
FO-325342	8/24/2015	8/28/2015		Core ChangeLost / StolenKey #: 63071Key Holder ID: Cindy HildrethQty: 1 core, 1 keyaction: 1 core and 1 key for room 1018.2Account #: 228400
FO-325343	8/24/2015	8/28/2015		Core Change Lost / Stolen Key #: 63097 Key Holder ID: Cindy Hildreth Qty: 1 core and 1 key action: 1 core and 1 key for room 1024.5 Account #: 228400
FO-325345	8/24/2015			Core ChangeLost / StolenKey #: 61816Key Holder ID: Cindy HildrethQty: 1 core and 1 keyaction: 1 core and 1 key for room 521.3Account #: 228400
FO-325346	8/24/2015			Core ChangeLost / StolenKey #: 62848Key Holder ID: Cindy HildrethQty: 1 core and 1 ketyaction: 1 core and 1 key for room 921.3Account #: 228400
FO-325347	8/24/2015			Core ChangeLost / StolenKey #: 62150Key Holder ID: Cindy HildrethQty: 1 core and 1 keyaction: 1 core and 1 key for room 608.2 AB/Account #: 228400
FO-325348	8/24/2015			Core ChangeLost / StolenKey #: 61840Key Holder ID: Cindy HildrethQty: 1 core and 2 keysaction: 1 core and 2 keys for room 542.3 CD/Account #: 228400
FO-325313	8/24/2015			New KeyNew Space AssignmentKey #: 16EF41Key Holder ID: Eric JohnsonQty: 2 keysaction: Cores were recently changed, correct number of key were not requested. Need 2 additional keysAccount #: 228184
FO-325314	8/24/2015			New Key New Space Assignment Key #: 16ED33 Key Holder ID: Eric Johnson Qty: 2 keys action: Cores were recently changed, correct amount of keys were not requested. Need 2 additional keys Account #: 228184

WO	Recieved	Finished	Total	Request
FO-325311	8/24/2015			New KeyNew Staff MemberKey #: 2569Key Holder ID: Tamaya DooleyQty: 1action: Please provide key to mail room on 4th floor F/AB, Room #4360Account #: 170001
FO-325350	8/25/2015			New KeyNew Space AssignmentKey #: 64660Key Holder ID: Paul BishopQty: 4action: Room used for instrument storage.
FO-325352	8/25/2015			New KeyNew Space AssignmentKey #: 64799Key Holder ID: Paul BishopQty: 2action: Keys for new faculty members.
FO-325353	8/25/2015			New KeyNew Space AssignmentKey #: 22578Key Holder ID: Paul BishopQty: 3action: Key for tuba closet.
FO-325354	8/25/2015			New KeyNew Space AssignmentKey #: 64801Key Holder ID: Paul BishopQty: 2action: Key for faculty members to open classroom.
FO-325398	8/25/2015			New KeyNew Staff MemberKey #: 63802Key Holder ID: Glen WeisfeldQty: 5action: New graduate will be working in research labAccount #: 126731
FO-325400	8/25/2015			New KeyNew Space AssignmentKey #: 12ZAKKey Holder ID: Paul BishopQty: 2action: Key for faculty office.
FO-325403	8/25/2015			New Key Lost / Stolen Key #: MMF Industries BL 39 Key Holder ID: Theresa Y. Hill Qty: 3 action: Please make 3 keys for this request.(This is to a key storage box) Contact Theresa Hill when complete. Call me at 313-577 1417 or 577-0556.
FO-325404	8/25/2015			Core Change Lost / Stolen Key #: Core #AB46, Key #037074 Key Holder ID: Angelica Reyna Qty: 2 cores and 4 keys action: 1 room core, 1 mailbox core, and 4 keys. Emergency core has not been installed Account #: 228156
FO-325401	8/26/2015			New KeyLost / StolenKey #: 11073Key Holder ID: Antonio YanceyQty: 2action: 2-KEYS for room 2022
FO-325497	8/26/2015	8/28/2015		Core Change Lost / Stolen Key #: Core #AD31, Key #037189 Key Holder ID: Angelica Reyna Qty: 2 cores and 3 keys action: 1 mailbox core, 1 room core, and 3 keys. Account #: 228156
FO-325498	8/26/2015	8/28/2015		New KeyNew Staff MemberKey #: 76811Key Holder ID: Dr. Kevin SpragueQty: 2action: To be picked up by Med. School courier.
FO-325500	8/26/2015	8/27/2015		New KeyNew Staff MemberKey #: 96326Key Holder ID: Steven WarnickQty: 1action: pls deliver to SOM Facilities to be picked up, thanks
FO-325502	8/26/2015	8/27/2015		New KeyLost / StolenKey #: 10A 3.9XKey Holder ID: Dr. Arun WakadeQty: 1action: Please issue a copy of key# 90445-2 for room 6133. Thanks.Account #: 133601
FO-325504	8/26/2015			New KeyNew Staff MemberKey #: 28021 SMKey Holder ID: Terrie PickeringQty: 2action: Order 2 additional keys for room 431 - sub masterAccount #: 1-26780
FO-325465	8/26/2015	8/26/2015		LOCKSMITH TO CHANGE OUT DEFECTIVE CORE ROOM # 1310.30
FO-325505	8/26/2015	8/27/2015		New KeyNew Space AssignmentKey #: 27711Key Holder ID: Jill-Morgan AubertQty: 4action: For InsideOut (new office space)Account #: 113231
FO-325587	8/27/2015			New KeyNew Space AssignmentKey #: ???Key Holder ID: Patrick Mueller Laboratory (5263 Scott Hall)Qty: 1action: This key request is for a room which houses our rats in DLAR facilities in the Elliman Building. I do not have the Key or Core mark infor

WO	Recieved	Finished	Total	Request
FO-325586	8/27/2015			Core ChangeNew Space AssignmentKey #: 17702--Key Holder ID: Katie McDowellQty: 1action: I believe we would like a key core change or split core.. This training room has a storage room and our key opens both the door to the room and the storage
FO-325562	8/27/2015			New KeyNew Staff MemberKey #: 82400Key Holder ID: HillQty: 2action: Core #23ABD-1Key #82400
FO-325584	8/28/2015			New KeyLost / StolenKey #: Mark Keys 1 thru 8Key Holder ID: Mark AllenQty: 8action: Provide 8-KEYS FOR THE REAR DOOR OF HECKER MANSION. Label 1 - 8 in separate envelopes.
FO-325617	8/28/2015			New KeyLost / StolenKey #: X259 & X693Key Holder ID: Bob OstrowskiQty: 3action: 3 X259 keys 3 X693 keys Can not read core mark...
T - Painter			21	
FO-323470	8/3/2015	8/17/2015		Woman's Bathroom, Plaster repair and paint to finish, 2nd floor.
FO-323471	8/3/2015	8/6/2015		HANDY MAN TO DELIVER 2 BOXES OF REPRODUCTION PAPER TO TIM HERR'S OFFICE
FO-323473	8/3/2015	8/28/2015		HANDYMAN TIME (AUGUST 2015)
FO-323553	8/4/2015			CLEAN & PAINT OVER GRAFFITI CAMPUS WIDE, FOR MONTH OF AUGUST.
FO-323567	8/4/2015	8/12/2015		Chipped ceiling paint around access pannel
FO-323775	8/5/2015	8/24/2015		Scrape, Prime & paint Entire South Elevation Handrail Black.
FO-324068	8/10/2015	8/12/2015		Repair an Paint ceiling in Rm. 0239
FO-324072	8/10/2015	8/11/2015		SAFTEY TIME.
FO-324283	8/13/2015			Paint and label blue light at the corner of Antoinette and Cass. Kenny has the paint in lock up.
FO-324340	8/13/2015	8/21/2015		PAINTERS, PLEASE PATCH/PAINT WINDOW COVE.PRIORITY-LOW
FO-324409	8/14/2015	8/18/2015		Painters please paint the ladders with I-Bio Engineering-WSU
FO-324711	8/18/2015			Plaster- Repair Windows, on West Entrance.
FO-325091	8/19/2015	8/24/2015		Graffiti on side wall of Study Room, Second Floor, Room 2441. Police Report #W15-2310039
FO-324996	8/19/2015	8/20/2015		Please stencil remainder of equipment at I-Bio for the engineer James Darga. Please see Jim.
FO-325173	8/21/2015			Due to Water Damage, Plaster Repair-scrape, Patch, Prime & Paint to finish, Living room ceiling. Upstairs Bathroom ceiling, Prime & paint over water stain.
FO-325223	8/24/2015	8/27/2015		PAINTERS TO MUDD & PAINT WALL REPAIR OVER DOOR WHERE TEMPORARY VENT WAS INSTALLED ROOM # 2537.00
FO-325255	8/24/2015	8/25/2015		PAINTERS MUDD & PAINT DRY WALL CORNER BEAD WALL OUTSIDE ROOM # 2380
FO-325365	8/25/2015			ADDING PAINTERS PLEASE FILL OLD DRILL/ANCHOR HOLES IN GLAZE BLOCK ABOVE URINALS IN ROOMS 109,209,309 THANKS.....Bathroom 109 remove 2 urinals from wall and clear main drain with k50 GS/5-26-15
FO-325407	8/26/2015			Repair Drywall & Plaster, entire Corridor - 2nd floor, Prime & paint to finish
FO-325406	8/26/2015	8/28/2015		PAINTERS TO MUDD & PAINT 2ND FLOOR MENS BATHROOM
FO-325537	8/27/2015			PAINTERS TO PATCH & PAINT 4TH FLOOR MENS REST ROOM WALL BETWEEN URINAL & TOILET
T - Pipefitter			48	
FO-323438	8/3/2015	8/4/2015		R/R Gate valve on steam Line in Mechanical 1ME.....8/3/15
FO-323544	8/4/2015			Fitters, please insulate chilled water lines on lower coil of AHU-4..... ME/8-4-15
FO-323630	8/4/2015	8/4/2015		Repair chemical line in basement JH/8-4-15
FO-323632	8/4/2015	8/5/2015		Repair cooling tower blow down line in basement JH/8-4-15
FO-323677	8/4/2015	8/4/2015		processing time for paperwork, e-mails, phone calls, etc.....CB.....8-4-15....
FO-323678	8/4/2015	8/4/2015		set up gain access and supervise 4 asbestos jobs on campus.....CB....8-4-15
FO-323752	8/5/2015	8/5/2015		investigate 6 different asbestos jobs to determine if they are positive for asbestos.....CB.....8-5-15
FO-323753	8/5/2015	8/5/2015		processing time for paperwork, e-mails,phone calls, etc.....CB....8-5-15
FO-323814	8/6/2015			please repair loose railing on the southside stairs.....EA....8-5-15
FO-324195	8/12/2015			Please replace feed water header (piping/valves) on feed water pump system as you did at Music. Please try to complete prior to us putting the boilers on in fall.....JH/RC....8-12-15

WO	Recieved	Finished	Total	Request
FO-324274	8/13/2015	8/26/2015		please repair pipe under hydronics pump 12. water leaking on floor. ME/8-24-15
FO-324275	8/13/2015			FITTERS, R/R ROOF E SUPPORTS FOR MAKEUP WATER LINE ON COOLING TOWER FAILED, PLEASE REPAIR. PRIORITY-LOW EA/8-24-15
FO-324277	8/13/2015	8/25/2015		please have pipefitters repair steam valve on ac -1 It is dripping very hot water to the floor. wear hard hat or head gear to avoid being hit in the head from high temp steam condensate. JH/8-24-15
FO-324319	8/13/2015	8/18/2015		1) This is NOT an inactive area. 2) There is a leak of brown water coming from the ceiling of this coldroom. It is inhibiting research because of the potential for contamination.....JH.....8/17/15
FO-324348	8/13/2015	8/13/2015		processing time for paperwork, e-mails,phone calls, etc....CB...8-13-15
FO-324349	8/13/2015	8/13/2015		run down paperwork, put up notifications and handle all related paperwork for emergency abatement job in the morning.....CB.....8-13-15
FO-324361	8/13/2015	8/25/2015		Ceiling by women's locker room has water dripping. ME/8-24-15
FO-324405	8/14/2015	8/14/2015		gain access supervise and follow up emergency abatement job.....CB.....8-14-15
FO-324406	8/14/2015	8/14/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....8-14-15
FO-324434	8/17/2015	8/20/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON # 2 FFC UNIT. PRIORITY-LOW.....JH....8/17/15
FO-324451	8/17/2015			Hecker House- 5510 Woodward-Please install slug feeder for chemical feed systems in Carriage House and main house. two units. Per Mark AllenME.....8/19/15
FO-324499	8/17/2015			Repair leaking suction piping on HHWP-1 and HHWP-2 located in mechanical room 10 of Shaver music. Minor drips at this time, may be coming from joints/connections.....EA...8/18/15
FO-324500	8/17/2015	8/24/2015		Install a 1/2 inch tee and cock to allow a water sample of the boiler feed water from the 1/2 inch boiler feed water sample line that runs to the cooling chamber. This is at the north/west side of the boiler feed water heater.....ME.....8/18/15
FO-324789	8/18/2015	8/18/2015		processing time for paperwork, e-mail,phone calls, etc....CB....8-18-15
FO-324791	8/18/2015	8/18/2015		chase down signatures for project notification for Saturday shutdown job....CB.....8-18-15
FO-324806	8/18/2015	8/19/2015		Ceiling leak - repair leak and need new tile....ME....8/19/15
FO-324813	8/19/2015			To pipefitters. The steam bypass valve on SF-1 is leaking by and overheating discharge air. Please repair or replace.....EA.....8/19/15
FO-325055	8/20/2015	8/20/2015		processing time for paperwork, e-mails, phone calls, etc....CB.....8-20-15
FO-325057	8/20/2015	8/20/2015		investigate corrosive acid leak in fume hood room 019.3, speak to OEHS and advise Dave K on findings.....8-20-15
FO-325058	8/20/2015	8/20/2015		run down signatures for impact report for this Saturdays emergency domestic water shutdown for the Plumbers.....8-20-15
FO-325060	8/20/2015	8/20/2015		post asbestos notifications at 2 different buildings for tomorrows abatement jobs....CB....8-20- 15
FO-325148	8/21/2015			WSU pipefitters to install conductivity probe for controllers on both steam boilers for automated blowdown control. Per Mark Allen. RC/8-24-15
FO-325150	8/21/2015			WSU pipefitters to install the chemical injection point in the surge tank. Per Mark Allen. RC/8-24-15
FO-325151	8/21/2015			WSU pipefitters to install Drain line for sample and cooling water on sample cooler. Per Mark Allen. RC/8-24-15
FO-325175	8/21/2015	8/28/2015		PIPEFITTERS- R/R PH-MECH RM please install new McDonnell Miller MU valve in the at 5425 Woodward. The North side valve needs replaced on the MU for the hydronic loop. This is located in the elevator mechanical room up a flight from the PH mechanical roo
FO-325319	8/25/2015			Install make up meter on the cooling tower..... RC/8-25-15
FO-325320	8/25/2015			Needs an inhibitor injection point on the main header for the cooling tower. This will require welding a 3/4" tap off the header with a ball valve, reduced down to 1/2" FNPT. See Duane Coplen RC/8-25-15
FO-325379	8/25/2015	8/25/2015		processing time for paperwork, e-mails, phone calls, etc....CB....8-25-15

WO	Recieved	Finished	Total	Request
FO-325380	8/25/2015	8/25/2015		work on water shutdown for building, painstaking effort to try and communicate with somebody from Detroit Water and Sewage to assist us in a domestic water shutdown scheduled for next Friday.....Wow what an adventure, never worked with such incompetence b
FO-325387	8/25/2015			Kresge Library 1st Floor - Library Science Offices, Room 101 Brown gunk dripped from ceiling onto window ledge. Please stop leak and clean ledge. Thank you. ,,,,,,,,,,,,,, ME/8-26-15 ,,,,,,,,,,,,,,
FO-325385	8/25/2015	8/25/2015		inspect several re-mod bathrooms to see if custodial has cleaned them yet....CB....8-25-15
FO-325536	8/27/2015	8/31/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON FFC UNIT. PRIORITY-LOW ,,,,,,,,,,,,,, JH/8-28-15 ,,,,,,,,,,,,,,
FO-325544	8/27/2015	8/28/2015		Repair leak in ceiling and provide hangers on stainless condensate return where needed in room 324,,,,,,,,,,,,, JH/8-27-15 ,,,,,,,,,,,,,,
FO-325568	8/27/2015	8/31/2015		FITTERS, PLEASE REPLACE LEAKING HWH CONTROL VALVE ON #1 FFC UNIT. PRIORITY-LOW. ,,,,,,,,,,,,,, JH/8-28-15 ,,,,,,,,,,,,,,
FO-325565	8/27/2015	8/27/2015		processing time for paperwork, e-mails, phone calls, etc.....CB....8-27-15
FO-325566	8/27/2015	8/27/2015		take contractor too look at several asbestos jobs on campus.....CB....8-27-15
FO-325569	8/27/2015	8/27/2015		Cut up flat stock steel for stockroom ,,,,,,,,,,,,,, EA/8-27-15 ,,,,,,,,,,,,,,
FO-325642	8/30/2015			FITTERS- Please repair the leak on the feed water line to # 1 boiler in Music boiler room.
T - Plumber			48	
FO-323443	8/3/2015	8/26/2015		Plumbers; insulate cold water pipe that is dripping thru ceiling on 1st floor in front of bathrooms.....GS.....8-3-15
FO-323446	8/3/2015			Plumbers: Please replace cracked and leaking storm drain line inside mechanical room 15. Priority: low.....GS....8/3/15
FO-323459	8/3/2015	8/31/2015		Pump out loading dock for month of august.....MM.....8/3/15
FO-323490	8/3/2015	8/19/2015		2nd floor men restroom # 2238 overflowing urinal.....MP.....8/3/15
FO-323776	8/5/2015			R/R RM 13124/WOMENS RR All three toilets in the women's restroom are leaking from the base. Thank you.,,,,,,,,,,,,,, MP/8-5-15 ,,,,,,,,,,,,,,
FO-323790	8/5/2015	8/20/2015		** CEILING ACCESS ABATEMENT NOW COMPLETE 8/4/15 SCAFFOLD ON LOCATION / EVALUATE NEEDED REPAIRS ASAP STAIRWELL D 2ND FL ACTIVE CEILING LEAK possible roof sump leak ,,,,,,,,,,,,,, GS/ 8-5-15 ,,,,,,,,,,,,,,
FO-323815	8/6/2015			Clean drains on roofs on the north side of the building.....MM.....8-7-15
FO-323849	8/6/2015			replace 2 inch leaking water line located in basement mech room line currently has 4 pipe clamps on it....GS....8-5-15
FO-324091	8/11/2015	8/20/2015		The toilet seats in the basement women's & men's rooms in Prentis are all loose.....DB/TT.....8-12-15
FO-324115	8/11/2015	8/12/2015		Plumbers: please clear the plugged up floor drain in main mechanical room. Priority: low.....MM.....8-11-15
FO-324136	8/11/2015	8/13/2015		Pipes make very loud sound after toilet is flushed.....MM....8-11-15
FO-324153	8/12/2015			please investigate and repair hot water to toilets....(crossover)....GS...8-12-15
FO-324154	8/12/2015	8/12/2015		**DUPLICATE / REFER to FO#324008 JWT plumbers please replace all 3 meter valves, meter, and all related piping....this work will require a city of Detroit water shutdown due to the valves being replaced are the main isolation valves for building and no
FO-324161	8/12/2015	8/13/2015		R/R 3RD FLR HALLWAY The drinking fountain right outside the janitor office before the lab wing is not working. It hasn't worked for months. Thank you.....MM.....8-12-15
FO-324255	8/12/2015	8/14/2015		Purdy Library 1st Floor Staff Women's Restroom Toilet - 2nd from the right - not flushing. Please repair ,,,,,,,,,,,,,, MM/8-13-15 ,,,,,,,,,,,,,,
FO-324279	8/13/2015	8/14/2015		Plumber R/R RM 00008/MENS RR repair urinal flush valve mens room basement. Leaks bad when used. ,,,,,,,,,,,,,, MM/8-13-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-324282	8/13/2015	8/13/2015		REFER TO DAVID KUFFNER FOR UPDATE. (NUMEROUS FIRE PLUGS SCHEDULED FOR REPAIR THIS ONE TO NOW BE INCLUDED) JWT 8/27/15 In front of the Multi Purpose bldg along the sidewalk - leaking fire hydrant needs repair 8/13/15 lps: Spoke w/John T says to proce
FO-324359	8/13/2015	8/24/2015		Toilet is leaking from the bottom of the tank. In unisex bathroom on third floor in the back of the building. ,,,,,,,,,,,,,, MM/8-24-15 ,,,,,,,,,,,,,,
FO-324381	8/14/2015	8/17/2015		The pressure on the water fountain is down.....MM.....8/17/15
FO-324383	8/14/2015	8/17/2015		3rd floor of Scott Hall center ale way ladies restroom 3rd stall keeps flushing on it on.....MM.....8/17/15
FO-324387	8/14/2015	8/18/2015		2nd floor Men's bathroom off elevator has toilet stall that runs non-stop. Thank you.....MP.....8/17/15
FO-324391	8/14/2015	8/17/2015		TOILET CONTINUOUSLY FLUSHING. LADIES RESTROOM. ROOM 3341.....MM.....8/17/15
FO-324403	8/14/2015			Replace leaking urinal PRV for 1st and 2nd floor mens room ,,,,,,,,,,,,,, DB/8-14-15 ,,,,,,,,,,,,,,
FO-324419	8/15/2015	8/20/2015		Repair sink faucet located in 1st floor Men's restroom in Rand's Annex. The Delta faucet seats and worn, and the faucet drips continuously. Also, the toilet Sloan valve is short-flushing and needs R/R.....MP.....8/17/15
FO-324724	8/18/2015	8/20/2015		R/R 2ND FLR HALLWAY Drinking Fountain adjacent to room 21238 is not working. 2nd Floor.....MM.....8/18/15
FO-324940	8/19/2015	8/20/2015		3rd floor men's restroom their no power when you flush the toilet.....DB.....8/19/15
FO-325024	8/20/2015	8/26/2015		R/R RM 00136/SHOP The sink in our paint shop needs snaked.....MM...8/20/15
FO-325025	8/20/2015			Install water filter on kitchen sink.....GS.....8/20/15
FO-325039	8/20/2015	8/21/2015		PLUMBERS R/R RM 00149/RR please repair toilet. It will not flush.....MM....8/21/15
FO-325099	8/21/2015	8/21/2015		Install cap on sanitary line in fan room 2MP.....8/21/15
FO-325109	8/21/2015			Please Test, Insect and Repair Backflow Devices in Building. Complete Testing Record Data and Install Valve Tag.....DB.....8/21/15
FO-325114	8/21/2015	8/28/2015		Please replace drain pipe connected to Floor drains in green house.....GS....8/21/15
FO-325126	8/21/2015			Replace leaking urinal PRV for 1st and 2nd floor mens room ,,,,,,,,,,,,,, DB/8-14-15 ,,,,,,,,,,,,,,
FO-325237	8/24/2015			R/R RM 2131/LAB EAST SIDE SINK HAS A CRACK. WHEN IN USE IT LEAKS ,,,,,,,,,,,,,, GS/8-24-15 ,,,,,,,,,,,,,,
FO-325281	8/24/2015	8/26/2015		R/R RM 3250 In the back room of lab 3250 the tap is not running any cold water. It is btw. the eye wash station and the autoclave. Need asap as this is used often. Note: This was reported back on 7/14/15 under FO-321933 & FP&M put a part on, but it st
FO-325285	8/24/2015	8/27/2015		R/R 2nd floor Ladies restroom - someone has stuffed the 2nd stall's toilet full of tissue. I didn't want to flush it in case it would overflow.,,,,,,,,,,,,,, MM/8-25-15 ,,,,,,,,,,,,,,
FO-325299	8/25/2015			Purdy Library 1st Floor Staff Women's restroom 2nd toilet from left has low pressure. Please repair. Thank you. ,,,,,,,,,,,,,, GS/8-25-15 ,,,,,,,,,,,,,
FO-325309	8/25/2015	8/26/2015		Repair toilet flush valve, UGL Men's Room, 1238. Toilet runs continuously.,,,,,,,,,,,,,, MM/8-25-15 ,,,,,,,,,,,,,,
FO-325362	8/25/2015	8/31/2015		please repair 3rd floor mens room handicap flush valve, not working ,,,,,,,,,,,,,, DB/8-25-15 ,,,,,,,,,,,,,
FO-325372	8/25/2015			Rm. 107 Kresge Men's Restroom Repair two leaking toilets valves and one leaking faucet. **Ask Jerry from the Pipe shop for additional information. ,,,,,,,,,,,,,, GS/8-26-15 ,,,,,,,,,,,,,,
FO-325375	8/25/2015			Rm. 108 Kresge Women's Restroom Repair two leaking toilets valves and one leaking faucet. **Ask Jerry from the Pipe shop for additional information.,,,,,,,,,,,,,, GS/8-26-15 ,,,,,,,,,,,,,,
FO-325416	8/26/2015	8/31/2015		Left and center faucets in male locker room don't provide water as needed. Batteries may be weak.,,,,,,,,,,,,,, DB/8-26-15 ,,,,,,,,,,,,,,

WO	Recieved	Finished	Total	Request
FO-325512	8/27/2015			Toilet #1 in the Women's 3rd Floor rest room is continuously flushing..... MM/8-27-15
FO-325538	8/27/2015			R/R leaking sink on 9th floor. See MM for location MM/8-25-15
FO-325542	8/27/2015			R/R urinal solenoid 1st floor men's room per Don DB/8-27-15
FO-325555	8/27/2015			Kresge Library 1st Floor Suite 106 Low water pressure in kitchenette sink. Please repair. Thank you. GS/8-27-15
FO-325558	8/27/2015			Kresge Library 1st Floor Room 113 Handicap Restroom Toilet seat loose. Please repair. Thank you. GS/8-27-15
FO-325577	8/27/2015			handle on toilet in unisex bathroom, 1st floor Freer House is broken
T - Roofing			3	
FO-323759	8/5/2015			ROOFER R/R Room 330/Dr. Frade REPAIR ROOF LEAK IN NEW AREA OF RM 330 has a puddle of water on his rug in front of his door from Sunday's rain.
FO-324939	8/19/2015			ATT KUFFNER - ROOFERS needed at Mort Sci. There has been on ongoing problem with large amounts of water leaking into Dr. Frede's office after rain storms. Our men have been out numerous times to try to resolve the problem and this still needs attention.
FO-325230	8/24/2015			Roofeer R/R ROOF repair leaks on lower above animal procedure rooms 2307, 2317, 2327.
Routine			9	
T - Electrician			7	
FO-323561	8/4/2015			PS#1 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323563	8/4/2015			PS#2 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323564	8/4/2015			PS#3 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323565	8/4/2015			PS#4 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323566	8/4/2015			PS#5 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323568	8/4/2015			PS#6 Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
FO-323569	8/4/2015			Various Campus Lots - Electrician Monthly ROUTINE CHECK for 8/1 thru 8/31/2015
T - Plumber			2	
FO-325105	8/21/2015			Please Test, Inspect and Repair Backflow Devices in Building. Complete Testing Record Data and Install Valve Tag.....DB.....8/21/15
FO-325107	8/21/2015			Please Test, Inspect and Repair Backflow Devices in Building. Complete Testing Record Data and Install Valve TagDB.....8/21/15

Scheduled Maint. (PM) 464

Engineering 421

Routine 421

E - Auxiliary 29

FO-322449	8/1/2015	8/12/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322450	8/1/2015	8/12/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322451	8/1/2015	8/27/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322452	8/1/2015	8/12/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322453	8/1/2015	8/11/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322454	8/1/2015	8/11/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322455	8/1/2015	8/11/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322467	8/1/2015			PM - Air Handling Unit, HV Type
FO-322469	8/1/2015			PM - Air Handling Unit, HV Type
FO-322487	8/1/2015	8/14/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers

WO	Recieved	Finished	Total	Request
FO-322497	8/1/2015	8/14/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322502	8/1/2015	8/2/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-322503	8/1/2015	8/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-322504	8/1/2015	8/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-322505	8/1/2015	8/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-322506	8/1/2015	8/28/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-322468	8/3/2015	8/7/2015		PM - Emergency Shower/Eyewash Station
FO-323008	8/10/2015	8/14/2015		PM - Emergency Shower/Eyewash Station
FO-323006	8/11/2015	8/11/2015		Generator Maintenance, Monthly
FO-323527	8/12/2015	8/12/2015		Generator Maintenance, Monthly
FO-323531	8/17/2015	8/21/2015		PM - Emergency Shower/Eyewash Station
FO-323655	8/19/2015	8/18/2015		Generator Maintenance, Monthly
FO-324082	8/20/2015			PM - Condensate Return Pump
FO-324081	8/24/2015	8/28/2015		PM - Emergency Shower/Eyewash Station
FO-323643	8/25/2015	8/24/2015		Generator Maintenance, Monthly
FO-323645	8/25/2015	8/25/2015		Generator Maintenance, Monthly
FO-323647	8/25/2015	8/25/2015		Generator Maintenance, Monthly
FO-323649	8/25/2015	8/25/2015		Generator Maintenance, Monthly
FO-323651	8/25/2015	8/25/2015		Generator Maintenance, Monthly
E - Command Center			2	
FO-324687	8/27/2015			State Boiler Inspection
FO-324688	8/27/2015			State Boiler Inspection
E - MedPharm			14	
FO-322332	8/1/2015			PM - Domestic Water Heater, Electric
FO-322333	8/1/2015			PM - Domestic Water Heater, Electric
FO-322334	8/1/2015	8/13/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322335	8/1/2015	8/13/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322336	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322337	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322338	8/1/2015	8/12/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322339	8/1/2015	4/13/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322340	8/1/2015	4/13/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322341	8/1/2015	8/12/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-323504	8/18/2015	8/26/2015		Generator Maintenance, Monthly
FO-323639	8/28/2015			Generator Maintenance, Monthly
FO-323641	8/28/2015			Generator Maintenance, Monthly
FO-324521	8/28/2015			PM - Reverse Osmosis Water Softener System
E - North			31	
FO-322342	8/1/2015	7/22/2015		PM - Sump Pump
FO-322343	8/1/2015	7/22/2015		PM - Sump Pump
FO-322344	8/1/2015	7/22/2015		PM - Unspecified
FO-322345	8/1/2015	7/22/2015		PM - Sump Pump
FO-322346	8/1/2015	8/6/2015		PM - Sump Pump
FO-322347	8/1/2015	8/6/2015		PM - Sump Pump
FO-322348	8/1/2015	8/6/2015		PM - Sump Pump
FO-322349	8/1/2015	8/5/2015		PM - Sump Pump
FO-322350	8/1/2015	8/5/2015		PM - Sump Pump
FO-322351	8/1/2015	7/22/2015		PM - Harmsco Side Stream Filter

WO	Recieved	Finished	Total	Request
FO-322352	8/1/2015	7/29/2015		PM - Harmsco Side Stream Filter
FO-322353	8/1/2015	7/29/2015		PM - Harmsco Side Stream Filter
FO-322354	8/1/2015	7/22/2015		PM - Harmsco Side Stream Filter
FO-322355	8/1/2015	8/6/2015		PM - Sump Pump
FO-322356	8/1/2015			PM - Unspecified
FO-322357	8/1/2015	7/29/2015		PM - Harmsco Side Stream Filter
FO-322358	8/1/2015	8/3/2015		PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-322359	8/1/2015	8/3/2015		Replace PRE-filters
FO-322360	8/1/2015	8/4/2015		Replace PRE-filters
FO-322361	8/1/2015	8/31/2015		Replace PRE-filters
FO-322362	8/1/2015			Replace PRE-filters
FO-322363	8/1/2015	8/7/2015		Replace PRE-filters
FO-322364	8/1/2015			Replace PRE-filters
FO-322365	8/1/2015			Replace PRE-filters
FO-322366	8/1/2015			Replace PRE-filters
FO-322367	8/1/2015			Replace PRE-filters
FO-322991	8/8/2015	8/12/2015		PM - Sewage Lift Pump
FO-322992	8/8/2015	8/19/2015		PM - Sewage Lift Pump
FO-323506	8/14/2015	8/14/2015		Generator Maintenance, Monthly
FO-323505	8/15/2015	8/27/2015		PM - Outside/Fresh Air Intake Screens
FO-323653	8/19/2015	8/20/2015		Generator Maintenance, Monthly
E - Northeast			26	
FO-322368	8/1/2015	8/31/2015		PM - Deaerator Tank
FO-322369	8/1/2015	8/18/2015		PM - Water Softener
FO-322370	8/1/2015	8/31/2015		PM - Fan Coil/HV/AC Unit
FO-322371	8/1/2015	8/31/2015		PM - Fan Coil/HV/AC Unit
FO-322372	8/1/2015	8/31/2015		PM - Fan Coil/HV/AC Unit
FO-322373	8/1/2015	8/19/2015		PM - Domestic Water Heater, Steam
FO-322374	8/1/2015	8/27/2015		PM - Vacuum Pump
FO-322375	8/1/2015	8/31/2015		PM - Domestic Water Heater, Electric
FO-322376	8/1/2015	8/7/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322377	8/1/2015	8/7/2015		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-322995	8/5/2015	8/19/2015		PM - Boiler, Hydronic/Hot Water, greater than 1000 MBH
FO-322996	8/5/2015	8/19/2015		PM - Boiler, Hydronic/Hot Water, greater than 1000 MBH
FO-322997	8/5/2015	8/19/2015		PM - Boiler, Hydronic/Hot Water, greater than 1000 MBH
FO-322998	8/7/2015	8/7/2015		Generator Maintenance, Monthly
FO-322999	8/7/2015	8/7/2015		Generator Maintenance, Monthly
FO-323000	8/7/2015	8/7/2015		Generator Maintenance, Monthly
FO-323001	8/7/2015	8/7/2015		Generator Maintenance, Monthly
FO-322993	8/8/2015			PM - Condensate Return Pump
FO-322994	8/8/2015			PM - Condensate Return Pump
FO-323507	8/18/2015	8/19/2015		Generator Maintenance, Monthly
FO-323657	8/20/2015	8/20/2015		Generator Maintenance, Monthly
FO-324079	8/21/2015	8/26/2015		PM - Domestic Water Heater, Gas
FO-323636	8/22/2015	8/19/2015		Generator Maintenance, Monthly
FO-324080	8/22/2015			PM - Sewage Lift Pump
FO-323663	8/27/2015	8/27/2015		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-323665	8/27/2015	8/27/2015		Generator Maintenance, Monthly
E - Preventative Maintenance			189	
FO-321068	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321069	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321070	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321071	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321072	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321073	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321074	8/1/2015	8/4/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321075	8/1/2015	8/4/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321076	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321077	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321078	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321079	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321080	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321081	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321082	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321083	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321084	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321085	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321086	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321087	8/1/2015	8/25/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321088	8/1/2015		8/1/2015	PM - Air Handling Unit, HV Type
FO-321089	8/1/2015	8/30/2015		HEPA Filter Replacement at Applebaum Pharmacy Building
FO-321090	8/1/2015	8/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321091	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321092	8/1/2015	8/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321093	8/1/2015	8/27/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321094	8/1/2015	8/29/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321095	8/1/2015	8/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321096	8/1/2015	8/6/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321097	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321098	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321099	8/1/2015	8/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321100	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321101	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321102	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321103	8/1/2015	8/12/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321104	8/1/2015	8/14/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321105	8/1/2015	8/12/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321106	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321107	8/1/2015	8/7/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321108	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321109	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321110	8/1/2015	8/16/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321111	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321112	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test

WO	Recieved	Finished	Total	Request
FO-321113	8/1/2015	8/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321114	8/1/2015	8/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321115	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321116	8/1/2015	8/20/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321117	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321118	8/1/2015	8/15/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321119	8/1/2015	8/17/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321120	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321121	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321122	8/1/2015	8/19/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321123	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321124	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321125	8/1/2015	8/9/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321126	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321127	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321128	8/1/2015	8/26/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321129	8/1/2015	8/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321130	8/1/2015	8/11/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321131	8/1/2015	8/8/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321132	8/1/2015	8/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321133	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321134	8/1/2015	8/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321135	8/1/2015	8/24/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321136	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321137	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321138	8/1/2015	8/30/2015		Replace PRE-filters
FO-321139	8/1/2015	8/24/2015		Replace PRE-filters
FO-321140	8/1/2015	8/25/2015		Replace PRE-filters
FO-321141	8/1/2015	8/25/2015		Replace PRE-filters
FO-321142	8/1/2015	8/17/2015		Replace PRE-filters
FO-321143	8/1/2015	8/17/2015		Replace PRE-filters
FO-321144	8/1/2015	8/24/2015		Replace PRE-filters
FO-321145	8/1/2015	8/10/2015		Replace PRE-filters
FO-321146	8/1/2015	8/26/2015		Replace PRE-filters
FO-321147	8/1/2015	8/26/2015		Replace PRE-filters
FO-321148	8/1/2015	8/20/2015		Replace PRE-filters
FO-321149	8/1/2015	8/21/2015		Replace PRE-filters
FO-321150	8/1/2015	8/22/2015		Replace PRE-filters
FO-321151	8/1/2015	8/20/2015		Replace PRE-filters
FO-321152	8/1/2015	8/23/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321153	8/1/2015	8/21/2015		Replace PRE-filters
FO-321154	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321155	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321156	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321157	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321158	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321159	8/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-321160	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321161	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321162	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321163	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321164	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321165	8/1/2015	8/7/2015		Replace PRE-filters
FO-321166	8/1/2015	8/7/2015		Replace PRE-filters
FO-321167	8/1/2015	8/6/2015		Replace PRE-filters
FO-321168	8/1/2015	8/6/2015		Replace PRE-filters
FO-321169	8/1/2015	8/4/2015		Replace PRE-filters
FO-321170	8/1/2015	8/4/2015		Replace PRE-filters
FO-321171	8/1/2015	8/3/2015		Replace PRE-filters
FO-321172	8/1/2015	8/3/2015		Replace PRE-filters
FO-321173	8/1/2015	8/18/2015		Replace PRE-filters
FO-321174	8/1/2015	8/15/2015		Replace PRE-filters
FO-321175	8/1/2015	8/15/2015		Replace PRE-filters
FO-321176	8/1/2015	8/18/2015		Replace PRE-filters
FO-321177	8/1/2015	8/21/2015		Replace PRE-filters
FO-321178	8/1/2015	8/25/2015		Replace PRE-filters
FO-321179	8/1/2015	8/26/2015		Replace PRE-filters
FO-321180	8/1/2015			Replace PRE-filters
FO-321181	8/1/2015	8/28/2015		Replace PRE-filters
FO-321182	8/1/2015	8/27/2015		Replace PRE-filters
FO-321183	8/1/2015	8/29/2015		Replace PRE-filters
FO-321184	8/1/2015	8/28/2015		Replace PRE-filters
FO-321185	8/1/2015			Replace PRE-filters
FO-321186	8/1/2015			Replace PRE-filters
FO-321187	8/1/2015			Replace PRE-filters
FO-321188	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321189	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321190	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321191	8/1/2015	8/4/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321192	8/1/2015	8/28/2015		Replace PRE-filters
FO-321193	8/1/2015	8/29/2015		Replace PRE-filters
FO-321194	8/1/2015			Replace PRE-filters
FO-321195	8/1/2015			Replace PRE-filters
FO-321196	8/1/2015			Replace PRE-filters
FO-321197	8/1/2015			Replace PRE-filters
FO-321198	8/1/2015			Replace PRE-filters
FO-321199	8/1/2015	8/21/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321200	8/1/2015			Replace PRE-filters
FO-321201	8/1/2015			Replace PRE-filters
FO-321202	8/1/2015			Replace PRE-filters
FO-321203	8/1/2015			Replace PRE-filters
FO-321204	8/1/2015			Replace PRE-filters
FO-321205	8/1/2015			Replace PRE-filters
FO-321206	8/1/2015			Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-321207	8/1/2015	8/26/2015		Replace PRE-filters
FO-321208	8/1/2015	8/26/2015		Replace PRE-filters
FO-321209	8/1/2015			Replace PRE-filters
FO-321210	8/1/2015	8/22/2015		Replace PRE-filters
FO-321211	8/1/2015	8/22/2015		Replace PRE-filters
FO-321212	8/1/2015			Replace PRE-filters
FO-321213	8/1/2015			Replace PRE-filters
FO-321214	8/1/2015	8/27/2015		Replace PRE-filters
FO-321215	8/1/2015	8/27/2015		Replace PRE-filters
FO-321216	8/1/2015	8/27/2015		Replace PRE-filters
FO-321217	8/1/2015	8/27/2015		Replace PRE-filters
FO-321218	8/1/2015	8/27/2015		Replace PRE-filters
FO-321219	8/1/2015	8/27/2015		Replace PRE-filters
FO-321220	8/1/2015			Replace PRE-filters
FO-321221	8/1/2015			Replace PRE-filters
FO-321222	8/1/2015	8/14/2015		Replace PRE-filters
FO-321223	8/1/2015	8/5/2015		Replace PRE-filters
FO-321224	8/1/2015	8/14/2015		Replace PRE-filters
FO-321225	8/1/2015	8/14/2015		Replace PRE-filters
FO-321226	8/1/2015	8/14/2015		Replace PRE-filters
FO-321227	8/1/2015	8/14/2015		Replace PRE-filters
FO-321228	8/1/2015	8/14/2015		Replace PRE-filters
FO-321229	8/1/2015	8/19/2015		Replace PRE-filters
FO-321230	8/1/2015	8/21/2015		Replace PRE-filters
FO-321231	8/1/2015	8/19/2015		Replace PRE-filters
FO-321232	8/1/2015	8/19/2015		Replace PRE-filters
FO-321233	8/1/2015			Replace PRE-filters
FO-321234	8/1/2015			Replace PRE-filters
FO-321235	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321236	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321237	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-321238	8/1/2015	8/12/2015		Replace PRE-filters
FO-321239	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321240	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321241	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321242	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321243	8/1/2015			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-321244	8/1/2015	8/25/2015		PM - Monthly Fire Alarm/Fire Protection System Test
FO-321245	8/1/2015			Replace PRE-filters
FO-318745	8/1/2015	8/11/2015		Replace PRE-filters
FO-318744	8/1/2015	8/11/2015		Replace PRE-filters
FO-318743	8/1/2015	8/11/2015		Replace PRE-filters
FO-318742	8/1/2015	8/11/2015		Replace PRE-filters
FO-318741	8/1/2015	8/12/2015		Replace PRE-filters
FO-318740	8/1/2015	8/12/2015		Replace PRE-filters
FO-318739	8/1/2015	8/12/2015		Replace PRE-filters
FO-321316	8/7/2015	8/26/2015		PM Replace Exhaust Air Filters

WO	Recieved	Finished	Total	Request
FO-321317	8/7/2015	8/26/2015		PM Replace Exhaust Air Filters
FO-321318	8/7/2015	8/26/2015		PM Replace Exhaust Air Filters
FO-321319	8/7/2015	8/26/2015		PM Replace Exhaust Air Filters
E - South			49	
FO-322378	8/1/2015	8/31/2015		PM - Water Softener
FO-322379	8/1/2015	8/21/2015		PM - Deaerator Tank
FO-322384	8/1/2015	8/12/2015		PM - Domestic Water Heater, Electric
FO-322386	8/1/2015	8/17/2015		PM - Vacuum Pump
FO-322387	8/1/2015	8/17/2015		PM - Vacuum Pump
FO-322433	8/1/2015	8/14/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322434	8/1/2015	8/13/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322441	8/1/2015			PM - Sump Pump
FO-322458	8/1/2015	8/14/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322461	8/1/2015	8/21/2015		PM - Sump Pump
FO-322462	8/1/2015	8/31/2015		PM - Sump Pump
FO-322463	8/1/2015	8/17/2015		PM - Sump Pump
FO-322464	8/1/2015	8/21/2015		PM - Sump Pump
FO-322465	8/1/2015	8/14/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322466	8/1/2015	8/14/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322470	8/1/2015	8/12/2015		PM - Domestic Water Heater, Electric
FO-322471	8/1/2015	8/14/2015		PM - Sump Pump
FO-322472	8/1/2015	8/14/2015		PM - Sump Pump
FO-322473	8/1/2015	8/18/2015		PM - Sump Pump
FO-322474	8/1/2015	8/18/2015		PM - Sump Pump
FO-322475	8/1/2015	8/12/2015		PM - Sump Pump
FO-322476	8/1/2015	8/12/2015		PM - Sump Pump
FO-322477	8/1/2015	8/17/2015		PM - Sump Pump
FO-322478	8/1/2015	8/17/2015		PM - Sump Pump
FO-322479	8/1/2015	8/13/2015		PM - Sump Pump
FO-322480	8/1/2015	8/13/2015		PM - Sump Pump
FO-322481	8/1/2015	8/17/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322482	8/1/2015	8/14/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322483	8/1/2015	8/14/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322484	8/1/2015	8/18/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322485	8/1/2015	8/13/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322486	8/1/2015	8/14/2015		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-322488	8/1/2015	8/7/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322489	8/1/2015	8/7/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322490	8/1/2015	8/7/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322491	8/1/2015	8/10/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322492	8/1/2015	8/26/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322493	8/1/2015	8/26/2015		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322501	8/1/2015	8/7/2015		PM - McQuay Chillers: Operational Inspections for Centrifugal & Screw Chille (Air cooled) Chillers
FO-322507	8/1/2015	8/26/2015		Replace PRE-filters
FO-323002	8/8/2015	8/11/2015		Monthly AHU Inspection Clean Room Unit 2
FO-323003	8/8/2015	8/11/2015		PM - Monthly AHU Inspection Clean Room Unit 1
FO-323514	8/13/2015	8/14/2015		Generator Maintenance, Monthly

WO	Recieved	Finished	Total	Request
FO-323516	8/13/2015	8/14/2015		Generator Maintenance, Monthly
FO-323530	8/13/2015	8/13/2015		Generator Maintenance, Monthly
FO-323508	8/16/2015	8/31/2015		PM - Domestic Water Heater, Gas
FO-323518	8/18/2015	8/18/2015		Generator Maintenance, Monthly
FO-323634	8/19/2015	8/19/2015		Generator Maintenance, Monthly
FO-323659	8/20/2015	8/20/2015		Generator Maintenance, Monthly
E - Southeast			73	
FO-322380	8/1/2015			PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322381	8/1/2015	8/31/2015		PM - Sump Pump
FO-322382	8/1/2015	8/31/2015		PM - Sump Pump
FO-322383	8/1/2015	8/31/2015		PM - Sump Pump
FO-322388	8/1/2015	8/27/2015		PM - Fan Coil/HV/AC Unit
FO-322389	8/1/2015	8/27/2015		PM - Fan Coil/HV/AC Unit
FO-322390	8/1/2015	8/27/2015		PM - Fan Coil/HV/AC Unit
FO-322391	8/1/2015	8/27/2015		PM - Fan Coil/HV/AC Unit
FO-322392	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322393	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322394	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322395	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322396	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322397	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322398	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322399	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322400	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322401	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322402	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322403	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322404	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322405	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322406	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322407	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322408	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322409	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322410	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322411	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322412	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322413	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322414	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322415	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322416	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322417	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322418	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322419	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322420	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322421	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322422	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322423	8/1/2015			PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-322424	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322425	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322426	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322427	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322428	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322429	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322430	8/1/2015			PM - Fan Coil/HV/AC Unit
FO-322435	8/1/2015	7/23/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322436	8/1/2015	7/23/2015		PM - Air Compressor, Reciprocating 5-40 H.P.
FO-322437	8/1/2015	8/12/2015		PM - Heat Pumps (5057 Woodward)
FO-322438	8/1/2015	8/12/2015		PM - Heat Pumps (5057 Woodward)
FO-322439	8/1/2015	8/12/2015		PM - Heat Pumps (5057 Woodward)
FO-322440	8/1/2015	8/12/2015		PM - Heat Pumps (5057 Woodward)
FO-322442	8/1/2015	8/11/2015		PM - Air Intake Dampers (Old Main)
FO-322443	8/1/2015	8/11/2015		PM - Air Intake Dampers (Old Main)
FO-322444	8/1/2015	8/11/2015		PM - Air Intake Dampers (Old Main)
FO-322445	8/1/2015	8/31/2015		PM - Sump Pump
FO-322446	8/1/2015	8/31/2015		PM - Sump Pump
FO-322447	8/1/2015	8/31/2015		PM - Sump Pump
FO-322459	8/1/2015			PM - Harmsco Side Stream Filter
FO-322460	8/1/2015			PM - Harmsco Side Stream Filter
FO-322494	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322495	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322496	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322498	8/1/2015			PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-322499	8/1/2015			PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-322500	8/1/2015			PM - Carrier Chillers: Operational Inspections for Centrifugal Chillers
FO-323509	8/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-323510	8/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-323511	8/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-323512	8/15/2015			PM - Chemical Feed/Metering Pump/Controller
FO-323521	8/18/2015	8/26/2015		Generator Maintenance, Monthly
FO-323523	8/18/2015	8/26/2015		Generator Maintenance, Monthly
E - West			8	
FO-322385	8/1/2015	8/28/2015		PM - Domestic Water Heater, Steam
FO-322431	8/1/2015	8/28/2015		PM - Domestic Water Heater, Electric
FO-322432	8/1/2015	8/28/2015		PM - Water Softener
FO-322448	8/1/2015	8/28/2015		PM - Domestic Water Heater, Electric
FO-322456	8/1/2015	8/28/2015		PM - Domestic Water Heater, Electric
FO-322457	8/1/2015	8/28/2015		PM - Domestic Water Heater, Electric
FO-323009	8/11/2015	8/12/2015		Generator Maintenance, Monthly
FO-323661	8/27/2015	8/28/2015		Generator Maintenance, Monthly
Trades			43	
Routine			43	
T - Electrician			38	
FO-322990	8/7/2015			Generator Maintenance, Monthly
FO-323004	8/7/2015	8/7/2015		Generator Test Friday 8/7/2015 @ 2PM.

WO	Recieved	Finished	Total	Request
FO-323007	8/7/2015	8/4/2015		Generator Test Tuesday 8/4/2015 @ 7:15AM.
FO-323010	8/7/2015	8/7/2015		Generator Test Friday 8/7/2015 @ 2PM.
FO-323011	8/7/2015	8/7/2015		Generator Test Friday 8/7/2015 @ @PM.
FO-323012	8/7/2015	8/7/2015		Generator Test Friday 8/7/2015, @ 2PM.
FO-323005	8/11/2015	8/11/2015		Generator Test Tuesday 8/11/2015 @ 1PM.
FO-323526	8/12/2015	8/12/2015		Generator Test Wednesday 8/12/2015 @ 1PM.
FO-323515	8/13/2015	8/13/2015		Generator Test Thursday 8/13/2015 @ 7:15AM.
FO-323517	8/13/2015	8/13/2015		Generator Test Thursday 8/13/2015 @ 7:15AM.
FO-323529	8/13/2015	8/12/2015		Generator Test Wednesday 8/13/2015 @ 7:15AM.
FO-323502	8/14/2015			Generator Maintenance, Monthly
FO-323503	8/14/2015			Generator Maintenance, Monthly
FO-323524	8/14/2015	8/11/2015		Generator Test Tuesday 8/11/2015 @ 7:15AM.
FO-323525	8/14/2015	8/11/2015		Generator Test Tuesday 8/11/2015 @ 7:15AM.
FO-323532	8/14/2015	8/14/2015		Generator Test Friday 8/14/2015 @ 7:15AM.
FO-323533	8/14/2015	8/11/2015		Generator Test Tuesday 8/11/2015 @ 1PM.
FO-323513	8/18/2015			Generator Test
FO-323519	8/18/2015	8/25/2015		Generator Test
FO-323520	8/18/2015			Generator Test
FO-323522	8/18/2015			Generator Test
FO-323528	8/18/2015	8/25/2015		Generator Test\
				Completed 8-25-2015 SRP
FO-323635	8/19/2015	8/19/2015		Generator Test
FO-323654	8/19/2015	8/19/2015		Generator Test
FO-323656	8/20/2015			Generator Test
FO-323658	8/20/2015			Generator Test
FO-323642	8/25/2015			Generator Test Tuesday, 8/25/2015 @ 10AM.
FO-323644	8/25/2015			Generator Test Tuesday, 8/25/2015 @ 8AM.
FO-323646	8/25/2015			Generator Test Tuesday, 8/25/2015 @ 8AM.
FO-323648	8/25/2015			Generator Test Tuesday, 8/25/2015 @ 8AM.
FO-323650	8/25/2015			Generator Test Tuesday, 8/25/2015 @ 8AM.
FO-323637	8/26/2015	8/26/2015		Generator Test Wednesday, 8/26/2015 @ 7:15 AM.
FO-323652	8/26/2015			Generator Test Wednesday, 8/26/2015 @ 7:15 AM.
FO-323660	8/27/2015	8/28/2015		Generator Test Thursday, 8/27/2015 @ 7:15 AM.
FO-323662	8/27/2015			Generator Test Thursday, 8/27/2015 @ 1PM.
FO-323664	8/27/2015			Generator Test Thursday, 8/27/2015 @ 1PM.
FO-323638	8/28/2015			Generator Test Tuesday, 8/25/2015 @ 7:15 AM.
FO-323640	8/28/2015			Generator Test Tuesday, 8/25/2015 @ 2PM.
T - Plumber			5	
FO-321560	8/1/2015	8/14/2015		PM - Main Drain with Copper Sulfate.....DB.....8/3/15
FO-321561	8/1/2015	8/1/2015		**CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-321562	8/1/2015			PM - Waterless Urinals ,,,,,,,,,,,,,, MM/8-5-15 ,,,,,,,,,,,,,,
FO-321563	8/1/2015	8/1/2015		**CANCELLED JWT
				PM - Waterless Urinals
FO-321564	8/1/2015	8/1/2015		**CANCELLED JWT PM - Waterless Urinals

Total: 2262