

DRAFT Facilities Operations PM Analysis from 5/1/16 through 5/31/16

Requested Finished Open WND										% Finished
Engineering		933		607	245	81				65%
E - Auxiliary		55		55	-12	12				100%
FO-345456	Finished	509-CHWP-001	5/1/2016	5/5/2016		False	1.50	PM - Centrifugal Pump, over 1 H.P.		
checked coupling lubricated pump and motor checked operation										
FO-345457	Finished	509-CHWP-002	5/1/2016	5/5/2016		False	1.50	PM - Centrifugal Pump, over 1 H.P.		
lubricated pump and motor checked coupling checked operation										
FO-345458	Finished	509-CWP-001	5/1/2016	6/7/2016		False	2.00	PM - Centrifugal Pump, over 1 H.P.		
completed routine P.M.										
FO-345459	Finished	509-CWP-002	5/1/2016	5/31/2016		False	3.00	PM - Centrifugal Pump, over 1 H.P.		
completed PM										
FO-345460	Finished	511-CWP-001	5/1/2016	5/10/2016		False	0.50	PM - Centrifugal Pump, over 1 H.P.		
new project replaced pump not yet commissioned to WSU										
FO-345461	Finished	511-CWP-002	5/1/2016	5/10/2016		False	0.50	PM - Centrifugal Pump, over 1 H.P.		
new project replaced pump. It is not yet commissioned to WSU										
FO-345463	Finished	510-CHWP-001	5/1/2016	5/10/2016		False	1.50	PM - Centrifugal Pump, over 1 H.P.		
Lubricated pump and motor, checked coupling checked operation										
FO-345477	Finished	034-COT-001	5/1/2016	5/17/2016		False	8.00	PM - Cooling Tower, 500 - 1000 Tons		
Cleaned tower fill, trays and basin. Lubed motors and bearings. Checked oil for gear box.										
FO-345482	Finished	136-MAU-001	5/1/2016	6/30/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		
FO-345487	Finished	501-GEN-001	5/10/2016	5/11/2016		False		Generator Maintenance, Monthly		
FO-345488	Finished	127-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345489	Finished	104-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345490	Finished	115-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345491	Finished	134-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345492	Finished	507-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345493	Finished	992-COT-001	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345494	Finished	992-COT-002	5/1/2016	5/31/2016		False		PM - Cooling Tower, 500 - 1000 Tons		
FO-345495	Finished	134-CHWP-003	5/1/2016	6/30/2016		False	0.00	PM - Centrifugal Pump, over 1 H.P.		
FO-345496	Finished	134-CHWP-004	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345497	Finished	134-CWP-001	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345498	Finished	507-CWP-001	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345499	Finished	507-CHWP-004	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345500	Finished	507-CHWP-005	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345501	Finished	507-CHWP-015	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345502	Finished	507-CHWP-016	5/1/2016	6/30/2016		True		PM - Centrifugal Pump, over 1 H.P.		
FO-345503	Finished	536-AHU-201	5/1/2016	6/30/2016		True		PM - Air Handling Unit, HV Type		
FO-345504	Finished	992-ES-001*	5/2/2016	5/6/2016		False		PM - Emergency Shower/Eyewash Station		
FO-345505	Finished	536-HP-001	5/1/2016	6/30/2016		True		PM - Air Handling Unit, HV Type		
FO-345512	Completed	104-CWP-001	5/1/2016	4/29/2016		False	2.00	PM - Centrifugal Pump, over 1 H.P.		
Lubricated. Checked coupling. Cleaned. Checked electrical. Tightened bolts on suction and discharge line. Tested automatic switch-over.										

Requested Finished Open WND

% Finished

FO-345513	Completed	104-CWP-002	5/1/2016	4/29/2016	False	2.00	PM - Centrifugal Pump, over 1 H.P. Lubricated. Cleaned. Checked coupling and electrical. Tightened bolts on suction and discharge lines. Tested automatic switch-over.
FO-345514	Finished	115-GCP-001	5/1/2016	6/30/2016	True		PM - Centrifugal Pump, over 1 H.P.
FO-345515	Finished	115-GCP-002	5/1/2016	6/30/2016	True		PM - Centrifugal Pump, over 1 H.P.
FO-345516	Finished	507-CHWP-001	5/1/2016	6/30/2016	True		PM - Centrifugal Pump, over 1 H.P.
FO-345523	Finished	001 SPARE from	5/11/2016	5/10/2016	False		Generator Maintenance, Monthly
FO-345554	Finished	134-ACU-001	5/1/2016	5/31/2016	False		PM - York Chillers: Startup Services for Absorber Chillers
FO-345557	Finished	507-ACU-001	5/1/2016	5/31/2016	False		PM - York Chillers: Startup Services for Absorber Chillers
FO-345558	Finished	134-ACU-001	5/1/2016	5/13/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345568	Finished	507-ACU-001	5/1/2016	5/13/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345573	Finished	134-FP-001	5/1/2016	5/31/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-345574	Finished	127-FP-001	5/1/2016	5/31/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-345575	Finished	115-FP-001	5/1/2016	5/31/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-345576	Finished	104-FP-001	5/1/2016	5/31/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-345577	Finished	507-FP-001	5/1/2016	5/31/2016	False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-345940	Finished	104-GEN-001	5/24/2016	5/25/2016	False		Generator Maintenance, Monthly
FO-345942	Finished	127-GEN-001	5/24/2016	5/25/2016	False		Generator Maintenance, Monthly
FO-345944	Finished	127-GEN-002	5/24/2016	5/25/2016	False		Generator Maintenance, Monthly
FO-345946	Finished	127-GEN-003	5/24/2016	5/25/2016	False		Generator Maintenance, Monthly
FO-345948	Finished	127-GEN-004	5/24/2016	5/25/2016	False		Generator Maintenance, Monthly
FO-345956	Finished	507-GEN-001	5/11/2016	5/12/2016	False		Generator Maintenance, Monthly
FO-345963	Finished	536-GEN-001	5/18/2016	5/18/2016	False		Generator Maintenance, Monthly
FO-345985	Finished	034-GEN-001	5/5/2016	5/5/2016	False	1.00	Generator Maintenance, Monthly Checked system before and after test.
FO-346085	Finished	992-ES-001*	5/9/2016	5/13/2016	False		PM - Emergency Shower/Eyewash Station
FO-346477	Finished	992-ES-001*	5/16/2016	5/20/2016	False		PM - Emergency Shower/Eyewash Station
FO-347085	Finished	992-ES-001*	5/23/2016	5/27/2016	False		PM - Emergency Shower/Eyewash Station
FO-347459	Finished	992-ES-001*	5/30/2016	5/31/2016	False		PM - Emergency Shower/Eyewash Station
E - Director			29	1	28	0	3%
FO-345526	Created By PM Schedule	637-ACU-003	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345527	Created By PM Schedule	637-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345528	Created By PM Schedule	629-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345529	Created By PM Schedule	629-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345530	Created By PM Schedule	612-ACU-003	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345531	Created By PM Schedule	499-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345532	Created By PM Schedule	193-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345533	Created By PM Schedule	155-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345534	Created By PM Schedule	155-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345535	Created By PM Schedule	140-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345536	Created By PM Schedule	140-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345537	Created By PM Schedule	089-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345538	Created By PM Schedule	062-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345539	Created By PM Schedule	062-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers

Requested Finished Open WND

% Finished

FO-345540	Created By PM Schedule	050-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345541	Created By PM Schedule	049-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345542	Created By PM Schedule	048-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345543	Created By PM Schedule	046-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345544	Created By PM Schedule	039-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345545	Created By PM Schedule	039-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345546	Created By PM Schedule	026-ACU-003	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345547	Created By PM Schedule	026-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345548	Created By PM Schedule	026-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345549	Created By PM Schedule	016-ACU-004	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345550	Created By PM Schedule	006-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345551	Finished completed	003-ACU-001	5/1/2016	5/31/2016	False	8.00	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345552	Created By PM Schedule	082-ACU-003	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345553	Created By PM Schedule	043-ACU-001	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
FO-345579	Created By PM Schedule	193-ACU-002	5/1/2016		False		PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers
E - MedPharm			88	36	52	0	41%
FO-345041	Finished cleaned tower	609-COT-001	5/1/2016	6/8/2016	False		PM - Cooling Tower, 500 - 1000 Tons
FO-345042	Finished cleaned tower	609-COT-002	5/1/2016	6/8/2016	False		PM - Cooling Tower, 500 - 1000 Tons
FO-345043	Finished cleaned fill trays/ checked lube cleaned sump/ eliminators	603-COT-001	5/1/2016	4/14/2016	False	6.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345044	Finished cleaned trays/ checked lube cleaned sump/ eliminators/ filth to trash	603-COT-002	5/1/2016	4/14/2016	False	12.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345045	Finished lubed/ cleaned dry run	603-CWP-001	5/1/2016	3/21/2016	False	2.00	PM - Centrifugal Pump, over 1 H.P.
FO-345046	Finished done	603-CWP-002	5/1/2016	3/21/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345047	Finished added oil, found air leak at small fitting	603-AC-001	5/1/2016	5/6/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-345048	Finished cleaned / greased pump	603-CHWP-001	5/1/2016	4/14/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345049	Finished greased pump checked roll	603-CHWP-002	5/1/2016	4/14/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345050	Created By PM Schedule	603-CHWP-003	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345051	Created By PM Schedule	603-CHWP-004	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345052	Created By PM Schedule	603-CHWP-005	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-345053	Created By PM Schedule	603-HRP-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345054	Created By PM Schedule	603-HRP-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345055	Created By PM Schedule	603-PCW-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345056	Created By PM Schedule	603-PCW-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345057	Created By PM Schedule	603-DWBP-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345058	Created By PM Schedule	603-DWBP-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345059	Created By PM Schedule	603-DWBP-003	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345060	Created By PM Schedule	608-DWBP-004	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345061	Finished	611-CHWP-004	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings
FO-345062	Finished	611-CHWP-005	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings
FO-345063	Finished	611-CHWP-003	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings.
FO-345064	Finished	611-CWP-001	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings.
FO-345065	Finished	611-CWP-002	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings.
FO-345066	Finished	611-CWP-000	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Greased motor and bearings.
FO-345067	Finished	611-DWBP-001	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P. Sealed bearings. Checked operation, OK
FO-345068	Finished	611-COT-001**	5/1/2016	6/27/2016	False	7.00	PM - Cooling Tower, 500 - 1000 Tons Cleaned cooling tower. PM'ed fans. West side fan needs new bearing.
FO-345069	Finished	529-CHWP-009A	5/1/2016	5/16/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345070	Finished	529-CHWP-009C	5/1/2016	5/16/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345071	Finished	629-CHWP-010	5/1/2016	5/17/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345072	Finished	29-CHWP-011*	5/1/2016	5/17/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345073	Finished	629-COT-001	5/1/2016	5/18/2016	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345074	Finished	629-COT-002	5/1/2016	5/18/2016	False	1.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345075	Finished	629-CWP-007	5/1/2016	5/19/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345076	Finished	629-CWP-008	5/1/2016	5/19/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345077	Finished	629-HEX-001	5/1/2016	5/26/2016	False	0.50	PM - Heat Exchanger and Economizer
FO-345078	Finished	629-HEX-002	5/1/2016	5/26/2016	False	0.50	PM - Heat Exchanger and Economizer
FO-345079	Created By PM Schedule	612-CHWP-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345080	Created By PM Schedule	612-CHWP-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345081	Created By PM Schedule	612-CHWP-003	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345082	Created By PM Schedule	612-CHWP-004	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345083	Created By PM Schedule	612-COT-001	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345084	Created By PM Schedule	612-COT-002	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345085	Created By PM Schedule	612-COT-003	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345086	Created By PM Schedule	612-COT-004	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345087	Created By PM Schedule	612-CWP-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345088	Created By PM Schedule	612-CWP-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-345089	Created By PM Schedule	612-CWP-003	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345090	Created By PM Schedule	612-CWP-004	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345091	Created By PM Schedule	612-CWP-005	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345092	Created By PM Schedule	612-CWP-006	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345093	Created By PM Schedule	612-CWP-007	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345094	Created By PM Schedule	612-CWP-008	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345095	Created By PM Schedule	612-CWP-009	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345096	Created By PM Schedule	612-DWBP-001	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345097	Created By PM Schedule	612-DWBP-002	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345098	Created By PM Schedule	612-DWBP-003	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345099	Finished	529-CHWP-009E	5/1/2016	5/31/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345100	Finished	529-CHWP-009E	5/1/2016	5/31/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345101	Created By PM Schedule	612-DWBP-020	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345102	Created By PM Schedule	612-DWBP-021	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345103	Created By PM Schedule	612-DWBP-022	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345104	Created By PM Schedule	612-DWBP-023	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345105	Created By PM Schedule	612-DWBP-024	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345106	Created By PM Schedule	612-DWBP-025	5/1/2016		False		PM - Centrifugal Pump, over 1 H.P.
FO-345107	Created By PM Schedule	612-GEN-001	5/10/2016		False		Generator Maintenance, Monthly
FO-345108	Created By PM Schedule	612-GEN-002	5/10/2016		False		Generator Maintenance, Monthly
FO-345109	Created By PM Schedule	608-GEN-001	5/3/2016		False		Generator Maintenance, Monthly
FO-345110	Finished	629-LCP-001	5/1/2016	5/31/2016	False	0.15	PM - Centrifugal Pump, over 1 H.P.
FO-345111	Created By PM Schedule	608-COT-002	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345112	Created By PM Schedule	608-COT-001	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345113	Finished	603-COT-003	5/1/2016	3/15/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
cleaned fills / sump screen removed cleaned							
FO-345114	Created By PM Schedule	612-ACU-002	5/1/2016		False		PM - York Chillers: Startup Services for Absorber Chillers
FO-345115	Created By PM Schedule	612-ACU-001	5/1/2016		False		PM - York Chillers: Startup Services for Absorber Chillers
FO-345116	Created By PM Schedule	612-ACU-002	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345117	Created By PM Schedule	612-ACU-001	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345118	Finished	611-ACU-002**	5/1/2016	6/27/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Trane here for PM maintenance.							
FO-345119	Finished	611-ACU-001**	5/1/2016	6/27/2016	False	0.10	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Trane here for chiller maintenance. Chiller has not ran this year due to bad flow switch.							
FO-345120	Created By PM Schedule	608-ACU-001	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345121	Created By PM Schedule	603-ACU-002	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345122	Created By PM Schedule	603-ACU-001	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345123	Created By PM Schedule	608-ACU-002	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345124	Created By PM Schedule	603-GEN-001	5/3/2016		False		Generator Maintenance, Monthly
FO-345937	Finished	611-GEN-001	5/24/2016	6/27/2016	False	0.50	Generator Maintenance, Monthly
Electricians did monthly generator load test.							
FO-345966	Finished	609-GEN-001	5/17/2016	5/19/2016	False		Generator Maintenance, Monthly
checked fluids							
FO-346005	Created By PM Schedule	629-GEN-001	5/24/2016		False		Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-347458	Finished	603-ROS-001	5/28/2016	6/28/2016	False	1.00	PM - Reverse Osmosis Water Softener System
assist evoqua waters RO UNIT							

E - North			80	77	3	0		96%
------------------	--	--	-----------	-----------	----------	----------	--	------------

FO-345017	Finished	025-AHU-005	5/1/2016	5/13/2016	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-345018	Created By PM Schedule	025-AHU-004	5/1/2016		False	0.00	PM - Air Handling Unit (ANNUAL) - Filters
FO-345019	Created By PM Schedule	025-AHU-003	5/1/2016		False		PM - Air Handling Unit (ANNUAL)
FO-345020	Created By PM Schedule	025-AHU-002	5/1/2016		False		PM - Air Handling Unit (ANNUAL)
FO-345021	Finished	025-AHU-001	5/1/2016	6/20/2016	False	1.50	PM - Air Handling Unit (ANNUAL)
FO-345125	Finished	140-HRP-001	5/1/2016	5/4/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345126	Finished	140-HRP-002	5/1/2016	5/4/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345127	Finished	140-CHWP-001	5/1/2016	5/3/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345128	Finished	140-CHWP-002	5/1/2016	5/3/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345129	Finished	140-CWP-001	5/1/2016	5/3/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345130	Finished	140-CWP-002	5/1/2016	5/10/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345131	Finished	140-COT-001	5/1/2016	5/6/2016	False	3.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345132	Finished	026-CHWP-007	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345133	Finished	026-CHWP-008	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345134	Finished	026-CHWP-009	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345135	Finished	026-CHWP-010	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345136	Finished	026-CHWP-013	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345137	Finished	026-CHWP-014	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345138	Finished	026-CHWP-015	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345139	Finished	026-CHWP-016	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345140	Finished	026-CWP-010	5/1/2016	5/16/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345141	Finished	026-CWP-011	5/1/2016	5/16/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345142	Finished	026-CWP-012	5/1/2016	5/16/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345143	Finished	026-CWP-013	5/1/2016	5/23/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345144	Finished	050-COT-001	5/1/2016	5/13/2016	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345145	Finished	050-RHC-001	5/1/2016	5/17/2016	False	1.50	PM - Unspecified
FO-345146	Finished	050-RHC-002	5/1/2016	5/17/2016	False	1.50	PM - Unspecified
FO-345147	Finished	050-RHC-003	5/1/2016	5/16/2016	False	1.50	PM - Unspecified
FO-345148	Finished	050-RHC-004	5/1/2016	5/23/2016	False	1.50	PM - Unspecified
FO-345149	Finished	050-RHC-005	5/1/2016	5/23/2016	False	1.50	PM - Unspecified
FO-345150	Finished	050-RHC-006	5/1/2016	5/24/2016	False	1.00	PM - Unspecified
FO-345151	Finished	050-RHC-007	5/1/2016	5/17/2016	False	1.00	PM - Unspecified
FO-345152	Finished	050-RHC-008	5/1/2016	5/16/2016	False	1.00	PM - Unspecified
FO-345153	Finished	050-RHC-009	5/1/2016	5/13/2016	False	1.00	PM - Unspecified
FO-345154	Finished	050-RHC-010	5/1/2016	5/11/2016	False	1.00	PM - Unspecified
FO-345155	Finished	050-RHC-011	5/1/2016	5/10/2016	False	1.00	PM - Unspecified
FO-345156	Finished	050-RHC-012	5/1/2016	5/9/2016	False	1.00	PM - Unspecified
FO-345157	Finished	050-RHC-013	5/1/2016	5/24/2016	False	1.00	PM - Unspecified
FO-345158	Finished	050-RHC-014	5/1/2016	5/18/2016	False	1.50	PM - Unspecified
FO-345159	Finished	050-SP-003	5/1/2016	5/20/2016	False	1.00	PM - Sump Pump
FO-345160	Finished	026-HWP-005	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-345161	Finished	026-HWP-006	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345162	Finished	046-CFP-002	5/1/2016	5/12/2016	False	0.52	PM - Chemical Feed/Metering Pump/Controller
FO-345163	Finished	046-CFP-003	5/1/2016	5/12/2016	False	0.55	PM - Chemical Feed/Metering Pump/Controller
FO-345164	Finished	048-CFP-002	5/1/2016	5/12/2016	False	0.51	PM - Chemical Feed/Metering Pump/Controller
FO-345165	Finished	048-CFP-003	5/1/2016	5/12/2016	False	0.52	PM - Chemical Feed/Metering Pump/Controller
FO-345166	Finished	048-CFP-001	5/1/2016	5/12/2016	False	0.54	PM - Chemical Feed/Metering Pump/Controller
FO-345167	Finished	022-CFP-001	5/1/2016	5/20/2016	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked all tubing connections, primed the pump and adjusted the speed and stroke of the pump. Also checked setting of tower controller.							
FO-345168	Finished	022-CFP-002	5/1/2016	5/20/2016	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked all tubing connections, primed the pump and adjusted the speed and stroke of the pump. Also checked setting of tower controller.							
FO-345169	Finished	022-CFP-003	5/1/2016	5/20/2016	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked all tubing connections, primed the pump and adjusted the speed and stroke of the pump. Also checked setting of tower controller.							
FO-345170	Finished	140-DWBP-001	5/1/2016	5/2/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345171	Finished	140-DWBP-002	5/1/2016	5/2/2016	False	1.50	PM - Centrifugal Pump, over 1 H.P.
FO-345172	Finished	039-COT-001	5/1/2016	5/25/2016	False	3.00	PM - Cooling Tower, 500 - 1000 Tons
Greased bearings, checked belts and operation of fans.							
FO-345173	Finished	026-CHWP-011	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345174	Finished	026-CHWP-012	5/1/2016	5/24/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345175	Finished	026-COT-001	5/1/2016	5/12/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345176	Finished	026-COT-002	5/1/2016	5/10/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345177	Finished	026-COT-003	5/1/2016	5/5/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345178	Finished	026-COT-004	5/1/2016	5/3/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345179	Finished	036-COT-001	5/1/2016	5/2/2016	False	3.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345180	Finished	048-SSF-001	5/1/2016	5/25/2016	False	0.45	PM - Harmsco Side Stream Filter
FO-345181	Finished	048-SSF-002	5/1/2016	5/25/2016	False	0.52	PM - Harmsco Side Stream Filter
FO-345182	Finished	046-SSF-001	5/1/2016	5/12/2016	False	0.77	PM - Harmsco Side Stream Filter
FO-345183	Finished	046-SSF-003	5/1/2016	5/12/2016	False	0.75	PM - Harmsco Side Stream Filter
FO-345184	Finished	036-CFP-001	5/1/2016	5/16/2016	False	0.10	PM - Chemical Feed/Metering Pump/Controller
FO-345185	Finished	026-HEX-001	5/1/2016	5/24/2016	False	0.50	PM - Heat Exchanger and Economizer
FO-345186	Finished	026-CWP-001	5/1/2016	6/27/2016	False	0.25	PM - Centrifugal Pump, over 1 H.P.
FO-345187	Finished	025-DHW-001	5/1/2016	5/24/2016	False	0.25	PM - Domestic Water Heater, Steam
FO-345188	Finished	046-SSF-002	5/1/2016	5/12/2016	False	0.70	PM - Harmsco Side Stream Filter
FO-345189	Finished	046-CFP-001	5/1/2016	5/12/2016	False	0.55	PM - Chemical Feed/Metering Pump/Controller
FO-345190	Finished	049-CHWBP-001	5/1/2016	5/18/2016	False	0.45	PM - Water Booster Pump
FO-345191	Finished	049-CHWBP-002	5/1/2016	5/18/2016	False	0.55	PM - Water Booster Pump
FO-345192	Finished	048-GEN-001	5/10/2016	5/10/2016	False	0.56	Generator Maintenance, Monthly
FO-345193	Finished	049-COT-001	5/1/2016	4/20/2016	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345194	Finished	048-COT-001	5/1/2016	4/21/2016	False	2.50	PM - Cooling Tower, 500 - 1000 Tons
FO-345195	Finished	046-COT-001	5/1/2016	4/20/2016	False	2.50	PM - Cooling Tower, 500 - 1000 Tons
FO-345196	Finished	026-ACU-004	5/1/2016	5/1/2014	False	1.00	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers
FO-345954	Finished	130-GEN-001	5/25/2016	5/25/2016	False	1.50	Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-346080 Finished 040-SAF-002 5/6/2016 6/8/2016 False 1.00 PM - Outside/Fresh Air Intake Screens
Checked and cleaned screens on intakes.

FO-346081 Finished 040-SAF-003 5/6/2016 6/8/2016 False 1.00 PM - Outside/Fresh Air Intake Screens
Checked and cleaned screens on outside air intakes.

E - Northeast

58

58

0

0

100%

FO-345011 Finished 209-AHU-005 5/1/2016 5/11/2016 False 2.00 Replace PRE-filters
FO-345012 Finished 209-AHU-004B 5/1/2016 5/24/2016 False 2.00 Replace PRE-filters
FO-345013 Finished 209-AHU-004A 5/1/2016 5/18/2016 False 2.00 Replace PRE-filters
FO-345014 Finished 209-AHU-002 5/1/2016 5/27/2016 False 2.00 Replace PRE-filters
FO-345197 Finished 062-CHWP-003 5/1/2016 6/1/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345198 Finished 062-CHWP-004 5/1/2016 6/1/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345199 Finished 193-CHWP-001 5/1/2016 7/12/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345200 Finished 193-CWP-001 5/1/2016 6/29/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345201 Finished 193-WSS-001 5/1/2016 5/13/2016 False 2.00 PM - Water Softener
FO-345202 Finished 193-COT-001 5/1/2016 5/2/2016 False 4.00 PM - Cooling Tower, 500 - 1000 Tons
FO-345203 Finished 193-COT-002 5/1/2016 4/5/2016 False 1.00 PM - Cooling Tower, 500 - 1000 Tons
FO-345204 Finished 193-CFP-003 5/1/2016 6/29/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345205 Finished 060-ACU-020 5/1/2016 5/11/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345206 Finished 060-ACU-021 5/1/2016 5/10/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345207 Finished 060-ACU-022 5/1/2016 5/10/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345208 Finished 060-ACU-023 5/1/2016 5/18/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345209 Finished 060-ACU-024 5/1/2016 5/10/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345210 Finished 060-ACU-025 5/1/2016 5/10/2016 False 4.00 PM - Fan Coil/HV/AC Unit
FO-345211 Finished 060-ACU-026 5/1/2016 5/13/2016 False PM - Fan Coil/HV/AC Unit
FO-345212 Finished 060-ACU-027 5/1/2016 5/16/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345213 Finished 060-ACU-028 5/1/2016 5/17/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345214 Finished 195-ACU-001 5/1/2016 6/1/2016 False 1.00 PM - Fan Coil/HV/AC Unit
FO-345215 Finished 195-ACU-002 5/1/2016 5/27/2016 False 1.00 PM - Fan Coil/HV/AC Unit
FO-345216 Finished 195-ACU-003 5/1/2016 6/15/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345217 Finished 066-CHWP-001 5/1/2016 5/17/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345218 Finished 067-CHWP-001 5/1/2016 5/13/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345219 Finished 193-DWBP-001 5/1/2016 6/29/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
FO-345220 Finished 509-COT-001 5/1/2016 5/6/2016 False 6.00 PM - Cooling Tower, 500 - 1000 Tons

Lubricated fan bearings, checked belts cleaned basin filled with water test ran unit

FO-345221 Finished 511-COT-001 5/1/2016 5/17/2016 False 6.00 PM - Cooling Tower, 500 - 1000 Tons
lubricated motor and fan checked louvers checked operation cleaned sump

FO-345222 Completed 067-ACU-109 5/1/2016 5/13/2016 False 2.00 PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345223 Finished 065-ACU-001 5/1/2016 5/13/2016 False 4.00 PM - McQuay Chillers: Seasonal Start Up for Centrifugal & Screw (Air cooled) Chillers
FO-345224 Finished 203-ACU-001 5/1/2016 5/16/2016 False 0.10 Clean condenser coils
FO-345225 Finished 203-ACU-002 5/1/2016 5/16/2016 False 0.10 Clean condenser coils
FO-345226 Finished 203-ACU-003 5/1/2016 5/16/2016 False 0.10 Clean condenser coils
FO-345227 Finished 060-ACU-029 5/1/2016 5/12/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345228 Finished 060-ACU-030 5/1/2016 5/11/2016 False 2.00 PM - Fan Coil/HV/AC Unit
FO-345229 Finished 060-ACU-031 5/1/2016 5/18/2016 False PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-345230	Finished	060-ACU-032	5/1/2016	5/9/2016	False	2.00	PM - Fan Coil/HV/AC Unit
FO-345231	Finished	060-ACU-033	5/1/2016	5/16/2016	False	2.00	PM - Fan Coil/HV/AC Unit
FO-345232	Finished	060-ACU-034	5/1/2016	5/9/2016	False	2.00	PM - Fan Coil/HV/AC Unit
FO-345233	Finished	060-ACU-035	5/1/2016	5/11/2016	False	2.00	PM - Fan Coil/HV/AC Unit
FO-345934	Finished	066-GEN-001	5/25/2016	5/25/2016	False	2.00	Generator Maintenance, Monthly
FO-345958	Finished	203-GEN-001	5/17/2016	5/17/2016	False	1.00	Generator Maintenance, Monthly
FO-345965	Finished	527-GEN-001	5/19/2016	6/6/2016	False	3.50	Generator Maintenance, Monthly
checked fluid levels, louver operation battery and connections checked for leaks							
FO-345967	Finished	193-GEN-001	5/6/2016	5/6/2016	False	1.00	Generator Maintenance, Monthly
FO-345969	Finished	GEN-001 (Towa	5/11/2016	5/11/2016	False	1.00	Generator Maintenance, Monthly
FO-345973	Finished	193-GEN-002	5/6/2016	5/6/2016	False	1.00	Generator Maintenance, Monthly
FO-345975	Finished	193-GEN-003	5/6/2016	5/6/2016	False	1.00	Generator Maintenance, Monthly
FO-345977	Finished	193-GEN-004	5/6/2016	5/6/2016	False		Generator Maintenance, Monthly
FO-345981	Finished	060-GEN-001A	5/26/2016	5/18/2016	False	1.00	Generator Maintenance, Monthly
FO-345983	Finished	060-GEN-001B	5/26/2016	5/27/2016	False	2.00	Generator Maintenance, Monthly
FO-345994	Finished	209-GEN-001	5/5/2016	5/5/2016	False	1.50	Generator Maintenance, Monthly
FO-345996	Finished	209-GEN-003	5/5/2016	5/5/2016	False	0.10	Generator Maintenance, Monthly
FO-345998	Finished	209-GEN-004	5/5/2016	5/5/2016	False	1.00	Generator Maintenance, Monthly
FO-346001	Finished	209-GEN-002	5/5/2016	5/5/2016	False	1.50	Generator Maintenance, Monthly
FO-346002	Finished	211-GEN-001	5/6/2016	5/5/2016	False	1.50	Generator Maintenance, Monthly
FO-346003	Finished	211-GEN-002	5/6/2016	5/5/2016	False	1.00	Generator Maintenance, Monthly
FO-346463	Finished	509-HWP-010	5/16/2016	5/13/2016	False	1.00	PB - B&G Series 100 Pump

checked for leaks lubricated checked operation and coupling

E - Preventative Maintenance **326** **257** **54** **15** **79%**

FO-341182	Finished	611-AHU-007**	5/1/2016	5/25/2016	False	10.00	Replace PRE-filters
FO-341183	Finished	611-AHU-006	5/1/2016	6/8/2016	False	2.00	Replace PRE-filters
FO-341184	Finished	611-AHU-005	5/1/2016	6/8/2016	False	2.00	Replace PRE-filters
FO-341185	Finished	611-AHU-004	5/1/2016	6/9/2016	False	4.00	Replace PRE-filters
FO-341186	Finished	611-AHU-003	5/1/2016	5/24/2016	False	4.00	Replace PRE-filters
FO-343834	Finished	016-EXF-001	5/1/2016	5/12/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343835	Finished	016-EXF-002	5/1/2016	5/4/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343836	Finished	016-EXF-003	5/1/2016	5/4/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343837	Finished	022-EXF-001	5/1/2016	5/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343838	Finished	603-EXF-001	5/1/2016	5/19/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343839	Finished	603-EXF-002	5/1/2016	5/19/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343840	Finished	503-EXF-001-A-F	5/1/2016	5/10/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343841	Finished	503-EXF-002-B-F	5/1/2016	5/11/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343842	Finished	603-EXF-003	5/1/2016	5/11/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343843	Finished	503-EXF-003-A-F	5/1/2016	5/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343844	Finished	503-EXF-004-A-F	5/1/2016	5/11/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343845	Finished	503-EXF-004-B-F	5/1/2016	5/11/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343846	Finished	603-EXF-005	5/1/2016	5/10/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343847	Finished	603-EXF-006	5/1/2016	5/10/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343848	Finished	603-EXF-007	5/1/2016	5/10/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-343849	Finished	603-EXF-008	5/1/2016	5/12/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343850	Finished	603-EXF-009	5/1/2016	5/12/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343851	Created By PM Schedule	603-EXF-010	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343852	Created By PM Schedule	603-EXF-012	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343853	Created By PM Schedule	603-EXF-013	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343854	Finished	603-EXF-015	5/1/2016	5/12/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343855	Finished	611-EXF-001	5/1/2016	6/7/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343856	Finished	611-EXF-002	5/1/2016	6/7/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343857	Finished	611-EXF-003	5/1/2016	6/8/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343858	Finished	611-EXF-003A	5/1/2016	6/16/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343859	Finished	611-EXF-004	5/1/2016	6/8/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343860	Created By PM Schedule	611-EXF-005	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343861	Finished	611-EXF-024**	5/1/2016	6/16/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343862	Finished	611-EXF-025	5/1/2016	6/8/2016	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343863	Finished	611-EXF-026	5/1/2016	6/8/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343864	Created By PM Schedule	611-EXF-027**	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343865	Finished	611-EXF-028**	5/1/2016	5/25/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343866	Finished	611-EXF-031	5/1/2016	6/16/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343867	Created By PM Schedule	611-EXF-032**	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343868	Finished	611-EXF-033	5/1/2016	5/25/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343869	Finished	629-EXF-001	5/1/2016	6/28/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343870	Created By PM Schedule	629-EXF-002**	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343871	Created By PM Schedule	629-EXF-003	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343872	Created By PM Schedule	629-EXF-004A	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343873	Created By PM Schedule	629-EXF-004B	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343874	Created By PM Schedule	629-EXF-005A	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343875	Created By PM Schedule	629-EXF-005B	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343876	Created By PM Schedule	629-EXF-006	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343877	Created By PM Schedule	629-EXF-007	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343878	Finished	629-EXF-008A	5/1/2016	6/29/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343879	Finished	629-EXF-008B	5/1/2016	6/28/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343880	Created By PM Schedule	629-EXF-009	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343881	Created By PM Schedule	629-EXF-010	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343882	Created By PM Schedule	629-EXF-012	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343883	Finished	629-EXF-014	5/1/2016	6/29/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343884	Created By PM Schedule	629-EXF-015	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343885	Created By PM Schedule	062-EXF-001	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343886	Created By PM Schedule	062-EXF-002	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343887	Created By PM Schedule	062-EXF-003	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343888	Created By PM Schedule	062-EXF-004	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343889	Created By PM Schedule	062-EXF-005	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343890	Created By PM Schedule	062-EXF-006	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343891	Created By PM Schedule	046-EXF-001	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343892	Finished	001-EXF-001	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan

Requested Finished Open WND

% Finished

FO-343893	Finished	001-EXF-EF1B	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343894	Finished	001-EXF-001OA	5/1/2016	4/28/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343895	Finished	001-EXF-002	5/1/2016	4/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343896	Finished	001-EXF-002OA	5/1/2016	4/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343897	Cancelled	001-EXF-003-1	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343898	Cancelled	001-EXF-003-2	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343899	Cancelled	001-EXF-003-3	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343900	Finished	001-EXF-003OA	5/1/2016	5/9/2016	True	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343901	Finished	001-EXF-004	5/1/2016	4/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343902	Finished	001-EXF-004OA	5/1/2016	5/9/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343903	Cancelled	001-EXF-005-1	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343904	Cancelled	001-EXF-005-2	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343905	Cancelled	001-EXF-005-3	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343906	Cancelled	001-EXF-005-4	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343907	Cancelled	001-EXF-005-5	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343908	Finished	001-EXF-006-1	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343909	Finished	001-EXF-006-2	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343910	Finished	001-EXF-007	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343911	Finished	001-EXF-008-1	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343912	Finished	001-EXF-008-2	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343913	Finished	001-EXF-009-1	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343914	Finished	001-EXF-009-2	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343915	Finished	001-EXF-010	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343916	Finished	001-EXF-011	5/1/2016	4/30/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343917	Finished	001-EXF-012-1	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343918	Finished	001-EXF-012-2	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343919	Finished	001-EXF-013	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343920	Finished	001-EXF-014	5/1/2016	4/30/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343921	Finished	001-EXF-015	5/1/2016	4/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343922	Finished	001-EXF-016B	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343923	Finished	001-EXF-016D	5/1/2016	4/28/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343924	Finished	001-EXF-019A	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343925	Finished	001-EXF-019C	5/1/2016	5/3/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343926	Finished	001-EXF-020	5/1/2016	4/29/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343927	Finished	001-EXF-021	5/1/2016	5/24/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343928	Finished	001-RAF-001	5/1/2016	5/24/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343929	Finished	090-ACU-1305	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343930	Finished	090-ACU-1310	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343931	Finished	090-ACU-1320	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343932	Finished	090-ACU-1325	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343933	Finished	090-ACU-1330.1	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343934	Finished	090-ACU-1330.2	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343935	Finished	090-ACU-1336	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343936	Finished	090-ACU-1338	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type

Requested Finished Open WND

% Finished

FO-343937	Finished	090-ACU-1342	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343938	Finished	090-ACU-1344	5/1/2016	5/24/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343939	Finished	090-ACU-1348	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343940	Finished	090-ACU-1350	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343941	Finished	090-ACU-1353	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343942	Finished	090-ACU-1354	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343943	Finished	090-ACU-1355	5/1/2016	5/24/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343944	Finished	090-ACU-1356	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343945	Finished	090-ACU-1359	5/1/2016	5/24/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343946	Finished	090-ACU-1360	5/1/2016	5/23/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343947	Finished	090-ACU-1361	5/1/2016	5/24/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343948	Finished	090-ACU-1405	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343949	Finished	090-ACU-2310	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343950	Finished	090-ACU-2311	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343951	Finished	090-ACU-2316	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343952	Finished	090-ACU-2319.1	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343953	Finished	090-ACU-2319.2	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343954	Finished	090-ACU-2330	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343955	Finished	090-ACU-2332	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343956	Finished	090-ACU-2335	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343957	Finished	090-ACU-2336	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343958	Finished	090-ACU-2342	5/1/2016	5/25/2016	False	0.25	PM - Air Handling Unit, HV Type
FO-343959	Finished	090-ACU-2348	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343960	Finished	090-ACU-2359	5/1/2016	6/1/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343961	Finished	090-ACU-2360	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343962	Finished	090-ACU-2404	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343963	Finished	090-ACU-2405	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343964	Finished	090-ACU-2410	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343965	Finished	090-ACU-0315.1	5/1/2016	5/31/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343966	Finished	090-ACU-0315.2	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343967	Finished	090-ACU-0320	5/1/2016	4/6/2016	False		PM - Air Handling Unit, HV Type
FO-343968	Finished	090-ACU-0320.1	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343969	Finished	090-ACU-0320.2	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343970	Finished	090-ACU-0324	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343971	Finished	090-ACU-0325	5/1/2016	5/31/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343972	Finished	090-ACU-0327	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343973	Finished	090-ACU-0330	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343974	Finished	090-ACU-3310	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343975	Finished	090-ACU-3317	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343976	Finished	090-ACU-3321	5/1/2016	5/27/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343977	Finished	090-ACU-3325	5/1/2016	5/27/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343978	Finished	090-ACU-3330	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343979	Finished	090-ACU-3335	5/1/2016	5/27/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-343980	Finished	090-ACU-3340	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type

Requested Finished Open WND

% Finished

FO-343981	Finished	090-ACU-3350	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343982	Finished	090-ACU-3354	5/1/2016	5/27/2016	False	0.25	PM - Air Handling Unit, HV Type
FO-343983	Finished	090-ACU-3355	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343984	Finished	090-ACU-3359	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343985	Finished	090-ACU-3359.1	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343986	Finished	090-ACU-3360	5/1/2016	5/27/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343987	Finished	023-EXF-001	5/1/2016	5/5/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
Moved to June for future PM's.							
FO-343988	Created By PM Schedule	001-EXF-005-6	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343989	Finished	001-EXF-006	5/1/2016	5/5/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343990	Finished	001-EXF-018	5/1/2016	5/24/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343991	Finished	001-EXF-EF1D	5/1/2016	4/28/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343992	Finished	001-EXF-007-2	5/1/2016	4/29/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343993	Finished	090-ACU-0331	5/1/2016	5/31/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-343994	Finished	003-EXF-001-B-F	5/1/2016	5/10/2016	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343995	Finished	003-EXF-002-A-F	5/1/2016	5/12/2016	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343996	Finished	003-EXF-003-B-F	5/1/2016	5/17/2016	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343997	Finished	603-EXF-017	5/1/2016	5/12/2016	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343998	Finished	603-EXF-018	5/1/2016	5/12/2016	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-343999	Finished	001-EXF-022A	5/1/2016	5/19/2016	False	2.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344000	Finished	001-EXF-022B	5/1/2016	5/11/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344001	Created By PM Schedule	048-SF-001	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344002	Created By PM Schedule	048-SF-002	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344003	Created By PM Schedule	048-EXF-001	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344004	Created By PM Schedule	048-EXF-002	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344005	Created By PM Schedule	048-EXF-003	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344006	Created By PM Schedule	049-EXF-008	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344007	Created By PM Schedule	049-EXF-007	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344008	Created By PM Schedule	049-EXF-005	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344009	Created By PM Schedule	049-EXF-004	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344010	Created By PM Schedule	049-EXF-003	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344011	Created By PM Schedule	049-EXF-002	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344012	Finished	090-ACU-1410	5/1/2016	5/25/2016	False	0.75	PM - Air Handling Unit, HV Type
FO-344013	Finished	090-ACU-2305.1	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344014	Finished	090-ACU-2326	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344015	Finished	090-ACU-2327	5/1/2016	5/25/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344016	Finished	090-ACU-3337	5/1/2016	5/27/2016	False	0.25	PM - Air Handling Unit, HV Type
FO-344017	Finished	090-ACU-2322.1	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344018	Finished	090-ACU-2322.2	5/1/2016	5/24/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344019	Created By PM Schedule	049-EXF-009	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344020	Created By PM Schedule	049-EXF-010	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344021	Created By PM Schedule	049-EXF-011	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344022	Finished	046-FAP-001	5/1/2016	5/13/2016	False	0.40	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344023	Finished	048-FAP-001	5/1/2016	5/13/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-344024	Finished	049-FAP-001	5/1/2016	5/13/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344025	Created By PM Schedule	062-SF-001	5/1/2016		False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344026	Finished	156-FAP-001	5/1/2016	5/4/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344027	Finished	499-FAP-001	5/1/2016	5/7/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344028	Finished	620-FAP-001	5/1/2016	5/6/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344029	Finished	036-FP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344030	Finished	025-FP-001	5/1/2016	5/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
Performed fire alarm test. Pressure tested main fire pump and jockey pump. Pulled necessary pull station. Reset main fire panel. Reset O.K at public safety. Filled fire alarm report and given back to Ms. Carol D for further process. 125/135110/50/135							
FO-344031	Finished	007-FP-001	5/1/2016	6/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344032	Finished	001-FP-001	5/1/2016	5/11/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344033	Finished	005-FAP-001	5/1/2016	6/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344034	Finished	040-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344035	Finished	038-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344036	Finished	028-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344037	Finished	026-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344038	Finished	022-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344039	Finished	017-FAP-001	5/1/2016	5/5/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344040	Finished	016-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344041	Finished	003-FAP-001	5/1/2016	5/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344042	Finished	006-FP-001	5/1/2016	5/28/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344043	Finished	050-FAP-001	5/1/2016	5/6/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344044	Finished	043-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344045	Finished	042-FAP-001	5/1/2016	5/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344046	Finished	062-FP-001	5/1/2016	5/11/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344047	Finished	065-FP-001	5/1/2016	5/11/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344048	Finished	068-FAP-001	5/1/2016	5/19/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344049	Finished	067-FP-001	5/1/2016	5/10/2016	False	0.40	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344050	Finished	089-FP-001	5/1/2016	5/28/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344051	Finished	082-FP-001	5/1/2016	5/4/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344052	Finished	080-FAP-001	5/1/2016	5/4/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344053	Finished	090-FP-001	5/1/2016	6/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344054	Finished	155-FP-001	5/1/2016	5/5/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344055	Finished	150-FAP-001	5/1/2016	5/4/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344056	Finished	167-FAP-001	5/1/2016	6/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344057	Finished	166-FP-001	5/1/2016	6/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344058	Finished	140-FAP-001	5/1/2016	5/5/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344059	Finished	130-FP-001	5/1/2016	5/6/2016	False	0.40	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344060	Finished	193-FAP-001	5/1/2016	5/13/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344061	Finished	189-FP-001	5/1/2016	5/10/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-344062	Finished	510-FAP-001	5/1/2016	5/5/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344063	Finished	509-FAP-001	5/1/2016	5/5/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344064	Finished	504-FAP-001	5/1/2016	5/4/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344065	Finished	629-FP-001	5/1/2016	5/17/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344066	Finished	612-FP-001	5/1/2016	5/13/2016	False	3.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344067	Finished	611-FP-001	5/1/2016	5/20/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344068	Finished	609-FP-001	5/1/2016	5/26/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344069	Finished	603-FP-001	5/1/2016	5/24/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344070	Finished	608-FP-001	5/1/2016	5/23/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344077	Finished	612-AHU-006	5/1/2016	5/3/2016	False	5.00	Replace PRE-filters
FO-344081	Finished	612-AHU-004	5/1/2016	5/5/2016	False	5.00	Replace PRE-filters
FO-344082	Finished	629-EXF-011A	5/1/2016	6/29/2016	False	4.00	Replace PRE-filters
FO-344083	Finished	629-AHU-003	5/1/2016	6/21/2016	False	5.00	Replace PRE-filters
FO-344084	Finished	629-AHU-002	5/1/2016	6/22/2016	False	5.00	Replace PRE-filters
FO-344085	Finished	629-AHU-001	5/1/2016	6/28/2016	False	5.00	Replace PRE-filters
FO-344086	Finished	074-FAP-001	5/1/2016	5/11/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344087	Finished	629-EXF-011B	5/1/2016	6/29/2016	False	2.00	Replace PRE-filters
FO-344088	Cancelled	016-FCU-001	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344089	Cancelled	016-FCU-002	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344090	Cancelled	016-FCU-003	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344091	Cancelled	016-FCU-004	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344092	Cancelled	016-FCU-005	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344093	Cancelled	016-FCU-006	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344094	Cancelled	016-HVU-001	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344095	Cancelled	016-HVU-002	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344096	Cancelled	016-HVU-003	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344097	Cancelled	016-HVU-004	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344098	Cancelled	016-HVU-005	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344099	Finished	090-AHU-548	5/1/2016	5/11/2016	False	1.50	Replace PRE-filters
FO-344100	Finished	090-AHU-547	5/1/2016	5/11/2016	False	1.50	Replace PRE-filters
FO-344101	Finished	090-AHU-546	5/1/2016	5/6/2016	False	1.50	Replace PRE-filters
FO-344102	Finished	090-AHU-545	5/1/2016	5/10/2016	False	1.50	Replace PRE-filters
FO-344103	Finished	090-AHU-544	5/1/2016	5/3/2016	False	1.50	Replace PRE-filters
FO-344104	Finished	090-AHU-543	5/1/2016	5/10/2016	False	1.50	Replace PRE-filters
FO-344105	Finished	090-AHU-542	5/1/2016	5/13/2016	False	1.50	Replace PRE-filters
FO-344106	Finished	090-AHU-541	5/1/2016	5/6/2016	False	1.50	Replace PRE-filters
FO-344107	Finished	090-AHU-003	5/1/2016	5/31/2016	False	1.50	Replace PRE-filters
FO-344108	Finished	090-AHU-002	5/1/2016	5/20/2016	False	2.00	Replace PRE-filters
FO-344109	Finished	090-AHU-001	5/1/2016	5/31/2016	False	1.50	Replace PRE-filters
FO-344110	Finished	090-HVU-004	5/1/2016	5/31/2016	False	1.50	Replace PRE-filters
FO-344111	Finished	090-HVU-003	5/1/2016	5/26/2016	False	1.50	Replace PRE-filters
FO-344112	Finished	090-HVU-002	5/1/2016	5/26/2016	False	1.50	Replace PRE-filters
FO-344113	Finished	090-HVU-001	5/1/2016	5/26/2016	False	1.50	Replace PRE-filters
FO-344114	Finished	603-EXF-011	5/1/2016	5/19/2016	False	3.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-344120	Finished	203-AHU-003	5/1/2016	5/19/2016	False	2.50	Replace PRE-filters
FO-344121	Created By PM Schedule	203-AHU-002	5/1/2016		False		Replace PRE-filters
FO-344122	Created By PM Schedule	203-AHU-001	5/1/2016		False		Replace PRE-filters
FO-344123	Finished	203-MAU-001	5/1/2016	5/14/2016	False	1.00	Replace PRE-filters
FO-344124	Created By PM Schedule	195-ACU-002	5/1/2016		False		Replace PRE-filters
FO-344125	Finished	060-ACU-001	5/1/2016	5/13/2016	False	2.00	Replace PRE-filters
FO-344127	Finished	016-EXF-005	5/1/2016	5/12/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344128	Finished	016-EXF-004	5/1/2016	5/11/2016	False	0.75	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-344129	Finished	096-FP-001	5/1/2016	5/11/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344132	Created By PM Schedule	062-AHU-004	5/1/2016		False		Replace PRE-filters
FO-344133	Finished	062-AHU-002	5/1/2016	5/12/2016	False	2.50	Replace PRE-filters
FO-344134	Finished	062-AHU-001	5/1/2016	5/12/2016	False	2.50	Replace PRE-filters
FO-344135	Finished	085-ACU-001	5/1/2016	5/21/2016	False	4.00	PM - Air Handling Unit (ANNUAL) - Filters
FO-344136	Finished	026-AHU-006	5/1/2016	5/20/2016	False	1.50	Replace PRE-filters
FO-344137	Finished	026-AHU-005	5/1/2016	5/17/2016	False	1.50	Replace PRE-filters
FO-344138	Finished	026-AHU-004	5/1/2016	5/18/2016	False	2.00	Replace PRE-filters
FO-344139	Finished	026-AHU-002	5/1/2016	5/19/2016	False	1.50	Replace PRE-filters
FO-344140	Finished	026-AHU-001	5/1/2016	5/19/2016	False	1.50	Replace PRE-filters
FO-344141	Finished	026-AHU-003	5/1/2016	5/18/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-344142	Finished	027-SAF-002	5/1/2016	5/21/2016	False	2.50	Replace PRE-filters
FO-344143	Finished	028-SAF-006	5/1/2016	5/5/2016	False	0.50	Replace PRE-filters
FO-344144	Finished	028-SAF-005	5/1/2016	5/5/2016	False	0.50	Replace PRE-filters
FO-344145	Finished	028-SAF-004	5/1/2016	5/5/2016	False	0.50	Replace PRE-filters
FO-344146	Finished	028-SAF-003	5/1/2016	5/5/2016	False	0.50	Replace PRE-filters
FO-344147	Finished	028-SAF-002	5/1/2016	5/25/2016	False	1.75	Replace PRE-filters
FO-344148	Finished	028-SAF-001	5/1/2016	5/25/2016	False	1.75	Replace PRE-filters
FO-344149	Finished	016-AHU-005	5/1/2016	5/12/2016	False	2.00	Replace PRE-filters
FO-344150	Finished	016-AHU-004	5/1/2016	5/11/2016	False	3.50	Replace PRE-filters
FO-344151	Finished	016-AHU-002	5/1/2016	5/12/2016	False	2.50	PM - Air Handling Unit (ANNUAL)
FO-344152	Finished	016-AHU-001	5/1/2016	5/4/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-344153	Created By PM Schedule	022-AHU-001	5/1/2016		False		PM - Air Handling Unit (ANNUAL)
FO-344157	Finished	022-HVU-001	5/1/2016	5/13/2016	False	1.00	Replace PRE-filters
FO-344158	Finished	022-HVU-002	5/1/2016	5/13/2016	False	1.00	Replace PRE-filters
FO-344159	Finished	022-SAF-001	5/1/2016	5/13/2016	False	8.00	PM - Air Handling Unit (ANNUAL)
FO-344160	Finished	027-SAF-001	5/1/2016	5/20/2016	False	4.50	PM - Air Handling Unit (ANNUAL)
FO-344161	Finished	036-RTU-001	5/1/2016	5/17/2016	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-344162	Finished	036-SAF-001	5/1/2016	5/14/2016	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-344163	Finished	036-AHU-002	5/1/2016	5/14/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-344164	Finished	036-AHU-003	5/1/2016	5/14/2016	False	1.00	Replace PRE-filters
FO-344165	Finished	082-AHU-002	5/1/2016	5/28/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-344166	Finished	082-AHU-001	5/1/2016	5/24/2016	False	5.00	PM - Air Handling Unit (ANNUAL)
FO-344167	Cancelled	016-HVU-006	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344168	Cancelled	016-HVU-007	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-344169	Cancelled	016-HVU-008	5/1/2016		True		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-344170	Finished	169-FAP-001	5/1/2016	6/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-344172	Finished	060-ACU-036	5/1/2016	5/13/2016	False	1.00	Replace PRE-filters
FO-344173	Finished	090-ACU-0346A	5/1/2016	6/1/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-344174	Finished	090-ACU-0346B	5/1/2016	6/1/2016	False	0.50	PM - Air Handling Unit, HV Type
FO-347123	Created	637-FP-001	5/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
E - South			64	57	7	0	89%
FO-345234	Finished	090-COT-001	5/1/2016	5/11/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345235	Finished	089-WSS-001	5/1/2016	5/12/2016	False	1.00	PM - Water Softener
FO-345236	Finished	089-CHWP-002S	5/1/2016	5/11/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345237	Finished	089-CWP-001	5/1/2016	5/24/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345238	Finished	089-CWP-001S	5/1/2016	5/24/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345239	Finished	089-AIR-001	5/1/2016	5/11/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-345240	Finished	089-COT-002	5/1/2016	5/17/2016	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345243	Finished	016-AIR-002	5/1/2016	5/25/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit, checked motor and compressor sheaves for alignment. Changed compressor oil, removed and cleaned air filter. Checked pressure switch operation, drained moisture from the tank. Checked operation or air dryer and it's moisture and oil separator. Cleaned it's coil.							
FO-345246	Finished	089-CHWP-002	5/1/2016	5/10/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345251	Finished	022-COT-001	5/1/2016	5/6/2016	False	8.00	PM - Cooling Tower, 500 - 1000 Tons
Cleaned tower basin and nozzles, cleaned tower strainers, lubricated tower fan motor bearings, tower fan gear box has synthetic oil that has been changed last year and is good for 5 years. recorded tower make up water meter before filling up the tower. Filled up the tower and checked for any water leaks. put the tower in operation and checked it for proper operation.							
FO-345252	Finished	096-COT-001	5/1/2016	5/11/2016	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345253	Finished	089-HRP-011	5/1/2016	5/25/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345254	Finished	089-HRP-013	5/1/2016	5/25/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345255	Finished	089-HRP-010	5/1/2016	5/25/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345256	Finished	089-HRP-012	5/1/2016	5/17/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345281	Finished	089-AIR-002	5/1/2016	5/10/2016	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-345282	Finished	089-VP-001**	5/1/2016	5/3/2016	False	1.00	PM - Vacuum Pump
FO-345283	Finished	089-VP-002**	5/1/2016	5/3/2016	False	1.00	PM - Vacuum Pump
FO-345284	Finished	005-CWP-001	5/1/2016	5/5/2016	False		PM - Centrifugal Pump, over 1 H.P.
PM completed as part of Chemistry FO.							
FO-345285	Finished	005-CWP-002	5/1/2016	5/5/2016	False		PM - Centrifugal Pump, over 1 H.P.
PM completed as part of Chemistry FO.							
FO-345286	Finished	006-CHWP-006	5/1/2016	5/18/2016	False		PM - Centrifugal Pump, over 1 H.P.
Equipment no longer in service.							
FO-345287	Finished	006-CWP-004	5/1/2016	5/18/2016	False		PM - Centrifugal Pump, over 1 H.P.
Equipment no longer in service.							
FO-345288	Finished	006-CWP-005	5/1/2016	5/18/2016	False		PM - Centrifugal Pump, over 1 H.P.
Equipment no longer in service.							
FO-345289	Finished	006-CHWP-007	5/1/2016	5/18/2016	False		PM - Centrifugal Pump, over 1 H.P.
Equipment no longer in service.							
FO-345362	Finished	005-SUP-002	5/1/2016	5/24/2016	False	0.20	PM - Centrifugal Pump, over 1 H.P.
FO-345363	Finished	005-SUP-003	5/1/2016	5/24/2016	False	0.20	PM - Centrifugal Pump, over 1 H.P.

Requested Finished Open WND

% Finished

FO-345364	Finished	005-SUP-004	5/1/2016	5/23/2016	False	0.20	PM - Centrifugal Pump, over 1 H.P.
FO-345365	Finished	005-SUP-005	5/1/2016	5/24/2016	False	0.20	PM - Centrifugal Pump, over 1 H.P.
FO-345366	Finished	005-CHWP-001	5/1/2016	5/5/2016	False		PM - Centrifugal Pump, over 1 H.P.
PM completed as part of Chemistry FO.							
FO-345367	Finished	005-CHWP-003	5/1/2016	5/5/2016	False		PM - Centrifugal Pump, over 1 H.P.
PM completed as part of Chemistry FO.							
FO-345368	Finished	005-CHWP-004	5/1/2016	5/5/2016	False		PM - Centrifugal Pump, over 1 H.P.
PM completed as part of Chemistry FO.							
FO-345451	Finished	016-AIR-003	5/1/2016	5/2/2016	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
Checked operation of the unit and it's pressure switch, checked the belt and checked for any excess vibration. drained and changed oil, removed and cleaned air filter. drained moisture from air tank, Checked it's belt and checked for any excess vibration.. Checked operation of air dryer and it's oil and moisture separator, checked the automatic blow down, cleaned condenser coil. cleaned the unit.							
FO-345452	Created By PM Schedule	016-COT-001	5/1/2016		False		PM - Cooling Tower, 500 - 1000 Tons
FO-345462	Finished	007-COT-001	5/1/2016	5/2/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345481	Finished	089-COT-001	5/1/2016	5/17/2016	False	2.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345506	Finished	007-CHWP-001	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345507	Finished	007-CHWP-002	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345508	Finished	007-CHWP-003	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345509	Finished	007-CWP-001	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345510	Finished	007-CWP-002	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345511	Finished	007-CWP-003	5/1/2016	5/5/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345517	Finished	090-COT-002	5/1/2016	5/25/2016	False	4.00	PM - Cooling Tower, 500 - 1000 Tons
FO-345518	Finished	090-GP-541	5/1/2016	5/13/2016	False	0.50	PM - Water Booster Pump
FO-345519	Finished	090-GP-542	5/1/2016	5/13/2016	False	0.50	PM - Water Booster Pump
FO-345520	Finished	090-ERP-542	5/1/2016	5/16/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
FO-345555	Created By PM Schedule	022-ACU-001	5/1/2016		False		PM - York Chillers: Startup Services for Absorber Chillers
FO-345559	Created By PM Schedule	090-ACU-403	5/1/2016		False	0.00	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345560	Created By PM Schedule	090-ACU-402	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345561	Created By PM Schedule	090-ACU-401	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345562	Created By PM Schedule	022-ACU-001	5/1/2016		False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345563	Finished	007-ACU-002	5/1/2016	7/27/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Finished after consultation with M. Bobick.							
FO-345564	Finished	007-ACU-001	5/1/2016	7/27/2016	False		PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
Closed after consultation with M. Bobick.							
FO-345572	Finished	096-ACU-001	5/1/2016	5/17/2016	False	1.00	PM - McQuay Chillers: Seasonal Start Up for Centrifugal & Screw (Air cooled) Chillers
FO-345578	Finished	007-MAU-001	5/1/2016	5/2/2016	False	2.00	Replace PRE-filters
FO-345926	Finished	007-GEN-001	5/12/2016	5/12/2016	False	0.50	Generator Maintenance, Monthly
FO-345928	Finished	007-GEN-002	5/12/2016	5/12/2016	False	0.50	Generator Maintenance, Monthly
FO-345930	Finished	090-GEN-001	5/17/2016	5/17/2016	False	1.00	Generator Maintenance, Monthly
FO-345932	Finished	089-GEN-001	5/18/2016	5/20/2016	False	1.00	Generator Maintenance, Monthly
FO-345962	Finished	090-GEN-002	5/12/2016	5/12/2016	False	1.00	Generator Maintenance, Monthly
FO-345971	Finished	006-GEN-001	5/19/2016	5/20/2016	False	1.50	Generator Maintenance, Monthly
FO-345989	Finished	005-GEN-001	5/4/2016	5/5/2016	False	0.50	Generator Maintenance, Monthly
FO-345991	Finished	090-GEN-003	5/12/2016	5/12/2016	False	1.00	Generator Maintenance, Monthly

Requested Finished Open WND

% Finished

FO-346083	Finished	090-ACU-CR2	5/8/2016	5/11/2016	False	0.10	Monthly AHU Inspection Clean Room Unit 2
FO-346084	Cancelled	090-ACU-CR1	5/8/2016		False		PM - Monthly AHU Inspection Clean Room Unit 1
Cancelled by CLD - Reference FO-348700							

E - Southeast **191** **25** **112** **54** **13%**

FO-345241	Finished	016-CHWP-001	5/1/2016	5/2/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	--------------	----------	----------	-------	------	------------------------------------

Checked motor and pump for proper alignment, greased pump and motor bearings, we do not use these pumps any more since chemistry bldg. installed variable drive pumps but I keep doing the PM in case we have to reuse them again. cleaned the equipment.

FO-345242	Finished	016-CHWP-001S	5/1/2016	5/2/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	---------------	----------	----------	-------	------	------------------------------------

Checked motor and pump for proper alignment, greased pump and motor bearings, we do not use these pumps any more since chemistry bldg. installed variable drive pumps but I keep doing the PM in case we have to reuse them again. cleaned the equipment.

FO-345244	Finished	016-HEX-001	5/1/2016	5/26/2016	False	1.00	PM - Heat Exchanger and Economizer
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

Checked operation of the unit. Checked for any steam or water leaks. Checked operation of control valve, checked temperature gauges for proper reading. Checked for coil leak. Cleaned the unit.

FO-345245	Finished	016-HEX-002	5/1/2016	5/26/2016	False	1.00	PM - Heat Exchanger and Economizer
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

Checked operation of the unit. Checked for any steam or water leaks. Checked operation of control valve, checked temperature gauges for proper reading. Checked for coil leak. Cleaned the unit.

FO-345247	Finished	022-CHWP-003	5/1/2016	5/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	--------------	----------	-----------	-------	------	------------------------------------

Checked pump coupling, removed and cleaned pump strainer at the end of the season when system was empty lubricated motor and pump bearings, checked operation of the pump. cleaned the unit.

FO-345248	Finished	022-CHWP-004	5/1/2016	5/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	--------------	----------	-----------	-------	------	------------------------------------

Checked pump coupling, removed and cleaned pump strainer at the end of the season when system was empty lubricated motor and pump bearings, checked operation of the pump. cleaned the unit.

FO-345249	Finished	022-CWP-001	5/1/2016	5/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

Checked pump coupling, removed and cleaned pump strainer at the end of the season when system was empty lubricated motor and pump bearings, checked operation of the pump. cleaned the unit.

FO-345250	Finished	022-CWP-002	5/1/2016	5/19/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

Checked pump coupling, removed and cleaned pump strainer at the end of the season when system was empty lubricated motor and pump bearings, checked operation of the pump. the pump runs very loud, we had problem with this pump for last 2 years and it got worse, informed Associate director.. cleaned the unit.

FO-345257	Created By PM Schedule	001-COT-001	5/1/2016		False	0.00	PM - Cooling Tower, 500 - 1000 Tons
-----------	------------------------	-------------	----------	--	-------	------	-------------------------------------

FO-345258	Finished	001-HWP-001	5/1/2016	6/29/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

CHECK OPERATION, LUBE PUMP & MTR, CLEAN AREA.

FO-345259	Finished	001-HWP-002	5/1/2016	6/29/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

CHECK OPERATION, LUBE PUMP & MTR, CLEAN AREA.

FO-345260	Finished	001-HWP-003	5/1/2016	6/29/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	-------------	----------	-----------	-------	------	------------------------------------

CHECK OPERATION, LUBE PUMP & MTR, CLEAN AREA.

FO-345261	Finished	001-HWP-017A	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	--------------	----------	-----------	-------	------	------------------------------------

CHECK OPERATION, LUBE PUMP & MTR, CLEAN AREA.

FO-345262	Finished	001-HWP-017B	5/1/2016	6/27/2016	False	0.50	PM - Centrifugal Pump, over 1 H.P.
-----------	----------	--------------	----------	-----------	-------	------	------------------------------------

CHECK OPERATION, LUBE PUMP & MTR, CLEAN AREA.

FO-345276	Finished	001-CFP-002	5/1/2016	5/31/2016	False	0.25	PM - Chemical Feed/Metering Pump/Controller
-----------	----------	-------------	----------	-----------	-------	------	---

CHECK OPERATION, CLEAN AREA.

FO-345277	Finished	001-CFP-003	5/1/2016	5/31/2016	False	0.25	PM - Chemical Feed/Metering Pump/Controller
-----------	----------	-------------	----------	-----------	-------	------	---

CHECK OPERATION, CLEAN AREA.

Requested Finished Open WND

% Finished

FO-345278	Finished	001-CFP-004	5/1/2016	5/31/2016	False	0.25	PM - Chemical Feed/Metering Pump/Controller
CHECK OPERATION, CLEAN AREA.							
FO-345279	Finished	001-CFP-005	5/1/2016	5/31/2016	False	0.25	PM - Chemical Feed/Metering Pump/Controller
CHECK OPERATION, CLEAN AREA.							
FO-345290	Completed	01-FCU-001ANT	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345291	Completed	01-FCU-001CAS	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345292	Completed	01-FCU-001COI	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345293	Completed	01-FCU-001HCF	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345294	Completed	01-FCU-001LOB	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345295	Completed	01-FCU-001LOO	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345296	Completed	01-FCU-001WAF	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345297	Completed	01-FCU-002ANT	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345298	Completed	01-FCU-002CAS	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345299	Completed	01-FCU-002COI	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345300	Completed	01-FCU-002LOB	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345301	Completed	01-FCU-002LOO	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345302	Completed	01-FCU-002WAF	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345303	Completed	01-FCU-003ANT	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345304	Completed	001-FCU-3101	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345305	Completed	001-FCU-3102	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345306	Completed	001-FCU-3103-1	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345307	Completed	001-FCU-3103-2	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345308	Completed	001-FCU-3103-3	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345309	Completed	001-FCU-3103-4	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345310	Completed	001-FCU-3103-5	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345311	Completed	001-FCU-3103-6	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345312	Completed	001-FCU-3103-7	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345313	Completed	001-FCU-3103-8	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345314	Completed	001-FCU-3106-1	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345315	Completed	001-FCU-3106-2	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345316	Completed	001-FCU-3106-3	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345317	Completed	001-FCU-3106-4	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345318	Completed	001-FCU-3106-5	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345319	Completed	001-FCU-3106-6	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345320	Completed	001-FCU-3106-7	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345321	Completed	001-FCU-3106-8	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345322	Completed	001-FCU-3107-1	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345323	Completed	001-FCU-3107-2	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345324	Completed	001-FCU-3107-3	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345325	Completed	001-FCU-3107-4	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345326	Completed	001-FCU-3107-5	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345327	Completed	001-FCU-3108.2	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345328	Completed	001-FCU-3108.3	5/1/2016		True		PM - Fan Coil/HV/AC Unit
FO-345329	Completed	001-FCU-3114-1	5/1/2016		True		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-345330	Completed	001-FCU-3114-2	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345331	Completed	001-FCU-3114-3	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345332	Completed	001-FCU-3114-4	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345333	Completed	001-FCU-3117-1	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345334	Completed	001-FCU-3117-1	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345335	Completed	001-FCU-3117-2	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345336	Completed	001-FCU-3117-3	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345337	Completed	001-FCU-3117-4	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345338	Completed	001-FCU-3117-5	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345339	Completed	001-FCU-3117-6	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345340	Completed	001-FCU-3117-7	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345341	Completed	001-FCU-3117-8	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345342	Completed	001-FCU-3117-9	5/1/2016	True	PM - Fan Coil/HV/AC Unit
FO-345361	Created By PM Schedule	167-HEX-001	5/1/2016	False	PM - Heat Exchanger and Economizer
FO-345369	Created By PM Schedule	071-DWBP-001	5/1/2016	False	PM - Centrifugal Pump, over 1 H.P.
FO-345370	Created By PM Schedule	071-DWBP-002	5/1/2016	False	PM - Centrifugal Pump, over 1 H.P.
FO-345371	Created By PM Schedule	071-DWBP-003	5/1/2016	False	PM - Centrifugal Pump, over 1 H.P.
FO-345372	Created By PM Schedule	071-CWP-001	5/1/2016	False	PM - Centrifugal Pump, over 1 H.P.
FO-345373	Created By PM Schedule	071-CWP-002	5/1/2016	False	PM - Centrifugal Pump, over 1 H.P.
FO-345374	Created By PM Schedule	071-COT-001	5/1/2016	False	PM - Cooling Tower, 500 - 1000 Tons
FO-345375	Created By PM Schedule	071-HWP-027	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345376	Created By PM Schedule	071-HWP-028	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345377	Created By PM Schedule	071-HWP-029	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345378	Created By PM Schedule	071-HWP-030	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345379	Created By PM Schedule	071-HWP-031	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345380	Created By PM Schedule	071-HWP-032	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345381	Created By PM Schedule	071-HWP-033	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345382	Created By PM Schedule	071-HWP-034	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345383	Created By PM Schedule	071-HWP-035	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345384	Created By PM Schedule	071-HWP-036	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345385	Created By PM Schedule	071-HWP-037	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345386	Created By PM Schedule	071-HWP-038	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345387	Created By PM Schedule	071-HWP-039	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345388	Created By PM Schedule	071-HWP-040	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345389	Created By PM Schedule	071-HWP-041	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345390	Created By PM Schedule	071-HWP-042	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345391	Created By PM Schedule	071-HWP-043	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345392	Created By PM Schedule	071-HWP-044	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345393	Created By PM Schedule	071-HWP-045	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345394	Created By PM Schedule	071-HWP-046	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345395	Created By PM Schedule	071-HWP-047	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345396	Created By PM Schedule	071-HWP-048	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345397	Created By PM Schedule	071-HWP-049	5/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-345398	Created By PM Schedule	071-HWP-050	5/1/2016	False	PM - Heat Pumps (5057 Woodward)

[illegible]

Requested Finished Open WND

% Finished

FO-345443	Created By PM Schedule	071-HWP-095	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345444	Created By PM Schedule	071-HWP-096	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345445	Created By PM Schedule	071-HWP-097	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345446	Created By PM Schedule	071-HWP-098	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345447	Created By PM Schedule	071-HWP-206	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345448	Created By PM Schedule	071-HWP-207	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345449	Created By PM Schedule	071-HWP-208	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345450	Created By PM Schedule	071-HWP-209	5/1/2016		False	PM - Heat Pumps (5057 Woodward)
FO-345453	Created By PM Schedule	499-COT-001	5/1/2016		False	PM - Cooling Tower, 500 - 1000 Tons
FO-345454	Created By PM Schedule	189-CHWP-001	5/1/2016		False	PM - Centrifugal Pump, over 1 H.P.
FO-345455	Created By PM Schedule	499-HEX-006	5/1/2016		False	PM - Heat Exchanger and Economizer
FO-345464	Created By PM Schedule	504-COT-001	5/1/2016		False	PM - Cooling Tower, 500 - 1000 Tons
FO-345465	Completed	001-FCU-2155	5/1/2016		True	PM - Fan Coil/HV/AC Unit
FO-345466	Created By PM Schedule	001-FMB-0014	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345467	Created By PM Schedule	001-FMB-0029	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345468	Created By PM Schedule	001-FMB-0030	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345469	Created By PM Schedule	001-FMB-0402-2	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345470	Created By PM Schedule	001-FMB-0402-1	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345471	Created By PM Schedule	001-FMB-0428	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345472	Created By PM Schedule	001-FMB-0429	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345473	Created By PM Schedule	001-FMB-1410	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345474	Created By PM Schedule	001-FMB-1412	5/1/2016		False	PM - Fan Motor Box (Old Main)
FO-345524	Finished	637-COT-001	5/1/2016	6/23/2016	False	PM - Cooling Tower, 500 - 1000 Tons
FO-345525	Finished	068-COT-001	5/1/2016	5/1/2016	False	PM - Cooling Tower, 500 - 1000 Tons
cleaned tower						
FO-345556	Created By PM Schedule	001-ACU-001	5/1/2016		False	PM - York Chillers: Startup Services for Absorber Chillers
FO-345565	Created By PM Schedule	001-ACU-003	5/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345566	Created By PM Schedule	001-ACU-002	5/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345567	Created By PM Schedule	001-ACU-001	5/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345569	Created By PM Schedule	189-ACU-003	5/1/2016		False	PM - York Chillers: Operational Inspections for Centrifugal/Screw/Scroll/& Absorber Chillers
FO-345570	Finished	609-ACU-002	5/1/2016	6/8/2016	False	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers
cleaned tower						
FO-345571	Finished	609-ACU-001	5/1/2016	6/23/2016	False	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers
FO-345950	Finished	637-GEN-001	5/17/2016	6/23/2016	False	Generator Maintenance, Monthly
FO-345952	Finished	637-GEN-002	5/17/2016	6/23/2016	False	Generator Maintenance, Monthly
FO-346465	Created By PM Schedule	028-ACU-001	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346466	Created By PM Schedule	028-ACU-002	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346467	Created By PM Schedule	028-ACU-003	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346468	Created By PM Schedule	028-ACU-004	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346469	Created By PM Schedule	028-ACU-005	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346470	Created By PM Schedule	028-ACU-006	5/15/2016		False	PM - Water/Air Cooled Condenser
FO-346471	Finished	001-AHU-001	5/15/2016	5/4/2016	False 0.50	PM - Steam to Air Handling Unit - Close for Spring (Old Main)
ISOLATE STEAM TO PREHEAT COILS						

Requested Finished Open WND

% Finished

FO-346472 Finished 001-AHU-002 5/15/2016 5/4/2016 False 0.50 PM - Steam to Air Handling Unit - Close for Spring (Old Main)
ISOLATE STEAM TO PREHEAT COILS

FO-346473 Created By PM Schedule 499-CFP-001 5/15/2016 False PM - Chemical Feed/Metering Pump/Controller

FO-346474 Created By PM Schedule 499-CFP-002 5/15/2016 False PM - Chemical Feed/Metering Pump/Controller

FO-346475 Created By PM Schedule 499-CFP-003 5/15/2016 False PM - Chemical Feed/Metering Pump/Controller

FO-346476 Created By PM Schedule 499-CFP-004 5/15/2016 False PM - Chemical Feed/Metering Pump/Controller

E - West 42 41 1 0 98%

FO-345263 Finished 155-CHWP-001 5/1/2016 5/24/2016 False 0.75 PM - Centrifugal Pump, over 1 H.P.
PM'd equipment

FO-345264 Finished 155-CHWP-002 5/1/2016 5/20/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345265 Finished 155-CHWP-003 5/1/2016 5/19/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345266 Finished 55-CHWP-1(601 5/1/2016 5/19/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345267 Completed 55-CHWP-2(601 5/1/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345268 Finished 55-CHWP-3(601 5/1/2016 5/18/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345269 Finished 55-CHWP-4(601 5/1/2016 5/18/2016 False 0.65 PM - Centrifugal Pump, over 1 H.P.
PM'D EQUIPMENT

FO-345270 Finished 155-CWP-001 5/1/2016 6/30/2016 False PM - Centrifugal Pump, over 1 H.P.

FO-345271 Finished 155-CWP-002 5/1/2016 6/30/2016 False PM - Centrifugal Pump, over 1 H.P.

FO-345272 Finished 155-CWP-003 5/1/2016 6/30/2016 False PM - Centrifugal Pump, over 1 H.P.

FO-345273 Finished 155-DWBP-001 5/1/2016 6/30/2016 False PM - Centrifugal Pump, over 1 H.P.

FO-345274 Finished 155-DWBP-002 5/1/2016 6/30/2016 False PM - Centrifugal Pump, over 1 H.P.

FO-345275 Finished 155-COT-001 5/1/2016 5/31/2016 False PM - Cooling Tower, 500 - 1000 Tons

FO-345280 Finished 155-CFP-001 5/2/2016 5/13/2016 False PM - Chemical Feed/Metering Pump/Controller

FO-345343 Finished 003-CHWP-003 5/1/2016 4/27/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
comp

FO-345344 Finished 003-CHWP-004 5/1/2016 4/27/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
completed

FO-345345 Finished 003-CHWP-005 5/1/2016 5/4/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
done

FO-345346 Finished 003-CHWP-006 5/1/2016 5/4/2016 False 2.00 PM - Centrifugal Pump, over 1 H.P.
done

FO-345347 Finished 003-CHWP-007 5/1/2016 1/12/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
done

FO-345348 Finished 003-CHWP-008 5/1/2016 5/12/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
done

FO-345349 Finished 003-CHWP-009 5/1/2016 5/12/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
done

FO-345350 Finished 003-CHWP-010 5/1/2016 5/12/2016 False 1.00 PM - Centrifugal Pump, over 1 H.P.
done

Requested Finished Open WND

% Finished

FO-345351	Finished completed	003-CHWP-011	5/1/2016	6/28/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345352	Finished done	003-CHWP-L01	5/1/2016	5/12/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345353	Finished completed	003-TMP-002	5/1/2016	5/12/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345354	Finished	003-CWP-003	5/1/2016	5/27/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345355	Finished done	003-CWP-004	5/1/2016	5/27/2016	False	1.00	PM - Centrifugal Pump, over 1 H.P.
FO-345356	Finished	003-COT-001	5/1/2016	5/31/2016	False		PM - Cooling Tower, 500 - 1000 Tons
FO-345357	Finished	003-WSS-001	5/1/2016	5/31/2016	False		PM - Water Softener
FO-345358	Finished completed	003-HEX-001	5/1/2016	5/27/2016	False	1.50	PM - Heat Exchanger and Economizer
FO-345359	Finished	167-AHU-001	5/1/2016	6/10/2016	False		PM - Water/Air Cooled Condenser
FO-345360	Finished	167-AHU-002	5/1/2016	6/10/2016	False		PM - Water/Air Cooled Condenser
FO-345475	Finished	080-PP-001	5/1/2016	6/3/2016	False		PM - Centrifugal Pump, over 1 H.P.
FO-345476	Finished	080-PP-002	5/1/2016	6/3/2016	False		PM - Centrifugal Pump, over 1 H.P.
FO-345478	Finished	080-COT-001	5/1/2016	5/31/2016	False		PM - Cooling Tower, 500 - 1000 Tons
FO-345479	Finished	166-HEX-001	5/1/2016	6/3/2016	False		PM - Heat Exchanger and Economizer
FO-345480	Finished	166-HEX-002	5/1/2016	6/10/2016	False		PM - Heat Exchanger and Economizer
FO-345483	Finished	156-CWP-001	5/1/2016	6/3/2016	False		PM - Centrifugal Pump, over 1 H.P.
FO-345979	Finished	169-GEN-001	5/26/2016	5/27/2016	False		Generator Maintenance, Monthly
FO-345987	Finished	003-GEN-001	5/4/2016	5/4/2016	False		Generator Maintenance, Monthly
FO-346082	Finished	155-CFP-002	5/9/2016	5/20/2016	False		PM - Chemical Feed/Metering Pump/Controller
FO-346464	Finished	155-CFP-003	5/16/2016	5/27/2016	False		PM - Chemical Feed/Metering Pump/Controller

Trades			119	104	15	0		87%
T - Electrician			77	65	12	0		84%
FO-345484	Finished	612-GEN-001	5/10/2016	5/10/2016	False	2.00	Generator Test	
FAULT ALARM FLASHING								
FO-345485	Finished	612-GEN-002	5/10/2016	5/10/2016	False	2.00	Generator Test	
FO-345486	Finished	501-GEN-001	5/10/2016	5/10/2016	False	4.00	Generator Test	
FO-345521	Finished	048-GEN-001	5/10/2016	5/10/2016	False	4.00	Generator Test	
FO-345522	Finished	001 SPARE from	5/10/2016	5/10/2016	False	4.00	Generator Test	
FO-345580	Finished	603-GEN-001	5/3/2016	6/1/2016	False		Generator Test Tuesday 5/3/2016 @ 7:15 AM.	
NO INFO WAS RECORDED								
FO-345581	Created By PM Schedule	051-SP-001	5/2/2016		False		PM - Sump Pump	
FO-345582	Created By PM Schedule	051-SP-002	5/2/2016		False		PM - Sump Pump	
FO-345583	Created By PM Schedule	051-SP-003	5/2/2016		False		PM - Sump Pump	
FO-345584	Created By PM Schedule	051-SP-004	5/2/2016		False		PM - Sump Pump	
FO-345585	Created By PM Schedule	051-SP-005	5/2/2016		False		PM - Sump Pump	
FO-345586	Created By PM Schedule	051-SP-006	5/2/2016		False		PM - Sump Pump	
FO-345925	Finished	609-GEN-001	5/17/2016	5/17/2016	False	4.00	Generator Test	
FO-345927	Finished	007-GEN-001	5/12/2016	5/12/2016	False	2.00	Generator Test	

Requested Finished Open WND

% Finished

FO-345929	Finished	007-GEN-002	5/12/2016	5/12/2016	False	2.00	Generator Test
FO-345931	Finished	090-GEN-001	5/17/2016	5/17/2016	False	4.00	Generator Test
FO-345933	Finished	089-GEN-001	5/18/2016	5/18/2016	False	4.00	Generator Test
FO-345935	Finished	066-GEN-001	5/25/2016	5/25/2016	False	4.00	Generator Test
FO-345936	Finished	611-GEN-001	5/24/2016	5/24/2016	False	4.00	Generator Test
FO-345938	Finished	193-GEN-001	5/6/2016	5/6/2016	False		Generator Test Friday 5/6/2016 @ 2:15 PM.
FO-345939	Finished	104-GEN-001	5/24/2016	5/24/2016	False	4.00	Generator Test
FO-345941	Finished	127-GEN-001	5/24/2016	5/24/2016	False	1.00	Generator Test
FO-345943	Finished	127-GEN-002	5/24/2016	5/24/2016	False	1.00	Generator Test
FO-345945	Finished	127-GEN-003	5/24/2016	5/24/2016	False	1.00	Generator Test
FO-345947	Finished	127-GEN-004	5/24/2016	5/24/2016	False	1.00	Generator Test
FO-345949	Finished	637-GEN-001	5/17/2016	5/17/2016	False	2.00	Generator Test
FO-345951	Finished	637-GEN-002	5/17/2016	5/17/2016	False	2.00	Generator Test
FO-345953	Finished	130-GEN-001	5/25/2016	5/25/2016	False	4.00	Generator Test
FO-345955	Finished	507-GEN-001	5/11/2016	5/11/2016	False	4.00	Generator Test
FO-345957	Finished	203-GEN-001	5/17/2016	5/17/2016	False	4.00	Generator Test
FO-345959	Finished	536-GEN-001	5/18/2016	5/18/2016	False	4.00	Generator Test
FO-345960	Finished	608-GEN-001	5/3/2016	5/3/2016	False	4.00	Generator Test Tuesday 5/3/2016 @ 7:15 AM.
FO-345961	Finished	090-GEN-002	5/12/2016	5/12/2016	False	2.00	Generator Test
FO-345964	Finished	527-GEN-001	5/19/2016	5/19/2016	False	4.00	Generator Test
FO-345968	Finished	GEN-001 (Towa	5/11/2016	5/12/2016	False	4.00	Generator Test
FO-345970	Finished	006-GEN-001	5/19/2016	5/19/2016	False	4.00	Generator Test
FO-345972	Finished	193-GEN-002	5/6/2016	5/6/2016	False	1.00	Generator Test Friday 5/6/2016 @ 2:15 PM.
FO-345974	Finished	193-GEN-003	5/6/2016	5/6/2016	False	1.00	Generator Test Friday 5/6/2016 @ 2:15 PM.
FO-345976	Finished	193-GEN-004	5/6/2016	5/6/2016	False	1.00	Generator Test Friday 5/6/2015 @ 2:15 PM.
FO-345978	Finished	169-GEN-001	5/26/2016	5/26/2016	False	4.00	Generator Test
FO-345980	Finished	060-GEN-001A	5/26/2016	5/26/2016	False	2.00	Generator Test
FO-345982	Finished	060-GEN-001B	5/26/2016	5/26/2016	False	2.00	Generator Test
FO-345984	Finished	034-GEN-001	5/5/2016	5/5/2016	False	4.00	Generator Test Thursday 5/5/2016 @ 7:30 AM.
ATS #4 doesn't transfer							
FO-345986	Finished	003-GEN-001	5/4/2016	5/4/2016	False	2.00	Generator Test Wednesday 5/4/2016 @ 7:30 AM.
FO-345988	Finished	005-GEN-001	5/4/2016	5/4/2016	False	4.00	Generator Test Wednesday 5/4/2016 @ 7:30 AM.
FO-345990	Finished	090-GEN-003	5/12/2016	5/12/2016	False	2.00	Generator Test
FO-345992	Finished	209-GEN-002	5/5/2016	5/5/2016	False	1.00	Generator Test Thursday 5/5/2016 @ 7:30 AM.
FO-345993	Finished	209-GEN-001	5/5/2016	5/5/2016	False	1.00	Generator Test Thursday 5/5/2016 @ 7:30 AM.
FO-345995	Parts on Order	209-GEN-003	5/5/2016	5/5/2016	False	1.00	Generator Test Thursday 5/5/2016 @ 7:30 AM.
OUT OF SERVICE							
FO-345997	Finished	209-GEN-004	5/5/2016	5/5/2016	False	1.00	Generator Test Thursday 5/5/2016 @ 7:30 AM.
FO-345999	Finished	211-GEN-001	5/6/2016	5/6/2016	False	2.00	Generator Test Friday 5/6/2016 @ 7:15 AM.
FO-346000	Finished	211-GEN-002	5/6/2016	5/6/2016	False	2.00	Generator Test Friday 5/6/2016 @ 7:15 AM.
FO-346004	Finished	629-GEN-001	5/24/2016	5/24/2016	False	4.00	Generator Test
WARNING - 2265/FUEL LIFT PUMP SENSOR HIGH							
FO-346086	Created By PM Schedule	051-SP-001	5/9/2016		False		PM - Sump Pump
FO-346087	Created By PM Schedule	051-SP-002	5/9/2016		False		PM - Sump Pump

Requested Finished Open WND

% Finished

FO-346088	Created By PM Schedule	051-SP-003	5/9/2016		False		PM - Sump Pump
FO-346089	Created By PM Schedule	051-SP-004	5/9/2016		False		PM - Sump Pump
FO-346090	Created By PM Schedule	051-SP-005	5/9/2016		False		PM - Sump Pump
FO-346091	Created By PM Schedule	051-SP-006	5/9/2016		False		PM - Sump Pump
FO-346478	Finished	051-SP-001	5/16/2016	6/1/2016	False	0.25	PM - Sump Pump
FO-346479	Finished	051-SP-002	5/16/2016	6/2/2016	False	0.25	PM - Sump Pump
FO-346480	Finished	051-SP-003	5/16/2016	6/2/2016	False	0.25	PM - Sump Pump
FO-346481	Finished	051-SP-004	5/16/2016	6/2/2016	False	0.25	PM - Sump Pump
FO-346482	Finished	051-SP-005	5/16/2016	6/1/2016	False	0.25	PM - Sump Pump
FO-346483	Finished	051-SP-006	5/16/2016	6/1/2016	False	0.25	PM - Sump Pump
FO-347086	Finished	051-SP-001	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347087	Finished	051-SP-002	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347088	Finished	051-SP-003	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347089	Finished	051-SP-004	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347090	Finished	051-SP-005	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347091	Finished	051-SP-006	5/23/2016	5/26/2016	False	0.75	PM - Sump Pump
FO-347460	Finished	051-SP-001	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
FO-347461	Finished	051-SP-002	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
FO-347462	Finished	051-SP-003	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
FO-347463	Finished	051-SP-004	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
FO-347464	Finished	051-SP-005	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
FO-347465	Finished	051-SP-006	5/30/2016	6/3/2016	False	0.25	PM - Sump Pump
T - Plumber			42	39	3	0	93%
FO-332404	Finished	080-RPZ-001	5/1/2016	5/25/2016	False	1.50	2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,
FO-333084	Finished	079-RPZ-001	5/1/2016	5/25/2016	False	1.50	2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,
FO-333085	Finished	079-RPZ-002	5/1/2016	12/24/2015	False	2.50	2015/2016 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,
FO-333087	Finished	078-PVB-001	5/1/2016	5/25/2016	False	1.50	2015/2016 PM - Preventative Maintenance - Pressure Vacuum Breaker ,,,,,,,,,, DB/12-1-15 ,,,,,,,,,,
FO-343705	Finished	042	5/1/2016	5/27/2016	False	2.00	PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/5-3-16 ,,,,,,,,,,
FO-343706	Finished	527	5/1/2016	5/2/2016	False		*CANCELLED JWT PM - Main Drain with Copper Sulfate
FO-343707	Finished	608	5/1/2016	5/2/2016	False		*CANCELLED JWT PM - Waterless Urinals
FO-343708	Finished	049	5/1/2016	5/2/2016	False		*CANCELLED JWT PM - Waterless Urinals
FO-343709	Finished	090	5/1/2016	5/2/2016	False		*CANCELLED JWT PM - Waterless Urinals
FO-343710	Created By PM Schedule	099-PVB-001	5/1/2016		False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker
FO-346007	Finished	048-RPZ-001	5/1/2016	5/31/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,5/13/16
FO-346008	Finished	048-RPZ-002	5/1/2016	5/31/2016	False	1.00	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,,DB,,,,,5/25/16
FO-346009	Finished	048-RPZ-003	5/1/2016	5/31/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB,,,,,5/13/16
FO-346010	Finished	049-PVB-001	5/1/2016	4/28/2016	False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker

Requested Finished Open WND

% Finished

FO-346011	Finished	067-PVB-001	5/1/2016	5/25/2016	False	1.00	PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,DB,,,5/13/16
FO-346012	Finished	038-PVB-001	5/1/2016	5/25/2016	False	1.00	PM - Preventative Maintenance - Pressure Vacuum Breaker,,,,DB,,,,5/13/2016
FO-346013	Finished	051-PVB-001	5/1/2016	5/24/2016	False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker
FO-346014	Finished	613-PVB-001	5/1/2016	5/25/2016	False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker
FO-346015	Finished	045-PVB-001	5/1/2016	5/24/2016	False	2.00	PM - Preventative Maintenance - Pressure Vacuum Breaker ,,,,,DB,,, 5/19/16
FO-346016	Finished	536-PVB-001	5/1/2016	5/25/2016	False	3.00	PM - Preventative Maintenance - Pressure Vacuum Breaker
FO-346017	Finished	536-RPZ-001	5/1/2016	5/25/2016	False	5.00	PM - Preventative Maintenance - Backflow Preventer Testing
FO-346018	Finished	056-RPZ-001	5/1/2016	5/24/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing
FO-346019	Finished	088-RPZ-001	5/1/2016	6/7/2016	False	4.00	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,,6/7/16
FO-346020	Created By PM Schedule	088-RPZ-002	5/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing
FO-346021	Created By PM Schedule	088-RPZ-003	5/1/2016		False		PM - Preventative Maintenance - Backflow Preventer Testing
FO-346022	Finished	003-RPZ-001	5/1/2016	5/2/2016	False	2.50	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,5/2/16
FAILED TEST							
FO-346023	Finished	003-RPZ-002	5/1/2016	5/2/2016	False	2.50	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,5/2/16
FO-346024	Finished	003-RPZ-003	5/1/2016	5/24/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,,DB 5/2/16
FO-346025	Finished	003-RPZ-004	5/1/2016	5/25/2016	False	2.50	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,5/2/16
FO-346026	Finished	130-RPZ-001	5/1/2016	5/26/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,,,5/25/16
FO-346027	Finished	130-RPZ-002	5/1/2016	5/26/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing. ,,,,,DB,,,,,5/25/16
FO-346028	Finished	023-RPZ-001	5/1/2016	5/25/2016	False	1.50	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/13/16
FO-346029	Finished	071-RPZ-001	5/1/2016	6/1/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/24/16
FO-346030	Finished	071-RPZ-002	5/1/2016	6/1/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/24/16
FO-346031	Finished	071-RPZ-005	5/1/2016	6/2/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/25/15
FO-346032	Finished	071-RPZ-004	5/1/2016	6/1/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/24/16
FO-346033	Finished	071-RPZ-003	5/1/2016	6/2/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,,,5/24/16
FO-346034	Finished	016-RPZ-002	5/1/2016	5/27/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/13/16
FO-346035	Finished	016-RPZ-001	5/1/2016	5/27/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/13/16
FO-346036	Finished	016-RPZ-003	5/1/2016	5/27/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,,,5/13/16
FO-346037	Finished	016-RPZ-004	5/1/2016	5/31/2016	False	2.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,5/13/16
FO-346038	Finished	016-RPZ-005	5/1/2016	5/31/2016	False	1.00	PM - Preventative Maintenance - Backflow Preventer Testing,,,,DB,,,,,5/13/16

Report Total

1052

711

260

81

68%