

# DRAFT Facilities Operations PM Analysis from 2/1/16 through 2/29/16

Requested Finished Open WND										% Finished	
Engineering			386	234	146	6					61%
E - Auxiliary			28	21	4	3					75%
FO-337229	Finished	034-RAF-001	2/1/2016	2/29/2016		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
Lubed motor & bearings. Checked belts and cleaned area.											
FO-337230	Finished	034-RAF-002	2/1/2016	2/29/2016		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
Lubed motor & bearings. Checked belts and cleaned area.											
FO-337231	Finished	034-RAF-003	2/1/2016	2/23/2016		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
Lubed bearings and checked belts.											
FO-337232	Finished	034-RAF-004	2/1/2016	2/23/2016		False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
Lubed bearings and checked belts. Changed air filters.											
FO-337233	Finished	034-RAF-005	2/1/2016	2/23/2016		False	0.25	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
Unit has been taken out of service and removed for renovation.											
FO-337240	Created By PM Schedule	134-AHU-001	2/1/2016			False		PM - Air Handling Unit			
FO-337241	Created By PM Schedule	134-AHU-002	2/1/2016			False		PM - Air Handling Unit			
FO-337242	Finished	501-ACU-001	2/1/2016	2/29/2016		True		PM - Water/Air Cooled Condenser			
FO-337243	Finished	536-AHU-201	2/1/2016	2/29/2016		True		PM - Air Handling Unit, HV Type			
FO-337244	Finished	992-ES-001*	2/1/2016	2/5/2016		False		PM - Emergency Shower/Eyewash Station			
FO-337245	Finished	536-HP-001	2/1/2016	2/29/2016		True		PM - Air Handling Unit, HV Type			
FO-337255	Created By PM Schedule	134-FP-001	2/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-337256	Created By PM Schedule	127-FP-001	2/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-337257	Created By PM Schedule	115-FP-001	2/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-337258	Created By PM Schedule	104-FP-001	2/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-337259	Created By PM Schedule	507-FP-001	2/1/2016			False		PM - Monthly Fire Alarm/Fire Protection System Test			
FO-337848	Finished	501-GEN-001	2/9/2016	2/10/2016		False		Generator Maintenance, Monthly			
FO-337849	Finished	992-ES-001*	2/8/2016	2/12/2016		False		PM - Emergency Shower/Eyewash Station			
FO-337858	Finished	034-GEN-001	2/4/2016	2/4/2016		False	1.00	Generator Maintenance, Monthly			
Electricians completed test.											
FO-338395	Finished	507-GEN-001	2/10/2016	2/11/2016		False		Generator Maintenance, Monthly			
FO-338399	Finished	992-ES-001*	2/15/2016	2/19/2016		False		PM - Emergency Shower/Eyewash Station			
FO-338643	Finished	104-GEN-001	2/23/2016	2/26/2016		False		Generator Maintenance, Monthly			
FO-338645	Finished	127-GEN-001	2/23/2016	2/26/2016		False		Generator Maintenance, Monthly			
FO-338647	Finished	127-GEN-002	2/23/2016	2/24/2016		False		Generator Maintenance, Monthly			
FO-338649	Finished	127-GEN-003	2/23/2016	2/24/2016		False		Generator Maintenance, Monthly			
FO-338651	Finished	127-GEN-004	2/23/2016	2/24/2016		False		Generator Maintenance, Monthly			
FO-338657	Finished	536-GEN-001	2/17/2016	2/17/2016		False		Generator Maintenance, Monthly			
FO-339134	Finished	992-ES-001*	2/22/2016	2/26/2016		False		PM - Emergency Shower/Eyewash Station			
E - MedPharm			39	0	39	0					0%
FO-337099	Created By PM Schedule	612-EXF-001	2/1/2016			False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-337100	Created By PM Schedule	612-EXF-002	2/1/2016			False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-337101	Created By PM Schedule	612-EXF-003	2/1/2016			False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			
FO-337102	Created By PM Schedule	612-EXF-004	2/1/2016			False		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan			

**Requested Finished Open WND**

**% Finished**

FO-337103	Created By PM Schedule	612-EXF-005	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337104	Created By PM Schedule	612-EXF-006	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337105	Created By PM Schedule	612-EXF-007	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337106	Created By PM Schedule	612-EXF-008	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337107	Created By PM Schedule	612-EXF-009	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337108	Created By PM Schedule	612-EXF-010	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337109	Created By PM Schedule	612-EXF-011	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337110	Created By PM Schedule	612-EXF-012	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337111	Created By PM Schedule	612-EXF-016	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337112	Created By PM Schedule	612-EXF-017	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337113	Created By PM Schedule	612-EXF-019	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337114	Created By PM Schedule	612-EXF-020	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337115	Created By PM Schedule	612-EXF-021	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337116	Created By PM Schedule	612-EXF-022	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337117	Created By PM Schedule	612-EXF-023	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337118	Created By PM Schedule	612-EXF-024	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337119	Created By PM Schedule	612-EXF-025	2/1/2016		False	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-337120	Created By PM Schedule	629-ES-001**	2/1/2016		False	PM - Emergency Shower/Eyewash Station
FO-337121	Created By PM Schedule	629-ES-002**	2/1/2016		False	PM - Emergency Shower/Eyewash Station
FO-337122	Created By PM Schedule	629-ES-003**	2/1/2016		False	PM - Emergency Shower/Eyewash Station
FO-337123	Created By PM Schedule	620-DHW-001	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337124	Created By PM Schedule	620-DHW-002	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337125	Created By PM Schedule	608-GEN-001	2/2/2016		False	Generator Maintenance, Monthly
FO-337126	Created By PM Schedule	603-GEN-001	2/2/2016		False	Generator Maintenance, Monthly
FO-337830	Created By PM Schedule	612-GEN-001	2/9/2016		False	Generator Maintenance, Monthly
FO-337831	Created By PM Schedule	612-GEN-002	2/9/2016		False	Generator Maintenance, Monthly
FO-338375	Created By PM Schedule	612-CFP-001	2/14/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-338376	Created By PM Schedule	612-CFP-002	2/14/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-338377	Created By PM Schedule	612-CFP-003	2/14/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-338378	Created By PM Schedule	612-CFP-004	2/14/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-338379	Created By PM Schedule	612-CFP-005	2/14/2016		False	PM - Chemical Feed/Metering Pump/Controller
FO-338380	Created By PM Schedule	609-GEN-001	2/16/2016		False	Generator Maintenance, Monthly
FO-338641	Created By PM Schedule	611-GEN-001	2/23/2016		False	Generator Maintenance, Monthly
FO-338673	Created By PM Schedule	629-GEN-001	2/23/2016		False	Generator Maintenance, Monthly
FO-339584	Created By PM Schedule	603-ROS-001	2/28/2016		False	PM - Reverse Osmosis Water Softener System

**E - North**

**19 18 1 0**

**95%**

FO-336294	Finished	025-AHU-005	2/1/2016	2/3/2016	False	2.00	Replace PRE-filters
FO-336295	Finished	025-AHU-004	2/1/2016	2/5/2016	False	3.00	Replace PRE-filters
FO-336296	Finished	025-AHU-003	2/1/2016	2/4/2016	False	2.50	Replace PRE-filters
FO-336297	Finished	025-AHU-001	2/1/2016	2/3/2016	False	3.00	Replace PRE-filters
FO-336301	Finished	025-AHU-002	2/1/2016	2/4/2016	False	2.50	Replace PRE-filters
FO-337127	Finished	027-SP-001	2/1/2016	2/16/2016	False	0.75	PM - Sump Pump
FO-337128	Finished	027-SP-002	2/1/2016	2/16/2016	False	0.75	PM - Sump Pump
FO-337129	Finished	027-SP-003	2/1/2016	2/16/2016	False	0.75	PM - Sump Pump

# Requested Finished Open WND

% Finished

FO-337130	Finished	036-SP-001	2/1/2016	2/18/2016	False	0.75	PM - Sump Pump
FO-337131	Finished	036-SP-002	2/1/2016	2/18/2016	False	0.75	PM - Sump Pump
FO-337132	Finished	048-SSF-001	2/1/2016	2/5/2016	False	0.75	PM - Harmsco Side Stream Filter
FO-337133	Finished	048-SSF-002	2/1/2016	2/9/2016	False	0.85	PM - Harmsco Side Stream Filter
FO-337134	Finished	046-SSF-001	2/1/2016	2/4/2016	False	0.75	PM - Harmsco Side Stream Filter
FO-337135	Finished	046-SSF-003	2/1/2016	2/4/2016	False	0.35	PM - Harmsco Side Stream Filter
FO-337136	Finished	027-SP-004	2/1/2016	2/16/2016	False	0.75	PM - Sump Pump
FO-337137	Finished	040-PNEM-001	2/1/2016	2/24/2016	False	0.50	PM - Unspecified
Unable to locate this equipment.							
FO-337138	Finished	046-SSF-002	2/1/2016	2/3/2016	False	0.45	PM - Harmsco Side Stream Filter
FO-337832	Finished	048-GEN-001	2/9/2016	2/9/2016	False	1.00	Generator Maintenance, Monthly
FO-338653	Created By PM Schedule	130-GEN-001	2/24/2016		False		Generator Maintenance, Monthly
<b>E - Northeast</b>			<b>28</b>	<b>22</b>	<b>6</b>	<b>0</b>	<b>79%</b>
FO-336277	Finished	527-AHU-004	2/1/2016	2/22/2016	False	1.50	Replace PRE-filters
cleaned external lint filter, replaced filters checked bely motor and fan checked operation							
FO-336278	Finished	527-AHU-003	2/1/2016	2/22/2016	False	1.50	Replace PRE-filters
cleaned external lint screen inspected filters, fan, motor and drive belt, did not replace filters. W. O. has been in system for some time, it does not run							
FO-336279	Finished	527-AHU-002	2/1/2016	2/22/2016	False		Replace PRE-filters
cleared external lint screen changed filters inspected fan, fan motor and belt							
FO-336280	Finished	527-AHU-001	2/1/2016	2/22/2016	False	1.50	Replace PRE-filters
changed filters, checked fan, motor, and belt. brushed off external lint screen. Unit runs but does not heat, wrote a work order to controls group							
FO-337139	Finished	193-DAT-001	2/1/2016	2/24/2016	False		PM - Deaerator Tank
FO-337140	Finished	193-WSS-001	2/1/2016	2/24/2016	False		PM - Water Softener
FO-337141	Created By PM Schedule	195-ACU-001	2/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-337142	Created By PM Schedule	195-ACU-002	2/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-337143	Created By PM Schedule	195-ACU-003	2/1/2016		False		PM - Fan Coil/HV/AC Unit
FO-337144	Created By PM Schedule	067-DHW-001	2/1/2016		False	0.00	PM - Domestic Water Heater, Steam
FO-337145	Finished	065-VPS-001	2/1/2016	2/1/2016	False	1.00	PM - Vacuum Pump
FO-337146	Finished	141-DHW-001	2/1/2016	2/16/2016	False	1.00	PM - Domestic Water Heater, Electric
FO-337833	Finished	193-GEN-001	2/5/2016	2/5/2016	False		Generator Maintenance, Monthly
FO-337834	Finished	193-GEN-002	2/5/2016	2/5/2016	False		Generator Maintenance, Monthly
FO-337835	Finished	193-GEN-003	2/5/2016	2/5/2016	False		Generator Maintenance, Monthly
FO-337836	Finished	193-GEN-004	2/5/2016	2/5/2016	False		Generator Maintenance, Monthly
FO-337837	Finished	209-GEN-001	2/4/2016	2/4/2016	False	1.00	Generator Maintenance, Monthly
FO-337838	Finished	209-GEN-003	2/4/2016	2/4/2016	False	0.25	Generator Maintenance, Monthly
FO-337839	Finished	209-GEN-004	2/4/2016	2/4/2016	False	1.00	Generator Maintenance, Monthly
FO-337840	Finished	211-GEN-001	2/5/2016	2/11/2016	False	1.00	Generator Maintenance, Monthly
FO-337841	Finished	211-GEN-002	2/5/2016	2/4/2016	False	1.00	Generator Maintenance, Monthly
FO-337887	Finished	209-GEN-002	2/4/2016	2/4/2016	False	1.00	Generator Maintenance, Thursday 2/4/2016 @ 7:30 AM.
FO-338381	Finished	203-GEN-001	2/16/2016	2/10/2016	False	1.00	Generator Maintenance, Monthly
FO-338638	Created By PM Schedule	066-GEN-001	2/24/2016		False		Generator Maintenance, Monthly
FO-338659	Finished	527-GEN-001	2/18/2016	2/18/2016	False	1.50	Generator Maintenance, Monthly
checked fluid levels damper operation belts and unit operation							

FO-338665	Finished	060-GEN-001A	2/25/2016	2/25/2016	False		Generator Maintenance, Monthly
FO-338667	Finished	060-GEN-001B	2/25/2016	2/25/2016	False		Generator Maintenance, Monthly
FO-339133	Created By PM Schedule	193-DHW-001	2/21/2016		False		PM - Domestic Water Heater, Gas
E - Preventative Maintenance			157	138	16	3	88%
FO-328921	Finished	090-AHU-548	2/1/2016	2/9/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328922	Finished	090-AHU-547	2/1/2016	2/9/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328923	Finished	090-AHU-546	2/1/2016	2/10/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328924	Finished	090-AHU-545	2/1/2016	2/10/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328925	Finished	090-AHU-544	2/1/2016	2/11/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328926	Finished	090-AHU-543	2/1/2016	2/11/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328927	Finished	090-AHU-542	2/1/2016	2/12/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-328928	Finished	090-AHU-541	2/1/2016	2/12/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-335938	Completed	603-AHU-010	2/1/2016		True		HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335939	Completed	603-EXF-005	2/1/2016		True		HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335940	Completed	603-AHU-009	2/1/2016		True		HEPA Filter Replacement at Applebaum Pharmacy Building
FO-335941	Finished	046-FAP-001	2/1/2016	2/27/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335942	Finished	048-FAP-001	2/1/2016	2/16/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335943	Finished	049-FAP-001	2/1/2016	2/27/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335944	Finished	156-FAP-001	2/1/2016	2/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335945	Finished	499-FAP-001	2/1/2016	2/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335946	Finished	620-FAP-001	2/1/2016	2/27/2016	False	0.30	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335947	Finished	036-FP-001	2/1/2016	2/3/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335948	Finished	025-FP-001	2/1/2016	2/17/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335949	Finished	007-FP-001	2/1/2016	3/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335950	Finished	001-FP-001	2/1/2016	2/10/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335951	Finished	005-FAP-001	2/1/2016	3/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335952	Finished	040-FAP-001	2/1/2016	2/3/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335953	Finished	038-FAP-001	2/1/2016	2/3/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335954	Finished	028-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335955	Finished	026-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335956	Finished	022-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335957	Finished	017-FAP-001	2/1/2016	2/11/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335958	Finished	016-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335959	Finished	003-FAP-001	2/1/2016	2/24/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335960	Finished	006-FP-001	2/1/2016	2/24/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335961	Finished	050-FAP-001	2/1/2016	2/16/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335962	Finished	043-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335963	Finished	042-FAP-001	2/1/2016	2/2/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335964	Finished	062-FP-001	2/1/2016	2/16/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335965	Finished	065-FP-001	2/1/2016	2/10/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335966	Created By PM Schedule	068-FAP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335967	Finished	067-FP-001	2/1/2016	2/17/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335968	Finished	089-FP-001	2/1/2016	2/24/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335969	Finished	082-FP-001	2/1/2016	2/9/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

**Requested Finished Open WND**

**% Finished**

FO-335970	Finished	080-FAP-001	2/1/2016	2/13/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335971	Finished	090-FP-001	2/1/2016	3/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335972	Finished	155-FP-001	2/1/2016	2/3/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335973	Finished	150-FAP-001	2/1/2016	2/12/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335974	Finished	167-FAP-001	2/1/2016	3/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335975	Finished	166-FP-001	2/1/2016	3/1/2016	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335976	Finished	140-FAP-001	2/1/2016	2/23/2016	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335977	Finished	130-FP-001	2/1/2016	2/23/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335978	Finished	193-FAP-001	2/1/2016	2/23/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335979	Finished	189-FP-001	2/1/2016	2/6/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335980	Finished	510-FAP-001	2/1/2016	2/11/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335981	Finished	509-FAP-001	2/1/2016	2/11/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335982	Finished	504-FAP-001	2/1/2016	2/9/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-335983	Created By PM Schedule	629-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335984	Created By PM Schedule	612-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335985	Created By PM Schedule	611-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335986	Created By PM Schedule	609-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335987	Created By PM Schedule	603-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335988	Created By PM Schedule	608-FP-001	2/1/2016		False		PM - Monthly Fire Alarm/Fire Protection System Test
FO-335989	Finished	603-AHU-010	2/1/2016	2/17/2016	False	14.00	PM - Air Handling Unit (ANNUAL)
FO-335990	Finished	603-AHU-009	2/1/2016	2/12/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-335991	Finished	603-AHU-008	2/1/2016	2/10/2016	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-335992	Finished	603-AHU-007	2/1/2016	2/5/2016	False	2.50	PM - Air Handling Unit (ANNUAL)
FO-335993	Finished	603-AHU-006	2/1/2016	2/9/2016	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-335994	Finished	603-AHU-005	2/1/2016	2/13/2016	False	6.50	PM - Air Handling Unit (ANNUAL)
FO-335995	Finished	603-AHU-004	2/1/2016	2/16/2016	False	8.00	PM - Air Handling Unit (ANNUAL)
FO-335996	Finished	603-AHU-003	2/1/2016	2/4/2016	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-335997	Finished	603-AHU-002	2/1/2016	2/9/2016	False	12.00	PM - Air Handling Unit (ANNUAL)
FO-335998	Finished	603-AHU-001	2/1/2016	2/4/2016	False	10.00	PM - Air Handling Unit (ANNUAL)
FO-335999	Finished	629-EXF-011A	2/1/2016	2/23/2016	False	5.00	Replace PRE-filters
FO-336000	Finished	629-AHU-003	2/1/2016	2/23/2016	False	8.00	PM - Air Handling Unit (ANNUAL)
FO-336001	Finished	629-AHU-002	2/1/2016	2/20/2016	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-336002	Finished	629-AHU-001	2/1/2016	2/20/2016	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-336003	Finished	074-FAP-001	2/1/2016	2/17/2016	False	0.35	PM - Monthly Fire Alarm/Fire Protection System Test
FO-336004	Created By PM Schedule	629-EXF-011B	2/1/2016		False		Replace PRE-filters
FO-336005	Finished	016-FCU-001	2/1/2016	2/5/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336006	Finished	016-FCU-002	2/1/2016	2/5/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336007	Finished	016-FCU-003	2/1/2016	2/10/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336008	Finished	016-FCU-004	2/1/2016	2/10/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336009	Finished	016-FCU-005	2/1/2016	2/5/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336010	Finished	016-FCU-006	2/1/2016	2/5/2016	False	0.50	PM - Fan Coil/HV/AC Unit
FO-336011	Finished	016-HVU-001	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336012	Finished	016-HVU-002	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336013	Finished	016-HVU-003	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit

**Requested Finished Open WND**

**% Finished**

FO-336014	Finished	016-HVU-004	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336015	Finished	016-HVU-005	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336016	Cancelled	090-AHU-548	2/1/2016		False		Replace PRE-filters
FO-336017	Cancelled	090-AHU-547	2/1/2016		False		Replace PRE-filters
FO-336018	Cancelled	090-AHU-546	2/1/2016		False		Replace PRE-filters
FO-336019	Cancelled	090-AHU-545	2/1/2016		False		Replace PRE-filters
FO-336020	Cancelled	090-AHU-544	2/1/2016		False		Replace PRE-filters
FO-336021	Cancelled	090-AHU-543	2/1/2016		False		Replace PRE-filters
FO-336022	Cancelled	090-AHU-542	2/1/2016		False		Replace PRE-filters
FO-336023	Cancelled	090-AHU-541	2/1/2016		False		Replace PRE-filters
FO-336024	Finished	090-AHU-003	2/1/2016	2/16/2016	False	2.00	Replace PRE-filters
FO-336025	Finished	090-AHU-002	2/1/2016	2/16/2016	False	2.00	Replace PRE-filters
FO-336026	Finished	090-AHU-001	2/1/2016	2/17/2016	False	2.00	Replace PRE-filters
FO-336027	Finished	090-HVU-004	2/1/2016	2/17/2016	False	2.00	Replace PRE-filters
FO-336028	Finished	090-HVU-003	2/1/2016	2/18/2016	False	2.00	Replace PRE-filters
FO-336029	Finished	090-HVU-002	2/1/2016	2/18/2016	False	2.00	Replace PRE-filters
FO-336030	Finished	090-HVU-001	2/1/2016	2/19/2016	False	2.00	Replace PRE-filters
FO-336031	Finished	611-AHU-007**	2/1/2016	2/20/2016	False	1.00	PM - Air Handling Unit (ANNUAL)
FO-336032	Finished	611-AHU-006	2/1/2016	2/19/2016	False	3.00	PM - Air Handling Unit (ANNUAL)
FO-336033	Finished	611-AHU-005	2/1/2016	2/19/2016	False	2.00	PM - Air Handling Unit (ANNUAL)
FO-336034	Finished	611-AHU-004	2/1/2016	2/20/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-336035	Finished	611-AHU-003	2/1/2016	2/18/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-336036	Finished	611-AHU-002	2/1/2016	2/13/2016	False	4.75	PM - Air Handling Unit (ANNUAL)
FO-336037	Finished	611-AHU-001	2/1/2016	2/17/2016	False	8.00	PM - Air Handling Unit (ANNUAL)
FO-336038	Finished	049-AHU-005	2/1/2016	2/6/2016	False	1.50	Replace PRE-filters
FO-336039	Finished	049-AHU-004	2/1/2016	2/3/2016	False	1.50	Replace PRE-filters
FO-336040	Finished	049-AHU-003	2/1/2016	2/6/2016	False	2.00	Replace PRE-filters
FO-336041	Finished	049-AHU-002	2/1/2016	2/6/2016	False	4.00	Replace PRE-filters
FO-336042	Finished	049-AHU-001	2/1/2016	2/3/2016	False	4.00	Replace PRE-filters
FO-336043	Finished	062-AHU-004	2/1/2016	2/10/2016	False	2.50	PM - Air Handling Unit (ANNUAL)
FO-336044	Finished	062-AHU-003	2/1/2016	2/13/2016	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-336045	Finished	062-AHU-002	2/1/2016	2/9/2016	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-336046	Finished	062-AHU-001	2/1/2016	2/9/2016	False	3.50	PM - Air Handling Unit (ANNUAL)
FO-336047	Finished	046-SAF-003	2/1/2016	2/10/2016	False	1.50	Replace PRE-filters
FO-336048	Finished	046-AHU-002	2/1/2016	1/29/2016	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-336049	Finished	046-AHU-001	2/1/2016	2/16/2016	False	6.00	PM - Air Handling Unit (ANNUAL)
FO-336050	Finished	096-FP-001	2/1/2016	2/10/2016	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-336051	Finished	085-ACU-001	2/1/2016	2/24/2016	False	5.00	Replace PRE-filters
FO-336052	Finished	026-AHU-006	2/1/2016	2/11/2016	False	0.45	Replace PRE-filters
FO-336053	Finished	026-AHU-005	2/1/2016	2/11/2016	False	1.50	Replace PRE-filters
FO-336054	Finished	026-AHU-004	2/1/2016	2/10/2016	False	1.00	Replace PRE-filters
FO-336055	Finished	026-AHU-003	2/1/2016	2/10/2016	False	2.50	Replace PRE-filters
FO-336056	Finished	026-AHU-002	2/1/2016	2/11/2016	False	2.00	Replace PRE-filters
FO-336057	Finished	026-AHU-001	2/1/2016	2/11/2016	False	3.00	Replace PRE-filters

**Requested Finished Open WND**

**% Finished**

FO-336058	Finished	027-SAF-002	2/1/2016	2/16/2016	False	4.50	Replace PRE-filters
FO-336059	Finished	027-SAF-001	2/1/2016	2/17/2016	False	3.50	Replace PRE-filters
FO-336060	Finished	028-SAF-006	2/1/2016	2/16/2016	False	0.50	Replace PRE-filters
FO-336061	Finished	028-SAF-005	2/1/2016	2/16/2016	False	0.50	Replace PRE-filters
FO-336062	Finished	028-SAF-004	2/1/2016	2/13/2016	False	0.50	Replace PRE-filters
FO-336063	Finished	028-SAF-003	2/1/2016	2/13/2016	False	0.50	Replace PRE-filters
FO-336064	Finished	028-SAF-002	2/1/2016	2/13/2016	False	1.00	Replace PRE-filters
FO-336065	Finished	028-SAF-001	2/1/2016	2/13/2016	False	1.00	Replace PRE-filters
FO-336066	Finished	016-AHU-005	2/1/2016	2/9/2016	False	2.50	Replace PRE-filters
FO-336067	Finished	016-AHU-004	2/1/2016	2/9/2016	False	3.50	Replace PRE-filters
FO-336068	Finished	016-AHU-002	2/1/2016	2/6/2016	False	3.00	Replace PRE-filters
FO-336069	Finished	016-AHU-001	2/1/2016	2/5/2016	False	3.00	Replace PRE-filters
FO-336070	Finished	023-AHU-003	2/1/2016	2/12/2016	False	1.50	Replace PRE-filters
FO-336071	Finished	023-AHU-002	2/1/2016	2/16/2016	False	1.50	Replace PRE-filters
FO-336072	Finished	023-AHU-001	2/1/2016	2/13/2016	False	2.00	Replace PRE-filters
FO-336073	Finished	022-HVU-001	2/1/2016	2/17/2016	False	2.50	Replace PRE-filters
FO-336074	Finished	022-HVU-002	2/1/2016	2/18/2016	False	2.50	Replace PRE-filters
FO-336075	Finished	036-SAF-001	2/1/2016	2/20/2016	False	3.50	Replace PRE-filters
FO-336076	Finished	036-RTU-001	2/1/2016	2/23/2016	False	3.50	Replace PRE-filters
FO-336077	Finished	036-AHU-003	2/1/2016	2/19/2016	False	2.00	Replace PRE-filters
FO-336078	Finished	036-AHU-002	2/1/2016	2/19/2016	False	3.50	Replace PRE-filters
FO-336079	Finished	082-AHU-002	2/1/2016	2/26/2016	False	4.00	Replace PRE-filters
FO-336080	Finished	082-AHU-001	2/1/2016	2/25/2016	False	3.50	Replace PRE-filters
FO-336081	Finished	016-HVU-006	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336082	Finished	016-HVU-007	2/1/2016	2/12/2016	False	0.45	PM - Fan Coil/HV/AC Unit
FO-336083	Finished	016-HVU-008	2/1/2016	2/12/2016	False	0.75	PM - Fan Coil/HV/AC Unit
FO-336084	Finished	022-AHU-001	2/1/2016	2/18/2016	False	3.50	Replace PRE-filters
FO-336085	Finished	169-FAP-001	2/1/2016	3/1/2016	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-336086	Finished	046-AHU-003	2/1/2016	2/6/2016	False	0.50	Replace PRE-filters
E - South			33	33	0	0	100%
FO-337147	Finished	089-WSS-001	2/1/2016	2/4/2016	False	1.00	PM - Water Softener
FO-337148	Finished	089-DAT-001	2/1/2016	2/4/2016	False	1.00	PM - Deaerator Tank
FO-337153	Finished	090-DHW-002	2/1/2016	2/2/2016	False	1.00	PM - Domestic Water Heater, Electric
FO-337155	Finished	089-VP-001**	2/1/2016	2/1/2016	False	1.00	PM - Vacuum Pump
FO-337156	Finished	089-VP-002**	2/1/2016	2/1/2016	False	1.00	PM - Vacuum Pump
FO-337213	Finished	006-AIR-001	2/1/2016	2/15/2016	False	1.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337214	Finished	005-AIR-001	2/1/2016	2/15/2016	False	2.25	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337236	Finished	006-AIR-002	2/1/2016	2/15/2016	False	4.50	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337237	Finished	007-AIR-008	2/1/2016	2/11/2016	False	4.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337238	Finished	007-AIR-009	2/1/2016	2/10/2016	False	3.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337246	Finished	090-DHW-003	2/1/2016	2/2/2016	False	1.00	PM - Domestic Water Heater, Electric
FO-337247	Finished	007-AIR-005	2/1/2016	12/12/2015	False	1.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337248	Finished	090-ECP-541B	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337249	Finished	090-ECP-542	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump

# Requested Finished Open WND

% Finished

FO-337250	Finished	090-ECP-543	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337251	Finished	090-ECP-544	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337252	Finished	090-ECP-545	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337253	Finished	090-ECP-546	2/1/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337254	Finished	090-ERP-542	2/1/2016	2/9/2016	False	0.50	PM - Water Booster Pump
FO-337260	Finished	007-MAU-001	2/1/2016	12/12/2015	False	1.00	Replace PRE-filters
FO-337842	Finished	090-ACU-CR2	2/8/2016	2/3/2016	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-337843	Finished	090-ACU-CR1	2/8/2016	2/3/2016	False	0.10	PM - Monthly AHU Inspection Clean Room Unit 1
FO-337850	Finished	090-ECP-541A	2/4/2016	2/18/2016	False	0.10	PM - Water Booster Pump
FO-337862	Finished	005-GEN-001	2/3/2016	2/3/2016	False	0.50	Generator Maintenance, Monthly
Did the normal Generator service... Checked the engine oil, battery levels, anti-freeze, the damper operation, and the fuel level.							
FO-338382	Finished	089-BSG-HW1	2/16/2016	2/23/2016	False	1.00	PM - Domestic Water Heater, Gas
FO-338384	Finished	007-GEN-001	2/11/2016	2/11/2016	False	0.50	Generator Maintenance, Monthly
FO-338386	Finished	007-GEN-002	2/11/2016	2/11/2016	False	0.50	Generator Maintenance, Monthly
FO-338388	Finished	090-GEN-001	2/16/2016	2/16/2016	False	1.00	Generator Maintenance, Monthly
FO-338398	Finished	090-GEN-002	2/11/2016	2/11/2016	False	1.00	Generator Maintenance, Monthly
FO-338419	Finished	090-GEN-003	2/11/2016	2/11/2016	False	1.00	Generator Maintenance, Monthly
FO-338636	Finished	089-GEN-001	2/17/2016	2/17/2016	False	1.00	Generator Maintenance, Monthly
FO-338661	Finished	006-GEN-001	2/18/2016	2/18/2016	False	1.20	Generator Maintenance, Monthly
FO-338671	Finished	089-GEN-002	2/17/2016	2/17/2016	False	1.00	Generator Maintenance, Monthly

## E - Southeast

73

0

73

0

0%

FO-337149	Created By PM Schedule	082-AIR-001	2/1/2016	False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337150	Created By PM Schedule	001-SP-018A	2/1/2016	False	PM - Sump Pump
FO-337151	Created By PM Schedule	001-SP-019A	2/1/2016	False	PM - Sump Pump
FO-337152	Created By PM Schedule	001-SP-020A	2/1/2016	False	PM - Sump Pump
FO-337157	Created By PM Schedule	001-FCU-2106-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337158	Created By PM Schedule	001-FCU-2106-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337159	Created By PM Schedule	001-FCU-2106-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337160	Created By PM Schedule	001-FCU-2106-4	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337161	Created By PM Schedule	001-FCU-2106-5	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337162	Created By PM Schedule	001-FCU-2106-6	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337163	Created By PM Schedule	001-FCU-2106-7	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337164	Created By PM Schedule	001-FCU-2106-8	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337165	Created By PM Schedule	001-FCU-2114-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337166	Created By PM Schedule	001-FCU-2114-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337167	Created By PM Schedule	001-FCU-2114-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337168	Created By PM Schedule	001-FCU-2117-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337169	Created By PM Schedule	001-FCU-2117-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337170	Created By PM Schedule	001-FCU-2117-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337171	Created By PM Schedule	001-FCU-2134-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337172	Created By PM Schedule	001-FCU-2134-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337173	Created By PM Schedule	001-FCU-2134-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337174	Created By PM Schedule	001-FCU-2135-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit



**Requested Finished Open WND**

**% Finished**

FO-337175	Created By PM Schedule	001-FCU-2135-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337176	Created By PM Schedule	001-FCU-2137-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337177	Created By PM Schedule	001-FCU-2137-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337178	Created By PM Schedule	001-FCU-2147.3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337179	Created By PM Schedule	001-FCU-2147.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337180	Created By PM Schedule	001-FCU-2147.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337181	Created By PM Schedule	001-FCU-2147.4	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337182	Created By PM Schedule	001-FCU-2147.5	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337183	Created By PM Schedule	001-FCU-2147.6	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337184	Created By PM Schedule	001-FCU-2147.7	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337185	Created By PM Schedule	001-FCU-2147.8	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337186	Created By PM Schedule	001-FCU-2147.9	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337187	Created By PM Schedule	001-FCU-2147.10	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337188	Created By PM Schedule	001-FCU-2147.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337189	Created By PM Schedule	001-FCU-2152	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337190	Created By PM Schedule	001-FCU-2153-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337191	Created By PM Schedule	001-FCU-2153-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337192	Created By PM Schedule	001-FCU-2155.10	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337193	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337194	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337195	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337196	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337197	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337198	Created By PM Schedule	001-FCU-2155.1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337199	Created By PM Schedule	001-FCU-2155.2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337200	Created By PM Schedule	001-FCU-2374-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337201	Created By PM Schedule	001-FCU-2374-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337202	Created By PM Schedule	001-FCU-2374-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337203	Created By PM Schedule	001-FCU-2374-4	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337204	Created By PM Schedule	001-FCU-2380-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337205	Created By PM Schedule	001-FCU-2380-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337206	Created By PM Schedule	001-FCU-2380-3	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337207	Created By PM Schedule	001-FCU-2383-1	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337208	Created By PM Schedule	001-FCU-2383-2	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337209	Created By PM Schedule	001-FCU-2388	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337210	Created By PM Schedule	001-FCU-2390	2/1/2016	False	PM - Fan Coil/HV/AC Unit
FO-337215	Created By PM Schedule	071-AIR-001	2/1/2016	False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337216	Created By PM Schedule	071-AIR-002	2/1/2016	False	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-337217	Created By PM Schedule	071-HWP-206	2/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-337218	Created By PM Schedule	071-HWP-207	2/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-337219	Created By PM Schedule	071-HWP-208	2/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-337220	Created By PM Schedule	071-HWP-209	2/1/2016	False	PM - Heat Pumps (5057 Woodward)
FO-337221	Created By PM Schedule	001-AHU-001ML	2/1/2016	False	PM - Air Intake Dampers (Old Main)
FO-337222	Created By PM Schedule	001-AHU-002ML	2/1/2016	False	PM - Air Intake Dampers (Old Main)

# Requested Finished Open WND

% Finished

FO-337223	Created By PM Schedule	101-AHU-003ML	2/1/2016		False	PM - Air Intake Dampers (Old Main)
FO-337224	Created By PM Schedule	001-FCU-4349	2/1/2016		False	PM - Fan Coil/HV/AC Unit
FO-337225	Created By PM Schedule	001-SP-018B	2/1/2016		False	PM - Sump Pump
FO-337226	Created By PM Schedule	001-SP-019B	2/1/2016		False	PM - Sump Pump
FO-337227	Created By PM Schedule	001-SP-020B	2/1/2016		False	PM - Sump Pump
FO-338391	Created By PM Schedule	637-GEN-001	2/16/2016		False	Generator Maintenance, Monthly
FO-338393	Created By PM Schedule	637-GEN-002	2/16/2016		False	Generator Maintenance, Monthly

<b>E - West</b>		<b>9</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>22%</b>
-----------------	--	----------	----------	----------	----------	------------

FO-337154	Created By PM Schedule	155-DHW-001	2/1/2016		False	PM - Domestic Water Heater, Steam
FO-337211	Created By PM Schedule	003-DHW-001	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337212	Created By PM Schedule	003-WSS-001	2/1/2016		False	PM - Water Softener
FO-337228	Created By PM Schedule	003-DHW-002	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337234	Created By PM Schedule	166-DHW-001	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337235	Created By PM Schedule	166-DHW-002	2/1/2016		False	PM - Domestic Water Heater, Electric
FO-337853	Finished	001 SPARE from	2/9/2016	2/10/2016	False	Generator Maintenance, Monthly
FO-337860	Finished	003-GEN-001	2/3/2016	2/3/2016	False	Generator Maintenance, Monthly
FO-338663	Created By PM Schedule	169-GEN-001	2/25/2016		False	Generator Maintenance, Monthly

<b>Trades</b>		<b>138</b>	<b>124</b>	<b>14</b>	<b>0</b>	<b>90%</b>
---------------	--	------------	------------	-----------	----------	------------

<b>T - Electrician</b>		<b>119</b>	<b>110</b>	<b>9</b>	<b>0</b>	<b>92%</b>
------------------------	--	------------	------------	----------	----------	------------

FO-337239	Finished	608-GEN-001	2/2/2016	2/2/2016	False	4.00	Generator Test Tuesday 2/2/2016 @ 7:15 AM.
FO-337261	Finished	603-GEN-001	2/2/2016	1/29/2016	False		Generator Test
FO-337262	Finished	051-SP-001	2/1/2016	2/1/2016	False	0.25	PM - Sump Pump
FO-337263	Finished	051-SP-002	2/1/2016	2/1/2016	False	0.25	PM - Sump Pump
FO-337264	Finished	051-SP-003	2/1/2016	2/1/2016	False	0.25	PM - Sump Pump
FO-337265	Finished	051-SP-004	2/1/2016	2/1/2016	False	0.25	PM - Sump Pump
FO-337266	Finished	051-SP-005	2/1/2016	2/1/2016	False	0.25	PM - Sump Pump
FO-337267	Finished	051-SP-006	2/1/2016	2/12/2016	False	0.25	PM - Sump Pump

Lab air comp took motor to electric motor 2/1/16

Building comp replaced bad fuses, put into service. Installed new motor ck rotation eng. to install belt & put in svc

FO-337844	Finished	193-GEN-001	2/5/2016	2/5/2016	False	1.00	Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337845	Finished	612-GEN-001	2/9/2016	2/9/2016	False	1.00	Generator Test Tuesday 2/9/2016 @ 7:15 AM.

\*\*\*\*PER EUGAN NO TEST\*\*\*\*\*

FO-337846	Finished	612-GEN-002	2/9/2016	2/9/2016	False	3.00	Generator Test Tuesday 2/9/2016 @ 7:15 AM.
-----------	----------	-------------	----------	----------	-------	------	--

\*\*\*\*\*PER EUGAN NO TEST\*\*\*\*\*

FO-337847	Finished	501-GEN-001	2/9/2016	2/9/2016	False	4.00	Generator Test Tuesday 2/9/2016 @ 7:15 AM.
FO-337851	Finished	048-GEN-001	2/9/2016	2/9/2016	False	4.00	Generator Test Tuesday 2/9/2019 @ 7:15 AM.
FO-337852	Finished	001 SPARE from	2/9/2016	2/9/2016	False	4.00	Generator Test Tuesday 2/9/2016 @ 1PM.
FO-337854	Finished	193-GEN-002	2/5/2016	2/5/2016	False	1.00	Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337855	Finished	193-GEN-003	2/5/2016	2/5/2016	False	1.00	Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337856	Finished	193-GEN-004	2/5/2016	2/5/2016	False	1.00	Generator Test Friday 2/5/2016 @ 2:15 PM.
FO-337857	Finished	034-GEN-001	2/4/2016	2/4/2016	False	4.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.

# Requested Finished Open WND

% Finished

FO-337859	Finished	003-GEN-001	2/3/2016	2/3/2016	False	4.00	Generator Test Wednesday 2/3/2016 @ 7:30 AM.
FO-337861	Finished	005-GEN-001	2/3/2016	2/3/2016	False	4.00	Generator Test Wednesday 2/3/2016 @ 7:30 AM.
FO-337863	Finished	051-SP-001	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337864	Finished	051-SP-001	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337865	Finished	051-SP-001	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337866	Finished	051-SP-002	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337867	Finished	051-SP-002	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337868	Finished	051-SP-002	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337869	Finished	051-SP-003	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck Ck vlv lkng-wtng on plumbers to replace							
FO-337870	Finished	051-SP-003	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck Bad ck vlv on motor #1. It leaks & has been sent to the plumbers to repair							
FO-337871	Finished	051-SP-003	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck  Lkng ck vlv waiting on plumbers to repair							
FO-337872	Finished	051-SP-004	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337873	Finished	051-SP-004	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							

**Requested Finished Open WND**

**% Finished**

FO-337874	Finished	051-SP-004	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck							
FO-337875	Finished	051-SP-005	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337876	Finished	051-SP-005	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337877	Finished	051-SP-005	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337878	Finished	051-SP-006	2/5/2016	2/5/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337879	Finished	051-SP-006	2/8/2016	2/8/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337880	Finished	051-SP-006	2/3/2016	2/3/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pumps for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-337881	Finished	209-GEN-002	2/4/2016	2/4/2016	False	1.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337882	Finished	209-GEN-001	2/4/2016	2/4/2016	False	1.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337883	Finished	209-GEN-003	2/4/2016	2/4/2016	False	2.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.
Off position-coolant leak CALLED FOR REPAIR							
FO-337884	Finished	209-GEN-004	2/4/2016	2/4/2016	False	2.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337885	Finished	211-GEN-001	2/5/2016	2/5/2016	False	2.00	Generator Test Thursday 2/4/2016 @ 7:30 AM.
FO-337886	Finished	211-GEN-002	2/5/2016	2/5/2016	False	2.00	Generator Test Friday 2/5/2016 @ 7:15 AM.
FO-338383	Finished	609-GEN-001	2/16/2016	2/16/2016	False	4.00	Generator Test, Tuesday 2/16/2016 @ 7:15 AM.
FO-338385	Finished	007-GEN-001	2/11/2016	2/11/2016	False	2.00	Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338387	Finished	007-GEN-002	2/11/2016	2/11/2016	False	2.00	Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338389	Finished	090-GEN-001	2/16/2016	2/16/2016	False	4.00	Generator Test, Tuesday 2/16/2016 @ 9:30 AM.
FO-338390	Finished	637-GEN-001	2/16/2016	2/16/2016	False	2.00	Generator Test, Tuesday 2/16/2016 @ 8:15
OUT OF SERVICE							
FO-338392	Finished	637-GEN-002	2/16/2016	2/16/2016	False	2.00	Generator Test, Tuesday 2/16/2016 @ 8:15 AM.
FO-338394	Finished	507-GEN-001	2/10/2016	2/10/2016	False	4.00	Generator Test Thursday 2/11/2016 @ 1PM.
FO-338396	Finished	203-GEN-001	2/16/2016	2/16/2016	False	4.00	Generator Test, Tuesday 2/16/2016 @ 9:15 AM.
FO-338397	Finished	090-GEN-002	2/11/2016	2/11/2016	False	4.00	Generator Test Thursday 2/11/2016 @ 7:15 AM.

# Requested Finished Open WND

% Finished

FO-338400	Finished	051-SP-001	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
FO-338401	Finished	051-SP-001	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
FO-338402	Finished	051-SP-001	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck							
2) Activate float switches & ck pups for proper operation-ck							
7) Fill out maintenance ck list & report deficiencies-ck							
FO-338403	Finished	051-SP-002	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
7) Fill out maintenance ck list & report deficiencies-ok							
FO-338404	Finished	051-SP-002	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
FO-338405	Finished	051-SP-002	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck							
2) Activate float switches & ck pups for proper operation-ck							
7) Fill out maintenance ck list & report deficiencies-ck							
FO-338406	Finished	051-SP-003	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
Motor #1 has a leaky ck vlv, wtng on plumbers to replace							
FO-338407	Finished	051-SP-003	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
Motor #1 ck vlv is lkng wtng on the plumbers to replace							
FO-338408	Finished	051-SP-003	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck							
2) Activate float switches & ck pups for proper operation-ck							
7) Fill out maintenance ck list & report deficiencies-ck							
Sump pump motor 1 has a bad/leaking ck vlv-wtng on plumbers to replace							
FO-338409	Finished	051-SP-004	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
7) Fill out maintenance ck list & report deficiencies-ok							
FO-338410	Finished	051-SP-004	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							
FO-338411	Finished	051-SP-004	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck							
2) Activate float switches & ck pups for proper operation-ck							
7) Fill out maintenance ck list & report deficiencies-ck							
FO-338412	Finished	051-SP-005	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok							
2) Activate float switches & ck pumps for proper operation-ok							

# Requested Finished Open WND

% Finished

FO-338413	Finished	051-SP-005	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-338414	Finished	051-SP-005	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pups for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-338415	Finished	051-SP-006	2/12/2016	2/12/2016	False	0.75	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-338416	Finished	051-SP-006	2/15/2016	2/15/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-338417	Finished	051-SP-006	2/10/2016	2/10/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ck 2) Activate float switches & ck pups for proper operation-ck 7) Fill out maintenance ck list & report deficiencies-ck							
FO-338418	Finished	090-GEN-003	2/11/2016	2/11/2016	False	4.00	Generator Test Thursday 2/11/2016 @ 7:15 AM.
FO-338637	Finished	089-GEN-001	2/17/2016	2/17/2016	False	4.00	Generator Test, Wednesday 2/17/2016 @ 10:00.
FO-338639	Finished	066-GEN-001	2/24/2016	2/24/2016	False	4.00	Generator Test, Wednesday 2/24/2016 @ 7:15 AM.
FO-338640	Finished	611-GEN-001	2/23/2016	2/23/2016	False	4.00	Generator Test, Tuesday 2/23/2016 @ 7:15 AM.
FO-338642	Finished	104-GEN-001	2/23/2016	2/23/2016	False	4.00	Generator Test, Tuesday 2/23/2016 @ 10AM.
FO-338644	Finished	127-GEN-001	2/23/2016	2/23/2016	False	1.00	Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338646	Finished	127-GEN-002	2/23/2016	2/23/2016	False	1.00	Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338648	Finished	127-GEN-003	2/23/2016	2/23/2016	False	1.00	Generator Test, Tuesday 2/23/2016 @ 8AM.
FO-338650	Finished	127-GEN-004	2/23/2016	2/23/2016	False	1.00	Generator Test, Tuesday 2/23/2016 @ 8AM.
NOT IN SERVICE (CRACKED BLOCK!)							
FO-338652	Finished	130-GEN-001	2/24/2016	2/24/2016	False	4.00	Generator Test, Wednesday 2/24/2016 @ 7:15 AM.
FO-338654	Finished	536-GEN-001	2/17/2016	2/17/2016	False	4.00	Generator Test, Wednesday 2/17/2016 @ 7:15 AM.
FO-338658	Finished	527-GEN-001	2/18/2016	2/18/2016	False	4.00	Generator Test, Thursday 2/18/2016 @ 7:15 AM.
FO-338660	Finished	006-GEN-001	2/18/2016	2/18/2016	False	4.00	Generator Test, Thursday 2/18/2016 @ 7:15 AM.
FO-338662	Created By PM Schedule	169-GEN-001	2/25/2016		False	4.00	Generator Test, Thursday 2/25/2016 @ 7:15 AM.
FO-338664	Created By PM Schedule	060-GEN-001A	2/25/2016		False	2.00	Generator Test, Thursday 2/25/2015 @ 1PM.
FO-338666	Created By PM Schedule	060-GEN-001B	2/25/2016		False	2.00	Generator Test, Thursday 2/25/2016 @ 1PM.
FO-338670	Finished	089-GEN-002	2/17/2016	2/15/2016	False		Generator Test, Wednesday 2/17/2016 @ 10 AM.
DUPLICATE-CLOSE OUT							
FO-338672	Finished	629-GEN-001	2/23/2016	2/23/2016	False	4.00	Generator Test, Tuesday 2/23/2016 @ 2PM.
FO-339004	Finished	051-SP-001	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck 7) Fill out maintenance ck list & report deficiencies-Ck							
FO-339005	Finished	051-SP-001	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-339006	Finished	051-SP-002	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck							

# Requested Finished Open WND

% Finished

FO-339007	Finished	051-SP-002	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-339008	Finished	051-SP-003	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck Motor #1 ck vlv still lkng, wtng on plumbers to repair							
FO-339009	Finished	051-SP-003	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok Lkng ck vlv, motor #1 sent to plumbers to replace							
FO-339010	Finished	051-SP-004	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck 7) Fill out maintenance ck list & report deficiencies-Ck							
FO-339011	Finished	051-SP-004	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-339012	Finished	051-SP-005	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck 7) Fill out maintenance ck list & report deficiencies-Ck							
FO-339013	Finished	051-SP-005	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-339014	Finished	051-SP-006	2/19/2016	2/19/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck							
FO-339015	Finished	051-SP-006	2/17/2016	2/17/2016	False	0.25	PM - Sump Pump
1) Ck electrical cords, plugs & connections-ok 2) Activate float switches & ck pumps for proper operation-ok							
FO-339135	Finished	051-SP-001	2/22/2016	2/22/2016	False	0.50	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck 7) Fill out maintenance ck list & report deficiencies-Ck							
FO-339136	Finished	051-SP-002	2/22/2016	2/22/2016	False	0.50	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck							
FO-339137	Finished	051-SP-003	2/22/2016	2/22/2016	False	1.00	PM - Sump Pump
1) Ck electrical cords, plugs & connections-Ck 2) Activate float switches & ck pumps for proper operation-Ck Adj the hight of floats. Bad ck vlv on sump #1 wtng on plumbers to replace.							
FO-339138	Finished	051-SP-004	2/22/2016	2/22/2016	False	1.00	PM - Sump Pump
Adj the hight of floats							
FO-339139	Finished	051-SP-005	2/22/2016	2/22/2016	False	0.50	PM - Sump Pump
FO-339140	Finished	051-SP-006	2/22/2016	2/22/2016	False	0.50	PM - Sump Pump
FO-339701	Created By PM Schedule	051-SP-001	2/26/2016		False	0.50	PM - Sump Pump

FO-339703 Finished 051-SP-001 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck

FO-339704 Created By PM Schedule 051-SP-002 2/26/2016 False 0.50 PM - Sump Pump

FO-339706 Finished 051-SP-002 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck

FO-339707 Created By PM Schedule 051-SP-003 2/26/2016 False 0.50 PM - Sump Pump

FO-339709 Finished 051-SP-003 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck  
Sump pump #1 motor ck vlv is stil lkng

FO-339710 Created By PM Schedule 051-SP-004 2/26/2016 False 0.50 PM - Sump Pump

FO-339712 Finished 051-SP-004 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck

FO-339713 Created By PM Schedule 051-SP-005 2/26/2016 False 0.50 PM - Sump Pump

FO-339715 Finished 051-SP-005 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck

FO-339716 Created By PM Schedule 051-SP-006 2/26/2016 False 0.50 PM - Sump Pump

FO-339718 Finished 051-SP-006 2/24/2016 2/24/2016 False 0.50 PM - Sump Pump

- 1) Ck electrical cords, plugs & connections-ck  
2) Activate float switches & ck pumps for proper operation-ck

**T - Plumber 19 14 5 0 74%**

FO-336281 Finished 527 2/1/2016 2/1/2016 False \*\*CANCELLED JWT

PM - Main Drain with Copper Sulfate

FO-336531 Created By PM Schedule 042 2/1/2016 False PM - Main Drain with Copper Sulfate ,,,,,,,,,, DB/2-1-16 ,,,,,,,,,,

FO-336532 Created By PM Schedule 608 2/1/2016 False PM - Waterless Urinals ,,,,,,,,,, MM/2-1-16 ,,,,,,,,,,

FO-336533 Finished 049 2/1/2016 2/3/2016 False PM - Waterless Urinals ,,,,,,,,,, TT/2-1-16 ,,,,,,,,,,

FO-336534 Finished 090 2/1/2016 2/3/2016 False 12.00 PM - Waterless Urinals ,,,,,,,,,, TT/2-1-16 ,,,,,,,,,,

FO-338963 Finished 026-RPZ-001 2/1/2016 2/10/2016 False 2.50 2015/2016  
PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,

FO-338964 Created By PM Schedule 026-RPZ-002 2/1/2016 False 2015/2016  
PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,

FO-338965 Finished 026-RPZ-003 2/1/2016 2/10/2016 False 1.50 2015/2016  
PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,

FO-338966 Finished 026-RPZ-004 2/1/2016 2/10/2016 False 1.00 2015/2016  
PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,

FO-338967 Finished 026-RPZ-005 2/1/2016 2/9/2016 False 4.00 2015/2016  
PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,

FO-338982 Finished 036-RPZ-001 2/1/2016 2/11/2016 False 2.50 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,

FO-338983 Finished 036-RPZ-002 2/1/2016 2/11/2016 False 3.00 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,

FO-338984 Created By PM Schedule 025-RPZ-002 2/1/2016 False PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,

FO-338985 Created By PM Schedule 025-RPZ-001 2/1/2016 False PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,

FO-338986 Finished 025-RPZ-003 2/1/2016 2/10/2016 False 1.50 PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,, DB/2-10-16 ,,,,,,,,,,



Requested Finished Open WND										% Finished
FO-338987	Finished	039-RPZ-002	2/1/2016	2/9/2016	False	1.50	2015/2016	PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,,,,,		
FO-338988	Finished	039-RPZ-001	2/1/2016	2/9/2016	False	1.50	2015/2016	PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,,,,,		
FO-339016	Finished	038-RPZ-002	2/1/2016	2/9/2016	False	1.50	2015/2016	PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,,,,,		
FO-339017	Finished	038-RPZ-001	2/1/2016	2/9/2016	False	1.50	2015/2016	PM - Preventative Maintenance - Backflow Preventer Testing ,,,,,,,,,,,,,, DB/2-8-16 ,,,,,,,,,,,,,,		
Report Total			524	358	160	6				68%