

Facilities Operations Maint. "Work Not Done" Report 5/1/16 through 5/31/16

		Total per Trade		Emergency 1 day		High 3 <= days		Medium <=14 days		Low <=30 days		Routine
Engineering		2 of 2	100%	1 of 1	100%	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
E - North		2 of 2	100%	1 of 1	100%	1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0
1	FO-348352 Maint. Work Order	5/25/2016	5/25/2016	0	Emergency	BSMNT KITCHEN EXHAUST FANS OVER STOVE NOT WORKING RM 00006/HOT KITCHEN STOVE VENTS ARE WORKING (Pls go to Rm 104 & see Kevette)				called in as emergency to electrical department. can not get exhaust fans over stove to come on and they are not able to cook without them on.		
2	FO-348512 Maint. Work Order	5/26/2016	5/25/2016	-1	High	PUMP FOR THE SPRINKLER NOT WORKING GROUNDS REQUESTING SOMEONE TO FIX PUMP				every year a company came out to check and put sprinkler system back on line. I have no knowledge of how this pump will be repaired.I talked to the Engineering supervisor Mark, and he said leave a note for the building Engineer.		
Trades		1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0 of 0	#Num!	1 of 1	100%	0
T - Electrician		1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0 of 0	#Num!	1 of 1	100%	0
4	FO-347069 Maint. Work Order	5/9/2016	5/17/2016	8	Low	R/R BLDG On May 5th during generator testing, we experienced multiple HVAC equipment shut downs. We are requesting an electrician to investigate and repair the issue. Please see Ed Nisnevich with any questions.				Talk w/engineer & we both agree that the Bldg should have a full load power otage to monitor & note what equip disable or needs to be reset. Pending 5/13/16		
Total:		3 of 3	100%	1 of 1	#Num!	1 of 1	#Num!	0 of 0	#Num!	1 of 1	100%	0