

Facilities Operations Work Orders Received 10/01/2013 through 10/31/2013

WO	Received	Finished	Total	Request
Maint. Work Order (MWRF)			2220	
Custodial			329	
Emergency			3	
C-Director			1	
FO-264645	10/16/2013			2ND FLOOR NEAR ROOM 2127 LEAKING ONTO 1ST FLOOR NEAR ROOM 1127 AND ELE
C-Materials			1	
FO-263901	10/8/2013	10/8/2013		Pick up 4 cases of tissue from 5425 Woodward the MHCC building room 429 contact person
C-Projects			1	
FO-264838	10/18/2013	10/18/2013		***URGENT****
High			2	
C-Lighting			1	
FO-264486	10/15/2013	10/15/2013		in room 0091, light flicker's when the switch is on mid way. This is was investigated by Micha
C-Repair			1	
FO-264189	10/10/2013	10/11/2013		R/R 2ND FLR RAMP MENS RR SOAP DISPENSER NEEDS REPLACING
Medium			6	
C-Director			2	
FO-263420	10/1/2013	10/10/2013		Support for the Saturday Football game.Grounds support, Custodial Support and Pest control
FO-264870	10/18/2013			Custodial and Grounds to provide support for the September 19, 2013 Open house. Buildings
C-Lighting			2	
FO-264479	10/15/2013	10/15/2013		3rd floor in ceiling next too office 301 there is an emergency light fixture that is beeping every
FO-265703	10/29/2013	10/29/2013		Light in ladies room in 95 w Hancock. Light bulbs replaced. The fixture is an electrical proble
C-Repair			1	
FO-264301	10/11/2013	10/11/2013		NEED CARPET EXTRACTOR HOSE REPLACE PLUG IS MISSING.
C-Sector 02			1	
FO-264291	10/11/2013	10/11/2013		Please shampoo carpet in conference room 2208, in front of sink area,and office 2217
Low			304	
C-Director			7	
FO-264529	10/14/2013	10/31/2013		Clean carpet in 3rd floor Meditation Room on 3rd floor of Student Center. Charge to account 2
FO-264619	10/16/2013	10/16/2013		Carpet cleaning.
FO-264992	10/21/2013			Clean carpet inside Room-289 on second floor of Student Center. Any charges are to account
FO-265223	10/23/2013			Floor in room 372 needs waxing.
FO-265243	10/23/2013			Clean carpets in second floor offices of
FO-265541	10/25/2013			Shampoo carpet in main office suite and adjacent staff offices 1321.1-1321.7
FO-265660	10/28/2013			Trade: Custodian
C-Lighting			131	
FO-263355	10/1/2013	10/1/2013		(2) cases of 32 watt CW Flo. Bulbs
FO-263376	10/1/2013	10/1/2013		3 lights in the lobby are out
FO-263389	10/1/2013	10/1/2013		Five fixtures rebulbed not lighting.Work order being forwarded to Mr.Eugene Owens for further
FO-263404	10/1/2013	10/2/2013		MEN'S RESTROOM 3108 LIGHT OUT NEAR URINALS.
FO-263544	10/2/2013	10/2/2013		Please repair the light fixture in the Men's room (ballast is bad).
FO-263549	10/2/2013	10/1/2013		Hallway near 223 (inside suite 206): burned out lightbulb, please replace.
FO-263652	10/3/2013	10/4/2013		installed 3 bulbs...close out.
FO-263654	10/3/2013	10/4/2013		This was written up and sent to the Electricians as an electrical problem on 6/1/13...it will be r
FO-263656	10/3/2013	10/4/2013		installed 6 bulbs..close out.
FO-263658	10/3/2013	10/3/2013		in room 6126, bulb needs to be replaced with a cone shaped light fixture
FO-263671	10/3/2013	10/3/2013		light is flickering on and off in s

WO	Recieved	Finished	Total	Request
FO-263685	10/3/2013	10/3/2013		We have a light out in the passenger elevator.
FO-263686	10/3/2013	10/11/2013		bulbs will be ordered for this area. There are none in stock.
FO-263710	10/3/2013	10/4/2013		More than one lightbulb out in loading dock
FO-263712	10/3/2013	10/10/2013		installed (12) bulbs prior to today.
FO-263742	10/4/2013	10/4/2013		Lights are out in the basement, storage room
FO-263743	10/4/2013	10/4/2013		This was wrote up on 10/01/13...and forwarded to Electricians...this is a high priority due to it b
FO-263780	10/4/2013	10/7/2013		There are some overheard lights flickering in
FO-263785	10/4/2013	10/4/2013		Hallway outside room 147: burned out lightbulb, please replace.
FO-263786	10/4/2013	10/7/2013		Hallway outside Margherio Conference Center/room 144: burned out lightbulb near portrait, ab
FO-263787	10/4/2013	10/11/2013		Burned out lightbulbs: three above Starboards along west wall; one florescent above white bo
FO-263788	10/4/2013	10/7/2013		Lightbulb burned out above last stall of women's restroom.
FO-263793	10/5/2013	10/9/2013		The inner lobby has about half of the sconce lights burned out. Please replace.
FO-263798	10/5/2013	10/9/2013		The reception room on the 2nd floor(Bonstelle Room) should have small size 40watt bulbs. Th
FO-263816	10/7/2013	10/21/2013		2 light bulbs out in room# 2125
FO-263823	10/7/2013	10/10/2013		waiting on approval to purchase bulbs for Schaap Hall and 2nd flr, interaction space. (last quot
FO-263874	10/7/2013	10/8/2013		Ceiling light directly in front of elevators in lobby needs replaced.
FO-263894	10/8/2013	10/9/2013		Replaced 9 bulbs in stairwell. However, there are 4 EP's from the 4th floor up to the roof exit t
FO-263902	10/8/2013	10/9/2013		2 lights out in room# 385
FO-263934	10/8/2013	10/9/2013		1st floor women's restroom needs light replacement.
FO-263935	10/8/2013	10/9/2013		KITCHEN IN BASEMENT LIGHT OUT.
FO-263937	10/8/2013	10/8/2013		REPLACE BLOWN LIGHT BULBS. ROOM 489.
FO-263959	10/8/2013	10/9/2013		7 lights are out in Rm 469
FO-264009	10/9/2013	10/9/2013		1 Case of Circle Bulbs(FC12T9CW)
FO-264021	10/9/2013	10/9/2013		REPLACE BLOWN LIGHT BULBS. ROOM 147
FO-264072	10/9/2013	10/15/2013		Lights needed in room 275 and corridor 201 in the office block.
FO-264080	10/9/2013	10/10/2013		completed. close out
FO-264082	10/9/2013	10/10/2013		This area is actually the lobby and has no room number. There are 8 lights out in the lobby are
FO-264083	10/9/2013	10/10/2013		2 or 3 Bulbs out in room 022
FO-264084	10/9/2013	10/10/2013		This is actually a hallway area and also has no room numbers. Down the long hallway leading
FO-264085	10/9/2013	10/11/2013		this was completed a week prior to the date. close out.
FO-264086	10/9/2013	10/10/2013		6th floor, Suite 6400, 2 light bulbs need to be replaced.
FO-264090	10/9/2013	10/9/2013		1 light out in room# 297
FO-264134	10/9/2013	10/11/2013		installed 30 bulbs in room. Close out.
FO-264196	10/10/2013	10/10/2013		lights out in hallway in front of 1107. Please
FO-264239	10/10/2013	10/11/2013		light out
FO-264240	10/11/2013	10/11/2013		The light is out in the Janitor's closet located inside of the Men's locker room. This is an EP, t
FO-264248	10/11/2013	10/11/2013		Please repair/replace blinking lights im MD lab 2258.
FO-264249	10/11/2013	10/11/2013		Please repair/replace burnt out lights/blinking lights in MD Lab 2343.
FO-264250	10/11/2013	10/11/2013		Please remove lights that are stored in 2nd floor janitors closet (#2104).
FO-264302	10/11/2013	10/15/2013		There are 2 lights burned out in the south
FO-264316	10/11/2013	10/14/2013		ceiling light needs replacing in hallway right outside of room 2155.16
FO-264324	10/12/2013	10/14/2013		There are two lights , in the Fourth floor tower near the restrooms, are flickering. They need to
FO-264363	10/12/2013	10/15/2013		there are lights out in the journal section on the right side of the building label on left side with
FO-264335	10/14/2013	10/15/2013		Replace lights in Old Main 0006.
FO-264354	10/14/2013	10/14/2013		flickering hallway lights outside of rm.1102
FO-264374	10/14/2013	10/14/2013		WOMEN'S RETROOM #2112 NEED LIGHT REPLACEMENT.
FO-264409	10/14/2013	10/15/2013		Replace burnt out lights in north passenger

WO	Recieved	Finished	Total	Request
FO-264391	10/14/2013	10/14/2013		in room 1279, 2 fluorescent bulbs are out, on the stairwell, westside of the building, 2nd floor. I
FO-264393	10/14/2013	10/14/2013		lights out in room 440, 4th floor, suite 416
FO-264400	10/14/2013	10/14/2013		A light cover is falling off at Eastside hallway, general area, nearby room# 147
FO-264407	10/14/2013	10/15/2013		1 panel dark, 1 bulb flickering in room 1321
FO-264412	10/14/2013	10/15/2013		Relamp fixtures in room 180, computer server room. Note: See Alex for access to room.
FO-264413	10/14/2013	10/15/2013		Relamp fixtures in room 180.2, computer server room. Note: See Alex for access to room.
FO-264414	10/14/2013	10/15/2013		Relamp fixtures in room 197. Note: See Alex for access to room.
FO-264415	10/14/2013	10/15/2013		Relamp fixtures in room 230 on mezz. Note: See Alex for access to room.
FO-264448	10/14/2013	10/15/2013		Relamp fixture in main hall outside room 114.
FO-264449	10/14/2013	10/15/2013		There are four fluorescent light bulbs out in room 2227 that need to be replaced.
FO-264465	10/15/2013	10/15/2013		Near room 219, burned out lightbulb. Please replace.
FO-264499	10/15/2013	10/15/2013		4 lights out in news room and sausha's office
FO-264579	10/16/2013	10/16/2013		Purdy Library 2nd Floor
FO-264593	10/16/2013	10/17/2013		Please continue to replace or repair the
FO-264594	10/16/2013	10/18/2013		Relamp fixtures in room 101.1. (Also known as room 127.)
FO-264601	10/16/2013	10/17/2013		installed (6) bulbs in office.
FO-264606	10/16/2013	10/17/2013		installed (6) bulbs in office.
FO-264629	10/16/2013	10/16/2013		Light bulb replacement: 3 in interior office, 2 in main lab, and 1 in back sound booth. Room 0
FO-264654	10/16/2013	10/17/2013		4TH FL HALLWAY LIGHTS OUT. Task was completed by Michael Seldon. One electrical prob
FO-264681	10/17/2013	10/17/2013		Behind Circulation desk are about 6 lights out, please replace. All bulbs replaced. 1 electrical
FO-264683	10/17/2013	10/17/2013		Basment of Purdy Library several lights out. Please replace. Basement bulbs replaced. No ele
FO-264714	10/17/2013	10/18/2013		Almost all the lights are out in the Hallway. (Middle to S. End) Outside of Room 3329. Depart
FO-264734	10/17/2013	10/17/2013		Hallway outside suite 206: burned out lightbulb. Please replace.
FO-264776	10/17/2013	10/18/2013		Please replace lights. Half of them are down.
FO-264813	10/18/2013	10/21/2013		1) 2nd floor mens restroom, North East side, couple of lights out near the sink.
FO-264814	10/18/2013	10/18/2013		In room 436, 4 lights are out. keys can be obtained from room 487.
FO-264861	10/18/2013	10/22/2013		Relamp fixture in room 160. Fixture is beeping for attention. See Alex for fixture.
FO-264885	10/18/2013	10/21/2013		Lamping Crew: Please relamp stairwell "G" in the "E" building. Priority:Medium
FO-264872	10/18/2013	10/21/2013		1st floor ladies restroom light is out.
FO-264873	10/18/2013	10/21/2013		2nd floor mens restroom light out.
FO-264935	10/21/2013	10/21/2013		Light bulb out, in front of Stairwell K, 3rd floor
FO-264937	10/21/2013	10/21/2013		room# 218, light cover is falling off
FO-264938	10/21/2013	10/21/2013		Light bulb out in first floor, Mens Restroom.
FO-264939	10/21/2013	10/21/2013		Light Bulb is Flickering in room# 34
FO-264952	10/21/2013	10/22/2013		Near room 222: burned out lightbulb. Please replace.
FO-265084	10/22/2013	10/23/2013		Light out; located outside stairwell A basement
FO-265126	10/22/2013	10/23/2013		Replace burned out florescent bulbs In room 385 Manoogian (388.2).
FO-265169	10/23/2013	10/28/2013		Lighting Med Priority
FO-265196	10/23/2013	10/23/2013		Replace burned out ceiling bulb at 5057 Woodward, Suite 3101, Educational Outreach. The c
FO-265226	10/23/2013	10/25/2013		2 lights flickering in room 3700.
FO-265227	10/23/2013	10/23/2013		in room# 279, ceiling lights are out
FO-265228	10/23/2013	10/24/2013		lights out in room# 43 and in the kitchen, 2nd floor One ep found in room 43. Request sent to
FO-265230	10/23/2013	10/23/2013		lights out in the following rooms
FO-265234	10/23/2013	10/24/2013		in room# 450, 4 lights are out (2 panels) Installed (6) bulbs.
FO-265273	10/23/2013	10/24/2013		Room 2337 has lights out in the office. Please change. Thanks!
FO-265282	10/23/2013	10/24/2013		Light replacement needed - center lights flickering on each track.
FO-265285	10/23/2013	10/24/2013		There are 3 light bulbs out in Room 3145.

WO	Recieved	Finished	Total	Request
FO-265300	10/24/2013	10/25/2013		Dr. Terlecky's office has a light out.
FO-265312	10/24/2013	10/25/2013		In Rm 3800, 2 lights flickering by front desk.
FO-265347	10/24/2013	10/28/2013		Lighting Med. Priority
FO-265343	10/24/2013	10/25/2013		Lights out in Storage operation room located in the Basement
FO-265345	10/24/2013	10/24/2013		In rm 125 2 lights and overhead desks lights are out. All bulbs have been replaced. The desk
FO-265361	10/24/2013	10/25/2013		Please replace burned out lights in the hallway.
FO-265362	10/24/2013	10/25/2013		Please replace burned out lights in the lab.
FO-265364	10/24/2013	10/25/2013		Please replace burned out lights in the lab.
FO-265365	10/24/2013	10/25/2013		Please replace burned out lights in the office.
FO-265367	10/24/2013	10/25/2013		Please replace burned out lights in the office.
FO-265372	10/24/2013	10/31/2013		Light bulb replacement for first two lights in the high bay area track that stay on 24/7. Lights n
FO-265439	10/24/2013	10/25/2013		Room 322, burnt out lights, light fixture needs new fluorescent bulbs, the bulbs are in a wareh
FO-265457	10/25/2013	10/25/2013		Hallway near room 235: burned out lightbulb. Please replace.
FO-265473	10/25/2013	10/25/2013		The light above one of the desks in the WDET
FO-265584	10/28/2013	10/30/2013		2 lights out in room# 3101, ECE Department.. this is an EP. it will be forwarded to Electricians.
FO-265673	10/28/2013			Graduate Programs - Room 1128 Dr. Terlecky's Office desk flourescent (1) light bulb needs re
FO-265693	10/29/2013	10/30/2013		Trade: Lighting crew Priority: Low
FO-265694	10/29/2013	10/29/2013		Need lights on east stairwell of Purdy.
FO-265700	10/29/2013	10/29/2013		RM 4316 NEED LIGHT BULBS REPLACED
FO-265716	10/29/2013	10/29/2013		rm 419 2 panels out
FO-265879	10/30/2013	10/31/2013		Relamping needed in multiple areas.
FO-265892	10/30/2013	10/30/2013		2 lights out in rm 220
FO-265898	10/30/2013	10/31/2013		1 light out in room 101.1 (Locked room) Call 71154 to get access to the room.
FO-265899	10/30/2013	10/30/2013		2 lights out in room 333.
FO-265907	10/30/2013	10/30/2013		Lights are out in first floor men's room.
FO-265908	10/30/2013			Light is out at top (on wall) of main stairway.
C-Materials			10	
FO-263745	10/4/2013	10/16/2013		recycle bin is needed in room# 2100
FO-263830	10/7/2013	10/8/2013		2 grey recycle bins are required in room# 4126
FO-264091	10/9/2013	10/14/2013		request for recycle bin drop-off and pickup in room# 4119
FO-264599	10/16/2013	10/16/2013		request a trsh can for room 326 State Hall - deliver to supervisors office 207 State Hall
FO-264604	10/16/2013	10/17/2013		Request for a grey recycle bin pickup and 2 more to be dropped off in rm# 4110 ASAP
FO-264818	10/18/2013	10/21/2013		request for recycle bin pickup and dropoff in room 3100
FO-264933	10/21/2013	10/21/2013		request for recycle bin picked up and dropped off in room# 3103, 3rd floor.
FO-265225	10/23/2013	10/28/2013		Request for recycle bin pickup and drop-off in room# 2361, hallway right outside
FO-265432	10/24/2013	10/28/2013		R/R RM 1215 To remove outdated material that is in boxes. Approximately 39 boxes of variou
FO-265900	10/30/2013	10/30/2013		request for recycle bin picked up at rm 2100
C-Projects			3	
FO-264810	10/18/2013			Room 1210 needs to be cleaned and waxed by October 25th.
FO-265109	10/22/2013			Please clean surfaces and sweep in room 0363 in the lower lobby. Thanks!10/22/13 lps: Re
FO-265260	10/23/2013			Office 362 needs to be cleaned out along with some items in the hallways of the 2nd and 3rd fl
C-Repair			68	
FO-263360	10/1/2013	10/1/2013		Need some supplies (Drill, Bit and Wall, Anchors).
FO-263423	10/1/2013	10/2/2013		toilet paper dispenser in women's restroom on the 1st floor is broke off the wall.
FO-263553	10/2/2013	10/3/2013		Toilet Paper Dispensor is broken in restroom 3008, Handicap Stall
FO-263597	10/2/2013	10/11/2013		Broken vacumn at 1200 Holden. Machine smoking and has stopped.
FO-263621	10/3/2013	10/3/2013		Men's 5th floor restroom paper towel dispenser off the wall.
FO-263683	10/3/2013	10/8/2013		UGL Dean's Office ladies restroom, Room 3134, needs new white plastic receptacle for dispo

WO	Recieved	Finished	Total	Request
FO-263718	10/4/2013	10/4/2013		1st floor hand sanitizer need refill.
FO-263726	10/4/2013	10/4/2013		Key for auto scrubber in Rackham.
FO-263859	10/7/2013	10/16/2013		Vacuum in Janitor closet 105.2 in Matthaehi is in pieces. Needs repair.
FO-263861	10/7/2013	10/9/2013		Dail Hand Sanitizer dispenser empty in Fitness. Please refill.
FO-263864	10/7/2013	10/25/2013		State Hall exit 4, Dial Hand Sanitizer dispensor empty. Please refill.
FO-263891	10/8/2013	10/11/2013		PAPER TOWEL HOLDER IS BROKEN. 1ST FLOOR MEN'S RESTROOM (NEAR CUSTODI
FO-263993	10/9/2013	10/9/2013		Men's Restroom on 3rd floor soap dispenser off the wall needs new 1.
FO-264154	10/9/2013	10/30/2013		Dail Hand Sanitizer broken not dispensing (near exit ramp and room #11 in the basement)
FO-264155	10/9/2013	10/15/2013		Vacuum Cleaner in Cohn needs repair. Screw missing, being held together by a pencil. Janitor
FO-264220	10/10/2013	10/18/2013		WOMEN'S RESTROOM 3126 TISSUE DISPENSER BROKEN. PLEASE REPAIR/REPLACE.
FO-264241	10/11/2013	10/16/2013		The paper towel dispenser in the Women's rest room (130 nearest exit 4) is broken and need
FO-264252	10/11/2013	10/15/2013		Men's 1st floor restroom paper towel dispenser off the wall needs new 1.
FO-264294	10/11/2013	10/15/2013		Please fix broken soap despencer in womens restroom in Scott Hall 3rd floor.
FO-264300	10/11/2013	10/11/2013		A REQUEST FOR RESTROOM'S DISPENSERS KEY'S (ROLL TOWEL, TISSUE, AND SOA
FO-264351	10/14/2013			Lande -Handyman, please install new soap dispenser in Penthouse.
FO-264349	10/14/2013	10/16/2013		1st floor mens restroom 132 hand soap dispenser broke (off the wall) State Hall
FO-264361	10/14/2013	10/14/2013		NEW EQUIPMENT:
FO-264367	10/14/2013	10/14/2013		Up Date:10-11-13
FO-264369	10/14/2013	10/11/2013		Up Date: 10-11-13
FO-264377	10/14/2013	10/17/2013		MEN'S RESTROOM 440, BROKEN SOAP DISPENSER. PLEASE REPAIR/REPLACE.
FO-264379	10/14/2013	10/23/2013		WOMEN'S RESTROOM 340, PAPER TOWEL DISPENSER BROKEN. PLEASE REPAIR.RE
FO-264380	10/14/2013	10/17/2013		4TH FLOOR WOMEN'S RESTROOM SOAP DISPENSER RIPPED OFF WALL. THIS RESTR
FO-264381	10/14/2013	10/16/2013		WOMEN'S RESTROOM 1ST FLOOR TISSUE DISPENSER BROKEN IN 3RD STALL--- TAP
FO-264424	10/14/2013			NEW EQUIPMENT: (NOBLES) W/D VACUUM
FO-264429	10/14/2013			NEW EQUIPMENT: (ADVANCE) CARPET, EXTRACTOR AQUACLEAN 16XP
FO-264450	10/15/2013			The hand sanitizer dispenser located near the western entrance (facing Manoogian) needs to b
FO-264451	10/15/2013			The hand sanitizer needs to be refilled near the Eastern exit (facing General lectures).
FO-264452	10/15/2013			The hand sanitizer dispenser across from Stair D, near the North Western exit needs repair. T
FO-264535	10/16/2013	10/16/2013		In room 130 Women's Restroom the paper towel dispenser is broken. It needs to be replaced
FO-264536	10/16/2013	10/25/2013		In room 102 Women's Restroom, the first stall toilet paper dispenser is broken. It is the stall n
FO-264537	10/16/2013	10/21/2013		The Versafill machine in the custodial closet located inside the Men's Room on the first floor,
FO-264627	10/16/2013	10/23/2013		4th floor rest room 402 soap dispenser broke State Hall
FO-264758	10/17/2013	10/23/2013		3rd floor mens room (no room number)paper towel dispenser broke Chemistry building
FO-264761	10/17/2013	10/17/2013		NEED SOME BATTERIES (Qty-24, / D') FOR THE HAND, SANITIZER DISPENSERS (5), SA
FO-264780	10/18/2013	10/18/2013		A soap dispenser in Women's room 1332.2 is in need of repair. It is missing the cover of the d
FO-264781	10/18/2013	10/23/2013		The paper towel dispenser is broken in the unisex bathroom.The bathroom is located on the fir
FO-264782	10/18/2013	10/31/2013		The paper towel dispenser is broken in the Women's bathroom. The bathroom is located on th
FO-264786	10/18/2013	10/18/2013		WOMEN'S RESTROOM #3126 PAPER TOWEL DISPENSER BROKEN. PLEASE REPAIR/R
FO-264853	10/18/2013	10/25/2013		A REQUEST TO ASSEMBLE (5), NEW HAND, SANITIZER DISPENSERS STAND WITH TH
FO-264876	10/18/2013	10/23/2013		1st floor womans restroom soap dispenser is broken.
FO-264877	10/18/2013	10/23/2013		Basement mens restroom paper towel dispenser is broken.
FO-264950	10/21/2013	10/21/2013		I PICK UP VACUUM CLEANER (FO-263859), FOR SERVICE REPAIRS. TRANSFER TO ST
FO-264967	10/21/2013	10/21/2013		A REQUEST TO REPACE A BROKEN SOAP DSIPENSER IN RESTROOM MEN'S RM# 132
FO-264983	10/21/2013			SUPERVISOR SIGNAGE INSTALL ON #014 OFFICE DOOR.
FO-264997	10/22/2013	10/23/2013		The soap dispenser is broken into jieces in the Women's Room (on the first floor. The soap di
FO-265063	10/22/2013			ADVANCE AUTO-SCRUBBER 26D #1839814 REPORTED TO ME BY GREGORY JOHNSO
FO-265251	10/23/2013			Ladies Room in Suite 1600, Advising, metal sanitary receptacle needs repair or replace in first

WO	Recieved	Finished	Total	Request
FO-265284	10/24/2013	10/25/2013		ADVANCE VACUUM, MODEL#ADVAC-12, SERIAL #1792083. THE SPIN WHEEL HOUSING
FO-265429	10/25/2013	10/31/2013		We have several paper towel dispensers that out of order. These area's are from the 1st floor t
FO-265550	10/26/2013			Please repair pacesetter 20TS side by side scrubber (SN # 3000132216). When plugged in no
FO-265553	10/26/2013			Please repair/replace 1st floor ladies restroom (#170) soap dispenser it is off the wall.
FO-265643	10/28/2013			VACUUM BEATER BAR, THE BAR WILL NOT TURN IN VACUUM. PLEASE REPLACE/REP
FO-265702	10/29/2013			Mens room papper towel despencer is broken need to be replaced.room 8101 8th floor Scott
FO-265755	10/29/2013			The hand sanitizer dispenser located near the stair well at the Eastern exit (facing Prentis) is n
FO-265758	10/29/2013			Inside the Women's Locker Room, there are several sanitary napkin disposal units that are no
FO-265780	10/30/2013			Ladies restroom #170. Please repair/replace paper towel dispenser. It is off the wall.
FO-265781	10/30/2013	10/31/2013		1st floor men's restroom soap dispenser is broken.
FO-265823	10/30/2013			Women's Restroom 1st paper towel dispenser off the wall & 5th floor soap dispenser off the w
FO-265855	10/30/2013			The Hand Sanitizer Dispensers aren't working on the 4th 3rd or 2nd floors. 2nd and 3rd floor h
FO-265874	10/30/2013			paper towel dispenser broke/ 1st floor back hall(behind the stage) mens room
FO-265875	10/30/2013			Paper towel dispenser comeing off the wall(screws are loose)2nd floor large dressing room - I
FO-265937	10/30/2013			In the women's restroom (170) a paper towel dispenser was broken off the wall. It has left two
C-Sector 01			5	
FO-265184	10/23/2013	10/23/2013		2 Case's of Dial Soap
FO-265187	10/23/2013	10/23/2013		2 Case's of Dial Soap
FO-265188	10/23/2013	10/23/2013		2 Case's of Dial Soap
FO-265189	10/23/2013	10/23/2013		2 Case's of Dial Soap
FO-265860	10/30/2013	10/30/2013		3RD FLOOR LADIES RESTROOM - BLOOD ON SINK. SOUTH SIDE OF BUILDING. (LEFT
C-Sector 02			9	
FO-263402	10/1/2013	10/1/2013		Shampoo inter office carpet in 2305 Scott Hall
FO-263938	10/8/2013	10/11/2013		Please strip and wax floor in room 3113. Also, please shampoo carpet in office 3355. Please
FO-264078	10/9/2013	10/25/2013		Comprehensive NIH Site Visit Projects: Basement: Strip/wax Basement corridor, and specializ
FO-264290	10/11/2013	10/11/2013		scrub and wax lab 8105
FO-264713	10/17/2013	10/18/2013		6 cases of White Rags
FO-264762	10/17/2013	10/31/2013		Room 4360 - Please strip and wax lab floor. Please contact Dr. Iulia Kovari at 577-0296 to sc
FO-264811	10/18/2013	10/28/2013		Room 1236 needs the floor cleaned and waxed.
FO-265614	10/28/2013			Carpet hallway on third floor (south side of building) needs cleaning. This includes suite 3610.
FO-265775	10/29/2013	10/29/2013		Photographer coming to lab to take photos.
C-Sector 03			7	
FO-264821	10/18/2013			Warehouse side of building is in need of floor sweeping. Dirt built up.
FO-265040	10/22/2013	10/22/2013		1 case of dial soap
FO-265042	10/22/2013	10/22/2013		1 case of dial soap
FO-265043	10/22/2013	10/22/2013		1 case of dial soap
FO-265580	10/28/2013	10/25/2013		2 cases of Dial Soap
FO-265581	10/28/2013	10/25/2013		2 cases of Dial Soap
FO-265583	10/28/2013	10/25/2013		1 case of Dial Soap
C-Sector 04			5	
FO-264183	10/10/2013	10/12/2013		2 Cases of Dial Soap
FO-265032	10/22/2013	10/24/2013		2 cases of dial soap
FO-265034	10/22/2013	10/24/2013		2 cases of dial soap
FO-265038	10/22/2013	10/24/2013		2 cases of dial soap
FO-265685	10/29/2013			Scrub restroom floors in shiffman library Rooms: 106,107
C-Sector 05			8	
FO-264523	10/15/2013	10/18/2013		The 2nd floor in the old wing has not been properly serviced this week. Trash in Room 2410 h
FO-265155	10/23/2013	10/18/2013		The FO-258669 was closed in August we are re-opening.Room 345 was completed on Oct 18

WO	Recieved	Finished	Total	Request
FO-265337	10/24/2013			Clean carpet and floor mats inside St.Andrews Hall. All charges are to account 227149.
FO-265484	10/25/2013	10/28/2013		4 cases of Dial Soap
FO-265486	10/25/2013	10/28/2013		3 cases of Dial Soap
FO-265488	10/25/2013	10/28/2013		2 cases of Dial Soap
FO-265490	10/25/2013	10/28/2013		3 cases of Dial Soap
FO-265491	10/25/2013	10/28/2013		2 boxes of white rags
C-Sector 06			7	
FO-263753	10/4/2013	10/7/2013		4 cases of Dial Soap task is complete
FO-263754	10/4/2013	10/7/2013		4 cases of Dial Soap task is complete
FO-263755	10/4/2013	10/7/2013		2 cases of Dial Soap task is complete
FO-263756	10/4/2013	10/7/2013		2 cases of Gojo Soap
FO-263757	10/4/2013	10/7/2013		4 cases of Rags for sector-6
FO-263758	10/4/2013	10/7/2013		2 cases of Dial Soap
FO-265342	10/24/2013	10/25/2013		1 case of dial soap task is complete
C-Sector 07			11	
FO-264000	10/9/2013	10/11/2013		3 Case's of Dial Soap
FO-264001	10/9/2013	10/11/2013		3 Case's of Dial Soap
FO-264003	10/9/2013	10/11/2013		2 Case's of Dial Soap for Purdy/Kresge
FO-264004	10/9/2013	10/11/2013		1 Case of Dial Soap
FO-264006	10/9/2013	10/11/2013		2 Case's of Dial Soap
FO-264007	10/9/2013	10/11/2013		1 Case of Dial Soap
FO-264016	10/9/2013	10/11/2013		1 Case of Dial Soap
FO-264168	10/10/2013	10/24/2013		Purdy Library 1st Floor Room/Suite 134
FO-264589	10/16/2013	10/24/2013		Purdy Library 4th Floor, Room 448
FO-264972	10/21/2013			Please clean both levels of the Elaine L. Jacob
FO-265045	10/22/2013	10/24/2013		5 Box's of Rag's
C-Sector 08			5	
FO-264256	10/9/2013	10/26/2013		AAB contact: Yvonne Maxwell
FO-264153	10/9/2013			Athletic Hall of Fame carpet needs to be cleaned by 10/17/2013.
FO-264618	10/16/2013			AAB Carpet Cleaning
FO-265162	10/23/2013			Mortuary Science- Carpet cleaning for room 314 and 421.
FO-265164	10/23/2013			Mortuary Science. Cleaning and wax by Nov 11 for our annual open house. Please clean and
C-Sector 09			28	
FO-263635	10/3/2013	10/3/2013		1 case of dial soap
FO-263636	10/3/2013	10/3/2013		1 case of dial soap
FO-263637	10/3/2013	10/3/2013		1 case of dial soap
FO-263639	10/3/2013	10/3/2013		1 case of dial soap
FO-263640	10/3/2013	10/3/2013		3 case's of dial soap
FO-263642	10/3/2013	10/3/2013		1 case of dial soap
FO-263643	10/3/2013	10/3/2013		1 case of dial soap
FO-263644	10/3/2013	10/3/2013		1 case of dial soap
FO-263645	10/3/2013	10/3/2013		1 case of dial soap
FO-263646	10/3/2013	10/3/2013		1 case of dial soap
FO-263647	10/3/2013	10/3/2013		1 case of dial soap
FO-263648	10/3/2013	10/3/2013		1 case of dial soap
FO-263649	10/3/2013	10/3/2013		1 case of dial soap
FO-264263	10/11/2013	10/24/2013		Reuther. It's been several years--we need the carpets
FO-264306	10/11/2013	10/29/2013		Applebaum. First Floor hallways need to be cleaned and waxed. This needs to be completed

WO	Recieved	Finished	Total	Request
FO-264673	10/16/2013	10/17/2013		Carpet cleaning on the 1st and 2nd floor of
FO-265862	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265863	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265864	10/30/2013	10/30/2013		2 case's of Dial Soap
FO-265865	10/30/2013	10/30/2013		2 case's of Dial Soap
FO-265866	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265867	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265868	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265869	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265870	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265871	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265872	10/30/2013	10/30/2013		1 case of Dial Soap
FO-265873	10/30/2013	10/30/2013		2 case's of Dial Soap
Routine			14	
C-Director			8	
FO-263396	10/1/2013	10/1/2013		FY 2013 FO for Grounds Department.
FO-263666	10/3/2013	10/3/2013		FY 2013 FO for Grounds Department.
FO-265987	10/23/2013	10/31/2013		FY 2014 FO for Grounds Department.
FO-265953	10/28/2013	10/31/2013		FY 2014 FO for Grounds Department.
FO-265989	10/28/2013	10/31/2013		FY 2014 FO for Grounds Department.
FO-265944	10/29/2013	10/31/2013		FY 2014 FO for Grounds Department.
FO-265945	10/29/2013	10/31/2013		FY 2014 FO for Grounds Department.
FO-265995	10/29/2013	10/31/2013	10/31/2013	FY 2014 FO for Grounds Department.
C-Materials			1	
FO-263545	10/2/2013	10/4/2013		Recycle Bin needs to be picked up and one dropped off outside of room# 339
C-Projects			2	
FO-265891	10/30/2013			pls buid a shelf near the sink in the boiler room
FO-265925	10/30/2013			pls wash and wax the engineers office
C-Repair			1	
FO-264862	10/18/2013			pls install 2 soap dispensers 1 in the
C-Sector 05			1	
FO-265156	10/23/2013	10/8/2013		The 1st & 2nd floor hallway are done.
C-Sector 08			1	
FO-264408	10/14/2013			pls wash and wax engineers office floor
Engineering			777	
Emergency			31	
E - Area 1 Engineer			6	
FO-263564	10/2/2013	10/2/2013		RM 1128 & 2126 PLS CK AGAIN WATER LKNG EMERGENCY R/R R1 1/2" sch 80 PVC R.O
FO-264636	10/16/2013	10/16/2013	10/16/2013	POWER BUMP.
FO-264637	10/16/2013	10/16/2013		POWER BUMP.
FO-264638	10/16/2013			POWER BUMP.
FO-264640	10/16/2013	10/16/2013		POWER BUMP.
FO-264642	10/16/2013	10/16/2013		POWER BUMP - GENERATOR IS RUNNING.
E - Area 2 Engineer			5	
FO-263737	10/4/2013	10/4/2013		GAS SMELL. 1ST FLOOR.
FO-264632	10/16/2013			POWER BUMP.
FO-264633	10/16/2013	10/16/2013		POWER BUMP.

WO	Recieved	Finished	Total	Request
FO-264634	10/16/2013	10/16/2013		POWER BUMP.
FO-264639	10/16/2013			POWER BUMP.
E - Auxiliary			6	
FO-264129	10/9/2013	10/9/2013		FAP FIRE ALARM SNDNG
FO-265081	10/22/2013	10/22/2013		ALARM GOING OFF ON THE 11TH, 12TH AND 10TH FLOORS. CALL FRONT DESK AT 7-
FO-265305	10/24/2013	10/24/2013		FIRE TROUBLE ALARM.
FO-265465	10/25/2013			FIRE TROUBLE ALARM.
FO-265724	10/29/2013			FIRE TROUBLE ALARM
FO-265920	10/30/2013			FAP SNDNG 15TH FLR
E - Command Center			2	
FO-264165	10/10/2013	10/15/2013		Boiler #2 won't start. Keeps tripping on FF.
FO-265348	10/24/2013	10/24/2013		RTU-2B NOT RUNNING
E - MedPharm			4	
FO-264132	10/9/2013			CALLED SCHINDLER ELEV CO FOR #3 ELEV ENTRAPMENT BSMT LEVEL
FO-265204	10/23/2013	10/23/2013		BURNING SMELL AND SOME AREAS ARE HOT (THINK THIS IS COMING FROM THE BUR
FO-265509	10/25/2013	10/25/2013		OZONE SMELL. 2ND FLOOR ROOMS 2122 AND 2120.
FO-265514	10/25/2013	10/25/2013		2ND FLR SMELL OF OZONE NEAR RM 2120
E - North			3	
FO-264831	10/18/2013	10/18/2013		SUMP PUMP ALARM SNDNG
FO-265354	10/24/2013	10/24/2013		CALLED SCHINDLER ELEV CO AGAIN PEOPLE STUCK IN ? ELEVATOR. 1ST FLRS
FO-265717	10/29/2013	10/29/2013		11:20 POWER BUMP, PLEASE CHECK ALL EQUIPMENT
E - Preventative Maintenance			1	
FO-264773	10/17/2013	10/18/2013		STE 3800 MAIN ENTRANCE DOOR UNABLE TO EXIT OR ENTER
E - South			3	
FO-264127	10/9/2013			RM 00016/BSMT MECH RM POWER FAIL ALARM W/EQUIP ACTIVATED
FO-264631	10/16/2013	10/16/2013		POWER BUMP.
FO-265726	10/29/2013	10/29/2013		PLASTIC BURNING SMELL. ROOMS 1664, 1662 AND 1654.
E - West			1	
FO-265408	10/24/2013	10/24/2013		POOL AREA SOMETHING IS CAUSING PEOPLE TO GET SICK BELIEVE SOMETHING TO
High			213	
E - Area 1 Engineer			16	
FO-263380	10/1/2013	10/1/2013		SUPPLY FAN # 1 & 2 IN ALARM
FO-263561	10/2/2013	10/2/2013		RM 200.07 LOW TEMP ALARM
FO-263668	10/3/2013	10/3/2013		RM 200.01 - 200.11 LOW TEMPS
FO-263676	10/3/2013			Make boiler plant ready to place in operation.
FO-263688	10/3/2013	10/3/2013		RM 21 PUBLIC SAFETY RECEIVING LOW TEMP/ HIGH TEMP FOR LAB 21
FO-263694	10/3/2013	10/3/2013		ENTIRE BLDG HAS NO HOT WTR
FO-263897	10/8/2013			LOW TEMP. ROOM 200.01
FO-264203	10/10/2013	10/10/2013		STRANGE CHEMICAL SMELL. ROOM 3341.
FO-264270	10/11/2013			Rooms 461,459 etc . We cannot house animals in these rooms due to loud noise caused by
FO-264272	10/11/2013			LOW TEMP. ROOM 411.
FO-264278	10/11/2013			Rooms 200.01 and 200.07 have positive air pressure to the hallway. Needs to be negative. 2
FO-264293	10/11/2013			HIGH TEMP ALARM ON AIR HANDLER UNIT #3.
FO-264521	10/15/2013			COLD ROOM IS WARM. ROOM 5113.
FO-264524	10/15/2013	10/15/2013		For the last couple of days a beeping sund is coming from the backside of the lab. Thank you
FO-264576	10/16/2013	10/17/2013		High humidity. Needs to be around 50%
FO-264603	10/16/2013			HIGH TEMP. COLD ROOM 5125.
E - Area 2 Engineer			3	

WO	Recieved	Finished	Total	Request
FO-263393	10/1/2013	10/1/2013		ROOF HATCH ALARM IS SOUNDING
FO-264313	10/11/2013	11/1/2013		GARAGE DOOR WON'T CLOSE ALL THE WAY. CLOSED ON ONE SIDE AND UP ON THE
FO-264471	10/15/2013	10/15/2013	10/15/2013	SMELL OF DIESEL FUMES. DISPATCH OFFICE.
E - Auxiliary			80	
H-41617	10/1/2013	10/2/2013	10/10/2013	The toilet in the back bathroom is overflowing.
H-41618	10/1/2013	10/18/2013	10/22/2013	toilet in the first bathroom is leaking. Water everywhere.
H-41601	10/1/2013		10/2/2013	Fuse blew for microwave
H-41627	10/2/2013	10/2/2013	10/10/2013	The pipe near the elevator lobby next to the Janitors closet is leaking
H-41645	10/2/2013		10/4/2013	The wash basin in the restroom/bathroom is leaking. Needs to be fixed asap.
H-41638	10/2/2013	10/10/2013	10/10/2013	Please fix the shower head leak in apartment 425. It is believed to be causing mold in room 3
H-41641	10/2/2013	10/4/2013	10/10/2013	Toilet in the first bathroom runs for a very long time after flushed.
H-41674	10/3/2013	10/4/2013	10/10/2013	Our kitchen and door's bulbs are out of work, could you please to help us fix them as soon as
H-41657	10/4/2013			In the middle of the kitchen area where they serve the salads.
H-41679	10/4/2013			Restroom wash basin is leaking needs to be fixed asap
H-41678	10/4/2013		10/8/2013	pop machine room, valve is leaking. Joe Hutting the Eng looked at it and a plumber is needed.
H-41684	10/4/2013			Ever since someone came to fix the A/C awhile ago, it sounds like a semi-truck idling. As it wa
H-41695	10/4/2013	10/9/2013	10/10/2013	Hi, I'm in 1017 and my garbage disposal was just fixed today and now it is leaking below the si
H-41686	10/5/2013		10/17/2013	my room air condition and heat system is broken please fix it
H-41697	10/5/2013	10/8/2013	10/10/2013	My shower drain got clogged and water started building up while taking a shower (The first bat
H-41699	10/6/2013	10/8/2013	10/10/2013	Hi,
H-41702	10/6/2013	10/9/2013	10/10/2013	The drain of the standing shower is not working which is causing the water to flood onto the flo
H-41706	10/7/2013	10/8/2013	10/10/2013	The first bathroom sink and the sink in the kitchen get clogged. Its a Guest Apartment.
H-41740	10/8/2013			Outlet on south wall next to networking plug and nightstand isn't working again. authenticate
H-41737	10/8/2013	10/9/2013	10/10/2013	-Kitchien sink gets clogged very fast
H-41735	10/8/2013	10/9/2013	10/10/2013	Toilet coninues to flush after it should stop.
H-41748	10/9/2013	10/9/2013	10/10/2013	The food waste disposer under the sink is leaking. Water is coming out!
H-41751	10/9/2013	10/9/2013	10/10/2013	Wall Socket behind microwave is broken. Tried to plug in microwave and it blew fuse and spar
H-41803	10/11/2013		10/22/2013	My bathroom ceiling was leaking this morning; it wasn't a continuous leak but there was enoug
H-41828	10/11/2013	10/14/2013	10/22/2013	URGENT Hi, I'm in 1017 and my "p-pipe" under my sink has completely rusted and I need an
FO-264304	10/11/2013	10/11/2013		FAP TROUBLE ALARM
H-41818	10/11/2013			Pipe under the bathroom sink is dripping ("U" shaped drain pipe). It's a leak, not condensation
H-41806	10/12/2013		10/14/2013	Power outlet on South wall [by window & internet port] isn't working again. This is the 3rd time
H-41817	10/13/2013		10/14/2013	Toilet won't flush, and bathroom is flooded.
H-41820	10/14/2013			Water dripping continiously from the tap at the bathroom sink
H-41845	10/14/2013		10/15/2013	Shower head is severely leaking.
H-41853	10/14/2013			-We have had an ongoing issue for a leaking sink drain, I've put in several work order requ
H-41856	10/14/2013		10/22/2013	The paint on the walls are stripping in the bathroom because the shower head is spraying onto
H-41863	10/15/2013		10/15/2013	Water keeps going into my toilet, and I'm worried that it might overflow. This is happening right
H-41868	10/15/2013			toilet in Subway is leaking.
H-41871	10/15/2013		10/15/2013	Some of the lights are not working. The fuse might have blown.
H-41887	10/15/2013		10/15/2013	Shower leaking excessively leaving the whole bathroom fogged with water dripping from the c
H-41888	10/16/2013			Possible short circuit with onecard reader and door latch. Residents were unable to swipe in s
H-41895	10/16/2013		10/17/2013	the ac is not working in this apt.
H-41899	10/16/2013		10/23/2013	Possible bad ballast in clinic hallway light. Bulb was replaced but light still does not work.
H-41907	10/17/2013	10/17/2013	10/22/2013	Plumbing problem in the kitchen-
H-41910	10/17/2013	10/17/2013	10/17/2013	Toilet is not functioning properly
H-41912	10/17/2013			Please repair the exhaust fan in the second bathroom.

WO	Recieved	Finished	Total	Request
FO-264744	10/17/2013			ALARM WENT OFF DUE TO AIR OFF IN BLDG
H-41918	10/18/2013			Hi, the tub in the kitchen always drops water, which is hot water. Thank you.
H-41927	10/18/2013	10/21/2013	10/22/2013	Hi, there is a fast water leaking under the kitchen sink while draining the water from the sink. T
H-41949	10/19/2013			The tube in the bathroom over the sink is dripping.
H-41944	10/21/2013		10/21/2013	URGENT Bathroom sink is leaking
H-41955	10/21/2013	10/21/2013	10/22/2013	Power is out in this apartment.
H-41971	10/21/2013			tub in bathroom is dripping
H-41999	10/22/2013	10/25/2013	10/30/2013	we fixed our sink for the time being , cause the water was too fast for us to not do anything. bu
H-41986	10/22/2013			power supply for the kitchen area is not there. This happened before as well. according to the
FO-265122	10/22/2013	10/22/2013		APT 702 OUTSIDE ENTRANCE DOOR HANDLE ISN'T TURNING
H-41989	10/22/2013			Heat in 2 examination rooms in health clinic is not working. Please investigate ASAP.
H-42004	10/22/2013		10/26/2013	Under the kitchen sink is leaking. An earlier request was put in and someone changed the pla
H-42005	10/22/2013			The apartment is cold and air is blowing through the vent.
H-42001	10/23/2013	10/23/2013	10/30/2013	Bathroom 2 toilet tank is leaking. Engineer from Public Safety came and cut off the water.
H-42007	10/23/2013		10/23/2013	When the heater is turned on the fan makes a bad noise - like it can't turn. Please fix it! Thank
H-42003	10/23/2013			Room 916 has a leak and hole in their ceiling. However, we do not have any paper document
H-42017	10/23/2013			bathroom sink make a very loud noise when we use water
H-42020	10/24/2013			Apartment 509 does not have any hot water in both bathroom and kitchen.
H-42026	10/24/2013	10/24/2013	10/30/2013	Heater is not working in room 901. Jimmy was unable to fix it.
H-42035	10/24/2013			The heat/air conditions in the room is not working.authenticated user: Christopher Allen - ei6
FO-265414	10/24/2013	10/24/2013		fire trouble alarm
H-42038	10/24/2013			Heat doesn't work. Vent is blowing out cool air.
H-42039	10/24/2013			Shower has very low water pressure.
H-42034	10/25/2013	10/25/2013	10/30/2013	The tap for the bathtub leaks continuously.
H-42052	10/25/2013	10/28/2013	10/30/2013	Heat is not working in the apartment.
H-42054	10/26/2013	10/25/2013	10/30/2013	Heating Not Working
H-42073	10/26/2013			Resident says something wrong with Heater in room. Not not enough.
H-42074	10/27/2013			They put in a work order 2 weeks ago but no one came to fix the problem. Their toilet doesn't f
H-42078	10/27/2013			The tub above the bathtub in the bathroom is dripping. Thank you.
H-42097	10/29/2013			There is no hot water in the bathroom sink or shower. Kitchen sink is fine. Please resolve ASA
H-42126	10/29/2013			Problem with sink in kitchen and flushing in rest room-1. authenticated user: Niraj Shrestha -
H-42111	10/29/2013		10/30/2013	Automatic hand sinks in the kitchen area do not work. They will not turn on when hand motion
H-42130	10/29/2013			toilet in bathroom #1 is making constant noise. It sounds like the water is constantly running .
H-42113	10/30/2013		10/30/2013	Light switch is broken!
H-42131	10/30/2013			Shower area got blocked. Water is getting stagnated here. No flow of hot water.authenticate
H-42139	10/30/2013			Thermostat isn't working neither for the air or heat red light keeps appearing. authenticated
H-42145	10/30/2013			The pipe connected to the bathroom sink (under the sink) is leaking.authenticated user: Sud
E - Command Center			14	
FO-262849	10/1/2013	10/3/2013		BOILER WON'T START.
FO-263963	10/8/2013		10/16/2013	RM 1204 TOO HOT, HEATING AND COOLING IN THIS RM NOT WORKING. PLEASE CHE
FO-264106	10/9/2013		10/14/2013	In room 5465, replace non-indicating temperature sensor with indicating, controllable thermost
FO-264137	10/9/2013	10/11/2013		refrigeration crew,please reconnect #2 trash pump motor to pump.priority high.
FO-264163	10/10/2013	10/11/2013		Siemens Controls
FO-264625	10/16/2013			Trade: Controls Priority: High
FO-264881	10/20/2013			Repair Siemens control serving animal quarters supply fan humidifier.
FO-265072	10/22/2013			EMERGENCY/REF CREW
FO-265299	10/24/2013	10/29/2013		AHU #1 & #2 TEMP CONTROL NOT WORKING

WO	Recieved	Finished	Total	Request
FO-265676	10/28/2013			1ST FL TOO COLD
FO-265708	10/29/2013			TOO HOT. ROOM 40.
FO-265729	10/29/2013	10/30/2013		Control Engineer; Control Engineer High
FO-265833	10/30/2013	10/30/2013		Boiler #1 needs new mod motor for the feedwater valve.
FO-265839	10/30/2013			Refrigerant Monitor alarm going off.
E - MedPharm			32	
FO-263824	10/7/2013			RM 200.07 200.08 LOW TEMP
FO-263825	10/7/2013			RM 8337 WALKIM COLD RM HI TEMP ALARM
FO-263828	10/7/2013			RM 1358 TOO COLD, MEETING IN RM
FO-263837	10/7/2013	10/7/2013		1ST FL NEAR RM 103 ALARM SOUNDING
FO-263844	10/7/2013			LAB 200.01 LOW TEMP
FO-264170	10/10/2013			RM 200.02/DLAR HAS LOW TEMP
FO-264226	10/10/2013	10/10/2013		RM 103 AN ALARM (GENERATOR ALARM)
FO-264425	10/14/2013	10/14/2013		RM 200.07 LOW TEMP
FO-264426	10/14/2013	10/14/2013		RM 200.00 LOW HUMIDITY
FO-264827	10/18/2013			BURNING SMELL IN STAIRWELL BETWEEN 1ST FL AND BASEMENT
FO-264837	10/18/2013			RM 0136 FREEZER #2 HAS HI TEMP ALARM
FO-264850	10/18/2013	10/18/2013		AN ALARM IS SNDNG IN THE CAFE
FO-264854	10/18/2013	10/18/2013		RM 0122/DLAR LOW TEMP
FO-264928	10/21/2013			RM 00136 FREEZER #15 HAS HI TEMP ALARM
FO-264929	10/21/2013	10/21/2013		RM 5565 HAS LOW TEMP ALARM
FO-264946	10/21/2013	10/21/2013		ENTIRE 200 SUITES HAVE HIGH TEMPS AND HIGH HUMIDITY, 200.08 & 200.07 HAVE O
FO-265021	10/22/2013			RM 00136 FREEZER #15 HAS HI TEMP ALARM (AGAIN)
FO-265177	10/23/2013			LOW HUMIDITIES. 200 AND 400 SUITES.
FO-265194	10/23/2013			JAFAR LECTURE HALL TOO COLD, CLASS STARTS AT 10
FO-265200	10/23/2013			LOW TEMP. ROOM 200.08.
FO-265210	10/23/2013			LOW HUMIDITY. ROOM 5465.
FO-265307	10/24/2013	10/24/2013		9TH FLR HALLWAY OUTSIDE OF RM 9211 A CHEMICAL SUBSTANCE IS LKNG THRU CL
FO-265380	10/24/2013	10/24/2013		LOW TEMP. ALARM. ROOM 468.
FO-265415	10/24/2013			SHIFFMAN LIBRARY, STAPLETON RM ACROSS FROM RM 109 TOO COLD
FO-265437	10/25/2013	10/25/2013		RM 8337 WALK IN COLD RM BOX LOW TEMP ALARM
FO-265600	10/28/2013			low humidity
FO-265601	10/28/2013			low humidity
FO-265602	10/28/2013			low humidity
FO-265605	10/28/2013			low humidity
FO-265656	10/28/2013			RM 469 HAS HI TEMP
FO-265705	10/29/2013			LAB 3341 FUME HOOD LEAKING, WATER ON FL THIS IS THE THIRD LEAK WITH THIS F
FO-265841	10/30/2013	10/30/2013		RM 2206/FREEZER RM IS EXTREMELY HOT CAUSING FREEZERS TO FAIL
E - North			5	
FO-263895	10/8/2013	10/8/2013		INNER HANDICAP DOOR ISN'T OPENNING ALL THE WAY (need door #)
FO-264454	10/15/2013	10/16/2013		Mark Bobick:
FO-264976	10/21/2013	10/21/2013		BLDG'S AIR PRESSURE TOO POSITIVE CAUSING DOORS TO BLOW OPEN & CAUSING
FO-265444	10/25/2013			RM 138 HAS A VERY BAD BURNT RUBBER SMELL (believe its comng from Mech Rm in Bs
FO-265718	10/29/2013	10/30/2013		POWER BUMP. ALARM SOUNDING. PLEASE CHECK YOUR EQUIPMENT.
E - Northeast			4	
FO-263838	10/7/2013	10/7/2013		ROOM HAS STEAM ALL OVER WINDOWS, PLEASE CHECK TEMP
FO-264729	10/17/2013	10/17/2013		DOOR ALARM SOUNDING AT MAIN ENTRANCE
FO-265061	10/22/2013	10/22/2013	10/22/2013	LOBBY HAS AN ALARM RINGING SOMEWHERE?

WO	Recieved	Finished	Total	Request
FO-265910	10/30/2013	10/30/2013		1ST FLR LUNCH RM 1S EXTREMELY HOT
E - Preventative Maintenance			39	
FO-263418	10/1/2013	10/2/2013		FIRE TROUBLE ALARM
FO-263593	10/2/2013	10/3/2013		ENTIRE BLDGS' SUPPLY OF PROCESS CHILLED WATER IS COMING OUT RUSTY/MUD
FO-263595	10/2/2013	10/3/2013		RM 3272 CEILING LEAK
FO-263596	10/2/2013	10/2/2013		FIRE TROUBLE ALARM
FO-263598	10/2/2013	10/3/2013		WESTSIDE ENTRANCE DOOR LOCKED
FO-263701	10/3/2013	10/4/2013		RM 6312 HIGH TEMP ALARM
FO-263711	10/3/2013	10/4/2013		RM 27.5 HIGH TEMP
FO-263781	10/4/2013	10/5/2013		FAN ALARM 1& 2
FO-263783	10/4/2013	10/5/2013		1ST FL WOODCOCK WING TOO HOT, EVENT GOING ON
FO-263784	10/4/2013	10/5/2013		RM 2339 DOOR LOCK NOT WORKING, SECURITY ISSUE
FO-263868	10/7/2013	10/8/2013		BSMNT FL DRAIN BACKING UP
FO-263873	10/7/2013	10/8/2013		Work room in the Dean's Suite in the College of Engineering has water leaking from the ceilin
FO-263876	10/7/2013	10/8/2013		RM A TOO HOT, EVENT GOING ON
FO-263961	10/8/2013	10/9/2013		AHU #3 HI TEMP ALARM
FO-263962	10/8/2013	10/9/2013		SUPPLY FAN 1 & 2 ALARM SOUNDING
FO-263963	10/8/2013		10/16/2013	RM 1204 TOO HOT, HEATING AND COOLING IN THIS RM NOT WORKING. PLEASE CHE
FO-263964	10/8/2013	10/9/2013		POWER FAILURE ALARM
FO-264236	10/10/2013	10/10/2013		AHU-3 HIGH TEMP ALARM
FO-264527	10/15/2013	10/15/2013		RM 461 SMELLS GAS
FO-264655	10/16/2013	10/17/2013		ALARM PANEL ALARMING
FO-264658	10/16/2013	10/17/2013		RM 3258 SMELLS LIKE FIRE
FO-264768	10/17/2013	10/18/2013		RM 101/AUD IS EXTREMELY HOT
FO-265121	10/22/2013	10/23/2013		RM 6312 WALK IN COLD RM BOX HI TEMP ALARM
FO-265123	10/22/2013	10/23/2013		RM 0154/MECH RM INSIDE RM SOUNDS LIKE A STM LEAK
FO-265127	10/22/2013			BOX AT FRONT DESK, ALARM SOUNDING COMMUNICATION FAILED
FO-265278	10/23/2013	10/24/2013		LOW WATER PRESSURE - 13TH FLOOR.
FO-265281	10/23/2013	10/24/2013		TOILET CONINOUSLY FLUSHING. 9TH FLOOR LADIES RESTROOM. ACROSS FROM R
FO-265283	10/23/2013	10/24/2013		SINK PLUGGED. COLD KITCHEN SINK.
FO-265415	10/24/2013			SHIFFMAN LIBRARY, STAPLETON RM ACROSS FROM RM 109 TOO COLD
FO-265416	10/24/2013	10/24/2013		SUPPLY FAN 1& 2 FAN ALARM BOUNCING
FO-265417	10/24/2013	10/24/2013		RM 8337 LOW TEMP ALARM
FO-265534	10/25/2013			RM 4169 WALK IN COLD RM BOX TEMP ISN'T COOLING
FO-265542	10/25/2013	10/26/2013		FAUCET CONTINUOUSLY RUNNING. 3RD FLOOR MEN'S RESTROOM.
FO-265543	10/25/2013	10/26/2013		CEILING LEAK. 1ST FLOOR LOBBY NEAR EXIT/ENTRANCE DOORS AND ELEVATOR.
FO-265668	10/28/2013	10/29/2013		212&214 NO POWER TO OUTLETS
FO-265676	10/28/2013			1ST FL TOO COLD
FO-265770	10/29/2013			FAUCET WATER IS VERY HOT AND MAKING BEEPING SOUND. 3RD FLOOR MEN'S RE
FO-265931	10/30/2013	10/31/2013		RM 279&277 FUSE BLOWN
FO-265933	10/30/2013	10/31/2013		HIGH TEMP. ALARM. AIR HANDLER UNIT #3.
E - South			15	
FO-263835	10/7/2013	10/7/2013		LAB 270 NEED HELP CONTROLLING THERMOSTAT SOME AREA'S ARE TOO COLD AND
FO-264125	10/9/2013			BSMNT LEADING TO PRENTIS DOOR ALARM SOUNDING
FO-264231	10/10/2013			ELEV ON RIGHT HAND SIDE STUCK ABOVE FLR LEVEL W/DOORS OPEN
FO-264271	10/11/2013	10/15/2013		LAB 50 TOO HOT, NO AIR
FO-264626	10/16/2013	10/16/2013		LAB 270 TOO COLD
FO-264844	10/18/2013	10/18/2013		4TH FL COLD RM, TOO WARM

WO	Recieved	Finished	Total	Request
FO-264969	10/21/2013	10/21/2013		FAP TROUBLE ALARM (notifying in case anything to do w/wtr & gas shutdown
FO-265233	10/23/2013	10/23/2013		Low humidity in entire animal quarters... Rooms 019-026.22. Needs to be 30% minimally. Cu
FO-265404	10/24/2013	10/25/2013		DEIONIZED WATER TAP SHOULD BE REVERSED. ROOM 0249.
FO-265507	10/25/2013	10/25/2013		AIR FLOW PROBLEMS WITH FUME HOODS IN ROOM 310.
FO-265534	10/25/2013			RM 4169 WALK IN COLD RM BOX TEMP ISN'T COOLING
FO-265632	10/28/2013	10/28/2013		LAB 170 LOSS AIR FLOW TO FUME HOODS ALL FUME HOODS SOUTH HALF OF BLDG
FO-265634	10/28/2013	10/28/2013		AIR FLOW PROBLEMS IN FUME HOODS. ROOMS.
FO-265723	10/29/2013	10/29/2013		ALARM SOUNDING. LOBBY (POSSIBLE POWER BUMP)
FO-265851	10/30/2013	10/30/2013		WATER COMING IN THRU WINDOW. ROOM 103. PLEASE INVESTIGATE.
E - Southeast			4	
FO-263941	10/8/2013			11TH FL STAIRWELL ALARM SOUNDING
FO-265232	10/23/2013			STRONG SEWAR SMELL. 1ST FLOOR.
FO-265713	10/29/2013			SEWAR SMELL - 1ST FLOOR.
FO-265893	10/30/2013			DOOR ALARM SOUNDING. 2ND FLOOR.
E - West			1	
FO-265331	10/24/2013			NO HEAT IN BLDG
Medium			333	
E - Area 1 Engineer			8	
FO-263371	10/1/2013	10/1/2013		TOO HOT. ROOMS 6225 & 6226.
FO-263414	10/1/2013	10/4/2013		Room 2105 - Chemical fume hood has low lfm - curently reading 23 should read 80-120. Plea
FO-263557	10/2/2013			TOO WARM. ROOM 560.
FO-263567	10/2/2013	10/2/2013		RM 103 TOO HOT
FO-263677	10/3/2013	10/3/2013		RM 5150 IS TOO COLD
FO-263777	10/4/2013	10/4/2013		RM 169 TOO COLD
FO-264218	10/10/2013	10/10/2013		TOO HOT. ROOM 0309.
FO-264672	10/16/2013	10/17/2013		group study room #130 is EXTREMELY COLD we reported this about 2 weeks ago. Can som
E - Area 2 Engineer			14	
FO-263379	10/1/2013	10/1/2013		RM 2079 IS EXTREMELY COLD
FO-263378	10/1/2013	10/8/2013		325.1 - 325.3 TOO COLD
FO-263383	10/1/2013	10/1/2013		1ST FL TOO COLD
FO-263425	10/1/2013	10/2/2013		BLDG TOO COLD
FO-263582	10/2/2013	10/2/2013		RM 3101 TOO COLD
FO-263741	10/4/2013			There is a loud ticking noise coming from the ceiling in my office.
FO-263910	10/8/2013	10/8/2013		TOO COLD. ROOM 7502.
FO-264193	10/10/2013	11/1/2013		Purdy Library 1st Floor Room/Suite 134
FO-264209	10/10/2013	10/10/2013		TOO HOT. ROOM 316.
FO-264266	10/11/2013	10/11/2013		Suite 134 is very cold. Please adjust temp.
FO-264470	10/15/2013	10/15/2013		TOO HOT. ROOM 1550.
FO-264608	10/16/2013	10/16/2013		Cold call via twitter from student-
FO-264616	10/16/2013	10/16/2013		TOO HOT. ROOM 2212.
FO-264648	10/16/2013	10/17/2013		TOO COLD. RED LIGHT ON HEATER. ROOM 427.
E - Auxiliary			65	
H-41587	10/1/2013			thermostat broken in the study lounge.
H-41622	10/1/2013	10/2/2013	10/10/2013	Please come fix our broken garbage disposal (second time) Sink will not drain.
H-41631	10/2/2013	10/2/2013	10/10/2013	The fan in the trash room is not working properly. Also the switch that operates it is damaged.
H-41647	10/3/2013		10/4/2013	Breauna informed me that her toilet isn't flushing properly.
H-41649	10/3/2013	10/4/2013	10/10/2013	Please replace the ballast on the light in the main stairwell on the 8th floor.
H-41671	10/3/2013	10/4/2013	10/10/2013	Hi, I'm in 1017 and my garbage disposal has stopped working, please come check it out. Than

WO	Recieved	Finished	Total	Request
H-41672	10/3/2013			Bathroom 2 sink clogged.
H-41673	10/3/2013	10/4/2013	10/10/2013	Kitchen Sink disposal unit not working.
H-41659	10/3/2013		10/4/2013	Air conditioning is not operating correctly. Fan is still working however cool air is not being pro
H-41668	10/4/2013		10/4/2013	The toilet in this guest room is not working
H-41676	10/4/2013	10/4/2013	10/10/2013	TV socket does not work.
H-41661	10/4/2013		10/4/2013	fix vent in room 320 Ghafari Hall
H-41677	10/4/2013	10/4/2013	10/10/2013	The shower head in the second washroom is acting up. The water flow is very slow and somet
H-41696	10/5/2013	10/8/2013	10/10/2013	Clogged first bathroom sink.
H-41688	10/5/2013		10/17/2013	The thermostat is malfunctioning. We have tried changing every setting but the room temperat
H-41689	10/5/2013		10/24/2013	Air Conditioner in room 1027 is not working. Has been this way for over a week.
H-41690	10/5/2013		10/22/2013	our air conditioning is broken, the red light is on, which means it's broken, it's 82 degrees in ou
H-41691	10/6/2013		10/8/2013	Air conditioner is broken and room doesn't get cool
H-41698	10/6/2013	10/9/2013	10/10/2013	Kitchen- Grinder problem authenticated user: Sagar Shinde - fk2179
H-41703	10/6/2013			AC is broken. Started making a lot of noise then just stopped running altogether. Apartment is
H-41724	10/7/2013	10/9/2013	10/10/2013	There is a toilet in the back of the apartment that cannot flush.
H-41725	10/7/2013	10/9/2013	10/10/2013	The toilet in the first bathroom is stuck. And the one who repaired it last week put a sheet "Do
H-41727	10/8/2013	10/9/2013	10/10/2013	Grinder not working. Drainage sweep out issue (Urgent Basis)
H-41753	10/9/2013			In the hallway between 1110 and 1108 there is a light with a broken ballast.
H-41771	10/9/2013	10/10/2013	10/10/2013	Outlet on the left side of the room next to the couch is broken. There is a metal prong from a c
H-41804	10/12/2013		10/18/2013	A/C is broken for the third time this semester. I keep setting the thermostat lower and lower on
H-41844	10/12/2013		10/14/2013	Garbage disposal is not working
H-41865	10/14/2013		10/15/2013	Shower is leaking excessively and has been for the past few days leaving the floor and rugs s
H-41854	10/14/2013		10/22/2013	Air conditioning not working
H-41847	10/14/2013			Please repair the fan in the bathroom of room 525
H-41855	10/14/2013		10/23/2013	The air condition in my room has not been working for several weeks now. A building engineer
H-41866	10/15/2013		10/15/2013	Power went out in the residents kitchen
H-41852	10/15/2013	10/15/2013	10/22/2013	Many of the living room and kitchen outlets are not working.
H-41857	10/15/2013		10/17/2013	The thermostat is broken.
H-41881	10/15/2013	10/16/2013	10/22/2013	Garbage disposal is broken
H-41904	10/16/2013	10/17/2013	10/22/2013	The sink in the kitchen has water backed up in it. And the garbage disposal doesn't work.
H-41905	10/16/2013	10/17/2013	10/22/2013	Toilet won't stop flushing.
H-41906	10/17/2013	10/17/2013	10/22/2013	The sink is blocking and the water cannot flow down and the garbage disposal dosen't work.PI
H-41908	10/17/2013			Toilet in first bathroom is still not working. Maintenance has previously worked on this issue fo
H-41911	10/17/2013			repair leak to sink in kitchen area of gold n greens
FO-264745	10/17/2013	10/17/2013		(WDET)4600 CASS NO AIR
H-41936	10/19/2013		10/21/2013	thermostat, red check light is on, and heat won't go up past 70 degrees
H-41994	10/20/2013			The toilet sprays when it flushes making a small mess when
FO-265068	10/22/2013	10/22/2013		ALL FLRS S.W. SIDE OF BLDG
H-41984	10/22/2013		10/22/2013	The garbage disposal is dispelling water when turned on.
H-41997	10/22/2013			thermostat only blows out cold air. no heat.
H-42006	10/23/2013		10/23/2013	The garbage disposal makes an awful noise when it is turned on - like something is stuck in th
H-42015	10/24/2013			Thermostat is broken. Only blows cold air.
H-42032	10/24/2013	10/25/2013	10/30/2013	Plumbing problems with the toilet
H-42036	10/25/2013	10/25/2013	10/30/2013	Hi, I'm in 1017 and the sink drain blocker is stuck in an almost shut position; please send som
H-42042	10/25/2013			Please write a work order for engineers to investigate copper line with spigot in 1st floor janitor
H-42061	10/26/2013			The heater for the room is not working. It is blowing out cold air making the temperature drop
H-42062	10/26/2013			The thermostat is broken, heat isn't working.authenticated user: Devan Simmons - ev6163r

WO	Recieved	Finished	Total	Request
H-42065	10/27/2013	10/28/2013	10/30/2013	kitchen sink water tap loose fitting
H-42079	10/28/2013			1. The heater in the living room does not have a regulatory valve.
H-42075	10/28/2013			Cap of the faucet in the bathroom sink has broken off and fell down the drain. Now the sink is
H-42090	10/28/2013			The heating is not working, no red light is present. Just the fan works, but not the heat.auth
H-42091	10/28/2013		10/30/2013	The red light at the bottom of our thermostat keeps coming on, and we cant turn the heat up p
H-42119	10/29/2013			Our thermostat stick thing broke on the side where you turn it on or off, and we need it fixed. Y
H-42128	10/29/2013			Socket Cover in kitchen has come off (near the refrigerator). Request you to fix it.authenticat
H-42112	10/29/2013			Ceiling tiles in the dish room need to be repaired.authenticated user: Philip Trela - eu7977r
H-42109	10/29/2013			Grinder in my kitchen is not working.
H-42123	10/30/2013			Heat is not opererating correctly
H-42114	10/30/2013			Please write a work order for Engineers to install light guards on the fixtures in the janitors clo
H-42140	10/30/2013			chicken sink was stuck .pleas come fix it ASAPauthenticated user: Yue Xi - fc3128request
E - Command Center			26	
FO-263381	10/1/2013			Investigate and correct cause of #2 lab air compressor not working properly.
FO-263687	10/3/2013	10/11/2013		REFRIGERATION CREW PLEASE CHECK
FO-263966	10/9/2013			AC/Refrig. Medium Priority. Work due to FO-263160. Repair AC-8 unit-due to unit not cooling
FO-264674	10/17/2013	10/18/2013		Refrig crew/control crew
FO-264879	10/19/2013			Repair D Boiler. No spark ignition.
FO-264949	10/21/2013			Boiler will not go thru purge for light off
FO-264974	10/21/2013	10/26/2013		Need Siemens graphics installed on Purdy Computer
FO-265041	10/22/2013			Please install actuator on pool fill safety butterfly valve . See John Towle for actuator . Valve b
FO-265129	10/22/2013			RM 110 FUME HOOD 14& 16 LOW SPACE VELOCITY
FO-265212	10/23/2013			HEATER HAS GAS SMELL. RECEIVING DECK AREA.
FO-265258	10/23/2013	10/24/2013		Request Honeywell to calibrate pilot positioner on AC-1 at Scott Hall.
FO-265275	10/23/2013			VERY COLD. ROOM 2033.
FO-265418	10/24/2013			RM 320 HOOD NOT WORKING
FO-265513	10/25/2013			RM 3210 IS TOO COLD needs work on VAV box.
FO-265520	10/25/2013	10/29/2013		repair replace the float switch for the make up tank to feed the boiler feed pumps does not aut
FO-265533	10/25/2013			3RD FLR WOODCOCK WING STACK AREA IS TOO HOT
FO-265558	10/25/2013			Control crew
FO-265563	10/28/2013	10/30/2013		CONTROLS CREW,
FO-265564	10/28/2013	10/30/2013		CONTROLS CREW,
FO-265630	10/28/2013			Too cold in this room - air flow stronger in ths room than others.
FO-265631	10/28/2013			Too cold in this room - air flow stronger in this room than others.
FO-265740	10/29/2013			Boiler #2; down, will not re-start. Boiler #1 is barely holding plant.
FO-265773	10/29/2013			Move thermostat from Athletic Directors office to outer office. See Bob Ostrowski or engineer
FO-265815	10/30/2013			CONTROLS CREW,
FO-265818	10/30/2013	10/30/2013		Boiler # 1 has repeataly failed overnight due to ALWCO problems. Investigate/resolve
FO-265922	10/30/2013			The chief of police office on the 2nd flooor north west corner is below
E - MedPharm			34	
FO-263846	10/7/2013			9TH FLR NO HOT WTR
FO-263995	10/9/2013			Close boiler
FO-263996	10/9/2013			Close boiler
FO-264099	10/9/2013	10/9/2013		RM 3609 TOO COLD, AIR BLOWING
FO-264227	10/10/2013			Engineer (J Keys) Med. Priority
FO-264481	10/15/2013			ENGINEER (J.KEYS) MED PRIORITY
FO-264715	10/17/2013			Lab Room 3329 temperature is too hot.
FO-264760	10/17/2013			RM 4263 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-264823	10/18/2013			BLUE LECTURE HALL TOO COLD
FO-264826	10/18/2013	10/18/2013		RM 154 TOO COLD
FO-264841	10/18/2013	10/19/2013		BLDG TOO COLD, NEED BOILER TURNED ON
FO-264843	10/18/2013			RM 1200 TOO HOT
FO-264887	10/21/2013			Light fixture hanging , room 9364 Finished 10/22/2013LT
FO-264920	10/21/2013	10/21/2013		RM 525/ANATOMY IS HOT
FO-264922	10/21/2013	10/21/2013		RM 527/ANATOMY IS HOT
FO-264923	10/21/2013	10/21/2013		RM 521/ANATOMY IS HOT
FO-264924	10/21/2013	10/21/2013		RM 523/ANATOMY IS HOT
FO-264932	10/21/2013	10/21/2013		Terrible smell coming from the Mechanical Room 139.
FO-264975	10/21/2013			RM 5150 IS TOO COLD
FO-265052	10/22/2013	10/22/2013		RM 324 TOO COLD
FO-265071	10/22/2013	10/22/2013		RM 9374 IS TOO COLD
FO-265172	10/23/2013	10/23/2013		Install 0-30 psig pressure gauge on condensate system
FO-265205	10/23/2013	10/23/2013		TOO COLD. ROOMS 5324 AND 5344.
FO-265215	10/23/2013	10/23/2013		RM 2361 IS TOO COLD
FO-265303	10/24/2013			Main lobby: security alarm on stairwell door activates occasionally with no cause.
FO-265314	10/24/2013			RM 102.33.1 IS TOO COLD
FO-265388	10/24/2013	10/24/2013		RM 043 HAS NO HEAT/HTR ISN'T WRKNG
FO-265391	10/24/2013			RM 3225.7 IS TOO COLD/ACU IS STILL ON
FO-265405	10/24/2013			RM 5565/DLAR IS TOO COLD
FO-265582	10/28/2013	10/28/2013		TOO COLD. ROOMS 9316 AND 9312.
FO-265707	10/29/2013			TOO HOT. ROOM 103.
FO-265709	10/29/2013	10/29/2013		TOO COLD. ROOM 1116.
FO-265840	10/30/2013			TOO HOT. ROOM 7256.
FO-265852	10/30/2013			RM 103 IS EXTREMELY HOT
E - North			46	
FO-263802	10/7/2013	11/1/2013		RM 2074 IS TOO COLD
FO-263839	10/7/2013	10/8/2013		Rooms 030 and 028 cold temperature near 70 degrees and thermostats pushed all the way up
FO-263908	10/8/2013	10/8/2013		OUTSIDE RM 2079, HALLWAY CEILING TILE WAS REMOVED TO TURN FAN OFF AND L
FO-264103	10/9/2013	10/9/2013		RM 3333 TOO HOT
FO-264198	10/10/2013	10/15/2013		RM 147 TOO HOT
FO-264299	10/11/2013	10/11/2013		RM 3333 IS TOO HOT
FO-264365	10/14/2013	10/15/2013		Purdy Library 2nd Floor Office Suite Room 231
FO-264480	10/15/2013	10/15/2013		RM 150 TOO COLD
FO-264488	10/15/2013	10/15/2013		LOWER LEVEL LM TOO COLD
FO-264622	10/16/2013	10/16/2013		2ND REQUEST Purdy Library 2nd Floor Office Suite Room 231
FO-264721	10/17/2013	10/17/2013		RM 150 TOO COLD
FO-264794	10/18/2013	10/22/2013		Bulbs for presidents apartment
FO-264800	10/18/2013	10/18/2013		Please turn the air conditioning off and turn on the heat.
FO-264951	10/21/2013			BLDG TOO COLD
FO-264980	10/21/2013			STE 106 IS EXTREMELY COLD
FO-265030	10/22/2013	10/25/2013		RM 3501 IS TOO COLD
FO-265033	10/22/2013	10/25/2013		RM 3502 IS TOO COLD
FO-265035	10/22/2013	10/25/2013		RM 3503 IS TOO COLD
FO-265037	10/22/2013	10/25/2013		RM 3504 IS TOO COLD
FO-265039	10/22/2013	10/25/2013		RM 3504 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-265050	10/22/2013	10/22/2013		3RD FL NO HEAT
FO-265104	10/22/2013	10/22/2013		1ST FL BACK OF LIBRARY TOO COLD
FO-265224	10/23/2013	10/23/2013		RM 300 TOO HOT
FO-265259	10/23/2013	10/23/2013		RM 293 IS TOO COLD
FO-265261	10/23/2013	10/23/2013		RM 2242 IS TOO COLD
FO-265265	10/23/2013	10/24/2013		RM 325.1 IS TOO COLD AGAIN
FO-265320	10/24/2013	10/24/2013		The temperature was 58 degrees this morning when the staff came in. Please adjust the tem
FO-265393	10/24/2013	10/24/2013		RM 223 IS TOO COLD
FO-265394	10/24/2013	10/24/2013		RM 225 IS TOO COLD
FO-265395	10/24/2013	10/24/2013		RM 227 IS TOO COLD
FO-265407	10/24/2013	10/24/2013		TOO WARM. (LOUNGE)
FO-265448	10/25/2013	10/25/2013		TOO COLD. ROOMS 3501 THROUGH 3505.
FO-265483	10/25/2013			RM 325 IS TOO COLD
FO-265485	10/25/2013			RM 327 IS TOO COLD (for access go thru 325)
FO-265489	10/25/2013			RM 329 IS TOO COLD (for access go thru 325)
FO-265492	10/25/2013			RM 329 IS TOO COLD (for access go thru 325)
FO-265494	10/25/2013			RM 331 IS TOO COLD (for access go thru 325)
FO-265498	10/25/2013			RM 333 IS TOO COLD (for access go thru 325)
FO-265518	10/25/2013			3RD FLR WOODCOCK WING STACK AREA IS TOO HOT
FO-265620	10/28/2013	10/28/2013		RM 3305 TOO COLD
FO-265622	10/28/2013	10/28/2013		RM 3401-3505 TOO COLD
FO-265638	10/28/2013			3RD FLR/WOODCOCK WING IS TOO HOT
FO-265715	10/29/2013	10/29/2013		TOO HOT. ROM 394.
FO-265743	10/29/2013	10/29/2013		Staff complaining it's too warm in room 134. Please lower temp.
FO-265832	10/30/2013			RM 441.2 IS TOO COLD
FO-265904	10/30/2013			RM 394 TOO HOT, PPL ARE GETTING SICK ITS SO HOT
E - Northeast			27	
FO-263841	10/7/2013	10/7/2013		BLDG TOO COLD, PLEASE TURN AIR OFF
FO-263896	10/8/2013	10/8/2013		ENTIRE 2ND FLR IS EXTREMELY COLD
FO-264277	10/11/2013			ENTIRE BLDG IS TOO COLD
FO-264378	10/14/2013	10/14/2013		2ND FL DIRECTORS AREA TOO WARM
FO-264487	10/15/2013	10/15/2013		Noise coming from above office. Send engineer.
FO-264508	10/15/2013	10/15/2013	10/15/2013	RM 109 1ST FL TOO HOT
FO-264628	10/16/2013	10/17/2013		SERVICE CTR RM TOO COLD
FO-264727	10/17/2013			TOO COLD. BUILDING.
FO-264751	10/17/2013			RM 239 IS EXTREMELY COLD
FO-264752	10/17/2013			ENTIRE BLDG IS COLD
FO-264755	10/17/2013			1ST FLR IS TOO COLD
FO-264798	10/18/2013			RM 239 IS EXTREMELY COLD AGAIN
FO-264802	10/18/2013			ENTIRE BLDG IS COLD
FO-264977	10/21/2013			1ST FLR IS EXTREMELY COLD
FO-265060	10/22/2013	10/22/2013	10/22/2013	RM 120 TOO COLD
FO-265064	10/22/2013	10/22/2013		BDLG TOO COLD, NO HEAT
FO-265153	10/23/2013			Please attach new chemical pumps to a shelf (board) and attach board to wall. Please see Bo
FO-265154	10/23/2013			Please attach new chemical pumps to a shelf (board) and attach board to wall. Please see Bo
FO-265212	10/23/2013			HEATER HAS GAS SMELL. RECEIVING DECK AREA.
FO-265316	10/24/2013	10/24/2013	10/24/2013	RM 313 IS TOO COLD

WO	Recieved	Finished	Total	Request
FO-265340	10/24/2013			TOO COLD. ROOM 240.
FO-265385	10/24/2013	10/25/2013		1ST FL TOO COLD
FO-265462	10/25/2013	10/25/2013		TOO COLD. ROOM 101.
FO-265471	10/25/2013	10/25/2013		TOO COLD. ROOMS 257 AND 255.
FO-265588	10/28/2013	10/29/2013		2ND FL OUTSIDE ON MIKE PINES OFFICE TOO HOT.
FO-265699	10/29/2013			TOO COLD. BUILDING.
FO-265837	10/30/2013			BLDG TOO COLD, ESPECIALLY NEAR RM 252
E - Preventative Maintenance			38	
FO-263416	10/1/2013	10/2/2013		Room is extremely cold.
FO-263421	10/1/2013	10/2/2013		280 SENSOR NOT WORKING ON LIGHTS
FO-263424	10/1/2013	10/1/2013		AIR NOT WORKING
FO-263601	10/2/2013	10/3/2013		RM 427 RED LIGHT ON THERMASTAT IS ON, UNABLE TO CONTROL TEMP
FO-263714	10/3/2013	10/4/2013		379 & 387 TOO HOT
FO-263782	10/4/2013	10/5/2013		RM 28 & 30 TOO COLD
FO-263862	10/7/2013			Entire building is very warm, 3rd and 4th temperatures are reaching 84 degrees. Please adjust
FO-263872	10/7/2013	10/8/2013		Packing on faucets on the right hand side of hood W11 are leaking quite a bit of water into the
FO-263956	10/8/2013	10/8/2013		AIR UNIT NOT WORKING
FO-264143	10/9/2013	10/9/2013		6TH FL CONF RM A TOO HOT
FO-264237	10/10/2013		10/17/2013	RM 1255 TOO HOT
FO-264238	10/10/2013	10/11/2013		WOODCOCK WING TOO HOT, ALL FLOORS SOUTHERN AREA
FO-264246	10/11/2013	10/11/2013		Clean Coil
FO-264443	10/14/2013	10/15/2013		Purdy Library 4th Floor Room 446
FO-264441	10/14/2013	10/15/2013		R/R BSMT TUNNEL BTWN COMMUNITY ARTS/MCGREGOR BEFORE THE OUTSIDE DOC
FO-264444	10/14/2013	10/15/2013		RM 2025 TOO COLD PLEASE ADJUST TEMP CLASS STARTS AT 6pm
FO-264775	10/17/2013	10/17/2013		RM 521,523,525,& 527 TOO HOT SHOULD BE 60 DEGREES
FO-264864	10/18/2013	10/19/2013		RM 5150 TOO COLD
FO-265125	10/22/2013			Am becoming an icicle . . . I think this may be a floor-wide problem, however. Is it possible to
FO-265128	10/22/2013	10/22/2013		RM 313 UNISEX RESTROOM RADIATOR DRIPPING
FO-265271	10/23/2013	10/24/2013		RM 4117 IS TOO COLD
FO-265275	10/23/2013			VERY COLD. ROOM 2033.
FO-265411	10/24/2013			RM 240 WINDOW HEATER NOT WORKING
FO-265412	10/24/2013	10/25/2013		TOO WARM. (LOUNGE)
FO-265413	10/24/2013	10/25/2013		RM 3225.7 IS TOO COLD/ACU IS STILL ON
FO-265418	10/24/2013			RM 320 HOOD NOT WORKING
FO-265533	10/25/2013			3RD FLR WOODCOCK WING STACK AREA IS TOO HOT
FO-265539	10/25/2013	10/26/2013		TOO COLD. 3RD FLOOR NORTHWEST SIDE OF BUILDING.
FO-265629	10/28/2013	10/29/2013		Too cold in this room - air flow stronger in this room than others.
FO-265630	10/28/2013			Too cold in this room - air flow stronger in ths room than others.
FO-265631	10/28/2013			Too cold in this room - air flow stronger in this room than others.
FO-265633	10/28/2013	10/29/2013		Too cold in this room - air flow stronger in this room than others.
FO-265669	10/28/2013			TOO COLD. ROOM 3315.
FO-265672	10/28/2013	10/29/2013		The 6th floor is reporting that the entire area is too warm. Please lower temperature.
FO-265677	10/28/2013	10/29/2013		1ST FL LOBBY AND OFFICES TOO COLD IN CHILD CARE CTR
FO-265761	10/29/2013	10/30/2013		Purdy Library 1st Floor, Room 134
FO-265769	10/29/2013	10/30/2013		LAB 30 TOO HOT, PRESSURE TO LOW (house air)
FO-265774	10/29/2013	10/30/2013		AIR NOT WORKING, ALARM FOR TEMP IS ON
E - South			35	
FO-263803	10/7/2013	10/7/2013		RM 100 TOO COLD

WO	Recieved	Finished	Total	Request
FO-263818	10/7/2013	10/7/2013		BLDG TOO COLD
FO-263826	10/7/2013	10/7/2013		RM 3167 TOO COLD,FEELS LIKE AIR IS ON
FO-263832	10/7/2013	10/15/2013		BSMNT & 1ST FL LIBRARY TOO HOT
FO-263845	10/7/2013	10/7/2013		RM 218 IS TOO COLD
FO-263913	10/8/2013	10/15/2013		ENTIRE BSMT IS TOO COLD (LABS 10/20)
FO-264504	10/15/2013	10/15/2013		Please lower temp in the food and bedding room to 70* F per new guide policys.
FO-264505	10/15/2013	10/16/2013		Please lower the food and bedding room temp to 70°F and maintain humidity below 50% per n
FO-264591	10/16/2013	10/16/2013		BSMNT NO AIR FLOW
FO-264646	10/16/2013	10/17/2013		TOO HOT. BASEMENT ROOM 50.
FO-264690	10/17/2013	10/17/2013		TOO HOT. BASEMENT ROOM 50.
FO-264732	10/17/2013	10/17/2013		LAB A RM 1140 TOO HOT
FO-264820	10/18/2013	10/18/2013		RM 169 TOO COLD
FO-264824	10/18/2013	10/18/2013		BLDG TOO COLD, RM 200 VERY COLD
FO-264921	10/21/2013	10/21/2013		STE 1600 IS EXTREMELY HOT
FO-264948	10/21/2013	10/21/2013		DELILAH CAFE IS TOO HOT
FO-265019	10/22/2013			BLDG TOO COLD, CHECK THE BOILER 64 DEGREES SHOULD BE 72
FO-265020	10/22/2013	10/22/2013		TOO COLD. BASEMENT.
FO-265097	10/22/2013			RM 5 IN BSMNT TOO HOT
FO-265129	10/22/2013			RM 110 FUME HOOD 14& 16 LOW SPACE VELOCITY
FO-265192	10/23/2013			TOO COLD. MEZZANINE.
FO-265202	10/23/2013	10/25/2013		RM 53 TOO HOT
FO-265229	10/23/2013	10/23/2013		BLDG TOO COLD
FO-265231	10/23/2013	10/23/2013		2ND & 3RD FL TOO COLD
FO-265384	10/24/2013	10/25/2013		2ND FL LADIES RM TOO COLD, STE 226 TOO COLD SEE FERNA
FO-265387	10/24/2013	10/24/2013		RM 053/LAB IS TOO HOT
FO-265474	10/25/2013	10/25/2013		TOO COLD. ROOMS 211.4 AND 211.2.
FO-265504	10/25/2013	10/25/2013		Entire building cold. Heat registers in hallways blowing cold air.
FO-265513	10/25/2013			RM 3210 IS TOO COLD needs work on VAV box.
FO-265527	10/25/2013	10/25/2013		RM 291 IS TOO HOT
FO-265659	10/28/2013	10/29/2013		Room is @ 78 degrees - too hot
FO-265704	10/29/2013	10/29/2013		RM 1520 BROKEN WATER HEATER
FO-265742	10/29/2013	10/29/2013		50A, 50B, & 73 IN BSMNT TOO HOT
FO-265748	10/29/2013	10/30/2013		TOO COLD. ROOM 300.6.
FO-265819	10/30/2013	10/30/2013		NO AIR FLOW (FANS ARE OFF). BASEMENT.
E - Southeast			18	
FO-263936	10/8/2013	10/8/2013		TURN AIR OFF IMMEDIATELY. TURN HEAT ON
FO-264095	10/9/2013			Fire/Pump Room, #101 is making a rather loud noise not sure what is going on in this room bu
FO-264096	10/9/2013			4th and 3rd floors are very hot, temperatures are averaging 80. Please adjust.
FO-264926	10/21/2013	10/21/2013		Temperature in the room is extremely hot. It's difficult to hold rehearsal in the room in the eve
FO-264934	10/21/2013	10/17/2013		RM 1204 HEATING AND COOLING UNIT NOT WORKING WITHIN ROOM, UNABLE TO AD
FO-264940	10/21/2013	10/21/2013		BLDG TOO COLD
FO-265048	10/22/2013	10/22/2013		ENTIRE BLDG TOO COLD
FO-265054	10/22/2013			STE 4100 TOO COLD
FO-265073	10/22/2013			TOO COLD. SUITE 6203.
FO-265078	10/22/2013			12212.2 TOO COLD
FO-265091	10/22/2013	10/22/2013		RM 1125 TOO COLD
FO-265098	10/22/2013			RM 2207 DROP CEILING AND VENT FELL OUT OF CEILING

WO	Recieved	Finished	Total	Request
FO-265363	10/24/2013	10/24/2013		RM 220 & 237 NO HEAT, TOO COLD
FO-265370	10/24/2013	10/24/2013		BDLG NEEDS HEAT TURNED ON, COLD
FO-265565	10/28/2013			Make boiler #1 ready for normal operation.
FO-265596	10/28/2013	10/28/2013		RM 240 TOO COLD
FO-265753	10/29/2013	10/29/2013		TOO COLD. ROOM 3315.
FO-265856	10/30/2013			BLDG IS TOO COLD
E - West			22	
FO-264394	10/14/2013	10/14/2013		1ST FLR IS TOO COLD
FO-264472	10/15/2013	10/15/2013		2ND FL TOO COLD
FO-264609	10/16/2013	10/17/2013		Cold call via twitter from student-
FO-264839	10/18/2013	10/18/2013		ENTIRE BLDG IS EXTREMELY COLD
FO-264927	10/21/2013	10/21/2013		BLDG TOO COLD
FO-264941	10/21/2013	10/21/2013		Office is freezing cold; staff cannot work in office.
FO-265036	10/22/2013	10/22/2013		RM 150 AIR ON, TOO COLD FOR PROFESSOR
FO-265080	10/22/2013			TOO COLD. ROOM 2033.
FO-265088	10/22/2013	10/22/2013		TOO COLD. AUDITORIUM
FO-265125	10/22/2013			Am becoming an icicle . . . I think this may be a floor-wide problem, however. Is it possible to
FO-265199	10/23/2013			Room is freezing--no heat on.
FO-265219	10/23/2013	10/23/2013		Lab is too hot -- 79 degrees
FO-265249	10/23/2013			RM 2033 IS STILL TOO COLD
FO-265313	10/24/2013	10/24/2013		ENTIRE BLDG TOO COLD 2ND FL EXTREMELY COLD
FO-265327	10/24/2013	10/24/2013		RM 150/AUDITORIUM ACU TURNS ON IN THE MORN (9AM) CAUSING AUD TOO COLD
FO-265374	10/24/2013			No heat in faculty office.
FO-265397	10/24/2013			RM 559 IS TOO COLD
FO-265398	10/24/2013			RM 565 IS TOO COLD
FO-265399	10/24/2013			RM 567 IS TOO COLD
FO-265400	10/24/2013			RM 569 IS TOO COLD
FO-265402	10/24/2013			RM 573 IS TOO COLD
FO-265449	10/25/2013			TOO HOT. ROOM 328.
Low			198	
E - Area 1 Engineer			4	
FO-263359	10/1/2013	10/17/2013		Engineer
FO-263573	10/2/2013	10/2/2013		Hi,
FO-264476	10/15/2013			ENGINEER (J.KEYS) MED PRIORITY
FO-264519	10/15/2013	10/21/2013		Building engineer
E - Area 2 Engineer			5	
FO-263363	10/1/2013	10/1/2013		MEET W/CONTRACTOR FOR CHILLER PH# 248-506-1310
FO-263588	10/2/2013	10/2/2013		MEET W/OMAR (D.S.) WALK THRU FOR CHILLERS 870-7910
FO-263638	10/3/2013	10/3/2013		Lab is too cold -- 66 degrees.
FO-263651	10/3/2013			WOULD LIKE ACCESS TO ROOF @10:30am (she's in rm 1147)
FO-263795	10/5/2013	10/7/2013		The heater in the handi-capped restroom of the main lobby is continually heating. Please repai
E - Auxiliary			62	
H-41572	10/1/2013		10/24/2013	The air conditioning unit in the Study Lounge is broken. The display pad does not light up at all
H-41582	10/1/2013		10/1/2013	right hand men's urinal water pressure is low - Ghafari men's restroom
H-41635	10/2/2013	10/2/2013	10/2/2013	My cooling (AC) and heat is not working. The fan works, but the heating/cooling unit is not wo
H-41605	10/2/2013		10/2/2013	The air conditioner in the room stopped working.
H-41639	10/2/2013	10/3/2013	10/3/2013	Hello, I wasn't sure which lounge this is, but it is the one closest to the elevators. I wanted to
H-41640	10/3/2013		10/7/2013	Power outlet next to network outlet on south wall (by nightstand and window)works intermittent

WO	Recieved	Finished	Total	Request
H-41655	10/3/2013		10/4/2013	Air conditioning had it fixed once already but our room is 78
H-41664	10/3/2013		10/6/2013	Garbage Disposal is not working
H-41665	10/3/2013			Request is actually for the 1st Floor backroom bathroom sink is clogged up. Maintenance tried
H-41669	10/4/2013		10/7/2013	The air conditioning vent in the living room is making leaking water noises and drips water fro
H-41683	10/4/2013			AC is brokenauthenticated user: David Lilley - fh1528requester ip address: 141.217.224.20
H-41680	10/4/2013		10/7/2013	Kitchen outlet to the right when entering is not working.
H-41682	10/5/2013		10/7/2013	Air stopped working
H-41712	10/6/2013		10/8/2013	Resident in apartment complained about water being in air conditioning system after raining a
H-41794	10/7/2013		10/18/2013	Our thermostat is broken. The temperature is stuck on 81
H-41708	10/7/2013	10/8/2013	10/10/2013	The disposer in the kitchen is blocked by food residue.
H-41722	10/7/2013			Power goes out a lot in this apartment. Can we check the apartment for any power deficiencie
H-41728	10/8/2013		10/8/2013	shampoo carpet by air conditioner.
H-41730	10/8/2013		10/8/2013	shampoo carpet by air conditioner.
H-41738	10/8/2013	10/9/2013	10/9/2013	The rectangle box underneath the temp control is broken. Resident's bed is blocking access t
H-41739	10/9/2013	10/9/2013	10/9/2013	The smoke alarm in Lounge 200 flashes a red light instead of a green one.
H-41770	10/9/2013	10/10/2013	10/10/2013	For the past two weeks, we have occasionally not had hot water in our shower. Can this pleas
H-41779	10/10/2013		10/10/2013	Kitchen falucet is loose and leaking
H-41781	10/10/2013		10/10/2013	A lot of water around the toilet. Something is leaking.
H-41789	10/10/2013	10/14/2013	10/22/2013	One of the Bathroom sink is not functioning
H-41793	10/11/2013	10/14/2013	10/22/2013	the power outlet inside the bathroom(the first one) does not have electricity and it does not w
H-41808	10/13/2013	10/14/2013	10/14/2013	Air conditioning will not turn on.
H-41815	10/14/2013			repair handle to handwashing sink - Starbucks
H-41849	10/14/2013	10/15/2013	10/22/2013	The crusher in the sink isnt working.
H-41872	10/15/2013		10/24/2013	When the bathroom light is turned on, there is a noise that sounds like a train.
H-41869	10/15/2013			canister light by the deli, and canister light inside of the dessert circle, and one tear drop light i
H-41870	10/15/2013			square light out in elevator lobby. Ballast out.
H-41883	10/16/2013	10/18/2013	10/22/2013	The faucet above the kitchen sink is leaking again. Last time some maintenance staff came to
H-41879	10/16/2013	10/17/2013	10/17/2013	The temperature box in Jimmy Johns is not working
H-41893	10/16/2013			Fix the leak in the wall by the AC unit.
H-41914	10/17/2013	10/18/2013	10/18/2013	New lightbulb in hallway and thermostat not working
H-41973	10/18/2013	10/22/2013	10/22/2013	Toilet is not flushing properly. Possible that flush has become weak or something is clogging u
H-41934	10/18/2013		10/24/2013	Shower pipe is leaking a little.
FO-264888	10/19/2013	10/21/2013		The elevator is stuck on the 7th floor no one is in elevator ,
H-41935	10/20/2013		10/21/2013	The garbage disposal isn't working.
H-41939	10/20/2013		10/21/2013	The power socket has no electricity in the kitchen.
H-41931	10/20/2013	10/21/2013	10/22/2013	The disposer is broken. Please come as soon as possible
H-41950	10/21/2013	10/22/2013	10/22/2013	the heating and cooling system does not work. Needs to be fixed asap
H-41975	10/21/2013			Bath tub tap not working
H-41977	10/21/2013		10/23/2013	A/C keeps breaking
H-41982	10/22/2013			Radiator in the bedroom is not functioning properly. This is the room to the right of the bathroo
H-41979	10/22/2013	10/22/2013	10/22/2013	Toilet in the first bathroom is not flushing properly. Also, the closet door across the hall from th
H-41980	10/22/2013	10/22/2013	10/23/2013	Storage cabinets below the sink is leaking. Request you to please fix it.
H-41981	10/22/2013	10/22/2013	10/30/2013	Maintenance check request-- Loud sounds that seem to be coming from water pipes(??) in cei
H-41992	10/22/2013		10/24/2013	Conveyor belt sink is leaking
H-42008	10/23/2013			The box in wall in Room A was alarmed and went off and needs checking and fixing.
H-42016	10/23/2013		10/24/2013	Please replace shower head with a new one. The shower head keeps flying off.
H-42021	10/23/2013			exhaust fan in second/last bathroomauthenticated user: Krupa Patel - eh2225requester ip

WO	Recieved	Finished	Total	Request
H-42023	10/23/2013	10/24/2013	10/30/2013	Their heater is not working, and they are very cold.
H-42025	10/24/2013	10/24/2013	10/30/2013	Heating is not working. Blower is not blowing at all if we turn to "warm". The AC is working tho
H-42047	10/25/2013			Toilet does not flush properly, continually runs after a while, generating a loud noise. A quick fl
H-42053	10/25/2013	10/28/2013	10/30/2013	1st bathroom's toilet flush not working properly.
H-42076	10/25/2013			I am hearing very loud clanking noises coming from the bathroom radiator. It seems like the h
H-42080	10/28/2013			Our shower light went out a few weeks ago. maintenance replaced bulb, still not working. esc
H-42100	10/29/2013			mechanical check
H-42103	10/29/2013			Please fix the following problems:
H-42134	10/30/2013			Lounge heater and AC not workingauthenticated user: Fatin Dubaybo - eq0916requester ip
E - Command Center			68	
FO-263407	10/1/2013	10/8/2013		A/C Controls,
FO-263552	10/2/2013			REFRIDGERATION (HIGH)
FO-263555	10/2/2013			Controls, High
FO-260626	10/3/2013	10/18/2013		Siemens
FO-263842	10/7/2013	10/21/2013		Trade: Controls/Siemens Priority: Medium
FO-263885	10/8/2013			Trade: Controls/Siemens Priority: Low
FO-264158	10/10/2013	10/14/2013		Controls
FO-264173	10/10/2013			Supervisor (C. Redman) Controls High Priority
FO-264282	10/11/2013	10/15/2013		Refrig shop,
FO-264288	10/11/2013	10/15/2013		Refrig shop,
FO-264430	10/14/2013	10/18/2013		Trade: Controls Priority: Medium
FO-264462	10/15/2013		10/17/2013	Command Center - Lloyd, Please repair controls for HPLCW. Pressures intermittently reachin
FO-264463	10/15/2013			Command Center - Lloyd, please repair HPDCW Controls. Temp controls have been rigged w
FO-264707	10/17/2013			CONTROLS CREW, R/R RM 1204 PLEASE REPAIR BAD STAT LINE TO FFC UNIT.PRI
FO-264710	10/17/2013			Refrigeration Crew
FO-264711	10/17/2013			REFRIGERATION CREW
FO-264712	10/17/2013			REFRIGERATION CREW
FO-264754	10/17/2013	10/21/2013		Move thermostat from reception area in Rm. 2190 to the 'open' area side (Rm. 2150) of the di
FO-264759	10/17/2013	10/22/2013		Control Engineer;
FO-264801	10/18/2013			Controls - Lloyd - High priority. Please R/R RM 0100/MECH RM repair controls/excessive pres
FO-264803	10/18/2013			Controls - Lloyd -
FO-264812	10/18/2013			Controls - Lloyd -
FO-264852	10/18/2013	10/18/2013		Complete re-assemble of boiler #1 and perform flue gas analysis.
FO-264865	10/18/2013			Request training course 5-620 for A. Sledge, R. Hosking & D. Jachman. To be held locally [PI
FO-264889	10/19/2013			Siemens:
FO-264896	10/20/2013	10/24/2013		Boilers & controls-
FO-264898	10/21/2013			Control Engineer;
FO-264897	10/21/2013	10/31/2013		Control Engineer; Medium
FO-264993	10/21/2013			Controls-
FO-265000	10/22/2013			Controls. Repair or replace mixed air damper motors on rear of fan #5
FO-265001	10/22/2013	10/22/2013		Trade: Controls/Siemens Priority: Low
FO-265057	10/22/2013	10/24/2013		REFRIG CREW:
FO-265108	10/22/2013	10/23/2013		R/R RM 0002/MECH RM AHU #2 will not start, tried to reset but it still will not start. Need Sei
FO-265110	10/22/2013	10/28/2013		R/R RM 232 Installed valv actuator on room 232 and after using my seimons computer to man
FO-265171	10/23/2013			AC Controls High Priority
FO-265195	10/23/2013			Trade: Controls/Siemens Priority: High
FO-265198	10/23/2013			Conrol Engineer; Medium

WO	Recieved	Finished	Total	Request
FO-265209	10/23/2013			A/C shop
FO-265206	10/23/2013	10/24/2013		CONTROLS (HIGH)
FO-265208	10/23/2013	10/25/2013		Refrig shop,
FO-265248	10/23/2013			Please repair West infared heater on loading dock.
FO-265256	10/23/2013			Trade: Controls Priority: Low
FO-265272	10/23/2013			Trade: Controls
FO-265306	10/24/2013			Controls High Priority
FO-265308	10/24/2013			Controls High Priority
FO-265324	10/24/2013			Trade: Controls/Siemens Priority: medium
FO-265330	10/24/2013			Trade: Controls/Siemens Priority: Low
FO-265332	10/24/2013			Trade: Controls/Siemens Priority: Low
FO-265358	10/24/2013			CONTROLS
FO-265366	10/24/2013			CONTROLS
FO-265410	10/24/2013			Supply Fans 1 & 2; no control, face & bypass dampers not responding.
FO-265441	10/25/2013			Trade: Refrig/controls Priority: HighTag#090-BSG-002R/R RM 4195/MECH-BLR RM Adjus
FO-265506	10/25/2013	10/29/2013		Trade: Controls Priority: Low
FO-265525	10/25/2013			A/C shop inspect and repair freezing evaporator in cold room. One fan is not running.
FO-265554	10/26/2013			Repair controller serving HV-2 heating coil. The valve is passing hot water to the coil even tho
FO-265568	10/28/2013			A/C Shop repair
FO-265599	10/28/2013			REPLACE STEAM REGULATING VALVE. PENTHOUSE. AC11.
FO-265603	10/28/2013	10/30/2013		REFRIG CREW
FO-265608	10/28/2013	10/30/2013		REFIGCREW
FO-265646	10/28/2013			CONTROLS (MED PRIORITY0
FO-265711	10/29/2013			Controls CREW
FO-265712	10/29/2013			Controls Crew
FO-265834	10/30/2013			#4 boiler has bad level master
FO-265836	10/30/2013			Open, Clean & Close boiler #1.
FO-265884	10/30/2013			R/R RM 2206 hot call: checked room and found thermostat not operating properly.
FO-265896	10/30/2013	10/30/2013		REFRIGERATION CREW #4 LOCHINVAR BLR
FO-265905	10/30/2013	10/30/2013		Stock for toolbag
FO-265909	10/30/2013			PS#8
E - Director			1	
FO-263761	10/4/2013			Lighting Crew; High
E - MedPharm			14	
FO-264257	10/11/2013			When testing with sling psychrometer I found that the rooms temp. sensor in these rooms nee
FO-264427	10/14/2013	10/14/2013		R/R PENTHOUSE Please order belts for EXF-25 size: A-73, qty: 2
FO-264702	10/17/2013			INSIDE STE 200/DLAR IN HALLWAY OUTSIDE OF RM 200.15 CLNG IS LKNG
FO-264703	10/17/2013			RM 200.07/DLAR HAS LOW TEMP
FO-264705	10/17/2013			RM 200.08/DLAR HAS LOW TEMP
FO-264884	10/18/2013	10/24/2013		R/R RM 454 Replace dirty filter on ceiling vent in room 454
FO-264891	10/19/2013			Animal room has a low temperature of 65 degrees and a high temperature of 67 degrees. Adj
FO-265011	10/22/2013			R/R 4TH FLR Change filters in all animal rooms
FO-265012	10/22/2013	10/22/2013		Fix theromstate in room and increase heat. Room very cold
FO-265118	10/22/2013	10/23/2013		Noise is coming from above ceiling panels. Please check.
FO-265571	10/25/2013	10/25/2013		Day Engineer please change filter
FO-265572	10/25/2013	10/25/2013		Day Engineer please change filter
FO-265466	10/25/2013			R/R RM 3141 Replace missing filters over vents in lab. Black dust is interfering with ability t
FO-265469	10/25/2013	12/25/2013		Very cold on 3rd floor. Specifically rooms 3105,

WO	Recieved	Finished	Total	Request
E - North			6	
FO-263906	10/8/2013	10/8/2013		Gurgling noises coming from radiator. Gurgling sounds also in pipes in first floor women's bat
FO-264982	10/21/2013	10/21/2013		Computer Lab Hot Call - please address ASAP.
FO-265254	10/23/2013	10/23/2013		We have no hot running water
FO-265333	10/24/2013			Purdy Library 1st Floor, Room 134
FO-265609	10/28/2013			Please adjust temperature in this suite. This morning it was 60 degrees when they walked in.
FO-265639	10/28/2013			The stacks area (in the original building and in
E - Northeast			5	
FO-264904	10/21/2013	10/21/2013		RM 118/DES SVCS IN THE BACK AREA PIPES ARE MAKING A NOISE MAYBE AIR IN PIP
FO-265106	10/22/2013	10/22/2013	10/22/2013	TOO COLD. CHIEF'S OFFICE ROOM 202.
FO-265174	10/23/2013	10/23/2013		GRND FLR EXIT DOOR ALARM ACCIDENTLY SET OFF BY LITING TECH
FO-265477	10/25/2013	10/25/2013		There is air trapped in the pipes overhead at Planning. This is related to the boiler. It sounds li
FO-265618	10/28/2013			Washers (5) for front door of boiler.
E - Preventative Maintenance			8	
FO-264156	10/10/2013	10/24/2013		Replace Belts & Sheaves
FO-264157	10/10/2013	10/23/2013		Replace Belts & Sheaves
FO-264244	10/11/2013	10/29/2013		Replace Belts on EF #4
FO-264245	10/11/2013	10/26/2013		Replace Belts
FO-264314	10/11/2013	10/11/2013		heat/cool register is making really loud noises, cannot conduct meetings, when unit is turned o
FO-264988	10/21/2013	10/22/2013		Thermostat in our food and bedding room needs to be replaced. It has been hit with pallets an
FO-265277	10/23/2013	10/24/2013		Lab is too hot -- 77 degrees
FO-265767	10/29/2013	10/30/2013		Laides and Mens restrooms on the 4th floor drains have a foul odor coming from them. Pleas
E - South			16	
FO-263952	10/8/2013	10/8/2013		Lab 2407 has the air conditioning off. They need you to check it. Thank you.
FO-264722	10/17/2013	10/16/2013		Refuel generators
FO-264723	10/17/2013	10/18/2013		Refuel generator
FO-264724	10/17/2013	10/18/2013		Refuel generator
FO-265007	10/22/2013	10/22/2013		BLDG EMERGENCY WATER SHUTDOWN 10/21/13 AFFECTING CHEM, SCI HALL, LIFE S
FO-265008	10/22/2013	10/22/2013		BLDG EMERGENCY WATER SHUTDOWN 10/21/13 AFFECTING CHEM, SCI HALL, LIFE S
FO-265009	10/22/2013	10/22/2013		BLDG EMERGENCY WATER SHUTDOWN 10/21/13 AFFECTING CHEM, SCI HALL, LIFE S
FO-265010	10/22/2013	10/22/2013		BLDG EMERGENCY WATER SHUTDOWN 10/21/13 AFFECTING CHEM, SCI HALL, LIFE S
FO-265191	10/23/2013	10/23/2013		RM 050/COMP LAB IS EXTREMELY HOT (call from voice mail 10/22/13 6:59pm)
FO-265238	10/23/2013			Still need room 027.5 to have its temp. a stable 78°F. Currently at 73*
FO-265434	10/24/2013			All the heat registers in the first floor hallway are not working . Hallway very cold.
FO-265436	10/24/2013	10/28/2013		North stairwell by State Hall heat not working. Very Cold
FO-265610	10/25/2013	10/28/2013		Trade: E - SouthPriority: HighR/R BSMT HALLWAY Please repair leak in hallway near ro
FO-265607	10/28/2013	10/28/2013		RM 040/LAB IS EXTREMELY HOT (note the equip will be damaged if continues @ hi temp)
FO-265658	10/28/2013	10/29/2013		Room is very hot
FO-265916	10/30/2013	10/31/2013		The Dalnet office says the areas are still too hot. Please lower temperature
E - Southeast			7	
FO-263814	10/7/2013	10/7/2013		MEET W/OMAR (D.S.) MECH CO CKNG ON COT 313-870-7910
FO-264919	10/21/2013	10/21/2013		RM 0006 NEED ACCESS TO RM TO STRIP/WAX
FO-264947	10/21/2013	10/23/2013		would like to gain access to roof
FO-264985	10/21/2013			Office 14110.2 a/c vent issue; please reference previous work order FO-262248 as issue
FO-265421	10/25/2013			Order & Replace Filters for Freezer Rm Units.
FO-265611	10/28/2013			Fan unit in ceiling making loud rattling noise.
FO-265828	10/30/2013			Mens restroom on third floor has a foul odor coming from I believe the drain trap
E - West			2	

WO	Recieved	Finished	Total	Request
FO-265510	10/25/2013			Several offices on the west side of the fifth floor -- 569, 567, 565, 563 in particular -- are still C
FO-265635	10/28/2013	10/29/2013		Trade: Engineer Priority: Low
Routine			2	
E - Command Center			1	
FO-265919	10/30/2013			The recently renovated office area
E - Northeast			1	
FO-264406	10/14/2013			Pls repaint the engineers office inside the comp center boiler room.
Grounds			9	
High			1	
G - Physical Grounds			1	
FO-265103	10/22/2013	10/23/2013		Please send power sweeper to clean sidewalk at front entrance mall side due to water main
Medium			1	
G - Physical Grounds			1	
FO-264219	10/10/2013	10/14/2013		pls remove trash and brick waste from
Low			6	
G - Moving/Storage			4	
FO-265701	10/4/2013			Removal and disposal of obsolete computer equipment stored in room 2302 F/AB
FO-263877	10/7/2013	10/9/2013		pick up 3 tagged desks from Holden Warehouse and deliver to 6E UHC, also remove 2 desk
FO-265468	10/25/2013			Please have Grounds move team move 4 wooden cabinets located outside of Engineering offi
FO-265722	10/25/2013	10/31/2013		We need 10 tables set up on Tuesday, October 29th at 1pm and taken down the next day on
G - Physical Grounds			2	
FO-265456	10/24/2013	10/29/2013		please remove weeds from deck area and
FO-265454	10/24/2013	10/29/2013		Please repair the landscaping at the
Routine			1	
G - Physical Grounds			1	
FO-265903	10/30/2013			FY 2014 FO for Sells & Sons.
Trades			1105	
Emergency			94	
T - Carpenter			17	
FO-263394	10/1/2013	10/1/2013		HANDICAP ENTRANCE DOOR STUCK OPEN Finished 10/2/2013LT
FO-263405	10/1/2013	10/2/2013		Emergency Repair Request.
FO-263406	10/1/2013	10/1/2013		R/R ENT HANDICAP Door #629 02S. Outer handicap door is closing too slowly. At least 5 s
FO-263409	10/1/2013	10/1/2013		R/R RM 4229 This is a swipe card practice room:
FO-263411	10/1/2013	10/1/2013		EAST HANDICAP INTERIOR AND EXTERIOR DOORS ARE NOT WORKING WHEN BUTTO
FO-263617	10/3/2013	10/7/2013		Low battery on main entrance door. Four people locked out of the 4th floor main entrance (418
FO-264126	10/9/2013	10/9/2013		EMERGENCY
FO-264289	10/11/2013	10/11/2013		2nd floor, closet# 222, core is messed up. unable to open Finished 10/14/2013LT
FO-264484	10/15/2013	10/15/2013		KEY STUCK IN ENTRANCE DOOR LOCK. BASEMENT ROOM 200.04. Finished 10/18/2013
FO-264516	10/15/2013	10/15/2013		DOOR WON'T CLOSE OR LOCK (DOOR SWINGING OPEN) DOOR FACING JACOB'S HOU
FO-264753	10/17/2013	10/17/2013		R/R 1ST FLR WESTEND STRWL HALLWAY DOOR PANIC BAR (PANIC BAR LEADING TO
FO-264788	10/17/2013	10/18/2013		R/R RM 3800 Please repair the lock at the door, lock isn't opening or unlocking this door. this
FO-265077	10/22/2013	10/22/2013		DOCK DOOR IS OFF TRACK. BASEMENT. Finished 10/25/2013LT
FO-265287	10/24/2013	10/24/2013		DOOR WON'T OPEN. ROOM 27.2. Finished 10/25/2013LT
FO-265458	10/25/2013	10/25/2013		DOOR WON'T LOCK. ROOM 8229.
FO-265467	10/25/2013	10/25/2013		DOOR 2 EAST IS NOT LATCHING OR LOCKING. Finished 10/28/2013
FO-265549	10/25/2013	10/29/2013		A/AB Suite 3660
T - Electrician			60	

WO	Recieved	Finished	Total	Request
FO-263370	10/1/2013	10/2/2013		RM 1128 BLOWN FUSE Finished 10/4/2013LT
FO-263377	10/1/2013	10/1/2013		R/R RM 1128.1 DUE TO WATER PIPE BURSTING IN RM 2126 RM 1128.1 LIGHTS AREN'T
FO-263382	10/1/2013			FIRE TROUBLE ALARM.
FO-263397	10/1/2013	10/1/2013		TABLE OUTLETS ARE NOT WORKING. CONFERENCE ROOM. ROOM 4200. Finished 10/
FO-263413	10/1/2013			RM 1136 OUTLET NOT WORKING
FO-263579	10/2/2013	10/2/2013		FIRE TROUBLE ALARM Finished 10/4/2013LT
FO-263583	10/2/2013	10/2/2013		FIRE ALARM. Finished 10/4/2013LT
FO-263590	10/2/2013	10/2/2013		FIRE ALARM SOUNDING Finished 10/4/2013LT
FO-263629	10/3/2013	10/3/2013		R/R RM 403/OFC AREA CUBICLES HAVE NO POWER TO THEM HOWEVER NEED TO CK
FO-263682	10/3/2013	10/3/2013		RM 1128 OUTLETS NOT WORKING Finished 10/4/2013 LT
FO-263696	10/3/2013	10/4/2013		R/R LOBBY FAP FIRE TROUBLE ALARM SNDNG Finished 10/7/2013LT
FO-263721	10/4/2013	10/4/2013		Disconnect / Reconnect blowdown solenoid in boiler room . See Jim Hill for location Finished
FO-263750	10/4/2013	10/4/2013		FIRE TROUBLE ALARM Finished 10/7/2013LT
FO-263765	10/4/2013	10/8/2013		FIRE ALARM ON THE 8TH FLOOR.Finished 10/9/2013LT
FO-263829	10/7/2013	10/8/2013		FIRE TROUBLE ALARMFinished 10/9/2013LT
FO-263931	10/8/2013	10/8/2013		FIRE TROUBLE ALARM.Finished 10/9/2013LT
FO-264044	10/9/2013	10/9/2013		Exterior lights in bushes, on the west side one of the mushroom head fixtures have fell over, a
FO-264077	10/9/2013	10/10/2013		Lights out in the Damon J. Keith Center for Civil
FO-264102	10/9/2013	10/9/2013		3125.1 NO POWER Finished 10/11/2013LT
FO-264146	10/9/2013	10/9/2013		WALL OUTLET IS SMOKING. ROOM 7374. Finished 10/11/2013LT
FO-264279	10/11/2013	10/11/2013		R/R RM 1143/CLASS RM CLEANING THE CARPET BLOWN THE CIRCUIT Finished 10/14/2
FO-264281	10/11/2013	10/11/2013		LIGHTS NOT WORKING. 1ST FLOOR OUTER LOBBY AT STAIRWAY NEAR WOODWARD
FO-264286	10/11/2013	10/11/2013		RM 2466 BLOWN FUSE Finished 10/14/2013LT
FO-264298	10/11/2013	10/11/2013		EMERGENCY R/R OVERHEAD GARAGE GATE DOOR WILL NOT CLOSE Finished 10/14/2
FO-264330	10/12/2013	10/12/2013		2nd floor lights not working, after power bump. Engineer attempted to re-set breaker, unsucce
FO-264331	10/12/2013	10/12/2013		Power Bump, generators running. Other buildings affected, called Electricians.
FO-264333	10/12/2013	10/12/2013		Fire alarm sounding, and will not reset. Finished 10/14/2013LT
FO-264356	10/14/2013	10/15/2013		R/R RM SUB B MECH RM HCFC FOR RM #3315 HAS NO POWER TO IT FUSES HAVE BL
FO-264386	10/14/2013	10/14/2013		RETURN AIR FAN #2 Finished 10/16/2013LT
FO-264395	10/14/2013	10/14/2013		The lights are out in my office. It must be an
FO-264405	10/14/2013	10/14/2013		EMERGENCY R/R RMS 1270, 1276 & 1078 HAVE NO LITES Finished 10/16/2013LT
FO-264419	10/14/2013	10/14/2013		MECH RM 51 AIR COMPRESSOR TRIPPING Finished 10/16/2013LT
FO-264577	10/16/2013	10/16/2013		NO POWER IN ROOMS 1021, 1025, 1029, 1035, BAY AREA, 2 RESTROOMS. (1ST FLOO
FO-264583	10/16/2013	10/24/2013		FIRE TROUBLE ALARM. Finished 10/25/2013LT
FO-264598	10/16/2013	10/16/2013		1 fixture out in 2nd Floor
FO-264643	10/16/2013	10/17/2013		POWER BUMP. ALARM GOING OFF - 1ST FLOOR. Finished 10/18/2013LT
FO-264678	10/17/2013	10/17/2013		Please diconnect drinking fountain on 2ed floor on cass side near eleavators . See Ray Banbu
FO-264740	10/17/2013	10/17/2013		RM 135,137,139 OUTLETS WENT OUT Finished 10/18/2013LT
FO-264825	10/18/2013	10/18/2013		RM 154 BLOWN CIRCUIT Finished 10/21/2013LT
FO-264880	10/19/2013	10/19/2013		Lights are not working in a large number of offices on the first floor. In lighting panel: LP-IBB, t
FO-264945	10/21/2013	10/19/2013		MOTOR WILL NOT START ON CHILLED WATER PUMP # 3, AUTO OR HAND...096-CHWP-
FO-264978	10/21/2013	10/21/2013		EMERGENCY
FO-265024	10/22/2013	10/22/2013		ALARM SOUNDING - 1ST FLOOR LOBBY. Finished 10/22/2013LT
FO-265049	10/22/2013	10/22/2013		EMERGENCY R/R 0200/MECH RM FAP TROUBLE SIGNAL IN PANEL W/RED LITE (Corey
FO-265239	10/23/2013	10/23/2013		FIRE TROUBLE ALARM. Finished 10/24/2013LT
FO-265268	10/23/2013	10/23/2013		NO POWER IN ROOMS 212 AND 214. Finished 10/24/2013LT
FO-265309	10/24/2013	10/24/2013		In the Damon Keith Wing, all the elevator lights are out.(6 Bulbs) Switch to turn them on cann

WO	Recieved	Finished	Total	Request
FO-265351	10/24/2013			R/R FAP FIRE TROUBLE ALARM
FO-265386	10/24/2013	10/25/2013		EMERGENCY R/R RM 2022 POWER WENT OUT OF WALL OUTLETS (DR. REED'S OFC A
FO-265519	10/25/2013	10/28/2013		EMERGENCY
FO-265566	10/28/2013	10/28/2013		FIRE TROUBLE ALARM. Finished 10/30/2013LT
FO-265590	10/28/2013	10/28/2013		FIRE TROUBLE ALARM. Finished 10/30/2013LT
FO-265626	10/28/2013	10/28/2013		Adding Eletricians : Please check eletricial sequence on booster pumps . See MIke Pummill f
FO-265720	10/29/2013	10/29/2013		FIRE TROUBLE ALARM Finished 10/30/2013LT
FO-265725	10/29/2013	10/29/2013		FIRE TROUBLE ALARM Finished 10/30/2013LT
FO-265754	10/29/2013	10/29/2013		NO POWER IN VIDEO SECURITY RECORDER. ROOM 1100. Finished 10/30/2013LT
FO-265816	10/30/2013			NO POWER IN ROOMS 1021, 1025, 1029, 1035, 1ST FLOOR RESTROOMS AND BAY ARE
FO-265817	10/30/2013			FIRE TROUBLE ALARM. (LAW SCHOOL ADDITION)
FO-265844	10/30/2013			BSMNT VENDING MACHINES HAVE NO POWER, NEAR SUB BSMNT ENTRANCE
FO-265923	10/30/2013			GYM 109 NO POWER TO PARTICIAN DOORS
T - Pipefitter			4	
FO-264255	10/11/2013	10/11/2013		VERY BAD CEILING LEAK CAUSING FLOOD. ROOM 14200.10....., EA/10-11-13
FO-264644	10/16/2013	10/16/2013		CEILING LEAK. 1ST FLOOR NEAR ROOM 1127 AND ELEVATOR....., Cancelled Wor
FO-265107	10/22/2013	10/22/2013		EMERGENCY/PIPEFITTER
FO-265247	10/23/2013	10/25/2013		EMERGENCY/PIPEFITTER
T - Plumber			13	
FO-263410	10/1/2013			R/R 7TH, 8TH & 9TH STILL HAVE NO HOT WATER (PLS CK PREVIOUS WO FO-262887) N
FO-263562	10/2/2013			EMERGENCY R/R R1 1/2" sch 80 PVC R.O. water for the building in lab 2126 WATER IS LE
FO-263725	10/4/2013	10/4/2013		PLEASE CHECK VERY BAD WATER LEAK OUTSIDE OF FAB BUILDING AT MEDIAN.....
FO-263730	10/4/2013	10/4/2013		3RD FL NO HOT WATER MM/10-4-13....., DUE 10-4-13 ASAP Finished 1
FO-263732	10/4/2013	10/4/2013		NO WATER IN ROOM 350....., Finished 10-4-13 JWT / *Duplicate Wwork order / Refer t
FO-264228	10/10/2013	10/10/2013		R/R BSMT MENS RR (STUDIO THEATRE) URINAL CON'T RUNNING RJC/RB 10-
FO-264275	10/11/2013	10/11/2013		STORAGE TANK SPLIT IN BOILER ROOM CAUSING FLOOD. (BASEMENT)....., RJC/
FO-264605	10/16/2013	10/16/2013		RM 9215 PIPE BUSTED IN CEILINGMM/10-16-13 DUE 10-17-13 ASAP
FO-264984	10/21/2013	10/21/2013		EMERGENCY
FO-265336	10/24/2013	10/24/2013		WATER GOES ON AND OFF - 13TH FLOOR....., Finished 10-24-13 duplicate work ord
FO-265472	10/25/2013	10/25/2013		NO HOT WATER. 2ND FLOOR LADIES RESTROOM....., MP/DB 10-25-13....., D
FO-265521	10/25/2013	10/25/2013		R/R 250 There is water leaking through the ceiling of studio 250 on the second floor. The floor
FO-265854	10/30/2013	10/30/2013		2ND FLOOR MEN'S RESTROOM URINAL IS LEAKING DOWN THRU WINDOW OF ROOM
High			274	
T - Carpenter			68	
FO-263422	10/1/2013	10/2/2013		R/R 1ST FLR WOMENS RR ACROSS FROM RM 109 1ST STALL DOOR IS STUCK CLOSE
FO-263558	10/2/2013	10/3/2013		WITHIN BUS SVC WOMENS RM HANDICAP STALL FLOOR BASE COMING UP Finished 1
FO-263655	10/3/2013	10/3/2013		R/R FRONT ENTRANCE DOOR #074 02N IS STICKING HARD TO OPEN ALSO CK DOOR
FO-263673	10/3/2013	10/3/2013		RM 2248, KEY IS VERY HARD TO PUT INTO CORE Finished 10/4/2013 LT
FO-263698	10/3/2013			R/R RM 224 WINDOW SHADE NEEDS TO BE RE-ATTACHED TO TOP PART OF WINDOW
FO-263715	10/3/2013	10/4/2013		ENTRANCE HANDICAP DOOR PUTNAM SIDE, AUTOMATIC BUTTON NOT OPERATING Fi
FO-263719	10/4/2013	10/4/2013		Door 3 North does not close all the way, closer needs to be stronger or door realigned Finishe
FO-263728	10/4/2013	10/4/2013		Repair the lock on the generator enclosure gate, and give Electricians 4 keys. Finished 10/7/2
FO-263729	10/4/2013	10/7/2013		RM 0002 DOUBLE DOORS NOT SECURING PROPERLYFinished 10/9/2013LT
FO-263746	10/4/2013	10/4/2013		CARPENTERS TO REORGANIZE STORAGE GARAGE ACROSS FROM THE CARPENTER
FO-263749	10/4/2013	10/7/2013		The outside handle to door #6 is falling off.
FO-263751	10/4/2013	10/4/2013		SECURE BUILDING FROM TRESPASSERS. Finished 10/7/2013LT
FO-263773	10/4/2013	10/4/2013		Install old ceiling tile back into ceiling. Current tile is just tucked into opening and hanging dow
FO-263791	10/5/2013	10/7/2013		R/R ENT DOOR #140-13W does not latch properly, receive nightly alarms on doorsFinished 1

WO	Recieved	Finished	Total	Request
FO-263792	10/7/2013	10/7/2013		R/R ENT DOOR #140-14W does not latch properly, receive nightly alarms on doorsFinished 1
FO-263822	10/7/2013	10/7/2013		9374 CEILING TILE NEEDS REPLACINGFinished 10/9/2013LT
FO-263878	10/8/2013	10/10/2013		Trade: Electricians
FO-263882	10/8/2013	10/22/2013		CARPENTERS
FO-263883	10/8/2013	10/21/2013		CARPENTERS
FO-263884	10/8/2013	10/15/2013		Door won't lock intermittently and need alignmennt. Finished 10/18/2013LT
FO-263886	10/8/2013	10/8/2013		Door # 316 will not open with key. Class is being held in this room. Please open.Finished 10/9/
FO-263900	10/8/2013	10/8/2013		R/R ENTRANCE HANDICAP DOOR #080-02S DOOR CLOSURE IS BROKEN & LOOSE CA
FO-263915	10/8/2013	10/9/2013		Hallway Door (Lock #D33X) entering room #0504 in the EDC Basement, keys are getting stuc
FO-263911	10/8/2013	10/9/2013		DOOR WON'T LOCK. ROOM 7204. Finished 10/11/2013LT
FO-263912	10/8/2013	10/11/2013		Prvvide access in wall 2ed floor outside mens toilet room . See Mike Pummill for location Finis
FO-263957	10/8/2013	10/9/2013		CARPENTERS TO BOARD UP ACCESS POINT FOR A WATER LEAK SOUTH/WEST STAI
FO-264211	10/10/2013	10/10/2013		RM 154.2 TRAINING RM LOCK WONT RELEASE, PLEASE CHECK LOCK Finished 10/11/2
FO-264217	10/10/2013	10/15/2013		Locksmith:
FO-264234	10/10/2013	10/17/2013		REMOVE WOOD, INSTALL WINDOW WITH OUTER PROCTION SCREEN IN PAINT SHOP
FO-264235	10/10/2013	10/11/2013		DOOR LOCK STICKING. ROOM 7204. Finished 10/14/2013LT
FO-264274	10/11/2013	10/11/2013		R/R PRESS BOX/ROOF Door to the football press box is out-of-line,,,It'sl hard to close/lock. P
FO-264317	10/11/2013	10/16/2013		tile on floor is coming up and is a trip hazard, grout is missing Finished 10/18/2013LT
FO-264320	10/11/2013	10/18/2013		ROLL UP GATE NOT WORKING Finished 10/22/2013LT
FO-264371	10/14/2013	10/14/2013		RM 235 DOOR NEEDS TO BE RE-ALIGNED Finished 10/16/2013LT
FO-264389	10/14/2013			R/R RM 224 Fix blind that has broken-off its mounting in
FO-264435	10/14/2013	10/15/2013		R/R ENT DOOR #155 020W IS RUBBING DOOR FRAME @ TOP CAUSING DOOR NOT TO
FO-264436	10/14/2013	10/15/2013		R/R ENT Door 130-06N stays ajar; scrapes threshold. Finished 10/18/2013LT
FO-264483	10/15/2013	10/16/2013		NW STAIRWELL DOOR 1ST FL UNABLE TO ACCESS, PROBLEM WITH LOCK CORE Finis
FO-264500	10/15/2013	10/16/2013		RM 124 When you lock the door inside your unable to get out
FO-264501	10/15/2013	10/16/2013		RM 126 When you lock the door inside your unable to get out Finished 10/18/2013LT
FO-264502	10/15/2013	10/16/2013		RM 128 When you lock the door inside your unable to get out Finished 10/18/2013LT
FO-264503	10/15/2013	10/16/2013		RM 220 When you lock the door inside your unable to get out
FO-264592	10/16/2013	10/17/2013		PROJECTION SCREEN WILL NOT GO UP. ROOM 131 Finished 10/18/2013LT.
FO-264649	10/16/2013	10/17/2013		Dean Jackson's door no longer locks. The key
FO-264675	10/17/2013	10/24/2013		Provide more access in wall 2ed floor outside mens toilet room . See Mike Pummill for location
FO-264680	10/17/2013	10/17/2013		REPAIR DOOR #016-03E - DOOR MISSING FASTENER ALSO ADJUST DOOR CLOSURE.
FO-264685	10/17/2013	10/18/2013		Adding Carpenters : Please remove and replace cabinet for Plumbers . See Mike Pummill for
FO-264701	10/17/2013	10/17/2013		CARPENTERS TO DEMO LIGHT TROUGHS IN THE WOMENS & MENS BATHROOMS FLO
FO-264741	10/17/2013	10/18/2013		Need 2 Handtrucks Assembled by 10-18-2013. This is a rush request.
FO-264789	10/18/2013	10/18/2013		High priority
FO-264790	10/18/2013	10/18/2013		High priority
FO-264822	10/18/2013	10/18/2013		2ND FL STAIRWELL 2E DOOR HANDLES OFF Finished 10/22/2013LT
FO-265120	10/22/2013	10/23/2013		DOOR WILL NOT CLOSE ON IT'S OWN. ROOM 230. Finished 10/25/2013LT
FO-265240	10/23/2013	10/23/2013		Mother of a student called Dean of Students
FO-265406	10/24/2013	10/25/2013		HANDICAL DOOR IS NOT WORKING. (EXTERIOR DOOR) Finished 10/28/2013
FO-265435	10/25/2013	10/25/2013		Adding Carpenters:R/R damaged ceiling tiles in room 318
FO-265496	10/25/2013	10/25/2013		CARPENTERS: Please repair exit doors 603 06 & 07 west. Doors would not open during fire d
FO-265503	10/25/2013	10/25/2013		New UGL Collaborative Study Room on Third Floor, Room 3542, door lock needs attention. D
FO-265560	10/28/2013	10/29/2013		the inside door for room 113 Receiving is not closing, the latch that is broken was not fixed an
FO-265591	10/28/2013			Replace lock body assembly on doublesided lock at East door of Cafe'.
FO-265598	10/28/2013			Adding Carpenters : PLease remove ceioling tiles ** See Mike McAlinden for location

WO	Recieved	Finished	Total	Request
FO-265670	10/28/2013	10/29/2013		CARPENTER TO REPLACE ALL WATER DAMAGED CEILING TILE 1ST FLOOR NEAR JA
FO-265692	10/28/2013	10/29/2013		Door was closed and mistakenly locked. Cannot find a key to unlock the door. Finished 10/30
FO-265679	10/28/2013			Adding Carpenters : R/R damaged ceiling tiles room 217
FO-265710	10/29/2013			Threshold strip by fireplace in first floor lobby was pushed to one side and is a trip hazard. Ple
FO-265719	10/29/2013	10/29/2013		Fix lens cover outside mens and womens restroom SAFETY ISSUE Finished 10/30/2013LT
FO-265747	10/29/2013	10/29/2013		CARPENTERS TO RE-ATTATCH DOOR HANDLE ROOM # 330 Finished 10/30/2013LT
FO-265831	10/30/2013			Please disassemble / Reassemble desk in engineers control office 1st floor to acess plumbing
T - Electrician			80	
FO-263391	10/1/2013	10/2/2013		Repair lights in room 018 Finished 10/4/2013LT
FO-263530	10/2/2013	10/2/2013		ELECTRICIANS,
FO-263660	10/3/2013	10/3/2013		Please disconnect acuator in basement mechanical room . See John for location Finished 10/
FO-263708	10/3/2013	10/3/2013		Disconnect lighting controller so Tech. can remove, and take to be repaired. Finished 10/4/20
FO-263736	10/4/2013	10/7/2013		There is a old EP in front of Stairwell B in Hallway. (3rd floor)
FO-263738	10/4/2013	10/11/2013		A few months ago, the Reuther Conference
FO-263760	10/4/2013	10/8/2013		Test, load test of the emergency generator outside bldg. near loading dock. Does the generat
FO-263776	10/4/2013	10/8/2013		ACTIVE FIRE TROUBLE ALARMFinished 10/9/2013LT
FO-263794	10/5/2013	10/7/2013		R/R RM 539 Recently a service request was entered to repair the lights so that they will shut o
FO-263801	10/5/2013	10/7/2013		R/R UNDER THE OVERHANG IN MAIN ENTRANCE on the outside of the building front entra
FO-263790	10/7/2013	10/8/2013		Repair sump pump controls motor / controlsFinished 10/9/2013LT
FO-263805	10/7/2013	10/8/2013		3RD FL GARDEN SPACE, POWER OUTLETS PULLED AWAY FROM WALLFinished 10/9/2
FO-263812	10/7/2013	10/21/2013		8 fixtures out in the storage room, basement , North East Corner. Contact Jody Cooper 577-4
FO-263854	10/7/2013			ELECTRICIANS-
FO-263880	10/7/2013	10/15/2013		Trade: Electricians
FO-263888	10/8/2013	10/8/2013		Re-wire domestic water booster pump . See Ron Clark for location if neededFinished 10/9/201
FO-263892	10/8/2013	10/8/2013		Electrician
FO-264025	10/9/2013	10/11/2013		4 fixtures out, 4th floor stairwell F. There are 4 EP's from the floor that exits to roof down to 4t
FO-264081	10/9/2013	10/10/2013		RM 027 LIGHT TIMER NEEDS TO BE REPAIRED Finished 10/11/2013LT
FO-264136	10/9/2013	10/10/2013		R/R RM 00016/BSMT MECH RM POWER FAIL ALARM W/EQUIP KEEPS ACTIVATING INSI
FO-264201	10/10/2013	10/10/2013		ELECT:please repair beeping light fix by elev PRIORITY:HIGH Finished 10/11/2013LT
FO-264242	10/11/2013	10/14/2013		Public Safety reported a trouble alarm. Engineer investigated. Found 'Operator open circuit'
FO-264295	10/11/2013	10/14/2013		BSMNT LIGHT BULBS NEED TO BE CHANGED Finished 10/16/2013LT
FO-264307	10/11/2013	10/11/2013		Meet PM Technologies at Comp. Ctr. and make sure Generator will transfer over. Finished 10/
FO-264332	10/12/2013	10/12/2013		Perform PM work on panels, and splices for machinery. Finished 10/14/2013LT
FO-264364	10/13/2013	10/14/2013		Trade: Electricians
FO-264368	10/14/2013	11/15/2013		R/R BLDG low oil pressure alarm on generator
FO-264372	10/14/2013	10/21/2013		LABORER (HIGH)
FO-264373	10/14/2013	10/18/2013		LABORER (HIGH)
FO-264433	10/14/2013	10/15/2013		electrician:
FO-264455	10/15/2013	10/14/2013		Repair roll up gate in back of building, parking area. Finished 10/16/2013LT
FO-264582	10/16/2013			Check fire system for low volume on alarm speakers on third floor, but check all floors, and no
FO-264630	10/16/2013	10/16/2013		It looks like a fuse has blown in the lunch room. The microwave will not turn on. Finished 10/1
FO-264650	10/16/2013	10/17/2013		Please wire pigtail to garbage disposal needed by Friday 10-18-13. See Mike Pummill Finishe
FO-264697	10/17/2013	10/17/2013		BSMNT LIGHT BULBS NEED TO BE CHANGED Finished 10/16/2013LT
FO-264698	10/17/2013	10/21/2013		Meet Steve at entrance of building (810) 836-2264 to move a sculpture, and you will need a 6'
FO-264720	10/17/2013	10/17/2013		Electrical receptacle at the east end of room 3028 is damaged. This is a teaching lab, so getti
FO-264731	10/17/2013	10/17/2013		The light switch on the north wall is shorting
FO-264742	10/17/2013	10/17/2013		Please hook up pigtail for welder in basement mechanical room 100. See Marty (Pipefitter) for

WO	Recieved	Finished	Total	Request
FO-264748	10/17/2013	10/18/2013		Please reconnect hot water tank in President's bathroom on Friday 10-18-13 before 1:00 PM .
FO-264769	10/17/2013	10/21/2013		RM 2144 BREAKERS TRIPPING..NO AIR FLOW IN HOOD Finished 10/22/2013LT
FO-264828	10/18/2013	10/18/2013		BSMNT FREEZER RM OUTLET SPARKS WHEN FREEZER CORD TOUCHED #9...RM IS T
FO-264890	10/19/2013			R/R RM 180 Please repair the fire panel trouble for Zone 8. This zone appears to consist of s
FO-264878	10/19/2013	10/19/2013		Power feeding the shed for grounds will be moved to a temporary box next to power hook up f
FO-264882	10/21/2013	10/23/2013		Fire Panel keeps going in alarm, and will not reset after several attempts. Finished 10/24/2013
FO-264900	10/21/2013	10/21/2013		Trade: Electrician Priority: High
FO-264917	10/21/2013	10/24/2013		Electricians (High)
FO-264943	10/21/2013	10/22/2013		RM 266 LIGHT SWITCH WONT TURN ON OR OFF Finished 10/22/2013LT
FO-264968	10/21/2013	10/21/2013		FAP TROUBLE ALARM Finished 10/22/2013LT
FO-264990	10/21/2013	10/21/2013		Connect motors, pumps, and controls along with Engineers, but they got job completed. Finis
FO-265014	10/22/2013	10/22/2013		Go to National Time, and pick up material. Finished 10/22/2013LT
FO-265055	10/22/2013	10/24/2013		ELECTRICIANS (HIGH)
FO-265075	10/22/2013	10/22/2013		WALL OUTLETS ARE NOT WORKING. ROOM 1233. Finished 10/22/2013LT
FO-265127	10/22/2013			BOX AT FRONT DESK, ALARM SOUNDING COMMUNICATION FAILED
FO-265186	10/23/2013	10/23/2013		R/R RM 197/CLASS RM LITE SENSOR KEEPS TURNING ON/OFF LITES Finished 10/24/20
FO-265201	10/23/2013	10/24/2013		Fire alarm "trouble".description "communication
FO-265211	10/23/2013	10/24/2013		ELECTRICIANS:
FO-265221	10/23/2013	10/23/2013		WALL OUTLETS ARE NOT WORKING. ROOM 300. Finished 10/24/2013LT
FO-265266	10/23/2013	10/23/2013		WALL OUTLETS ARE NOT WORKING. ROOM 306. Finished 10/24/2013LT
FO-265433	10/24/2013	10/28/2013		R/R STADIUM AUX BLDG TICKET BOOTH electric heaters in east ticket booth does not work
FO-265302	10/24/2013	10/24/2013		R/R BLDG TROUBLESHOOT FIRST Exterior: Sign on front of building has burned out lightbul
FO-265392	10/24/2013	10/25/2013		R/R RM 200.07 LITE TIMER DOESN'T WORK ON AUTO ONLY LETS YOU CHNG MANUAL
FO-265517	10/25/2013	10/25/2013		Move Generator so contractors can tear down shed, and move wire to hook back up to genera
FO-265531	10/25/2013	10/25/2013		please pick up Geni lift from UGL and deliver to prentiss (fishbowl) Finished 10/28/2013
FO-265559	10/26/2013	10/28/2013		Electricians - Please repair/clear the alarm on the fire panel that shows "power loss" to the fire
FO-265579	10/28/2013			Trade: Electrician Priority: HighTag#089-AHU-003R/R RM 6149/MECH RM Investigate wh
FO-265619	10/28/2013	10/29/2013		Replace lamps, and covers to fixtures in corridor leading to basement. Ladder and material is
FO-265623	10/28/2013	10/28/2013		R/R RM 1800 LOSS POWER IN WALL OUTLETS Finished 10/30/2013LT
FO-265636	10/28/2013			Fan will not start, checked fuses and all are OK
FO-265644	10/28/2013	10/28/2013		Trade: Electricians
FO-265688	10/28/2013			Several electrical wall outlets are not working.....
FO-265682	10/28/2013			Reset pump on trailer and move to inside Pipefitter 3rd floor lock up . See Ron Clark
FO-265706	10/29/2013	10/29/2013		LIGHTS WILL NOT COME ON. ROOM 2156.
FO-265737	10/29/2013	10/29/2013		RM 1309 ELECTRICAL OUTLET NOT WORKING Finished 10/30/2013LT
FO-265765	10/29/2013			Repair light fixtures in conferance room 4 downstairs. Maike this your first Job Wednesday m
FO-265814	10/30/2013			There are 3 troubles on the system, clear troubles, and reset to normal.
FO-265825	10/30/2013			R/R RM 200.07 NEWLY REPLACED LITE TIMER STOPPED WORKING SAME PROBLEM A
FO-265838	10/30/2013			R/R BLDG CK CIRCUIT BREAKER FOR The Wayne State lights on the Mack side of the buil
FO-265882	10/30/2013			LABORER TO TRANSPORT THE 1 MAN LIFT FROM PRENTIS TO MATTHAIE MAIN GYMS
FO-265912	10/30/2013			Adding Electricians: Disconnect / Reconnect hot water heater on 10-31-13 AM . See Ray Ban
T - Laborer			2	
FO-264981	10/21/2013			Adding Laborer : Please set up scaffold for Plumbers in mechanical room 100 . See Roy Caloi
FO-265095	10/22/2013	10/23/2013		Meet Sorenson Gross Wednesday morning at 10AM with the Hi-Lo, and assist them with movi
T - Locksmith			11	
FO-263662	10/3/2013	10/3/2013		74973 1 KEY Finished 10/4/2013 LT
FO-264197	10/10/2013	10/11/2013		74717 2 KEYS Finished 10/14/2013LT
FO-264466	10/15/2013	10/15/2013		74994 2-Keys Finished 10/18/2013LT

WO	Recieved	Finished	Total	Request
FO-264467	10/15/2013	10/15/2013		74995 1-Key Green Van Hockey Puck Lock Finished 10/18/2013LT
FO-264766	10/17/2013	10/17/2013		75010 6-KEYS Finished 10/18/2013LT
FO-264886	10/21/2013	10/29/2013		Make up a lock with the 14 key. Finished 10/30/2013LT
FO-265168	10/23/2013	10/23/2013		75014 Key will not open lock in room 255 Matthaei. Key number 29962. Inspect lock. Please s
FO-265570	10/28/2013	10/29/2013		75017 1 Core 2-Keys Room 2618 Finished 10/30/2013LT
FO-265859	10/30/2013			75022 2-KEYS Room 0363
FO-265877	10/30/2013			#74541 4 Keys and 1 Core Room 2248
FO-265928	10/30/2013			Both doors to the Primary Electrical rooms are stuck closed, we couldn't turn the lock to unloc
T - Painter			1	
FO-264147	10/9/2013	10/11/2013		MUDD & PAINT SOUTH WEST STAIRWELL 1ST FLOOR LANDING LOWER WALL REPAIR
T - Pipefitter			38	
FO-263415	10/1/2013	10/2/2013		CEILING LEAK OVER TABLE #2. ROOM 310,,,,,,,,,,,,, ME/10-2-13 ,,,,,,,,,, DUE 10-3-13
FO-263572	10/2/2013	10/7/2013		RM 0121 CEILING LEAK ,,,,,,,,,, EA/RC 10-2-13 ,,,,,,,,,, DUE 10-5-13Finished 10/9/2013
FO-263724	10/3/2013	10/4/2013		R/R flange leak on 3" water line ,,,,,,,,,, ME/10-3-13 ,,,,,,,,,, DUE ASAP Finished 10/7/2
FO-263622	10/3/2013	10/3/2013		FITTERS (HIGH)
FO-263764	10/4/2013	10/4/2013		Water dripping from ceiling defuser in women's bathroom near business services. See Sandy
FO-263804	10/7/2013	10/8/2013		BSMNT BETWEEN RM 50&53 CEILING LEAK,,,,,,,,,,,,, JH/ 10-7-13 ,,,,,,,,,, DUE 10-9-13
FO-263836	10/7/2013	10/11/2013		leak from ceiling happening again in Suite 1600 nearest to Advising Reception Counter.
FO-263867	10/7/2013	10/8/2013		HALLWAY OUTSIDE RM 32 CEILING LEAK,,,,,,,,,,,,, ME/10-8-13 ,,,,,,,,,, DUE 10-9-13Fi
FO-263905	10/8/2013	10/11/2013		Radiator is dripping from where valve connects to radiator. This radiator has leaked significan
FO-264269	10/11/2013	10/11/2013		HALLWAY OUTSIDE OF RM 14001 CEILING LEAK ,,,,,,,,,, Finished 10-11-13 JWT / Du
FO-264442	10/14/2013	10/15/2013		FITTERS,
FO-264482	10/15/2013	10/15/2013		Evaluate winterization of chill water coils through entire building ,,,,,,,,,, ME/10-15-13 ,,,,,,,,,
FO-264506	10/15/2013	10/16/2013		Repair steam leak to cagewasher,,,,,,,,,,,,, JH/10-16-13 ,,,,,,,,,, DUE 10-18-13 Finished 10
FO-264520	10/15/2013	10/18/2013		Ceiling leak on the 2nd floor in front of the freight elevator. (reported by custodial person),,,,,,,,,
FO-264676	10/16/2013	10/16/2013		Please assist in portable chiller removal ,,,,,,,,,, EA/RC 10-16-13 ,,,,,,,,,, DUE 10-18-13
FO-264587	10/16/2013	10/16/2013		CEILING LEAK. CLASSROOM 2028. BEST HOURS 9:00 A.M. UNTIL 10:30 A.M. AND 1:00
FO-264621	10/16/2013	10/18/2013		Fitters; replace approx. one foot pipe section the one inch pipe has a pinhole leak the pipe is o
FO-264635	10/16/2013	10/17/2013		Install actuator on pool fill / safety butterfly valve ,,,,,,,,,,JH/10-16-13 ,,,,,,,,,, DUE 10-18-13
FO-264647	10/16/2013	10/18/2013		CEILING TILE IS WET. ROOM 326,,,,,,,,,,,,, JH/10-18-13 ,,,,,,,,,, DUE 10-18-13 Finished
FO-264737	10/17/2013	10/18/2013		PLUMBER:please repair badly leaking soft water make-up line to feedwater tank.PRIORITY:H
FO-264777	10/17/2013	10/18/2013		Please cut 3" blinds for Mike Pummill natural gas project ,,,,,,,,,, JH/10-18-13,,,,,,,,,,,,,DU
FO-264817	10/18/2013	10/22/2013		fitters, repair leak in a hydronic heating coil in the duct for the Peacock room. there is a big ev
FO-264842	10/18/2013	10/18/2013		RM 2025 CEILING LEAK, TILE COLLAPSED,,,,,,,,,,,,, JH /10-18-13 ,,,,,,,,,, DUE 10-21-1
FO-265099	10/21/2013	10/21/2013		Install chemical quill in D.A. tank ,,,,,,,,,, EA/10-21-13 ,,,,,,,,,, DUE 10-23-13 Finished 10
FO-265056	10/22/2013	10/25/2013		FITTERS (HIGH)
FO-265076	10/22/2013	10/25/2013		HEATING SYSTEM LEAKING. STACK AREA NEAR ELEVATOR. ROOM 320,,,,,,,,,,,,, EA/
FO-265276	10/22/2013	10/22/2013		Evaluate needed material for winterization of chill water coils throughout building ,,,,,,,,,, ME/
FO-265242	10/23/2013	10/23/2013		Evaluate needed material for winterization of chill water coils throughout building ,,,,,,,,,, ME
FO-265508	10/23/2013	10/23/2013		R/R Steam coil leaks in arpartment mechanical room ,,,,,,,,,, EA/RC 10-23-13 ,,,,,,,,,, DUE
FO-265267	10/23/2013	10/24/2013		Evaluate needed material for winterization of chill water coils ,,,,,,,,,, ME/10-23-13 ,,,,,,,,,,
FO-265442	10/24/2013			Evaluate needed material to winterize chill water coils throughout building ,,,,,,,,,, ME/10-2
FO-265445	10/24/2013	10/25/2013		Evaluate needed material to winterize chill water coils throughout building ,,,,,,,,,, ME/10-2
FO-265371	10/24/2013			Trade: Pipefitters
FO-265378	10/24/2013	10/25/2013		Fitters, please repair leak in condensate line behind AHU-4 ,,,,,,,,,, ME/10-25-13 ,,,,,,,,,,
FO-265389	10/24/2013			Evaluate needed material for winterization of chill water coils ,,,,,,,,,, CB 10-24-13 ,,,,,,,,,,
FO-265455	10/25/2013	10/28/2013		Trade: Pipefitter Priority: High
FO-265592	10/28/2013	10/28/2013		1. Ceiling in men's restroom on the 1st floor fell in over the weekend. Custodian threw out tile.

WO	Recieved	Finished	Total	Request
FO-265779	10/30/2013			Leak in condensate return line in penthouse mech rm. Priority = High
T - Plumber			74	
FO-263353	10/1/2013	10/4/2013		Plumbers. High Priority. Repair leaking glass drain line in ceiling room 3227,,,,,,,,,,,,, MM/9-
FO-263356	10/1/2013	10/1/2013		this is a mens room restroom that has water all over the bathroom floor
FO-263361	10/1/2013	10/1/2013		**TOILET WON'T FLUSH. MEN'S RESTROOM NEXT TO ROOM 5625,,,,,,,,,,,,, MM/10-1-
FO-263384	10/1/2013			**CEILING LEAK. ROOM 3272,,,,,,,,,,,,, MM/10-1-13,,,,,,,,,,,,, DUE 10-3-13
FO-263565	10/2/2013	10/3/2013		Third floor bathroom by front stairs - toilet is leaking from the tank when it is flushed, causing
FO-263571	10/2/2013	10/9/2013		PLUMBERS:
FO-263584	10/2/2013	10/3/2013		R/R RM 126 WOMENS RR (Bus Svcs' Side) 1ST STALL (HANDICAP) FLUSH VLV IS SQUIR
FO-263641	10/3/2013	10/4/2013		Room 306, sink in the bathroom is clogged. It will not drain. Please repair,,,,,,,,,,,,, RJC/RB 1
FO-263650	10/3/2013	10/4/2013		R/R RM 3025.10 ONLY Eyewash does not work properly. Little or no water flow. Does not ap
FO-263663	10/3/2013	10/7/2013		**RM 6255 COLD WATER HANDLE IS FROZEN, WONT TURN ON,,,,,,,,,,,,, MM/10-7-13 ,,,,
FO-263713	10/3/2013	10/4/2013		Sink in room 336 is clogged and overflowing causing water to seep into the room below (236),,
FO-263727	10/4/2013	10/4/2013		TOILET OVERFLOWING. 1ST FLOOR WOMEN'S RESTROOM,,,,,,,,,,,,, RJC/RB 10-4-13 ,
FO-263740	10/4/2013	10/7/2013		TOILET OVERFLOWING. 1ST FLOOR MEN'S RESTROOM,,,,,,,,,,,,, MP/DB 10-4-13 ,,,,,,
FO-263748	10/4/2013	10/7/2013		PLUGGED TOILET. 6TH FLOOR LADIES RESTROOM (NEAR WOODWARD),,,,,,,,,,,,,, MP/
FO-263769	10/4/2013	10/7/2013		**URINAL IS OVERFLOWING. MEN'S RESTROOM. ROOM. 2238,,,,,,,,,,,,, RJC/RB 10-7-
FO-263772	10/4/2013	10/7/2013		**BAD FAUCET LEAK. KITCHEN ROOM 4011,,,,,,,,,,,,, MP/DB 10-7-13,,,,,,,,,,,,, DUE 10-7-13
FO-263831	10/7/2013	11/8/2013		BSMNT LADIES RM 2ND STALL TOILET CONTINUOUSLY FLUSHING,,,,,,,,,,,,, RJC/RB
FO-263875	10/7/2013	10/8/2013		1ST FL MENS RM TOILET OVERFLOWS,,,,,,,,,,,,, MP/DB 10-8-13,,,,,,,,,,,,, DUE 10-9-13F
FO-263899	10/8/2013	10/8/2013		CEILING LEAK. ROOM 454,,,,,,,,,,,,, ME/ 10-8-13,,,,,,,,,,,,, DUE 10-10-13Finished 10/9/2
FO-263928	10/8/2013	10/8/2013		13th FL WOMENS TOILET CONTINUOUSLY FLUSHING,,,,,,,,,,,,, MP/DB 10-8-13 ,,,,,,
FO-263950	10/8/2013	10/14/2013		PLUMBERS,
FO-263994	10/8/2013	10/9/2013		faucet in sink is leaking. Not a drip, a strong leak.
FO-264111	10/9/2013	10/11/2013		FAUCET LEAK. ROOM 8123,,,,,,,,,,,,, MM/10-9-13,,,,,,,,,,,,, DUE 10-12-13 Finished 10/14/2
FO-264123	10/9/2013	10/9/2013		RM 410 ONLY SINK HAS NO WTR,,,,,,,,,,,,, MM/10-9-13,,,,,,,,,,,,, DUE 10-10-13 ASAP Fi
FO-264124	10/9/2013	10/10/2013		RM 6322 SINK LEAKING,,,,,,,,,,,,, MM/10-9-13,,,,,,,,,,,,, DUE 10-10-13 ASAP Finished 10/11
FO-264138	10/9/2013	10/10/2013		HEATER UNIT REPAIR IN 5100.3 UNISEX RESTROOM. HEATER LEAKING WATER CAUSI
FO-264152	10/9/2013	10/15/2013		In the Women's restroom, near South Eastern exit and stairs the last stall (furthest from the d
FO-264164	10/10/2013	10/10/2013		R/R RM 1111/CLASS RM HAS A CLNG LEAK (FCU?) W/CLNG TILES BULGING W/WTR ,,,,
FO-264171	10/10/2013	10/10/2013		R/R 2ND FLR #2 DRESSING RM SNAKE OUT ONLY SINK THAT IS PLUGGED & FILLED T
FO-264190	10/10/2013	10/11/2013		1st floor mens room 1234 - someone bagged toilet and urinal and put a closed sign on the do
FO-264326	10/11/2013	10/14/2013		Building: Biological Science
FO-264360	10/14/2013	10/14/2013		1ST FL KITCHEN AREA SINK IS LEAKING FROM BOTTOM,,,,,,,,,,,,, Finished 10-14-13 / D
FO-264366	10/14/2013	10/15/2013		10TH FL WOMENS RM NEAR ELEV, TOILET BACKED UP,,,,,,,,,,,,, MP/DB 10-14-13 ,,,,,,
FO-264384	10/14/2013	10/15/2013		Plumbers: Please replace the corroded and leaking drain line udderneath the sink in the kitche
FO-264509	10/15/2013	10/16/2013		UNISEX RESTROOM WITHIN 249 TOILET PLUGGED PLEASE COME BEFORE 9:00AM ,,,,,,
FO-264651	10/16/2013	10/18/2013		LAB 416 UNABLE TO TURN OFF HOT WATER,,,,,,,,,,,,, MP/DB 10-18-13,,,,,,,,,,,,, DUE AS
FO-264682	10/17/2013	10/18/2013		No hot water in President bathroom at Stadium,,,,,,,,,,,,, MP/DB 10-17-13,,,,,,,,,,,,, DUE 10
FO-264694	10/17/2013			Plumbers - high priority - safety issue. Please replace non-functioning check valve on high pr
FO-264719	10/17/2013	10/18/2013		PLUMBERS TO FASTEN SINK TO THE WALL, EXTREMELY LOOSE. 4TH FLOOR UNISEX
FO-264918	10/21/2013	10/22/2013		Sink in unisex bathroom, room 167 in the northwest end of the Lobby, is clogged. Please uncl
FO-265093	10/21/2013	10/22/2013		Assist in water main leak,,,,,,,,,,,,, MP/DB 10-21-13,,,,,,,,,,,,, DUE 10-23-13 Finished 10/25/2
FO-264960	10/21/2013	10/23/2013		RM 226 GARBAGE DISPOSAL NOT WORKING,,,,,,,,,,,,, MP/DB 10-22-13,,,,,,,,,,,,, DUE
FO-264998	10/22/2013	10/23/2013		Plumbers:
FO-265046	10/22/2013	10/25/2013		R/R ceiling leak in suite 200 DLAR,,,,,,,,,,,,, MM/10-22-13,,,,,,,,,,,,, DUE 10-24-13 Finished 1
FO-265070	10/22/2013	10/23/2013		6TH FL UNISEX RESTROOM TOILET PLUGGED. PLEASE CHECK WATER PRESSURE O

WO	Recieved	Finished	Total	Request
FO-265074	10/22/2013	10/25/2013		PLUMBERS (HIGH)
FO-265079	10/22/2013	10/23/2013		#5 FUME HOOD IS LEAKING. ROOM 3040 ,,,,,,,,,,,,,, MP/DB 10-23-13 ,,,,,,,,,,,,,, DUE 10-24
FO-265102	10/22/2013	10/25/2013		CLOGGED TOILET. 1ST FLOOR UNISEX RESTROOM. GROUNDS DEPT.,,,,,,,,,,,,,, RJC/R
FO-265105	10/22/2013	10/23/2013		TOILET LEAK. 2ND FLOOR MEN'S RESTROOM.,,,,,,,,,,,,,, MP/DB 10-23-13,,,,,,,,,,,,, DUE
FO-265111	10/22/2013	10/23/2013		lots of water leaks when flushed
FO-265115	10/22/2013	10/24/2013		Repair toilet located behind reception desk. Power-flush type residential toilet, will not stop run
FO-265178	10/23/2013	10/23/2013		CEILING LEAK. HALLWAY OUTSIDE OF ROOM 200.15.,,,,,,,,,,,,,, Finished 10-23-13 JWT /
FO-265245	10/23/2013	10/24/2013		Install heating element in hot water tank that Eugene had requested,,,,,,,,,,,,, MP/DB 10-23-
FO-265376	10/24/2013			PLUMBERS PLEASE REPAIR CRACK SHOWER BASE SEAL,WOMEN LOCKER RM. WITH
FO-265377	10/24/2013	10/25/2013		Plumbers, please snake drain in front of AHU-3 chill coils. Priority: high ,,,,,,,,,,,,,, MM/10-25
FO-265373	10/24/2013	10/24/2013		TOILETS ARE CONTINUOUSLY FLUSHING. 13TH FLOOR.,,,,,,,,,,,,,, Finished 10-24-13 Du
FO-265381	10/24/2013	10/24/2013		TOILET NOT FLUSHING. 12TH FLOOR LADIES RESTROOM NEAR ELEVATOR.,,,,,,,,,,,,,,
FO-265383	10/24/2013	10/24/2013		8TH FL UNISEX RESTROOM TOILETS NOT FLUSHING ,,,,,,,,,,,,,, Finished 10-24-13 Dupli
FO-265480	10/25/2013	10/25/2013		LOW WATER PRESSURE. 13TH FLOOR.,,,,,,,,,,,,,, MP/DB 10-25-13 ,,,,,,,,,,,,,, DUE 10-28-1
FO-265593	10/28/2013			2. Urinal in men's restroom on the 2nd floor on the eastwing won't flush. ,,,,,,,,,,,,,, RJC / R
FO-265612	10/28/2013			3RD FL MENS RM WATER TOO HOT ,,,,,,,,,,,,,, MP/DB 10-28-13 ,,,,,,,,,,,,,, DUE 10-30-13
FO-265613	10/28/2013			3RD FL MENS RM SINK ON LEFT WATER CONTINUOUSLY RUNNING ,,,,,,,,,,,,,, MP/DB
FO-265652	10/28/2013	10/29/2013		4th floor ladies room second stall/ water is spraying out from handel when flushing the toilet (t
FO-265681	10/28/2013	10/28/2013		R/R stuck isolation valve to backflow preventer on perimeter heat . System cannot be filled ,,,,,,
FO-265696	10/29/2013			URINALS ARE NOT FLUSHING. BASEMENT ROOM 50, 3RD FLOOR AND 5TH FLOOR.,,,,,,
FO-265727	10/29/2013	10/29/2013		MENS 2ND FL AND WOMENS 3RD FL TOILETS CONTINUOUSLY RUNNING ,,,,,,,,,,,,,, RJ
FO-265732	10/29/2013	10/29/2013		MENS RM 7101 SINK CLOGGED ,,,,,,,,,,,,,, MM/10-29-13 ,,,,,,,,,,,,,, DUE 10-31-13 Finished
FO-265746	10/29/2013	10/30/2013		SINK OVERFLOWING. 7TH FLOOR MEN'S RESTROOM.,,,,,,,,,,,,,, MM/10-29-13 ,,,,,,,,,,,,,,
FO-265750	10/29/2013			5TH FLOOR MEN'S RESTROOM URINALS ARE NOT FLUSHING.,,,,,,,,,,,,,, RJC/RB 10-29-1
FO-265751	10/29/2013			5TH FLOOR WOMEN'S RESTROOM TOILETS ARE NOT FLUSHING.,,,,,,,,,,,,,, RJC/RB 10
FO-265770	10/29/2013			FAUCET WATER IS VERY HOT AND MAKING BEEPING SOUND. 3RD FLOOR MEN'S RE
FO-265822	10/30/2013			Order, and replace Gas Regulator for Generator.
FO-265853	10/30/2013			2ND FL LADIES RM 2234 BIG STALL TOILET LEAKING FROM BASE, SMALL STALL HAS
FO-265895	10/30/2013			First floor men's room, the larger stall toilet is badly clogged ,,,,,,,,,,,,,, RJC/RB 10-30-13 ,,,,,,
Medium			243	
T - Carpenter			55	
FO-263539	10/2/2013	10/7/2013		Please repair the floor tile in the hallway outside room 1205.Finished 10/9/2013LT
FO-263548	10/2/2013	10/8/2013		Carpenter; Medium
FO-263550	10/2/2013	10/9/2013		Carpenter; Medium
FO-263560	10/2/2013	10/2/2013		R/R RM 2103 ENT DOOR OIL/ADJUST DOOR DUE TO IT IS SQUEAKING/SQUEALIN Finis
FO-263575	10/2/2013	10/3/2013		Crash Bar on rear exit door is sticking in the open position. Finished 10/4/2013 LT
FO-263679	10/3/2013	10/4/2013		Replace 3 ceiling tiles that were damaged when
FO-263716	10/4/2013			North garage door not operating properly (will not close).
FO-263774	10/4/2013	10/7/2013		BACK DOOR STICKS.Finished 10/9/2013LT
FO-263840	10/7/2013	10/7/2013		Door needs to be plane down as rubbing and hard to open.
FO-263967	10/9/2013	10/9/2013		Locksmith. Medium Priority. Repair north entrance door to boiler room-due to door not locking
FO-264017	10/9/2013	10/10/2013		PLEASE REPLACE MISSING CEILING TILES. ROOMS 296 AND 296.1. Finished 10/11/201
FO-264224	10/10/2013	10/11/2013		R/R RM 418.10 ADJUST DOOR/DOOR CLOSURE The door is out of alignment and needs att
FO-264243	10/10/2013	10/11/2013		Locksmith. Medium Priority. Repair broken handle on entrance door (handle located in engine
FO-264276	10/11/2013	10/14/2013		R/R RM 105 Please reapiir the following lockers at the football stadium...#6 & #41 - & Coach P
FO-264309	10/11/2013	10/17/2013		Ceiling tiles need replacing in hallways near rooms:
FO-264376	10/14/2013	10/16/2013		UNISEX 4TH FLOOR THE SINK IS LOOSE FROM THE WALL. PLEASE REPAIR. Finished 1

WO	Recieved	Finished	Total	Request
FO-264383	10/14/2013			Fix blind that has broken-off its mounting in
FO-264387	10/14/2013	10/16/2013		Carpenters: Please repair The handicap door opener on entrance door #(016 14 W), the door s
FO-264410	10/14/2013	10/15/2013		The exterior doors on the north side of the lobby (620-07-N and 620-08-N) are not closing and
FO-264420	10/14/2013	10/16/2013		Please inspect all basketball rims & backboards for the WSU Basketball season, (Check all ri
FO-264468	10/15/2013	10/17/2013		A ceiling tile fall out. Needs to be put back.
FO-264469	10/15/2013	10/16/2013		Replace damaged ceiling tile behind door room 322 Finished 10/18/2013LT
FO-264498	10/15/2013	10/23/2013		Carpenters please replace missing ceiling tiles in west hallways on fourth floor. Finished 10/25
FO-264512	10/15/2013	10/18/2013		ceiling tile Med. Priority
FO-264533	10/15/2013	10/16/2013		6TH FL W. WING LOBBY DOORS METAL PLATE AROUND DOOR LOCK LOOSE, MISSIN
FO-264590	10/16/2013	10/18/2013		Carpenters:
FO-264600	10/16/2013	10/18/2013		JANITOR CLOSET #13 KEY STICKS IN LOCK AND TUMBLER WILL NOT TURN. PLEASE
FO-264607	10/16/2013	10/17/2013		Office 489.1 - Door will not lock when closed. Finished 10/18/2013LT
FO-264610	10/16/2013	10/17/2013		1ST FL LADIES RM DOOR SQUEAKS WHEN OPENED, HARD TO OPEN Finished 10/18/20
FO-264612	10/16/2013	10/17/2013		Door handle is very loose. Feels like it's ready to fall off. Needs repair. Thank you. Finished
FO-264657	10/16/2013	10/17/2013		RM 121 PROJECTION SCREEN TORN Finished 10/18/2013LT
FO-264716	10/17/2013	10/17/2013		R/R HALLWAY Door leading from 1510 to 1535 (loading dock) has a push bar that is hanging
FO-264725	10/17/2013	10/18/2013		In the EDC wing the double doors facing west to Kummier Commons has the middle metal ho
FO-264733	10/17/2013			Please replace the stained and dirty, partially
FO-264735	10/17/2013			CARP:please replace missing ceiling tile in hallway.PRIORITY:REG
FO-264736	10/17/2013	10/18/2013		Repair broken door stop on entrance door to room 128 Matthaei. See Bob OStrowski if neede
FO-264738	10/17/2013	10/18/2013		CARPENTERS: Please repair panic bar on the inner DOCK door leading to hallway. MED. Fini
FO-264767	10/17/2013	10/18/2013		Adding Carpenters: Replace stained ceiling tiles basement hallway outside room 008
FO-264787	10/18/2013	10/18/2013		CARPENTER TO LUBE & CLOSE WINDOW ROOM # 0354 FACING THE SOUTH TOWARD
FO-264871	10/18/2013	10/22/2013		Room 2020 & 2020A are connecting rooms. Partition brackets need anchor and seal for both
FO-265015	10/22/2013	10/24/2013		Adding Carpenters : Replace stained ceiling tiles in room 326 Finished 10/25/2013LT
FO-265017	10/22/2013	10/29/2013		Adding Carpenters: replace ceiling tiles in room 2025
FO-265044	10/22/2013	10/29/2013		Adding Carpenters: Replaced stained tiles in room 304
FO-265053	10/22/2013	10/24/2013		Adding Carpenters: Repair backing and drywall so Painters can be added.
FO-265112	10/22/2013	10/23/2013		LOCKSMITH,
FO-265083	10/22/2013	10/24/2013		DOOR IS NOT CLOSING. ENTRANCE DOOR TO SERVICE CENTER. Finished 10/25/2013
FO-265163	10/23/2013	10/25/2013		Carpenters; Medium
FO-265359	10/24/2013	10/24/2013		5th floor east freight elevator pedestrian door stays ajar. Latch plate is missing a machine scr
FO-265431	10/25/2013			Adding Carpenters: Please R/R counter top see Mike McAlindin for direction
FO-265512	10/25/2013			Trade: CarpentersPriority: MediumR/R W STRWL 1ST FLR Please repair loose hand rail
FO-265532	10/25/2013			please chk on broken floor tiles in the 3rd floor restroom (313) noticed broken floor tiles when r
FO-265674	10/28/2013			Wall repair needed outside of ladies room 106 and inside of men's room 104 of the atrium. It l
FO-265739	10/29/2013			1st floor, stairwell G, door handle is missing/off
FO-265771	10/29/2013			Remove two red lock-out locks from boiler
FO-265890	10/30/2013			Pls build a chemical feed station in the boiler room, for drums as nesc..
T - Electrician			49	
FO-263372	10/1/2013	10/1/2013		Medium: Refer to FO#262967:
FO-263559	10/2/2013	10/8/2013		Laborer Med Priority
FO-263566	10/2/2013	10/4/2013		Electricians:
FO-263574	10/2/2013	10/8/2013		Electricians:
FO-263578	10/2/2013	10/7/2013		Lights in this room do not work. We are sure that it not due to burned light bulbs, because non
FO-263587	10/2/2013	10/3/2013		R/R 2ND FLR BTWN THE MAIN STAIRS & STUDY RM AREA (going towards the back) CLN
FO-263627	10/3/2013	10/8/2013		Electrician

WO	Recieved	Finished	Total	Request
FO-263659	10/3/2013	10/3/2013		Pick up 8" gate valve and deliver back to Stock Room . See Marty for location Finished 10/4/2
FO-263759	10/4/2013	10/9/2013		All emergency light units and exit signs need to be tested and batteries replaced. None of the
FO-263789	10/5/2013	10/29/2013		Follow up to PM FO-261483
FO-263796	10/7/2013	10/7/2013		Repair light fixture in attic for Fitters.Finished 10/9/2013LT
FO-263809	10/7/2013	10/7/2013		Basement NE corner of building, in the storage room fixtures have been tagged more than a y
FO-263862	10/7/2013			Entire building is very warm, 3rd and 4th temperatures are reaching 84 degrees. Please adjus
FO-263887	10/8/2013	10/9/2013		Please check for power on lighting behind AHU-7 several lights in area do not work Finished 1
FO-263898	10/8/2013	10/9/2013		Laborer Med. Priority
FO-263917	10/8/2013			Electricians - Medium.
FO-264148	10/9/2013	10/14/2013		R/R RM 152/LAB TROUBLESHOOT CIRCUIT BREAKER THAT POWERS SOUTH WALL OU
FO-264159	10/10/2013			Maint. Laborer
FO-264160	10/10/2013			MAINT. LABORER
FO-264161	10/10/2013			Maint. Laborer
FO-264162	10/10/2013			Maint. Laborer
FO-264358	10/14/2013	10/16/2013		Adding Electrician: Please check sticking switch see Mike McAlinden or Al Kotel if needed for I
FO-264421	10/14/2013			Card Reader (4) wiring to switchboard room. Time not to exceed 20 hrs.
FO-264573	10/15/2013	10/22/2013		Electrical
FO-264574	10/15/2013			Electrician
FO-264696	10/17/2013	10/17/2013		Please have Maintenance Laborer pick up 2 long (8 ft.) heavy boxes from Purchasing departm
FO-264778	10/17/2013	10/18/2013		Please pick up drinking fountain/bottle filler from Holdon Trades lock up and deliver to Old Mai
FO-264902	10/21/2013			Laborer- remove old sheaves and bushings by boilerroom door.
FO-264887	10/21/2013			Light fixture hanging , room 9364 Finished 10/22/2013LT
FO-264905	10/21/2013	10/23/2013		R/R LIGHTS IN THE BASEMENT NORTH - EAST CORNER STORAGE ROOM. Finished 10/
FO-264954	10/21/2013	10/23/2013		Trade: Electrician Priority: Medium
FO-265183	10/23/2013	10/24/2013		Trade: Electrician Priority: Medium
FO-265237	10/23/2013			Electrical- please replace mechanical room ballast by expantion tank in penthouse, 3 are need
FO-265241	10/23/2013			Electrician; Medium
FO-265311	10/24/2013			please deliver and assist plumbers with water booster pumps(see me for more info)
FO-265344	10/24/2013	10/28/2013		Electricians:
FO-265396	10/24/2013	10/25/2013		R/R RM 3141.2 RESET BREAKER (she's leaving soon however would like someone to reset
FO-265411	10/24/2013			RM 240 WINDOW HEATER NOT WORKING
FO-265526	10/25/2013			pls remove misc file cabnets and scrap metal from comp center equipment room
FO-265604	10/28/2013	10/28/2013		Call Wolverine Power out to repair alarm at generator. Finished 10/30/2013LT
FO-265625	10/28/2013			Please repair 9 troubles in system.
FO-265662	10/28/2013			Please re-caulk electrical power outlet in pool deck by lane #2. (this was not recaulked after th
FO-265669	10/28/2013			TOO COLD. ROOM 3315.
FO-265689	10/29/2013	10/29/2013		ELECTRICIANS TO DROP EMERGENCY EXIT SIGN TO REPLACE WATER DAMAGED CE
FO-265730	10/29/2013			Electrician; Medium
FO-265731	10/29/2013			RESTROOM 2438 HAND DRYER NOT WORKING
FO-265745	10/29/2013			Work with DTE to get access to building electrical meters.
FO-265848	10/30/2013			First floor hallway outside room 1208 - West face of dual faced simplex clock 1 hour too fast -
FO-265849	10/30/2013			Please program simplex clock system to accommodate daylight savings time that will take pla
T - Locksmith			7	
FO-263403	10/1/2013	10/7/2013		Request #74968 desk key K-093Finished 10/9/2013LT
FO-263581	10/2/2013	10/8/2013		One (1) - Best OE54 PadLock and (2) OE54 KeysFinished 10/9/2013LT
FO-263942	10/8/2013	10/10/2013		74860 4 KEYS AND 1 CORE Finished 10/11/2013LT
FO-264687	10/17/2013	10/17/2013		75009 10 KEYS Finished 10/18/2013LT

WO	Recieved	Finished	Total	Request
FO-265246	10/23/2013	10/24/2013		R/R lock on room 162 key is broke off in lock Finished 10/25/2013LT
FO-265409	10/24/2013			75015 19 Keys
FO-265697	10/29/2013	10/29/2013		75019 1-CORE ROOM 3139 Finished 10/30/2013LT
T - Painter			5	
FO-263387	10/1/2013			Purdy Library 3rd Floor, north west corner windows.
FO-263400	10/1/2013	10/23/2013		PAINT CHIP FALLING FROM CEILING IN CORRIDOR NEAR LECTURE HALL 1343. Finishe
FO-263680	10/3/2013			Repair drywall on ceiling of rooms 206 and 202
FO-264677	10/16/2013			Reference WO #FO-256730. Work was turned over to Mario Sanchez for evaluation of repair
FO-265678	10/28/2013			NW Corridor on the 3rd floor just outside of lab 330 needs the wall repaired and repainted. PI
T - Pipefitter			47	
FO-263775	10/4/2013	10/7/2013		**Fitters, please replace auto air vent on chilled water line on AHU-1 in basement mechanical
FO-264464	10/7/2013	10/24/2013		Evaluate winterization of chill water coils through entire building ,,,,,,,,,, JH/10-7-13 ,,,,,,,,,,
FO-263817	10/7/2013	10/16/2013		Trade: Pipefitter Priority: Medium
FO-263815	10/7/2013	10/15/2013		Trade: Pipefitter Priority: Medium
FO-263951	10/8/2013	10/11/2013		FITTERS,
FO-264139	10/9/2013	10/14/2013		Adding Pipefitters : See Don Bear for location and discription of support needed,,,,,,,,,,,,,,,,,EA/
FO-264144	10/9/2013	10/10/2013		FITTERS,
FO-264172	10/10/2013	10/18/2013		Fitters Med Priority
FO-264185	10/10/2013	10/10/2013		FITTERS,
FO-264206	10/10/2013	10/17/2013		BSMNT ANIMAL QUARTERS TAP HOT WATER COMING OUT DANGEROUSLY HOT ,,,,,,,,,,
FO-264222	10/10/2013	10/14/2013		R/R RM 322 CLNG IS LKNG (CLNG TILES HAVE FALLEN),,,,,,,,,, EA/10-10-13 ,,,,,,,,,,
FO-264461	10/11/2013	10/15/2013		Evaluate winterization of chill water coils through entire building ,,,,,,,,,, ME/10-11-13 ,,,,,,,,,,
FO-264265	10/11/2013			Trade: Pipefitter Priority: Medium
FO-264296	10/11/2013	10/14/2013		Remove broken screw from Probe fitting (8/32" tap) ,,,,,,,,,, JH/10-14-13 ,,,,,,,,,, DUE 10-25-
FO-264303	10/11/2013	10/14/2013		Investigate and correct cause of leak in condensate line near the floor between chiller and ahu
FO-264439	10/14/2013	10/16/2013		R/R BSMT TUNNEL BTWN COMMUNITY ARTS/MCGREGOR BEFORE THE OUTSIDE DOC
FO-264440	10/14/2013	10/17/2013		Apparent leak in ceiling - stained ceiling tiles. Please address,,,,,,,,,,,,,,,, JH/10-15-13 ,,,,,,,,,,
FO-264530	10/15/2013	10/17/2013		R/R leaking 4" hydronic heat header in room 100 near circulating pumps ,,,,,,,,,, ME/ 10-15-
FO-264706	10/17/2013	10/21/2013		FITTERS,
FO-264901	10/21/2013			repair radiator leaking steam and condensate on stairway above box office,,,,,,,,,,,,,,,, JH/10-
FO-264903	10/21/2013			repair or replace marked steamtrap on Supply fan #2 in basement,,,,,,,,,,,,,,,, JH/10-30-13 ,,,,,,,,,,
FO-265059	10/22/2013			FITTERS,
FO-265065	10/22/2013			pipefitter
FO-265094	10/22/2013	10/24/2013		FITTERS,
FO-265113	10/22/2013	10/25/2013		FITTERS: PLEASE REPAIR LEAKING STEAM COIL IN AHU#7 ,,,,,,,,,, JH/10-23-13 ,,,,,,,,,,
FO-265114	10/22/2013	10/23/2013		FITTERS: PLEASE REPAIR LEAKING COOLING COIL IN AHU#7 ,,,,,,,,,,Finished 10-23-1
FO-265166	10/23/2013			Please repair or replace float for condensate return tank and pumps.
FO-265207	10/23/2013			We have a leak in the storage closet located in the student lounge room 125. It looks like the
FO-265289	10/24/2013	10/29/2013		FITTERS,
FO-265290	10/24/2013	10/29/2013		FITTERS,
FO-265291	10/24/2013			FITTERS,
FO-265317	10/24/2013			PF med Priority
FO-265323	10/24/2013	10/25/2013		Fitters:
FO-265338	10/24/2013	10/21/2013		RM 313 UNISEX RESTROOM RADIATOR STILL DRIPPING ,,,,,,,,,, EA/RC 10-24-13 ,,,,,,,,,,
FO-265349	10/24/2013			PF Med Priority
FO-265346	10/24/2013			R/R RM 00187.01 Replace pump seals on #1 City Water Booster Pump ,,,,,,,,,, MM/MP 1
FO-265360	10/24/2013			PIPRFITTERS please r/r needle valve on boiler #1. I'm unable to pull a sample from the boiler.
FO-265369	10/24/2013			Trade: Pipefitters

WO	Recieved	Finished	Total	Request
FO-265379	10/24/2013			FITTERS (HIGH)
FO-265500	10/25/2013	10/28/2013		Pipe Fitters:
FO-265537	10/25/2013	10/25/2013		Ceiling leak 317 ,,,,,,,,,, EA/RC 10-25-13 ,,,,,,,,,, DUE 11-8-13 Finished 10/28/2013
FO-265661	10/28/2013			Fitters:
FO-265663	10/28/2013			Fitters:
FO-265695	10/29/2013			please re-pack main leaking staem valve above condensate pit...EA/RC 10-29-13 ,,,,,,,,,, D
FO-265764	10/29/2013			R/R steam control valve on AHU#11 stem will not move / no control ,,,,,,,,,, ME/10-29-13 ,,,
FO-265826	10/30/2013			Pipe Fitters: please unplug or replace restricted lines to reheat coils for fish bowl area, the coil
FO-265876	10/30/2013			steamfitters-please check leak in main office rm 585-possible condensate line leak ,,,,,,,,,,
T - Plumber			80	
FO-263395	10/1/2013	10/3/2013		Plumbers:
FO-263398	10/1/2013	10/2/2013		5th floor near public elevator the unisex restroom 5100.3 toilet contine to flush non-stop,,,,,,,,,
FO-263546	10/2/2013	10/4/2013		Toilet leaking in men's restroom,,,,,,,,,,,,, MM/10-3-13 ,,,,,,,,,, DUE 10-16-13 Finished 10/
FO-263623	10/3/2013	10/7/2013		R/R 1ST FLR ACROSS FROM RM 140 WOMENS RR 2ND SINK (next to stall) IS PLUGGED
FO-263664	10/3/2013			4th floor mens toilet room urinal is plugged ,,,,,,,,,, MP/DB 10-3-13 ,,,,,,,,,, DUE 10-17-13
FO-263667	10/3/2013			R/R 2ed floor mens bathroom in old wing ,,,,,,,,,, MP/DB 10-3-13 ,,,,,,,,,, DUE 10-17-13
FO-263672	10/3/2013			R/R 4TH FLR MENS RR NEXT TO JANITOR'S CLOSET/STE AREA 1ST STALL TOILET CO
FO-263678	10/3/2013	10/8/2013		faucet in UGL Dean's Office Staff Room, Room 3149, has a constant drip,,,,,,,,,,,,, RJC/RB 1
FO-263695	10/3/2013	10/14/2013		PLUMBERS (MED. PRIORITY)
FO-263703	10/3/2013	10/7/2013		R/R RM 4116 ONLY SINK IS LKNG FROM UNDERNEATH ,,,,,,,,,, MM/10-4-13 ,,,,,,,,,,
FO-263752	10/4/2013			Distilled water dispenser at base is leaking
FO-263847	10/7/2013	10/8/2013		R/R RM 218/UNISEX RR ONLY TOILET IS LKNG FROM UNDERNEATH SLOWLY,,,,,,,,,,,,,
FO-263879	10/8/2013	10/8/2013		Trade: Plumbers
FO-263881	10/8/2013	10/8/2013		R/R 2ed floor mens restroom old wing , broken toilet seat ,,,,,,,,,, MP/DB 10-8-13 ,,,,,,,,,,
FO-263904	10/8/2013	10/15/2013		MEN'S RESTROOM #0105 IN BASEMENT, MIDDLE STALL THE TOILET IS LEAKING WAT
FO-263916	10/8/2013	10/9/2013		Plumber repair water leak under toilet in Mens room in basement,,,,,,,,,,,,, MM/10-9-13 ,,,,,,,,,,
FO-263918	10/8/2013	10/16/2013		Plumber repair water leak under cooling tower sump,,,,,,,,,,,,, RJC/RB 10-9-13 ,,,,,,,,,, DU
FO-263998	10/9/2013			Plumbers:
FO-264122	10/9/2013	10/9/2013		Faucet for room 0507 is not working properly. The maintenance gentleman said to order a ne
FO-264130	10/9/2013			Please install new ADA drinking fountain/Bottle filling station by ladies restroom #2126 ,,,,,,,,,,
FO-264149	10/9/2013			R/R 5TH FLR BY ELEVS UNISEX RR ONLY UNDER SINK DEVICE USED TO GENERATE
FO-264221	10/10/2013	10/11/2013		R/R RM 3105 ONLY EYE WASH IS LKNG ,,,,,,,,,, MM/10-10-13 ,,,,,,,,,, DUE 10-24-13
FO-264223	10/10/2013			R/R RM 1019 custodian's sink is plugged and will not drain. They tried plunging it and still doe
FO-264352	10/11/2013			P.M all faucets in bathrooms / al floors ,,,,,,,,,, MM/10-14-13 ,,,,,,,,,, DUE 10-25-13
FO-264273	10/11/2013	10/24/2013		Please repair the following in the restroom areas inside the football locker room....
FO-264350	10/14/2013			P.M waterless urinals for month of October 2013 ,,,,,,,,,, MM/10-14-13 ,,,,,,,,,, DUE 10-28
FO-264457	10/15/2013	10/16/2013		MEN'S RESTROOM 4104 THE TOILET SEAT BROKEN. PLEASE REPLACE/REPAIR,,,,,,,,,,,,,
FO-264460	10/15/2013	10/16/2013		second floor ladies restroom 2234 handi-cap stall / pipe leaking between pipe and flush valve -
FO-264507	10/15/2013			Plumber 3rd floor mens room. Repair toilet in small stall. Only get half of a flush ,,,,,,,,,, M
FO-264588	10/16/2013	10/18/2013		Plumber; Medium
FO-264689	10/17/2013	10/18/2013		R/R RM 256/CLASS LAB The sink in room 256 Art Bldg. back ups after only a few uses. One
FO-264695	10/17/2013			Plumbers - high priority -
FO-264730	10/17/2013	10/25/2013		3RD FL MENS RM 349..URINA ,,,,,,,,,, RJC/RB 10-18-13 ,,,,,,,,,, DUE 10-30-13 Finished
FO-264739	10/17/2013			PLUMBER:please repair domestic water booster pump,making loud noise.NOTE:pump was ju
FO-264746	10/17/2013	10/18/2013		(WDET)4600 CASS SINK IN MENS RM PLUGGED,,,,,,,,,,,,, MP/DB 10-18-13 ,,,,,,,,,, DU
FO-264770	10/17/2013			please check out and repair an apparent leak in the 2nd floor restroom--toilet,,,,,,,,,,,,, RJC/R
FO-264774	10/17/2013	10/23/2013		RM 1253 TOILET BUBBLING,,,,,,,,,,,,, MM/ 10-18-13 ,,,,,,,,,, DUE 10-31-13 Finished 10/25/

WO	Recieved	Finished	Total	Request
FO-264785	10/18/2013			The water fountain on the 1st floor between restroom 170 & room 172 is falling off the wall. Pl
FO-264799	10/18/2013	10/25/2013		Plumbers:
FO-264830	10/18/2013	10/24/2013		R/R FROM THE CHAULK BOARD #1(1ST) Sink in front of room clogged. This is an undergra
FO-264857	10/18/2013	10/21/2013		R/R RM 2238/MENS RR HANDICAP STALL TOILET IS LKNG @BASE ,,,,,,, RJC/RB 1
FO-264883	10/21/2013	10/24/2013		EMERGENCY R/R 2ND FLR EAST SIDE WOMENS RR ACROSS FROM RM 2217 SINK FA
FO-264942	10/21/2013	10/21/2013		strong smell of urine from
FO-264956	10/21/2013	10/28/2013		Plumbers, please repair overhead chemical shower next to room 474. Spring loaded valve mu
FO-264953	10/21/2013			RM 340 SINK LEAKING, CLASS STARTS AT 2:00pm ,,,,,,, MM/10-22-13 ,,,,,,, D
FO-264957	10/21/2013	10/28/2013		Plumbers, please repair overhead chemical shower located on SW corner of 3rd floor next to
FO-264958	10/21/2013			Plumbers, please repair overhead chemical shower located on SE corner of 3rd floor next to
FO-264959	10/21/2013	10/28/2013		Plumbers, please repair overhead chemical shower located on NW corner of 2nd floor. Showe
FO-264961	10/21/2013	10/28/2013		Plumbers, please repair overhead chemical shower located on NE corner of 2nd floor. Shower
FO-264962	10/21/2013	10/28/2013		Plumbers, please repair overhead chemical shower located on SE corner of 2nd floor. Spring I
FO-264963	10/21/2013			Plumbers, please repair overhead chemical shower located on NW corner of 1st floor. Shower
FO-264996	10/21/2013			5TH FL MENS RM CEILING LEAK ,,,,,,, RJC/RB/10-22-13 ,,,,,,, DUE 11-4-13
FO-265047	10/22/2013	10/24/2013		Bathroom 322.10: toilet not flushing completely.,,,,,,, MM/10-22-13 ,,,,,,, DUE 11-5-
FO-265235	10/23/2013			plumbers-please replace gate valve to backflow preventer on the left hand side when facing th
FO-265301	10/24/2013			HOT WATER TANK LEAKING. LOADING DOCK.,,,,,,, RJC/RB 10-28-13 ,,,,,,, DUE
FO-265318	10/24/2013			Plumb Med Priority
FO-265352	10/24/2013			PLUMBERS
FO-265438	10/25/2013	10/25/2013		Inspect and repair pump assembling for Cholrine feed to the pool. Pump loses prime and m
FO-265447	10/25/2013			Trade: Plumber Priority: Medium
FO-265499	10/25/2013			WATER ON FLOOR UNDER SINK. (POSSIBLE LEAK) 1ST FLOOR LADIES RESTROOM.
FO-265515	10/25/2013			R/R 3RD FLR WOMENS RR (ONLY RM) 2ND STALL TOILET IS LKNG @ BOTTOM ,,,,,,,
FO-265516	10/25/2013			R/R 3RD FLR ONLY WOMENS RR SMALL STALL TOILET IS PLUGGED ,,,,,,, RJC/RB
FO-265524	10/25/2013	10/25/2013		EMERGENCY R/R 13TH FLR ALL BATHROOMS TOILETS & URINALS ARE BACKING UP,,
FO-265589	10/28/2013			Trade: Plumber Priority: Medium
FO-265595	10/28/2013			R/R 3RD FLR (ONLY) WOMENS RR (as you enter)SINK ON YOUR LEFT NEEDS BATTERIE
FO-265650	10/28/2013	10/29/2013		8th floor unisex restroom 8100.1 toilet not flushing properly.,,,,,,, MP/DB 10-29-13 ,,,,,,,
FO-265666	10/28/2013			PLUMBERS:
FO-265671	10/28/2013			Purdy Library, 1st Floor, west side of floor
FO-265675	10/28/2013			Room 207 - 2nd floor of the office block. Faucet is leaking and needs to be replaced.
FO-265683	10/28/2013			Witerize electric domestic water heater ,,,,,,, MP/DB 10-29-13 ,,,,,,, DUE 11-11-13
FO-265698	10/29/2013			1ST FL NEAR RM 1272 WATER FOUNTAIN LEAKING ,,,,,,, MM/10-29-13 ,,,,,,, DU
FO-265714	10/29/2013	10/30/2013		3RD FL WOMENS RM SINK NEEDS BATTERIES ,,,,,,, MP/DB 10-29-13 ,,,,,,, DUE
FO-265738	10/29/2013			2ND AND 3RD FL WOMENS RM COLD WATER NOT WORKING, HOT WATER NOT HOT ,,
FO-265759	10/29/2013			PLUMBERS: PLEASE REPAIR OR REPLACE LEAKING VACUUM BREAKER ON FUME H
FO-265897	10/30/2013			5057 Woodward Ave, 3rd floor, Ladies Restroom by elevators, second stall on left. When the t
FO-265911	10/30/2013			Ladies room 4th floor 1st stall/when the toilet is flushed a lot of water is spraying from the pipe
FO-265913	10/30/2013			Ladies room 110 1st floor - 1st sink on the right side need batteries. State Hall,,,,,, MP/
FO-265914	10/30/2013			R/R 2ND FLR WOMENS RR STALL? TOILET IS LKNG @ BOTTOM (BAG IS OVER TOILET)
FO-265915	10/30/2013			Plumbers-
FO-265935	10/30/2013			Right-hand sink needs a new battery in the faucet.,,,,,,, MM/10-31-13 ,,,,,,, DUE 11-
Low			453	
T - Carpenter			104	
FO-263366	10/1/2013	10/1/2013		ATTACH SAND BLASTER TO THE FLOOR IN THE PAINT SHOP. Finished 10/2/2013LT
FO-263388	10/1/2013	10/1/2013		Purdy Library 1st Floor, Stair 2

WO	Recieved	Finished	Total	Request
FO-264283	10/1/2013	10/11/2013		Remove/ Replace entry door mullion (Palmer Side) for access by ARAMARK installer for Einst
FO-263529	10/2/2013	10/2/2013		CARPENTER TO LOWER BLIND SERVICE CENTER IN FRONT OF SIRENA'S DESK Finish
FO-263535	10/2/2013	10/2/2013	10/2/2013	TEAM LEADER TIME (OCTOBER 2013)
FO-263537	10/2/2013			TEAM LEADER TIME (OCTOBER 2013)
FO-263600	10/2/2013	10/3/2013		desired_date: 10/02/2013
FO-263669	10/2/2013	10/3/2013		PS#3- I would like the door checked on the
FO-263661	10/3/2013	10/4/2013		Replace stained ceiling tiles in room 3634 Finished 10/7/2013LT
FO-263675	10/3/2013			PLEASE INSTALL BILCO LU-4 ALUMINUM LADDER UP SAFETY POST ON THE ROOF HA
FO-263684	10/3/2013			PLEASE INSTALL 6 BILCO LU-4 ALUMINUMLADDER UP SAFETY POST ON THE ROOF H
FO-263926	10/3/2013	10/10/2013		Room 415
FO-263927	10/3/2013	10/10/2013		Room 242
FO-263925	10/3/2013	10/10/2013		Room 218
FO-263930	10/3/2013	10/10/2013		115 04 N inside double door. (Gold N' Greens
FO-263747	10/4/2013	10/3/2013		CARPENTER TO ATTEND SAFETY MEETNG (OCTOBER 2013) Finished 10/4/2013 LT
FO-263766	10/4/2013	10/4/2013		Insurance - Police Report #W13-100498 - Please board up broken window on the north & sout
FO-263819	10/7/2013			Insurance - Police Report #W13-280036 - Please R/R Shattered Atrium Glass Panel. Damag
FO-263889	10/8/2013	10/8/2013		Repair floor tile room# 0006.00Finished 10/9/2013LT
FO-263890	10/8/2013	10/8/2013		CARPENTER TO REPLACE KICK DOWN DOOR STOP ROOM # 00006.00Finished 10/9/201
FO-263903	10/8/2013	10/8/2013		3rd floor Deans office ladies room the entrance/exit door hinges are loose - door off trackFinis
FO-263907	10/8/2013	10/8/2013		"RUSH" Doug, please have the Carpenters disassemble the 2 desks in room 6E UHC so that
FO-263939	10/8/2013	10/9/2013		Trade: Carpenter Priority: Low
FO-263955	10/8/2013	10/11/2013		R/R 1ST FLR LIBRARY CIRCULATION DESK SEVERAL WINDOW BLINDS OPEN/CLOSIN
FO-263953	10/8/2013	10/17/2013		Trade: Carpenter Priority: Low
FO-264056	10/9/2013	10/10/2013		CARPENTER TO REPAIR THE INSIDE DOOR HANDLE OF THE CUSTODIAL STOCKROO
FO-264142	10/9/2013	10/10/2013		R/R RM 5420 Handicap door entry pads going in or out of room 5420 do not work. Finished 10
FO-264145	10/9/2013	10/11/2013		Please put sign back on the office door in Suite 2100 Undergraduate Library Room 2105. In th
FO-264151	10/9/2013	10/29/2013		Women's Restroom # 131, the third stall from the door needs the stall lock to be replaced Fini
FO-264186	10/10/2013	10/10/2013		R/R OUTSIDE BLDG RE-ATTACH One side of Manufacturing Building outside sign off - can b
FO-264187	10/10/2013	10/11/2013		CARPENTERS,
FO-264210	10/10/2013			Put up chair rails on one section of south wall.
FO-264214	10/10/2013	10/10/2013		PLEASE ATTACH SAND BLASTER TO THE FLOOR Finished 10/11/2013LT
FO-264254	10/11/2013	10/11/2013		CARPENTERS TO REPAIR THE 2 PODIUMS IN THE CARPENTERS SHOP Finished 10/14/
FO-264264	10/11/2013			Freight elevator floor needs to be replaced. Perhaps with something other than tiles. The IAC
FO-264310	10/11/2013	10/11/2013		CARPENTER TO PUT CEILING STOCK IN TO TYHE STOCKROOM Finished 10/14/2013LT
FO-264392	10/14/2013	10/14/2013		R/R RM 6304 Doorstop has busted off door please replace/fix Finished 10/16/2013LT
FO-264447	10/14/2013	10/16/2013		CARPENTERS TO ANNUAL CLEANING OF THE INTERIOR OF THE VANS Finished 10/18/
FO-264458	10/15/2013			REPLACE WORN OUT ADA OPERATORS MAIN ENTRANCES
FO-264459	10/15/2013			INSTALL KICK DOWN DOOR HOLDER IN MARIO SANCHEZ OFFICE
FO-264477	10/15/2013	10/21/2013		Need shelves for room # 13. Finished 10/22/2013LT
FO-264485	10/15/2013	10/22/2013		PLEASE INSTALL ADJUSTMENT RODS TO WINDOW BLINDS. SERVICE CENTER. Finish
FO-264490	10/15/2013			Vendor (FBH) to supply ADA solenoid valves
FO-264528	10/15/2013			contact: Dixon Kirkland
FO-264595	10/16/2013	10/18/2013		Replace/repair metal hood over exterior door card reader at main entrance. Finished 10/22/20
FO-264596	10/16/2013	10/21/2013		CARPENTERS,
FO-264613	10/16/2013	10/21/2013		Repair/Replace panic bars to three doors leading to stairway/hall on the 3rd floor south of Stu
FO-264617	10/16/2013	10/16/2013		Room 8101 outer and inner doors not closing properly. Please repair. Finished 10/18/2013LT
FO-264641	10/16/2013	10/23/2013		please build 20 x 20 box for empty propane and map gas cylinders per Walter P at OEHS..this

WO	Recieved	Finished	Total	Request
FO-264684	10/17/2013			Carpenters:
FO-264708	10/17/2013	10/17/2013		please replace damaged ceiling tiles in DLAR area outside room 410.... Finished 10/18/2013L
FO-264717	10/17/2013	10/22/2013		Room 2113 is a womens restroom. The second stall from the door needs a new lock on the d
FO-264771	10/17/2013			R/R LOBBY ENTRANCE TO DOOR #608-05W N.W. CORNER PLEASE CUT & REMOVE AP
FO-264791	10/18/2013	10/18/2013		Hang bulletin board in Ms. Lisa Turner's office pretty please! Finished 10/22/2013LT
FO-264858	10/18/2013	10/21/2013		R/R RM Storage Closet double door to the immediate left of 2329 has a security issue. The lo
FO-264892	10/19/2013	10/21/2013		the handicap release buttons on the main outside door and the inside door are not working.
FO-264944	10/21/2013	10/21/2013		We have a door closer at PS2 booth on the
FO-264991	10/21/2013	10/21/2013		need Onity lock repaired or replaced. Locksmith
FO-264989	10/21/2013	10/22/2013		Inner entrance door closest to the outside
FO-264987	10/21/2013	10/22/2013		The bedroom door in 1515B won't work with
FO-265087	10/21/2013	10/22/2013		The lock to 702 is not working properly. It
FO-265085	10/21/2013			We have a broken sliding window at the
FO-265089	10/22/2013	10/23/2013		I would 50 wood gate arms made 1 x 4 1/2 x 10. A sample of the wooden gate arms were give
FO-265066	10/22/2013	10/23/2013		CARPENTERS,
FO-265067	10/22/2013	10/23/2013		CARPENTERS,
FO-265090	10/22/2013			carpenter w/o, rebuild/repair compactor loading ramp on loading dock. wood ramp is damage
FO-265119	10/22/2013	10/24/2013		CARPENTER TO REPLACE THE CEILING TILES ENTIRE 4TH FLOOR Finished 10/25/2013
FO-265193	10/23/2013	10/23/2013		R/R ENT HANDICAP DOOR #608 03N the handicap release buttons on the main outside doo
FO-265222	10/23/2013	10/29/2013		Check drivers side door on Joe, and Sue's van. Finished 10/30/2013LT
FO-265236	10/23/2013	10/23/2013		Remove ADA Signs - exterior of Cohn Building.
FO-265244	10/23/2013	10/23/2013		CARPENTERS TO CLEAN THE SHOP Finished 10/25/2013LT
FO-265250	10/23/2013			CARPENTERS,R/R RM 3141.20/CLASS LAB PLEASE REPAIR EGRESS WINDOW , DIFFI
FO-265263	10/23/2013	10/24/2013		outer door knob plate is loose. Afraid anyone can break the door knob and enter the room. fo
FO-265264	10/23/2013	10/24/2013		Purdy Library 1st Floor Main Entrance
FO-265270	10/23/2013	10/24/2013		Carpenter; Medium
FO-265279	10/23/2013	10/24/2013		Locksmith repaired lock on 10/22/13 Per D.
FO-265295	10/24/2013	10/25/2013		Please replace worn out door stops on the entrance doors to the mens locker room.
FO-265315	10/24/2013	10/25/2013		CARPENTERS: Please replace door sweeps on doors 620-10-11 north LOW. Finished 10/28/
FO-265321	10/24/2013	10/24/2013		Carpenters:
FO-265319	10/24/2013	10/24/2013		Carpenters:
FO-265353	10/24/2013	10/24/2013		Men's & Women's restroom door off line in the basement.Next to room 13
FO-265642	10/24/2013	10/29/2013		Shapero Hall
FO-265443	10/25/2013			Partition doors are not operating well...Please have these doors checked as soon as possible.
FO-265460	10/25/2013	10/25/2013		R/R Room 3117 Elliman. Replace missing
FO-265461	10/25/2013	10/25/2013		R/R Room 3141 Elliman. Replace missing
FO-265479	10/25/2013			R/R RM 1545 Projector screen not pulling down all the way and is stuck. Please repair.
FO-265501	10/25/2013	10/29/2013		Repair/Replace door closure to first floor north exterior (#07702) door. Door is slamming hard
FO-265535	10/25/2013	10/29/2013		CARPENTERS TO CLEAN THE CARPENTERS SHOP Finished 10/30/2013LT
FO-265640	10/28/2013			PS#4- Per my conversation with Jimmy
FO-265624	10/28/2013	10/29/2013		R/R RMS 4204 & 4223 (BRACKETS TORN OFF ACCIDENTLY) acoustic panels in practice ro
FO-265645	10/28/2013			Please have Carpenter drill a hole in the wall between the copier and the service window , FP
FO-265752	10/29/2013			Need two padlocks keyed to Chatsworth
FO-265768	10/29/2013			Replace 2 broken door stops on the floor by the hallway door....1 at the south end and 1 at the
FO-265776	10/29/2013			Carpenters- Low priority. Install safety mast on roof hatch in mechanical room fourth floor. Wo
FO-265821	10/30/2013			Have Locksmith cut 4 keys total, 2 for the generator enclosure at Mazurek, and 2 for the genie
FO-265936	10/30/2013			Repair desk drawer in room 104-first floor of Knapp Building. Front panel of drawer came off.

WO	Recieved	Finished	Total	Request
FO-265843	10/30/2013			R/R Room 1374 - Door leading into suite is not closing properly - Please adjust/replace door cl
FO-265921	10/30/2013			CARPENTERS TO REPLACE CEILING TILES 1ST FLOOR N/W HALL BY STAIRWELL & 1S
FO-265924	10/30/2013			Locksmith; need cores repaired to both PLD doors, 1 out in hall will not unlock and the other in
FO-265926	10/30/2013			CARPENTERS TO REBASE WOMENS BATHROOM DESIGN SERVICES
FO-265929	10/30/2013			CARPENTERS TO REPAIR 1ST FLOOR SOUTH OUTER MENS ROOM DOOR DOES NOT
FO-265930	10/30/2013			Two drop-ceiling panels are missing. Please
FO-265932	10/30/2013			CARPENTER TO REPAIR LOADING DOCK DOOR DOUBLE DOORS FLUSH BOLT & AST
FO-265934	10/30/2013			CARPENTERS TO REPAIR DRYWALL SOUTH LOBBY WEST SIDE ABOVE WINDOW
T - Electrician			164	
FO-263352	10/1/2013	10/1/2013		Trade: Electricians
FO-263357	10/1/2013	9/30/2013		Time for Paul Prouty III to go to the clinic. Finished 10/2/2013LT
FO-263368	10/1/2013	10/1/2013		In need of another electrical outlet plus...Please secure electrcal cords from comp system aga
FO-263373	10/1/2013	10/2/2013		1 fixture out in the hall outside of room 338 Finished 10/4/2013LT
FO-263374	10/1/2013	10/9/2013		Elevator light. Finished 10/11/2013LT
FO-263375	10/1/2013	10/2/2013		1 fixture out in the hall outside of room 10204. Finished 10/4/2013LT
FO-263401	10/1/2013	10/3/2013		Disconnect Hot Water Heater, and connect when new one is installed.
FO-263532	10/2/2013	10/4/2013		4 lights with EP's in ROOMS 1369 and 1369.3 Finished 10/7/2013LT
FO-263547	10/2/2013	10/8/2013		R/R RM 5106 Please repair the light fixture in the Men's room (ballast is bad).Finished 10/9/20
FO-263540	10/2/2013	10/9/2013		1 EP in 3rd floor womens restroom. Fixture requires tool to change bulbs. Finished 10/11/2013
FO-263541	10/2/2013	10/18/2013		5 EP's in 2nd floor Finished 10/21/2013LT
FO-263543	10/2/2013	10/14/2013		In room 320, there is 1 EP directly over the desk of Dhanusha. The area is Dim (The office is i
FO-263551	10/2/2013	10/15/2013		1 fixture out in room# 9406 Finished 10/16/2013LT
FO-263556	10/2/2013		10/18/2013	Hallway/Stairwell light is not working. Seems to be a special type of lamp. I am not sure if the
FO-263576	10/2/2013			A few months ago, the Reuther Conference
FO-263580	10/2/2013			Erect Scaffolding for Boiler Tube Cleaning
FO-263589	10/2/2013	10/9/2013		Electrician
FO-263618	10/3/2013	10/3/2013		Time for Safety Meeting Finished 10/4/2013 LT
FO-263626	10/3/2013	10/4/2013		EP in the third floor, book ranges 134-143
FO-263628	10/3/2013	10/18/2013		1) 1 EP in the stairwell. EXIT 1, STAIR 6, 3rd floor landing
FO-263630	10/3/2013			3 EP's
FO-263631	10/3/2013	10/16/2013		1 EP. Fixture is in front of EXIT SIGN, going up seating entrance 31-60 Finished 10/18/2013L
FO-263632	10/3/2013	10/10/2013		1 fixture out in room 3108 Finished 10/11/2013LT
FO-263633	10/3/2013	10/9/2013		1 fixture out in mens restroom, 5th floor Finished 10/11/2013LT
FO-263634	10/3/2013	10/7/2013		The following EP's are in front of the following room numbers 437, 449, 506.The areas are dim
FO-263674	10/3/2013	10/4/2013		Repair clock in hallway outside of room 230. Finished 10/7/2013LT
FO-263734	10/4/2013	10/16/2013		1) 2 EP's. Ranges 136 & 173. (1st floor)
FO-263735	10/4/2013	10/21/2013		1) 1 fixture out in room 1525
FO-263744	10/4/2013	10/11/2013		1 fixture out in the ENG- Office, room# 037 Finished 10/14/2013LT
FO-263770	10/4/2013	10/16/2013		Need gennie lift at fish bowl by 11:00 am Monday (10-7-13) morning for Corey Finished 10/18/
FO-263810	10/7/2013	10/14/2013		1 EP in 124 Social lounge, circular ceiling light near red tile wall Finished 10/16/2013LT
FO-263811	10/7/2013	10/22/2013		Display case at the entrance, all 4 bulbs have EP's Finished 10/22/2013LT
FO-263827	10/7/2013	10/23/2013		Replace lights in room 010. There are 2 electrical problems. Finished 10/24/2013LT
FO-263852	10/7/2013	10/14/2013		R/R FAP/SMOKE DETECTOR MESSAGE BOARD PANEL STATES SMOKE ACCUMULATI
FO-263863	10/7/2013	10/24/2013		R/R 112/ASSEMBLY-Auditorium ceiling has about 4 ceiling lights that are out, this floor is on
FO-263865	10/7/2013	10/7/2013		ELECTRICIANS TO DISCONNECT & RELOCATE OUTLET BOX ROOM # 238Finished 10/9/
FO-263909	10/8/2013	10/10/2013		R/R RM 1012/MECH RM, lower right corner on west wall inside mechanical room is cracked &
FO-263914	10/8/2013	10/18/2013		Fill in pothole in driveway between St. Andrews, and Structure 2. It have been bought up at th

WO	Recieved	Finished	Total	Request
FO-263919	10/8/2013			Repair exterior lights.
FO-263949	10/8/2013	10/11/2013		PS#2- It's okay for the department to billed
FO-263940	10/8/2013	10/21/2013		ELECT:please wire float switch to control transfer pump to FW tank.PRIORITY:HIGH. ATTN:D
FO-263999	10/9/2013	10/22/2013		Meet Schindler Elevator Mechanics to repair disconnect.
FO-264018	10/9/2013	10/14/2013		1 EP, 4th floor Mens restroom, fixture outside of middle stall Finished 10/16/2013LT
FO-264019	10/9/2013	10/14/2013		1 EP in room# 115. Fixture out over entrance Finished 10/16/2013LT
FO-264020	10/9/2013	10/25/2013		1 EP in 1st floor, room# 124. Fixture above fire exit door. Finished 10/28/2013
FO-264079	10/9/2013			repair light fixture above boiler room west door
FO-264093	10/9/2013	10/9/2013		contact: Jason Clark
FO-264101	10/9/2013	10/14/2013		4 fixtures out in room# 2352 Finished 10/16/2013LT
FO-264119	10/9/2013			Replace lens in areas lens is missing.
FO-264280	10/10/2013			The light at the top of the blue light phone
FO-264166	10/10/2013	10/23/2013		1 fixture out in room# 6400 Finished 10/24/2013LT
FO-264167	10/10/2013	10/11/2013		1 fixture out in kitchen, basement Finished 10/14/2013LT
FO-264176	10/10/2013	10/24/2013		1 fixture out in room 149, Cricket room Finished 10/25/2013LT
FO-264177	10/10/2013	10/24/2013		1 fixture out in room# 166, Butterfly room Finished 10/25/2013LT
FO-264178	10/10/2013	10/16/2013		8 fixtures out in Donor Gallery (1st floor) Finished 10/18/2013LT
FO-264181	10/10/2013	10/17/2013		4 Fixtures out in the hallway, 1st floor Finished 10/18/2013LT
FO-264184	10/10/2013	10/11/2013		R/R RM 1051 Electrical outlet on right side of room not working/possibly shorted out. Needs r
FO-264259	10/11/2013	10/14/2013		In room# 1545, there is an EP in the switch Finished 10/16/2013LT
FO-264260	10/11/2013	10/15/2013		2 fixtures out, lights over the file cabinets, next to ranges (Basement) Finished 10/16/2013LT
FO-264261	10/11/2013	10/15/2013		1 fixture out in the basement, Range 1 Finished 10/16/2013LT
FO-264262	10/11/2013	10/15/2013		1 fixture out in the hall across from womens restroom and room 1120 Finished 10/16/2013LT
FO-264267	10/11/2013	10/16/2013		1 EP in room# 208
FO-264268	10/11/2013	10/16/2013		1 EP in 4th floor hallway. only one out in the hall Finished 10/18/2013LT
FO-264370	10/13/2013	10/14/2013		R/R BLDG The Light sconces on the stairwells ,the lights are out, (2) stair well light need rep
FO-264343	10/14/2013	10/15/2013		Repair clocks on snd floor east hallway Finished 10/16/2013LT
FO-264344	10/14/2013	10/14/2013		Repair clocks on 2nd floor west hallway. Finished 10/16/2013LT
FO-264346	10/14/2013	10/14/2013		Repair clock on 4th floor hallway. Finished 10/16/2013LT
FO-264355	10/14/2013	10/23/2013		Therer is one EP directly over the desk where the client sits in at room# 275 Finished 10/24/2
FO-264357	10/14/2013			ELECTRICIANS,
FO-264388	10/14/2013	10/17/2013		EP's :
FO-264390	10/14/2013	10/24/2013		1 EP in 149 hallway, overhead. all bulbs have been replaced. Finished 10/25/2013LT
FO-264404	10/14/2013	10/14/2013		Repair clock on the 4th floor hallway west end. Finished 10/16/2013LT
FO-264416	10/14/2013	10/18/2013		Please have Maintenance Laborer pick up toner cartridges from Cashiers office AAB and brin
FO-264434	10/14/2013	10/21/2013		Room 3210 - There are quite a few lights out in our cold room 3 sets with 2 bulbs/set. 3 ele
FO-264478	10/15/2013			RM 288 LIGHTS WON'T TURN OFF, PLEASE CHECK LIGHT SENSOR
FO-264491	10/15/2013	10/29/2013		2 fixtures out in the south stairwell, 2-3rd floor Finished 10/30/2013LT
FO-264492	10/15/2013	10/25/2013		1 fixture out in room# 440 Finished 10/28/2013
FO-264493	10/15/2013	10/18/2013		1 fixture out in women's restroom, 2116 Finished 10/21/2013LT
FO-264495	10/15/2013	10/17/2013		There are 2 EP's in room# 0006, sub basement. Finished 10/18/2013LT
FO-264497	10/15/2013	10/29/2013		Lights are out in room# 7501. 1 electrical problem. Finished 10/30/2013LT
FO-264510	10/15/2013	10/25/2013		3 EP's. 301, overhead light. bulbs have been changed. (Sensor do not stop making noise) Fini
FO-264511	10/15/2013	10/28/2013		There are 2 EP's located inside office 2227 Finished 10/30/2013LT
FO-264513	10/15/2013	10/18/2013		In room #38, there is 1 EP in room that is going to be occupied soon Finished 10/21/2013LT
FO-264526	10/15/2013	10/16/2013		LABORER,
FO-264597	10/16/2013	10/23/2013		ELECTRICIANS,

WO	Recieved	Finished	Total	Request
FO-264615	10/16/2013			Lighting tech Michael Seldon is referring the request for further investigation :
FO-264652	10/16/2013			MECH RM 51 AIR COMPRESSOR TRIPPING Finished 10/16/2013LT
FO-264653	10/16/2013	10/29/2013		Disconnect wire to temporary chiller, and coil up on the roof.
FO-264671	10/17/2013	10/18/2013		Move lift from structure 1, to UGL for storage. Finished 10/21/2013LT
FO-264686	10/17/2013			The light lenses in the hallway in subbasement continuously come down from the fixture. Man
FO-264718	10/17/2013	10/28/2013		Ceiling lights are out in Rooms 5324 and Room 5344. At least 6 lights are out.
FO-264726	10/17/2013	10/22/2013		There is a problem with the electrical circuit in lab 2524. Some electrical outlets are not worki
FO-264849	10/17/2013	10/21/2013		"RUSH" Doorbell/intercom for rear door is not working. The front door is not accessible becau
FO-264756	10/17/2013	10/18/2013		R/R Kresge Library Porch Outside of Main Entrance Please adjust the Kresge porch light time
FO-264764	10/17/2013	10/23/2013		Stairwell to the 3rd floor in the Freer House.
FO-264804	10/18/2013			There are 4 fixtures out :
FO-264805	10/18/2013	10/29/2013		1 fixture out in the law library, Range 111 (1st floor) Finished 10/30/2013LT
FO-264806	10/18/2013	10/25/2013		1 fixture out in Range 2 (Basement) Finished 10/28/2013
FO-264807	10/18/2013			6 fixtures out. Lights over stairwell facing education building. They are too high to reach. (1st fl
FO-264808	10/18/2013			3 fixtures out on stairs facing the McGregor Conference Building. They are too high reach (1st
FO-264815	10/18/2013			Room 220 has lights out. Room 220 has 2 electrical problems.
FO-264819	10/18/2013			1 fixture out in the hall past the mens restroom across from room 1120
FO-264834	10/18/2013			In room#309, There is one EP directly above the desk.the area is dim
FO-264835	10/18/2013			1 EP,4th floor, fixture is directly across from elevators in front of window (case ave)
FO-264836	10/18/2013			1 EP, 4th floor, fixture is overhead at the entrance to room# 410
FO-264845	10/18/2013	10/24/2013		Please have Maintenance laborer deliver 1 drum of Lokor from FP&M stock room to Bio Sci b
FO-264846	10/18/2013	10/21/2013		Please have Maintenance laborer deliver 1 drum of Aquakleen and 2 drums of Lokor from FP
FO-264847	10/18/2013	10/23/2013		Please have Maintenance laborer deliver 1 drum of Oxykor , 1 drum Quest , 2 drums Lokor an
FO-264848	10/18/2013	10/21/2013		Please have Maintenance laborer deliver 1 drum Lokor , 1 drum Aquakleen and 1 drum Haloc
FO-264859	10/18/2013	10/24/2013		R/R RM 00013/CLASS RM WALL CLOCK NEEDS CORRECT TIME Finished 10/25/2013LT
FO-264860	10/18/2013	10/25/2013		R/R RM 00027/CLASS RM WALL CLOCK NEEDS CORRECT TIME Finished 10/28/2013
FO-264866	10/18/2013	10/22/2013		R/R RM 1545/LECT HALL WALL CLOCK STOPPED WORKING Finished 10/22/2013LT
FO-264893	10/21/2013			LABORER TO PICKUP & DISPOSE THE OLD BATHROOM LIGHT TRUOGHS OUTSIDE AL
FO-264973	10/21/2013			Romm 27 mechanical room in basement, light switches don't work, flickering lights
FO-264979	10/21/2013	10/22/2013		Move lift from UGL to Reuther Library, and take back to UGL when job is done. Finished 10/22
FO-265013	10/22/2013	10/24/2013		R/R RM 2327 TIGHTEN LITE FIXTURE Ceiling light fixture is loose and air is leaking out arou
FO-265022	10/22/2013			2 fixtures out, 3rd floor, men's restroom
FO-265023	10/22/2013			2 EP's
FO-265025	10/22/2013	10/29/2013		in room 43, fixture in the middle of the room is out. Finished 10/30/2013LT
FO-265026	10/22/2013			in room 436, fixture over the blackboard is out.
FO-265027	10/22/2013			1 EP in room# 446, overhead. (Bulbs have been changed)
FO-265029	10/22/2013			2 fixture's out in room34
FO-265051	10/22/2013	10/29/2013		R/R RM 106 please repair generator alarm
FO-265197	10/22/2013			Two lights above the basketball courts are out and need to be replaced.
FO-265179	10/23/2013			1 fixture out. Lights outside of the Pepsi mahine in the grounds department.
FO-265180	10/23/2013			in room 140. 1 EP. Fixture sits in front of entrance to room 140 behind (check out desk)
FO-265181	10/23/2013	10/28/2013		1 fixture out in room 101.1
FO-265182	10/23/2013			1 EP in room#426, over entrance. Fixture Bulb's replaced
FO-265190	10/23/2013	10/24/2013		Please have Maintenance laborer deliver 2 pails Quest , 2 pails Neutramine and 3 pails Qxyco
FO-265253	10/23/2013			ELECTRICIANS,R/R BSMT PLEASE REPAIR INDICATOR LIGHTS ON BOILERS.PRIORI
FO-265310	10/24/2013			1 fixture out in room# 279
FO-265390	10/24/2013	10/28/2013		Electricians-

WO	Recieved	Finished	Total	Request
FO-265463	10/25/2013			Carpenters- R/R BLDG Please erect scaffold on indoor side of loading dock under west infra
FO-265481	10/25/2013	10/28/2013		Please have Maintenance laborer deliver 2 drums Lokor , 1 drum Aquakleen from FP&M stock
FO-265482	10/25/2013	10/28/2013		Unload steel delivery for Pipe Shop,,,,,,,,,,,,, See Jim Hill Finished 10/30/2013LT
FO-265493	10/25/2013			in room# 3700, 4 fixtures are out.
FO-265495	10/25/2013	10/28/2013		There are 12 fixtures out in the Elaine L. Jacob Gallery- 1st and 2nd level in gallery. There is a
FO-265497	10/25/2013			In room# 125, 2 EP's on the desk at rear of the office
FO-265502	10/25/2013			1 fixture out in room# 1128
FO-265505	10/25/2013			Electricians please replace motor bearings on AHU-3.
FO-265585	10/28/2013			Light above the stairwell landing (between 2nd and 3rd floor) facing reuther library. too high to
FO-265587	10/28/2013			1 fixture out on the stairwell landing (2nd floor) facing reuther library
FO-265597	10/28/2013			Repair bad clock in room 112.
FO-265621	10/28/2013			Move car to roof
FO-265627	10/28/2013			2 fixtures out in the mechanical room, 3rd floor
FO-265628	10/28/2013			3 fixtures out in room# 1237.
FO-265649	10/28/2013			8th floor men's restroom across from conference room8308---light bulb out. Please replace. 1
FO-265664	10/28/2013	10/29/2013		Electricians:
FO-265690	10/28/2013			Replace lights in rooms 153 and 182. There is a cover missing outside of room 153.Also if it's
FO-265691	10/28/2013			Replace lights bulbs in front of room 126 and in the kitchen. 2 electrical problems. Enter thru r
FO-265687	10/29/2013	10/29/2013		Pick up air mover, and bring it back to shop. Finished 10/30/2013LT
FO-265721	10/29/2013	10/30/2013		Donald Wrench wants all T12 bulbs converted to T8 bulbs in the building. He wants it all to ma
FO-265749	10/29/2013	10/29/2013		Return Ballast to Grainger, and get a receipt. Finished 10/30/2013LT
FO-265824	10/30/2013			Repair lighting in Electric shop.
FO-265842	10/30/2013			1 fixture out. Wall light along side of elevator (1st floor)
FO-265845	10/30/2013			R/R RM 2528 There is no power on one side of the lab. The phone does not work from this.
FO-265847	10/30/2013			1 fixture out in room 151 (Custodial Closet
FO-265850	10/30/2013			1 fixture out in mens room, 1st floor. There is a fixture that is constantly flickering in restroom.
FO-265857	10/30/2013			1 EP in womens restroom
FO-265858	10/30/2013			1 EP in room# 322. Fixture is in front of Blackboard
FO-265861	10/30/2013			1 Fixture out between hallway room 34-31
FO-265902	10/30/2013			Removed old electric motor and surge tank from motor end of AHU #2
FO-265901	10/30/2013			Please have "Laborer" remove old spence valves left by the pipefitters on the floor by the heat
FO-265918	10/30/2013			Lights out in 5123,5136, and 5130. Room 5136 has 1 electrical problem. Room 5130 has 1 el
T - Laborer			2	
FO-263408	10/1/2013	10/3/2013		This is a maintenance request for Doug to arrange to deliver a podium to State Hall general cl
FO-263536	10/2/2013			Weed/growing vine removal on buildings thru-out the University campus.
T - Locksmith			63	
FO-263533	10/2/2013	10/7/2013		#74834 5 Keys Room 2214Finished 10/9/2013LT
FO-263534	10/2/2013	10/7/2013		#74969 2 CoreFinished 10/9/2013LT
FO-263538	10/2/2013	10/7/2013		#74967 1 KeyFinished 10/9/2013LT
FO-263563	10/2/2013	10/3/2013		#71920 5 Keys Room 224.6 Finished 10/4/2013 LT
FO-263585	10/2/2013	10/7/2013		#74970 3 Keys and 2 Cores Room 1209Finished 10/9/2013LT
FO-263586	10/2/2013	10/7/2013		#74971 1 Key
FO-263591	10/2/2013	10/7/2013		#74869 1 KeyFinished 10/9/2013LT
FO-263624	10/3/2013	10/3/2013		73756 8 KEYS Finished 10/4/2013 LT
FO-263722	10/4/2013	10/8/2013		#73648 3 Keys Room 1524Finished 10/9/2013LT
FO-263723	10/4/2013	10/8/2013		#73654 3 Key Rpp, 3314Finished 10/9/2013LT
FO-263767	10/4/2013	10/8/2013		#73413 2 KeysFinished 10/9/2013LT
FO-263768	10/4/2013	10/8/2013		#74974 3 Keys and 2 Cores Room 1208Finished 10/9/2013LT

WO	Recieved	Finished	Total	Request
FO-263820	10/7/2013	10/8/2013		#74948 4 KeysFinished 10/9/2013LT
FO-263821	10/7/2013	10/8/2013		#74975 1 Key Room 2074Finished 10/9/2013LT
FO-263943	10/8/2013	10/8/2013		72436 2 KEYSFinished 10/9/2013LT
FO-263944	10/8/2013	10/9/2013		72437 3 KEYS AND 3 CORES Finished 10/11/2013LT
FO-263945	10/8/2013	10/9/2013		74801 1 CORE Finished 10/11/2013LT
FO-263946	10/8/2013	10/11/2013		71714 5 KEYS Finished 10/14/2013LT
FO-263947	10/8/2013	10/9/2013		62439 10 KEYS AND 2 CORE Finished 10/11/2013LT
FO-263997	10/9/2013	10/11/2013		#74978 2 Keys Room 3.384 Finished 10/14/2013LT
FO-264005	10/9/2013	10/11/2013		#74716 3 Keys Room 9244 Finished 10/14/2013LT
FO-264050	10/9/2013	10/9/2013		#74976 1 Key Finished 10/11/2013LT
FO-264140	10/9/2013	10/9/2013		#72150 2 Keys Finished 10/11/2013LT
FO-264141	10/9/2013	10/9/2013		#72149 6 Keys Room 598 Finished 10/11/2013LT
FO-264337	10/14/2013			74898 17 Cores 67 Keys
FO-264338	10/14/2013	10/15/2013		#66031 2 Keys Finished 10/18/2013LT
FO-264339	10/14/2013	10/15/2013		#70361 2 Keys Room 3105 Finished 10/18/2013LT
FO-264340	10/14/2013	10/15/2013		#70360 5 Keys Room 3105 Finished 10/18/2013LT
FO-264341	10/14/2013	10/15/2013		#65851 6 Keys Finished 10/18/2013LT
FO-264342	10/14/2013	10/16/2013		#74844 4 Keys Finished 10/18/2013LT
FO-264423	10/14/2013	10/16/2013		REQ# 73733 8 KEYS ROOMS # 2209 , 1120 & 2215 Finished 10/18/2013LT
FO-264473	10/15/2013	10/15/2013		71878 Scott Hall 9213 Finished 10/18/2013LT
FO-264489	10/15/2013	10/16/2013		74094 10 DESK KEYS
FO-264494	10/15/2013	10/15/2013		69708 1 KEY
FO-264496	10/15/2013	10/15/2013		72404 3 KEYS Finished 10/18/2013LT
FO-264517	10/15/2013	10/16/2013		74707 1 KEY Finished 10/18/2013LT
FO-264518	10/15/2013	10/16/2013		74708 1 KEY Finished 10/18/2013LT
FO-264525	10/15/2013	10/15/2013		72519 1 FILE KEY
FO-264581	10/16/2013	10/15/2013		#73757 5 Keys Room 7702 Finished 10/18/2013LT
FO-264584	10/16/2013	10/16/2013		#75008 5 Keys Finished 10/18/2013LT
FO-264602	10/16/2013	10/22/2013		#63938 6 Keys and 6 Cores Finished 10/25/2013LT
FO-264688	10/17/2013	10/17/2013		72406 4-KEYS Finished 10/18/2013LT
FO-264851	10/18/2013	10/18/2013		#73768 9 Keys Room 3138 Finished 10/22/2013LT
FO-264855	10/18/2013			#75011 14 Keys
FO-264856	10/18/2013	10/22/2013		#74943 2 Cores Finished 10/25/2013LT
FO-264863	10/18/2013			Request #75013; (2) Cores.
FO-264894	10/21/2013			#73559 3 Keys
FO-265216	10/23/2013	10/23/2013		#74899 1 Keys Stockroom Finished 10/25/2013LT
FO-265217	10/23/2013	10/23/2013		#74821 6 Keys Finished 10/25/2013LT
FO-265218	10/23/2013	10/23/2013		#74822 5 Keys Room 4402,4413,4416 Finished 10/25/2013LT
FO-265292	10/24/2013	10/24/2013		#73762 2 Keys Room 7702 Finished 10/25/2013LT
FO-265293	10/24/2013	10/24/2013		#61655 12 Keys Room 1001 Finished 10/25/2013LT
FO-265573	10/28/2013	10/28/2013		#72405 3 Keys Room 2235 Finished 10/30/2013LT
FO-265575	10/28/2013	10/25/2013		#71221 18 Keys Room 1316 Finished 10/28/2013
FO-265576	10/28/2013	10/28/2013		#74305 3 Keys Room 9244 Finished 10/30/2013LT
FO-265578	10/28/2013	10/28/2013		#74301 3 Keys Room 9252 Finished 10/30/2013LT
FO-265615	10/28/2013	10/2/2013		#74703 4 Keys Room3325 Finished 10/30/2013LT
FO-265616	10/28/2013	10/29/2013		#74704 4 Keys Room 3327 Finished 10/30/2013LT
FO-265617	10/28/2013	10/28/2013		#75018 1 Key Finished 10/30/2013LT

WO	Recieved	Finished	Total	Request
FO-265653	10/28/2013	10/29/2013		combo lock to stockroom not working Finished 10/30/2013LT
FO-265820	10/30/2013			KEYS & CORES (OCTOBER 2013)
FO-265830	10/30/2013			#73770 10 Keys
FO-265878	10/30/2013			#72460 1 Key and 1 Core Room 4015
T - Painter			24	
FO-263364	10/1/2013	10/2/2013		PAINT THE BACKING BOARD. SECOND FLOOR DRINKLING FOUNTAIN. Finished 10/4/20
FO-264284	10/1/2013	10/11/2013		Mud & Tape Gypsum wall and paint in area of (ARAMARK - Provisions on Demand). This is d
FO-263843	10/3/2013			Graffiti is sprayed on the wall and limestone
FO-263704	10/3/2013	10/4/2013		SAFETY TIME FOR THE MONTH OF OCTOBER. Finished 10/7/2013LT
FO-263797	10/5/2013	10/17/2013		The ceiling paint is peeling and falling to the floor over the audience on the right sight at the re
FO-263856	10/7/2013			R/R 2ND FLR HALLWAY OUTSIDE OF RM 238 PAINT/PATCH DRYWALL PATCH. PAINT R
FO-263857	10/7/2013			R/R RM 238 PAINT/PATCH DRYWALL PATCH BEHIND REFRIGERATOR. PAINT REQUES
FO-264002	10/9/2013	10/10/2013		R/R GARAGE/BACK DOOR 3 FIRE EXTINGUISHERS NEED REFILLING Finished 10/11/201
FO-264327	10/12/2013			HANDYMAN TIME.
FO-264328	10/12/2013			MTL TIME.
FO-264693	10/17/2013	10/22/2013		PAINT THE STEAL ON THE HIGH ROOF. Finished 10/22/2013LT
FO-264765	10/17/2013	10/18/2013		R/R 150/SUPERVISOR'S OFC NEED 2 BOXES OF COPY PAPER Finished 10/21/2013LT
FO-264936	10/18/2013			Need WSU painters to paint exhaust vent in room 0513 at Elliman.
FO-264964	10/21/2013			Painters are needed to paint two offices in the Grounds Department. Room 111 and 111A. If
FO-265101	10/22/2013	10/28/2013		I would 50 wood gate arms made 1 x 4 1/2 x 10. A sample of the wooden gate arms were give
FO-265160	10/23/2013	10/25/2013		PAINT THE STEEL ON THE PARKING DECK. Finished 10/28/2013
FO-265401	10/24/2013			PAINT THE LADIES ROOM FIRST FLOOR FRIEGHT ELEVATOR SIDE. DUE TO LIGHTING
FO-265403	10/24/2013			PAINT THE MEN'S ROOM FIRST FLOOR FRIEGHT ELEVATOR SIDE. DUE TO LIGHTING
FO-265637	10/25/2013			Men's 2nd flr Purdy Public Restroom (in stairwell)
FO-265523	10/25/2013			Painter scrape and repaint ceiling in lab. Paint is peeling.
FO-265733	10/25/2013			Purdy Library Room 240, Located in Stair 1
FO-265536	10/25/2013	10/25/2013		PAINT AS NEEDED DUE TO A PLASTER REPAIR. FIRST FLOOR MEN'S ROOM CASS SID
FO-265561	10/28/2013			PAINT AS NEEDED. BASEMENT HALLWAY GOING TO THE KITCHEN AREA.
FO-265762	10/29/2013			Inside the women's locker room, above the middle stall, there is plaster on the ceiling that is cr
T - Pipefitter			23	
FO-263367	10/1/2013			**PIPEFITERS TO RUN AIR AND CONNECT TO SAND BLASTER.....JH/ 10-1-13.....
FO-263592	10/2/2013	10/7/2013		R/R grease fitting to motor ef-6b , ef-5b JH/10-2-13 DUE 11-2-13Finished
FO-263594	10/2/2013	10/4/2013		R/R flange leak on main steam header JH/10-2-13 DUE 11-2-13 Finished
FO-263625	10/3/2013			STEAM FITTERS-
FO-263653	10/3/2013	10/3/2013		R/R condensate valve on heat exchanger in room 0201 JH/10-3-13 DUE
FO-263691	10/3/2013			Building Utility Interruption / Communication / Processing Time for Month of October 2013.....
FO-263692	10/3/2013			Asbestos/Insulation Processing for Month of October 2013.....CB/ 10-3-13 D
FO-263693	10/3/2013			Safety / Energy Curtailment Meetings for Month of October 2013.....CB/ 10-2-13
FO-263720	10/4/2013			(**)Pipefitter; Medium
FO-263858	10/7/2013			PIPEFITERS-
FO-263929	10/8/2013	10/17/2013		RM 111 GYMNASIUM HAS BROKEN RAILING NEEDS TO BE FIXED ASAP JH/1
FO-263933	10/8/2013			(**)Please remove accitrem controller on D.A. tank for small boiler . Boiler will be shut down 1
FO-264131	10/9/2013			FITTERS:
FO-264182	10/10/2013			(**)HEATING UNIT LEAKING. BASEMENT.....RC/10-14-13 DUE 11-10-1
FO-264438	10/14/2013	10/22/2013		R/R RM 213 Radiator in the room is leaking again - there is a small amount or water on the flo
FO-264899	10/21/2013	10/21/2013		R/R BUS SVCS' AREA (next to lunch rm) Larry's new office - install steam control valve for exi
FO-264955	10/21/2013	10/21/2013		Trade: Pipefitter Priority: Low
FO-264999	10/22/2013	10/22/2013		Steam fitters- Repair leaking steam coil on fan #3.

WO	Recieved	Finished	Total	Request
FO-265356	10/24/2013	10/29/2013		R/R RM 0002/MECH RM please r/r leaking condensate line by feed tank in boiler room.....
FO-265511	10/25/2013			Fitters-
FO-265667	10/28/2013			Fitters:
FO-265680	10/28/2013			R/R steam leak on 4" gate valve in mechanical room up stairs EA/RC 10-29-13
FO-265917	10/30/2013			STEAMFITTERS-PLEASE REPAIR STEAM LEAK FROM FLANGE IN FRONT OF #2 BOILE
T - Plumber			71	
FO-263390	10/1/2013			**R/R RM 237 Left-hand sink drains slowly..... MM/10-1-13..... DUE 11-1-13
FO-263392	10/1/2013	10/4/2013		R/R RM 137/Men's Restroom (in study area) one stall is not working.
FO-263419	10/1/2013			R/R 2nd floor CK BEHIND WALL THAT IS BTWN MENS RM & HALLWAY-NOTE URINALS
FO-263866	10/1/2013	10/24/2013		Investigate source of water in sub-basement tunnel MP/DB 10-1-13 DU
FO-263428	10/1/2013			Ceiling Leak in basement of Art Building. Leak is located above practice rms down the hall fro
FO-263619	10/2/2013			Administrative Time for October 2013
FO-263531	10/2/2013	10/9/2013		R/R Rm. 60.1, sink is not draining..... RJC/RB 10-2-13 DUE 11-2-13 Finished 1
FO-263577	10/2/2013			LAB 160 EYE WASH NEEDS TO BE REPLACED, ACROOS FROM FUME HOOD #5. SINK
FO-263670	10/3/2013			Water fountain on 3rd floor need to be repaired/replaced / No water making it to fountain.....
FO-263689	10/3/2013			Plumber / Pipefitter Shop Time for Month of October 2013
FO-263702	10/3/2013	10/4/2013		R/R RM 140 Fix leak from sanitary drain line above the unit substation area in room 140.....
FO-263771	10/4/2013			R/R water leak from meter on 1st HWH on left in room 100 MM/10-4-13 D
FO-263813	10/7/2013	10/8/2013		R/R RM 3341 (Fumehood south side of rm) Fumehood has a leak. This is a second request.
FO-263920	10/7/2013	10/11/2013		@ Parking Lot 31 (Anthony Wayne Dr.)
FO-263860	10/7/2013			(**)Toilet in Men's Room 42 clogged. Needs to be unclogged , janitors closet just off elevator h
FO-264191	10/8/2013			PS#3- I would like for Power Vac to move
FO-264192	10/8/2013			PS#3- I would like for Power Vac to move
FO-264133	10/9/2013			R/R 4" check valve on acid sump pump (Sub Basement).....MP/DB 10-9-13
FO-264202	10/10/2013			Carpet is always wet in training room (doctor's exam room)..Supposedly water leaking from in
FO-264225	10/10/2013	10/16/2013		REPLACE WATER FILTER ON THE DRINKING FOUNTAIN AND THE ICE MAKER IN THE L
FO-264229	10/10/2013	10/16/2013		R/R 1st floor mens plumbing needs MP/DB 10-10-13 DUE 11-10-13 Finis
FO-264253	10/10/2013			Leak in third floor bathroom - water pooling between sink and toilet. Please investigate.....
FO-264297	10/11/2013			Plumbers:
FO-264422	10/11/2013	10/15/2013		The men rest room at PS1 sink water is
FO-264325	10/12/2013	10/15/2013		The water pressure in the men's room urinals and toilets is low. Men's Room on the south side
FO-264348	10/14/2013			Retrieve lost 5/8" cable in drain line MP/DB 10-14-13..... DUE 11-14-13
FO-264353	10/14/2013	10/16/2013		Janitors closet room 2431 laundry tub faucet leaks and cold water handle is missing
FO-264359	10/14/2013			R/R RM 012 REPAIR ONLINE WATER FILTER CONNECTED TO ICE MAKER IS LEAKING ,
FO-264453	10/15/2013	10/15/2013		The men's restroom (room 240) has a leaking toilet. It is located in the third stall from the door
FO-264534	10/15/2013	10/16/2013		5th floor mens room nonhandicap urinal has a long flush cycle MP/DB 10-15-13.....
FO-264575	10/16/2013	10/17/2013		Men's Restroom by the frieght elevtor 2 facucet linking very badly..... MP/DB 10-16-13
FO-264624	10/16/2013			faucet appears to be loose from the sink. Possible need for replacement..... MM/10-
FO-264779	10/18/2013	10/22/2013		In the women's restroom on the first floor (room #1332.2)The toilet closest to the electric hand
FO-264783	10/18/2013	10/18/2013		The metal water fountain on the second floor across from janitor closet #203, placed between
FO-264784	10/18/2013	10/18/2013		In the women's room 330, the second stall on the right hand side has flushing issues. It is in n
FO-264816	10/18/2013	10/29/2013		R/R 1ST FLR RECEIVING AREA Need filter from water fountain replaced..... RJC/RB
FO-264874	10/18/2013	10/24/2013		1st floor womans restroom toilet is not working..... RJC/RB 10-21-13..... DUE
FO-264875	10/18/2013	10/29/2013		2nd floor (silver) water fountain over flowing..... RJC/RB 10-21-13 DUE 11-1
FO-264925	10/21/2013			R/R 1st FLR MENS RR ACROSS FROM ELEVS' HANDICAP STALL TOILET SEAT NEEDS
FO-264930	10/21/2013	10/24/2013		R/R RM 106 Men's restroom - front of building behind service desk (Room 106). The toliets ar
FO-264965	10/21/2013	10/28/2013		Plumbers,

WO	Recieved	Finished	Total	Request
FO-264966	10/21/2013	10/28/2013		Plumbers,
FO-265028	10/22/2013	10/23/2013		R/R 2ND FLR Men's restroom located on the 2nd floor west wing urinal is out of order. Water i
FO-265031	10/22/2013	10/25/2013		Plumber repair toilet water leak when flushing.....,MM/10-22-13 DUE 11-22-13
FO-265058	10/22/2013	10/28/2013		PLUMBERS,
FO-265062	10/22/2013	10/28/2013		PLUMBERS,
FO-265100	10/22/2013			The 19 tile from the kitchen door has black
FO-265096	10/22/2013	10/28/2013		MEN'S RESTROOM #0348 LAST STALL, TOILET SEAT BROKEN. PLEASE REPLACE.....
FO-265255	10/23/2013			R/R RM 114/Mens locker room shower in room 114 has no hot water. Not even warm water, ju
FO-265262	10/23/2013			EMERGENCY/PLUMBERS
FO-265274	10/23/2013			R/R 1ST FLR LANDNING MENS RR ONE OF THE TOILETS FLUSH HANDLE LEAKS
FO-265286	10/24/2013			Trade: Plumber Priority: Low
FO-265288	10/24/2013			Lecture Hall on the stage their is a access door on the floor of the stage. Old drain line openin
FO-265375	10/24/2013			Trade: Plumbers
FO-265426	10/25/2013			The 1st floor water fountain out of order has a clear bag over it....., MP/DB 10-28-13 ..
FO-265446	10/25/2013			Work order FO-265028 was completed incorrectly. The plumber fixed the wrong urinal. The uri
FO-265451	10/25/2013	10/29/2013		In the Dean's suite on the 1st floor in the workroom then cold water facuet in the sink does not
FO-265464	10/25/2013			R/R RM 3122 Repair dripping faucet in kitchenette (rm 3122
FO-265529	10/25/2013			In room 2234 Women's Room on the second floor. The toilet is having flushing issues. There i
FO-265530	10/25/2013			The Women's Restroom (room 2432) has a toilet in the third stall, closest to the sinks, with flu
FO-265577	10/25/2013	10/29/2013		R/R RM 13100.1Need new flusher for toilet on 13th floor for ladies room #13100.1 near break
FO-265552	10/26/2013	10/29/2013		4th floor woman's restroom (Rm 420) toilet (2nd stall)water shoots up when flushed.....
FO-265654	10/28/2013			Plumber
FO-265665	10/28/2013	10/29/2013		Room # 215 Station #1 in the embalming lab has a leaking faucet.....,MM/10-29-13.....
FO-265684	10/29/2013			Mens locker room 1st floor, room 1303, Urinal (when flushed)leaked at base of flush handle.
FO-265728	10/29/2013			(**)PLUGGED URINAL. 2ND FLOOR MEN'S RESTROOM NEAR ROOM 226....., MP/D
FO-265756	10/29/2013			In the Women's Locker Room on the restroom side, the toilet that is in the fourth stall from the
FO-265763	10/29/2013			In Room 3432 (Women's Restroom), the middle stall is having flushing issues.
FO-265778	10/30/2013			Room #174 in Knapp daycare, floor sink in custodial closet is backed up.
FO-265846	10/30/2013			R/R RM 2528 the sink is blocked. Thank you....., MP/DB 10-30-13 DUE 11
FO-265880	10/30/2013			R/R RM 108/WOMENS RR Handle/lever on toilet in first floor women's bathroom is broken - to
T - Roofing			1	
FO-265329	10/24/2013	10/28/2013		R/R roof repair.REPAIRS WERE MADE. TAH
T - Sheetmetal			1	
FO-264660	10/17/2013			Refer PO#649446; Law classroom: Site previously inspected by L.Morris.w/quote. Section of h
Routine			41	
T - Electrician			41	
FO-264092	10/7/2013	10/11/2013		contact: Jason Clark
FO-264008	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264010	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264011	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264012	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264013	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264014	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264015	10/9/2013	10/14/2013		ROUTINE CHECK 10/7 THRU 10/11/13 Finished 10/16/2013LT
FO-264094	10/9/2013	10/14/2013		contact: Jason Clark Finished 10/16/2013LT
FO-264098	10/9/2013	10/16/2013		contact: Jason Clark
FO-264100	10/9/2013	10/21/2013		contact: Jason Clark
FO-264204	10/10/2013	10/23/2013		contact: Jason Clark

WO	Recieved	Finished	Total	Request
FO-264205	10/10/2013	10/28/2013		contact: Jason Clark
FO-264207	10/10/2013			contact: Jason Clark
FO-264208	10/10/2013			contact: Jason Clark
FO-264212	10/10/2013			contact: Jason Clark
FO-264213	10/10/2013			contact: Jason Clark
FO-264215	10/10/2013			contact: Jason Clark
FO-264216	10/10/2013			contact: Jason Clark
FO-264329	10/12/2013	10/14/2013		Generator test Finished 10/16/2013LT
FO-264396	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264397	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264398	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264399	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264401	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264402	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264403	10/14/2013	10/21/2013		ROUTINE CHECK 10/14 THRU 10/18/13 Finished 10/22/2013LT
FO-264908	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264910	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264911	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264912	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264913	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264914	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-264915	10/21/2013	10/26/2013		ROUTINE CHECK 10/21 THRU 11/1/13 Finished 10/28/2013
FO-265881	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265883	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265885	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265886	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265887	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265888	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13
FO-265889	10/30/2013			ROUTINE CHECK 10/28 THRU 11/1/13

Scheduled Maint. (PM)

715

Engineering

681

Low

2

E - Preventative Maintenance

1

FO-265424 10/25/2013

PM: AHU-3 (field name AHU-1)

E - Southeast

1

FO-264118 10/9/2013

FO Number for Year-Long Chemicals to treat boiler , FY 2014.

Routine

679

E - Area 1 Engineer

24

FO-262413 10/1/2013 10/2/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262414 10/1/2013 10/2/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262415 10/1/2013 10/2/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262416 10/1/2013 10/2/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262417 10/1/2013 10/3/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262418 10/1/2013 10/3/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262419 10/1/2013 10/3/2013

PM - Centrifugal Pump, over 1 H.P.

FO-262420 10/1/2013 10/3/2013

PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262421	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262422	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262423	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262424	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262439	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262441	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262442	10/1/2013	10/7/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262444	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262445	10/1/2013	10/7/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262515	10/1/2013	10/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262516	10/1/2013	10/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262517	10/1/2013	10/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262518	10/1/2013	10/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-263237	10/14/2013		10/8/2013	PM - Emergency Shower/Eyewash Station
FO-263238	10/14/2013		10/8/2013	PM - Emergency Shower/Eyewash Station
FO-263239	10/14/2013		10/8/2013	PM - Emergency Shower/Eyewash Station
E - Area 2 Engineer			13	
FO-262666	10/1/2013		10/2/2013	PM - Humidifier
FO-262667	10/1/2013		10/2/2013	PM - Humidifier
FO-262668	10/1/2013		10/12/2013	PM - Humidifier
FO-262669	10/1/2013		10/12/2013	PM - Humidifier
FO-262672	10/1/2013		10/12/2013	PM - Humidifier
FO-262673	10/1/2013		10/12/2013	PM - Humidifier
FO-260781	10/4/2013		10/6/2013	Generator Maintenance, Monthly
FO-260787	10/4/2013		10/6/2013	Generator Maintenance, Monthly
FO-260789	10/4/2013		10/6/2013	Generator Maintenance, Monthly
FO-260791	10/4/2013		10/6/2013	Generator Maintenance, Monthly
FO-262531	10/4/2013	10/9/2013		PM - Unspecified
FO-262532	10/4/2013	10/11/2013		PM - Unspecified
FO-260783	10/8/2013	10/8/2013		Generator Maintenance, Monthly
E - Auxiliary			47	
FO-262675	10/1/2013	10/11/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-262679	10/1/2013	9/26/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262680	10/1/2013	9/26/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262681	10/1/2013	9/26/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262682	10/1/2013	9/26/2013		PM - Water Booster Pump
FO-262683	10/1/2013	9/26/2013		PM - Water Booster Pump
FO-262685	10/1/2013			PM - Air Handling Unit
FO-262686	10/1/2013			PM - Air Handling Unit
FO-262687	10/1/2013			PM - Air Handling Unit
FO-262688	10/1/2013			PM - Air Handling Unit
FO-262689	10/1/2013			PM - Air Handling Unit
FO-262690	10/1/2013			PM - Air Handling Unit
FO-262691	10/1/2013			PM - Air Handling Unit
FO-262692	10/1/2013			PM - Water/Air Cooled Condenser
FO-262693	10/1/2013			PM - Absorption Unit
FO-262694	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262695	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262696	10/1/2013	10/8/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262697	10/1/2013			PM - Absorption Unit
FO-262698	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262699	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262700	10/1/2013	10/2/2013		PM - Heat Exchanger and Economizer
FO-262701	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262702	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262703	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262704	10/1/2013			PM - Heat Exchanger and Economizer
FO-262705	10/1/2013			PM - Heat Exchanger and Economizer
FO-262706	10/1/2013			PM - Heat Exchanger and Economizer
FO-262708	10/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-262709	10/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-262710	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262711	10/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
FO-262677	10/2/2013	10/23/2013		PM - Air Handling Unit
FO-262678	10/2/2013			PM - Air Handling Unit
FO-262707	10/7/2013			PM - Emergency Shower/Eyewash Station
FO-260765	10/8/2013			Generator Maintenance, Monthly
FO-260767	10/9/2013	10/9/2013		Generator Maintenance, Monthly
FO-263255	10/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-263256	10/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-263257	10/13/2013			PM - Centrifugal Pump, over 1 H.P.
FO-263254	10/14/2013			PM - Emergency Shower/Eyewash Station
FO-260775	10/16/2013			Generator Maintenance, Monthly
FO-260745	10/22/2013	10/22/2013		Generator Maintenance, Monthly
FO-260747	10/22/2013	10/22/2013		Generator Maintenance, Monthly
FO-260749	10/22/2013	10/22/2013		Generator Maintenance, Monthly
FO-260751	10/22/2013	10/22/2013		Generator Maintenance, Monthly
FO-260753	10/22/2013	10/22/2013		Generator Maintenance, Monthly
E - Command Center			1	
FO-262602	10/5/2013			PM - Air Compressor, Reciprocating 5-40 H.P.
E - MedPharm			50	
FO-259228	10/1/2013			PM - Reverse Osmosis Water Softener System
FO-262425	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262428	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262429	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262430	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262431	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262432	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262433	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262450	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262456	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262457	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262458	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262459	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262460	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262461	10/1/2013			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262462	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262463	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262464	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262465	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262513	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262514	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262470	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262471	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262472	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262473	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262474	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262475	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262476	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262477	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262478	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262479	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262480	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262481	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262482	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262483	10/3/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262484	10/4/2013	10/16/2013		PM - Water Softener
FO-262451	10/7/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-262452	10/7/2013	10/25/2013		PM - Emergency Shower/Eyewash Station
FO-262453	10/7/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-262454	10/7/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-262455	10/7/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-260761	10/11/2013			Generator Maintenance, Monthly
FO-260763	10/11/2013			Generator Maintenance, Monthly
FO-258073	10/14/2013			PM - Domestic Water Heater, Electric
FO-258732	10/14/2013			PM - Domestic Water Heater, Electric
FO-263235	10/14/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-263236	10/14/2013	10/21/2013		PM - Emergency Shower/Eyewash Station
FO-260778	10/15/2013			Generator Maintenance, Monthly
FO-260740	10/25/2013			Generator Maintenance, Monthly
FO-260742	10/25/2013	10/25/2013		Generator Maintenance, Monthly
E - Midnight Swing Shift			1	
FO-262523	10/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test
E - North			73	
FO-256101	10/1/2013			PM - Domestic Water Heater, Electric
FO-256102	10/1/2013			PM - Domestic Water Heater, Electric
FO-256891	10/1/2013			PM - Sump Pump
FO-256892	10/1/2013			PM - Sump Pump
FO-262526	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262527	10/1/2013	10/4/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262528	10/1/2013	10/3/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262529	10/1/2013	10/25/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262530	10/1/2013	10/2/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262541	10/1/2013			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262542	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262543	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262544	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262545	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262553	10/1/2013	10/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262554	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262555	10/1/2013	10/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262556	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262557	10/1/2013	10/21/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262558	10/1/2013	10/18/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262566	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262567	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262568	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262569	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262577	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262578	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262579	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262580	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262581	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262582	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262583	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262584	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262585	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262670	10/1/2013			PM - Cooling Tower Lay-up - GE Betz
FO-262671	10/1/2013	10/24/2013		PM - Cooling Tower Lay-up - GE Betz
FO-262674	10/1/2013	10/23/2013		PM - Cooling Tower Lay-up - GE Betz
FO-262661	10/2/2013	10/24/2013		PM - Heat Exchanger and Economizer
FO-262662	10/2/2013	10/25/2013		PM - Heat Exchanger and Economizer
FO-262663	10/2/2013			PM - Heat Exchanger and Economizer
FO-262664	10/2/2013			PM - Heat Exchanger and Economizer
FO-262665	10/2/2013			PM - Heat Exchanger and Economizer
FO-258726	10/7/2013	10/7/2013		PM - Unspecified
FO-258727	10/7/2013	10/10/2013		PM - Unspecified
FO-259866	10/7/2013			PM - Forced Air Furnace (Jacob House) - Winter
FO-259867	10/7/2013			PM - Forced Air Furnace (Jacob House) - Winter
FO-259868	10/7/2013			PM - Forced Air Furnace (Jacob House) - Winter
FO-262676	10/7/2013			PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-260780	10/11/2013	10/11/2013		Generator Maintenance, Monthly
FO-263247	10/11/2013			PM - Air Handling Unit
FO-263248	10/11/2013			PM - Air Handling Unit
FO-265419	10/11/2013			PM - Air Handling Unit
FO-265420	10/11/2013			PM - Air Handling Unit
FO-256887	10/14/2013	10/23/2013		PM - Unspecified
FO-258070	10/14/2013			PM - Heat Exchanger and Economizer
FO-258071	10/14/2013			PM - Heat Exchanger and Economizer
FO-258735	10/14/2013	10/21/2013		PM - Harmsco Side Stream Filter
FO-258736	10/14/2013	10/24/2013		PM - Harmsco Side Stream Filter

WO	Recieved	Finished	Total	Request
FO-258739	10/14/2013	10/21/2013		PM - Harmsco Side Stream Filter
FO-260512	10/14/2013	10/11/2013		PM - Centrifugal Pump, over 1 H.P.
FO-260519	10/14/2013			PM - Water/Air Cooled Condenser
FO-260520	10/14/2013			PM - Water/Air Cooled Condenser
FO-260521	10/14/2013			PM - Water/Air Cooled Condenser
FO-260523	10/14/2013			PM - Water/Air Cooled Condenser
FO-260524	10/14/2013			PM - Water/Air Cooled Condenser
FO-261835	10/14/2013	10/28/2013		PM - Water Booster Pump
FO-261836	10/14/2013	10/28/2013		PM - Water Booster Pump
FO-262574	10/14/2013	10/14/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262575	10/14/2013	10/14/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262576	10/14/2013	10/14/2013		PM - Centrifugal Pump, over 1 H.P.
FO-256097	10/21/2013	10/22/2013		PM - Heat Exchanger and Economizer
FO-265557	10/21/2013			PM - Grease Fan Bearings & Check Belts Bi-Monthly
FO-260759	10/23/2013	10/23/2013		Generator Maintenance, Monthly
FO-265556	10/23/2013			PM - Domestic Water Heater, Electric
E - Northeast			55	
FO-258728	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-258729	10/1/2013			PM - Domestic Water Heater, Gas
FO-259241	10/1/2013	10/29/2013		PM - Unit/Space Heater
FO-259242	10/1/2013	10/23/2013		PM - Unit/Space Heater
FO-259243	10/1/2013	10/29/2013		PM - Unit/Space Heater
FO-259244	10/1/2013	10/23/2013		PM - Unit/Space Heater
FO-259245	10/1/2013	10/23/2013		PM - Unit/Space Heater
FO-259246	10/1/2013	10/29/2013		PM - Unit/Space Heater
FO-259247	10/1/2013	10/29/2013		PM - Unit/Space Heater
FO-260525	10/1/2013			PM - Sump Pump
FO-260526	10/1/2013			PM - Sump Pump
FO-262615	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262616	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262617	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262618	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262619	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262620	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262621	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262622	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262623	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262624	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262625	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262626	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262627	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262628	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262629	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262630	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262631	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262632	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262633	10/1/2013			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262634	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262635	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-259248	10/7/2013			PM - Unit/Space Heater
FO-259249	10/7/2013			PM - Unit/Space Heater
FO-259250	10/7/2013			PM - Unit/Space Heater
FO-259251	10/7/2013			PM - Unit/Space Heater
FO-259252	10/7/2013			PM - Unit/Space Heater
FO-259864	10/7/2013			PM - Sump Pump
FO-259865	10/7/2013			PM - Sump Pump
FO-257507	10/14/2013			PM - Condensate Return Pump
FO-257508	10/14/2013			PM - Condensate Return Pump
FO-258061	10/14/2013			PM - Centrifugal Pump, over 1 H.P.
FO-258077	10/14/2013			PM - Centrifugal Pump, over 1 H.P.
FO-258088	10/14/2013			PM - Domestic Water Heater, Electric
FO-258741	10/14/2013			PM - Sewage Lift Pump
FO-259862	10/14/2013			PM - Domestic Water Heater, Gas
FO-259863	10/14/2013			PM - Domestic Water Heater, Gas
FO-261831	10/14/2013			PM - Centrifugal Pump, over 1 H.P.
FO-257255	10/14/2013			perform PM on RTU #2
FO-257256	10/14/2013			perform PM on RTU #3
FO-257257	10/14/2013			perform PM on RTU #4
FO-260769	10/15/2013			Generator Maintenance, Monthly
FO-260777	10/17/2013			Generator Maintenance, Monthly
FO-257490	10/21/2013			PM - Heat Exchanger and Economizer
FO-260737	10/23/2013			Generator Maintenance, Monthly
E - Preventative Maintenance			282	
FO-260810	10/1/2013	9/27/2013		PM - Fan Coil/HV/AC Unit
FO-260823	10/1/2013			PM - Air Handling Unit
FO-260825	10/1/2013	9/28/2013		PM - Fan Coil/HV/AC Unit
FO-260826	10/1/2013	9/28/2013		PM - Fan Coil/HV/AC Unit
FO-260827	10/1/2013	9/28/2013		PM - Fan Coil/HV/AC Unit
FO-260828	10/1/2013	9/28/2013		PM - Fan Coil/HV/AC Unit
FO-260829	10/1/2013	10/4/2013		PM - Fan Coil/HV/AC Unit
FO-260830	10/1/2013	10/4/2013		PM - Fan Coil/HV/AC Unit
FO-260831	10/1/2013	10/4/2013		PM - Fan Coil/HV/AC Unit
FO-260832	10/1/2013	10/4/2013		PM - Fan Coil/HV/AC Unit
FO-260833	10/1/2013	10/4/2013		PM - Fan Coil/HV/AC Unit
FO-260836	10/1/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-260837	10/1/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-260838	10/1/2013	10/5/2013		Maintain Fan Powered Boxes
FO-260839	10/1/2013			Maintain Fan Powered Boxes
FO-260840	10/1/2013	10/5/2013		Maintain Fan Powered Boxes
FO-260841	10/1/2013			Maintain Fan Powered Boxes
FO-260844	10/1/2013	10/24/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-260845	10/1/2013	10/25/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-260846	10/1/2013	10/24/2013		PM - Monthly Fire Alarm/Fire Protection System Test
FO-260847	10/1/2013			PM - Monthly Fire Alarm/Fire Protection System Test

[illegible]

WO	Recieved	Finished	Total	Request
FO-263163	10/1/2013	9/28/2013		PM - Unit/Space Heater
FO-263164	10/1/2013	9/28/2013		PM - Unit/Space Heater
FO-263165	10/1/2013	9/28/2013		PM - Unit/Space Heater
FO-263166	10/1/2013	10/18/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260834	10/3/2013	10/4/2013		PM - Unit/Space Heater
FO-260835	10/3/2013	10/4/2013		PM - Unit/Space Heater
FO-260795	10/4/2013	9/27/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260796	10/4/2013	9/24/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260797	10/4/2013	9/24/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260798	10/4/2013	9/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260799	10/4/2013	9/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260800	10/4/2013	9/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260801	10/4/2013	9/17/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260802	10/4/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260803	10/4/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260804	10/4/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260805	10/4/2013	10/5/2013		PM - Air Handling Unit
FO-260815	10/4/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260816	10/4/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260817	10/4/2013	10/31/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260818	10/4/2013	10/29/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-260819	10/4/2013	10/26/2013		PM - Air Handling Unit
FO-260820	10/4/2013	10/26/2013		PM - Air Handling Unit
FO-260821	10/4/2013	10/29/2013		PM - Air Handling Unit
FO-260822	10/4/2013	10/29/2013		PM - Air Handling Unit
FO-260824	10/4/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261493	10/6/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261494	10/6/2013	10/10/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261496	10/6/2013	10/23/2013		PM - Air Handling Unit
FO-261497	10/6/2013	10/23/2013		PM - Air Handling Unit
FO-261498	10/6/2013			PM - Air Handling Unit
FO-261499	10/6/2013			PM - Air Handling Unit
FO-263158	10/7/2013	10/9/2013		Replace PRE-filters
FO-263159	10/7/2013	10/9/2013		Replace PRE-filters
FO-263160	10/7/2013	10/9/2013		Replace PRE-filters
FO-263161	10/7/2013	10/9/2013		Replace PRE-filters
FO-263602	10/7/2013	10/23/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263603	10/7/2013	10/23/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263604	10/7/2013	10/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263605	10/7/2013	10/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263606	10/7/2013	10/22/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263607	10/7/2013	10/19/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263608	10/7/2013	10/19/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263609	10/7/2013	10/19/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263610	10/7/2013	10/19/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261477	10/8/2013	10/10/2013		Replace PRE-filters
FO-261478	10/8/2013	11/1/2013		Replace PRE-filters

WO	Recieved	Finished	Total	Request
FO-261479	10/8/2013	11/1/2013		Replace PRE-filters
FO-261480	10/8/2013	10/10/2013		Replace PRE-filters
FO-261481	10/8/2013	10/10/2013		Replace PRE-filters
FO-261505	10/8/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-261506	10/8/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-261507	10/8/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-261508	10/8/2013	10/5/2013		PM - Fan Coil/HV/AC Unit
FO-261509	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261510	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261511	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261512	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261513	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261514	10/8/2013	10/10/2013		PM - Fan Coil/HV/AC Unit
FO-261515	10/8/2013	10/11/2013		PM - Fan Coil/HV/AC Unit
FO-261516	10/8/2013	10/11/2013		PM - Fan Coil/HV/AC Unit
FO-261517	10/8/2013	10/11/2013		PM - Fan Coil/HV/AC Unit
FO-261518	10/9/2013	10/15/2013		Replace PRE-filters
FO-261519	10/9/2013	10/15/2013		Replace PRE-filters
FO-261520	10/9/2013	10/15/2013		Replace PRE-filters
FO-261492	10/10/2013			PM - Air Handling Unit
FO-261483	10/11/2013	10/5/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261484	10/11/2013	10/5/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261485	10/11/2013	10/5/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261486	10/11/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261487	10/11/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261488	10/11/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261489	10/11/2013	10/9/2013		PM - Air Handling Unit
FO-261490	10/11/2013	10/9/2013		PM - Air Handling Unit
FO-261491	10/11/2013	10/11/2013		PM - Air Handling Unit
FO-261495	10/11/2013	10/31/2013		PM - Air Handling Unit
FO-261500	10/11/2013	10/2/2013		PM - Air Handling Unit
FO-261501	10/11/2013	10/2/2013		PM - Air Handling Unit
FO-261502	10/11/2013	10/8/2013		PM - Air Handling Unit
FO-261503	10/11/2013	10/8/2013		PM - Air Handling Unit
FO-261504	10/11/2013	10/8/2013		PM - Air Handling Unit
FO-262056	10/12/2013			PM - Air Handling Unit
FO-262057	10/12/2013			PM - Air Handling Unit
FO-262053	10/13/2013			PM - Air Handling Unit
FO-262054	10/13/2013			PM - Air Handling Unit
FO-262055	10/13/2013			PM - Air Handling Unit
FO-262107	10/13/2013			PM - Air Handling Unit
FO-262047	10/14/2013	10/8/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262049	10/15/2013			PM - Unit/Space Heater
FO-262050	10/15/2013	10/29/2013		PM - Unit/Space Heater
FO-262051	10/15/2013	10/29/2013		PM - Unit/Space Heater
FO-262052	10/15/2013			PM - Unit/Space Heater
FO-262058	10/15/2013	10/11/2013		PM - Fan Coil/HV/AC Unit

WO	Recieved	Finished	Total	Request
FO-262059	10/15/2013	10/11/2013		PM - Fan Coil/HV/AC Unit
FO-262060	10/15/2013	10/11/2013		PM - Fan Coil/HV/AC Unit
FO-262061	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262062	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262063	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262064	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262065	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262066	10/15/2013	10/12/2013		PM - Fan Coil/HV/AC Unit
FO-262067	10/15/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262068	10/15/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262069	10/15/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262082	10/15/2013	10/16/2013		PM - Unit/Space Heater
FO-262083	10/15/2013	10/16/2013		PM - Unit/Space Heater
FO-262084	10/15/2013	10/16/2013		PM - Unit/Space Heater
FO-262085	10/15/2013	10/29/2013		PM - Unit/Space Heater
FO-262086	10/15/2013	10/29/2013		PM - Unit/Space Heater
FO-262087	10/15/2013	10/5/2013		PM - Unit/Space Heater
FO-262088	10/15/2013	10/5/2013		PM - Unit/Space Heater
FO-262089	10/15/2013	10/5/2013		PM - Unit/Space Heater
FO-262090	10/15/2013	10/15/2013		PM - Unit/Space Heater
FO-262091	10/15/2013			PM - Unit/Space Heater
FO-262092	10/15/2013	10/15/2013		PM - Unit/Space Heater
FO-262093	10/15/2013	10/16/2013		PM - Unit/Space Heater
FO-262094	10/15/2013			PM - Unit/Space Heater
FO-262095	10/15/2013			PM - Unit/Space Heater
FO-262096	10/15/2013	10/15/2013		PM - Unit/Space Heater
FO-262105	10/15/2013	10/15/2013		PM - Unit/Space Heater
FO-262106	10/15/2013	10/15/2013		PM - Unit/Space Heater
FO-262048	10/16/2013	10/9/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262097	10/16/2013			PM - Air Handling Unit
FO-262098	10/16/2013			PM - Air Handling Unit
FO-262099	10/16/2013			PM - Air Handling Unit
FO-262100	10/16/2013			PM - Air Handling Unit
FO-262101	10/16/2013			PM - Air Handling Unit
FO-262102	10/16/2013			PM - Air Handling Unit
FO-262103	10/16/2013			PM - Air Handling Unit
FO-262104	10/16/2013			PM - Air Handling Unit
FO-260998	10/17/2013			PM - Air Handling Unit
FO-260999	10/17/2013			PM - Air Handling Unit
FO-262070	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262071	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262072	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262073	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262074	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262075	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262076	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262077	10/17/2013			PM - Fan Motor Box (Old Main)

WO	Recieved	Finished	Total	Request
FO-262078	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262079	10/17/2013			PM - Fan Motor Box (Old Main)
FO-262080	10/17/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262081	10/17/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261009	10/18/2013	10/4/2013		PM - Air Handling Unit
FO-261010	10/18/2013	10/5/2013		PM - Air Handling Unit
FO-261011	10/18/2013	10/4/2013		PM - Air Handling Unit
FO-261012	10/18/2013	10/3/2013		PM - Air Handling Unit
FO-261013	10/18/2013	10/3/2013		PM - Air Handling Unit
FO-261014	10/18/2013	10/2/2013		PM - Air Handling Unit
FO-262108	10/18/2013	10/30/2013		PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262932	10/22/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262933	10/22/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262934	10/22/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262935	10/22/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262936	10/22/2013	11/1/2013		PM - Fan Coil/HV/AC Unit
FO-262937	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262938	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262939	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262940	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262941	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262942	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262943	10/22/2013			PM - Fan Coil/HV/AC Unit
FO-262947	10/23/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262948	10/23/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262949	10/23/2013			PM - Unit/Space Heater
FO-262950	10/23/2013			PM - Unit/Space Heater
FO-262915	10/24/2013			PM - Air Handling Unit
FO-262916	10/24/2013			PM - Air Handling Unit
FO-262917	10/24/2013			PM - Air Handling Unit
FO-262918	10/24/2013			PM - Air Handling Unit
FO-262919	10/24/2013			PM - Air Handling Unit
FO-262920	10/24/2013			PM - Air Handling Unit
FO-262921	10/24/2013			PM - Air Handling Unit
FO-262922	10/24/2013			PM - Air Handling Unit
FO-262923	10/24/2013			PM - Air Handling Unit
FO-262944	10/24/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262945	10/24/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262946	10/24/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-261000	10/25/2013			PM - Air Handling Unit
FO-261001	10/25/2013			PM - Air Handling Unit
FO-261002	10/25/2013			PM - Air Handling Unit
FO-262924	10/25/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-262925	10/25/2013			PM - Air Handling Unit
FO-262926	10/25/2013			PM - Air Handling Unit
FO-262927	10/25/2013			PM - Air Handling Unit
FO-262928	10/25/2013	9/26/2013		PM - Air Handling Unit

WO	Recieved	Finished	Total	Request
FO-262929	10/25/2013			PM - Air Handling Unit
FO-262930	10/25/2013			PM - Air Handling Unit
FO-262931	10/25/2013			PM - Air Handling Unit
FO-263433	10/26/2013	10/22/2013		PM - Unit/Space Heater
FO-263434	10/26/2013	10/22/2013		PM - Unit/Space Heater
FO-263453	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263454	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263455	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263456	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263457	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263458	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263459	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263460	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263461	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263462	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263463	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263464	10/29/2013			PM - Fan Coil/HV/AC Unit
FO-263478	10/29/2013			PM AHU - Belts & Lubrication
FO-263479	10/29/2013			PM AHU - Belts & Lubrication
FO-263468	10/30/2013			PM - Air Handling Unit, HV Type
FO-263469	10/30/2013			PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-263470	10/30/2013			PM - Air Handling Unit, over 50 Ton (Filters Excluded)
FO-263471	10/30/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263472	10/30/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263473	10/30/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263474	10/30/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
E - South			41	
FO-262434	10/1/2013	10/31/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262435	10/1/2013	10/31/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262436	10/1/2013	10/31/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262437	10/1/2013	10/31/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262438	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262440	10/1/2013	10/30/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262443	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262446	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262447	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262448	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262449	10/1/2013	10/15/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262466	10/1/2013	10/24/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262467	10/1/2013	10/24/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262468	10/1/2013	10/24/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262469	10/1/2013	10/24/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262500	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262501	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262502	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262503	10/1/2013	10/22/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262504	10/1/2013	10/22/2013		PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262519	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262538	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262539	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262540	10/1/2013	10/16/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262603	10/1/2013	10/17/2013		PM - Centrifugal Pump, over 1 H.P.
FO-262520	10/2/2013			PM INSPECT AND CLEAN COIL
FO-262521	10/2/2013			PM INSPECT AND CLEAN COIL
FO-262522	10/2/2013			PM INSPECT AND CLEAN COIL
FO-262651	10/3/2013	10/18/2013		PM - Domestic Water Heater, Electric
FO-263240	10/8/2013			Monthly AHU Inspection Clean Room Unit 2
FO-263241	10/8/2013			PM - Monthly AHU Inspection Clean Room Unit 1
FO-263242	10/8/2013			PM - Sump Pump
FO-263243	10/8/2013			PM - Sump Pump
FO-263244	10/8/2013	10/30/2013		PM - Sump Pump
FO-263245	10/8/2013	10/30/2013		PM - Sump Pump
FO-263246	10/8/2013	10/16/2013		PM - Domestic Water Heater, Gas
FO-260729	10/10/2013			Generator Maintenance, Monthly
FO-260731	10/10/2013			Generator Maintenance, Monthly
FO-260774	10/10/2013	10/10/2013		Generator Maintenance, Monthly
FO-260733	10/15/2013	10/15/2013		Generator Maintenance, Monthly
FO-260735	10/16/2013	10/16/2013		Generator Maintenance, Monthly
E - Southeast			42	
FO-262426	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262427	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262525	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262533	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262534	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262535	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262536	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262611	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262612	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262639	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262640	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262657	10/2/2013			PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-262658	10/2/2013			PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-262659	10/2/2013			PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-262660	10/2/2013			PM - Steam Valves to PreHeat Coils - Open (Old Main)
FO-262586	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262587	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262588	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262589	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262590	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262591	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262592	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262593	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262594	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262595	10/3/2013			PM - Heat Pumps (5057 Woodward)

WO	Recieved	Finished	Total	Request
FO-262596	10/3/2013			PM - Heat Pumps (5057 Woodward)
FO-262684	10/3/2013			PM - Domestic Water Heater, Gas
FO-262570	10/4/2013			PM - Chemical Feed/Metering Pump/Controller
FO-262571	10/4/2013			PM - Chemical Feed/Metering Pump/Controller
FO-262572	10/4/2013			PM - Chemical Feed/Metering Pump/Controller
FO-262573	10/4/2013			PM - Chemical Feed/Metering Pump/Controller
FO-262641	10/4/2013			PM - Cooling Tower Fan (Old Main)
FO-263249	10/10/2013			PM - Heat Exchanger and Economizer
FO-263250	10/10/2013			PM - Heat Pumps (5057 Woodward)
FO-256096	10/14/2013			PM - Domestic Water Heater, Gas
FO-260527	10/14/2013			PM - Domestic Water Heater, Electric
FO-261833	10/14/2013			PM - Water/Air Cooled Condenser
FO-261834	10/14/2013			PM - Water/Air Cooled Condenser
FO-260755	10/15/2013	10/16/2013		Generator Maintenance, Monthly
FO-260757	10/15/2013	10/16/2013		Generator Maintenance, Monthly
FO-258730	10/21/2013			PM - Heat Exchanger and Economizer
FO-258731	10/25/2013			PM - Heat Exchanger and Economizer
E - West			50	
FO-255452	10/1/2013			PM - Unspecified
FO-255453	10/1/2013			PM - Unspecified
FO-261200	10/1/2013			PM - Domestic Water Heater, Electric
FO-262485	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262486	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262487	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262488	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262489	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262490	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262491	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262492	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262494	10/1/2013			PM - Water/Air Cooled Condenser
FO-262495	10/1/2013			PM - Water/Air Cooled Condenser
FO-262496	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262497	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262498	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262499	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262505	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262506	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262507	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262508	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262509	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262510	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262511	10/1/2013			PM - Heat Exchanger and Economizer
FO-262512	10/1/2013			PM - Heat Exchanger and Economizer
FO-262638	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262642	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262643	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262644	10/1/2013			PM - Centrifugal Pump, over 1 H.P.

WO	Recieved	Finished	Total	Request
FO-262645	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262646	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262647	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262648	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262649	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262650	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262653	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262654	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262655	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262656	10/1/2013			PM - Centrifugal Pump, over 1 H.P.
FO-262652	10/3/2013			PM - Domestic Water Heater, Electric
FO-262493	10/5/2013			PM - Heat Exchanger and Economizer
FO-259869	10/6/2013			PM - Condensate Return System **Needs Task Sheet**
FO-259870	10/6/2013			PM - Condensate Return System **Needs Task Sheet**
FO-263251	10/10/2013			PM - Domestic Water Heater, Electric
FO-263252	10/10/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-263253	10/10/2013			PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-256100	10/14/2013			PM - Sump Pump
FO-258065	10/14/2013			PM - Domestic Water Heater, Steam
FO-257495	10/15/2013			PM - Heat Exchanger and Economizer
FO-260785	10/17/2013			Generator Maintenance, Monthly

Trades

34

Routine

34

T - Electrician

33

FO-260743	10/4/2013	10/4/2013	Generator Test Finished 10/7/2013LT
FO-260771	10/4/2013	10/4/2013	Generator Test Finished 10/7/2013LT
FO-260772	10/4/2013		Generator Maintenance, Monthly
FO-260786	10/4/2013	10/4/2013	Generator Test Finished 10/7/2013LT
FO-260788	10/4/2013	10/4/2013	Generator Test Finished 10/7/2013LT
FO-260790	10/4/2013	10/4/2013	Generator Test Finished 10/7/2013LT
FO-260764	10/8/2013	10/8/2013	Generator TestFinished 10/9/2013LT
FO-260782	10/8/2013	10/8/2013	Generator TestFinished 10/9/2013LT
FO-260766	10/9/2013	10/9/2013	Generator Test Finished 10/11/2013LT
FO-260730	10/10/2013	10/10/2013	Generator Test Finished 10/11/2013LT
FO-260732	10/10/2013	10/10/2013	Generator Test Finished 10/11/2013LT
FO-260773	10/10/2013	10/10/2013	Generator Test Finished 10/11/2013LT
FO-260760	10/11/2013	10/11/2013	Generator Test Finished 10/14/2013LT
FO-260762	10/11/2013	10/11/2013	Generator Test Finished 10/14/2013LT
FO-260779	10/11/2013		Generator Test
FO-260728	10/15/2013	10/15/2013	Generator Test Finished 10/16/2013LT
FO-260734	10/15/2013	10/15/2013	Generator Test Finished 10/16/2013LT
FO-260754	10/15/2013	10/15/2013	Generator Test Finished 10/16/2013LT
FO-260756	10/15/2013	10/15/2013	Generator Test Finished 10/16/2013LT
FO-260768	10/15/2013		Generator Test
FO-260736	10/16/2013	10/16/2013	Generator Test Finished 10/18/2013LT
FO-260770	10/16/2013	10/16/2013	Generator Test Finished 10/18/2013LT
FO-260776	10/17/2013	10/17/2013	Generator Test Finished 10/18/2013LT

WO	Recieved	Finished	Total	Request
FO-260784	10/17/2013	10/17/2013		Generator Test Finished 10/18/2013LT
FO-260744	10/22/2013	10/22/2013		Generator Test Finished 10/22/2013LT
FO-260746	10/22/2013	10/22/2013		Generator Test Finished 10/22/2013LT
FO-260748	10/22/2013	10/22/2013		Generator Test Finished 10/22/2013LT
FO-260750	10/22/2013	10/22/2013		Generator Test Finished 10/22/2013LT
FO-260752	10/22/2013	10/22/2013		Generator Test Finished 10/22/2013LT
FO-260738	10/23/2013	10/23/2013		Generator Test Finished 10/24/2013LT
FO-260758	10/23/2013	10/23/2013		Generator Test Finished 10/24/2013LT
FO-260739	10/25/2013	10/25/2013		Generator Test Finished 10/28/2013
FO-260741	10/25/2013	10/25/2013		Generator Test Finished 10/28/2013
T - Roofing			1	
FO-262524	10/1/2013			Check Roof-Chemistry North Substation (Flat-Roof)

Total: 2935