

Facilities Operations Maint. "Work Not Done" Report 8/1/16 through 8/31/16

			Total per Trade		Emergency 1 day		High 3 <= days		Medium <=14 days		Low <=30 days		Routine
Engineering			5 of 5	100%	0 of 0	#Num!	2 of 2	100%	0 of 0	#Num!	3 of 3	100%	0
E - Northeast			1 of 1	100%	0 of 0	#Num!	0 of 0	#Num!	0 of 0	#Num!	1 of 1	100%	0
4	FO-354064	Maint. Work Order	8/4/2016	8/4/2016	0	Low	Stand alone A/C unit in storage office is leaking. Could be clogged drain. Please investigate and stop leak.			evaporator condensation pump is not working. water running on floor from pan. sent in work request for A/C section to replace condensate pump under evaporator coil tray. must remove cover to see blue condensate pump.			
E - Preventative Maintenance			4 of 4	100%	0 of 0	#Num!	2 of 2	100%	0 of 0	#Num!	2 of 2	100%	0
2	FO-354269	Maint. Work Order	8/8/2016	8/8/2016	0	High	POWER OUT IN HALF OF OFFICE. ROOMS 315 AND 316.			SPOKE WITH FRANK VAUGHT. (SAB)			
2	FO-355025	Maint. Work Order	8/18/2016	8/18/2016	0	High	R/R Door 067 10W will not close. This is an outside door, on the west side of the building, and is a security issue. Door hits the door jamb.						
4	FO-352969	Maint. Work Order	7/22/2016	8/1/2016	10	Low	A/C unit not working properly.						
4	FO-355849	Maint. Work Order	8/26/2016	8/27/2016	1	Low	Belt Order AHU-1						
							C-105 Qty: 3						
Total:			5 of 5	100%	0 of 0	#Num!	2 of 2	100%	0 of 0	#Num!	3 of 3	100%	0