

DRAFT Facilities Operations PM Analysis from 9/1/2014 through 9/30/2014

Requested Finished Open WND

% Finished

Engineering		444	359	52	33	81%	
E - Auxiliary		31	31	-1	1	100%	
FO-292672	Finished	507-ST-001	9/1/2014	9/2/2014	False	Inspection of DA / Surge Tank	
FO-292673	Finished	507-DAT-001	9/1/2014	9/2/2014	False	Inspection of DA / Surge Tank	
FO-292674	Finished	127-MAU-005	9/1/2014	9/26/2014	True	PM - Fan Coil/HV/AC Unit	
FO-292676	Finished	115-DHWP-007	9/1/2014	9/12/2014	False	PB - B&G Series 100 Pump	
FO-292677	Finished	115-DHWP-006	9/1/2014	9/12/2014	False	PB - B&G Series 100 Pump	
FO-292678	Finished	115-DWB-003	9/1/2014	9/12/2014	False	PB - B&G Series 100 Pump	
FO-292679	Finished	115-DWB-004	9/1/2014	9/12/2014	False	PB - B&G Series 100 Pump	
FO-292680	Finished	992-ES-001*	9/1/2014	9/5/2014	False	0.25	PM - Emergency Shower/Eyewash Station
Tested unit's operation.							
FO-292683	Finished	134-FP-001	9/1/2014	9/30/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-292684	Finished	127-FP-001	9/1/2014	9/30/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-292685	Finished	115-FP-001	9/1/2014	9/30/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-292686	Finished	104-FP-001	9/1/2014	9/30/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-292687	Finished	507-FP-001	9/1/2014	9/30/2014	False	PM - Monthly Fire Alarm/Fire Protection System Test	
FO-293273	Finished	501-GEN-001	9/9/2014	9/10/2014	False	Generator Maintenance, Monthly	
FO-293275	Finished	992-ES-001*	9/8/2014	9/12/2014	False	0.25	PM - Emergency Shower/Eyewash Station
Tested unit's operation.							
FO-293904	Finished	507-GEN-001	9/10/2014	9/11/2014	False	Generator Maintenance, Monthly	
FO-293908	Finished	992-ES-001*	9/15/2014	9/19/2014	False	0.25	PM - Emergency Shower/Eyewash Station
Tested unit's operation.							
FO-294284	Finished	104-GEN-001	9/23/2014	9/23/2014	False	1.00	Generator Maintenance, Monthly
Diesel level below half full. Requested supervisor (Massa) order fuel.							
FO-294286	Finished	127-GEN-001	9/23/2014	9/23/2014	False	0.25	Generator Maintenance, Monthly
Noticed no problems.							
FO-294288	Finished	127-GEN-002	9/23/2014	9/23/2014	False	0.25	Generator Maintenance, Monthly
Unit smokes at start-up. Oil level lower than other two that are on.							
FO-294290	Finished	127-GEN-003	9/23/2014	9/23/2014	False	0.25	Generator Maintenance, Monthly
Turned off. Oil level low. Suspect burning oil.							
FO-294292	Finished	127-GEN-004	9/23/2014	9/23/2014	False	0.25	Generator Maintenance, Monthly
Noticed no problems.							
FO-294296	Finished	536-GEN-001	9/17/2014	9/17/2014	False	Generator Maintenance, Monthly	
FO-294784	Finished	034-AHU-001	9/19/2014	10/11/2014	False	2.00	PM - Air Handling Unit
Cleaned, lubed motor, bearings and dampers, changed filters and checked belts.							
FO-294785	Finished	034-AHU-002	9/19/2014	10/11/2014	False	0.50	PM - Air Handling Unit
AHU is out of service due to bldg. renovations.							
FO-294786	Finished	034-AHU-003	9/19/2014	10/6/2014	False	1.50	PM - Air Handling Unit
Lubed motor, bearings and dampers. Checked belts and changed filters.							
FO-294792	Finished	507-AHU-003	9/21/2014	10/3/2014	False	PM - Air Handling Unit	
FO-294793	Finished	507-AHU-002	9/21/2014	10/3/2014	False	PM - Air Handling Unit	
FO-294794	Finished	507-AHU-001	9/21/2014	10/3/2014	False	PM - Air Handling Unit	

FO-294795	Finished	992-ES-001*	9/22/2014	9/26/2014	False	PM - Emergency Shower/Eyewash Station	
FO-295369	Finished	992-ES-001*	9/29/2014	9/30/2014	False	PM - Emergency Shower/Eyewash Station	
E - Command Center			32	0	32	0	0%
FO-293278	Created By PM Schedule	064-ACU-101	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293279	Created By PM Schedule	064-ACU-105	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293280	Created By PM Schedule	064-ACU-109	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293281	Created By PM Schedule	064-ACU-111	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293282	Created By PM Schedule	064-ACU-117	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293283	Created By PM Schedule	064-ACU-114	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293284	Created By PM Schedule	064-ACU-112	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293285	Created By PM Schedule	064-ACU-104	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293286	Created By PM Schedule	064-ACU-216	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293287	Created By PM Schedule	064-ACU-212	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293288	Created By PM Schedule	064-ACU-206	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293289	Created By PM Schedule	064-ACU-204	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293290	Created By PM Schedule	064-ACU-202	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293291	Created By PM Schedule	064-ACU-201	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293292	Created By PM Schedule	064-ACU-203	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293293	Created By PM Schedule	064-ACU-205	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293294	Created By PM Schedule	064-ACU-207	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293295	Created By PM Schedule	064-ACU-211	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293296	Created By PM Schedule	064-ACU-209	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293297	Created By PM Schedule	064-ACU-213	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293298	Created By PM Schedule	064-ACU-217	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293299	Created By PM Schedule	064-ACU-316	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293300	Created By PM Schedule	064-ACU-314	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293301	Created By PM Schedule	064-ACU-312	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293302	Created By PM Schedule	064-ACU-306	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293303	Created By PM Schedule	064-ACU-304	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293304	Created By PM Schedule	064-ACU-302	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293305	Created By PM Schedule	064-ACU-301	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293306	Created By PM Schedule	064-ACU-307	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293307	Created By PM Schedule	064-ACU-309	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293308	Created By PM Schedule	064-ACU-311	9/3/2014		False	Window AC Unit - Annual Maintenance	
FO-293309	Created By PM Schedule	064-ACU-317	9/3/2014		False	Window AC Unit - Annual Maintenance	
E - MedPharm			14	8	6	0	57%
FO-292650	Finished	603-SRS-001*	9/1/2014	8/26/2014	False	2.00	PM - Unspecified
assisted fitters with pressure reducing valve did complete lube and popped safety							
FO-292651	Finished	629-ROS-001	9/1/2014	9/15/2014	False	1.50	PM - Reverse Osmosis Water Softener System
assisted contractor with mo. PM							
FO-292652	Parts on Order	612-HWH-001	9/1/2014		False		PM - Domestic Water Heater, Steam
FO-292653	Parts on Order	612-HWH-002	9/1/2014		False		PM - Domestic Water Heater, Steam
FO-292654	Parts on Order	612-HWH-003	9/1/2014		False		PM - Domestic Water Heater, Steam

Requested Finished Open WND

% Finished

FO-293248	Created By PM Schedule	611-HVU-001**	9/9/2014		False		PM - Fan Coil/HV/AC Unit
FO-293249	Created By PM Schedule	611-HVU-004**	9/9/2014		False		PM - Fan Coil/HV/AC Unit
FO-293250	Finished	629-VPS-001	9/3/2014	9/17/2014	False	1.00	PM - Vacuum Pump
Medical vacuum sys in bad shape. #2 pump set is frozen and #1 is short cycling. Have requested contractors look at system...There has been talk of replacing it.							
FO-293251	Created By PM Schedule	612-DAT-001	9/4/2014		False		PM - Deaerator Tank
FO-293252	Finished	608-GEN-001	9/5/2014	9/5/2014	False		Generator Maintenance, Monthly
FO-293253	Finished	629-WSS-001	9/4/2014	9/4/2014	False	1.00	PM - Water Softener
completed							
FO-293856	Finished	609-GEN-001	9/16/2014	9/26/2014	False		Generator Maintenance, Monthly
checked fluids, heater and battery							
FO-294280	Finished	611-GEN-001	9/26/2014	9/26/2014	False	0.50	Generator Maintenance, Monthly
Electricians did monthly generator load test, checked equipment. Generator needs fuel.							
FO-294282	Finished	629-GEN-001	9/26/2014	9/26/2014	False	1.00	Generator Maintenance, Monthly
completed							
E - North			15	13	2	0	87%
FO-293254	Finished	033-HVU-001	9/5/2014	9/9/2014	False	1.00	PM - Forced Air Furnace (Jacob House) - Winter
FO-293255	Created By PM Schedule	033-HVU-002	9/5/2014		False		PM - Forced Air Furnace (Jacob House) - Winter
FO-293256	Created By PM Schedule	033-HVU-003	9/5/2014		False		PM - Forced Air Furnace (Jacob House) - Winter
FO-293257	Finished	130-AHU-001	9/8/2014	9/9/2014	False	2.50	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-293857	Finished	042-ACU-004	9/15/2014	9/2/2014	False	1.00	PM - Water/Air Cooled Condenser
Inspected and cleaned equipment.							
FO-293858	Finished	042-ACU-005	9/15/2014	10/2/2014	False	1.00	PM - Water/Air Cooled Condenser
Checked condenser for problems, cleaned unit.							
FO-293859	Finished	042-ACU-006	9/15/2014	10/2/2014	False	1.00	PM - Water/Air Cooled Condenser
Checked condenser for problems, cleaned unit.							
FO-293860	Finished	036-FCU-001	9/12/2014	9/29/2014	False	6.00	PM - Fan Coil/HV/AC Unit
FO-293861	Finished	027-ACU-001	9/12/2014	10/8/2014	False	1.50	PM - Water/Air Cooled Condenser
FO-293862	Finished	027-ACU-002	9/12/2014	9/4/2014	False	0.45	PM - Water/Air Cooled Condenser
FO-293863	Finished	048-GEN-001	9/12/2014	9/10/2014	False	0.65	Generator Maintenance, Monthly
FO-294294	Finished	130-GEN-001	9/24/2014	9/24/2014	False	1.00	Generator Maintenance, Monthly
FO-294780	Finished	130-AHU-001	9/22/2014	9/26/2014	False	2.50	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]
FO-295360	Finished	049-HWBP-001	9/24/2014	10/14/2014	False	0.75	PM - Water Booster Pump
FO-295361	Finished	049-HWBP-002	9/24/2014	10/14/2014	False	0.75	PM - Water Booster Pump
E - Northeast			19	19	0	0	100%
FO-292655	Finished	193-AIR-001	9/1/2014	9/5/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-292656	Finished	195-AIR-001	9/1/2014	9/10/2014	False	2.00	PM - Air Compressor, Reciprocating 5-40 H.P.
FO-292658	Finished	509-DHW-001	9/1/2014	8/29/2014	False		PM - Domestic Water Heater, Electric
checked temp. checked for leaks, verified recirc. pump operation							
FO-292659	Finished	509-SP-001	9/1/2014	9/3/2014	False	2.00	PM - Sump Pump
Greased pump and motor, checked coupling, checked operation checked for leaks							
FO-292660	Finished	509-SP-002	9/1/2014	9/3/2014	False	0.00	PM - Sump Pump
greased pump and motor, checked coupling, checked float operation, checked for leaks							

Requested Finished Open WND

% Finished

FO-292661	Finished	510-SP-001	9/1/2014	9/9/2014	False	2.00	PM - Sump Pump
Filled sump to check float operation, lubricated pump and motor, checked for leaks and check valve operation							
FO-292662	Finished	510-SP-002	9/1/2014	9/10/2014	False	2.00	PM - Sump Pump
Filled sump tested float and switch. checked operation lubricated both pump and motor							
FO-293258	Finished	141-CRS-002	9/5/2014	9/10/2014	False	1.00	PM - Condensate Return System **Needs Task Sheet**
FO-293259	Finished	510-DHW-001	9/7/2014	9/4/2014	False	1.00	PM - Domestic Water Heater, Gas
Checked flame, checked for leaks checked exhaust duct, checked temp, checked and lubricated pump							
FO-293260	Finished	510-DHW-002	9/7/2014	9/4/2014	False	1.00	PM - Domestic Water Heater, Gas
Checked flame, checked for leaks, checked exhaust duct. checked water temp, checked pump operation							
FO-293261	Finished	193-GEN-001	9/5/2014	9/5/2014	False	0.50	Generator Maintenance, Monthly
FO-293262	Finished	193-GEN-002	9/5/2014	9/5/2014	False	0.50	Generator Maintenance, Monthly
FO-293263	Finished	193-GEN-003	9/5/2014	9/5/2014	False	0.50	Generator Maintenance, Monthly
FO-293264	Finished	193-GEN-004	9/5/2014	9/5/2014	False	0.50	Generator Maintenance, Monthly
FO-293864	Finished	509-HWP-010	9/16/2014	9/2/2014	False	1.00	PB - B&G Series 100 Pump
checked operation, checked for leaks lubricated bearing, checked coupling							
FO-293865	Finished	203-GEN-001	9/16/2014	9/16/2014	False	1.00	Generator Maintenance, Monthly
FO-293866	Finished	-GEN-001 (Towa	9/10/2014	9/10/2014	False	2.00	Generator Maintenance, Monthly
FO-294277	Finished	066-GEN-001	9/24/2014	9/24/2014	False	0.50	Generator Maintenance, Monthly
FO-294298	Finished	527-GEN-001	9/18/2014	9/11/2014	False	1.50	Generator Maintenance, Monthly
checked oil level, coolant level, damper operation battery terminals and electrolyte. note contractor was here this month doing their inspection							
E - Preventative Maintenance		257	221	4	32	86%	
FO-291448	Finished	608-EXF-001	9/1/2014	9/4/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291449	Finished	608-EXF-002	9/1/2014	9/13/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291450	Finished	608-EXF-004	9/1/2014	9/13/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291451	Finished	050-RAF-001	9/1/2014	9/16/2014	False	2.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291452	Completed	140-HVU-001	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291453	Completed	140-HVU-002	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291454	Completed	140-HVU-003	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291455	Completed	140-HVU-004	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291456	Completed	140-HVU-005	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291457	Completed	140-HVU-006	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291458	Completed	140-HVU-007	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291459	Completed	140-HVU-008	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291460	Completed	140-HVU-009	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291461	Completed	140-HVU-010	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291462	Completed	140-HVU-011	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291463	Completed	140-HVU-012	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291464	Completed	140-HVU-013	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291465	Completed	140-HVU-014	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291466	Completed	140-HVU-015	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291467	Completed	140-HVU-016	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291468	Completed	140-HVU-017	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291469	Completed	140-HVU-018	9/1/2014		True		PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-291470	Completed	140-HVU-019	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291471	Completed	140-HVU-020	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291472	Completed	140-HVU-021	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291473	Completed	140-HVU-022	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291474	Completed	140-HVU-023	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291475	Completed	140-HVU-024	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291476	Completed	140-HVU-025	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291477	Completed	140-HVU-026	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291478	Completed	140-HVU-027	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291479	Completed	140-HVU-028	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291480	Completed	140-HVU-029	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291481	Completed	140-HVU-030	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291482	Completed	140-HVU-031	9/1/2014		True		PM - Fan Coil/HV/AC Unit
FO-291483	Finished	01-FCU-001HCF	9/1/2014	9/30/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-291484	Finished	001-FCU-4219	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291485	Finished	001-FCU-4220	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291486	Finished	001-FCU-4221	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291487	Finished	001-FCU-4222	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291488	Finished	001-FCU-4223	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291489	Finished	001-FCU-4224	9/3/2014	9/16/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291490	Finished	001-FCU-4225	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291491	Finished	001-FCU-4226	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291492	Finished	001-FCU-4227	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291493	Finished	001-FCU-4228	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291494	Finished	001-FCU-4229	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291495	Finished	001-FCU-4230	9/3/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-291496	Finished	089-EXF-001	9/1/2014	9/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291497	Finished	089-EXF-005	9/1/2014	9/25/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291498	Finished	068-EXF-001	9/1/2014	9/30/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291499	Finished	608-EXF-010	9/1/2014	9/16/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291500	Finished	089-EXF-002	9/1/2014	9/23/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291501	Finished	089-EXF-003	9/1/2014	9/23/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291502	Finished	089-EXF-004	9/1/2014	9/23/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291503	Finished	089-EXF-006	9/1/2014	9/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291504	Finished	089-EXF-007	9/1/2014	9/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291505	Finished	089-EXF-008	9/1/2014	9/26/2014	False	1.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291506	Finished	046-FAP-001	9/1/2014	9/25/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291507	Finished	048-FAP-001	9/1/2014	9/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291508	Finished	049-FAP-001	9/1/2014	9/25/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291509	Finished	156-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291510	Finished	499-FAP-001	9/1/2014	9/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291511	Finished	620-FAP-001	9/1/2014	9/18/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291512	Finished	036-FP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291513	Finished	025-FP-001	9/1/2014	9/27/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-291514	Finished	007-FP-001	9/1/2014	9/30/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291515	Finished	001-FP-001	9/1/2014	9/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291516	Finished	005-FAP-001	9/1/2014	9/30/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291517	Finished	040-FAP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291518	Finished	038-FAP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291519	Finished	028-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291520	Finished	026-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291521	Finished	022-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291522	Finished	017-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291523	Finished	016-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291524	Finished	003-FAP-001	9/1/2014	9/30/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291525	Finished	006-FP-001	9/1/2014	9/30/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291526	Finished	050-FAP-001	9/1/2014	9/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291527	Finished	043-FAP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291528	Finished	042-FAP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291529	Finished	062-FP-001	9/1/2014	9/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291530	Finished	065-FP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291531	Finished	068-FAP-001	9/1/2014	9/5/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291532	Finished	067-FP-001	9/1/2014	9/18/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291533	Finished	609-EXF-001	9/1/2014	9/30/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291534	Finished	609-EXF-001A	9/1/2014	9/18/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291535	Finished	609-EXF-001B	9/1/2014	10/1/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291536	Finished	609-EXF-002A	9/1/2014	9/23/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291537	Finished	609-EXF-002B	9/1/2014	9/23/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291538	Finished	609-EXF-003A1	9/1/2014	9/24/2014	False	2.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291539	Finished	609-EXF-003A2	9/1/2014	9/24/2014	False	2.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291540	Finished	609-EXF-003B2	9/1/2014	10/1/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291541	Finished	609-EXF-003B1	9/1/2014	10/1/2014	False	0.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291542	Finished	609-EXF-005A	9/1/2014	9/18/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291543	Finished	609-EXF-005B	9/1/2014	9/18/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291544	Finished	609-EXF-006A	9/1/2014	9/18/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291545	Finished	609-EXF-006B	9/1/2014	9/18/2014	False	1.50	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291546	Finished	609-EXF-010A	9/1/2014	9/26/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291547	Finished	609-EXF-010B	9/1/2014	9/26/2014	False	3.00	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan
FO-291548	Finished	089-FP-001	9/1/2014	9/30/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291549	Finished	082-FP-001	9/1/2014	9/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291550	Finished	080-FAP-001	9/1/2014	9/9/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291551	Finished	090-FP-001	9/1/2014	9/29/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291552	Finished	155-FP-001	9/1/2014	9/10/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291553	Finished	150-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291554	Finished	167-FAP-001	9/1/2014	9/29/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291555	Finished	166-FP-001	9/1/2014	9/29/2014	False	0.75	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291556	Finished	140-FAP-001	9/1/2014	9/13/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291557	Finished	130-FP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test

Requested Finished Open WND

% Finished

FO-291558	Finished	193-FAP-001	9/1/2014	9/18/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291559	Finished	189-FP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291560	Finished	510-FAP-001	9/1/2014	9/11/2014	False	0.45	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291561	Finished	509-FAP-001	9/1/2014	9/13/2014	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291562	Finished	504-FAP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291563	Finished	629-FP-001	9/1/2014	9/4/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291564	Finished	611-FP-001	9/1/2014	9/4/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291565	Finished	609-FP-001	9/1/2014	9/5/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291566	Finished	603-FP-001	9/1/2014	9/5/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291567	Finished	608-FP-001	9/1/2014	9/5/2014	False	1.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291568	Completed	603-AHU-010	9/1/2014		True		Replace PRE-filters
FO-291569	Finished	612-AHU-006	9/1/2014	9/12/2014	False	2.50	Replace PRE-filters
FO-291570	Finished	612-AHU-005C	9/1/2014	9/11/2014	False	1.50	Replace PRE-filters
FO-291571	Finished	612-AHU-005B	9/1/2014	9/11/2014	False	1.50	Replace PRE-filters
FO-291572	Finished	612-AHU-005A	9/1/2014	9/11/2014	False	1.50	Replace PRE-filters
FO-291573	Finished	612-AHU-004	9/1/2014	9/11/2014	False		Replace PRE-filters
FO-291574	Finished	637-AHU-004	9/1/2014	9/10/2014	False	2.50	Replace PRE-filters
FO-291575	Finished	637-AHU-003	9/1/2014	9/10/2014	False	5.00	Replace PRE-filters
FO-291576	Finished	637-AHU-002	9/1/2014	9/9/2014	False	2.50	Replace PRE-filters
FO-291577	Finished	637-AHU-001A	9/1/2014	9/9/2014	False	2.50	Replace PRE-filters
FO-291578	Finished	637-AHU-001	9/1/2014	9/9/2014	False	2.50	Replace PRE-filters
FO-291579	Finished	074-FAP-001	9/1/2014	9/18/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291580	Finished	005-AHU-006	9/1/2014	9/17/2014	False	2.00	Replace PRE-filters
FO-291581	Finished	005-AHU-005	9/1/2014	9/17/2014	False	4.00	Replace PRE-filters
FO-291582	Finished	005-AHU-004	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291583	Finished	005-AHU-003	9/1/2014	9/25/2014	False	1.50	Replace PRE-filters
FO-291584	Finished	005-AHU-002	9/1/2014	9/12/2014	False	3.00	Replace PRE-filters
FO-291585	Finished	005-AHU-001	9/1/2014	9/12/2014	False	3.00	Replace PRE-filters
FO-291586	Finished	089-AHU-006	9/1/2014	9/24/2014	False	1.50	Replace PRE-filters
FO-291587	Finished	089-AHU-004	9/1/2014	9/19/2014	False	2.00	Replace PRE-filters
FO-291588	Finished	089-AHU-003	9/1/2014	9/19/2014	False	2.00	Replace PRE-filters
FO-291589	Finished	089-AHU-002	9/1/2014	9/18/2014	False	2.00	Replace PRE-filters
FO-291590	Finished	089-AHU-001	9/1/2014	9/10/2014	False	4.50	Replace PRE-filters
FO-291591	Finished	008-AHU-005	9/1/2014	9/10/2014	False	2.00	Replace PRE-filters
FO-291592	Finished	008-AHU-004	9/1/2014	9/9/2014	False	4.00	Replace PRE-filters
FO-291593	Finished	008-AHU-003	9/1/2014	9/9/2014	False	1.00	Replace PRE-filters
FO-291594	Finished	008-AHU-002	9/1/2014	9/9/2014	False	2.00	Replace PRE-filters
FO-291595	Finished	008-AHU-001	9/1/2014	9/24/2014	False	1.50	Replace PRE-filters
FO-291596	Finished	006-AHU-005	9/1/2014	9/24/2014	False	1.50	Replace PRE-filters
FO-291597	Finished	006-AHU-004	9/1/2014	9/6/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-291598	Finished	006-AHU-003	9/1/2014	9/5/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-291599	Finished	006-AHU-002	9/1/2014	9/5/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-291600	Finished	006-AHU-001	9/1/2014	9/6/2014	False	4.00	PM - Air Handling Unit (ANNUAL)
FO-291601	Finished	203-AHU-003	9/1/2014	9/23/2014	False	2.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-291602	Finished	203-AHU-002	9/1/2014	9/27/2014	False	3.00	Replace PRE-filters
FO-291603	Finished	203-AHU-001	9/1/2014	9/27/2014	False	3.00	Replace PRE-filters
FO-291604	Finished	203-MAU-001	9/1/2014	9/23/2014	False	1.00	Replace PRE-filters
FO-291605	Finished	140-AHU-004	9/1/2014	9/17/2014	False	3.00	Replace PRE-filters
FO-291606	Finished	140-AHU-003	9/1/2014	9/17/2014	False	3.00	Replace PRE-filters
FO-291607	Created By PM Schedule	620-AHU-001	9/1/2014		False		Replace PRE-filters
FO-291608	Finished	140-AHU-002	9/1/2014	9/23/2014	False	3.00	Replace PRE-filters
FO-291609	Finished	140-AHU-001	9/1/2014	9/23/2014	False	3.00	Replace PRE-filters
FO-291610	Finished	189-AHU-002	9/1/2014	9/4/2014	False	5.00	Replace PRE-filters
FO-291611	Finished	189-AHU-001	9/1/2014	9/3/2014	False	3.00	Replace PRE-filters
FO-291612	Finished	042-SAF-013	9/1/2014	9/25/2014	False	3.00	Replace PRE-filters
FO-291613	Finished	042-SAF-012	9/1/2014	9/25/2014	False	3.00	Replace PRE-filters
FO-291614	Created By PM Schedule	042-SAF-001	9/1/2014		False		Replace PRE-filters
FO-291615	Finished	042-AHU-001	9/1/2014	10/2/2014	False	1.00	Replace PRE-filters
FO-291616	Created By PM Schedule	040-SAF-004	9/1/2014		False		Replace PRE-filters
FO-291617	Finished	040-SAF-003	9/1/2014	10/2/2014	False	2.00	Replace PRE-filters
FO-291618	Finished	040-SAF-002	9/1/2014	10/2/2014	False	2.00	Replace PRE-filters
FO-291619	Finished	039-SAF-009	9/1/2014	9/26/2014	False	2.00	Replace PRE-filters
FO-291620	Finished	039-SAF-008	9/1/2014	9/26/2014	False	2.00	Replace PRE-filters
FO-291621	Finished	039-SAF-007	9/1/2014	9/26/2014	False	2.00	Replace PRE-filters
FO-291622	Finished	039-SAF-006	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291623	Finished	039-SAF-005	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291624	Finished	039-SAF-004	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291625	Finished	039-SAF-003	9/1/2014	9/26/2014	False	2.00	Replace PRE-filters
FO-291626	Finished	039-SAF-002	9/1/2014	9/26/2014	False	2.00	Replace PRE-filters
FO-291627	Finished	039-SAF-001	9/1/2014	9/26/2014	False	0.30	Replace PRE-filters
FO-291628	Finished	038-SAF-004	9/1/2014	9/30/2014	False	1.00	Replace PRE-filters
FO-291629	Finished	038-SAF-003	9/1/2014	9/30/2014	False	1.00	Replace PRE-filters
FO-291630	Created By PM Schedule	038-SAF-002	9/1/2014		False		Replace PRE-filters
FO-291631	Finished	038-SAF-001	9/1/2014	9/30/2014	False	3.00	Replace PRE-filters
FO-291632	Finished	189-HVU-001	9/1/2014	9/3/2014	False	2.00	Replace PRE-filters
FO-291633	Finished	189-HVU-002	9/1/2014	9/3/2014	False	2.00	Replace PRE-filters
FO-291634	Finished	043-HVU-001	9/1/2014	9/12/2014	False	1.00	Replace PRE-filters
FO-291635	Finished	043-AHU-003	9/1/2014	9/12/2014	False	1.00	Replace PRE-filters
FO-291636	Finished	043-AHU-002	9/1/2014	9/12/2014	False	2.00	Replace PRE-filters
FO-291637	Finished	043-AHU-001	9/1/2014	9/12/2014	False	2.00	Replace PRE-filters
FO-291638	Finished	067-AHU-400.1	9/1/2014	9/26/2014	False	0.50	Replace PRE-filters
Units are not being run. Filters did not need to be changed. Engineer checked operation.							
FO-291639	Finished	067-AHU-400.2	9/1/2014	9/26/2014	False	0.50	Replace PRE-filters
Units are not being run. Filters did not need to be changed. Engineer checked operation.							
FO-291640	Finished	067-AHU-405.2	9/1/2014	9/26/2014	False	0.50	Replace PRE-filters
Units are not being run. Filters did not need to be changed. Engineer checked operation.							
FO-291641	Finished	096-FP-001	9/1/2014	9/11/2014	False	1.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-291642	Finished	050-AHU-001	9/1/2014	9/16/2014	False	5.00	Replace PRE-filters

Requested Finished Open WND

% Finished

FO-291643	Finished	065-AHU-001	9/1/2014	9/26/2014	False	3.50	Replace PRE-filters
Replaced filters , check belts, lubed motor and dampers. Discarded old filters.							
FO-291644	Finished	067-AHU-003	9/1/2014	9/26/2014	False	0.50	Replace PRE-filters
changed filters, checked belts, lubricated fans.							
FO-291645	Finished	067-AHU-001	9/1/2014	9/26/2014	False	0.45	Replace PRE-filters
Changed filters, changed belt, lubricated fan.							
FO-291646	Finished	609-AHU-005	9/1/2014	9/27/2014	False	2.50	Replace PRE-filters
FO-291647	Finished	609-AHU-004	9/1/2014	9/25/2014	False	2.00	Replace PRE-filters
FO-291648	Finished	609-AHU-003B	9/1/2014	9/25/2014	False		Replace PRE-filters
FO-291649	Finished	609-AHU-003A	9/1/2014	9/25/2014	False	2.50	Replace PRE-filters
FO-291650	Finished	609-AHU-002	9/1/2014	9/30/2014	False	3.00	Replace PRE-filters
FO-291651	Finished	609-AHU-001	9/1/2014	9/27/2014	False	3.00	Replace PRE-filters
FO-291652	Finished	001-AHU-004O	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291653	Finished	001-AHU-003O	9/1/2014	9/16/2014	False	2.00	Replace PRE-filters
FO-291654	Finished	001-AHU-003ML	9/1/2014	9/5/2014	False	3.00	Replace PRE-filters
FO-291655	Finished	001-AHU-002O	9/1/2014	9/10/2014	False	4.00	Replace PRE-filters
FO-291656	Finished	001-AHU-002ML	9/1/2014	9/13/2014	False	2.00	Replace PRE-filters
FO-291657	Finished	001-AHU-002	9/1/2014	9/11/2014	False	2.00	Replace PRE-filters
FO-291658	Finished	001-AHU-001O	9/1/2014	9/11/2014	False	2.00	Replace PRE-filters
FO-291659	Finished	001-AHU-001ML	9/1/2014	9/11/2014	False	3.00	Replace PRE-filters
FO-291660	Finished	001-AHU-001	9/1/2014	9/13/2014	False	3.00	Replace PRE-filters
FO-292199	Finished	001-FCU-4231	9/10/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292200	Finished	001-FCU-4232	9/10/2014	9/17/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292201	Finished	001-FCU-4233	9/10/2014	9/19/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292202	Finished	001-FCU-4234-1	9/10/2014	9/19/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292203	Finished	001-FCU-4234-2	9/10/2014	9/19/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292204	Finished	001-FCU-4235-1	9/10/2014	9/19/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292205	Finished	001-FCU-4235-2	9/10/2014	9/19/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292206	Finished	001-FCU-4335	9/10/2014	9/19/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292207	Finished	001-FCU-4341	9/10/2014	9/13/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292208	Finished	001-FCU-4343	9/10/2014	9/13/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292209	Finished	001-FCU-4344	9/10/2014	9/19/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292210	Finished	001-FCU-4345	9/10/2014	9/13/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292211	Finished	001-FCU-4346	9/10/2014	9/24/2014	False	1.00	PM - Fan Coil/HV/AC Unit
FO-292212	Finished	612-FP-001	9/1/2014	9/20/2014	False	2.00	PM - Monthly Fire Alarm/Fire Protection System Test
FO-292688	Finished	001-FCU-1129-1	9/17/2014	9/5/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292689	Finished	001-FCU-1129-2	9/17/2014	9/5/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292690	Finished	001-FCU-1129-3	9/17/2014	9/5/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292691	Finished	001-FCU-1133-1	9/17/2014	9/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292692	Finished	001-FCU-1133-2	9/17/2014	9/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292693	Finished	001-FCU-1133-3	9/17/2014	9/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292694	Finished	001-FCU-1134-1	9/17/2014	9/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292695	Finished	001-FCU-1134-2	9/17/2014	9/20/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292696	Finished	001-FCU-1137-1	9/17/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit

Requested Finished Open WND

% Finished

FO-292697	Finished	001-FCU-1137-2	9/17/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-292698	Finished	001-FCU-1137-3	9/17/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293315	Finished	001-FCU-1143-1	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293316	Finished	001-FCU-1143-2	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293317	Finished	001-FCU-1143-3	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293318	Finished	001-FCU-1145-1	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293319	Finished	001-FCU-1145-2	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293320	Finished	001-FCU-1145-3	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293321	Finished	001-FCU-1145-4	9/24/2014	9/24/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293322	Finished	001-FCU-1147-1	9/24/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293323	Finished	001-FCU-1147-2	9/24/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293324	Finished	001-FCU-1151-1	9/24/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293325	Finished	001-FCU-1151-2	9/24/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293326	Finished	001-FCU-1151-3	9/24/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293327	Finished	001-FCU-3141-2	9/21/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-293328	Finished	001-FCU-2353	9/21/2014	9/30/2014	False	0.50	PM - Fan Coil/HV/AC Unit
FO-294273	Finished	169-FAP-001	9/2/2014	9/30/2014	False	0.50	PM - Monthly Fire Alarm/Fire Protection System Test
FO-294417	Finished	608-AHU-004	9/1/2014	9/13/2014	False	2.50	Replace PRE-filters
FO-294418	Finished	608-AHU-003	9/1/2014	9/12/2014	False	2.50	Replace PRE-filters
FO-294419	Finished	608-AHU-002	9/1/2014	9/12/2014	False	2.50	Replace PRE-filters
FO-294420	Finished	608-AHU-001	9/1/2014	9/13/2014	False	2.50	Replace PRE-filters

E - South

23

23

0

0

100%

FO-292670	Finished	089-AHU-003	9/1/2014	9/2/2014	False	1.00	PM - Bi Annual Inspection of Glycol
FO-292671	Finished	089-AHU-004	9/1/2014	9/2/2014	False	1.00	PM - Bi Annual Inspection of Glycol
FO-293236	Finished	007-GEN-001	9/11/2014	9/11/2014	False	1.00	Generator Maintenance, Monthly
FO-293237	Finished	007-GEN-002	9/11/2014	9/11/2014	False	4.00	Generator Maintenance, Monthly
FO-293238	Finished	007-AHU-007	9/13/2014	9/15/2014	False	4.00	Replace PRE-filters
FO-293239	Finished	007-AHU-006	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293240	Finished	007-AHU-005	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293241	Finished	007-AHU-004	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293242	Finished	007-AHU-003	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293243	Finished	007-AHU-002	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293244	Finished	007-AHU-001	9/13/2014	9/13/2014	False	2.00	Replace PRE-filters
FO-293245	Finished	007-EXF-002	9/13/2014	9/13/2014	False	2.00	Replace PRE-filters
FO-293246	Finished	007-EXF-001	9/13/2014	9/13/2014	False	4.00	Replace PRE-filters
FO-293265	Finished	090-ACU-CR2	9/8/2014	9/10/2014	False	1.00	Monthly AHU Inspection Clean Room Unit 2
FO-293270	Finished	090-ACU-CR1	9/8/2014	9/10/2014	False	1.00	PM - Monthly AHU Inspection Clean Room Unit 1
FO-293276	Finished	090-VPS-541	9/3/2014	9/4/2014	False	1.00	PM - Vacuum Pump
FO-293277	Finished	090-WSS-001	9/4/2014	9/4/2014	False	1.00	PM - Water Softener
FO-293895	Finished	090-GEN-001	9/16/2014	9/16/2014	False	1.00	Generator Maintenance, Monthly
FO-293907	Finished	090-GEN-002	9/11/2014	9/11/2014	False	1.00	Generator Maintenance, Monthly
FO-294275	Finished	089-GEN-001	9/17/2014	9/17/2014	False	1.00	Generator Maintenance, Monthly
FO-294300	Finished	006-GEN-001	9/18/2014	9/18/2014	False	0.75	Generator Maintenance, Monthly
FO-294303	Finished	089-GEN-002	9/17/2014	9/17/2014	False	1.00	Generator Maintenance, Monthly

Request ID	Status	Job ID	Start Date	End Date	Open	WND	Description
FO-294781	Finished	090-DHW-001	9/20/2014	9/23/2014	False	1.00	PM - Domestic Water Heater, Steam
E - Southeast							
			45	36	9	0	
FO-292663	Finished	016-SP-001	9/1/2014	10/2/2014	False	1.50	PM - Sump Pump
Checked float and pump operation, changed oil for seal and bearing cavities, lubricated motor bearing, checked alignment and cleaned the equipment.							
FO-292664	Finished	016-SP-002	9/1/2014	10/2/2014	False	1.50	PM - Sump Pump
Checked float and pump operation, changed oil for seal and bearing cavities, lubricated motor bearing, checked alignment and cleaned the equipment.							
FO-292665	Finished	609-AIR-001C	9/1/2014	9/26/2014	False		PM - Air Compressor, Reciprocating 5-40 H.P.
checked belts and oil, greased equipment							
FO-292666	Finished	609-AIR-001L	9/1/2014	9/26/2014	False		PM - Air Compressor, Reciprocating 5-40 H.P.
checked belts and oil, greased equipment							
FO-292668	Created By PM Schedule	188-DHW-001	9/1/2014		False		PM - Domestic Water Heater, Electric
FO-292675	Finished	637-ACU-005	9/1/2014	9/26/2014	False		PM - Water/Air Cooled Condenser
cleaned coils							
FO-293266	Created By PM Schedule	068-CFP-001	9/7/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293267	Created By PM Schedule	068-CFP-002	9/7/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293867	Finished	001-DRF-001	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293868	Finished	001-DRF-002	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293869	Finished	001-DRF-003-1	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293870	Finished	001-DRF-004-1	9/12/2014	10/8/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293871	Finished	001-DRF-005-1	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS							
FO-293872	Finished	001-DRF-006-1	9/12/2014	10/8/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293873	Finished	001-DRF-007	9/12/2014	10/8/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293874	Finished	001-DRF-008	9/12/2014	10/8/2014	False	0.30	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN. COMPRESSOR WILL NOT RUN, W.O TO REFRIG SHOP.							
FO-293875	Finished	001-DRF-009	9/12/2014	10/8/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293876	Finished	001-DRF-010	9/12/2014	10/8/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293877	Finished	001-DRF-011	9/12/2014	10/8/2014	False	0.50	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN. COMPRESSOR WILL NOT RUN, W.O. ORDER REFRIG CREW.							
FO-293878	Finished	001-DRF-012	9/12/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293879	Finished	001-DRF-013	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							
FO-293880	Finished	001-DRF-014	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							

80%

Requested Finished Open WND

% Finished

FO-293881	Finished	001-DRF-015	9/12/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293882	Finished	001-DRF-003-2	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							
FO-293883	Finished	001-DRF-004-2	9/12/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293884	Finished	001-DRF-005-2	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							
FO-293885	Finished	001-DRF-006-2	9/12/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-293886	Finished	001-DRF-016	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							
FO-293887	Finished	001-DRF-017	9/12/2014	9/25/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAINS.							
FO-293888	Created By PM Schedule	499-CFP-001	9/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293889	Created By PM Schedule	499-CFP-002	9/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293890	Created By PM Schedule	499-CFP-003	9/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293891	Created By PM Schedule	499-CFP-004	9/15/2014		False		PM - Chemical Feed/Metering Pump/Controller
FO-293898	Finished	637-GEN-001	9/16/2014	9/26/2014	False		Generator Maintenance, Monthly
Checked fluids battery and belts							
FO-293900	Finished	637-GEN-002	9/16/2014	9/26/2014	False		Generator Maintenance, Monthly
Checked fluids battery and belts							
FO-294787	Finished	001-AHU-001	9/18/2014	10/20/2014	False	0.25	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
OPENED STEAM TO HUMIDIFIERS & HEATING COILS.							
FO-294788	Finished	001-AHU-002	9/18/2014	10/20/2014	False	0.25	PM - Steam to Air Handling Unit - Open for Winter (Old Main)
OPENED STEAM TO HUMIDIFIERS & HEATING COILS.							
FO-294789	Finished	001-DRF-018	9/18/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-294790	Finished	001-DRF-019	9/18/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-294791	Finished	001-DRF-020	9/18/2014	10/9/2014	False	0.25	PM - Drinking Fountain and Water Cooler
CHECK OPERATION & CLEAR DRAIN.							
FO-295362	Finished	022-CFP-001	9/28/2014	10/3/2014	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked pump operation, checked for any leaks, checked controller for proper operation. Cleaned the equipment.							
FO-295363	Finished	022-CFP-002	9/28/2014	10/3/2014	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked pump operation, checked for any leak, checked controller for proper operation. cleaned the equipment.							
FO-295364	Finished	022-CFP-003	9/28/2014	10/3/2014	False	0.50	PM - Chemical Feed/Metering Pump/Controller
Checked pump operation, checked for any leak, checked controller for proper operation. cleaned the equipment.							
FO-295367	Created By PM Schedule	001-ACU-ROOF5	9/26/2014		False		PM - Water/Air Cooled Condenser
FO-295368	Created By PM Schedule	001-ACU-ROOF6	9/26/2014		False		PM - Water/Air Cooled Condenser
E - West			8	8	0	0	
FO-292667	Finished	150-DHW-002	9/1/2014	8/20/2014	False		PM - Domestic Water Heater, Electric
FO-292669	Finished	150-DHW-002	9/1/2014	9/30/2014	False		PM - Domestic Water Heater, Electric
FO-293268	Finished	155-CRS-001	9/6/2014	10/3/2014	False		PM - Condensate Return System ***Needs Task Sheet**

100%

Requested Finished Open WND

% Finished

FO-293269	Finished	155-CRS-002	9/6/2014	10/3/2014	False	PM - Condensate Return System **Needs Task Sheet**
FO-293311	Finished	001 SPARE from	9/9/2014	9/10/2014	False	Generator Maintenance, Monthly
FO-294302	Finished	169-GEN-001	9/25/2014	9/26/2014	False	Generator Maintenance, Monthly
FO-294782	Finished	155-CRS-003	9/19/2014	10/17/2014	False	PM - Condensate Return System **Needs Task Sheet**
FO-294783	Finished	155-CRS-005	9/19/2014	10/17/2014	False	PM - Condensate Return System **Needs Task Sheet**

Trades		38	35	3	0	92%	
T - Electrician		38	35	3	0	92%	
FO-293271	Finished	193-GEN-001	9/5/2014	9/5/2014	False	1.00	Generator Test
FO-293272	Finished	501-GEN-001	9/9/2014	9/16/2014	False	4.00	Generator Test
FO-293274	Finished	608-GEN-001	9/5/2014	9/5/2014	False	4.00	Generator Test
FO-293310	Finished	001 SPARE from	9/9/2014	9/10/2014	False	4.00	Generator Test
FO-293312	Finished	193-GEN-002	9/5/2014	9/5/2014	False	1.00	Generator Test
FO-293313	Finished	193-GEN-003	9/5/2014	9/5/2014	False	1.00	Generator Test
FO-293314	Finished	193-GEN-004	9/5/2014	9/5/2014	False	1.00	Generator Test
FO-293854	Created By PM Schedule	612-GEN-001	9/12/2014		False		Generator Maintenance, Monthly
FO-293855	Created By PM Schedule	612-GEN-002	9/12/2014		False		Generator Maintenance, Monthly
FO-293892	Finished	609-GEN-001	9/16/2014	9/16/2014	False	4.00	Generator Test Tuesday 9/16/2014 @ 7:15AM.
FO-293893	Finished	007-GEN-001	9/11/2014	9/11/2014	False	2.00	Generator Test
FO-293894	Finished	007-GEN-002	9/11/2014	9/11/2014	False	2.00	Generator Test
FO-293896	Finished	090-GEN-001	9/16/2014	9/16/2014	False	3.00	Generator Test Tuesday 9/16/2014 @ 9:30AM.
FO-293897	Finished	637-GEN-001	9/16/2014	9/16/2014	False	2.00	Generator Test Tuesday 9/16/2014 @8:15AM.
FO-293899	Finished	637-GEN-002	9/16/2014	9/16/2014	False	2.00	Generator Test Tuesday 9/16/2014 @ 8:15AM,.
FO-293901	Finished	612-GEN-001	9/12/2014	9/12/2014	False	2.00	Generator Test
FO-293902	Finished	612-GEN-002	9/12/2014	9/12/2014	False	2.00	Generator Test
FO-293903	Finished	507-GEN-001	9/10/2014	9/16/2014	False	4.00	Generator Test
FO-293905	Finished	203-GEN-001	9/16/2014	9/16/2014	False	4.00	Generator Test Tuesday 9/16/2014 @ 9:15AM.
FO-293906	Finished	090-GEN-002	9/11/2014	9/11/2014	False	4.00	Generator Test
FO-293909	Finished	048-GEN-001	9/12/2014	9/12/2014	False	4.00	Generator Test
FO-293910	Finished	GEN-001 (Towa	9/10/2014	9/10/2014	False	4.00	Generator Test
FO-294276	Finished	089-GEN-001	9/17/2014	9/17/2014	False	4.00	Generator Test Wednesday 9/17/2014 @ 10AM.
FO-294278	Finished	066-GEN-001	9/24/2014	9/24/2014	False	4.00	Generator Test Wednesday 9/24/2014 @7:15 AM.
FO-294279	Finished	611-GEN-001	9/26/2014	9/26/2014	False	4.00	Generator Test Friday 9/26/2014 @7:15 AM.
FO-294281	Finished	629-GEN-001	9/26/2014	9/26/2014	False	4.00	Generator Test Friday 9/26/2014 @10AM.
FO-294283	Finished	104-GEN-001	9/23/2014	9/23/2014	False	4.00	Generator Test Tuesday 9/23/2014 @10AM.
FO-294285	Finished	127-GEN-001	9/23/2014	9/23/2014	False	1.00	Generator Test Tuesday 9/23/2014 @8AM.
FO-294287	Finished	127-GEN-002	9/23/2014	9/23/2014	False	1.00	Generator Test Wednesday 9/23/2014 @8AM.
FO-294289	Finished	127-GEN-003	9/23/2014	9/23/2014	False	1.00	Generator Test Tuesday 9/23/2014 @ 8AM.
FO-294291	Finished	127-GEN-004	9/23/2014	9/23/2014	False	1.00	Generator Test Tuesday 9/23/2014 @8AM.
FO-294293	Finished	130-GEN-001	9/24/2014	9/24/2014	False	4.00	Generator Test Wednesday 9/24/2014 @7:15AM.
FO-294295	Finished	536-GEN-001	9/17/2014	9/17/2014	False	4.00	Generator Test Wednesday 9/17/2014 @ 7:15AM.
FO-294297	Finished	527-GEN-001	9/18/2014	9/18/2014	False		Generator Test Thursday 9/18/2014 @7:15AM.
FO-294299	Finished	006-GEN-001	9/18/2014	9/18/2014	False	4.00	Generator Test Thursday 9/18/2014 @7:15AM.
FO-294301	Finished	169-GEN-001	9/25/2014	9/25/2014	False	4.00	Generator Test Thursday 9/25/2014 @7:15AM.

Requested Finished Open WND

% Finished

FO-294304	Finished	089-GEN-002	9/17/2014	9/16/2014	False	Generator Test Wednesday 9/17/2014 @ 10AM.
FO-296722	Created By PM Schedule	999	9/7/2014		False	Adjust Clocks For Daylight Savings Time.

Report Total			482	394	55	33		82%
---------------------	--	--	------------	------------	-----------	-----------	--	------------