

***DRAFT* Facilities Operations PM Analysis from 5/1/2014 through 5/31/2014**

Request		% Finished		Requested	Open	WND	Finished
Engineering		72%		720	189	10	519
E - Area 2 Engineer		0%		1	1	0	0
FO-284097	089-VPS-001	PM Vacuum pump system. Finished 4/4/13LT Changed to low, Laborer didn't receive work order till 7/22/2013.	see results for fo#16406	5/12/2014		False	
E - Auxiliary		19%		27	22	0	5
FO-282198	992-ES-001*	PM - Emergency Shower/Eyewash Station		5/5/2014		False	
FO-282754	501-GEN-001	Generator Maintenance, Monthly		5/13/2014		False	
FO-283030	536-GEN-001	Generator Maintenance, Monthly		5/14/2014		False	
FO-282197	536-AHU-201	PM - Air Handling Unit, HV Type		5/1/2014		False	
FO-282199	536-HP-001	PM - Air Handling Unit, HV Type		5/1/2014		False	
FO-283026	507-GEN-001	Generator Maintenance, Monthly		5/14/2014		False	
FO-282759	992-ES-001*	PM - Emergency Shower/Eyewash Station		5/12/2014		False	
FO-282160	025-AHU-001	PM - Air Handling Unit		5/4/2014		False	
FO-282161	025-AHU-002	PM - Air Handling Unit		5/4/2014		False	
FO-282162	025-AHU-003	PM - Air Handling Unit		5/4/2014		False	
FO-282163	025-AHU-004	PM - Air Handling Unit		5/4/2014		False	
FO-282195	025-AHU-005	PM - Air Handling Unit		5/4/2014		False	
FO-283382	992-ES-001*	PM - Emergency Shower/Eyewash Station		5/19/2014		False	
FO-283010	104-GEN-001	Generator Maintenance, Monthly	Ran test with WSU electricians (FO-283009). No issues with the generator. Elevator technician requests we turn power off to Ghafari one day to test elevators. We have a long-standing issue of trapping people on the elevators at Ghafari during these monthly tests.	5/27/2014		False	5/27/2014
FO-283012	127-GEN-001	Generator Maintenance, Monthly	Ran test with WSU electricians, FO-283011. No issues.	5/27/2014		False	5/27/2014
FO-283014	127-GEN-002	Generator Maintenance, Monthly	Ran test with WSU electricians, FO-283013. No issues.	5/27/2014		False	5/27/2014
FO-283016	127-GEN-003	Generator Maintenance, Monthly	Ran test with WSU electricians, FO-283015. No issues.	5/27/2014		False	5/27/2014
FO-283018	127-GEN-004	Generator Maintenance, Monthly	Ran test with WSU electricians, FO-283017. No issues.	5/27/2014		False	5/27/2014
FO-282193	136-MAU-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-282242	134-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-282243	127-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	

Request		% Finished	Requested	Open	WND	Finished
FO-282244	115-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	5/1/2014			False
FO-282245	104-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	5/1/2014			False
FO-282246	507-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	5/1/2014			False
FO-284158	992-ES-001*	PM - Emergency Shower/Eyewash Station	5/26/2014			False
FO-282757	507-CRP-001	PM - Centrifugal Pump, over 1 H.P.	5/10/2014			False
FO-282758	507-CRP-002	PM - Centrifugal Pump, over 1 H.P.	5/10/2014			False
E - Director		5%	39	37	0	2
FO-282237	026-ACU-004	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers	5/1/2014			False
FO-282238	609-ACU-002	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers	5/1/2014			False
FO-282239	609-ACU-001	PM - Carrier Chillers: Start Up Services for Centrifugal Chillers	5/1/2014			False
FO-282240	096-ACU-001	PM - McQuay Chillers: Seasonal Start Up for Centrifugal & Screw (Air cooled) Chillers	5/1/2014			False
FO-282241	065-ACU-001	PM - McQuay Chillers: Seasonal Start Up for Centrifugal & Screw (Air cooled) Chillers	5/1/2014			False
FO-282203	637-ACU-003	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282204	637-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282205	629-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	Chiller #1 on line...Repairs made by oneil 5/1/2014			False 5/8/2014
FO-282206	629-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282207	612-ACU-003	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282208	499-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282209	193-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282210	155-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282211	155-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False

Request		% Finished	Requested	Open	WND	Finished
FO-282212	140-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282213	140-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282214	089-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282215	062-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282216	062-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282217	050-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282218	049-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282219	048-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282220	046-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282221	039-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282222	039-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282223	026-ACU-003	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282224	026-ACU-002	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282225	026-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282226	016-ACU-004	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282227	006-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False
FO-282228	003-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers	5/1/2014			False

Request		% Finished		Requested	Open	WND	Finished
FO-282229	082-ACU-003	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers		5/1/2014		False	
FO-282230	043-ACU-001	PM - Trane Chillers: Start-up Services for Centrifugal/Rotary Screw (Water Cooled)/ Rotary (Air Cooled) Chillers		5/1/2014		False	
FO-282231	134-ACU-001	PM - York Chillers: Startup Services for Absorber Chillers		5/1/2014		False	
FO-282232	022-ACU-001	PM - York Chillers: Startup Services for Absorber Chillers	This is a vendor service. PM scheduler to be adjusted.	5/1/2014		False	5/16/2014
FO-282233	001-ACU-001	PM - York Chillers: Startup Services for Absorber Chillers		5/1/2014		False	
FO-282234	612-ACU-002	PM - York Chillers: Startup Services for Absorber Chillers		5/1/2014		False	
FO-282235	612-ACU-001	PM - York Chillers: Startup Services for Absorber Chillers		5/1/2014		False	
FO-282236	507-ACU-001	PM - York Chillers: Startup Services for Absorber Chillers		5/1/2014		False	
E - MedPharm		16%		19	16	0	3
FO-282134	608-GEN-001	Generator Maintenance, Monthly		5/2/2014		False	
FO-282711	612-GEN-001	Generator Maintenance, Monthly		5/9/2014		False	
FO-282712	612-GEN-002	Generator Maintenance, Monthly		5/9/2014		False	
FO-283033	609-GEN-001	Generator Maintenance, Monthly	checked battery fluids and heater	5/20/2014		False	5/29/2014
FO-283006	611-GEN-001	Generator Maintenance, Monthly	Electricians completed monthly generator load test	5/23/2014		False	5/23/2014
FO-282129	603-AC-001	PM - Air Compressor, Reciprocating 5-40 H.P.		5/1/2014		False	
FO-282135	612-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-282131	612-SP-001	PM - Centrifugal Pump, over 1 H.P.		5/2/2014		False	
FO-282132	612-SP-002	PM - Centrifugal Pump, over 1 H.P.		5/2/2014		False	
FO-282133	612-SP-003	PM - Centrifugal Pump, over 1 H.P.		5/2/2014		False	
FO-283008	629-GEN-001	Generator Maintenance, Monthly		5/23/2014		False	
FO-284753	603-ROS-001	PM - Reverse Osmosis Water Softener System		5/28/2014		False	
FO-284750	603-HEX-001	PM - Heat Exchanger and Economizer		5/30/2014		False	
FO-284751	603-HEX-002	PM - Heat Exchanger and Economizer		5/30/2014		False	
FO-284752	603-HEX-003*	PM - Heat Exchanger and Economizer		5/30/2014		False	
FO-284761	603-HEX-004*	PM - Heat Exchanger and Economizer		5/30/2014		False	
FO-282130	603-DWBP-003	PM - Centrifugal Pump, over 1 H.P.		5/6/2014		False	
FO-283316	608-DWBP-004	PM - Centrifugal Pump, over 1 H.P.		5/18/2014		False	
FO-283317	611-DWBP-001	PM - Centrifugal Pump, over 1 H.P.	Cannot take #1 booster pump out of service for maintenance because #2 pump is down.	5/18/2014		False	5/29/2014
E - North		16%		25	21	0	4
FO-282716	048-GEN-001	Generator Maintenance, Monthly		5/9/2014		False	
FO-282146	130-AHU-001	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	Carl Smith-changed belts on condenser fan grease bearing	5/5/2014		False	4/28/2014

Request		% Finished		Requested	Open	WND	Finished
FO-282144	040-SAF-002	PM - Outside/Fresh Air Intake Screens		5/6/2014		False	
FO-282145	040-SAF-003	PM - Outside/Fresh Air Intake Screens		5/6/2014		False	
FO-283321	130-AHU-001	PM - Grease Fan Bearings & Check Belts Bi-Monthly [FAB RoofTop Units]	Carl Smith-check belts ok	5/19/2014		False	5/13/2014
FO-282714	025-DHW-001	PM - Domestic Water Heater, Steam		5/13/2014		False	
FO-283024	130-GEN-001	Generator Maintenance, Monthly		5/28/2014		False	5/28/2014
FO-283319	049-CHWBP-001	PM - Water Booster Pump		5/15/2014		False	
FO-283320	049-CHWBP-002	PM - Water Booster Pump		5/15/2014		False	
FO-280898	025-AHU-005	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-280899	025-AHU-004	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-280900	025-AHU-003	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-280901	025-AHU-002	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-280902	025-AHU-001	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-282139	050-SP-003	PM - Sump Pump		5/2/2014		False	4/29/2014
FO-284135	048-SSF-001	PM - Harmsco Side Stream Filter		5/21/2014		False	
FO-284136	048-SSF-002	PM - Harmsco Side Stream Filter		5/21/2014		False	
FO-284137	046-SSF-001	PM - Harmsco Side Stream Filter		5/21/2014		False	
FO-284138	046-SSF-003	PM - Harmsco Side Stream Filter		5/21/2014		False	
FO-284139	046-SSF-002	PM - Harmsco Side Stream Filter		5/21/2014		False	
FO-283318	025-CRS-001	PM - Condensate Return Pump		5/15/2014		False	
FO-282713	026-HEX-001	PM - Heat Exchanger and Economizer		5/13/2014		False	
FO-282715	026-HEX-002	PM - Heat Exchanger and Economizer		5/13/2014		False	
FO-284764	140-HRP-001	PM - Centrifugal Pump, over 1 H.P.		5/29/2014		False	
FO-284765	140-HRP-002	PM - Centrifugal Pump, over 1 H.P.		5/29/2014		False	
E - Northeast		19%		21	17	0	4
FO-282156	193-GEN-001	Generator Maintenance, Monthly		5/2/2014		False	
FO-282157	193-GEN-002	Generator Maintenance, Monthly		5/2/2014		False	
FO-282158	193-GEN-003	Generator Maintenance, Monthly		5/2/2014		False	
FO-282159	193-GEN-004	Generator Maintenance, Monthly		5/2/2014		False	
FO-282147	193-WSS-001	PM - Water Softener		5/1/2014		False	
FO-283032	527-GEN-001	Generator Maintenance, Monthly		5/15/2014		False	
FO-283035	060-GEN-001 (Towable)	Generator Maintenance, Monthly		5/14/2014		False	
FO-282152	060-ACU-025	PM - Fan Coil/HV/AC Unit		5/2/2014		False	
FO-282153	060-ACU-026	PM - Fan Coil/HV/AC Unit		5/2/2014		False	
FO-282154	060-ACU-027	PM - Fan Coil/HV/AC Unit		5/2/2014		False	
FO-282155	060-ACU-028	PM - Fan Coil/HV/AC Unit		5/2/2014		False	
FO-283028	203-GEN-001	Generator Maintenance, Monthly		5/20/2014		False	
FO-283003	066-GEN-001	Generator Maintenance, Monthly		5/28/2014		False	
FO-283322	195-ACU-001	PM - Fan Coil/HV/AC Unit	Timothy Deroo-brush condenser coils clean evap coil change filters 6at 12x24x2 order new condenser fan belt and more filters prep to acid wash coils	5/15/2014		False	5/13/2014

Request		% Finished	Requested Open WND Finished				
FO-283323	195-ACU-002	PM - Fan Coil/HV/AC Unit	Timothy Deroo-changed air filters check motor fan lube as nesc	5/15/2014	5/13/2014	False	5/13/2014
FO-283324	195-ACU-003	PM - Fan Coil/HV/AC Unit	Timothy Deroo-check motor n belt changed filterd trying to order more 16x25x5	5/15/2014		False	5/13/2014
FO-282148	193-CRP-001	PM - Condensate Return Pump		5/2/2014		False	
FO-282149	193-CRP-002	PM - Condensate Return Pump		5/2/2014		False	
FO-282150	193-CRP-003	PM - Condensate Return Pump		5/2/2014		False	
FO-282151	193-CRP-004	PM - Condensate Return Pump		5/2/2014		False	
FO-283325	509-HWP-010	PB - B&G Series 100 Pump	checked coupling, rotation lubricated bearing	5/16/2014		False	5/27/2014
E - Preventative Maintenance		82%		432	67	10	353
FO-280223	611-EXF-026	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-284299	006	Quarterly Filter Order for Life Science Animal Quarters.	Order only. Filters received on 2-11-14 & delivered to Department (DLAR).	5/14/2014		False	
		Filters to be turned over to DLAR Staff.					
FO-283581	080-ACU-001	PM - Replace Prefilters	Thomas Townsel-Changed filters an inspected unit.	performed pm task list	5/6/2014	False	5/3/2014
FO-283582	080-ACU-002	PM - Replace Prefilters	Thomas Townsel-changed filters, checked motor an inspected coils.	performed pm task list	5/6/2014	False	5/3/2014
FO-283583	080-ACU-003	PM - Replace Prefilters		performed pm task list	5/6/2014	False	5/3/2014
FO-283041	499-AHU-008**	Replace PRE-filters	Thomas Townsel-Change filters, checked belts, lubricated bearings, and placed unit backed in services.	5/1/2014		False	4/30/2014
FO-280929	001-FCU-3101	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280930	001-FCU-3102	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280931	001-FCU-3106-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280932	001-FCU-3106-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280933	001-FCU-3106-3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280934	001-FCU-3106-4	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280935	001-FCU-3106-5	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280936	001-FCU-3106-6	PM - Fan Coil/HV/AC Unit		5/7/2014		False	
FO-280937	001-FCU-3106-7	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280938	001-FCU-3106-8	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280939	001-FCU-3108.2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014
FO-280940	001-FCU-3108.3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.	5/7/2014		False	5/29/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280941	001-FCU-2155	PM - Fan Coil/HV/AC Unit		5/7/2014		False	
FO-280342	203-AHU-003	PM - Air Handling Unit, HV Type		5/1/2014	5/2/2014	True	
FO-280953	091-AHU-001	PM - Air Handling Unit		5/4/2014	5/5/2014	True	
FO-280952	074-AHU-002	PM - Air Handling Unit, HV Type		5/6/2014	5/14/2014	True	
FO-281625	001-FCU-3114-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.	5/14/2014		False	5/29/2014
FO-281626	001-FCU-3114-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.	5/14/2014		False	5/29/2014
FO-281627	001-FCU-3114-3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.	5/14/2014		False	5/29/2014
FO-281628	001-FCU-3114-4	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.	5/14/2014		False	5/29/2014
FO-281629	001-FCU-3117-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281630	001-FCU-3117-10	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281631	001-FCU-3117-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281632	001-FCU-3117-3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281633	001-FCU-3117-4	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281634	001-FCU-3117-5	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281635	001-FCU-3117-6	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281636	001-FCU-3117-7	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281637	001-FCU-3117-8	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281638	001-FCU-3117-9	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.	5/14/2014		False	5/31/2014
FO-281088	022-HVU-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out fan. Checked condition of fan and motor. Checked coil, valves, and piping. Inspected and changed belts. Changed filters. Lubricated motor. Placed back in service. Cleaned area.	5/1/2014		False	5/20/2014
FO-277446	612-AHU-005A	Replace PRE-filters	Derrick Allen-pm ahu #5a scotthall bldg. #612 Lubricate motor and fan bearings Lubricate linkages and dampers Change dirty and dispose of filters Check wear and alignment of belts and sheaves Clean up around fan housing	5/1/2014		False	5/13/2014
FO-277447	612-AHU-004	Replace PRE-filters	Derrick Allen-pm # ahu #4 scotthall bldg. #612 Lubricate motor and fan bearings Lubricate linkages and dampers Change and dispose of dirty filters Check belts and sheaves for wear and alignment Clean up around fan housing	5/1/2014		False	5/13/2014

Request		% Finished		Requested	Open	WND	Finished
FO-277445	612-AHU-005B	Replace PRE-filters	Derrick Allen-pm ahu # 5b scotthall bldg. #612 lubricate fan and motor bearings lubricate linkages and dampers change and dispose of dirty filters check belts and sheaves for wear ? clean up around fan housing	5/1/2014		False	5/13/2014
FO-277444	612-AHU-005C	Replace PRE-filters	Derrick Allen-pm ahu #5c scotthall #612 lubricate motor and fan bearings lubricate linkages and dampers check belts and sheaves for wear and alignment clean up around fan housing	5/30/2014		False	5/13/2014
FO-277443	612-AHU-006	Replace PRE-filters	Derrick Allen-pm ahu #6 scotthall bldg. #612 lubricate fan and motor bearings ? lubricate linkages and dampers check belts and sheaves for wear and alignment change and dispose of dirty filters clean up around fan housing	5/1/2014		False	5/13/2014
FO-280189	016-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed fan guard. Checked fan. Inspected belts. Lubricated fan and motor bearings. Replaced guard. Returned to service.	5/1/2014		False	5/6/2014
FO-280190	016-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed fan guard. Checked fan. Inspected belts. Lubricated fan and motor bearings. Replaced guard. Returned to service.	5/1/2014		False	5/6/2014
FO-280191	016-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed fan guard. Checked fan. Inspected belts. Lubricated fan and motor bearings. Replaced guard. Returned to service.	5/1/2014		False	5/6/2014
FO-280192	022-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Checked condition of fan and motor. Lubricated fan bearings. Inspected and changed belt. Placed back in service. Cleaned area.	5/1/2014		False	5/20/2014
FO-280193	603-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #1 pharmacy #603 remove belt and motor guard lubricate motor and fan bearings check belt and sheave for wear ? put guard back on	5/1/2014		False	5/30/2014
FO-280194	603-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #2 pharmacy bldg. #603 remove belt and motor guard lubricate fan and motor bearings check belts and sheaves for wear put guard back on	5/1/2014		False	5/30/2014
FO-280195	603-EXF-001-A-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #1a pharmacy bldg. #603 lubricate fan and motor bearings lubricate dampers and linkages check belts and sheaves for wear clean up around fan housing	5/1/2014		False	5/31/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280196	603-EXF-002-B-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #2b lubricate fan and motor bearings lubricate linkages and dampers check belts and sheaves for wear clean up around fan housing	5/1/2014		False	5/31/2014
FO-280197	603-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280198	603-EXF-003-A-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #3a lubricate fan and motor bearings lubricate dampers and linkages check belts and sheaves for wear cleanup around fan housing	5/1/2014		False	5/31/2014
FO-280199	603-EXF-004-A-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #4a lubricate fan and motor bearings lubricate linkages and dampers check belts and sheaves for wear clean up around fan housing	5/1/2014		False	5/31/2014
FO-280200	603-EXF-004-B-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan # 4b lubricate fan and motor bearings lubricate linkages and dampers check belts and sheaves for wear clean up around fan housing	5/1/2014		False	5/31/2014
FO-280201	603-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #5 pharmacy bldg. #603 remove belt and motor guard lubricate fan and motor bearings check belt and sheaves for wear put guard back on	5/1/2014		False	5/30/2014
FO-280202	603-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #6 pharmacy bldg. #603 remove belt and fan guard lubricate motor and fan bearings check sheaves and belt for wear put guard back on	5/1/2014		False	5/30/2014
FO-280203	603-EXF-007	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #7 pharmacy bldg. #603 remove fan and belt guard lubricate fan and motor bearings check belt and sheave for wear put guard back on	5/1/2014		False	5/30/2014
FO-280204	603-EXF-008	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280205	603-EXF-009	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280206	603-EXF-010	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex- fan #10 pharmacy bldg. #603 check belt for wear and alignment grease motor and fan bearings clean around fan housing	5/1/2014		False	5/27/2014
FO-280207	603-EXF-012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #12 pharmacy bldg. #603 lubricate fan and motor bearings check belt for wear and alignment check sheave for wear clean up around fan	5/1/2014		False	5/27/2014
FO-280208	603-EXF-013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280209	603-EXF-015	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	

Request		% Finished		Requested	Open	WND	Finished
FO-280210	611-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280211	611-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280212	611-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280213	611-EXF-003A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280214	611-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280215	611-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280216	611-EXF-006**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280217	611-EXF-007**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280218	611-EXF-008**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280219	611-EXF-009**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280220	611-EXF-010**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280221	611-EXF-024**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280222	611-EXF-025	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Greased bearings. Check Belts. Clean equipment. Check for proper operation.	5/1/2014		False	5/24/2014
FO-280224	611-EXF-027**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM on fan. Check Belts. Clean equipment. Check for proper operation. Need belt.	5/1/2014		False	5/24/2014
FO-280225	611-EXF-028**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280226	611-EXF-031	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #31 lande bldg. #611 lubricate fan and motor bearings check belts and sheaves for wear	5/1/2014		False	5/29/2014
FO-280227	611-EXF-032**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #32 lande #611 lubricate fan and motor bearings check belts and sheaves for wear	5/1/2014		False	5/29/2014
FO-280228	611-EXF-033	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #33 lande #611 lubricate motor and fan bearings check belts and sheaves for wear	5/1/2014		False	5/29/2014
FO-280229	629-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	

Request		% Finished		Requested	Open	WND	Finished
FO-280230	629-EXF-002**	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280231	629-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280232	629-EXF-004A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280233	629-EXF-004B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280234	629-EXF-005A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280235	629-EXF-005B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280236	629-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280237	629-EXF-007	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/31/2014
FO-280238	629-EXF-008A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/31/2014
FO-280239	629-EXF-008B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/31/2014
FO-280240	629-EXF-009	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/30/2014
FO-280241	629-EXF-010	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/30/2014
FO-280242	629-EXF-012	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/30/2014
FO-280243	629-EXF-014	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/31/2014
FO-280244	629-EXF-015	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Jimmy Dykes-Perform PM. Lube Bearings . Check belts. Clean equipment.	5/1/2014		False	5/31/2014
FO-280245	046-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the supply fan operation Auto/Manual. Replaced pre- filters. Lubricated motor and fan bearing. Checked belts and belts tension. Cleaned surrounding area. Boxed dirty filter and disposed of dirty filters. Checked the units for vibration. Checked the units for dirty coil. Coils were dirty. Need chemical treatment for cleaning. Wrong size filters were used and filter were collapsed 16x25x1 instead 16x25x2. Missing motor pulley side grease fitting (Bottom screw) Placed the supply fan/return fan back in service	5/1/2014		False	5/25/2014
FO-280246	001-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access door. Cleaned interior. Checked condition of fan and motor. Checked belt. Closed access door and returned to service.	5/1/2014		False	5/24/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280247	001-EXF-EF1B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access door. Cleaned interior. Checked condition of fan and motor. Checked belt. Closed access door and returned to service.	5/1/2014		False	5/24/2014
FO-280248	001-EXF-001OA	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down unit. Cleaned interior. Checked condition of belts. Lubricated fan and motor bearings. Checked fire dampers. Test ran and returned to service.	5/1/2014		False	5/15/2014
FO-280249	001-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Cleaned interior. Checked fire damper. Checked motor and fan. Changed belt (A-44). Closed up unit and returned to service.	5/1/2014		False	5/29/2014
FO-280250	001-EXF-002OA	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down unit. Cleaned interior. Checked condition of belts. Lubricated fan and motor bearings. Checked fire dampers. Test ran and returned to service.	5/1/2014		False	5/15/2014
FO-280251	001-EXF-003-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.	5/1/2014		False	5/22/2014
FO-280252	001-EXF-003-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked belt. Checked operation of discharge air damper. Test ran and returned to service.	5/1/2014		False	5/22/2014
FO-280253	001-EXF-003-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.	5/1/2014		False	5/22/2014
FO-280253	001-EXF-003-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.	5/1/2014		False	5/22/2014
FO-280254	001-EXF-003OA	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down unit. Cleaned interior. Checked condition of belts. Lubricated fan and motor bearings. Checked fire dampers. Test ran and returned to service.	5/1/2014		False	5/15/2014
FO-280255	001-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Opened access door. Cleaned interior. Checked fire damper. Checked belt. Closed up access doors. Returned to service. Checked for noise and vibration.	5/1/2014		False	5/29/2014

Request				% Finished	Requested	Open	WND	Finished
FO-280256	001-EXF-004OA	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down unit. Cleaned interior. Checked condition of belts. Lubricated fan and motor bearings. Checked fire dampers. Test ran and returned to service.		5/1/2014		False	5/15/2014
FO-280257	001-EXF-005-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.		5/1/2014		False	5/22/2014
FO-280258	001-EXF-005-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked belt. Checked operation of discharge air damper. Test ran and returned to service.		5/1/2014		False	5/22/2014
FO-280259	001-EXF-005-3	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.		5/1/2014		False	5/22/2014
FO-280260	001-EXF-005-4	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.		5/1/2014		False	5/22/2014
FO-280261	001-EXF-005-5	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed cover. Cleaned interior. Checked and changed belt. (4L360). Checked operation of discharge air damper. Test ran and returned to service.		5/1/2014		False	5/22/2014
FO-280262	001-EXF-006-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.		5/1/2014		False	5/30/2014
FO-280263	001-EXF-006-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.		5/1/2014		False	5/30/2014
FO-280264	001-EXF-007	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Changed belt(A-44). Replaced cover and returned to service.		5/1/2014		False	5/30/2014
FO-280265	001-EXF-008-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.		5/1/2014		False	5/30/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280266	001-EXF-008-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280267	001-EXF-009-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280268	001-EXF-009-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280269	001-EXF-010	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Greased fan bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280270	001-EXF-011	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Greased bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280271	001-EXF-012-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280271	001-EXF-012-1	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access cover. Cleaned interior. Checked condition of fan and bearings. Checked belt. Replaced cover and returned to service.	5/1/2014		False	5/30/2014
FO-280272	001-EXF-012-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the fan. Checked the operation of the unit. Cleaned the surrounding area.	5/1/2014		False	6/1/2014
FO-280273	001-EXF-013	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the fan. Checked the operation of the unit. Cleaned the surrounding area.	5/1/2014		False	6/1/2014
FO-280274	001-EXF-014	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the fan. Checked the operation of the unit. Cleaned the surrounding area.	5/1/2014		False	6/1/2014
FO-280275	001-EXF-015	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Opened access door. Cleaned interior. Checked fire damper. Checked belt. Closed up access doors. Returned to service. Checked for noise and vibration	5/1/2014		False	5/29/2014
FO-280276	001-EXF-016B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access door. Cleaned interior. Checked condition of fan and motor. Checked belt. Closed access door and returned to service.	5/1/2014		False	5/24/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280277	001-EXF-016D	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Opened access door. Cleaned interior. Checked fire damper. Replaced belt(A-33). Closed up access doors. Returned to service. Checked for noise and vibration	5/1/2014		False	5/29/2014
FO-280278	001-EXF-019A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the fan. Checked the operation of the unit. Cleaned the surrounding area.	5/1/2014		False	6/1/2014
FO-280279	001-EXF-019C	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Checked the fan. Checked the operation of the unit. Cleaned the surrounding area.	5/1/2014		False	6/1/2014
FO-280280	001-EXF-020	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed access door. Checked condition of fan and motor. Test ran. Checked for noise and vibration. Closed access door and returned to service.	5/1/2014		False	5/24/2014
FO-280281	001-EXF-021	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280282	001-RAF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280283	090-ACU-1305	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280284	090-ACU-1310	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280285	090-ACU-1320	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280286	090-ACU-1325	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/5/2014
FO-280287	090-ACU-1330.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/5/2014
FO-280288	090-ACU-1330.2	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/5/2014
FO-280289	090-ACU-1336	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/6/2014
FO-280290	090-ACU-1338	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/6/2014
FO-280291	090-ACU-1342	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/6/2014
FO-280292	090-ACU-1344	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/7/2014
FO-280293	090-ACU-1348	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/7/2014
FO-280294	090-ACU-1350	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/7/2014
FO-280295	090-ACU-1353	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/8/2014
FO-280296	090-ACU-1354	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/8/2014
FO-280297	090-ACU-1355	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/8/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280298	090-ACU-1356	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/9/2014
FO-280299	090-ACU-1359	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/8/2014
FO-280300	090-ACU-1360	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/9/2014
FO-280301	090-ACU-1361	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/9/2014
FO-280302	090-ACU-1405	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/9/2014
FO-280303	090-ACU-2310	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280304	090-ACU-2311	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280305	090-ACU-2316	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280306	090-ACU-2319.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280307	090-ACU-2319.2	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/14/2014
FO-280308	090-ACU-2330	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/16/2014
FO-280309	090-ACU-2332	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/16/2014
FO-280310	090-ACU-2335	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/16/2014
FO-280311	090-ACU-2336	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/17/2014
FO-280312	090-ACU-2342	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/20/2014
FO-280313	090-ACU-2348	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/20/2014
FO-280314	090-ACU-2359	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/20/2014
FO-280315	090-ACU-2360	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/21/2014
FO-280316	090-ACU-2404	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/21/2014
FO-280317	090-ACU-2405	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/21/2014
FO-280318	090-ACU-2410	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/22/2014
FO-280319	090-ACU-0315.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280320	090-ACU-0315.2	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280321	090-ACU-0320	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280321	090-ACU-0320	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280322	090-ACU-0320.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280323	090-ACU-0320.2	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280324	090-ACU-0324	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280325	090-ACU-0325	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/1/2014
FO-280326	090-ACU-0327	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280327	090-ACU-0330	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280328	090-ACU-3310	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/22/2014
FO-280329	090-ACU-3317	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/22/2014
FO-280330	090-ACU-3321	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/22/2014
FO-280331	090-ACU-3325	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/23/2014
FO-280332	090-ACU-3330	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/23/2014
FO-280333	090-ACU-3335	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/23/2014
FO-280334	090-ACU-3340	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/24/2014
FO-280335	090-ACU-3350	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/24/2014
FO-280336	090-ACU-3354	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/24/2014
FO-280337	090-ACU-3355	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280338	090-ACU-3359	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/13/2014
FO-280339	090-ACU-3359.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/14/2014
FO-280340	090-ACU-3360	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/14/2014
FO-280341	023-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280343	001-EXF-005-6	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Opened access door. Cleaned interior. Checked fire damper. Replaced belt(4L360). Closed up access doors. Returned to service. Checked for noise and vibration	5/1/2014		False	5/29/2014
FO-280344	001-EXF-006	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280345	001-EXF-018	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	

Request		% Finished		Requested	Open	WND	Finished
FO-280346	001-EXF-EF1D	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down and locked out fan. Opened access door. Cleaned interior. Checked fire damper. Checked belt. Closed up access doors. Returned to service. Checked for noise and vibration	5/1/2014		False	5/29/2014
FO-280347	001-EXF-007-2	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280348	090-ACU-0331	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/2/2014
FO-280349	603-EXF-001-B-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #1bLubricate fan and motor bearingsLubricate dampers and linkagesCheck belts and sheaves for wearClean up around fan housing	5/1/2014		False	5/31/2014
FO-280350	603-EXF-002-A-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #2aLubricate fan and motor bearingsLubricate linkages and dampersCheck sheaves and belts for wearClean up around fan housing	5/1/2014		False	5/31/2014
FO-280351	603-EXF-003-B-P	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Derrick Allen-pm ex-fan #3bLubricate fan and motor bearingsLubricate linkages and dampersCheck belts and sheaves for wearClean up around fan housing	5/1/2014		False	5/31/2014
FO-280352	603-EXF-017	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280353	603-EXF-018	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280354	001-EXF-022A	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280355	001-EXF-022B	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280356	048-AHU-001	Final Filter Replacement (18 MONTH FIXED INTERVAL)	Kumash Shah-Checked the final bags. It appears that it may last couple of months more. Checked the coils. (Heating and Cooling. Appears to be O.K. Cleaned air intake fresh air plenum. Lubricated supply fan motor, return fan motor, relief damper, intake damper and return air dampers. Cleaned surrounding area. Checked the belts and belts tension. Start/stop supply fan and return fan. Checked operation of VFDs.	5/1/2014		False	6/1/2014
FO-280357	048-AHU-002	Final Filter Replacement (18 MONTH FIXED INTERVAL)	Kumash Shah-Checked the final bags. It appears that it may last couple of months more. Checked the coils. (Heating and Cooling. Appears to be O.K. Cleaned air intake fresh air plenum. Lubricated supply fan motor, return fan motor, relief damper, intake damper and return air dampers. Cleaned surrounding area. Checked the belts and belts tension. Start/stop supply fan and return fan. Checked operation of VFDs.	5/1/2014		False	6/1/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280358	048-AHU-003	Final Filter Replacement (18 MONTH FIXED INTERVAL)	Kumash Shah-Checked the final bags. It appears that it may last couple of months more. Checked the coils. (Heating and Cooling). Appears to be O.K. Cleaned air intake fresh air plenum. Lubricated supply fan motor, return fan motor, relief damper, intake damper and return air dampers. Cleaned surrounding area. Checked the belts and belts tension. Start/stop supply fan and return fan. Checked operation of VFDs.	5/1/2014		False	6/1/2014
FO-280359	048-SF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280360	048-SF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280361	048-EXF-001	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280362	048-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280363	048-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280364	049-EXF-008	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-No Access.	5/1/2014		False	5/26/2014
FO-280365	049-EXF-007	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet.	5/1/2014		False	5/26/2014
FO-280366	049-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet. Replaced belt. Qty (1)	5/1/2014		False	5/26/2014
FO-280367	049-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet.	5/1/2014		False	5/26/2014
FO-280368	049-EXF-003	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet.	5/1/2014		False	5/26/2014
FO-280369	049-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet.	5/1/2014		False	5/26/2014
FO-280369	049-EXF-002	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Kumash Shah-Performed pm as per PM specification sheet.	5/1/2014		False	5/26/2014
FO-280370	090-ACU-1410	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/12/2014
FO-280371	090-ACU-2305.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/12/2014
FO-280372	090-ACU-2326	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/15/2014
FO-280373	090-ACU-2327	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/15/2014
FO-280374	090-ACU-3337	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/24/2014
FO-280375	090-ACU-2322.1	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/14/2014
FO-280376	090-ACU-2322.2	PM - Air Handling Unit, HV Type	Timothy Bowman-checked belt, changed filters.	5/1/2014		False	5/14/2014
FO-280377	049-EXF-009	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	

Request		% Finished		Requested	Open	WND	Finished
FO-280378	049-EXF-010	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280379	049-EXF-011	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan		5/1/2014		False	
FO-280380	046-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire pump and jockey pump ,greased were nessary called PS , system back in service.	5/1/2014		False	5/23/2014
FO-280381	048-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught- Tested the panel and pull station ,called PS reset the system ,back in service.	5/1/2014		False	5/15/2014
FO-280382	049-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested system and pull station called PS, put system back in service.	5/1/2014		False	5/23/2014
FO-280383	156-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing.	5/1/2014		False	5/5/2014
FO-280384	499-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/6/2014
FO-280385	620-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the panel called PS ,checked pull station back in service.	5/1/2014		False	5/22/2014
FO-280386	036-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/22/2014
FO-280387	025-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pressure tested fire pump and jocket pump. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/6/2014
FO-280388	007-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.	5/1/2014		False	5/29/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280389	001-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/21/2014
FO-280390	005-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.	5/1/2014		False	5/29/2014
FO-280391	040-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/8/2014
FO-280392	038-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/8/2014
FO-280393	028-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing.	5/1/2014		False	5/1/2014
FO-280394	026-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/1/2014
FO-280395	022-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/1/2014
FO-280396	017-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire panel and pullstation, called PS reset and put it back in service.	5/1/2014		False	5/15/2014
FO-280397	016-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/1/2014
FO-280398	003-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.	5/1/2014		False	5/29/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280399	006-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.	5/1/2014		False	5/29/2014
FO-280400	050-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested pull station , called PS put system back in service.	5/1/2014		False	5/23/2014
FO-280401	043-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/13/2014
FO-280402	042-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/8/2014
FO-280403	062-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire pump and the jockey pump ,called PS reset the system ,back in service. Greased the bearing as needed.	5/1/2014		False	5/16/2014
FO-280404	065-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested fire pump and jockey pump , called PS put system back in service.	5/1/2014		False	5/23/2014
FO-280405	068-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280406	067-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested nthe fire pump and the jockey pump , called PS and got reset , system in service.	5/1/2014		False	5/22/2014
FO-280407	089-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Morris Mims-Conducted monthly fire system test.	5/1/2014		False	5/29/2014
FO-280408	082-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/5/2014
FO-280409	080-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/6/2014
FO-280410	090-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test	5/1/2014		False	5/30/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280411	155-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/6/2014
FO-280412	150-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/5/2014
FO-280413	167-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test	5/1/2014		False	5/31/2014
FO-280414	166-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Timothy Bowman-ran fire alarm test	5/1/2014		False	5/31/2014
FO-280415	140-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire panel called PS ,reset ,system back in service.	5/1/2014		False	5/8/2014
FO-280416	130-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire pump and the jockey pump, called PS got reset ,greased where needed , system back in service.	5/1/2014		False	5/16/2014
FO-280417	193-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire panel called PS reset ,system back in service	5/1/2014		False	5/8/2014
FO-280418	189-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.	5/1/2014		False	5/5/2014
FO-280419	510-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280420	509-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught- tested the fire panel called PS reset the system.	5/1/2014		False	5/8/2014
FO-280421	504-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Pefromed fire alarm test. Pulled pull station. Reset O.K at public safety. Copied reading in PM report and report given back to Ms. Carol D for further processing	5/1/2014		False	5/5/2014
FO-280422	629-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280423	611-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280424	609-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280425	603-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	

Request		% Finished		Requested	Open	WND	Finished
FO-280426	608-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test		5/1/2014		False	
FO-280427	603-AHU-005	Replace PRE-filters	Derrick Allen-pm ahu #5 pharmacy bldg. #603 lubricate fan and motor bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/24/2014
FO-280428	603-AHU-004	Replace PRE-filters	Derrick Allen-pm ahu #4 pharmacy bldg. #603 lubricate fan and motor bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/24/2014
FO-280429	603-AHU-003	Replace PRE-filters	Derrick Allen-pm ahu #3 pharmacy bldg. #603 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/23/2014
FO-280430	603-AHU-002	Replace PRE-filters	Derrick Allen-pm ahu #2 pharmacy bldg. #603 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/23/2014
FO-280431	603-AHU-001	Replace PRE-filters	Derrick Allen-pm ahu #1 pharmacy bldg #603 lubricate motor and fan bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/23/2014
FO-280432	629-EXF-011A	Replace PRE-filters	Derrick Allen-pm ex-fan #11a elliman bldg. #629 lubricate motor and fan bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/25/2014
FO-280433	629-AHU-003	Replace PRE-filters	Derrick Allen-pm ahu #3 elliman bldg. #629 lubricate fan and motor bearings lubricate linkages and dampers change dirty filters dispose of dirty filters inspect belts and sheaves clean up around fan housing	5/1/2014		False	5/25/2014

Request				% Finished	Requested	Open	WND	Finished
FO-280434	629-AHU-002	Replace PRE-filters	Derrick Allen-pm ahu #2 elliman bldg. #629 Lubricate fan and motor bearings Lubricate dampers and linkages Change dirty filters Dispose of dirty filters Clean up around fan housing		5/1/2014		False	5/25/2014
FO-280435	629-AHU-001	Replace PRE-filters	Derrick Allen-pm ahu #1 elliman bldg. #629 Lubricate motor and fan bearings Lubricate dampers and linkages Change dirty filters Dispose of dirty filters Clean up around fan housing		5/1/2014		False	5/25/2014
FO-280436	074-FAP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Frank Vaught-Tested the fire panel and the pull station , called PS got reset back on line.		5/1/2014		False	5/16/2014
FO-280437	629-EXF-011B	Replace PRE-filters	Derrick Allen-pm ex-fan #11b elliman bldg. #629 Lubricate motor and fan bearings Lubricate linkages and dampers Change dirty filters Dispose of dirty filters Clean up around fan housing		5/1/2014		False	5/25/2014
FO-280438	016-FCU-001	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/6/2014
FO-280439	016-FCU-002	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/6/2014
FO-280440	016-FCU-003	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/6/2014
FO-280441	016-FCU-004	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/7/2014
FO-280442	016-FCU-005	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/7/2014
FO-280443	016-FCU-006	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/7/2014
FO-280444	016-HVU-001	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/7/2014
FO-280445	016-HVU-002	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/8/2014

Request				% Finished	Requested	Open	WND	Finished
FO-280446	016-HVU-003	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/8/2014
FO-280447	016-HVU-004	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/9/2014
FO-280448	016-HVU-005	PM - Fan Coil/HV/AC Unit	Roman Wojtowicz-Shut down unit. Checked fan and motor Inspected coil, valves, and piping. Changed filters. Cleaned interior. Replaced cover and returned to service.		5/1/2014		False	5/9/2014
FO-280449	090-AHU-548	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/9/2014
FO-280450	090-AHU-547	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/8/2014
FO-280451	090-AHU-546	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/24/2014
FO-280452	090-AHU-545	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/23/2014
FO-280453	090-AHU-544	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/22/2014
FO-280454	090-AHU-543	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/21/2014
FO-280455	090-AHU-542	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/21/2014
FO-280456	090-AHU-541	Replace PRE-filters	Timothy Bowman-changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/20/2014
FO-280457	090-AHU-003	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/20/2014
FO-280458	090-AHU-002	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/17/2014
FO-280459	090-AHU-001	Replace PRE-filters	Timothy Bowman-checked belt, changed filters.		5/1/2014		False	5/15/2014
FO-280460	090-HVU-004	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/17/2014
FO-280461	090-HVU-003	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/15/2014
FO-280462	090-HVU-002	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/14/2014
FO-280463	090-HVU-001	Replace PRE-filters	Timothy Bowman-adjusted belts, changed filters, greased and lubricated bearing and dampers.		5/1/2014		False	5/13/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280464	603-EXF-011	Replace PRE-filters	Derrick Allen-pm ex-fan #11 pharmacy bldg. #603 Lubricate fan and motor bearings ☐ check belts and sheave for wear and alignment Clean up around fan	5/1/2014		False	5/27/2014
FO-280465	049-AHU-005	Replace PRE-filters	Edward Nisnevich-Delivered filters to mechanical room,replaced filters-filter rack is not aligned properly, had to take side panel off to correctly replaced filters,after replacement put side panel back,grease fan and motor bearings,checked belts,lubricated dampers,verified open and close damper positions.	5/1/2014		False	5/29/2014
FO-280466	049-AHU-004	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual.☐checked return fan operation Auto/Manual.☐Shutdown of the fan through honey well computer.☐Replaced pre-filters.☐Lubricated motor and fan bearing.☐Lubricated supply and return fan dampers.☐Lubricated damper motors.☐checked belts and belts tension.☐cleaned surrounding area.☐Boxed dirty filter and disposed of dirty filters.☐checked the units for vibration.☐checked the units for dirty coil.☐laced the supply fan/return fan back in service	5/1/2014		False	5/25/2014
FO-280467	049-AHU-003	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual.☐checked return fan operation Auto/Manual.☐Shutdown of the fan through honey well computer.☐Replaced pre-filters.☐Lubricated motor and fan bearing.☐Lubricated supply and return fan dampers.☐Lubricated damper motors.☐checked belts and belts tension.☐cleaned surrounding area.☐Boxed dirty filter and disposed of dirty filters.☐checked the units for vibration.☐checked the units for dirty coil.☐laced the supply fan/return fan back in service	5/1/2014		False	5/25/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280468	049-AHU-002	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual. Checked return fan operation Auto/Manual. Shutdown of the fan through honey well computer. Replaced pre-filters. Lubricated motor and fan bearing. Lubricated supply and return fan dampers. Lubricated damper motors. Checked belts and belts tension. Cleaned surrounding area. Boxed dirty filter and disposed of dirty filters. Checked the units for vibration. Checked the units for dirty coil. Placed the supply fan/return fan back in service.	5/1/2014		False	5/25/2014
FO-280469	049-AHU-001	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual. Checked return fan operation Auto/Manual. Shutdown of the fan through Honey well computer. Replaced pre-filters. Lubricated motor and fan bearing. Lubricated supply and return fan dampers. Lubricated damper motors. Checked belts and belts tension. Cleaned surrounding area. Boxed dirty filter and disposed of dirty filters. Checked the units Supply/Return fan for noise and vibration. Fan back in service.	5/1/2014		False	5/25/2014
FO-280470	203-AHU-003	Replace PRE-filters	Michael Fitzgerald-check belt- tension wear and alignment lubricate fan and motor bearings lubricate dampers and damper motor points change filters (recommend more filter changes due to construction in the area.)	5/1/2014		False	5/24/2014
FO-280471	203-AHU-002	Replace PRE-filters	Michael Fitzgerald-check belt- tension wear and alignment lubricate fan and motor bearings lubricate dampers and damper motor points change filters (recommend more filter changes due to construction in the area.)	5/1/2014		False	5/24/2014
FO-280472	203-AHU-001	Replace PRE-filters	Michael Fitzgerald-check belt- tension wear and alignment lubricate fan and motor bearings lubricate dampers and damper motor points change filters (recommend more filter changes due to construction in the area.)	5/1/2014		False	5/24/2014
FO-280473	203-MAU-001	Replace PRE-filters	Michael Fitzgerald-check belt- tension wear and alignment lubricate fan and motor bearings lubricate dampers and damper motor points change filters (recommend more filter changes due to construction in the area.)	5/1/2014		False	5/24/2014
FO-280474	195-ACU-002	Replace PRE-filters		5/1/2014		False	
FO-280475	060-ACU-001	Replace PRE-filters		5/1/2014		False	5/23/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280476	046-SAF-003	Replace PRE-filters		Coil cleaning required due to incorrect filter size installed during prior filter change.	5/1/2014	False	5/25/2014
FO-280477	016-EXF-005	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed fan guard. Checked fan. Inspected belts. Lubricated fan and motor bearings. Replaced guard. Returned to service.		5/1/2014	False	5/6/2014
FO-280478	016-EXF-004	PM - Fan, Centrifugal: Supply/Return/Exhaust Fan	Roman Wojtowicz-Shut down fan. Removed fan guard. Checked fan. Inspected belts. Lubricated fan and motor bearings. Replaced guard. Returned to service.		5/1/2014	False	5/6/2014
FO-280479	096-FP-001	PM - Monthly Fire Alarm/Fire Protection System Test	Kumash Shah-Performed fire alarm test. Pressure tested jockey pump and main fire pump. Pulled pull station. Reset O.k at public safety. Copied reading to PM report. Report given back to Ms. Carol D for further processing.		5/1/2014	False	5/22/2014
FO-280584	046-AHU-002	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual. Checked return fan operation Auto/Manual. Shutdown of the fan through honey well computer. Replaced pre-filters. Lubricated motor and fan bearing. Lubricated supply and return fan dampers. Lubricated damper motors. Checked belts and belts tension. Cleaned surrounding area. Boxed dirty filter and disposed of dirty filters. Checked the units for vibration. Checked the units for dirty coil. Placed the supply fan/return fan back in service		5/1/2014	False	5/24/2014
FO-280585	046-AHU-001	Replace PRE-filters	Kumash Shah-Checked the supply fan operation Auto/Manual. Checked return fan operation Auto/Manual. Shutdown of the fan through honey well computer. Replaced pre-filters. Lubricated motor and fan bearing. Lubricated supply and return fan dampers. Lubricated damper motors. Checked belts and belts tension. Cleaned surrounding area. Boxed dirty filter and disposed of dirty filters. Checked the units for vibration. Checked the units for dirty coil. Placed the supply fan/return fan back in service		5/1/2014	False	5/25/2014
FO-280586	062-AHU-004	Replace PRE-filters	Edward Nisnevich-Delivered right size of pre-filters to mech.room,changed pre-filters,greased fan and motor bearings,lubricated damper and damper motor points,verified open and closed damper positions, checked belts-needed replacement,informed AD.		5/1/2014	False	5/15/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280587	062-AHU-003	Replace PRE-filters	Edward Nisnevich-Changed pre-filters,checked belts-ok, greased fan and motor bearings,lubricated damper and damper motor points, verified opened and closed damper positions.	5/1/2014		False	5/15/2014
FO-280588	062-AHU-002	Replace PRE-filters	Michael Fitzgerald-check belts- tension wear and alignment lubricate fan and motor bearings change filters cleaning fan housing lubricate dampers and damper motor points cleaning fan room	5/1/2014		False	5/7/2014
FO-280589	062-AHU-001	Replace PRE-filters	Michael Fitzgerald-Checked belts- tension wear and alignment lubricated fan and motor bearings lubricated dampers and damper motor points changed filters cleaning fan housing cleaning fan room brush down fan coil (will need to be acid cleaned soon.	5/1/2014		False	4/16/2014
FO-280690	611-AHU-007**	Replace PRE-filters	Derrick Allen-pm ahu #7 lande bldg. #611 lubricate fan and motor bearings lubricate linkages and dampers check belt and sheaves for wear and alignment change and dispose of dirty filters clean up around fan housing	5/1/2014		False	5/14/2014
FO-280691	611-AHU-006	Replace PRE-filters	Derrick Allen-pm ahu #6 lande bldg. #611 lubricate fan and motor bearings lubricate linkages and dampers check belts and sheaves for wear and alignment change and dispose of dirty filters clean up around fan housing	5/1/2014		False	5/14/2014
FO-280691	611-AHU-006	Replace PRE-filters	Derrick Allen-pm ahu #6 lande bldg. #611 lubricate motor and fan bearings lubricate dampers and linkages check belts and sheaves for wear change and dispose of dirty filters clean up around fan housing	5/1/2014		False	5/14/2014
FO-280692	611-AHU-005	Replace PRE-filters	Derrick Allen-pm ahu # 5 lande bldg. #611 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/10/2014
FO-280693	611-AHU-004	Replace PRE-filters	Derrick Allen-pm ahu # 4 lande bldg.#611 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/8/2014

Request		% Finished		Requested	Open	WND	Finished
FO-280694	611-AHU-003	Replace PRE-filters	Derrick Allen-pm ahu #3 lande bldg. #611 lubricate fan motor bearings lubricate linkages and dampers change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/6/2014
FO-280695	611-AHU-002	Replace PRE-filters	Derrick Allen-pm ahu #2 lande blde #611 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean up around fan housing	5/1/2014		False	5/7/2014
FO-280696	611-AHU-001	Replace PRE-filters	Derrick Allen-pm ahu #2 lande bldg. #611 lubricate motor and fan bearings lubricate dampers and linkages change dirty filters dispose of dirty filters clean around fan housing	5/1/2014		False	5/7/2014
FO-280897	085-ACU-001	PM - Air Handling Unit (ANNUAL)	Edward Nisnevich-Delivered pre-filters to the roof, shut unit down at disconnect, replaced filters, greased fan and motor bearings, checked belts, restarted RTU, disposed dirty filters.	5/1/2014		False	5/29/2014
FO-280897	085-ACU-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down unit. Opened access doors. Cleaned interior. Changed pre-filters. Greased motor and fan bearings. Checked belts. Closed up and returned to service.	5/1/2014		False	5/29/2014
FO-281062	026-AHU-006	Replace PRE-filters		5/1/2014		False	
FO-281063	026-AHU-005	Replace PRE-filters		5/1/2014		False	
FO-281064	026-AHU-004	Replace PRE-filters	Thomas Townsel-Changed filters and checked belts and chivs. Lubricated bearings and cleaned area.	5/1/2014		False	5/16/2014
FO-281065	026-AHU-003	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed filters and pre filters. Checked belts and chivs. Lubricated bearings on fan and motor. Cleaned area and place unit back in services.	5/1/2014		False	5/16/2014
FO-281068	016-FCU-006	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281069	016-FCU-005	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281070	016-FCU-004	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281071	016-FCU-003	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281072	016-FCU-002	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281073	016-FCU-001	Replace PRE-filters		5/1/2014	4/10/2014	True	
FO-281074	016-AHU-005	Replace PRE-filters	Thomas Townsel-Changed filters, checked belts, lubricated bearing, checked coils, and placed unit back in service.	5/1/2014		False	5/13/2014
FO-281075	016-AHU-004	Replace PRE-filters	Thomas Townsel-Changed filters, checked belts, lubricated bearing, checked coils, and placed unit back in service.	5/1/2014		False	5/13/2014

Request				% Finished	Requested	Open	WND	Finished
FO-281076	016-AHU-002	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed filters and prefilters. Checked motor and bearings. Lubricated bearings. Cleaned area and placed unit back in service.		5/1/2014		False	5/5/2014
FO-281077	016-AHU-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Inspected coil, valves, and piping. Changed filters and bags 24x24x2 (25) 12x24x2 (5).Inspected belts. Lubricated fan and motor bearings. Inspected fan. Checked drip pan. Checked controls for leaks. Cleaned interior. Closed up access doors and returned to service. Disposed of old filters and cleaned arera.		5/1/2014		False	5/7/2014
FO-281078	028-SAF-006	Replace PRE-filters	Roman Wojtowicz-Replaced filter. Cleaned equipment and area		5/1/2014		False	5/14/2014
FO-281079	028-SAF-005	Replace PRE-filters	Roman Wojtowicz-Replaced filter. Cleaned equipment and area		5/1/2014		False	5/14/2014
FO-281080	028-SAF-004	Replace PRE-filters	Roman Wojtowicz-Replaced filter. Cleaned equipment and area		5/1/2014		False	5/14/2014
FO-281081	028-SAF-003	Replace PRE-filters	Roman Wojtowicz-Replaced filter. Cleaned equipment and area		5/1/2014		False	5/14/2014
FO-281082	028-SAF-002	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out fan unit. Opened access doors. Cleaned interior. Lubricated and exercised dampers. Cleaned fresh air inlet screen. Changed filters. Lubricated fan and motor bearings. Changed belt (A-66). Closed up unit and returned to service. Disposed of old filters and cleand area.		5/1/2014		False	5/14/2014
FO-281083	028-SAF-001	Replace PRE-filters	Roman Wojtowicz-Shut down and locked out fan unit. Opened access doors. Cleaned interior. Lubricated and exercised dampers. Cleaned fresh air inlet screen. Changed filters. Lubricated fan and motor bearings. Changed belt (A-66). Closed up unit and returned to service. Disposed of old filters and cleand area.		5/1/2014		False	5/14/2014
FO-281086	027-SAF-002	Replace PRE-filters			5/1/2014		False	
FO-281087	022-HVU-002	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out fan. Checked condition of fan and motor. Checked coil, valves, and piping. Inspected belts. Changed filters. Lubricated motor. Placed back in service. Cleaned area.		5/1/2014		False	5/20/2014
FO-281089	022-AHU-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out fan. Checked condition of fan and motor. Checked coil, valves, and piping. Changed filters. Lubricated motor. Placed back in service. Cleaned area.		5/1/2014		False	5/20/2014
FO-281192	023-AHU-003	Replace PRE-filters	Thomas Townsel-Changed pre filters, checked belts, and lubricaed bearings. Cleaned area.		5/1/2014		False	5/6/2014

Request		% Finished		Requested	Open	WND	Finished
FO-281193	023-AHU-002	Replace PRE-filters	Thomas Townsel-Changed pre filters, checked belts, and lubricaed bearings. Cleaned area.	5/1/2014		False	5/6/2014
FO-281194	023-AHU-001	Replace PRE-filters	Thomas Townsel-Changed pre filters, checked belts, and lubricaed bearings. Cleaned area.	5/1/2014		False	5/6/2014
FO-281195	022-SAF-001	PM - Air Handling Unit (ANNUAL)	Roman Wojtowicz-Shut down and locked out unit. Opened access doors. Cleaned interior. Checked condition of coil, valves, and piping. Replaced pre and bag filters 24x24x2 (40). Lubricated fan and motor bearings. Checked condition of belt. Checked drip pan. Lubricated and exercised dampers. Closed unit up and returned to service. Disposed of old filters and cleaned area.	5/1/2014		False	5/17/2014
FO-281196	027-SAF-001	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-281306	036-RTU-001	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-281307	036-ACU-001	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-281308	036-SAF-001	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed filters, lubricated fan and motor bearings, checked belts, and cleaned area.	5/1/2014		False	5/27/2014
FO-281309	036-AHU-002	PM - Air Handling Unit (ANNUAL)	Thomas Townsel-Changed filters, lubricated fan and motor bearings, checked belts, and cleaned area.	5/1/2014		False	5/27/2014
FO-281310	036-AHU-003	Replace PRE-filters		5/1/2014		False	
FO-281311	082-AHU-002	PM - Air Handling Unit (ANNUAL)	Scott Sharp-Inspect belts , greased bearings, dampers, changed all filters,and lubed RFU.	5/1/2014		False	5/31/2014
FO-281312	082-AHU-001	PM - Air Handling Unit (ANNUAL)	Scott Sharp- Inspect belts , greased bearings, dampers, changed all filters,and lubed RFU.	5/1/2014		False	5/31/2014
FO-282247	048-AHU-003	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-282248	048-AHU-002	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-282249	048-AHU-001	PM - Air Handling Unit (ANNUAL)		5/1/2014		False	
FO-282250	048-SF-002	PM - Air Handling Unit, HV Type		5/1/2014		False	
FO-282251	048-SF-001	PM - Air Handling Unit, HV Type		5/1/2014		False	
FO-281066	026-AHU-002	Replace PRE-filters	Thomas Townsel-Checked belts, lubricated bearings (fan and motor), and changed filters.	5/1/2014		False	5/27/2014
FO-281066	026-AHU-002	Replace PRE-filters	Thomas Townsel-Changed filters, lubricated fan and motor bearings, checked belts, and cleaned area.	5/1/2014		False	5/27/2014
FO-281067	026-AHU-001	Replace PRE-filters	Thomas Townsel-Changed filters, lubricated fan and motor bearings, checked belts, and cleaned area.	5/1/2014		False	5/28/2014
FO-281639	074-AHU-003	PM - Air Handling Unit, HV Type		5/13/2014	5/14/2014	True	
FO-282252	001-FCU-001ANTH	PM - Fan Coil/HV/AC Unit		5/21/2014		False	

Request				% Finished	Requested	Open	WND	Finished
FO-282253	001-FCU-001CASS	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282254	001-FCU-001COR	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282255	001-FCU-001LOBB	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filter, cleaned unit, and checked operation.		5/21/2014		False	5/31/2014
FO-282256	001-FCU-001LOOM	PM - Fan Coil/HV/AC Unit			5/21/2014		False	
FO-282257	001-FCU-001WARR	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282258	001-FCU-002ANTH	PM - Fan Coil/HV/AC Unit			5/21/2014		False	
FO-282259	001-FCU-002CASS	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282260	001-FCU-002COR	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282261	001-FCU-002LOBB	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014
FO-282262	001-FCU-002LOOM	PM - Fan Coil/HV/AC Unit			5/21/2014		False	
FO-282263	001-FCU-002WARR	PM - Fan Coil/HV/AC Unit	Kumash Shah-checked the unit for heating and cooling. Replaced the filter. Cleaned the surrounding area. Start/stop the unit. Cleaned inside of filter area. Disposed of dirty filter. Unit back in service.		5/21/2014		False	6/1/2014

Request				% Finished	Requested	Open	WND	Finished
FO-280942	001-FMB-0014	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280943	001-FMB-0029	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280944	001-FMB-0030	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280945	001-FMB-0402-2	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280946	001-FMB-0402-1	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280947	001-FMB-0428	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280948	001-FMB-0429	PM - Fan Motor Box (Old Main)	Roman Wojtowicz-Shut down unit. Accessed with ladder. Changed filter. Lubricated motor. Cleaned interior. Test ran and returned to service.		5/7/2014		False	5/31/2014
FO-280949	001-FMB-1410	PM - Fan Motor Box (Old Main)			5/7/2014		False	
FO-280950	001-FMB-1412	PM - Fan Motor Box (Old Main)			5/7/2014		False	
FO-280951	001-FMB-1415	PM - Fan Motor Box (Old Main)			5/7/2014		False	
FO-281640	130-HVU-002	PM - Air Handling Unit, HV Type			5/10/2014	5/2/2014	False	
FO-281641	130-HVU-001	PM - Air Handling Unit, HV Type			5/10/2014	5/2/2014	False	
FO-282772	001-FCU-3103-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.		5/28/2014		False	5/29/2014
FO-282773	001-FCU-3103-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.		5/28/2014		False	5/29/2014
FO-282774	001-FCU-3103-3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Change filter and checked operation.		5/28/2014		False	5/29/2014
FO-282775	001-FCU-3103-4	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282776	001-FCU-3103-5	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282777	001-FCU-3103-6	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282778	001-FCU-3103-7	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282779	001-FCU-3103-8	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014

Request				% Finished	Requested	Open	WND	Finished
FO-282780	001-FCU-3107-1	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282781	001-FCU-3107-2	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282782	001-FCU-3107-3	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282783	001-FCU-3107-4	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
FO-282784	001-FCU-3107-5	PM - Fan Coil/HV/AC Unit	Thomas Townsel-Changed filters and checked operation.		5/28/2014		False	5/30/2014
E - South				100%	52	0	0	52
FO-282747	007-GEN-001	Generator Maintenance, Monthly	Dennis Paul-Completed the PM		5/8/2014		False	5/8/2014
FO-282749	007-GEN-002	Generator Maintenance, Monthly	Dennis Paul-Completed the PM		5/8/2014		False	5/8/2014
FO-282756	090-GEN-002	Generator Maintenance, Monthly	Robert McPherson-Check all fluid levels, belts.		5/8/2014		False	5/8/2014
FO-282760	090-CRP-001	PM - Condensate Return Pump	Robert McPherson-Grease bearings check ops.		5/10/2014		False	5/14/2014
FO-282761	090-CRP-002	PM - Condensate Return Pump			5/10/2014		False	5/14/2014
FO-282762	090-CRP-003	PM - Condensate Return Pump			5/10/2014		False	5/14/2014
FO-282763	090-CRP-004	PM - Condensate Return Pump	Robert McPherson-Grease bearings and check ops.		5/10/2014		False	5/14/2014
FO-282764	090-CRP-005	PM - Condensate Return Pump			5/10/2014		False	5/14/2014
FO-282765	090-CRP-006	PM - Condensate Return Pump	Robert McPherson-Grease bearings check ops.		5/10/2014		False	5/14/2014
FO-282766	090-CRP-007	PM - Condensate Return Pump	Robert McPherson-gREASE BEarings and check ops.		5/10/2014		False	5/14/2014
FO-282767	090-CRP-008	PM - Condensate Return Pump	Robert McPherson-Grease bearings check ops		5/10/2014		False	5/14/2014
FO-282164	089-WSS-001	PM - Water Softener	Darnell Smiley-Inspected tank,check float control,check.piping,vavles,fittings,check fill vavle,and cleaned around tank area.		5/2/2014		False	5/2/2014
FO-282999	090-GEN-001	Generator Maintenance, Monthly	Robert McPherson-Check all fluid levels, add 2 quarts of oil, check battery.		5/20/2014		False	5/20/2014
FO-283001	089-GEN-001	Generator Maintenance, Monthly	Darnell Smiley-checked oil level full,check fuel level 3/4 full. check antifreeze level normal, and battery level all ports are full.		5/21/2014		False	5/21/2014
FO-283198	089-GEN-002	Generator Maintenance, Monthly	Darnell Smiley-checked oil level full,;checkfuel level 3/4 full,check antifreeze normal,check battery all ports full.completed test with electrians.		5/21/2014		False	5/21/2014
FO-282745	090-ACU-CR2	Monthly AHU Inspection Clean Room Unit 2	Robert McPherson-Check filters and belt, check ops.		5/8/2014		False	5/16/2014
FO-283037	006-GEN-001	Generator Maintenance, Monthly	Dennis Paul-Completed the PM		5/22/2014		False	5/22/2014
FO-282768	090-CRP-541	PM - Condensate Return Pump	Robert McPherson-Check operation.		5/10/2014		False	5/14/2014
FO-283383	090-DWBP-002	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Guardian Plumbing is here today and rebuilding this pump so I did not do any PM's this month on it.		5/15/2014		False	5/20/2014

Request		% Finished		Requested	Open	WND	Finished
FO-283327	089-VP-001**	PM - Vacuum Pump	Darnell Smiley-This pump is out if service right now.	5/16/2014		False	5/16/2014
FO-283328	089-VP-002**	PM - Vacuum Pump	Darnell Smiley-Lubracated pump, checked coupling,cleared drain line,this pump is the only pump online right now and has very bad seals and water shoots out of seals.	5/16/2014		False	5/16/2014
FO-282165	089-AIR-001	PM - Air Compressor, Reciprocating 5-40 H.P.	Darnell Smiley-completed pm task on compressor, changed oil,checked belt,cleaned compressor, and around area.pm,s completed.	5/1/2014		False	5/1/2014
FO-282165	089-AIR-001	PM - Air Compressor, Reciprocating 5-40 H.P.	Darnell Smiley-completed task of pm,s.changed oil, checked belts,cleaned compressor,cleaned around area,all pms completed.	5/1/2014		False	5/1/2014
FO-282166	016-AIR-002	PM - Air Compressor, Reciprocating 5-40 H.P.		Checked the unit operation. Checked air filter, it was clean, checked oil level, checked belts, cleaned the unit. Also checked air dryer operation, cleaned its coil and drained the moisture separator.oil and oil filter and air filter on this compressor was changed on 3-13-14 and didn't need to be done again at this time.	5/1/2014	False	5/22/2014
FO-282168	089-AIR-002	PM - Air Compressor, Reciprocating 5-40 H.P.	Darnell Smiley-Completed task of PM,S ON COMPRESSOR.Cleaned compressor and area ,changed oil,checked belts,completed all pms.	5/1/2014		False	5/1/2014
FO-282168	089-AIR-002	PM - Air Compressor, Reciprocating 5-40 H.P.	Darnell Smiley-completed task of pms on compressor.Change oil check level,checked belts,filters ok,cleaned compressor,and cleaned around area,all pms completed.	5/1/2014		False	5/1/2014
FO-282192	016-AIR-003	PM - Air Compressor, Reciprocating 5-40 H.P.		Checked operation of the unit, checked air filter it was clean, did not change the oil at this time because it was done on 2-19-14. Cleaned the air dryer and drained it's moisture separator. cleaned the unit.	5/1/2014	False	5/23/2014
FO-282746	090-ACU-CR1	PM - Monthly AHU Inspection Clean Room Unit 1	Robert McPherson-Check filters, tighten belt, check ops.	5/8/2014		False	5/16/2014
FO-282720	090-SP-002	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-check ops.	5/10/2014		False	5/20/2014
FO-282721	090-SP-003	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Check ops.	5/10/2014		False	5/20/2014
FO-282722	090-SP-004	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-Check ops.	5/10/2014		False	5/20/2014
FO-282723	090-SP-006	PM - Centrifugal Pump, over 1 H.P.	Robert McPherson-check ops.	5/10/2014		False	5/20/2014
FO-283329	005-HWP-001	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283330	006-HWP-003	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283331	005-SUP-002	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283332	005-SUP-003	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283333	005-SUP-004	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Pump out of Service, being replaced	5/18/2014		False	5/19/2014
FO-283334	005-SUP-005	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283335	006-SUP-001	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283336	006-SUP-002	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Pump is a submerged type pump, did housekeeping	5/18/2014		False	5/19/2014

Request		% Finished		Requested	Open	WND	Finished
FO-283337	006-SUP-003	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Pump is a submerged type pump, did the housekeeping	5/18/2014		False	5/19/2014
FO-283338	006-SUP-004	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283339	006-SUP-005	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Pump is the submerged type pump, did the housekeeping	5/18/2014		False	5/19/2014
FO-283340	006-SUP-006	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM, found the coupling guard missing and could not locate it	5/18/2014		False	5/19/2014
FO-283341	006-VPS-001	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Lubed the motor and did some housekeeping, pumps have been out of service for years.	5/18/2014		False	5/19/2014
FO-283342	006-VPS-002	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Lubed the motor,checked oil in pump and did some housekeeping. Pumps have been out of service for years.	5/18/2014		False	5/19/2014
FO-283343	006-DWBP-001	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283344	006-DWBP-002	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM, but a work order was requested to determine why the motor will not turn over.	5/18/2014		False	5/19/2014
FO-283345	005-CRP-001	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283346	005-CRP-002	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283347	005-CRP-003	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
FO-283348	005-CRP-004	PM - Centrifugal Pump, over 1 H.P.	Dennis Paul-Completed the PM	5/18/2014		False	5/19/2014
E - Southeast		98%		98	2	0	96
FO-283020	637-GEN-001	Generator Maintenance, Monthly	checked belts fluids and battery	5/20/2014		False	5/29/2014
FO-283022	637-GEN-002	Generator Maintenance, Monthly	checked belts fluids and battery	5/20/2014		False	5/29/2014
FO-283378	499-CFP-001	PM - Chemical Feed/Metering Pump/Controller	checked pump operation	5/15/2014		False	5/29/2014
FO-283379	499-CFP-002	PM - Chemical Feed/Metering Pump/Controller	checked pump operation	5/15/2014		False	5/29/2014
FO-283380	499-CFP-003	PM - Chemical Feed/Metering Pump/Controller	checked pump operation	5/15/2014		False	5/29/2014
FO-283381	499-CFP-004	PM - Chemical Feed/Metering Pump/Controller	checked pump operation	5/15/2014		False	5/29/2014
FO-282724	071-UNH-001	PM - Unit/Space Heater	William Willard-Completed the pm per the tasking sheet pm.	5/9/2014		False	5/12/2014
FO-282725	071-UNH-002	PM - Unit/Space Heater	William Willard-Finished the pm per the pm tasking sheet.	5/9/2014		False	5/12/2014
FO-282726	071-UNH-003	PM - Unit/Space Heater	William Willard-Finished the pm per the tasking pm sheet	5/9/2014		False	5/12/2014
FO-282188	071-HWP-206	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/6/2014		False	5/7/2014
FO-282189	071-HWP-207	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/6/2014		False	5/7/2014
FO-282190	071-HWP-208	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/6/2014		False	5/7/2014
FO-282191	071-HWP-209	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet	5/6/2014		False	5/7/2014

Request		% Finished		Requested	Open	WND	Finished
FO-282727	071-HWP-081	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/7/2014		False	5/12/2014
FO-282728	071-HWP-082	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/7/2014		False	5/12/2014
FO-282729	071-HWP-083	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/7/2014		False	5/12/2014
FO-282730	071-HWP-084	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/7/2014		False	5/12/2014
FO-282731	071-HWP-085	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/7/2014		False	5/12/2014
FO-282732	071-HWP-086	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/7/2014		False	5/12/2014
FO-282733	071-HWP-087	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/7/2014		False	5/12/2014
FO-282734	071-HWP-088	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/7/2014		False	5/12/2014
FO-282735	071-HWP-089	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/7/2014		False	5/13/2014
FO-282736	071-HWP-090	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/7/2014		False	5/13/2014
FO-282737	071-HWP-091	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the tasking pm sheet.	5/7/2014		False	5/13/2014
FO-282738	071-HWP-092	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/7/2014		False	5/13/2014
FO-282739	071-HWP-093	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/7/2014		False	5/13/2014
FO-282740	071-HWP-094	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/7/2014		False	5/13/2014
FO-282741	071-HWP-095	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/7/2014		False	5/13/2014
FO-282742	071-HWP-096	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/7/2014		False	5/14/2014
FO-282743	071-HWP-097	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/7/2014		False	5/14/2014
FO-282744	071-HWP-098	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/7/2014		False	5/14/2014
FO-282717	022-CRP-001	PM - Condensate Return Pump	Checked the unit for proper operation. Checked for any leaks,noise and overheating. Cleaned the equipment.	5/9/2014		False	5/21/2014
FO-282718	022-CRP-002	PM - Condensate Return Pump	Checked the unit for proper operation. Checked for any leaks,noise,vibration and overheating. Cleaned the equipment.	5/9/2014		False	5/21/2014
FO-283352	071-HWP-063	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet	5/14/2014		False	5/16/2014
FO-283353	071-HWP-064	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/14/2014		False	5/16/2014
FO-283354	071-HWP-065	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/14/2014		False	5/16/2014
FO-283355	071-HWP-066	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/16/2014

Request		% Finished		Requested	Open	WND	Finished
FO-283356	071-HWP-067	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/14/2014		False	5/16/2014
FO-283357	071-HWP-068	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/14/2014		False	5/19/2014
FO-283358	071-HWP-069	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/19/2014
FO-283359	071-HWP-070	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/14/2014		False	5/19/2014
FO-283360	071-HWP-071	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/14/2014		False	5/19/2014
FO-283361	071-HWP-072	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/19/2014
FO-283362	071-HWP-073	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/19/2014
FO-283363	071-HWP-074	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/14/2014		False	5/19/2014
FO-283364	071-HWP-075	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/14/2014		False	5/19/2014
FO-283365	071-HWP-076	PM - Heat Pumps (5057 Woodward)	William Willard-Installed a new heat pump on 5-7-2014.	5/14/2014		False	5/20/2014
FO-283366	071-HWP-077	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/20/2014
FO-283367	071-HWP-078	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/14/2014		False	5/20/2014
FO-283368	071-HWP-079	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/14/2014		False	5/20/2014
FO-283369	071-HWP-080	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/14/2014		False	5/20/2014
FO-283376	001-AHU-001	PM - Steam to Air Handling Unit - Close for Spring (Old Main)		5/15/2014		False	
FO-283377	001-AHU-002	PM - Steam to Air Handling Unit - Close for Spring (Old Main)		5/15/2014		False	
FO-284140	071-HWP-045	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/21/2014		False	5/21/2014
FO-284141	071-HWP-046	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/21/2014		False	5/21/2014
FO-284142	071-HWP-047	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/21/2014		False	5/21/2014
FO-284143	071-HWP-048	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/21/2014		False	5/21/2014
FO-284144	071-HWP-049	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/21/2014		False	5/21/2014
FO-284145	071-HWP-050	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/21/2014		False	5/21/2014
FO-284146	071-HWP-051	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/21/2014		False	5/21/2014
FO-284147	071-HWP-052	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/21/2014		False	5/21/2014
FO-284148	071-HWP-053	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/21/2014		False	5/22/2014

Request		% Finished		Requested	Open	WND	Finished
FO-284149	071-HWP-054	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/21/2014		False	5/22/2014
FO-284150	071-HWP-055	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/21/2014		False	5/22/2014
FO-284151	071-HWP-056	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet	5/21/2014		False	5/22/2014
FO-284152	071-HWP-057	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/21/2014		False	5/22/2014
FO-284153	071-HWP-058	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/21/2014		False	5/22/2014
FO-284154	071-HWP-059	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/21/2014		False	5/22/2014
FO-284155	071-HWP-060	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/21/2014		False	5/22/2014
FO-284156	071-HWP-061	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet	5/21/2014		False	5/22/2014
FO-284157	071-HWP-062	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/21/2014		False	5/22/2014
FO-284774	071-HWP-027	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/28/2014		False	5/28/2014
FO-284775	071-HWP-028	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/28/2014		False	5/28/2014
FO-284776	071-HWP-029	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/28/2014		False	5/28/2014
FO-284777	071-HWP-030	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/28/2014		False	5/28/2014
FO-284778	071-HWP-031	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/28/2014		False	5/28/2014
FO-284779	071-HWP-032	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm	5/28/2014		False	5/28/2014
FO-284780	071-HWP-033	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/28/2014		False	5/28/2014
FO-284781	071-HWP-034	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/28/2014		False	5/28/2014
FO-284782	071-HWP-035	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking sheet pm.	5/28/2014		False	5/28/2014
FO-284783	071-HWP-036	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking pm sheet.	5/28/2014		False	5/28/2014
FO-284784	071-HWP-037	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/28/2014		False	5/28/2014
FO-284785	071-HWP-038	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/28/2014		False	5/27/2014
FO-284786	071-HWP-039	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the pm tasking sheet.	5/28/2014		False	5/27/2014
FO-284787	071-HWP-040	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the tasking pm sheet.	5/28/2014		False	5/27/2014
FO-284788	071-HWP-041	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.	5/28/2014		False	5/27/2014
FO-284789	071-HWP-042	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.	5/28/2014		False	5/27/2014

Request				% Finished	Requested	Open	WND	Finished
FO-284790	071-HWP-043	PM - Heat Pumps (5057 Woodward)	William Willard-Finished the pm per the tasking sheet pm.		5/28/2014		False	5/27/2014
FO-284791	071-HWP-044	PM - Heat Pumps (5057 Woodward)	William Willard-Completed the pm per the pm tasking sheet.		5/28/2014		False	5/27/2014
FO-283370	028-ACU-001	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283371	028-ACU-002	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283372	028-ACU-003	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283373	028-ACU-004	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283374	028-ACU-005	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283375	028-ACU-006	PM - Water/Air Cooled Condenser		Checked operation of the unit, cleaned the condenser coil.	5/15/2014		False	5/29/2014
FO-283349	071-DWBP-001	PM - Centrifugal Pump, over 1 H.P.	William Willard-Completed the pm per the pm tasking sheet.		5/16/2014		False	5/16/2014
FO-283350	071-DWBP-002	PM - Centrifugal Pump, over 1 H.P.	William Willard-Finished the pm per the tasking pm sheet.		5/16/2014		False	5/16/2014
FO-283351	071-DWBP-003	PM - Centrifugal Pump, over 1 H.P.	William Willard-Completed the pm per the tasking sheet pm		5/16/2014		False	5/16/2014
E - West				0%	6	6	0	0
FO-282771	195-GEN-001 SPARE from TechTwn	Generator Maintenance, Monthly			5/13/2014		False	
FO-282169	167-HEX-001	PM - Heat Exchanger and Economizer			5/1/2014		False	
FO-282167	155-CFP-001	PM - Chemical Feed/Metering Pump/Controller			5/2/2014		False	
FO-282719	155-CFP-002	PM - Chemical Feed/Metering Pump/Controller			5/9/2014		False	
FO-283197	169-GEN-001	Generator Maintenance, Monthly			5/22/2014		False	
FO-283326	155-CFP-003	PM - Chemical Feed/Metering Pump/Controller			5/16/2014		False	
Trades				97%	35	1	0	34
T - Electrician				97%	35	1	0	34
FO-282196	608-GEN-001	Generator Test Finished 5/5/2014LT			5/2/2014		False	5/2/2014
FO-282194	193-GEN-001	Generator Test Finished 5/5/2014LT			5/2/2014		False	5/2/2014
FO-282200	193-GEN-002	Generator Test Finished 5/5/2014LT			5/2/2014		False	5/2/2014
FO-282201	193-GEN-003	Generator Test Finished 5/5/2014LT			5/2/2014		False	5/2/2014
FO-282202	193-GEN-004	Generator Test Finished 5/5/2014LT			5/2/2014		False	5/2/2014
FO-282748	007-GEN-001	Generator Test Finished 5/12/2014LT			5/8/2014		False	5/8/2014
FO-282750	007-GEN-002	Generator Test Finished 5/12/2014LT			5/8/2014		False	5/8/2014
FO-282755	090-GEN-002	Generator Test Finished 5/12/2014LT			5/8/2014		False	5/8/2014
FO-282769	048-GEN-001	Generator Test Finished 5/12/2014LT			5/9/2014		False	5/9/2014
FO-282751	612-GEN-001	Generator Test Finished 5/12/2014LT			5/9/2014		False	5/9/2014

Request			% Finished	Requested	Open	WND	Finished
FO-282752	612-GEN-002	Generator Test Finished 5/12/2014LT		5/9/2014		False	5/9/2014
FO-282753	501-GEN-001	Generator Test Finished 5/14/2014LT		5/13/2014		False	5/13/2014
FO-282770	195-GEN-001 SPARE from TechTwn	Generator Test Finished 5/14/2014LT		5/13/2014		False	5/13/2014
FO-283029	536-GEN-001	Generator Test		5/14/2014		False	5/21/2014
FO-283025	507-GEN-001	Generator Test Finished 5/15/2014LT		5/14/2014		False	5/14/2014
FO-283031	527-GEN-001	Generator Test Finished 5/16/2014		5/15/2014		False	5/15/2014
FO-283034	060-GEN-001 (Towable)	Generator Test Finished 5/15/2014LT		5/14/2014		False	5/14/2014
FO-283036	006-GEN-001	Generator Test Finished 5/16/2014		5/15/2014		False	5/15/2014
FO-283000	090-GEN-001	Generator Test Finished 5/22/2014LT		5/20/2014		False	5/20/2014
FO-282998	609-GEN-001	Generator Test Finished 5/22/2014LT		5/20/2014		False	5/20/2014
FO-283019	637-GEN-001	Generator Test Finished 5/22/2014LT		5/20/2014		False	5/20/2014
FO-283021	637-GEN-002	Generator Test Finished 5/22/2014LT		5/20/2014		False	5/20/2014
FO-283027	203-GEN-001	Generator Test Finished 5/22/2014LT		5/20/2014		False	5/20/2014
FO-283002	089-GEN-001	Generator Test		5/21/2014		False	5/21/2014
FO-283199	089-GEN-002	Generator Test		5/21/2014		False	
FO-283196	169-GEN-001	Generator Test, Wednesday 5/28/2014 @ 7:15 AM Finished 5/29/2014LT		5/22/2014		False	5/28/2014
FO-283005	611-GEN-001	Generator Test Finished 5/27/2014		5/23/2014		False	5/23/2014
FO-283007	629-GEN-001	Generator Test Finished 5/27/2014		5/23/2014		False	5/23/2014
FO-283009	104-GEN-001	Generator Test Finished 5/27/2014LT		5/27/2014		False	5/27/2014
FO-283011	127-GEN-001	Generator Test Finished 5/27/2014LT		5/27/2014	5/28/2014	False	5/28/2014
FO-283013	127-GEN-002	Generator Test Finished 5/27/2014LT		5/27/2014		False	5/27/2014
FO-283015	127-GEN-003	Generator Test Finished 5/27/2014LT		5/27/2014		False	5/27/2014
FO-283017	127-GEN-004	Generator Test Finished 5/27/2014LT		5/27/2014		False	5/27/2014
FO-283004	066-GEN-001	Generator Test Finished 5/29/2014LT		5/28/2014		False	5/28/2014
FO-283023	130-GEN-001	Generator Test Finished 5/29/2014LT		5/28/2014		False	5/28/2014
Report Total:				755	190	10	553 73%